

Notice Inviting Written Public Comment

Notice is hereby given that the Air Pollution Control Officer of the Bay Area Air Quality Management District has issued a preliminary Determination of Compliance for application number 1889 for the United Golden Gate Power Plant Phase I, a natural gas fired 51 megawatt peaking power plant to be located at San Francisco International Airport, San Mateo County, California.

The proposed power plant is projected to emit the following maximum quantities of regulated air pollutants:

Nitrogen Oxides	12.7 tons per year
Carbon Monoxide	15.4 tons per year
Particulate Matter (PM ₁₀)	6.1 tons per year
Precursor Organic Compounds	1.4 tons per year
Sulfur Dioxide	2.6 tons per year

The emissions of nitrogen oxides, carbon monoxide, particulate matter (PM₁₀), precursor organic compounds, and sulfur dioxide associated with this project trigger the Best Available Control Technology (BACT) requirement of District Regulation 2-2-301.1.

Pursuant to District Regulation 2-2-407, the Air Pollution Control Officer invites written public comment on the preliminary Determination of Compliance and its intended action.

The preliminary Determination of Compliance is available for public inspection at the Public Information and Education Office located on the 5th floor of District headquarters at 939 Ellis Street, San Francisco CA, 94109. The document is also available on the District website at www.baaqmd.gov. Written comments should be directed to Barry Young, of the District Permit Services Division, by January 30, 2001.

Dated at San Francisco, the 22nd day of December 2000

Ellen Garvey
Executive Officer/Air Pollution Control Officer
Bay Area Air Quality Management District