



BAY AREA
AIR QUALITY
MANAGEMENT
DISTRICT

PUBLIC NOTICE

July 1, 2005

TO: Parents or guardians of children enrolled at the following school:

Windsor High School, Windsor

All residential and business neighbors located within 1,000 feet of the proposed new or modified source of air pollution listed below.

FROM: Bay Area Air Quality Management District

RE: Permit Application for the following source of air pollution:

Emergency Standby Generator Set: Diesel Engine: Volvo; Rated Horsepower: 402 HP
Town of Windsor, 8400 Windsor Road, Windsor, CA 95492

The Bay Area Air Quality Management District (the "District") is a local agency that regulates stationary sources of air pollution such as factories, industrial sites, and gasoline stations.

Whenever we receive a permit application for a new or modified source(s) of toxic air contaminants located within 1,000 feet of a school site, State law requires that we notify the public. To comply with this requirement, we distribute or mail a Public Notice to the parents or guardians of students enrolled at schools located within ¼ mile, and all residents and businesses located within 1,000 feet, of the proposed source(s).

You are receiving this Public Notice because a permit application has been filed with the District for the above referenced source of air pollution. A description of the proposed project follows:

The standby generator set will be located at 8400 Windsor Road, Windsor, California 95492. This equipment will provide emergency power in the event of a blackout for emergency lights, elevators, etc for the building at the above location. This engine must be periodically tested to ensure that it will generate when needed. Testing or maintenance may not be conducted between 7:30 AM and 3:30 PM on days when schools are in session.

The District has determined that the increase in health risks resulting from toxic air contaminant emissions from the proposed source are within acceptable levels, and that the project will comply with all other applicable air pollution control requirements. Accordingly, the District plans to issue an Authority to

Construct/Permit to Operate for the proposed project.

If you are interested in getting more information on the District's evaluation of this proposed project, you may request copies of the applicable staff report(s) by calling the District at the telephone number listed at the end of this notice. This information also can be viewed or downloaded from the District website at:

http://www.baaqmd.gov/pmt/public_notices/2005/index.asp

PUBLIC COMMENT PERIOD

There is a 30-day period for public response to this proposal. If you wish to comment on the proposed project, you may do so in writing or by e-mail. Alternatively, you may call and leave a telephone message up to one minute in length. Please leave your name and telephone number so that a District staff member may respond to your message.

Please use the following contact information if you would like to comment on the proposed project:

Mailing address: Town of Windsor Public Notice Response
BAAQMD
Engineering Division
939 Ellis Street
San Francisco, CA 94109
Attn: Madhav Patil

E-mail address: mpatil@baaqmd.gov

Telephone Number: (415) 749-5076

The public comment period for this project ends on July 30, 2005.