

Notice Inviting Written Public Comment

Notice is hereby given that the Air Pollution Control Officer of the Bay Area Air Quality Management District has issued a preliminary Determination of Compliance for application number 12344 for the San Francisco Electric Reliability Project, a natural gas fired simple cycle power plant to be located at the corner of Maryland and 25th Streets in the city of San Francisco.

The proposed power plant is projected to emit the following maximum quantities of regulated air pollutants:

Nitrogen Oxides	39.8 tons per year
Carbon Monoxide	27.9 tons per year
Particulate Matter (PM ₁₀)	18 tons per year
Precursor Organic Compounds	7.7 tons per year
Sulfur Dioxide	2.7 tons per year

The emissions of nitrogen oxides, carbon monoxide, particulate matter (PM₁₀), precursor organic compounds, and sulfur dioxide associated with this project trigger the Best Available Control Technology (BACT) requirement of District Regulation 2-2-301.1. The emissions of nitrogen oxides and precursor organic compounds associated with this project trigger the emission offset requirements of District Regulation 2-2-302.

Pursuant to District Regulation 2-2-405, the Air Pollution Control Officer invites written public comment on the preliminary Determination of Compliance and its intended action.

The preliminary Determination of Compliance is available for public inspection at the Public Information and Education Office located on the 5th floor of District headquarters at 939 Ellis Street, San Francisco CA, 94109. Written comments should be directed to Bob Nishimura of the District Engineering Division by August 31, 2005.

Dated at San Francisco, the 26th day of July, 2005

Signed by Jack P. Broadbent
Jack P. Broadbent
Executive Officer/Air Pollution Control Officer
Bay Area Air Quality Management District