

NEW SOURCE REVIEW

This station will emit more than 10# of VOC in a single day. Thus the BACT requirements of Regulation 2-2-301 is triggered.

BACT for GDFs is considered the use of CARB-certified Phase-I and Phase-II vapor recovery equipment. State law prohibits the District from requiring vapor recovery equipment that is not CARB-certified.

Emissions from this station will remain less than 10 tpy. Per Regulation 2-2-302, offsets are not required.

TBACT

The increased risk from this project exceeds 1 per million, triggering the use of TBACT equipment. TBACT for GDFs is considered the use of CARB-certified Phase-I and Phase-II vapor recovery equipment. State law prohibits the District from requiring vapor recovery equipment that is not CARB-certified.

COMPLIANCE

The facility shall comply with Regulation 8-7-301 and 302 (Phase I and Phase II) and CARB Executive Orders VR-102E and G-70-150AE.

A. Permits – General Requirements, Regulation 2, Rule 1

The facility is located within 1000 feet of the outer boundary of Adventures in Learning, Delphi Academy, and Challenger School. It is therefore subject to the public notification requirements of Regulation 2-1-412. A public notice will be sent to all parents of students of the above-mentioned schools and all residents within 1000 feet of the facility. There will be a 30-day public comment period.

B. Permits – New Source Review, Regulation 2, Rule 2

1. **Offsets, Regulation 2-2-302:** Because the total facility emissions will be less than 10 tons per year, the facility is not required to provide offsets.
2. **California Environmental Quality ACT (CEQA), Regulation 2-1-311:** This project is considered to be ministerial under Regulation 2-1-311 and therefore is not subject to CEQA review. The engineering review for this project requires only the application of standard permit conditions and standard emission factors in accordance with Permit Handbook Chapter 2.3 and therefore is not discretionary as defined by CEQA.

C. Fees – Regulation 3

All applicable fees have been paid.

RECOMMENDATION

It is recommended that a P/O be granted to this station upon completion of the Public Comment period.

by: _____
Lorna O. Santiago
Air Quality Technician

Date: _____