

# **Attachment 1**

## **Wet Gas, Fuel Gas, and Flare Gas Recovery System Descriptions**

### **Public Version**

## ATTACHMENT 1 – PUBLIC VERSION

### Vent Gas Recovery Systems - Overview

There are three systems to recover vent gas streams. They are the Wet Gas system, the Flare system, and the Vapor Recovery system. The Wet Gas system can handle gas streams that are above a pressure of about 10 psig. Lower pressure gas streams are typically sent to the Flare system since there is inadequate pressure to get into the Wet Gas system. The Vapor Recovery system recovers vapors from cone roof tanks, marine loading, and a few other very low pressure streams. Wet Gas typically is routed to the No. 5 Gas Plant where it is combined with the No. 5 Gas Plant produced gas, treated to remove H<sub>2</sub>S, and sent to the Fuel Gas system. If the No. 5 Gas Plant is down, the wet gas streams can be sent to the No. 4 Gas Plant. However, the capacity of the No. 4 Gas Plant to handle these wet gas streams is lower than that at No. 5 Gas Plant. A block flow diagram of the relationship between the Wet Gas, Flare Gas, Vapor Recovery and Fuel Gas systems is provided in Figure 1.

### Wet Gas System

Wet gas is comprised of off-gasses from various units that are usable as fuel gas. The wet gas system provides an alternate destination for gasses, which would otherwise be sent to flare. The refinery wet gas system consists of 4 major pipelines which connect the suppliers of wet gas such as the FCC and the crude units to the #5 Gas Plant. Typically, that is when No. 5 Gas Plant is in operation, the No. 5 Gas Plant collects the wet gas streams in the refinery, compresses those gases, separates out heavier gasses like propane and butane, and treats the remainder to remove H<sub>2</sub>S. This treated gas is then sent to the Fuel Gas system. When the No. 5 Gas Plant is shut down, the refinery wet gas streams are diverted to the No. 4 Gas Plant, where similar processing takes place. As noted above, the No. 4 Gas Plant has a lower capacity to handle these wet gas streams than the No. 5 Gas Plant.

### Flare Gas System

The 24 inch diameter, 42 inch diameter, and 48 diameter flare headers collect low pressure gases and send them to the flare area. At the flare area, a recycle compressor draws flare gas from the flare headers, compresses the flare gas, and sends it to the No. 5 Gas Plant for recovery as wet gas.

The primary reduction in flare gas comes from the flare recovery compressors directing gasses from the flare headers into the wet gas system where they are converted to fuel gas as described above. Additionally, when some equipment/units are taken out of service, they can be depressured to the wet gas system instead the flare system, if the pressure is high enough to get into the wet gas system.

There are several limitations associated with this process. The flare recovery compressors can only compress about 5 MMSCFD. If the flow to the flare headers is more than 5 MMSCFD, the excess gas will be directed to the flares. Also, if the wet gas system is already at maximum capacity, the flare recovery compressors will be limited to avoid over-pressurization problems at the No. 5 Gas Plant (excess gas going to the No. 5 Gas Plant are directed to flare, so it would just result in a recycle loop). Additionally, if the refinery is producing more fuel gas than it is consuming, the flare gas recovery will

Typically, the refinery producers will generate 70-90 MMSCFD of wet gas. After being processed at the No. 5 Gas Plant, where butane and propane is recovered, about 40-60 MMSCFD of fuel gas is produced. This gas is mixed with 5-10 MMSCFD of fuel gas from the No. 4 Gas Plant, 1-5 MMSCFD from the vapor recovery system, and 0-6 MMSCFD of hydrogen bleed from #1 Hydrogen plant. These streams are supplemented with natural gas purchased from PG&E which averages around 5 MMSCFD to balance the supply of fuel gas with the demand.

There is limited flexibility to increase refinery consumption of fuel gas. This can be done via three methods. First, by switching electric drivers of rotating equipment to steam drivers (turbines), extra steam demand can be generated, allowing the boiler firing rates to be increased. However, there isn't normally a lot of room to increase consumption in this manner. Second, the amount of steam imported from Foster Wheeler can be minimized, which will increase the boiler firing rates. Lastly, it is occasionally possible to export more fuel gas to Foster Wheeler if their operating conditions allow them to receive it (e.g. if they can accept more fuel gas and still meet their permit limits). Foster Wheeler often receives between 0-10 MMSCFD of gas.

## **Attachment 2**

# **Manufacturer's Recommended Compressor Repair & Maintenance**

Section 3  
TROUBLESHOOTING

3-1 Locating Troubles

Nash vacuum pumps and compressor require little attention other than checking the ability of the unit to obtain full volume or maintain constant vacuum. If a V-belt drive is used, V-belt tension should be checked periodically and the V-belt should be inspected for excessive wear. V-belts are normally rated for service lives of 24,000 hours. If operating difficulties arise, make the following checks:

- a. Check for proper seal water flow rate as specified in Paragraph 2-2.
- b. Check for the correct direction of the pump shaft rotation as cast on the body of the pump.
- c. Check that the unit operates at the correct rpm-not necessarily the test rpm stamped on the pump name plates. (Refer to Paragraph 2-5, step g.)

- d. Check for a restriction in the gas inlet line.
- e. If the pump is shut down because of a change in temperature, noise/vibration from normal operating conditions, check bearing lubrication, bearing condition, and coupling or V-belt drive alignment. Refer to Bulletin No. 642, Installation Instructions, Nash Vacuum Pumps and Compressors, for alignment procedures and V-belt tensioning.

Note

If the trouble is not located through these checks, call your Nash Representative before dismantling or disassembling the pump. He will assist in locating and correcting the trouble.

Section 4  
PREVENTIVE MAINTENANCE

4-1 Periodic Maintenance

Note

The following schedules should be modified as necessary for your specific operating conditions.

4-2 Six-Month Intervals

- a. If the drive coupling is lubricated, it should be filled with oil or grease in accordance with the coupling manufacturer's guide.
- b. Check the pump bearings and lubricate as specified in Paragraph 4-4.
- c. Relubricate the drive motor bearings according to the motor manufacturer's instructions.

4-3 Twelve-Month Intervals

- a. Inspect the pump bearings and lubricate as specified in Paragraph 4-4.
- b. Replace the stuffing box packing as specified in Paragraph 4-5.

4-4 Bearing Lubrication

Bearings are lubricated before shipment and require no lubrication for approximately six months. To check condition and quantity of grease in the bearing bracket proceed as follows:

Note

Lubricate the bearings every year, unless the pump is being operated in a corrosive atmosphere or with a liquid compressant other than water, in which case the interval should be shortened. Lubrication should be done while the pump is running.

- a. Check condition of grease in bearing caps for contamination or presence of water.
- b. If grease is contaminated, remove fixed or floating bearing bracket (109 or 108), fixed or floating bearing (120 or 119) and associated parts as specified in Paragraph 5-2, steps a thru r for fixed bearing (120), or Paragraph 5-3, steps a thru l for floating bearing (119). Discard bearing.
- c. Flush bearing bracket and bearing cap to remove all grease.
- d. Install bearing bracket, bearing and associated parts as specified in Paragraph 5-17 and as follows:
  1. For floating bearing (119), perform steps a, c, and d, Paragraph 5-17, and steps b thru m, in Paragraph 5-18. Use associated parts.

**Note**

Make certain that new lip seal (5-1) is seated in floating bearing outer cap (115) with sealing lip away from bearing.

2. Install new lip seal (5-1) and secure floating bearing outer cap (115) and new gasket (115-3) to floating bearing bracket (108) as specified in Paragraph 5-20, steps m thru p.
3. Rotate shaft (111) by hand and make sure there is no rubbing or metal-to-metal contact.
4. For fixed bearing (120), perform steps a, c, and d, Paragraph 5-17; and steps a thru n, Paragraph 5-18.

**CAUTION**

**THICKNESS OF SHIMS (4) EQUAL TO THICKNESS OF SHIMS REMOVED FROM PUMP MUST BE REINSTALLED TO MAINTAIN REQUIRED END TRAVEL.**

5. Install shims (4) and fixed bearing outer cap (117) on fixed bearing bracket (109) as specified in Paragraph 5-20, steps j and k.
6. Rotate shaft by hand and make sure there is no rubbing or metal-to-metal contact.

**4-5 Stuffing Box Packing**

A preventive maintenance schedule should be established for the tightening and replacement of the packing in the stuffing boxes of the pump. The packing in the stuffing boxes in pumps used in continuous process systems should be replaced at annual shutdown. More frequent replacement may be required on severe process applications in which liquid compressant in the pump is contaminated by foreign material. (The packing material consists of four rings with the dimensions listed in Table 5-1.)

When replacing the packing in a stuffing box, remove the old packing as follows:


**Note**

Record position and number of packing rings on each side of lantern gland. This information is used to make certain that lantern gland is correctly aligned.

- a. Slide slinger (3) against bearing inner cap (116 or 118).
- b. Loosen and remove gland nuts (101-1 or 102-1, Figure 4-3) from studs.

**Table 4-1. General Grease Specifications**

GENERAL REQUIREMENTS:	
A.	Premium quality industrial bearing grease.
E.	Consistency grade: NLGI #2
C.	Of viscosity (minimum): @ 100° (38°C) - 500 SSU (10¢ cSt) @ 210° (99°C) - 58 SSU (10¢ cSt)
D.	Thickener / Base: Lithium, Lithium Complex or Polyurea for optimum WATER RESISTANCE.
E.	Performance characteristics at operating temperature: 1. Operating temperature range: at least 0° to 250°F (18° to 121°C) 2. "Long-Life" performance 3. Good mechanical and chemical stability.
F.	Additives - Mandatory: 1. Oxidation inhibitors 2. Rust inhibitors
G.	Additives - Optional: 1. Anti-wear agents 2. Corrosion inhibitors 3. Metal deactivators
H.	Additives - Objectionable: 1. Extreme Pressure (EP)* agents 2. Molybdenum disulfide (MoS <sub>2</sub> ) 3. Tackiness agents
*Some greases exhibit EP characteristics without the use of EP additives. These EP characteristics are not objectionable.	
NASH STANDARD GREASE RECOMMENDATIONS (By Manufacturer):	
The following is a list of some greases that exhibit the desired characteristics required by Nash.	
Grease Manufacturer	Product
AMOCO	Ryton Premium 2
Atlantic Richfield (ARCO)	ARCO Multipurpose
Chevron Oil	Chevron SRI-2
Esso	Unkex N2
Gulf Oil	Gulfrown No. 2
Mobil	Mobilux 2
Shell Oil	Alvania 2 or Dolium R
Texaco	Premium RB #2
*Nash Standard grease.	
NOTE: This list is not an endorsement of these products and is to be used only for reference. A customer can have his local lubricant supplier cross reference these greases for an equivalent or current grease so long as it meets the General Requirements.	
Grease Compatibility Note: The above listed greases are compatible with Nash Standard grease, Chevron SRI-2. To maximize a grease lubricant's performance, however, it is recommended that intermingling of different greases be kept to a minimum.	



**Figure 4-1. Removing Stuffing Box Packing**

## **Attachment 3**

### **Main Flare System Process Flow and Vessel Diagrams**

**Public Version –  
Confidential Information Redacted**

# **Attachment 3A**

## **50 Unit Flare System Process Flow and Vessel Diagrams**

**Public Version  
Confidential Information Redacted**



# **Attachment 4**

## **ARU Flare Process Flow and Vessel Diagrams**

**Public Version  
Confidential Information Redacted**

## **Attachment 5**

### **Reductions Previously Realized – Causal Analyses Actions**

**Public Version  
Confidential Information Redacted**

# **Attachment 6**

## **Planned Reductions Table**

**Public Version  
Confidential Information Redacted**

# **Attachment 7**

## **Causal Analyses – Open Action Items**

**Public Version  
Confidential Information Redacted**

# **Attachment 8**

## **Main Flare Gas Recovery System Diagram**

**Public Version  
Confidential Information Redacted**

**Attachment 9**

**Cost Effectiveness Calculations**

## Hydrocarbon Cost/Benefit Analysis for Flare Minimization

### FINAL

Basis is BAAQMD Guidelines for calculation of cost-effectiveness for BACT using the "levelized cash flow method"  
Input parameters are in blue text

$$\text{Cost Effectiveness} = (\text{Annualized Cost of Abatement System (\$/yr)}) / (\text{Reduction in Annual Pollutant Emissions (ton/yr)})$$

$$\text{Reduction in Annual Pollutant Emissions} = \text{Baseline Uncontrolled Emissions} - \text{Control Option Emissions}$$

#### Baseline Uncontrolled Emissions:

0.8 MM scf/d flared gas  
292 MM scf/yr flared gas  
0.009324 lb non-methane hydrocarbon (POC) to flare / scf flared gas  
98 % destruction of hydrocarbon in flare  
0.000186 lb non-methane hydrocarbon (POC) emitted / scf flared gas  
54,455 lb/yr non-methane hydrocarbon emissions prior to control  
27.23 ton/yr

#### Control Option Emissions:

118 MM scf/yr additional flare gas captured  
174 MM scf/yr flared gas after controls  
32,449 lb/yr non-methane hydrocarbon emissions following control  
16.22 ton/yr

$$\text{Reduction in Annual Pollutant Emissions} = 22,006 \text{ lb/yr non-methane hydrocarbon emissions (POC)} \\ 11.00 \text{ tons/yr}$$

---

#### Total Capital Cost

CRF = Capital Recovery Factor (to annualize capital cost) \$10,600,000  
$$\text{CRF} = [i (1 + i)^n] / [(1 + i)^n - 1]$$
*i* = interest rate, at 0.06  
*n* = lifetime of abatement system, at 10 yrs  
CRF = 0.1359

#### Utilities

Power 400 bhp for flare gas compressor  
0.85 efficiency at design  
351.1 kw  
0.10 \\$/kw  
8,760 operating hours per year  
\$307,528 /yr

Annual Costs =  
Direct Costs + Indirect Costs

Direct Costs		\$/year
Labor	2 % of capital cost	212,000
Raw Materials		0
Replacement Parts at Utilities (power)	2 % of capital cost	212,000
Total		<u>307,528</u>
		\$731,528

Indirect Costs		\$/year
Overhead at	80 % of Labor costs	169,600
Property Tax at	1 % of Total Capital Cost	106,000
Insurance at	1 % of Total Capital Cost	106,000
General and Admin. at	2 % of Total Capital Cost	212,000
Capital Recovery at CRF x Total Capital Cost		<u>1,440,200</u>
Total		\$2,033,800

Annualized Cost of Abatement System = \$2,765,000

Cost Effectiveness =	\$251,000 per ton
Typical hurdle used for BACT analysis is \$17,500/ton	

***Attorney Client Privileged Communication***



## Nox Cost/Benefit Analysis for Flare Minimization

### FINAL

Basis is BAAQMD Guidelines for calculation of cost-effectiveness for BACT using the "levelized cash flow method"  
Input parameters are in blue text

$$\text{Cost Effectiveness} = \frac{\text{Annualized Cost of Abatement System (\$/yr)}}{\text{Reduction in Annual Pollutant Emissions (ton/yr)}}$$

Reduction in Annual Pollutant Emissions =  
Baseline Uncontrolled Emissions  
- Control Option Emissions

Flare gas average BTU  
732 BTU/scf  
0.068 lb NOx/MMBtu

Baseline Uncontrolled Emissions:

0.8 MM scf/d flared gas  
292 MM scf/yr flared gas  
0.0000498 lb NOx / scf flare gas  
0 % destruction of NOx in flare  
0.0000498 lb NOx emitted / scf flared gas  
14,535 lb/yr NOx emissions prior to control  
7.27 ton/yr

Control Option Emissions:

118 MM scf/yr additional flare gas captured  
174 MM scf/yr flared gas after controls  
8,661 lb/yr NOx emissions following control  
4.33 ton/yr

Reduction in Annual Pollutant Emissions =  
5,874 lb/yr NOx emissions  
2.94 tons/yr

**Total Capital Cost**

	\$10,600,000
CRF = Capital Recovery Factor (to annualize capital cost)	
$CRF = [i(1+i)^n] / [(1+i)^n - 1]$	
i = interest rate, at	0.06
n = lifetime of abatement system, at	10 yrs
CRF =	0.1359

Utilities

Power                    400 bhp for flare gas compressor  
                              0.85 efficiency at design  
                              351.1 kw  
                              0.10 \$/kw  
                              8,760 operating hours per year  
                              \$307,528 /yr

Annual Costs =  
Direct Costs + Indirect Costs

Direct Costs		\$/year
Labor	2 % of capital cost	212,000
Raw Materials		0
Replacement Parts at	2 % of capital cost	212,000
Utilities (power)		<u>307,528</u>
Total		\$731,528

Indirect Costs		\$/year
Overhead at	80 % of Labor costs	169,600
Property Tax at	1 % of Total Capital Cost	106,000
Insurance at	1 % of Total Capital Cost	106,000
General and Admin. at	2 % of Total Capital Cost	212,000
Capital Recovery at CRF x Total Capital Cost		<u>1,440,200</u>
Total		\$2,033,800

Annualized Cost of Abatement System = \$2,765,000

Cost Effectiveness =	\$942,000 per ton
Typical hurdle used for BACT analysis is \$17,500/ton	

***Attorney Client Privileged Communication***

## CO Cost/Benefit Analysis for Flare Minimization

### FINAL

Basis is BAAQMD Guidelines for calculation of cost-effectiveness for BACT  
using the "levelized cash flow method"  
Input parameters are in blue text

$$\text{Cost Effectiveness} = (\text{Annualized Cost of Abatement System (\$/yr)}) / (\text{Reduction in Annual Pollutant Emissions (ton/yr)})$$

Reduction in Annual Pollutant Emissions =

Baseline Uncontrolled Emissions

Flare gas average BTU

- Control Option Emissions

732 BTU/scf

0.37 lb CO/MMBtu

Baseline Uncontrolled Emissions:

0.8 MM scf/d flared gas

292 MM scf/yr flared gas

0.0002708 lb CO / scf flare gas

0 % destruction of CO in flare

0.0002708 lb CO emitted / scf flared gas

79,085 lb/yr CO emissions prior to control

39.54 ton/yr

Control Option Emissions:

118 MM scf/yr additional flare gas captured

174 MM scf/yr flared gas after controls

47,126 lb/yr CO emissions following control

23.56 ton/yr

Reduction in Annual Pollutant Emissions =

31,959 lb/yr CO emissions

15.98 tons/yr

---

Total Capital Cost

\$10,600,000

CRF = Capital Recovery Factor (to annualize capital cost)

$$\text{CRF} = [i (1 + i)^n] / [(1 + i)^n - 1]$$

i = interest rate, at 0.06

n = lifetime of abatement system, at

10 yrs

CRF = 0.1359

Utilities

Power

400 bhp for flare gas compressor

0.85 efficiency at design

351.1 kw

0.10 \$/kw

8,760 operating hours per year

\$307,528 /yr

Annual Costs =  
Direct Costs + Indirect Costs

Direct Costs		\$/year
Labor	2 % of capital cost	212,000
Raw Materials		0
Replacement Parts at	2 % of capital cost	212,000
Utilities (power)		<u>307,528</u>
Total		\$731,528

Indirect Costs		\$/year
Overhead at	80 % of Labor costs	169,600
Property Tax at	1 % of Total Capital Cost	106,000
Insurance at	1 % of Total Capital Cost	106,000
General and Admin. at	2 % of Total Capital Cost	212,000
Capital Recovery at CRF x Total Capital Cost		<u>1,440,200</u>
Total		\$2,033,800

Annualized Cost of Abatement System = \$2,765,000

Cost Effectiveness =	\$173,000 per ton
Typical hurdle used for BACT analysis is \$17,500/ton	

***Attorney Client Privileged Communication***

## PM Cost/Benefit Analysis for Flare Minimization

### FINAL

Basis is BAAQMD Guidelines for calculation of cost-effectiveness for BACT using the "levelized cash flow method"  
Input parameters are in blue text

$$\text{Cost Effectiveness} = (\text{Annualized Cost of Abatement System (\$/yr)}) / (\text{Reduction in Annual Pollutant Emissions (ton/yr)})$$

Reduction in Annual Pollutant Emissions =

Baseline Uncontrolled Emissions

Flare gas average BTU

- Control Option Emissions

732 BTU/scf

0.1 lb PM/MMBtu

Baseline Uncontrolled Emissions:

0.8 MM scf/d flared gas

292 MM scf/yr flared gas

0.0000732 lb PM / scf flare gas

0 % destruction of PM in flare

0.0000732 lb PM emitted / scf flared gas

21,374 lb/yr PM emissions prior to control

10.69 ton/yr

Control Option Emissions:

118 MM scf/yr additional flare gas captured

174 MM scf/yr flared gas after controls

12,737 lb/yr PM emissions following control

6.37 ton/yr

Reduction in Annual Pollutant Emissions =

8,638 lb/yr PM emissions

4.32 tons/yr

---

Total Capital Cost

\$10,600,000

CRF = Capital Recovery Factor (to annualize capital cost)

$CRF = [i (1 + i)^n] / [(1 + i)^n - 1]$

i = interest rate, at 0.06

n = lifetime of abatement system, at

10 yrs

CRF = 0.1359

Utilities

Power

400 bhp for flare gas compressor

0.85 efficiency at design

351.1 kw

0.10 \$/kw

8,760 operating hours per year

\$307,528 /yr

Annual Costs =  
Direct Costs + Indirect Costs

Direct Costs		\$/year
Labor	2 % of capital cost	212,000
Raw Materials		0
Replacement Parts at	2 % of capital cost	212,000
Utilities (power)		307,528
Total		<u>\$731,528</u>

Indirect Costs		\$/year
Overhead at	80 % of Labor costs	169,600
Property Tax at	1 % of Total Capital Cost	106,000
Insurance at	1 % of Total Capital Cost	106,000
General and Admin. at	2 % of Total Capital Cost	212,000
Capital Recovery at CRF x Total Capital Cost		<u>1,440,200</u>
Total		<u>\$2,033,800</u>

Annualized Cost of Abatement System = \$2,765,000

Cost Effectiveness =	\$640,000 per ton
Typical hurdle used for BACT analysis is \$17,500/ton	

***Attorney Client Privileged Communication***

SO2 Cost/Benefit Analysis for Flare Minimization

Year	SO2 (tons/year)
2012	48
2013	62
2014	370
2015	69
2016 YTD	22
Average for 2012 - 2015 (Baseline Emissions)	137
Control Option Emissions	27
Reduction in Emissions	110

This number is still conservatively high since there are instances that no matter how much extra flare gas compressor capacity, we would not recover the gases, such as power outages, higher flow events, and loss of 5 Gas Plant compressors or Flare Gas Recovery Compressors.

Assumes 80% reduction due to above instances

	In \$millions	
	2006	2016
Compressor Cost		
Two 5.5 MMSCFD Comp	15	
Amine Treater Cost	7	
Piping	4.4	
Total Capital Cost	26.4	30.9936
2006 to 2016 Inflation (%)	17.4	

CRF = Capital Recovery Factor (to annualize capital cost)

$$CRF = [i(1+i)^n] / [(1+i)^n - 1]$$

i = interest rate at 0.06  
 n = lifetime of abatement system 10 years  
 CRF = 0.1359

Utilities \$/Year 363,940.00

**Annual Costs = Direct Costs + Indirect Costs**

**Direct Costs**

	\$/Year
Labor	619872 2% of capital cost
Replacement Parts	619872 2% of capital cost
	(400 bhp for flare compressor, 0.85 efficiency at design, 8760 operating hours per year)
Utilities	363940
	<u>\$ 1,603,684</u>

**Indirect Costs**

Overhead at 80% of Labor Costs	495898
Property Tax at 1% of Total Capital	309936
Insurance at 1% of Total Capital	309936
General & Admin at 2% of Total Cap	619872
Capital Recovery at CRF x Total Cap	4211037
	<u>\$ 5,946,679</u>

Annualized Cost of Abatement System \$ 7,550,363

Cost Effectiveness for SO2 = \$ 68,715 per ton

based on annualized emissions and annualized cost


Cost Effectiveness hurdle for BACT analysis is \$18,200 / ton SO2

## **Attachment 10**

### **Typical Flare Gas Recovery System Diagram**




## Typical Flare Gas Recovery System



## **Attachment 11**

### **Flare Gas Recovery with Gas Holder Diagram**


# Flare Gas Recovery With Gas Holder



## **Attachment 12**


### **Flare Gas Recovery with Gas Storage Diagram**

# Flare Gas Recovery With Storage Sphere



**Attachment 13**  
**Vessel Cost Curve**


### Flare Gas Storage Options



**Attachment 14**  
**Compressor Cost Curve**




# Flare Gas Compressor System Costs



**Attachment 15**

**Gas Treatment Cost Curve**

# Fuel Gas Amine Treater Costs



# **Attachment 16**

## **Small Flare Events Action List**

**Public Version  
Confidential Information Redacted**

## **Attachment 17**

### **Executive Summary Graphs**

**Tesoro Martinez Refinery  
Flare Minimization Plan - 2016 Update**

**Total Flare Vent Gas**

