

BAY AREA AIR QUALITY MANAGEMENT DISTRICT
Best Available Control Technology (BACT) Guideline

Source Category

Source:	<i>Boiler - Municipal Refuse Fired</i>	Revision:	<i>1</i>
		Document #:	<i>17.8.1</i>
Class:	<i>All</i>	Date:	<i>08/05/91</i>

Determination

POLLUTANT	BACT 1. Technologically Feasible/ Cost Effective 2. Achieved in Practice	TYPICAL TECHNOLOGY
POC	1. n/d 2. 50 ppm @ 12% CO ₂ ^a	1. n/d 2. Boiler Design (Overfire Air Jets) + Automatic Combustion Air Control
NO _x	1. n/s 2. 200 ppm @ 12% CO ₂ ^a	1. SCR + Staged Combustion and Automatic Combustion Air Control + Natural Gas as Auxiliary Fuel 2. Flue Gas Recirculation + Combustion Modification ^a
SO ₂	1. n/d 2. 30 ppm @ 12% CO ₂ ^a	1. n/d 2. Dry Scrubber with Baghouse + Natural Gas as Auxiliary Fuel ^a
CO	1. n/d 2. 100 ppm @ 12% CO ₂ ^a	1. Catalytic Oxidation 2. Boiler Design (Overfire Air Jets) + Automatic Combustion Air Control
PM ₁₀	1. ≤0.002 gr/dscf @ 12% CO ₂ 2. ≤0.005 gr/dscf @ 12% CO ₂	1. Baghouse and Natural Gas as auxiliary Fuel 2. Baghouse and Natural Gas as auxiliary Fuel
NPOC	1. n/a 2. n/a	1. n/a 2. n/a

References

a. CARB/CAPCOA Clearinghouse