

CO:

$$= (50 \text{ hr/yr})(215 \text{ hp})(0.447 \text{ g/hp-hr})(\text{lb}/454 \text{ g})$$

$$= \mathbf{10.58 \text{ lb/yr}} \text{ or } \mathbf{0.0053 \text{ TPY}}$$

PM10:

$$= (50 \text{ hr/yr})(215 \text{ hp})(0.075 \text{ g/hp-hr})(\text{lb}/454 \text{ g})$$

$$= \mathbf{1.78 \text{ lb/yr}} \text{ or } \mathbf{0.0009 \text{ TPY}}$$

SO₂ emissions are quantified based on the full conversion of 0.0015 wt% (~15 ppm) sulfur in the ULS diesel fuel with a density of 7.206 lbs/gal that is consumed at a rate of 9.4 gal/hr.

SO₂:

$$= (0.000015 \text{ lb S/lb fuel})(7.206 \text{ lb fuel/gal fuel})(9.4 \text{ gal fuel/hr})(64 \text{ lb SO}_2/32 \text{ lb S})(50 \text{ hr/yr})$$

$$= \mathbf{0.1016 \text{ lb/yr}} \text{ or } \mathbf{0.00005 \text{ TPY}}$$

Daily Emissions:

Daily emissions are calculated to establish whether a source triggers the requirement for BACT (10 lb/highest day total source emissions for any class of pollutants). 24-hr/day of operation will be assumed since no daily limits are imposed on intermittent and unexpected operations.

NO_x:

$$= (24 \text{ hr/day})(215 \text{ hp})(4.052 \text{ g/hp-hr})(\text{lb}/454 \text{ g}) = \mathbf{46.05 \text{ lb/day}}$$

POC:

$$= (24 \text{ hr/day})(215 \text{ hp})(0.213 \text{ g/hp-hr})(\text{lb}/454 \text{ g}) = \mathbf{2.42 \text{ lb/day}}$$

CO:

$$= (24 \text{ hr/day})(215 \text{ hp})(0.447 \text{ g/hp-hr})(\text{lb}/454 \text{ g}) = \mathbf{5.08 \text{ lb/day}}$$

PM10:

$$= (24 \text{ hr/day})(215 \text{ hp})(0.075 \text{ g/hp-hr})(\text{lb}/454 \text{ g}) = \mathbf{0.85 \text{ lb/day}}$$

SO₂ emissions are quantified based on the full conversion of 0.0015 wt% (~15 ppm) sulfur in the ULS diesel fuel with a density of 7.206 lbs/gal that is consumed at a rate of 9.4 gal/hr.

SO₂:

$$= (0.000015 \text{ lb S/lb fuel})(7.206 \text{ lb fuel/gal fuel})(9.4 \text{ gal fuel/hr})(64 \text{ lb SO}_2/32 \text{ lb S})(24 \text{ hr/day})$$

$$= \mathbf{0.0488 \text{ lb/day}}$$

PLANT CUMULATIVE INCREASE

123 Mission LLC is a new facility. Therefore, the District's database does not contain information on existing emissions at the plant. Table 1 summarizes the cumulative increase in criteria pollutant emissions that will result at Plant 17243 from the operation of S-1.

Table 1

Pollutant	Current plant emissions (TPY)	Increase in plant emissions associated with this application (TPY)	Cumulative emissions (Current + Increase) (TPY)
NO _x	0	0.0480	0.0480
POC	0	0.0025	0.0025
CO	0	0.0053	0.0053
PM10	0	0.0009	0.0009

SO2	0	0.00005	0.00005
-----	---	---------	---------

TOXIC RISK SCREENING ANALYSIS

The cancer risk is calculated based on the emission rate of diesel exhaust particulate matter. Diesel exhaust particulate matter is used as a surrogate for all toxic contaminants found in diesel exhaust. Because the proposed emissions exceed the risk screening trigger level for diesel exhaust particulate matter in Table 2-5-1, a risk screening was performed.

In order for these engines to meet the risk level set by the District’s Risk Management Policy, the applicant has requested that S-1’s hours of operation, excluding periods when operation is required due to emergency conditions, be limited to no more than 50 hours per year. Results from the health risk screening analysis indicate that the maximum cancer risk is estimated at 0.8 in a million if the engine were to run for 50 hours/year.

Estimates of residential risk assume exposure to annual average toxic air contaminate concentrations occur 24 hours per day, 350 days per year, for a 70-year lifetime. Risk estimates for offsite workers assume exposure occurs 8 hours per day, 245 days per year, for 40 years. Risk estimates for students assume a higher breathing rate, and exposure is assumed to occur 10 hours per day, 36 weeks per year, for 9 years.

Based on 50 hours per year of operation, the emergency generator passed the Health Risk Screening Analysis (HRA) conducted on March 26, 2008 by the District's Toxic Evaluation Section. This source poses no significant toxic risk, since the increased cancer risk to the maximally exposed receptor (resident) is 0.8 in a million and the hazard index is 4.6E-4. The increased cancer risk to a worker is 0.6 in a million and the hazard index is 4.5E-4. The increased cancer risk to students is 0.03 in a million and the hazard index is 8.3E-5. In accordance with Regulation 2, Rule 5, the above risk level is considered acceptable for an engine such as S-1.

PUBLIC NOTICE REVIEW

On [REDACTED] 2008 Application 17388 was sent on public notice and was distributed to residences, businesses and parents/guardians of the nearby schools. The public notice was closed on [REDACTED] 2008. At the end of the comment period that lasted for 30 days, [REDACTED] was received.



BACT

BACT is triggered for NOx since the maximum daily emissions of the above pollutants exceed 10 lb/day. Please refer to the discussion on “Daily Emissions” in page 2 of this evaluation. BACT for this source is presented in the current BAAQMD BACT/TBACT Workbook for this source category as shown below:

Source Category

Source:	<i>IC Engine - Compression Ignition</i>	Revision:	5
		Document #:	96.1.2
Class:	<i>> or = 175 horsepower output rating</i>	Date:	01/11/02

Determination

POLLUTANT	BACT	TYPICAL TECHNOLOGY
	1. Technologically Feasible/ Cost Effective 2. Achieved in Practice 3. TBACT	
POC	1. 0.30 g/bhp-hr [62 ppmvd @ 15% O ₂] ^{a,b} 2. 1.5 g/bhp-hr [309 ppmvd @ 15% O ₂] ^{b,c}	1. Catalytic Oxidation and CARB or EPA (or equivalent) low-total hydrocarbon emitting certified engine ^{a,b} 2. CARB or EPA (or equivalent) low-total hydrocarbon emitting certified engine ^{b,c}
NO _x	1. 1.5 g/bhp-hr [107 ppmvd @ 15% O ₂] ^{a,b} 2. 6.9 g/bhp-hr [490 ppmvd @ 15% O ₂] ^{a,b,c} 3. 6.9 g/bhp-hr [490 ppmvd @ 15% O ₂]	1. Selective Catalytic Reduction (SCR) + Timing Retard + Turbocharger w/ Intercooler ^{a,b} 2. Timing Retard ≤ 4° + Turbocharger w/ Intercooler ^{a,b,c} 3. Timing Retard ≤ 4° + Turbocharger w/ Intercooler
SO ₂	1. n/d 2. fuel oil < 0.05% sulfur ^{a,b}	1. n/d 2. Fuel Selection ^{a,b}
CO	1. n/s 2. 2.75 g/bhp-hr [319 ppmvd @ 15% O ₂] ^{b,c}	1. Catalytic Oxidation ^b 2. CARB or EPA (or equivalent) low-CO emitting certified engine ^{b,c}
PM ₁₀	1. n/d 2. If practical, gas-fueled engine or electric motor. If not, "California Diesel Fuel" (fuel oil w/ < 0.05% by weight sulfur and < 20% by volume aromatic hydrocarbons) ^b 3. 0.1 grams/bhp-hr	1. Catalyst Guard Bed ^{a,b} 2. Fuel Selection ^{b,d} 3. CARB or EPA (or equivalent) low-particulate matter emitting certified engine, or particulate filter

References

<p>a. CARB/CAPCOA Clearinghouse</p> <p>b. BAAQMD NOTE: IC Engine BACT and TBACT is a low emitting, spark-ignited, gas-fueled engine with lean burn combustion or rich burn with non-selective catalytic reduction, or electric motor. A diesel engine will be permitted only if a gas-fueled engine, or electric motor, is not practical (e.g., a remote location without natural gas availability or electric power, or only a diesel engine will meet the portability and/or power/torque/rpm requirements of the application under review, or the engine is used exclusively for emergency use during involuntary loss of power).</p> <p>c. Timing retard, etc. controls alone may be acceptable only in very limited situations for temporary sources.</p>

It can be seen from above that S-1 satisfies the current BACT 2 standard for NO_x (6.9 g/hp-hr). The more restrictive BACT 1 standard is not applicable to this engine because it will be limited to operation as an emergency standby engine.

OFFSETS

123 Mission LLC is a new facility. Table 2 summarizes the increase in criteria pollutant emissions that will result at Plant 17243 from the operation of S-1.

Table 2

Pollutant	Increase in Emissions At Plant Since April 5, 1991 ¹ (TPY)	Increase in Emissions Associated With This Application (TPY)	Total Emissions (Post 4/5/91 + Increase) (TPY)	Regulation 2-2-302 and 2-2-303 Offset Triggers (TPY)
NOx	0	0.0480	0.0480	> 10; < 35
POC	0	0.0025	0.0025	> 10; < 35
CO	0	0.0053	0.0053	NA
PM10	0	0.0009	0.0009	> 1
SO2	0	0.00005	0.00005	> 1

It can be seen from Table 2 above that S-1 does not trigger any offset. Therefore, offsets are not warranted for any emission.

CARB STATIONARY DIESEL ENGINE ATCM

The State Office of Administrative Law approved the Airborne Toxic Control Measure (ATCM) on November 8, 2004. State law requires the local Air Districts to implement and enforce the requirements of the ATCM. Effective January 1, 2005, there is a prohibition on the operation of new diesel emergency standby engines greater than 50 bhp unless the following operating requirements and emission standards are met:

“Stationary Diesel Engine ATCM” section 93115, title 17, CA Code of Regulations.

Diesel PM – General Requirements

1. Meet 0.15 g/bhp-hr PM standard
2. Operate 50 hours per year, or less, for maintenance and testing (except emergency use and emissions testing)

HC,NO_x, NMHC+NO_x, CO

1. Meet standards for off-road engines of the same model year and horsepower rating
As specified in the OFF-Road Compression Ignition Engine Standards;
Or if no standards have been established
2. Meet the Tier 3 standards in Title 13, CCR, Section 2423 for off-road engines of the same horsepower rating, irrespective of the new engine’s model year

This emergency standby diesel engine (S-1) is in compliance with the above ATCM requirements. The diesel engine will operate for no more than 50 hours per year for maintenance and reliability testing. This engine is subject to the EPA Tier 2 requirements for HC, NO_x, NMHC+NO_x and CO. As shown in the Table 3, the engines meet these requirements.

Table 3. ATCM Tier 2 Compliance

	CARB	ATCM Tier 2

¹ In PSDP do the following steps to get data on the aggregate sum of all increases as defined in Reg. 2-2-212 after April 5, 1991: option 1 → type of pollutant.

	g/bhp-hr	g/bhp-hr
NMHC (POC)	0.213	N/A
NO _x	4.052	N/A
NMHC+NO _x	4.265	4.9
CO	0.447	2.6
PM	0.075	0.15

STATEMENT OF COMPLIANCE

Source S-1 is subject to and expected to be in compliance with the requirements of District Regulation 1-301 (*Public Nuisance*), Regulation 6-303 (*Particulate Matter and Visible Emissions*), Regulation 9-1 (*Sulfur Dioxide*) and Regulation 9-8 (*NO_x and CO from Stationary Internal Combustion Engines*). In order to ensure compliance with the requirements of these regulations, the facility will be conditionally permitted to meet the requirements.

From Regulation 1-301, no person shall discharge from any source whatsoever such quantities of air contaminants or other material which cause injury, detriment, nuisance or annoyance to any considerable number of persons or the public; or which endangers the comfort, repose, health or safety of any such persons or the public, or which causes, or has a natural tendency to cause, injury or damage to business or property. For purposes of this section, three or more violation notices validly issued in a 30 day period to a facility for public nuisance shall give rise to a rebuttable presumption that the violations resulted from negligent conduct.

S-1 is subject to the limitations of Regulation 6-303 (*Particulate Matter and Visible Emissions*). Regulation 6, Section 303 states that a person shall not emit for a period or periods aggregating more than three minutes in any hour, a visible emission that is as dark or darker than No. 2 on the Ringelmann Chart, or of such opacity as to obscure an observer's view to an equivalent or greater degree, nor shall said emission, as perceived by an opacity sensing device in good working order, where such device is required by District Regulations, be equal to or greater than 40% opacity. This low PM10 emitting engine is not expected to produce visible emissions or fallout in violation of this regulation, and it will be assumed to be in compliance with Regulation 6 pending a regular inspection

S-1 is also subject to the SO₂ limitations of Regulation 9-1-301 (*Limitation on Ground Level Concentrations of Sulfur Dioxide*), Regulation 9-1-302 (*Limitations Sulfur Dioxide Emissions*) and 9-1-304 (*Burning of Solid and Liquid Sulfur Dioxide Fuel*). From Regulation 9-1-301, the ground level concentrations of SO₂ will not exceed 0.5 ppm continuously for 3 consecutive minutes or 0.25 ppm averaged over 60 consecutive minutes, or 0.05 ppm averaged over 24 hours. Per Regulation 9, Rule 1, Section 302, a person shall not emit from any source a gas stream containing sulfur dioxide in excess of 300 ppm (dry). And Regulation 9, Rule 1, Section 304, states that a person shall not burn any liquid fuel having sulfur content in excess of 0.5% by weight. Compliance with both Regulations 9-1-302 and 9-1-304 is likely since California law mandates using diesel fuel with a 0.0015% by weight sulfur.

Regulation 9-8 "NO_x and CO from Stationary Internal Combustion Engines." From Regulation 9-8-110.4, the source is not subject to the requirements of Regulations 9-8-301 (*Emission Limits on Fossil Derived Fuel Gas*), 9-8-302 (*Emission Limits on Waster Derived Fuel Gas*), and 9-8-502(*Record Keeping*).

S-1 is exempt from Regulation 9-8-502 however; it is subject to the monitoring and record keeping procedures described in Regulation 9-8-530(*Emergency Standby Engines, Monitoring and Recordkeeping*). The requirements of this Regulation are included in the permit conditions

This project is considered to be ministerial under the District's CEQA Regulation 2-1-311 and therefore is not subject to CEQA review. The engineering review for this project requires only the application of standard permit conditions and standard emission factors in accordance with Permit Handbook Chapter 2.3.

The project is within 1000 feet of the nearest school and therefore the owner/operator is subject to the public notification requirements of Reg. 2-1-412. A public notice was prepared and sent on [REDACTED], 2008:

All addresses within 1000 feet of the diesel generator and
Parents and guardians of students at Youth Chance High School

PSD, NSPS and NESHAPS are not triggered.

PERMIT CONDITIONS

COND# 22850 -----

1. Operating for reliability-related activities is limited to 50 hours per year per engine.
[Basis: "Stationary Diesel Engine ATCM" section 93115, title 17, CA Code of Regulations, subsection (e)(2)(A)(3) or (e)(2)(B)(3)]
2. The owner or operator shall operate each emergency engine only for the following purposes: to mitigate emergency conditions, for emission testing to demonstrate compliance with a District, state or Federal emission limit, or for reliability-related activities (maintenance and other testing, but excluding emission testing). Operating hours while mitigating emergency or while emission testing to show compliance with District, state or Federal emission limits is not limited.
[Basis: "Stationary Diesel Engine ATCM" section 93115, title 17, CA Code of Regulations, subsection (e)(2)(A)(3) or (e)(2)(B)(3)]
3. The owner/operator shall operate each emergency standby engine only when a non-resettable totalizing meter (with a minimum display capability of 9,999 hours) that measures the hours of operation for the engine is installed, operated and properly maintained.
[Basis: "Stationary Diesel Engine ATCM" section 93115, title 17, CA Code of Regulations, subsection (e)(4)(G)(1)]
4. Records: The owner/operator shall maintain the following monthly records in a District-approved log for at least 36 months from the date of entry (60 months if the facility has been issued a Title V Major Facility Review Permit or a Synthetic Minor Operating Permit). Log entries shall be retained on-site, either at a central location or at the engine's location, and made immediately available to the District staff upon request.
 - a. Hours of operation for reliability-related activities (maintenance and testing).
 - b. Hours of operation for emission testing to show compliance with emission limits.
 - c. Hours of operation (emergency).

- d. For each emergency, the nature of the emergency condition.
- e. Fuel usage for each engine(s).

[Basis: "Stationary Diesel Engine ATCM" section 93115, title 17, CA Code of Regulations, subsection (e)(4)(I), (or Regulation 2-6-501)]

5. At School and Near-School Operation:

If the emergency standby engine is located on school grounds or within 500 feet of any school grounds, the following requirements shall apply:

The owner or operator shall not operate each stationary emergency standby diesel-fueled engine for non-emergency use, including maintenance and testing, during the following periods:

- a. Whenever there is a school-sponsored activity (if the engine is located on school grounds).
- b. Between 7:30 a.m. and 3:30 p.m. on days when school is in session. "School" or "School Grounds" means any public or private school used for the purposes of the education of more than 12 children in kindergarten or any of grades 1 to 12, inclusive, but does not include any private school in which education is primarily conducted in a private home(s). "School" or "School Grounds" includes any building or structure, playground, athletic field, or other areas of school property but does not include unimproved school property.

[Basis: "Stationary Diesel Engine ATCM" section 93115, title 17, CA Code of Regulations, subsection (e)(2)(A)(1)] or (e)(2)(B)(2)]

RECOMMENDATION

Issue 123 Mission LLC an AC for the following equipment:

<p>S-1 Emergency Standby Generator Cummins, Model: Q5B5.9 215 BHP, 1.29 MMBTU/hr</p>	at	<p>123 Mission Street San Francisco, CA 94105</p>
--------------------------------------------------------------------------------------------------	----	-------------------------------------------------------

Milyani H. Rizal
Air Quality Engineering Intern
Engineering Division
12/20/07