

Nominal Performance Data

Introduction

This document describes the nominal performance for a SGT-800 in simple cycle application for San Francisco Bay Area, California, USA

1.1 Set Description

Gas Turbine	4 x SGT-800.
Combustor system	Third generation low emission combustion system and gas fuel capability.

Summary performance data

A summary of the nominal net performance calculation is enclosed on the following pages.

SUMMARY OF GAS TURBINE PERFORMANCE DATA WITHOUT CHILLER

=====

GTperform version : 2.4.1
 Project Name : SF Bay area
 Run date : 2010-05-12
 Run performed by : John Erik Hansson
 Gas turbine unit : SGT-800
 Altitude : 120. ft above sea level
 Barometric pressure : 14.63236 psia
 Inlet pressure loss : 4.02 inches H2O
 Outlet pressure loss : 12.02 inches H2O
 Fuel : Gas fuel
 LHV : 20690.3 Btu/lb
 Fuel Temp. : 77.0 F (Ref. Temperature 77F)

F U E L C O M P O S I T I O N

Component	Volume %	Component	Volume %	Component	Volume %
CH4	96.210	C2H6	1.350	C3H8	0.760
IC4H10	0.190	CO2	1.060	N2	0.430

Special notes : GENERATOR DRIVE 60 Hz WITH GEAR
 Powerfactor : 0.90
 POWER TURBINE 6600 RPM

Run results.

=====

Run id	Amb. temp. F	R.H %	Load Case %	Output kW	el eff. %	Heat Rate Btu/kWh	Fuel flow pps	IGV angle	Exh. temp. F	Exh. flow pps
1	42.0	60.0	100.00	47433	36.96	9231	5.878	1.20	1013.15	294.63
2	42.0	60.0	75.00	35575	34.18	9984	4.769	-25.57	1073.27	233.45
3	42.0	60.0	50.00	23717	29.16	11702	3.726	-40.00	1109.72	188.95

EXHAUST GAS COMPOSITION

RUNID		SO2	H2O	CO2	N2	O2	Ar	He
1	% WT:	0.0000	4.599	5.405	73.788	14.95	1.253	0.000
1	% VOL:	0.0000	7.272	3.498	75.025	13.31	0.893	0.000
2	% WT:	0.0000	4.701	5.533	73.753	14.76	1.252	0.000
2	% VOL:	0.0000	7.430	3.579	74.963	13.13	0.893	0.000
3	% WT:	0.0000	4.550	5.343	73.806	15.04	1.253	0.000
3	% VOL:	0.0000	7.195	3.459	75.056	13.39	0.894	0.000

We reserve all rights in this document and in the information contained therein. Reproduction, use or disclosure to third Parties without express authority is strictly forbidden.
 © Siemens Industrial Turbomachinery AB