

From: [Gregory Darwin](#)
To: [Kathleen Truesdell](#);
CC: ["Jim McLucas"](#);
Subject: FW: OGS - Description of Startup and Shutdown Sequences for BAAQMD
Date: Friday, June 04, 2010 4:10:29 PM
Attachments: RR Overview final.doc

Hi Kathleen. Attached is the GE write-up that GE has prepared showing the sequence of the Rapid Response design.

Also, I have attached the estimated fuel use during startup and shutdown. We would not like to establish these as permit limits as these are for reference only.

These values are for a single CT (i.e. total plant numbers will be double).

Hot Start – 269 MMBtu (HHV)
Warm Stat – 269 MMBtu (HHV)
Cold Start – 909 MMBtu (HHV)
Shutdown – 450 MMBtu (HHV)

Please let me know if you have other questions.

Gregory Darwin
Atmospheric Dynamics, Inc.
2925 Puesta del Sol
Santa Barbara, CA 93105
darwin@atmosphericdynamics.com
805.569.6555 (p)
805.569.6558 (f)