

Kathleen Truesdell

From: Jim McLucas <jim.mclucas@radback.com>
Sent: Friday, January 21, 2011 11:18 AM
To: Kathleen Truesdell
Cc: 'Greg Darwin'
Subject: RE: Oakley FDOC DRAFT

Kathleen -

This works for us.

Thanks!

- Jim

-----Original Message-----

From: Kathleen Truesdell [mailto:ktruesdell@baaqmd.gov]
Sent: Friday, January 21, 2011 10:10 AM
To: Jim McLucas
Cc: Greg Darwin
Subject: RE: Oakley FDOC DRAFT

Jim,

We are proposing the following language:

1. Commissioning Period:

The Commissioning Period shall commence when all mechanical, electrical, and control systems are installed and individual system start-up has been completed, or when a gas turbine is first fired, whichever occurs first. The Commissioning Period for each gas turbine shall terminate when the activities identified in the Commissioning Plan (submitted under Part 4 below) are complete and the gas turbine has reached safe and reliable steady-state operation as demonstrated by compliance with NOx and CO normal operating limits using the continuous emissions monitors.

2. initial source testing (Conditions 24 to 28 in the Oakley FDOC DRAFT.doc file I sent yesterday).

Within 90 days of the beginning of the start-up period (as defined in Regulation 2-1-210) of each of the OGS GE 7FA units or as otherwise approved by the APCO,...

Please let me know ASAP if you agree to these changes.

Thanks,
Kathleen

-----Original Message-----

From: Jim McLucas [mailto:jim.mclucas@radback.com]
Sent: Thursday, January 20, 2011 3:30 PM

To: Kathleen Truesdell
Cc: 'Greg Darwin'
Subject: RE: Oakley FDOC DRAFT

Kathleen -

Our comments are embedded in the attached. We have only two comments:

1. Definition of Commissioning Period
2. Condition 26 - we'd like "startup" to be defined

Please give us a call if you'd like to discuss our comments (call Greg Darwin and he will add me on).

Thanks!

- Jim

-----Original Message-----

From: Kathleen Truesdell [mailto:ktruesdell@baaqmd.gov]
Sent: Thursday, January 20, 2011 9:37 AM
To: Jim McLucas
Cc: Greg Darwin; Greg Lamberg
Subject: Oakley FDOC DRAFT

<<Oakley FDOC DRAFT.doc>> Jim,

Please review the attached draft FDOC.

If you have any comments, please "accept all" changes from my document and then track changes for your edits, so I can find them easier.

As we are preparing to issue tomorrow, I need any comments (especially on any permit conditions) by 7am tomorrow morning.

Thanks,
Kathleen Truesdell
Air Quality Engineer
Bay Area Air Quality Management District Phone (415)749-4628 Fax
(415)749-5030