



BAY AREA
AIR QUALITY
MANAGEMENT
DISTRICT

PUBLIC NOTICE

August 8, 2014

TO: Parents or guardians of children enrolled at the following school(s):
La Paloma High School

All residential and business neighbors located within 1,000 feet of the proposed new or modified source(s) of air pollution listed below.

FROM: Bay Area Air Quality Management District

RE: Permit Application #26176 for the following source of air pollution:
Stationary Emergency Generator- Diesel Engine
The City of Brentwood Police Department
9100 Brentwood Blvd.
Brentwood, CA 94513

The Bay Area Air Quality Management District (the "District") is a local agency that regulates stationary sources of air pollution such as factories, industrial sites, and gasoline stations.

Whenever we receive a permit application for a new or modified source(s) of toxic air contaminants located within 1,000 feet of a school site, State law requires that we notify the public. To comply with this requirement, we distribute or mail a Public Notice to the parents or guardians of students enrolled at schools located within ¼ mile, and all residents and businesses located within 1,000 feet, of the proposed source(s).

You are receiving this Public Notice because a permit application has been filed with the District for the above referenced source of air pollution. A description of the proposed project follows:

The City of Brentwood Police Department has applied for a Permit to Operate a Stationary Emergency Diesel Engine Powered Generator at 9100 Brentwood Blvd., Brentwood, CA 94513. It will be used to generate power during emergency conditions only. The emergency engine will be tested periodically, not more than 50 hours per year, to ensure that it will generate electricity when needed. Testing is not allowed to occur between 7:30 am and 3:30 pm on days when school is in session including times when any school sponsored activities are scheduled.

PRELIMINARY EVALUATION

The District has evaluated the permit application for the proposed project and determined that the project will comply with all applicable District, state, and federal air quality-related regulations, including the health risks resulting from toxic air contaminant emissions. The preliminary recommendation is to issue a permit for this project. A final determination will be made after considering all comments received.

ADDITIONAL INFORMATION

If you are interested in getting more information, you may request copies of the the District's evaluation report by calling the District at the telephone number listed at the end of this notice. This information is also accessible on the District website at:

<http://www.baaqmd.gov/Divisions/Engineering/Public-Notices-on-Permits.aspx>

PUBLIC COMMENT PERIOD

There is a 30-day period for public response to this proposal. If you wish to comment on the proposed project, you may do so in writing or by e-mail. Alternatively, you may call and leave a telephone message up to one minute in length. Please leave your name and telephone number so that a District staff member may respond to your message.

Please use the following contact information if you would like to comment on the proposed project:

Mailing address: City of Brentwood (A/N 26176)
Public Notice Response
BAAQMD
Engineering Division
939 Ellis Street
San Francisco, CA 94109
Attn: Anne Werth

E-mail address: awerth@baaqmd.gov

Telephone Number: (415) 749-5155

The public comment period for this project ends on September 6, 2014.