

February 9, 2005

Ms. Deborah Jordan
Director, Air Management Division
United States Environmental Protection Agency
75 Hawthorne Street
San Francisco, CA 94105

Dear Ms. Jordan:

The requirement for public and EPA review for the renewal of the Major Facility Review and Acid Rain Permit for the following facility has been completed.

ALAMEDA COUNTY

Roberta Cooper
Scott Haggerty
(Chairperson)
Nate Miley
Shelia Young

CONTRA COSTA COUNTY

Mark DeSaulnier
Erling Horn
Mark Ross
Gayle Uilkema
(Secretary)

MARIN COUNTY

Harold C. Brown, Jr.

NAPA COUNTY

Brad Wagenknecht

SAN FRANCISCO COUNTY

Chris Daly
Jake McGoldrick
Gavin Newsom

SAN MATEO COUNTY

Jerry Hill
Marland Townsend
(Vice-Chairperson)

SANTA CLARA COUNTY

Erin Garner
Liz Kniss
Patrick Kwok
Julia Miller

SOLANO COUNTY

John F. Silva

SONOMA COUNTY

Tim Smith
Pamela Torliatt

Jack P. Broadbent
EXECUTIVE OFFICER/APCO

Plant	Plant Name	Application	Permit Engineer	City	County
A0026	Mirant Potrero, LLC.	6441, 7181	D. Van Buren	San Francisco	San Francisco

The public comment procedures for this permit have been completed as follows: The public notice for this permit was published in the San Francisco Chronicle on March 30, 2004. The notice stated that the end of the public comment period was May 13, 2004. The notice announced a public hearing on May 6, 2004, at the Potrero Hill Neighborhood House (Theater) at 953 De Haro Street, San Francisco, CA from 6:30 p.m. to 9 p.m., which was held as planned. Written comments were also received from the public and various agencies.

In response to comments from Mirant, BAAQMD Regulation 9-11-302 and 9-11-302.1 were retained as applicable requirements, BAAQMD Regulation 9-11-309.3 and 9-11-309.4 were changed to be not federally enforceable, all references to diesel oil for S1, Boiler, were changed to fuel oil, the CEMS requirement in Permit Condition ID# 21294 to measure O2 was expanded to either O2 or CO2 and the S10 through S15, Turbine output and firing capacity were increased.

A Compliance Assurance Monitoring (CAM) plan was added for sources S10 through S15, Turbines, in response to a verbal comment from EPA received prior to July 22, 2004. On July 22, 2004, the District transmitted the revised proposed permit and the evaluation report/statement of basis to the US EPA for US EPA review. The 45-day US EPA review period ended on September 5, 2004. The US EPA did not comment on either the revised proposed permit or the evaluation report/statement of basis. However, we have since corrected the language of Standard Condition L, Conditions to Implement Regulation 2, Rule 7, Acid Rain, to be consistent with 40CFR72.2.

The District has not made any other changes due to comments. The District has responded formally to comments and will post those responses on our website.

Enclosed is a copy of the final revised permit. If you have any questions regarding this permit, please call Steve A Hill, Air Quality Engineering Manager, at (415) 749-4673.

Sincerely yours,

Jack P. Broadbent
Executive Officer / APCO

BFB:SAH:myl

H:\PUB_DATA\TITLE V Permit Appls\A0026\Renew -\1.0 Working docs\A0026-Issuance.doc