Anheuser-Busch LLC- Fairfield Brewery

BAAQMD Plant #: A0606

Permit Condition #13032

S-1, S-2, S-3 Cummulative Boiler Fuel Usage (MMBTUs)

2014 - 15

Month	Fuel Usage	12 Month Consecutive
September	24981	302063
October	24007	300454
November	22581	298462
December	25682	298347
January	25923	324270
February	23828	348098

Anheuser-Busch LLC - Fairfield Brewery

BAAQMD Plant #: A0606

Permit Condition #13032

S-1 Boiler Fuel Usage (MMBTUs)

Limit: 1,042,440 MMBTU for any consecutive 12-month period

2014 - 15

Month	Fuel Usage	12 Month Consecutive
September	13845	38668
October	2227	39776
November	0	35808
December	0	35808
January	0	35808
February	0	35808

Anheuser-Busch LLC- Fairfield Brewery

BAAQMD Plant #: A0606

Permit Condition #13032

S-2 Boiler Fuel Usage (MMBTUs)

Limit: 1,042,440 MMBTU for any consecutive 12-month period

2014 - 15

Month	Fuel Usage	12 Month Consecutive
September	**10668**	109705
October	**21626**	106857
November	**20595**	121910
December	**916**	122627
January	**19748**	142375
February	**2123**	144498

Anheuser-Busch LLC - Fairfield Brewery

BAAQMD Plant #: A0606

Permit Condition #13032

S-3 Boiler Fuel Usage (MMBTUs)

Limit: 1,042,440 MMBTU for any consecutive 12-month period

2014 - 15

Month	Fuel Usage	12 Month Consecutive
September	**468**	153690
October	**154**	153821
November	**1986**	140744
December	**24766**	139912
January	**6175**	146087
February	**21705**	167792

Anheuser-Busch LLC - Fairfield Brewery

BAAQMD Plant #: A0606

Permit Condition # 16202

S-75, -76, -77, -78, -120, -128, -131, -132, -133, -138, -146, -147, -161, -162, -171, -172, -173, -174, -175, -176, -177, -178

12 Month Limit: Ink 1339 gallons; Solvent thinner 569 gallons; Acetone 90 gallons

POC Emission Limit: 17370 pounds per consecutive 12 months from all sources, NPOC Emission Limit: 603 pounds per consecutive 12 months from all sources

NOTE Ink usage and related POC emissions for S-169 and S-170 have separate limits and are tracked on a separate logsheet. Beginning in Jan. 2009, usage of 16-8200 and 16-8205 attributed to S-169 and S-170 have been deducted from the totals below.

Month & Year	Video-Jet Ink 16-8200 (Qt)	Video-Jet Solvent 16-8205 (Qt)	Diagraph TWP-101 Black Ink (5 Gal Pail)	Diagraph TWP-101 Conditioner (5 Gal Pail)	Linx Ink 3103 (1/2 Ltr)	Linx Solvent 3501 (1/2 Ltr)	Scan Trac II Ink Jet Ink (Liter)	Video-Jet Ink V410-D (750 ml)	Video-Jet Make up V705-D (750 ml)	Video-Jet Conditioner V001-Q (Liter)	Monthly Ink Usage (Gal)	Monthly Solvent Usage (Gal)	Monthly Acetone Usage (Gal)	12 Month Ink Usage (Gal)	12 Month Solvent Usage (Gal)	12 month Acetone Usage (Gal)	Monthly POC Emission (Lb.)	Monthly NPOC Emission (Lb.)	12Month POC Emission (Lb.)	12Month NPOC Emission (Lb.)
SAP #	1812066	1206384	1369178	1326520	1318353	1318352	1568880	1745231	1745232	1722033										
CIS #	03528-000	00152-000	16810-000	06050-000	13635-000	13694-000	27321-000	45683-000	45684-000	42559-0000										
Density lb/gal	7.52	6.68	8.84	8.39	7.52	6.68	8.35	6.68	6.68	7.52										
Density lb/unit	1.88	1.67	44	42	0.99	0.88	2.20	1.34	1.34	1.98										
% POC	71	100	20	40	47.5	20	80	67.00	100	100										
lbs POC/unit	1.33	1.67	8.84	16.78	0.47	0.18	1.76	0.90	1.34	1.98										
% NPOC	0	0	0	0	47.5	80	20	0	0	0										
lbs NPOC/unit	0.00	0.00	0.00	0.00	0.47	0.71	0.44	0.00	0.00	0.00										
September-14	18	81	1	0	0	20	11	6	6	0	14	24.21	2.11	131.6	238.3	37.0	192.38	18.96	1803.5	267.2
October-14	9	54	1	0	0	30	1	18	12	2	11	20.57	3.17	127.4	235.8	35.9	119.41	21.60	1746.0	259.2
November-14	9	27	1	0	0	10	1	12	7	0	10	9.53	1.06	124.6	229.4	33.8	70.79	7.49	1700.5	244.7
December-14	0	0	1	0	0	20	9	0	24	3	7	8.35	2.11	123.1	216.0	29.6	29.57	18.08	1596.6	217.8
January-15	0	0	1	0	0	20	0	12	20	2	7	7.29	2.11	121.7	209.3	29.6	13.70	14.11	1483.2	216.0
February-15	0	0	0	0	0	10	0	14	36	0	3	8.58	1.06	112.2	201.6	28.5	1.76	7.05	1358.9	209.0

NOTE: Beginning February 2009, Videojet Ink & Solvent for Line 1 are subtracted from the totals above and tracked on a separate spreadsheet

Anheuser-Busch LLC - Fairfield Brewery

BAAQMD Plant #: A0606

Permit Condition #9061

S-134 & S-137 Total Filtering Aid Loading Throughputs

Permit Limit: 222 tons during 12 month consecutive period

	Summary (tons)	Summary (tons)	Consecutive Summary	Consecutive Summary
Month	*Filter Aid 2014*	*Filter Aid 2015*	*12 MONTH TOTAL 14*	*12 MONTH TOTAL 15*
JAN	0.2	0.2	3.2	3.3
FEB	0.2	0.2	3.2	3.3
MAR	0.2		3.2	
APR	0.3		3.0	
MAY	0.3		3.2	
JUN	0.3		3.2	
JUL	0.3		4.6	
AUG	0.3		4.3	
SEP	0.3		4.0	
OCT	0.3		3.7	
NOV	0.2		3.5	
DEC	0.3		3.3	
Sum	3.25	0.48		

Note: In November 2011, the filtering aid ACP was replaced with Tannin. S-134 is not utilized with tannin.

Anheuser-Busch LLC- Fairfield Brewery

BAAQMD Plant #: A0606

Permit Condition #8195

S-135 Railcar Fumigation Venting

Permit Limit: 2,190 rail cars in a 12 month period

		Number of railcars unloaded		*12 Month Total Railcars Unloaded*	*12 Month Total Railcars Unloaded*
Month	*2014*	*2015*		2014	2015
JAN	0	0		62	67
FEB	0	0		62	67
MAR	0			62	
APR	0			62	
MAY	2			63	
JUN	8			60	
JUL	12			63	
AUG	15			64	
SEP	7			58	
OCT	15			66	
NOV	6			65	
DEC	2			67	
Sum	67	0			

No fumigants are added to railcars at this facility.

Anheuser-Busch LLC - Fairfield Brewery

BAAQMD Plant #: A0606

Permit Condition #17177

S-141, 142 Fumigation of Milling Operations

Limit: 240 lbs. of phosphine gas in any consecutive 12-month period

Fumigant Usage (lbs.)

Quarter	*2014*	*2015*
1st	0.00	0 as of 03/17/2015
2nd	0.00	
3rd	0.00	
4th	0.00	
Sum	0.00	0.00

12 MONTH TOTAL 14	*12 MONTH TOTAL 15*
4.10	**0.00**
4.10	
4.10	
0.00	

1st Quarter is through March.
2nd Quarter is through June.
3rd Quarter is through September.
4th Quarter is through December.

Anheuser-Busch LLC- Fairfield Brewery

BAAQMD Plant #: A0606

Permit Condition #20632(3) & 21639(2)

S-149, S-150, S-151, & S-158 Total Beer Throughput

Limit: 6,351,088 bbls of beer per consecutive 12 month period

	Production Summary (BBLs)	*Production Summary (BBLs)*		*12 Month Consecutive Summary*	*12 Month Consecutive Summary*
Month	***2014***	***2015***		***12 MONTH TOTAL 14***	***12 MONTH TOTAL 15***
JAN	320,158	242,453		3,092,802	3,187,688
FEB	255,176	255,176		3,454,992	3,430,142
MAR	279,151			3,469,699	
APR	302,372			3,456,287	
MAY	311,474			3,460,996	
JUN	313,572			3,461,650	
JUL	320,240			3,455,255	
AUG	314,515			3,582,570	
SEP	295,312			3,571,201	
OCT	298,436			3,554,139	
NOV	213,769			3,500,371	
DEC	283,672			3,507,847	
Sum	3,507,847	497,629			

****New brewhouse went online on 1/07/2005**

Anheuser-Busch LLC- Fairfield Brewery

BAAQMD Plant #: A0606

Permit Condition #20632 (1 & 2)

S-149, S-150, & S-151 Lauter Tub and Brew Kettle Throughput

Limit: 4,441,320 bbls of wort per consecutive 12 month period

	Production Summary (BBLs)			***12 Month Consecutive Summary***	***12 Month Consecutive Summary***
Month	***2014***	***2015***		***12 MONTH TOTAL 14***	***12 MONTH TOTAL 15***
JAN	213,612	177,486		2,290,877	2,161,349
FEB	171,945	171,674		2,288,543	2,161,078
MAR	167,377			2,261,736	
APR	191,512			2,273,059	
MAY	216,828			2,296,757	
JUN	204,692			2,298,677	
JUL	182,395			2,271,936	
AUG	176,733			2,226,198	
SEP	187,887			2,235,612	
OCT	164,847			2,216,091	
NOV	159,153			2,200,067	
DEC	160,494			2,197,475	
Sum	2,197,475				

****New brewhouse went online on 1/07/2005**

Anheuser-Busch LLC- Fairfield Brewery

BAAQMD Plant #: A0606 Permit Condition # 21595 (1) & 21639 (1)

S-154, 155 & 158 Weekly Filler Rate

S-158 = 1,800 bottle/min, S-154 = 1,560 cans/min,
S-155 = 1,565 cans/min, S-168 = 2.124MMBls/12 months

Week	Line 01 (1800 bottles) Source 158	(New) Line 40 (2.124 MMbls/12 months) Source 168 (BBLS/WEEK)	Line 50 (weekly can throughput) Source 155 (CAN/Week)	Line 50 (1565 cans) Source 155 (CAN/MIN)
9/1/2014	0	32,723	10,186,668	1,292
9/8/2014	0	31,546	9,542,448	1,373
9/15/2014	0	33,753	9,718,380	1,249
9/22/2014	0	33,839	7,451,328	1,227
9/29/2014	0	29,610	15,993,444	1,733
10/6/2014	0	34,386	10,203,822	1,370
10/13/2014	0	35,491	10,407,774	1,250
10/20/2014	0	30,654	7,718,466	1,412
10/27/2014	0	28,083	8,359,500	1,162
11/3/2014	0	26,188	11,621,328	1,239
11/10/2014	0	32,206	9,210,288	1,223
11/17/2014	0	22,246	5,576,556	1,257
11/24/2014	0	11,492	7,025,490	1,134
12/1/2014	0	22,236	11,394,900	1,160
12/8/2014	0	36,248	10,282,830	1,254
12/15/2014	0	30,631	11,508,546	1,194
12/22/2014	0	23,256	8,302,740	1,249
12/29/2014	0	26,579	8,260,488	1,425
1/5/2015	0	27,948	6,521,682	1,055
1/12/2015	0	29,589	5,279,940	1,252
1/19/2015	0	28,108	7,880,730	1,143
1/26/2015	0	28,498	6,947,658	1,288
2/2/2015	0	31,034	8,835,084	1,177
2/9/2015	0	30,882	6,139,056	946
2/16/2015	0	24,871	8,019,222	1,232
2/23/2015	0	31,373	9,159,036	1,050

Note: Line 40 (S- 154) was replaced during the summer of 2008.

The beer packaged during the engineering run was not saleable beer.

Anheuser-Busch LLC- Fairfield Brewery

BAAQMD Plant #: A0606

Permit Condition # 21369 (2) S - 158 = 6,351,088 barrels/12 months
Permit Condition # 23956 (1) S - 168 = 2,124,000 barrels/12 months

Month	Source 158 Line 01 Monthly Barrels	Source 158 Line 01 (6,351,088 barrels/12 month)	Source 168 Line 40 Monthly Barrels	Source 168 Line 40 (2,124,000 barrels/12 months)
September-14	0	0	145551.05	1,702,260.97
October-14	0	0	142577.35	1,686,475.98
November-14	0	0	94087.66	1,662,141.42
December-14	0	0	126163.54	1,660,731.09
January-15	0	0	126928.9	1,637,404.11
February-15	0	0	116725.71	1,637,404.11

Anheuser-Busch LLC - Fairfield Brewery

BAAQMD Plant #: A0606

Permit Condition # 21610

S-156 Emergency Standby Diesel Engine

Limit: For emergency use or 100 hours/calendar year for reliability testing

	Reliability Testing (Hrs)	*Reliability Testing (Hrs)*
Month	**2014**	**2015**
JAN	0.0	0.1
FEB	0.2	0.5
MAR	0.0	
APR	0.1	
MAY	0.0	
JUN	0.0	
JUL	0.0	
AUG	1.0	
SEP	0.5	
OCT	0.1	
NOV	0.8	
DEC	0.2	
TOTAL	**2.9**	**0.6**

	Emergency Testing (Hrs)	*Emergency Testing (Hrs)*
(Standby Eng)	**2014**	**2015**
JAN	0	0
FEB	0	0
MAR	0	
APR	0	
MAY	0	
JUN	0	
JUL	0	
AUG	0	
SEP	0	
OCT	0	
NOV	0	
DEC	0	
TOTAL	**0**	**0**

Anheuser-Busch LLC- Fairfield Brewery

BAAQMD Plant #: A0606

Permit Condition # 22850

S-165 Stationary Diesel Engine

Limit: For emergency use or 50 hours/calendar year for reliability testing

	Reliability Testing (Hrs)	
Month	***2014***	***2015***
JAN	0.10	0.20
FEB	0.00	0.00
MAR	0.00	
APR	0.00	
MAY	0.00	
JUN	0.00	
JUL	1.80	
AUG	0.00	
SEP	0.00	
OCT	0.10	
NOV	0.00	
DEC	0.00	
TOTAL	2.0	0.2

	Emergency Conditions (Hrs)	
(Generators)	***2014***	***2015***
JAN	0	0
FEB	0	0
MAR	0	
APR	0	
MAY	0	
JUN	0	
JUL	0	
AUG	0	
SEP	0	
OCT	0	
NOV	0	
DEC	0	
TOTAL	0	0

	Emission Testing (Hrs)	
Month	***2014***	***2015***
JAN	0	0
FEB	0	0
MAR	0	
APR	0	
MAY	0	
JUN	0	
JUL	0	
AUG	0	
SEP	0	
OCT	0	
NOV	0	
DEC	0	
TOTAL	0	0

Anheuser-Busch LLC- Fairfield Brewery

BAAQMD Plant #: A0606

Permit Condition # 23750

S-166 and S-167 BERS Biogas H2S

Limit: 52 week rolling average not to 200 ppmv

Year	Week #	Biogas H2S (ppmv)	52-Week Rolling Average Not to exceed 200 ppmv	
2014	37	57.86	128.54	
	38	55.71	125.87	
	39	58.57	123.31	
	40	78.57	121.09	
	41	147.14	121.21	
	42	0.00	117.69	
	43	115.71	116.06	
	44	99.29	115.36	
	45	96.43	114.62	
	46	114.29	114.93	
	47	83.57	114.97	
	48	88.57	114.85	
	49	68.57	114.63	
	50	38.57	113.93	
	51	55.71	114.34	
	52	52.86	113.02	
2015	1	54.29	111.22	
	2	58.57	110.33	
	3	52.86	109.07	
	4	42.86	107.06	
	5	52.86	105.81	
	6	72.86	106.33	
	7	115.00	105.63	
	8	197.86	106.69	
	9	191.43	107.05	

From Andy Messer's Op Data Report

Anheuser-Busch LLC - Fairfield Brewery

BAAQMD Plant #: A0606

Permit Condition # 23750

S-166 and S-167 BERS Offgas H2S

Limit: 52 week rolling average not to 10 ppmv

		Offgas H2S	52-Week Rolling Average
2014	37	0.86	0.56
	38	1.29	0.57
	39	1.14	0.57
	40	1.14	0.58
	41	1.14	0.61
	42	0.00	0.59
	43	1.00	0.55
	44	0.57	0.52
	45	1.57	0.55
	46	1.57	0.58
	47	1.86	0.62
	48	0.71	0.63
	49	1.00	0.65
	50	0.86	0.67
	51	1.14	0.69
	52	1.71	0.72
2015	1	1.00	0.74
	2	1.71	0.76
	3	1.71	0.77
	4	1.14	0.79
	5	1.00	0.81
	6	1.14	0.83
	7	1.14	0.85
	8	0.86	0.86
	9	1.29	0.89

Anheuser-Busch LLC- Fairfield Brewery

BAAQMD Plant #: A0606

Permit Condition # 23750

S-166 and S-167 BERS Boiler Flare Ratio

Limit: 52 week rolling average not to 10%

Year	Week #	Biogas Production (cubic feet)	Biogas Flared (cubic feet)	Ratio of Biogas Flared to Produced (%)	Ratio of Biogas Flared to Produced 52-Week Rolling Average Not to exceed 10%
2014	37	1333859.0	0.0	0.00	0.61
	38	1198589.6	1567.0	0.13	0.56
	39	1096596.6	5476.0	0.50	0.49
	40	1176340.0	0.0	0.00	0.49
	41	1210911.5	0.0	0.00	0.47
	42	1229487.0	0.0	0.00	0.47
	43	1053992.2	0.0	0.00	0.45
	44	989523.8	0.0	0.00	0.31
	45	1061281.8	0.0	0.00	0.30
	46	1007982.5	0.0	0.00	0.13
	47	1046510.5	1860.0	0.18	0.13
	48	847611.2	98869.0	11.66	0.28
	49	1065900.7	0.0	0.00	0.28
	50	939249.3	0.0	0.00	0.28
	51	918720.3	2177.0	0.24	0.29
	52	887661.4	0.0	0.00	0.29
	1	825520.4	107.0	0.01	0.29
	2	1127320.3	0.0	0.00	0.29
	3	992514.1	1598.0	0.16	0.27
	4	926778.8	18501.0	2.00	0.31
	5	1093454.7	1092.0	0.10	0.31
	6	1237777.6	11454.0	0.93	0.32
	7	1288647.8	92.0	0.01	0.33
	8	1110396.4	20068.0	1.81	0.36
	9	1322566.8	889.0	0.07	0.36

From UPA report

Anheuser-Busch LLC - Fairfield Brewery

BAAQMD Plant #: A0606

Permit Condition # 23750

S-166 and S-167 BERS WW Throughput

Limit: 12 month rolling average not to exceed 778 MM Gallons

Month	Wastewater Throughput (MM Gallons)	Wastewater Throughput 12-Month Rolling Average	Wastewater Total for 12 month period Not to Exceed 778 MM Gallons
September-14	15.11	15.32	183.80
October-14	14.78	15.22	182.62
November-14	13.09	15.08	180.95
December-14	15.13	15.13	181.60
January-15	12.33	14.83	177.93
February-15	10.91	14.47	173.67

From Monthly Master WW data sheet

Anheuser-Busch LLC - Fairfield Brewery

BAAQMD Plant #: A0606

Permit Condition # 23750

S-166 and S-167 Daily Biogas Production Log

DATE	BIOGAS PRODUCTION (cubic feet)
9/1/2014	161,781
9/2/2014	166,074
9/3/2014	189,415
9/4/2014	205,281
9/5/2014	172,115
9/6/2014	180,043
9/7/2014	180,063
9/8/2014	192,134
9/9/2014	193,439
9/10/2014	188,835
9/11/2014	195,188
9/12/2014	198,192
9/13/2014	186,007
9/14/2014	153,551
9/15/2014	184,485
9/16/2014	189,495
9/17/2014	174,335
9/18/2014	174,345
9/19/2014	178,183
9/20/2014	144,196
9/21/2014	148,652
9/22/2014	162,763
9/23/2014	179,778
9/24/2014	173,890
9/25/2014	133,609
9/26/2014	141,832
9/27/2014	156,072
9/28/2014	124,333
9/29/2014	170,387
9/30/2014	173,558
10/1/2014	157,062
10/2/2014	183,543
10/3/2014	170,892
10/4/2014	196,565
10/5/2014	214,523
10/6/2014	219,569
10/7/2014	186,292
10/8/2014	132,193

Source of Data: UPA Data imported to 010310 to 020610 Biogas and Offgas.xls

10/9/2014	155,773
10/10/2014	149,999
10/11/2014	152,562
10/12/2014	181,972
10/13/2014	158,960
10/14/2014	189,572
10/15/2014	177,057
10/16/2014	179,953
10/17/2014	160,994
10/18/2014	180,979
10/19/2014	177,861
10/20/2014	146,318
10/21/2014	166,198
10/22/2014	151,192
10/23/2014	148,716
10/24/2014	130,372
10/25/2014	133,335
10/26/2014	92,571
10/27/2014	121,489
10/28/2014	163,539
10/29/2014	178,004
10/30/2014	151,657
10/31/2014	148,485
11/1/2014	133,780
11/2/2014	120,130
11/3/2014	147,335
11/4/2014	153,501
11/5/2014	167,908
11/6/2014	148,610
11/7/2014	157,497
11/8/2014	166,301
11/9/2014	135,321
11/10/2014	139,551
11/11/2014	129,903
11/12/2014	146,163
11/13/2014	142,522
11/14/2014	152,225
11/15/2014	162,298
11/16/2014	112,453
11/17/2014	143,667
11/18/2014	133,011
11/19/2014	146,774
11/20/2014	139,007
11/21/2014	122,194
11/22/2014	87,107
11/23/2014	96,026
11/24/2014	162,788
11/25/2014	178,434
11/26/2014	156,076
11/27/2014	95,778
11/28/2014	67,263
11/29/2014	91,247
11/30/2014	134,825
12/1/2014	140,672

Source of Data: UPA Data imported to 010310 to 020610 Biogas and Offgas.xls

12/2/2014	164,472
12/3/2014	153,818
12/4/2014	136;769
12/5/2014	162,794
12/6/2014	172,551
12/7/2014	150,745
12/8/2014	142,635
12/9/2014	120,967
12/10/2014	117,496
12/11/2014	115,668
12/12/2014	140,540
12/13/2014	151,198
12/14/2014	157,415
12/15/2014	144,685
12/16/2014	132,503
12/17/2014	109,597
12/18/2014	93,976
12/19/2014	135,339
12/20/2014	145,205
12/21/2014	160,225
12/22/2014	178,164
12/23/2014	172,561
12/24/2014	99,280
12/25/2014	48,074
12/26/2014	88,932
12/27/2014	140,426
12/28/2014	130,522
12/29/2014	179,836
12/30/2014	150,416
12/31/2014	73,806
1/1/2015	53,814
1/2/2015	109,919
1/3/2015	127,209
1/4/2015	121,937
1/5/2015	185,618
1/6/2015	202,140
1/7/2015	184,112
1/8/2015	182,371
1/9/2015	119,313
1/10/2015	131,829
1/11/2015	142,512
1/12/2015	160,011
1/13/2015	144,868
1/14/2015	139,541
1/15/2015	138,137
1/16/2015	133,551
1/17/2015	133,894
1/18/2015	132,529
1/19/2015	97,535
1/20/2015	116,929
1/21/2015	121,148
1/22/2015	129,866
1/23/2015	158,720
1/24/2015	170,052

Source of Data: UPA Data imported to 010310 to 020610 Biogas and Offgas.xls

1/25/2015	137,244
1/26/2015	131,124
1/27/2015	146,314
1/28/2015	167,161
1/29/2015	167,857
1/30/2015	169,116
1/31/2015	174,638
2/1/2015	159,427
2/2/2015	154,351
2/3/2015	168,312
2/4/2015	198,835
2/5/2015	200,817
2/6/2015	183,530
2/7/2015	172,506
2/8/2015	157,985
2/9/2015	180,032
2/10/2015	191,601
2/11/2015	188,400
2/12/2015	177,461
2/13/2015	201,489
2/14/2015	191,679
2/15/2015	88,366
2/16/2015	111,566
2/17/2015	118,990
2/18/2015	201,162
2/19/2015	215,731
2/20/2015	194,162
2/21/2015	180,420
2/22/2015	154,366
2/23/2015	147,828
2/24/2015	190,903
2/25/2015	199,324
2/26/2015	202,753
2/27/2015	211,631
2/28/2015	215,762

Source of Data: UPA Data imported to 010310 to 020610 Biogas and Offgas.xls

Anheuser-Busch LLC- Fairfield Brewery

BAAQMD Plant #: A0606

Permit Condition # 8A

S-167 Flare

Condition 8 of the Permit to Operate states: Owner/operator shall maintain the minimum temperature of S-167 flare at not less than 1400 degrees F.

Condition 8A of the Permit to Operate states:

> This condition shall only apply when the biogas supply valves to all boilers are closed and biogas flaring exceeding 300 cfm occurs longer than 15 minutes continuously.

For the period of September 1, 2014 to February 28, 2015 no conditions of 8 or 8A have occurred.

Anheuser-Busch LLC - Fairfield Brewery

BAAQMD Plant #: A0606

Permit Condition # 24244

S-169, S-170

12 Month Limit: Ink 6 gallons; Solvent thinner 19 gallons

POC Emission Limit: 303.4 pounds per consectutive 12 months from each source

Note: Usage of 16-8200 and 16-8205 attributed to S-75, -76, -77, -78, -120, -128, -131, -132, -133, -138, -146, -147, -161, -162 is tracked on a separate logsheet.

Month & Year	Total Line 1 Video-Jet Ink 16-8200 (Qt)	Total Line 1 Video-Jet Solvent 16-8205 (Qt)	Total Line 1 Rolling Rock/RRL Produced (BBLS)	Total Line 1 Production (BBLS)	Ink Usage Attributed to S-169 & S-170 (Qt)	Solvent Usage Attributed to S-169 & S-170 (Qt)	Monthly Ink Usage (Gal)	Monthly Solvent Usage (Gal)	12 Month Ink Usage (Gal)	12 Month Solvent Usage (Gal)	Monthly POC Emission (Lb.)	12-Month POC Emission (Lb.)
SAP #	1012066	1206384										
CTS #	03528-000	00152-000										
Density lb/gal	7.52	6.68										
Density lb/unit	1.88	1.67										
% POC	71	100										
lbs POC/unit	1.33	1.67										
% NPOC	0	0										
lbs NPOC/unit	0.00	0.00										
September-13	0	0	0	0	0	0	0	0	0	0	0.00	0
September-14	0	0	0	0	0	0	0	0	0	0	0.00	0
October-14	0	0	0	0	0	0	0	0	0	0	0.00	0
November-14	0	0	0	0	0	0	0	0	0	0	0.00	0
December-14	0	0	0	0	0	0	0	0	0	0	0.00	0
January-15	0	0	0	0	0	0	0	0	0	0	0.00	0
February-15	0	0	0	0	0	0	0	0	0	0	0.00	0

Line 1 was idled on April 28,2010.

Anheuser-Busch LLC- Fairfield Brewery

BAAQMD Plant #: A0606
Permit Chart IIB
Condition #17176

PRESSURE DROP (INCHES OF WATER)

Month	***A-12*** *(0.5-6 in)*	***A-36*** *(0.5-6 in)*	***A-51*** [b] *(1-6 in.)*	***A-54*** *(1-6 in.)*	***A-126*** *(0.5-6 in)*	***A-125*** [a] *(0.25-3 in)*	***A-130*** *(0.5-4 in)*
Sep-14	5.19	0.95	5.06	4.64	N/A	N/A	0.82
Oct-14	5.08	1.10	2.07	5.15	N/A	N/A	1.11
Nov-14	5.67	N/A	2.20	1.76	N/A	N/A	0.69
Dec-14	3.61	N/A	4.40	5.42	N/A	N/A	0.96
Jan-15	3.74	N/A	4.79	1.09	N/A	N/A	0.76
Feb-15	3.89	N/A	2.89	3.69	N/A	N/A	0.93

* N/A = Not in operation during this month (no bagged DE/Perlite used or equipment was not utilized during the month)

*a = Devices run only as a back-up system

*b = Device only runs when grains are being unloaded