Anheuser-Busch LLC- Fairfield Brewery

BAAQMD Plant #: A0606

Permit Condition #13032

S-1, S-2, S-3 Cummulative Boiler Fuel Usage (MMBTUs)

2015		
Month	**Fuel Usage**	**12 Month Consecutive**
March	24638	372736
April	26484	399220
May	26697	425917
June	26026	451943
July	26705	478648
August	26596	505244

Anheuser-Busch LLC - Fairfield Brewery

BAAQMD Plant #: A0606

Permit Condition #13032

S-1 Boiler Fuel Usage (MMBTUs)

Limit: 1,042,440 MMBTU for any consecutive 12-month period

2015

Month	Fuel Usage	12 Month Consecutive
March	0	35808
April	0	35715
May	3769	36497
June	11006	47503
July	7145	50594
August	7887	45879

Anheuser-Busch LLC- Fairfield Brewery

BAAQMD Plant #: A0606

Permit Condition #13032

S-2 Boiler Fuel Usage (MMBTUs)

Limit: 1,042,440 MMBTU for any consecutive 12-month period

2015

	Fuel Usage	**12 Month Consecutive**
March	**13417**	157915
April	**19228**	177143
May	**128**	177271
June	**134**	177405
July	**10395**	187800
August	**16762**	204562

Anheuser-Busch LLC - Fairfield Brewery

BAAQMD Plant #: A0606

Permit Condition #13032

S-3 Boiler Fuel Usage (MMBTUs)

Limit: 1,042,440 MMBTU for any consecutive 12-month period

2015

Month	Fuel Usage	12 Month Consecutive
March	**11221**	179013
April	**7256**	186269
May	**22800**	209069
June	**14886**	223955
July	**9165**	233120
August	**1947**	235067

Anheuser-Busch LLC - Fairfield Brewery

BAAQMD Plant #: A0606

Permit Condition # 16202

S-120, -128, -131, -132, -133, -138, -146, -147, -161, -162, -169, -170, -171, -172,-173,-174,-175,-176,-179

12 Month Limit: Ink 1339 gallons; Solvent thinner 569 gallons; Acetone 90 gallons

POC Emission Limit: 17370 pounds per consecutive 12 months from all sources; NPOC Emission Limit: 803 pounds per consecutive 12 months from all sources

NOTE: Ink usage and related POC emissions for S-169 and S-170 have separate limits and are tracked on a separate logsheet. Beginning in Jan. 2009, usage of 16-8200 and 16-8205 attributed to S-169 and S-170 have been deducted from the totals below.

Month & Year	Video-Jet Ink 16-8200 (Qt)	Video-Jet Solvent 16-8205 (Qt)	Diagraph TWP-101 Black Ink (5 Gal Pail)	Diagraph TWP-101 Conditioner (5 Gal Pail)	Linx Ink 3103 (1/2 Ltr)	Linx Solvent 3501 (1/2 Ltr)	Scan True II Ink Jet Ink (Liter)	Video-Jet Ink V410-D (750 ml)	Video-Jet Make up V705-D (750 ml)	Video-Jet Conditioner V901-Q (Liter)	Monthly Ink Usage (Gal)	Monthly Solvent Usage (Gal)	Monthly Acetone Usage (Gal)	12 Month Ink Usage (Gal)	12 Month Solvent Usage (Gal)	12 month Acetone Usage (Gal)	Monthly POC Emission (Lb.)	Monthly NPOC Emission (Lb.)	12-Month POC Emission (Lb.)	12-Month NPOC Emission (Lb.)
SAP #	1012066	1206384	1369178	1326520	1318353	1318352	1568880	1745231	1745232	1722033										
CTS #	03528-000	00152-000	16510-000	06080-000	13635-000	13694-000	27321-000	45683-000	45684-000	42559-0000										
Density lb/gal	7.52	6.68	8.84	8.39	7.52	6.68	8.35	6.68	6.68	7.52										
Density lb/unit	1.88	1.67	44	42	0.99	0.88	2.20	1.34	1.34	1.98										
% POC	71	100	20	40	47.5	20	80	67.00	100	100										
lbs POC/unit	1.33	1.67	8.84	16.78	0.47	0.18	1.76	0.90	1.34	1.98										
% NPOC	0	0	0	0	47.5	80	20	0	0	0										
lbs NPOC/unit	0.00	0.00	0.00	0.00	0.47	0.71	0.44	0.00	0.00	0.00										
March-15	0	0	2	0	0	30	5	12	32	1	14	10.62	3.17	114.9	196.0	29.6	87.95	23.37	1504.1	215.6
April-15	0	0	1	0	0	10	5	12	54	1	9	12.38	1.13	114.1	182.0	27.5	103.64	9.26	1419.7	203.7
May-15	0	0	1	0	0	20	6	24	36	4	11	10.90	2.15	119.9	168.5	26.5	93.86	16.75	1341.9	197.5
June-15	0	0	2	0	0	30	6	6	42	0	13	12.36	3.20	121.9	162.3	27.6	97.70	23.81	1287.9	205.0
July-15	0	0	1	0	0	10	0	12	38	0	7	8.92	1.06	118.5	153.6	25.5	73.45	7.05	1222.8	188.7
August-15	0	0	1	0	0	50	15	12	42	2	11	15.53	5.35	117.6	149.2	27.7	112.30	41.88	1192.3	209.4

NOTE: Beginning February 2009, VideoJet Ink & Solvent for Line 1 are subtracted from the totals above and tracked on a separate spreadsheet

Anheuser-Busch LLC - Fairfield Brewery

BAAQMD Plant #: A0606

Permit Condition # 24244

S-169, S-170

12 Month Limit: Ink 6 gallons; Solvent thinner 19 gallons

POC Emission Limit: 303.4 pounds per consectutive 12 months from each source

Note: Usage of 16-8200 and 16-8205 attributed to S-75, -76, -77, -78, -120, -128, -131, -132, -133, -138, -146, -147, -161, -162 is tracked on a separate logsheet.

Month & Year	Total Line 1 Video-Jet Ink 16-8200 (Qt)	Total Line 1 Video-Jet Solvent 16-8205 (Qt)	Total Line 1 Rolling Rock/RRL Produced (BBLS)	Total Line 1 Production (BBLS)	Ink Usage Attributed to S-169 & S-170 (Qt)	Solvent Usage Attributed to S-169 & S-170 (Qt)	Monthly Ink Usage (Gal)	Monthly Solvent Usage (Gal)	12 Month Ink Usage (Gal)	12 Month Solvent Usage (Gal)	Monthly POC Emission (Lb.)	12-Month POC Emission (Lb.)
SAP #	1012066	1206384										
CTS #	03528-000	00152-000										
Density lb/gal	7.52	6.68										
Density lb/unit	1.88	1.67										
% POC	71	100										
lbs POC/unit	1.33	1.67										
% NPOC	0	0										
lbs NPOC/unit	0.00	0.00										
March-15	0	0	0	0	0	0	0	0	0	0	0.00	0
April-15	0	0	0	0	0	0	0	0	0	0	0.00	0
May-15	0	0	0	0	0	0	0	0	0	0	0.00	0
June-15	0	0	0	0	0	0	0	0	0	0	0.00	0
July-15	0	0	0	0	0	0	0	0	0	0	0.00	0
August-15	0	0	0	0	0	0	0	0	0	0	0.00	0

Line 1 was idled on April 28,2010.

Anheuser-Busch LLC - Fairfield Brewery

BAAQMD Plant #: A0606

Permit Condition #9061

S-134 & S-137 Total Filtering Aid Loading Throughputs

Permit Limit: 222 tons during 12 month consecutive period

	Summary (tons)	Consecutive Summary
Month	*Filter Aid 2015*	*12 MONTH TOTAL 15*
JAN	0.2	3.3
FEB	0.2	3.3
MAR	0.3	3.4
APR	0.3	3.4
MAY	0.3	3.4
JUN	0.3	3.4
JUL	0.4	3.5
AUG	0.3	3.5
SEP		
OCT		
NOV		
DEC		
Sum	2.43	

Note: In November 2011, the filtering aid ACP was replaced with Tannin. S-134 is not utilized with tannin.

Anheuser-Busch LLC- Fairfield Brewery

BAAQMD Plant #: A0606

Permit Condition #8195

S-135 Railcar Fumigation Venting

Permit Limit: 2,190 rail cars in a 12 month period

	Number of railcars unloaded	*12 Month Total Railcars Unloaded*
Month	*2015*	2015
JAN	0	67
FEB	0	67
MAR	0	67
APR	0	67
MAY	0	65
JUN	8	65
JUL	11	64
AUG	9	58
SEP		
OCT		
NOV		
DEC		
Sum	28	

No fumigants are added to railcars at this facility.

Anheuser-Busch LLC- Fairfield Brewery

BAAQMD Plant #: A0606

Permit Condition #20632(3) & 21639(2)

S-149, S-150, S-151, & S-158 Total Beer Throughput

Limit: 6,351,088 bbls of beer per consecutive 12 month period

	Production Summary (BBLs)		***12 Month Consecutive Summary***
Month	***2015***		***12 MONTH TOTAL 15***
JAN	242,453		3,187,688
FEB	255,176		3,430,142
MAR	271,188		3,422,179
APR	285,881		3,405,687
MAY	318,975		3,413,188
JUN	318,378		3,417,995
JUL	333,708		3,431,463
AUG	328,147		3,445,095
SEP			
OCT			
NOV			
DEC			
Sum	2,353,905		

****New brewhouse went online on 1/07/2005**

Anheuser-Busch LLC- Fairfield Brewery

BAAQMD Plant #: A0606

Permit Condition #20632 (1 & 2)

S-149, S-150, & S-151 Lauter Tub and Brew Kettle Throughput

Limit: 4,441,320 bbls of wort per consecutive 12 month period

	Production Summary (BBLs)		***12 Month Consecutive Summary***
Month	***2015***		***12 MONTH TOTAL 15***
JAN	177,486		2,161,349
FEB	171,674		2,161,078
MAR	169,297		2,162,998
APR	200,924		2,172,410
MAY	211,162		2,166,744
JUN	202,528		2,164,580
JUL	192,459		2,174,644
AUG	206,460		2,204,371
SEP			
OCT			
NOV			
DEC			
Sum			

****New brewhouse went online on 1/07/2005**

Anheuser-Busch LLC- Fairfield Brewery

BAAQMD Plant #: A0606 Permit Condition # 21595 (1) & 21639 (1)

S-154, 155 & 158 Weekly Filler Rate

S-158 = 1,800 bottle/min, S-154 = 1,560 cans/min,
S-155 = 1,565 cans/min, S-168 = 2.124MMBls/12 months

Week	Line 01 (1800 bottles) Source 158	(New) Line 40 (2.124 MMbls/12 months) Source 168 (BBLS/WEEK)	Line 50 (weekly can throughput) Source 155 (CAN/Week)	Line 50 (1565 cans) Source 155 (CAN/MIN)
3/2/2015	0	41,813	7,531,506	1,215
3/9/2015	0	27,507	8,943,432	1,280
3/16/2015	0	10,065	10,099,650	1,302
3/23/2015	0	32,115	10,643,832	1,128
3/30/2015	0	36,524	10,441,194	1,202
4/6/2015	0	32,392	7,426,200	1,219
4/13/2015	0	33,575	7,906,128	1,130
4/20/2015	0	32,270	9,714,678	1,067
4/27/2015	0	33,109	9,968,076	1,035
5/4/2015	0	35,308	10,650,774	1,260
5/11/2015	0	42,637	9,624,840	1,159
5/18/2015	0	31,886	11,653,590	1,238
5/25/2015	0	39,477	10,996,020	1,258
6/1/2015	0	33,954	11,967,252	1,265
6/8/2015	0	35,938	10,438,386	1,239
6/15/2015	0	36,581	12,297,192	1,277
6/22/2015	0	35,442	10,164,666	1,180
6/29/2015	0	33,627	10,858,986	1,134
7/6/2015	0	34,894	12,172,530	1,274
7/13/2015	0	38,699	9,529,827	1,199
7/20/2015	0	36,520	9,781,200	1,228
7/27/2015	0	38,972	11,837,400	1,237
8/3/2015	0	37,832	11,491,638	1,196
8/10/2015	0	31,992	10,213,806	1,307
8/17/2015	0	42,576	10,810,902	1,257
8/24/2015	0	33,284	10,353,780	1,252
8/31/2015	0	45,988	11,970,204	1,273

Note: Line 40 (S- 154) was replaced during the summer of 2008.

The beer packaged during the engineering run was not saleable beer.

Anheuser-Busch LLC- Fairfield Brewery

BAAQMD Plant #: A0606

Permit Condition # 21369 (2) S - 158 = 6,351,088 barrels/12 months
Permit Condition # 23956 (1) S - 168 = 2,124,000 barrels/12 months

Month	Source 158 Line 01 Monthly Barrels	Source 158 Line 01 (6,351,088 barrels/12 month)	Source 168 Line 40 Monthly Barrels	Source 168 Line 40 (2,124,000 barrels/12 months)
March-15	0	0	123589.2	1,619,370.92
April-15	0	0	150376.89	1,629,458.43
May-15	0	0	156483.2	1,636,566.30
June-15	0	0	150802.18	1,637,497.05
July-15	0	0	164,020.07	1,649,794.45
August-15	0	0	162,937.71	1,660,243.46

Anheuser-Busch LLC - Fairfield Brewery

BAAQMD Plant #: A0606

Permit Condition # 21610

S-156 Emergency Standby Diesel Engine

Limit: For emergency use or 100 hours/calendar year for reliability testing

	Reliability Testing (Hrs)			***Emergency Testing (Hrs)***
Month	***2015***		***(Standby Eng)***	**2015**
JAN	0.1		**JAN**	0
FEB	0.5		**FEB**	0
MAR	0.2		**MAR**	0
APR	0.4		**APR**	0
MAY	0.5		**MAY**	0
JUN	0.2		**JUN**	0
JUL	0.6		**JUL**	0
AUG	0.0		**AUG**	0
SEP			**SEP**	
OCT			**OCT**	
NOV			**NOV**	
DEC			**DEC**	
TOTAL	**2.5**		**TOTAL**	**0**

Anheuser-Busch LLC- Fairfield Bre

BAAQMD Plant #: A0606

Permit Condition # 22850

S-165 Stationary Diesel Engine

Limit: For emergency use or 50 hours/calendar year for reliability testing

	Reliability Testing (Hrs)		*Emergency Conditions (Hrs)*		*Emission Testing (Hrs)*
Month	***2015***	*(Generators)*	***2015***	***Month***	***2015***
JAN	0.20	**JAN**	0	**JAN**	0
FEB	0.00	**FEB**	0	**FEB**	0
MAR	0.00	**MAR**	0	**MAR**	0
APR	0.00	**APR**	0	**APR**	0
MAY	0.00	**MAY**	0	**MAY**	0
JUN	0.60	**JUN**	0	**JUN**	0
JUL	2.00	**JUL**	0	**JUL**	0
AUG	0.00	**AUG**	0	**AUG**	0
SEP		**SEP**		**SEP**	
OCT		**OCT**		**OCT**	
NOV		**NOV**		**NOV**	
DEC		**DEC**		**DEC**	
TOTAL	**2.8**	**TOTAL**	**0**	**TOTAL**	**0**

Anheuser-Busch LLC- Fairfield Brewery

BAAQMD Plant #: A0606

Permit Condition # 23750

S-166 and S-167 BERS Boiler Flare Ratio

Limit: 52 week rolling average not to 10%

Year	Week #	Biogas Production (cubic feet)	Biogas Flared (cubic feet)	Ratio of Biogas Flared to Produced (%)	Ratio of Biogas Flared to Produced 52-Week Rolling Average Not to exceed 10%
	10	1498023.1	0.0	0.00	0.36
	11	1388977.7	168.0	0.01	0.36
	12	1167729.1	0.0	0.00	0.36
	13	1230039.5	363.0	0.03	0.35
	14	1244161.1	0.0	0.00	0.35
	15	1302152.1	1155.0	0.09	0.36
	16	1319944.6	0.0	0.00	0.36
	17	1221431.3	0.0	0.00	0.36
	18	1463537.4	0.0	0.00	0.36
	19	1236452.1	0.0	0.00	0.36
	20	1352969.4	0.0	0.00	0.36
	21	1243651.8	0.0	0.00	0.36
	22	1369084.3	0.0	0.00	0.36
	23	1359914.6	256.0	0.02	0.36
	24	1445488.6	0.0	0.00	0.36
	25	1283587.3	0.0	0.00	0.36
	26	1435670.7	0.0	0.00	0.36
	27	1417383.6	1101.0	0.08	0.36
	28	1297833.0	1010.0	0.08	0.36
	29	1356532.0	0.0	0.00	0.36
	30	1277393.9	1163.0	0.09	0.36
	31	1406783.6	0.0	0.00	0.36
	32	1459122.6	709.0	0.05	0.35
	33	1,664,326	0.0	0.00	0.35
	34	1,589,333	463.0	0.03	0.35
	35	1,368,346	0.0	0.00	0.35
	36	1,349,329	852.0	0.06	0.35

From UPA report

Anheuser-Busch LLC- Fairfield Brewery

BAAQMD Plant #: A0606

Permit Condition # 23750

S-166 and S-167 BERS Biogas H2S

Limit: 52 week rolling average not to 200 ppmv

Year	Week #	Biogas H2S (ppmv)	52-Week Rolling Average Not to exceed 200 ppmv	
2015	1	54.29	111.22	
	2	58.57	110.33	
	3	52.86	109.07	
	4	42.86	107.06	
	5	52.86	105.81	
	6	72.86	106.33	
	7	115.00	105.63	
	8	197.86	106.69	
	9	191.43	107.05	
	10	202.86	107.73	
	11	200.00	107.79	
	12	174.29	108.26	
	13	162.86	108.57	
	14	147.14	110.05	
	15	145.71	109.29	
	16	85.71	108.68	
	17	58.57	106.59	
	18	102.86	105.77	
	19	41.43	103.02	
	20	52.86	101.98	
	21	45.71	99.95	
	22	127.86	99.85	
	23	187.14	99.60	
	24	182.86	99.27	
	25	133.57	97.99	
	26	177.14	97.50	
	27	182.14	97.12	
	28	158.57	99.01	
	29	179.29	101.37	
	30	174.29	102.86	
	31	160.71	104.40	
	32	144.29	105.91	
	33	199.29	108.43	
	34	138.57	109.67	
	35	129.29	112.16	
	36	164.29	113.64	

From Andy Messer's Op Data Report

Anheuser-Busch LLC - Fairfield Brewery

BAAQMD Plant #: A0606

Permit Condition # 23750

S-166 and S-167 BERS Offgas H2S

Limit: 52 week rolling average not to 10 ppmv

Year	Week #	Offgas H2S (ppmv)	52-Week Rolling Average Not to exceed 10 ppmv
2015	10	1.14	0.88
	11	1.29	0.88
	12	0.71	0.88
	13	1.00	0.90
	14	0.71	0.75
	15	0.71	0.77
	16	0.57	0.77
	17	0.86	0.77
	18	0.71	0.78
	19	0.86	0.80
	20	0.57	0.81
	21	0.57	0.82
	22	0.43	0.82
	23	0.43	0.83
	24	0.57	0.84
	25	0.57	0.85
	26	0.43	0.86
	27	0.57	0.87
	28	0.71	0.88
	29	1.14	0.90
	30	0.29	0.90
	31	0.43	0.90
	32	0.43	0.91
	33	0.86	0.92
	34	0.86	0.93
	35	0.86	0.92
	36	0.71	0.91

Anheuser-Busch LLC - Fairfield Brewery

BAAQMD Plant #: A0606

Permit Condition # 23750

S-166 and S-167 BERS WW Throughput

Limit: 12 month rolling average not to exceed 778 MM Gallons

Month	Wastewater Throughput (MM Gallons)	Wastewater Throughput 12-Month Rolling Average	Wastewater Total for 12 month period Not to Exceed 778 MM Gallons
March-15	11.90	14.25	171.00
April-15	12.70	14.05	168.56
May-15	12.96	13.83	165.93
June-15	14.59	13.77	165.18
July-15	15.70	13.71	164.57
August-15	15.04	13.69	164.24

From Monthly Master WW data sheet

Anheuser-Busch LLC - Fairfield Brewery

BAAQMD Plant #: A0606

Permit Condition # 23750

S-166 and S-167 Daily Biogas Production Log

DATE	BIOGAS PRODUCTION (cubic feet)
3/1/2015	214,414
3/2/2015	201,059
3/3/2015	215,465
3/4/2015	215,862
3/5/2015	207,749
3/6/2015	215,928
3/7/2015	227,547
3/8/2015	238,197
3/9/2015	202,542
3/10/2015	232,147
3/11/2015	165,181
3/12/2015	176,104
3/13/2015	180,265
3/14/2015	194,542
3/15/2015	161,440
3/16/2015	164,450
3/17/2015	166,165
3/18/2015	177,926
3/19/2015	137,488
3/20/2015	158,987
3/21/2015	201,273
3/22/2015	174,991
3/23/2015	146,619
3/24/2015	230,162
3/25/2015	198,923
3/26/2015	181,457
3/27/2015	148,707
3/28/2015	149,180
3/29/2015	172,044
3/30/2015	171,641
3/31/2015	175,391
4/1/2015	174,979
4/2/2015	193,507
4/3/2015	190,079
4/4/2015	166,521
4/5/2015	149,499
4/6/2015	155,015

Source of Data: UPA Data imported to 010310 to 020610 Biogas and Offgas.xls

4/7/2015	173,173
4/8/2015	174,677
4/9/2015	195,114
4/10/2015	229,826
4/11/2015	224,848
4/12/2015	167,494
4/13/2015	172,188
4/14/2015	176,477
4/15/2015	200,012
4/16/2015	221,187
4/17/2015	219,191
4/18/2015	163,395
4/19/2015	154,236
4/20/2015	170,553
4/21/2015	209,192
4/22/2015	185,877
4/23/2015	142,673
4/24/2015	173,308
4/25/2015	185,593
4/26/2015	177,546
4/27/2015	222,198
4/28/2015	214,794
4/29/2015	223,091
4/30/2015	197,059
5/1/2015	224,757
5/2/2015	204,093
5/3/2015	162,024
5/4/2015	179,460
5/5/2015	183,370
5/6/2015	193,746
5/7/2015	158,838
5/8/2015	176,871
5/9/2015	182,142
5/10/2015	175,968
5/11/2015	190,815
5/12/2015	220,485
5/13/2015	220,262
5/14/2015	204,530
5/15/2015	188,100
5/16/2015	152,808
5/17/2015	159,526
5/18/2015	173,935
5/19/2015	192,683
5/20/2015	181,437
5/21/2015	174,525
5/22/2015	173,554
5/23/2015	187,993
5/24/2015	155,562
5/25/2015	157,195
5/26/2015	226,937
5/27/2015	236,921
5/28/2015	232,047
5/29/2015	164,834
5/30/2015	195,588

Source of Data: UPA Data imported to 010310 to 020610 Biogas and Offgas.xls

5/31/2015	207,227
6/1/2015	181,178
6/2/2015	200,101
6/3/2015	212,024
6/4/2015	189,546
6/5/2015	178,188
6/6/2015	191,651
6/7/2015	199,771
6/8/2015	224,202
6/9/2015	199,473
6/10/2015	197,382
6/11/2015	210,197
6/12/2015	210,288
6/13/2015	204,176
6/14/2015	150,093
6/15/2015	173,787
6/16/2015	214,616
6/17/2015	200,765
6/18/2015	185,072
6/19/2015	181,496
6/20/2015	177,759
6/21/2015	167,785
6/22/2015	208,925
6/23/2015	222,284
6/24/2015	216,164
6/25/2015	211,400
6/26/2015	208,870
6/27/2015	200,242
6/28/2015	200,542
6/29/2015	207,066
6/30/2015	206,016
7/1/2015	205,808
7/2/2015	192,496
7/3/2015	209,184
7/4/2015	196,273
7/5/2015	201,223
7/6/2015	205,982
7/7/2015	226,920
7/8/2015	207,391
7/9/2015	168,691
7/10/2015	146,115
7/11/2015	141,514
7/12/2015	152,214
7/13/2015	212,568
7/14/2015	224,876
7/15/2015	203,150
7/16/2015	179,032
7/17/2015	200,567
7/18/2015	184,127
7/19/2015	196,566
7/20/2015	160,941
7/21/2015	171,595
7/22/2015	185,544
7/23/2015	178,544

Source of Data: UPA Data imported to 010310 to 020610 Biogas and Offgas.xls

7/24/2015	181,640
7/25/2015	202,564
7/26/2015	226,410
7/27/2015	196,828
7/28/2015	221,610
7/29/2015	211,237
7/30/2015	191,042
7/31/2015	177,442
8/1/2015	182,214
8/2/2015	184,280
8/3/2015	196,106
8/4/2015	205,835
8/5/2015	215,384
8/6/2015	234,051
8/7/2015	213,656
8/8/2015	209,811
8/9/2015	210,496
8/10/2015	242,758
8/11/2015	269,357
8/12/2015	259,043
8/13/2015	218,102
8/14/2015	259,822
8/15/2015	204,748
8/16/2015	209,084
8/17/2015	248,952
8/18/2015	258,565
8/19/2015	238,448
8/20/2015	232,309
8/21/2015	209,382
8/22/2015	192,593
8/23/2015	140,811
8/24/2015	199,665
8/25/2015	232,328
8/26/2015	198,759
8/27/2015	204,378
8/28/2015	225,129
8/29/2015	167,277
8/30/2015	164,700
8/31/2015	203,102

Source of Data: UPA Data imported to 010310 to 020610 Biogas and Offgas.xls

Anheuser-Busch LLC - Fairfield Brewery

BAAQMD Plant #: A0606

Permit Condition # 23750

S-166 and S-167 BERS Biogas Production

Limit: 12 month rolling average not to exceed 864,000 cf/day

	Biogas Production (cubic feet)	Biogas Production 12-Month Rolling Average Not to Exceed 864,000 Ft3/day
March-15	5803845	168,384.31
April-15	5603301	169,989.08
May-15	5838235	170,195.33
June-15	5931057	169,966.31
July-15	4662258	167,773.15
August-15	6631142	171,250.05

Source of Data: UPA Data imported to FFD 12-1-08 BERS Log.xls

Anheuser-Busch LLC- Fairfield Brewery

BAAQMD Plant #: A0606

Permit Condition # 8A

S-167 Flare

Condition 8 of the Permit to Operate states: Owner/operator shall maintain the minimum temperature of S-167 flare at not less than 1400 degrees F.

Condition 8A of the Permit to Operate states:

> This condition shall only apply when the biogas supply valves to all boilers are closed and biogas flaring exceeding 300 cfm occurs longer than 15 minutes continuously.

For the period of March 1, 2015 to August 31, 2015 no conditions of 8 or 8A have occurred.

Anheuser-Busch LLC - Fairfield Brewery

BAAQMD Plant #: A0606

Permit Condition #17177

S-141, 142 Fumigation of Milling Operations

Limit: 240 lbs. of phosphine gas in any consecutive 12-month period

Fumigant Usage (lbs.)

Quarter	*2014*	*2015*		*12 MONTH TOTAL 14*	*12 MONTH TOTAL 15*
1st	0.00	0.00		4.10	**0.00**
2nd	0.00	0.00		4.10	**0.00**
3rd	0.00	0.00	As of Sept 21, 2015	4.10	**0.00**
4th	0.00			0.00	
Sum	0.00	0.00			

1st Quarter is through March.
2nd Quarter is through June.
3rd Quarter is through September.
4th Quarter is through December.

Anheuser-Busch LLC- Fairfield Brewery

BAAQMD Plant #: A0606
Permit Chart IIB
Condition #17176

PRESSURE DROP (INCHES OF WATER)

Month	***A-12*** *(0.5-6 in)*	***A-36*** *(0.5-6 in)*	***A-51*** [b] *(1-6 in.)*	***A-54*** *(1-6 in.)*	***A-126*** *(0.5-6 in)*	***A-125*** [a] *(0.25-3 in)*	***A-130*** *(0.5-4 in)*
Mar-15	4.17	NA	2.97	4.35	NA	NA	1.51
Apr-15	3.89	0.77	3.57	4.03	NA	**4.00** **	1.31
May-15	4.00	1.35	2.94	4.52	NA	NA	0.76
Jun-15	4.16	1.30	4.79	3.69	NA	NA	0.69
Jul-15	4.04	0.93	4.02	4.67	NA	NA	0.75
Aug-15	4.32	1.18	1.60	5.59	NA	**0.00** ***	0.85

* N/A = Not in operation during this month (no bagged DE/Perlite used or equipment was not utilized during the month)

*a = Devices run only as a back-up system

*b = Device only runs when grains are being unloaded

** April 22 dP was found high, dust filter was replaced and unit was reading 0.2 - unit was placed out of service an unused until new door gaskets could be installed. Unit back in service 5/8/2015

*** Aug 12 dP was found low again, unit has been placed out of service an unused as of 9/21/2015