

Bay Area Air Quality Management District

939 Ellis Street
San Francisco, CA 94109
(415) 771-6000

Final

MAJOR FACILITY REVIEW PERMIT

Issued To:
Martinez Cogen Limited Partnership (MCLP)
Facility #A1820

Facility Address:
550 Solano Way
Martinez, CA 94553

Mailing Address:
550 Solano Way
Martinez, CA 94553

Responsible Official
Phil Porter, Plant Manager
(925) 313-0801

Facility Contact
David Wallenstein
(925) 313-0810

Type of Facility: Cogeneration Facility, 99.9 MW
Primary SIC: 4911
Product: Cogeneration of electricity and steam

BAAQMD Permit Division Contact:
Bob Nishimura

ISSUED BY THE BAY AREA AIR QUALITY MANAGEMENT DISTRICT

Signed by Ellen Garvey
Ellen Garvey, Executive Officer/Air Pollution Control Officer

December 18, 1998
Date

TABLE OF CONTENTS

I. STANDARD CONDITIONS	3
II. EQUIPMENT LIST	7
A. PERMITTED SOURCE LIST	7
III. GENERALLY APPLICABLE REQUIREMENTS	8
IV. SOURCE-SPECIFIC APPLICABLE REQUIREMENTS	10
V. SCHEDULE OF COMPLIANCE	15
VI. PERMIT CONDITIONS	15
A. SOURCE SPECIFIC PERMIT CONDITIONS	15
VII. APPLICABLE EMISSION LIMITS & COMPLIANCE MONITORING REQUIREMENTS	22
VIII. TEST METHODS	26
IX. PERMIT SHIELD	28
A. NON-APPLICABLE REQUIREMENTS	28
B. SUBSUMED REQUIREMENTS	29
X. GLOSSARY	31
XI. APPENDIX A - APPLICABLE STATE IMPLEMENTATION PLAN	35

I. STANDARD CONDITIONS

A. Administrative Requirements

The permit holder shall comply with all applicable requirements in the following regulations:

- BAAQMD Regulation 1 - General Provisions and Definitions
(as amended by the District Board on 10/7/98);
- SIP Regulation 1 - General Provisions and Definitions
(as approved by EPA through 11/10/82);
- BAAQMD Regulation 2, Rule 1 - Permits, General Requirements
(as amended by the District Board on 10/7/98);
- SIP Regulation 2, Rule 1 - Permits, General Requirements
(as approved by EPA through 6/23/95);
- BAAQMD Regulation 2, Rule 2 - Permits, New Source Review
(as amended by the District Board on 10/7/98);
- SIP Regulation 2, Rule 2 - Permits, New Source Review and Prevention of Significant Deterioration
(as approved by EPA through 10/19/84); and
- BAAQMD Regulation 2, Rule 4 - Permits, Emissions Banking
(as amended by the District Board on 10/7/98).

B. Conditions to Implement Regulation 2, Rule 6, Major Facility Review

1. This Major Facility Review Permit expires on December 18, 2003. The permit holder shall submit a complete application for renewal of this Major Facility Review Permit no later than June 18, 2003 and no earlier than December 18, 2002. **If a complete application for renewal has not been submitted in accordance with these deadlines, the facility may not operate after December 18, 2003.** (Regulation 2-6-307, 404.2, & 409.6; MOP Volume II, Part 3, §4.2)
2. The permit holder shall comply with all conditions of this permit. The permit consists of this document and all appendices. Any non-compliance with the terms and conditions of this permit will constitute a violation of the law and will be grounds for enforcement action; permit termination, revocation and reissuance, or modification; or denial of a permit renewal application. (Regulation 2-6-307; MOP Volume II, Part 3, §4.11)
3. In the event any enforcement action is brought as a result of a violation of any term or condition of this permit, the fact that it would have been necessary for the permittee to halt or reduce the permitted activity in order to maintain compliance with such term or condition shall not be a defense to such enforcement action. (MOP Volume II, Part 3, §4.11)
4. This permit may be modified, revoked, reopened and reissued, or terminated for cause. (Regulation 2-6-307, 409.8, 415; MOP Volume II, Part 3, §4.11)

I. Standard Conditions (continued)

5. The filing of a request by the facility for a permit modification, revocation and reissuance, or termination, or of a notification of planned changes or anticipated non-compliance does not stay the applicability of any permit condition. (Regulation 2-6-409.7; MOP Volume II, Part 3, §4.11)
6. This permit does not convey any property rights of any sort, nor any exclusive privilege. (Regulation 2-6-409.7; MOP Volume II, Part 3, §4.11)
7. The permit holder shall supply within 30 days any information that the District requests in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. (Regulation 1-441, Regulation 2-6-409.4 & 501; MOP Volume II, Part 3, §4.11)
8. Any records required to be maintained pursuant to this permit which the permittee considers to contain proprietary or trade secret information shall be prominently designated as such. Copies of any such proprietary or trade secret information which are provided to the District shall be maintained by the District in a locked confidential file, provided, however, that requests from the public for the review of any such information shall be handled in accordance with the District's procedures set forth in Section 11 of the District Administrative Code. (Regulation 2-6-419; MOP Volume II, Part 3, §4.11)
9. Proprietary or trade secret information provided to EPA will be subject to the requirements of 40 CFR Part 2, Subpart B - Public Information, Confidentiality of Business Information. (40 CFR Part 2)
10. The emissions inventory submitted with the application for this Major Facility Review Permit is an estimate of actual emissions for the time period stated and is included only as one means of determining applicable requirements for emission sources. It does not establish, or constitute a basis for establishing, any new emission limitations. (MOP Volume II, Part 3, §4.11)

C. Requirement to Pay Fees

The permit holder shall pay annual fees in accordance with District Regulation 3, including Schedule P. (Regulation 2-6-402 & 409.13, Regulation 3; MOP Volume II, Part 3, §4.12)

D. Inspection and Entry

Access to Facility: The permit holder shall provide reasonable access to the facility and equipment which is subject to this permit to the APCO and/or to his or her designee. (Regulation 1-440, Regulation 2-6-409.3; MOP Volume II, Part 3, §4.14)

E. Records

Notwithstanding the specific wording in any requirement, all records for federally enforceable requirements shall be maintained for at least five years from the date of entry. (Regulation 2-6-501, Regulation 3; MOP Volume II, Part 3, §4.7)

I. Standard Conditions (continued)

F. Monitoring Reports

All required monitoring reports must be submitted to the District at least once every six months, except where an applicable requirement specifies more frequent reporting. All instances of non-compliance shall be clearly identified in these reports. The reports shall be certified by the responsible official as true, accurate, and complete. In addition, all instances of non-compliance with the permit shall be reported in writing to the District's Compliance and Enforcement Division within 10 calendar days of the discovery of the incident. Within 30 calendar days of the discovery of any incident of non-compliance, the facility shall submit a written report including the probable cause of non-compliance and any corrective or preventative actions. The reports shall be sent to the following address:

Director of Compliance and Enforcement
Bay Area Air Quality Management District
939 Ellis Street
San Francisco, CA 94109
Attn: Title V Reports

(Regulation 2-6-502, Regulation 3; MOP Volume II, Part 3, §4.7)

G. Compliance Certification

Compliance certifications shall be submitted annually by the responsible official of this facility to the Bay Area Air Quality Management District and to the Environmental Protection Agency. The certification must list each applicable requirement, the compliance status, whether compliance was continuous or intermittent, the method used to determine compliance, and any other specific information required by the permit. The permit holder may satisfy this requirement through submittal of District-generated Compliance Certification forms. The certification should be directed to the District's Compliance and Enforcement Division at the address above, and a copy of the certification should be sent to the Environmental Protection Agency at the following address:

Director of the Air Division
USEPA, Region IX
75 Hawthorne Street
San Francisco, CA 94105
Attention: Air-3

(MOP Volume II, Part 3, §4.5 and 4.15)

H. Emergency Provisions

1. The permit holder may seek relief from enforcement action in the event of a breakdown, as defined by Regulation 1-208 of the District's Rules and Regulations, by

I. Standard Conditions (continued)

following the procedures contained in Regulations 1-431 and 1-432. The District will thereafter determine whether breakdown relief will be granted in accordance with Regulation 1-433. (MOP Volume II, Part 3, §4.8)

2. The permit holder may seek relief from enforcement action for a violation of any of the terms and conditions of this permit caused by conditions beyond the permit holder's reasonable control by applying to the District's Hearing Board for a variance pursuant to Health and Safety Code Section 42350. The Hearing Board will determine after notice and hearing whether variance relief should be granted in accordance with the procedures and standards set forth in Health and Safety Code Section 42350 et seq. Any variance granted by the Hearing Board from any term or condition of this permit which lasts longer than 90 days will be subject to EPA approval. (MOP Volume II, Part 3, §4.8)
3. Notwithstanding the foregoing, the granting by the District of breakdown relief or the issuance by the Hearing Board of a variance will not provide relief from federal enforcement unless the Major Facility Review Permit has been modified pursuant to Regulation 2, Rule 6. (MOP Volume II, Part 3, §4.8)

I. Severability

1. In the event that any provision of this permit is invalidated by a court or tribunal of competent jurisdiction, or by the Administrator of the EPA, all remaining portions of the permit shall remain in full force and effect. (Regulation 2-6-409.5; MOP Volume II, Part 3, §4.10)

II. EQUIPMENT LIST

A. Permitted Source List

Each of the following sources has been issued a permit to operate pursuant to the requirements of BAAQMD Regulation 2-1-302.

Table II-A

S-#	Description	Make or Type	Model	Capacity
1	Sludge Drying Operation	Carver Greenfield	Custom	0.71 dry tons/hr
2	Product Silo	Custom	Custom	1200 cubic feet
5	Sludge Feed Storage Tank	Custom	Custom	2000 gal
10	Gas Turbine (natural gas, refinery gas)	John Brown PG6551B	Frame 6	500 MM Btu/hr
11	Gas Turbine (natural gas, refinery gas)	John Brown PG6551B	Frame 6	500 MM Btu/hr

B. Abatement Device List

Table II-B

A-#	Description	Source(s) Controlled	Applicable Requirement	Operating Parameters	Limit or Efficiency
1	Carbon Adsorber	1	BAAQMD 7-301	None	N/A
2	Baghouse Filter	2	BAAQMD 6-310	None	0.15 gr/dscf

III. GENERALLY APPLICABLE REQUIREMENTS

The permit holder shall comply with all applicable requirements, including those specified in the BAAQMD and SIP Rules and Regulations and other federal requirements cited below. These requirements apply in a general manner to the facility and/or to sources exempt from the requirement to obtain a District Permit to Operate. The District has determined that these requirements would not be violated under normal, routine operations, and that no additional periodic monitoring or reporting to demonstrate compliance is warranted. In cases where a requirement, in addition to being generally applicable, is also specifically applicable to one or more sources, the requirement and the source are also included in Section IV, Source-Specific Applicable Requirements, of this permit.

The dates in parenthesis in the Title column identify the versions of the regulations being cited and are, as applicable:

1. BAAQMD regulation(s):
 The date(s) of adoption or most recent amendment of the regulation by the District Board
2. Any federal requirement, including a version of a District regulation that has been approved into the SIP:
 The most recent date of EPA approval of any portion of the rule, encompassing all actions on the rule through that date
 Where an applicable requirement is a SIP requirement, the full language of the SIP requirement is included in Appendix A of this permit.

NOTE:

There are differences between current BAAQMD rules and versions of the rules in the SIP. For specific information, contact the District's Planning and Research Division. All sources must comply with both versions of a rule until the U.S. EPA has reviewed and approved (or disapproved) the District's revision of the regulation.

Table III

Applicable Requirement	Regulation Title or Description of Requirement	Federally Enforceable (Y/N)
BAAQMD Regulation 1	General Provisions and Definitions (11/3/93)	N
SIP Regulation 1	General Provisions and Definitions (11/10/82)	Y
BAAQMD Regulation 4	Air Pollution Episode Plan (3/20/91)	N
SIP Regulation 4	Air Pollution Episode Plan (8/06/90)	Y

III. Generally Applicable Requirements (continued)

Table III (continued)

Applicable Requirement	Regulation Title or Description of Requirement	Federally Enforceable (Y/N)
BAAQMD Regulation 6	Particulate Matter and Visible Emissions (12/19/90)	N
BAAQMD Regulation 7	Odorous Substances (3/17/82)	N
BAAQMD Regulation 8	Organic Compounds	N
BAAQMD Regulation 8, Rule 1	Organic Compounds - General Provisions (6/15/94)	Y
BAAQMD Regulation 8, Rule 3	Organic Compounds - Architectural Coatings (12/20/95)	Y
BAAQMD Regulation 8, Rule 49	Organic Compounds - Aerosol Paint Products (12/20/95)	N
SIP Regulation 8, Rule 49	Organic Compounds - Aerosol Paint Products (3/22/95)	Y
BAAQMD Regulation 8, Rule 51	Organic Compounds - Adhesive and Sealant Products (12/20/95)	N
BAAQMD Regulation 12, Rule 4	Miscellaneous Standards of Performance - Sandblasting (7/11/90)	N
SIP Regulation 12, Rule 4	Miscellaneous Standards of Performance - Sandblasting (9/2/81)	Y

IV. SOURCE-SPECIFIC APPLICABLE REQUIREMENTS

The permit holder shall comply with all applicable requirements, including those specified in the BAAQMD and SIP Rules and Regulations and other federal requirements cited below. The requirements cited in the following tables apply in a specific manner to the indicated source(s).

The dates in parenthesis in the Title column identify the versions of the regulations being cited and are, as applicable:

1. BAAQMD regulation(s):
 The date(s) of adoption or most recent amendment of the regulation by the District Board
2. Any federal requirement, including a version of a District regulation that has been approved into the SIP:
 The most recent date of EPA approval of any portion of the rule, encompassing all actions on the rule through that date

The full text of each permit condition cited is included in Section VI, Permit Conditions, of this permit. Additionally, where an applicable requirement is a SIP requirement, the full language of the SIP requirement is included in Appendix A of this permit. All other text may be found in the regulations themselves.

**Table IV-A
 S10 and S11: Gas Turbines**

Applicable Requirement	Regulation Title or Description of Requirement	Federally Enforceable (Y/N)	Future Effective Date
BAAQMD Regulation 1	General Provisions and Definitions (11/3/93)		
1-208	Breakdown (malfunction)	Y	
1-431	Breakdown Report	Y	
1-432	Written Breakdown Report	Y	
1-433	Determination of Breakdown	Y	
1-522	Continuous Emission Monitoring and Recordkeeping Procedures	Y	
1-522.1	Plans and Specifications	Y	
1-522.2	Installation Scheduling	Y	
1-522.3	Performance Testing	Y	
1-522.4	Periods of Inoperation Greater Than 24 Hours	Y	
1-522.5	Calibration	Y	
1-522.6	Accuracy	Y	
1-522.7	Excesses	Y	

IV. Source-Specific Applicable Requirements (continued)

Table IV-A (continued)
S10 and S11: Gas Turbines

Applicable Requirement	Regulation Title or Description of Requirement	Federally Enforceable (Y/N)	Future Effective Date
1-522.8	Monthly Reports	Y	
1-522.9	Records	Y	
1-522.10	Monitors Required by Sections 1-521 or 2-1-403	Y	
1-602	Area and Continuous Emission Monitoring Requirements	N	
SIP Regulation 1	PROVISIONS NO LONGER IN CURRENT RULE General Provisions and Definitions (11/10/82)		
1-541	Emission Excesses	Y ¹	
1-602	Area and Continuous Emission Monitoring Requirements	Y ¹	
BAAQMD Regulation 2, Rule 1	Regulation 2, Rule 1 - Permits, General Requirements (6/7/95)		
2-1-501	Monitors	N	
BAAQMD Regulation 6	Particulate Matter and Visible Emissions (12/19/90)		
6-301	Ringelmann Number 1 Limitation	N	
6-305	Visible Particles	Y	
6-310	Particulate Weight Limitation	Y	
6-401	Appearance of Emissions	Y	
BAAQMD Regulation 9, Rule 1	Inorganic Gaseous Pollutants- Sulfur Dioxide (3/15/95)		
9-1-301	Limitations on Ground Level Concentrations	N	
9-1-302	General Emission Limitations	Y	
SIP Regulation 9, Rule 1	PROVISIONS NO LONGER IN CURRENT RULE Inorganic Gaseous Pollutants – Sulfur Dioxide (5/3/84)		
9-1-301	Limitations on Ground Level Concentrations	Y ¹	
BAAQMD Regulation 9, Rule 2	Inorganic Gaseous Pollutants- Hydrogen Sulfide (3/17/82)		
9-2-301	Limitations on Ground Level Concentrations	N	
9-2-501	Area Monitoring Requirements	N	
BAAQMD Regulation 9, Rule 9	Inorganic Gaseous Pollutants- Nitrogen Oxides from Stationary Gas Turbines (5/5/93)	Y	

IV. Source-Specific Applicable Requirements (continued)

Table IV-A (continued)
S10 and S11: Gas Turbines

Applicable Requirement	Regulation Title or Description of Requirement	Federally Enforceable (Y/N)	Future Effective Date
9-9-113	Exemption- Inspection and Maintenance	Y	
9-9-114	Exemption- Start-up and Shutdown	Y	
9-9-301	Emission Limits, General	Y	
9-9-301.2	Emission Limits, Turbines over 10.0 MW w/o SCR	Y	
9-9-401	Efficiency Certification	Y	
9-9-501	Monitoring and Recordkeeping requirements	Y	
BAAQMD Manual of Procedures, Volume V	Continuous Emission Monitoring Policy and Procedures (1/20/82)	Y	
40 CFR 60	Standards of Performance for New Stationary Sources (12/23/71)	Y	
Subpart A	General Provisions	Y	
60.4(b)	Reports to EPA and District	Y	
60.7(a)(4)	Written notification of physical or operational changes	Y	
60.7(b)	Records	Y	
60.8	Performance Tests	Y	
60.9	Availability of Information	Y	
60.11(a)	Compliance with standards and maintenance requirements	Y	
60.11(d)	Minimizing emissions	Y	
60.12	Circumvention	Y	
60.19	General notification and reporting requirements	Y	
Subpart GG	Standards of Performance for Stationary Gas Turbines (1/27/82)		
60.332 (a)(1)	NOX Performance Standard	Y	
60.333 (b)	Fuel Sulfur Limit	Y	
60.335(b)	NOX and SO2 testing	Y	
60.335(c)(1)	Calculation of NOX emission rate	Y	
60.335(c)(3)	Use of Method 20	Y	
60.335(d)	Test for sulfur content of fuel	Y	
60.335(e)	Tests for sulfur and nitrogen content	Y	
BAAQMD Condition #13422			

IV. Source-Specific Applicable Requirements (continued)

Table IV-A (continued)
S10 and S11: Gas Turbines

Applicable Requirement	Regulation Title or Description of Requirement	Federally Enforceable (Y/N)	Future Effective Date
part 1	Fuel usage rate and fuel type limitations (basis: Cumulative Increase)	Y	
part 2	Emissions limits: PM, Hydrocarbons, NO _x , SO ₂ , CO, fuel limits (basis: Cumulative Increase)	Y	
part 2	Emissions limits: NO _x (basis: Regulation 9, Rule 9/Banking Certificate)	Y	
part 3	NO _x concentration limit (basis: Regulation 9, Rule 9)	Y	
part 4	H ₂ S concentration limit in fuel (basis: Cumulative Increase)	Y	
part 5	Monitoring and Recordkeeping requirements (basis: BACT, Cumulative Increase)	Y	
parts 6- through 10	Monitoring and Recordkeeping requirements (basis: Banking Certificate)	Y	
part 11	Annual source test for CO (Basis: Regulation 2-6-409.2)	Y	
part 12	Inspections for hydrogen sulfide leaks (Basis: Regulation 9, Rule 2)	N	
PSD Permit			
III.	Facilities Operation	Y	
V.	Right of Entry	Y	
VI.	Transfer of Ownership	Y	
VII.	Severability	Y	
VIII.	Other Applicable Regulations	Y	
IX.C.	NO _x Emission Limits	Y	
IX.D.	Performance Tests	Y	
IX.E.1.b	Stack Volumetric Flow Rates	Y	
IX.E.3.e	Excess Emissions	Y	
IX.F.	Fuel Usage	Y	

¹ This section has been removed from BAAQMD Regulations because it has been superseded. Nevertheless, the source must comply with this regulation until US EPA has reviewed and approved (or disapproved) the District's revision of the regulation.

IV. Source-Specific Applicable Requirements (continued)

**Table IV-B
 S1, S2, & S5: Sludge Drying Operation,
 Product Silo, & Sludge Feed Storage Tank**

Applicable Requirement	Regulation Title or Description of Requirement	Federally Enforceable (Y/N)	Future Effective Date
BAAQMD Condition #390			
Part 1	Objectionable odors (basis: BAAQMD Regulation 7)	N	

V. SCHEDULE OF COMPLIANCE

The permit holder shall continue to comply with all applicable requirements cited in this permit. The permit holder shall also comply with applicable requirements that become effective during the term of this permit.

VI. PERMIT CONDITIONS

Any condition that is preceded by an asterisk is not federally enforceable.

A. *Source Specific Permit Conditions*

***Condition #390**

**For S1, Sludge Drying Operation
S2, Product Silo
S5, Sludge Feed Storage Tank**

- *1. In the event the APCO determines that a source/s in the operation creates objectionable odors, such source/s shall have added controls to abate these odors. (Basis: Regulation 7)

Condition #13422 (as proposed in Banking application 17207)

For S-10, S-11: Gas Turbines

1. The combined fuel usage rate at each of the gas turbines S-10 and S-11 shall not exceed 500 million BTU/hr. The turbines shall be fired on natural gas or refinery gas exclusively. (Basis: Cumulative Increase)
2. The combined emissions from the two turbines shall not exceed the following:

PM10	240	lbs/day and	43.8	TPY (Basis: Cumulative Increase)
Non-Methane Hydrocarbon	210	lbs/day and	35	TPY (Basis: Cumulative Increase)
Sulfur Dioxides	550	lbs/day and	36	TPY (Basis: Cumulative Increase)
Carbon Monoxide	1,248	lbs/day and	228	TPY (Basis: Cumulative Increase)
Nitrogen Oxides	1,512	lbs/day and	198.5	TPY (Basis: Banking Certificate)

If the emissions of sulfur dioxide emissions in a calendar year reach 36 tons, these turbines shall be fired exclusively on natural gas for the remainder of the year. (Basis: Cumulative Increase)

VI. Permit Conditions (continued)

A. Source Specific Permit Conditions (continued)

Condition #13422 (continued)

**For S10, Gas Turbine
S11, Gas Turbine**

3. The oxides of nitrogen (NOX) concentration in the gas turbine exhaust shall not exceed 17.1 ppmv (15 ppm adjusted based on efficiency per Regulation 9-9-401) at 15% oxygen (dry basis) averaged over any consecutive 3-hour period whether firing refinery and/or natural gas. This limit shall not apply during the start-up, which is not to exceed three hours, or during the shutdown procedure, which is not to exceed one hour. (Basis: Regulation 9, Rule 9)
4. The concentration of hydrogen sulfide (H₂S) in the fuel gas to both turbines shall not exceed 62 ppm annual average. This average shall not include periods when both turbines are not operating. The annual average shall be determined by summing daily averages and dividing by the number of days that at least one turbine was operating. (Basis: Cumulative Increase)
5. The operator shall install, calibrate and operate District-approved monitors for NOX, oxygen, H₂S (in the fuel), fuel gas usage, and electricity production. The monitoring system shall be designed to calculate and record NOX mass emissions from S-10 and S-11 on an hourly, daily, monthly, and rolling 12 month basis, as well as demonstrating 3-hour average compliance with the Regulation 9, Rule 9 adjusted NOX limit of 17.1 ppmv @ 15% O₂ dry. Emissions reports shall be submitted to the District on a monthly basis. [Basis: Cumulative Increase, Banking Certificate]
6. Until such time as sufficient CEM data is available to demonstrate rolling 12-month NOX emissions, combined monthly NOX emissions from the gas turbines S-10 and S-11 shall not exceed 20 tons. [Basis: Banking Certificate].
7. In order to demonstrate NOX mass reductions for banked emissions credits during periods of monitor downtime, the owner/operator of the gas turbines S-10 and S-11 shall substitute average hourly NOX mass emissions for the missing period with the higher of the following: [Basis: Banking Certificate]
 - 1) Previous month average NOX mass emission rate.
 - 2) Average of the NOX mass emission rates for the hour before and the hour after the missing period.

In the event that such data is not available, the highest allowable NOX mass emission rate (i.e. 31.5 lb/hour per turbine) shall be substituted for the missing period.

8. Data shall be substituted on an average hourly basis each time NOX mass emissions can not be measured because a monitor is out of service. Substituted emissions data shall be added to the monthly reports and shall include: [Basis: Banking Certificate]
 - a. monthly total hours of substituted data resulting from monitor downtime
 - b. substituted NOX mass emissions and method of substitution for each downtime period during the month
 - c. monthly total of substituted NOX mass emissions
 - d. rolling 12 month total of substituted NO_x mass emissions

Condition #13422 (continued)

VI. Permit Conditions (continued)

A. Source Specific Permit Conditions (continued)

**For S10, Gas Turbine
S11, Gas Turbine**

9. In the event that NO_x mass emissions from S-10 and S-11 exceed 198.5 tons in any calendar year, the facility owner/operator shall apply for a modification of their permit to operate and shall reimburse the District with emission reduction credits for the amount of the exceedance. All emission credit reimbursements shall be permanent until such time that the facility owner/operator reapplies for and is granted credits by the District. [Basis: Banking Certificate]
10. Copies of all continuous emission monitor and data substitution records shall be kept on site and be made available for inspection by District personnel upon request for a period of 5 years from the date that a record is made. This provision shall apply to all new records and all records that have been made within the two years previous to issuance of the Major Facility Review permit.
(Basis: Regulation 2-6-501)
11. The facility owner/operator shall ensure that an annual performance test is conducted on each turbine in accordance with the District test procedures to demonstrate compliance with the CO limit. The owner/operator may submit an alternative monitoring plan to the District for approval. If the alternative monitoring plan is approved, the plan shall supersede the annual source test requirement. Approvals shall be processed using the permit modification procedure contained in Regulation 2, Rule 6. (Basis: Regulation 2-6-409.2)
- *12. The owner or operator shall conduct weekly hydrogen sulfide leak equipment inspection either visually, or by audible or olfactory detection methods. Hydrogen sulfide leaks as indicated by visual, audible, or olfactory methods, shall be repaired as soon as practicable, but no later than 7 days after the leak is detected. The owner or operator shall monitor and record the following information:
 - a.) For each inspection during which a leak is detected, a record of the date, operator name, and identification of the equipment where the leak occurred.
 - b.) For each inspection during which no leak is detected, a record that the inspection was performed, the date of the inspection, and a statement that no leaks were detected.
(Basis: Regulation 9, Rule 2)

PSD conditions

Following are the PSD conditions imposed by EPA and modified by the District in Application #25830.

- I. Deleted Application #25820.
- II. Deleted Application #25820.
- III. Facilities Operation

PSD conditions (continued)

VI. Permit Conditions (continued)

A. Source Specific Permit Conditions (continued)

All equipment, facilities, and systems installed or used to achieve compliance with the terms and conditions of this Permit to Operate shall at all times be maintained in good working order and be operated as efficiently as possible so as to minimize air pollutant emissions. (PSD)

IV. Deleted Application #25820.

V. Right to Entry

The EPA Regional Administrator, the head of the California Air Resources Board, the APCO of the District, and/or their authorized representatives, upon the presentation of credentials, shall be permitted:

- A. to enter upon the premises where the source is located or in which any records are required to be kept under the terms and conditions of this Permit to Operate; and
- B. at reasonable times to have access to and copy any records required to be kept under the terms and conditions of this Permit to Operate; and
- C. to inspect any equipment, operation, or method required in this Permit to Operate; and
- D. to sample emissions from the source. (PSD)

VI. Transfer of Ownership

In the event of any changes in control or ownership of facilities to be constructed or modified, this Permit to Operate shall be binding on all subsequent owners and operators. The applicant shall notify the succeeding owner and operator of the existence of this Permit to Operate and its conditions by letter, a copy of which shall be forwarded to the Regional Administrator and the State and local Air Pollution Control Agency. (PSD)

VII. Severability

The provisions of this Permit to Operate are severable, and, if any provision of this Permit to Operate is held invalid, the remainder of this Permit to Operate shall not be affected thereby. (PSD)

VIII. Other Applicable Regulations

The owner and operator of the project shall construct and operate the stationary source in compliance with all other applicable provisions of 40 CFR Parts 52, 60 and 61 and all other applicable Federal, State and local air quality regulations other than those monitoring requirements that have been subsumed by the permit shield. (PSD)

PSD conditions (continued)

IX. Special Conditions

VI. Permit Conditions (continued)

A. Source Specific Permit Conditions (continued)

A. deleted Application #25830.

B. deleted Application #25830.

C. Emission Limits for NOX.

MCLP shall not discharge or cause the discharge into the atmosphere from the exhaust stack of any turbine, the following pollutants in excess of the following limits:

Pollutant	Mass Emission Limit	Concentration Emission Limit
NOX	81.0 #/hr/turbine (as NO ₂)	45.0 ppm @ 15% O ₂

The above emission limits shall be measured on a 3-hr average, for the purpose of source tests (but not during a 3-hr period following commencement of startup or a 1-hr period preceding completion of shutdown). Averaging times for continuous emission monitors shall be as specified in E, below. (PSD)

D. Performance Tests

1. MCLP shall conduct or cause to be conducted performance for nitrogen oxides (NOX) at such times as may be specified by the District or by EPA.

MCLP shall furnish the Bay Area Air Quality Management District-a written report of each such test. All performance tests shall be conducted at the maximum operating capacity of the unit being tested. (PSD)

2. Performance tests for the emissions of NOX shall be conducted and results reported in accordance with the test methods set forth in 40 CFR 60 Appendix A, and 40 CFR 60.8. The following test methods shall be used:
 - a) Performance tests for the emission of NOX shall be conducted using EPA Method 20. (PSD)
3. At least 30 days prior to actual testing, MCLP shall submit to the District's Source Test Section (1) a quality assurance project plan detailing methods and procedures to be used and (2) a written quality assurance test plan. Such a plan shall conform to EPA guidelines for developing project plans. A test plan or QA plan that does not have District approval may be grounds to invalidate any test and require a retest. (PSD)

PSD conditions (continued)

E. Continuous Monitoring

VI. Permit Conditions (continued)

A. Source Specific Permit Conditions (continued)

1. NOX Continuous Monitoring:
 - a. Condition IX.E.1a subsumed by Application #25820.
 - b. Stack gas volumetric flow rates shall be calculated using the F-factor method in EPA Method 19. (PSD)
2. Deleted Application #25820.
3. Report of excess emissions:
 - a. Condition IX.E.3a subsumed by Application #25820.
 - b. Condition IX.E.3b subsumed by Application #25820.
 - c. Condition IX.E.3c subsumed by Application #25820.
 - d. Condition IX.E.3d subsumed by Application #25820.
 - e. Excess emissions shall be defined as:
 - (1) any consecutive 3-hour period (but not during a 3-hr period following commencement of startup or a 1-hr period preceding completion of shutdown) during which the mass emissions of NOX or the NOX concentration, as measured by the continuous monitoring system, exceeds the maximum emission limits set in IX.C above.

Excess emissions indicated by the CEM system shall be considered violations of the applicable emission limit for the purposes of this permit. (PSD)

4. deleted Application #25830.
5. deleted Application #25830.
6. Condition IX.E.6 subsumed by Application #25820.

F. Fuel Use

MCLP shall not consume more than 500.0 MMBTU/hr per turbine on a one hour average. MCLP shall measure and record the heating value of the fuel consumed in the turbine on at least a monthly basis. Refinery gas or natural (pipeline) gas shall be the only fuels consumed. (PSD)

X. Agency Notifications

All correspondence as required by this Permit to Operate shall be forwarded to:

- A. Deleted Application #25820.
- B. Deleted Application #25820.
- C. Air Pollution Control Officer

VI. Permit Conditions (continued)

A. Source Specific Permit Conditions (continued)

Bay Area Air Quality Management District
939 Ellis Street
San Francisco, CA 94109

VII. APPLICABLE EMISSION LIMITS & COMPLIANCE MONITORING REQUIREMENTS

This section has been included only to summarize the applicable emission limits contained in Section IV, Source-Specific Applicable Requirements, of this permit. The following tables show the relationship between each emission limit and the associated compliance monitoring provisions, if any. The monitoring frequency indicates whether periodic (P) or continuous (C) monitoring is required. For periodic monitoring, the frequency of the monitoring has also been shown, either annual (A), quarterly (Q), monthly (M), daily (D), or on an event basis (E). No monitoring (N) has been required if the current applicable rule or regulation does not require monitoring, and the operation is unlikely to deviate from the applicable emission limit based upon the nature of the operation.

**Table VII-A
 S10 and S11: Gas Turbines**

Limit or Pollutant	Emission Limit Citation	FE Y/N	Future Effective Date	Emission Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type
NOX	BAAQMD 9-9-301.2, 9-9-401	Y		17.1 ppmv dry @15% O ₂ , 3-hr average excluding startup and shutdown periods (includes efficiency adjustment)	BAAQMD 9-9-501	C	CEM
	BAAQMD Condition 13422, part 2	Y		1,512 #/day and 198.5 tons/yr	BAAQMD Condition 13422, parts 5 through 10	C	CEM
	BAAQMD Condition 13422, part 3	Y		17.1 ppmv dry @15% O ₂ , 3-hr average excluding startup period not to exceed 3 hrs and shutdown periods not to exceed 1 hr (includes efficiency adjustment)	BAAQMD Condition 13422, part 5	C	CEM

VII. Applicable Emission Limits & Compliance Monitoring Requirements (continued)

**Table VII-A (continued)
 S10 and S11: Gas Turbines**

Limit or Pollutant	Emission Limit Citation	FE Y/N	Future Effective Date	Emission Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type
NOX	NSPS Subpart GG, 60.332 (a)(1)	Y		85.2 ppmv , @ 15% O ₂ , dry, 3 hour average excluding startup and shutdown periods	Monitoring requirement subsumed by Regulation 9, Rule 9 monitoring. See Permit Shield.	N	
NOX	PSD Permit Condition IX, C	Y		81.0 #/hr/turbine, 3 hour average except for 3 hours following commencement of turbine startup and 1-hour preceding completion of turbine shutdown	Monitoring requirement subsumed by Regulation 9, Rule 9 monitoring. See Permit Shield.	N	
NOX	PSD Permit Condition IX,C	Y		45.0 ppm @ 15% O ₂ , 3 hour average except for 3 hours following commencement of turbine startup and 1-hour preceding completion of turbine shutdown	Monitoring requirement subsumed by Regulation 9, Rule 9 monitoring. See Permit Shield.	N	
SO ₂	BAAQMD Condition 13422, part 2	Y		550 #/day and 36 tons/yr	BAAQMD Condition 13422, part 5	C	CMS

VII. Applicable Emission Limits & Compliance Monitoring Requirements (continued)

**Table VII-A (continued)
 S10 and S11: Gas Turbines**

Limit or Pollutant	Emission Limit Citation	FE Y/N	Future Effective Date	Emission Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type
	BAAQMD 9-1-301	N		GLC of 0.5 ppm for 3 min., or 0.25 ppm for 60 min., or 0.05 ppm for 24 hours		N	
SO2	SIP 9-1-301	Y		Federal std: GLC ¹ of 140 ppb, 24-hr average, once/yr and 30 ppb, annual average State std: GLC ¹ of 40 ppb, 24-hr average, and 250 ppb, 1 hr average		N	
SO2	BAAQMD 9-1-302	Y		300 ppm (dry)		N	
SO2	NSPS Subpart GG, 60.333(b)	Y		Sulfur content of fuel < 0.8% by weight	Subsumed by BAAQMD Cond #13422, parts 4 and 5	N	
	BAAQMD Condition 13422, part 4	Y		≤ 62 ppm H2S in refinery gas, annual average, (not emission limit)	BAAQMD Condition 13422, part 4 and part 5	C	CMS
CO	BAAQMD Condition 13422, part 2	Y		1,248 #/day and 228 tons/yr		P/A	annual source test
NMHC	BAAQMD Condition 13422, part 2	Y		210 #/day and 35 tons/yr		N	
PM10	BAAQMD Condition 13422, part 2	Y		240 #/day and 43.8 tons/yr		N	

**VII. Applicable Emission Limits & Compliance Monitoring Requirements
 (continued)**

**Table VII-A (continued)
 S10 and S11: Gas Turbines**

Limit or Pollutant	Emission Limit Citation	FE Y/N	Future Effective Date	Emission Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type
TSP	BAAQMD 6-301	N		Ringelmann No. 1		N	
TSP	BAAQMD 6-310	Y		0.15 grain/dscf @ 6% O ₂		N	
H ₂ S	BAAQMD 9-2-301	N		GLC of 0.06 ppm 3 min. average, or 0.03 ppm 60 min. average	BAAQMD Condition 13422, part 12	P/W	weekly inspection
Fuel Usage	BAAQMD Condition 13422, part 1	Y		500 MMBtu/hr per turbine	BAAQMD Condition 13422, part 5	C	records
Fuel Usage	PSD Permit Condition VII, F.	Y		500 MMBtu/hr per turbine	PSD Permit Condition VII, F.	C	records

¹ Ground Level Concentration

VIII. TEST METHODS

The test methods associated with the emission limit of a District regulation are generally found in Section 600 of the regulation. The following table indicates only the test methods associated with the emission limits referenced in Section V - Applicable Emission Limits & Compliance Monitoring Requirements.

Table VIII

Applicable Requirement	Description of Requirement	Acceptable Test Methods
BAAQMD 6-301	Ringelmann No. 1 Limitation	Manual of Procedures, Volume I, Evaluation of Visible Emissions
BAAQMD 6-310	Particulate Weight Limitation	Manual of Procedures, Volume IV, ST-15, Particulates Sampling
BAAQMD 9-1-302	General Emission Limitation	Manual of Procedures, Volume IV, ST-19A, Sulfur Dioxide, Continuous Sampling, or ST-19B, Total Sulfur Oxides Integrated Sample
BAAQMD 9-9-301.2	Emission Limits- Turbines Rated \geq 10 MW w/o SCR	Manual of Procedures, Volume IV, ST-13A, Oxides of Nitrogen, Continuous Sampling or ST-14, Oxygen, Continuous Sampling
PSD permit, part IX.C.	NO _x Emission Limits	EPA Method 7,-Determination of Nitrogen Oxide Emissions from Stationary Sources EPA Method 20-Determination of Nitrogen Oxides, Sulfur Dioxide, and Diluent Emissions from Stationary Gas Turbines
NSPS 40 CFR 60.332(a)(1)	NO _x Emission Limits	EPA Method 7,-Determination of Nitrogen Oxide Emissions from Stationary Sources EPA Method 20-Determination of Nitrogen Oxides, Sulfur Dioxide, and Diluent Emissions from Stationary Gas Turbines
NSPS 40 CFR 60.333(b)	Fuel Sulfur Content	ASTM D 1072-80, Standard Method for Total Sulfur in Fuel Gases ASTM D 3031-81, Standard Test Method for Total Sulfur in Natural Gas by Hydrogenation

VIII. Test Methods (continued)

Table VIII (continued)

Applicable Requirement	Description of Requirement	Acceptable Test Methods
BAAQMD Permit Condition #13422		
Part 2	NO _x Emission Limits	Manual of Procedures, Volume IV, ST-13A, Oxides of Nitrogen, Continuous Sampling or ST-14, Oxygen, Continuous Sampling
Part 2	S02 Emission Limits	Manual of Procedures, Volume IV, ST-19A, Sulfur Dioxide, Continuous Sampling, or ST-19B, Total Sulfur Oxides Integrated Sample
Part 2	CO Emission Limit	Manual of Procedures, Volume IV, ST-6, Carbon Monoxide, Continuous Sampling and ST-14, Oxygen, Continuous Sampling
Part 2	NMHC Emission Limit	Manual of Procedures, Volume IV, ST-7, Non-Methane Organic Carbon Sampling
Part 2	PM10 Emission Limit	Manual of Procedures, Volume IV, ST-15, Particulates Sampling
Part 3	NO _x Emission Limits	Manual of Procedures, Volume IV, ST-13A, Oxides of Nitrogen, Continuous Sampling or ST-14, Oxygen, Continuous Sampling
Part 4	H2S Fuel Limit	Manual of Procedures, Volume IV, ST-28, Hydrogen Sulfide, Integrated Sampling

IX. PERMIT SHIELD

A. NON-APPLICABLE REQUIREMENTS

Pursuant to District Regulations 2-6-233 and 2-6-409.12, the federally enforceable regulations and/or standards cited in the following table[s] are not applicable to the source or group of sources identified at the top of the table[s]. Enforcement actions and litigation may not be initiated against the source or group of sources covered by this shield based on the regulatory and/or statutory provisions cited.

**Table IX-A
 Facility Wide**

Citation	Title or Description (Reason not applicable)
BAAQMD Regulation 8, Rule 18	Equipment Leaks (Facility is not a petroleum refinery, chemical plant, bulk plant, or bulk terminal)
SIP Regulation 8, Rule 18	Valves and Connectors at Petroleum Refinery Complexes, Chemical Plants, and Bulk Terminals (Facility is not a petroleum refinery, chemical plant, bulk plant, or bulk terminal)
BAAQMD Regulation 8, Rule 22	Valves and Flanges at Chemical Plants (Facility is not a chemical plant)
BAAQMD Regulation 8, Rule 25	Pump and Compressor Seals at Petroleum Refineries, Chemical Plants, Bulk Plants and Bulk Terminals (Facility is not a petroleum refinery, chemical plant, bulk plant, or bulk terminal)
BAAQMD Regulation 8, Rule 28	Pressure Relief Valves at Petroleum Refineries and Chemical Plants (Facility is not a petroleum refinery or chemical plant)
SIP Regulation 8, Rule 28	Pressure Relief Valves at Petroleum Refineries and Chemical Plants (Facility is not a petroleum refinery or chemical plant)

IX. Permit Shield (continued)

B. SUBSUMED REQUIREMENTS

Pursuant to District Regulations 2-6-233 and 2-6-409.12, as of the date this permit is issued, the federally enforceable “subsumed” regulations and/or standards cited in the following table are not applicable to the source or group of sources identified at the top of the table. The District has determined that compliance with the “streamlined” requirements listed below and elsewhere in this permit will assure compliance with the substantive requirements of the “subsumed” regulations and/or standards. Enforcement actions and litigation may not be initiated against the source or group of sources covered by this shield based on the “subsumed” regulatory and/or statutory provisions cited.

**Table IX-B
 S10 & S11, Gas Turbines**

Subsumed Requirement Citation	Title or Description	Streamlined Requirements	Title or Description
NSPS Subpart A			
60.13	Monitoring Requirements	BAAQMD Cond #13422, Part 5	Monitoring Requirements
NSPS Subpart GG	Standards of Performance for Stationary Gas Turbines		
60.334(b)(2)	Fuel Sulfur Limit Monitoring	BAAQMD Cond #13422, Part 4	H2S Concentration Limit in Fuel
60.334(b)(2)	Fuel Nitrogen Monitoring	BAAQMD Regulation 9-9-501	Monitoring and Recordkeeping Requirements
60.334(c)(1)	Periods of excess NOX emissions	BAAQMD Regulation 9-9-501	Monitoring and Recordkeeping Requirements
PSD Condition IX.E.1.a	NOX monitoring systems	BAAQMD Regulation 9-9-501	Monitoring and Recordkeeping Requirements

IX. Permit Shield (continued)

**Table IX-B (continued)
 S10 & S11, Gas Turbines**

Subsumed Requirement Citation	Title or Description	Streamlined Requirements	Title or Description
PSD Condition IX.E.3.a	Magnitude of Excess Emissions	BAAQMD Regulation 9-9-501	Monitoring and Recordkeeping Requirements
PSD Condition IX.E.3.b	Periods of Excess Emissions	BAAQMD Regulation 9-9-501	Monitoring and Recordkeeping Requirements
PSD Condition IX.E.3.c	CEM Downtime	BAAQMD Regulation 9-9-501	Monitoring and Recordkeeping Requirements
PSD Condition IX.E.3.d	Reports	BAAQMD Regulation 9-9-501	Monitoring and Recordkeeping Requirements
PSD Condition IX.E.6	Records	BAAQMD Regulation 9-9-501	Monitoring and Recordkeeping Requirements
BAAQMD Regulation 2-6-409.2	Periodic Monitoring for NOX limit in NSPS Subpart GG, 60.332(a)(1)	BAAQMD Regulation 9-9-501	Monitoring and Recordkeeping Requirements

X. GLOSSARY

BAAQMD

Bay Area Air Quality Management District

BACT

Best Available Control Technology

CAA

The federal Clean Air Act

CAAQS

California Ambient Air Quality Standards

CEQA

California Environmental Quality Act

CFR

The Code of Federal Regulations. 40 CFR contains the implementing regulations for federal environmental statutes such as the Clean Air Act. Parts 50-99 of 40 CFR contain the requirements for air pollution programs.

CO

Carbon Monoxide

Cumulative Increase

The sum of permitted emissions from each new or modified source since a specified date. Used to determine whether threshold-based requirements are triggered.

District

The Bay Area Air Quality Management District

EPA

The federal Environmental Protection Agency.

Excluded

Not subject to any District Regulations.

Federally Enforceable, FE

All limitations and conditions which are enforceable by the Administrator of the EPA including those requirements developed pursuant to 40 CFR Part 51, subpart I (NSR), Part 52.21 (PSD), Part 60, (NSPS), Part 61, (NESHAPS), Part 63 (HAP), and Part 72 (Permits Regulation, Acid Rain), and also including limitations and conditions contained in operating permits issued under an EPA-approved program that has been incorporated into the SIP.

X. Glossary (continued)

GLC

Ground level concentration.

HAP

Hazardous Air Pollutant. Any pollutant listed pursuant to Section 112(b) of the Act. Also refers to the program mandated by Title I, Section 112, of the Act and implemented by both 40 CFR Part 63, and District Regulation 2, Rule 5.

Major Facility

A facility with potential emissions of regulated air pollutants greater than 100 tons per year, greater than or equal to 10 tons per year of any single hazardous air pollutant, and/or greater than or equal to 25 tons per year of any combination of hazardous air pollutants, or such lesser quantity as determined by the EPA administrator.

MFR

Major Facility Review. The District's term for the federal operating permit program mandated by Title V of the Act and implemented by District Regulation 2, Rule 6.

MOP

The District's Manual of Procedures.

NAAQS

National Ambient Air Quality Standards

NESHAPS

National Emission Standards for Hazardous Air Pollutants. Contained in 40 CFR Part 61.

NMHC

Non-methane Hydrocarbons

NO_x

Oxides of nitrogen.

NSPS

Standards of Performance for New Stationary Sources. Federal standards for emissions from new stationary sources. Mandated by Title I, Section 111 of the Act, and implemented by both 40 CFR Part 60 and District Regulation 10.

NSR

New Source Review. A federal program for preconstruction review and permitting of new and modified sources of air pollutants for which the District is classified "non-attainment". Mandated by Title I of the Clean Air Act and implemented by 40 CFR Parts 51 and 52 as well as District Regulation 2, Rule 2. (Note: There are additional NSR requirements mandated by

X. Glossary (continued)

the California Clean Air Act.)

Offset Requirement

A New Source Review requirement to provide federally enforceable emission offsets at a specified ratio for the emissions from a new or modified source and any pre-existing cumulative increase minus any onsite contemporaneous emission reduction credits. Applies to emissions of POC, NO_x, PM₁₀, and SO₂.

Phase II Acid Rain Facility

A facility that generates electricity for sale through fossil-fuel combustion and by virtue of certain other characteristics (defined in Regulation 2, Rule 6) is subject to Titles IV and V of the Clean Air Act.

POC

Precursor Organic Compounds

PM

Total Particulate Matter

PM₁₀

Particulate matter with aerodynamic equivalent diameter of less than 10 microns

PSD

Prevention of Significant Deterioration. A federal program for permitting new and modified sources of air pollutants for which the District is classified "attainment" of the National Air Ambient Quality Standards. Mandated by Title I of the Act and implemented by both 40 CFR Part 52 and District Regulation 2, Rule 2.

SIP

State Implementation Plan. State and District programs and regulations approved by EPA and developed in order to attain the National Air Ambient Quality Standards. Mandated by Title I of the Act.

SO₂

Sulfur dioxide

Title V

Title V of the federal Clean Air Act. Requires a federally enforceable operating permit program for major and certain other facilities.

X. Glossary (continued)

VOC

Volatile Organic Compounds

Units of Measure:

bhp	=	brake-horsepower
Btu	=	British Thermal Unit
g	=	grams
gal	=	gallon
hp	=	horsepower
hr	=	hour
lb	=	pound
in=		inches
max	=	maximum
m ²	=	square meter
min	=	minute
MM	=	million
ppmv	=	parts per million, by volume
ppmw	=	parts per million, by weight
psia	=	pounds per square inch, absolute
psig	=	pounds per square inch, gauge
scfm	=	standard cubic feet per minute
yr	=	year

XI. APPENDIX A - APPLICABLE STATE IMPLEMENTATION PLAN

See Attachments