

Bay Area Air Quality Management District

939 Ellis Street
San Francisco, CA 94109
(415) 771-6000

Final

MAJOR FACILITY REVIEW PERMIT

Issued To:

West Contra Costa Sanitary Landfill, Inc.
Facility #A1840

Facility Address:

Foot of Parr Boulevard
Richmond, CA 94801

Mailing Address:

3260 Blume Drive, Suite 200
Richmond, CA 94806

Responsible Official

Mr. Bryce Howard
General Manager
707-396-1366

Facility Contact

Mr. Bryce Howard
General Manager
707-396-1366

Type of Facility: Solid Waste Landfill
and Electrical Generation
Primary SIC: 4953
Product: Disposal Services and Electricity

BAAQMD Engineering
Division Contact:
Jane H. Lundquist

ISSUED BY THE BAY AREA AIR QUALITY MANAGEMENT DISTRICT

Signed by Jack P. Broadbent _____ October 17, 2006
Jack P. Broadbent, Executive Officer/Air Pollution Control Officer Date

TABLE OF CONTENTS

| | |
|--|------------|
| I. STANDARD CONDITIONS..... | 3 |
| II. EQUIPMENT | 8 |
| III. GENERALLY APPLICABLE REQUIREMENTS..... | 12 |
| IV. SOURCE-SPECIFIC APPLICABLE REQUIREMENTS..... | 15 |
| V. SCHEDULE OF COMPLIANCE | 60 |
| VI. PERMIT CONDITIONS..... | 61 |
| VII. APPLICABLE LIMITS & COMPLIANCE MONITORING REQUIREMENTS | 82 |
| VIII. TEST METHODS..... | 112 |
| IX. PERMIT SHIELD | 118 |
| X. REVISION HISTORY | 119 |
| XI. GLOSSARY..... | 123 |
| XII. APPLICABLE STATE IMPLEMENTATION PLAN..... | 131 |

I. STANDARD CONDITIONS

A. Administrative Requirements

The permit holder shall comply with all applicable requirements in the following regulations:

- BAAQMD Regulation 1 - General Provisions and Definitions
(as amended by the District Board on 5/2/01);
- SIP Regulation 1 - General Provisions and Definitions
(as approved by EPA through 6/28/99);
- BAAQMD Regulation 2, Rule 1 - Permits, General Requirements
(as amended by the District Board on 6/15/05);
- SIP Regulation 2, Rule 1 - Permits, General Requirements
(as approved by EPA through 1/26/99);
- BAAQMD Regulation 2, Rule 2 - Permits, New Source Review
(as amended by the District Board on 6/15/05);
- SIP Regulation 2, Rule 2 - Permits, New Source Review and Prevention of Significant Deterioration
(as approved by EPA through 1/26/99);
- BAAQMD Regulation 2, Rule 4 - Permits, Emissions Banking
(as amended by the District Board on 12/21/04);
- SIP Regulation 2, Rule 4 - Permits, Emissions Banking
(as approved by EPA through 1/26/99); and
- BAAQMD Regulation 2, Rule 6 - Permits, Major Facility Review
(as amended by the District Board on 4/16/03).

B. Conditions to Implement Regulation 2, Rule 6, Major Facility Review

1. This Major Facility Review Permit was issued on May 29, 2002 and expires on April 30, 2007. The permit holder shall submit a complete application for renewal of this Major Facility Review Permit no later than October 31, 2006, and no earlier than April 30, 2006. **If a complete application for renewal has not been submitted in accordance with this deadline, the facility may not operate after April 30, 2007.** If the permit renewal has not been issued by April 30, 2007, but a complete application for renewal has been submitted in accordance with the above deadlines, the existing permit will continue in force until the District takes final action on the renewal application. (Regulation 2-6-307, 404.2, 407, & 409.6; MOP Volume II, Part 3, §4.2)
2. The permit holder shall comply with all conditions of this permit. The permit consists of this document and all appendices. Any non-compliance with the terms and conditions of this permit will constitute a violation of the law and will be grounds for enforcement action; permit termination, revocation and re-issuance, or modification; or denial of a permit renewal application. (Regulation 2-6-307; MOP Volume II, Part 3, §4.11)

I. Standard Conditions

3. In the event any enforcement action is brought as a result of a violation of any term or condition of this permit, the fact that it would have been necessary for the permittee to halt or reduce the permitted activity in order to maintain compliance with such term or condition shall not be a defense to such enforcement action. (MOP Volume II, Part 3, §4.11)
4. This permit may be modified, revoked, reopened and reissued, or terminated for cause. (Regulation 2-6-307, 409.8, 415; MOP Volume II, Part 3, §4.11)
5. The filing of a request by the facility for a permit modification, revocation and re-issuance, or termination, or the filing of a notification of planned changes or anticipated non-compliance does not stay the applicability of any permit condition. (Regulation 2-6-409.7; MOP Volume II, Part 3, §4.11)
6. This permit does not convey any property rights of any sort, or any exclusive privilege. (Regulation 2-6-409.7; MOP Volume II, Part 3, §4.11)
7. The permit holder shall supply within 30 days any information that the District requests in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. (Regulation 1-441, Regulation 2-6-409.4 & 501; MOP Volume II, Part 3, §4.11)
8. Any records required to be maintained pursuant to this permit, which the permittee considers to contain proprietary or trade secret information, shall be prominently designated as such. Copies of any such proprietary or trade secret information which are provided to the District shall be maintained by the District in a locked confidential file, provided, however, that requests from the public for the review of any such information shall be handled in accordance with the District's procedures set forth in Section 11 of the District's Administrative Code. (Regulation 2-6-419; MOP Volume II, Part 3, §4.11)
9. Proprietary or trade secret information provided to EPA will be subject to the requirements of 40 CFR Part 2, Subpart B - Public Information, Confidentiality of Business Information. (40 CFR Part 2)
10. The emissions inventory submitted with the application for this Major Facility Review Permit is an estimate of actual emissions or the potential to emit for the time period stated and is included only as one means of determining applicable requirements for emission sources. It does not establish, or constitute a basis for establishing, any new emission limitations. (MOP Volume II, Part 3, §4.11)

I. Standard Conditions

11. The responsible official shall certify all documents submitted by the facility pursuant to the major facility review permit. The certification shall state that based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete. The certifications shall be signed by a responsible official for the facility. (Regulation 2-6-409.20, MOP Volume II, Part 3, §4.11)
12. The permit holder is responsible for compliance, and certification of compliance, with all conditions of the permit, regardless whether it acts through employees, agents, contractors, or subcontractors. (Regulation 2-6-307)

C. Requirement to Pay Fees

The permit holder shall pay annual fees in accordance with District Regulation 3, including Schedule P. (Regulation 2-6-402 & 409.13, Regulation 3; MOP Volume II, Part 3, §4.12)

D. Inspection and Entry

Access to Facility: The permit holder shall provide reasonable access to the facility and equipment, which is subject to this permit, to the APCO and/or to his or her designee. (Regulation 1-440, Regulation 2-6-409.3; MOP Volume II, Part 3, §4.14)

E. Records

1. The permit holder must provide any information, records, and reports requested or specified by the APCO. (Regulation 1-441, Regulation 2-6-409.4)
2. Notwithstanding the specific wording in any requirement, all records for federally enforceable requirements shall be maintained for at least five years from the date of creation of the record. (Regulation 2-6-501, MOP Volume II, Part 3, §4.7)

F. Monitoring Reports

Reports of all required monitoring must be submitted to the District at least once every six months, except where an applicable requirement specifies more frequent reporting. The first reporting period for this permit shall be May 29, 2002 to October 31, 2002. The report shall be submitted by November 30, 2002. Subsequent reports shall be for the following periods: November 1st through April 30th and May 1st through October 31st, and are due on the last day of the month after the end of the reporting period. All instances of non-compliance shall be clearly identified in these reports. The reports shall be certified by the responsible official as true, accurate, and complete. In addition, all instances of non-compliance with the permit shall be reported in writing to the District's Compliance and Enforcement Division within 10 calendar days of the discovery of the incident. Within 30 calendar days of the discovery of any incident of non-compliance, the facility shall submit a written report including the probable cause of non-compliance and any corrective or preventative

I. Standard Conditions

actions. The reports shall be sent to the following address:

Director of Compliance and Enforcement
Bay Area Air Quality Management District
939 Ellis Street
San Francisco, CA 94109
Attn: Title V Reports

(Regulation 2-6-502, MOP Volume II, Part 3, §4.7)

G. Compliance Certification

Compliance certifications shall be submitted annually by the responsible official of this facility to the Bay Area Air Quality Management District and to the Environmental Protection Agency. The certification period will be May 1st through April 30th. The certification shall be submitted by May 31st of each year. The certification must list each applicable requirement, the compliance status, whether compliance was continuous or intermittent, the method used to determine compliance, and any other specific information required by the permit. The permit holder may satisfy this requirement through submittal of District-generated Compliance Certification forms. The certification should be directed to the District's Compliance and Enforcement Division at the address above, and a copy of the certification shall be sent to the Environmental Protection Agency at the following address:

Director of the Air Division
USEPA, Region IX
75 Hawthorne Street
San Francisco, CA 94105
Attention: Air-3

(MOP Volume II, Part 3, §4.5 and 4.15)

H. Emergency Provisions

1. The permit holder may seek relief from enforcement action in the event of a breakdown, as defined by Regulation 1-208 of the District's Rules and Regulations, by following the procedures contained in Regulations 1-431 and 1-432. The District will thereafter determine whether breakdown relief will be granted in accordance with Regulation 1-433. (MOP Volume II, Part 3, §4.8)
2. The permit holder may seek relief from enforcement action for a violation of any of the terms and conditions of this permit by applying to the District's Hearing Board for a variance pursuant to Health and Safety Code Section 42350. The

I. Standard Conditions

Hearing Board will determine after notice and hearing whether variance relief should be granted in accordance with the procedures and standards set forth in Health and Safety Code Section 42350 et seq. (MOP Volume II, Part 3, §4.8)

3. The granting by the District of breakdown relief or the issuance by the Hearing Board of a variance will not provide relief from federal enforcement. (MOP Volume II, Part 3, §4.8)

I. Severability

In the event that any provision of this permit is invalidated by a court or tribunal of competent jurisdiction, or by the Administrator of the EPA, all remaining portions of the permit shall remain in full force and effect. (Regulation 2-6-409.5; MOP Volume II, Part 3, §4.10)

J. Miscellaneous Conditions

1. The maximum capacity for each source as shown in Table II-A is the maximum allowable capacity. Exceedance of the maximum allowable capacity for any source is a violation of Regulation 2, Rule 1, Section 301. (Regulation 2-1-301)

II. EQUIPMENT

Table II A - Permitted Sources

Each of the following sources has been issued a permit to operate pursuant to the requirements of BAAQMD Regulation 2, Permits. The capacities in this table are the maximum allowable capacities for each source, pursuant to Standard Condition I.J and Regulation 2-1-301.

| S-# | Description | Make or Type | Model | Capacity |
|------|--|---|-----------|---|
| S-5 | Internal Combustion Lean Burn Engine, fired exclusively on landfill gas | Waukesha Lean Burn | 7042 GL | 1478 hp, 975 kW, 7040 in ³ , 11.9 E6 BTU/hour, 330-496 scfm of landfill gas, based on heat contents of 600-400 BTU/scf, respectively |
| S-6 | Internal Combustion Lean Burn Engine, fired exclusively on landfill gas | Waukesha Lean Burn | 7042 GL | 1478 hp, 975 kW, 7040 in ³ , 11.9 E6 BTU/hour, 330-496 scfm of landfill gas, based on heat contents of 600-400 BTU/scf, respectively |
| S-15 | West Contra Costa Sanitary Landfill Active Solid Waste Disposal Site with Active Gas Collection System Landfill gas collection system | Type of waste accepted are MSW, Commercial, Industrial, and Construction Horizontal Collectors Vertical Wells | | Max. Design Capacity = 21.47 E6 yd ³ (16.42 E6 m ³) Max. Acceptance Rate = 2500 tons/day Max. Cumulative Waste In Place = 13.0 E6 tons 16 collectors and 53 wells |
| S-22 | Primary Oil/Water Separator, TK-2 | Polycal Plastics | SP-084-4 | 1,850 Gallon Capacity, 1700 Gallons/Hour |
| S-23 | Secondary Oil/Water Separator, TK-4 | AFL Industries | VTC-5 | 450 Gallon Capacity, 300 Gallons/Hour |
| S-24 | Load Equalization Tank, TK-7 | Polycal Plastics | SPC-52 | 500 Gallon Capacity, 1700 Gallons/Hour |
| S-25 | Photo-Oxidizer Tank, TK-5 | Ryan Herco | 7353-030 | 300 Gallon Capacity, 1700 Gallons/Hour |
| S-26 | Neutralization Tank, TK-9 | Polycal Plastics | SPC-52 | 500 Gallon Capacity, 1700 Gallons/Hour |
| S-27 | First Stage Clarifier, TK-8 | Great Lakes | IPC-2-110 | 1700 Gallons/Hour |
| S-28 | Air Stripper Sump | Polycal Plastics | SP-724-U | 550 Gallon Capacity, 1700 Gallons/Hour |

II. Equipment

Table II A - Permitted Sources

Each of the following sources has been issued a permit to operate pursuant to the requirements of BAAQMD Regulation 2, Permits. The capacities in this table are the maximum allowable capacities for each source, pursuant to Standard Condition I.J and Regulation 2-1-301.

| S-# | Description | Make or Type | Model | Capacity |
|------|---|--|-------------|--|
| S-29 | Flocculation/Mixing Tank, TK-8A | Custom Made | Custom made | 20,300 Gallon Capacity, 1700 Gallons/Hour |
| S-30 | Air Stripper | Terraqua | | 1700 Gallons/Hour, 200 cfm |
| S-37 | Internal Combustion Lean Burn Engine, fired exclusively on landfill gas | Waukesha Lean Burn | 7042 GL | 1585 hp, 1050 kW, 7040 in ³ , 10.5 E6 BTU/hour, 292-437 scfm of landfill gas, based on heat contents of 600-400 BTU/scf, respectively |
| S-38 | Secondary Oil/Water Separator, TK-4 | Custom Made | Custom Made | 780 Gallon Capacity, 1700 Gallons/Hour |
| S-39 | Sludge Storage Tank, TK-3 | Custom Made | Custom Made | 1100 Gallon Capacity, 1700 Gallons/Hour |
| S-40 | Equalization Tank, TK-1 | Custom Made | Custom Made | 5000 Gallon Capacity, 1700 Gallons/Hour |
| S-46 | Hazardous Waste Management Facility (HWMF) equipped with landfill gas collection system | inactive hazardous waste disposal unit horizontal collectors | | 210,700 tons of decomposable waste 19 collectors (under construction) |
| S-50 | Solid Waste Transfer Station (under authority to construction) | Custom | Custom | 2000 tons/day, 730000 tons/year |

II. Equipment

Table II B – Abatement Devices

| A-# | Description | Source(s) Controlled | Applicable Requirement | Operating Parameters | Limit or Efficiency |
|-----|---|---|---------------------------------------|-------------------------------------|---|
| A-1 | Carbon Adsorber (in series with A-1 first followed by A-2) | S-22, S-23, S-24, S-25, S-26, S-27, S-28, S-29, S-38, S-39, and S-40 | BAAQMD Condition # 7463, Part 1 | NMHC in inlet and in A-1 exhaust | Replace carbon when NMHC removal effi- ciency is less than 90% by volume |
| A-2 | Carbon Adsorber (in series with A-1 first followed by A-2) | S-22, S-23, S-24, S-25, S-26, S-27, S-28, S-29, S-38, S-39, and S-40 | BAAQMD Condition # 7463, Part 1 | NMHC in A-2 exhaust | Replace carbon upon detection of 6 ppmv of NMHC |
| A-3 | Carbon Adsorber (in series with A-3 first followed by A-4) | S-30 | BAAQMD Condition # 7463, Part 2 | NMHC in inlet and in A-3 exhaust | Replace carbon when NMHC removal effi- ciency is less than 90% by volume |
| A-4 | Carbon Adsorber (in series with A-3 first followed by A-4) | S-30 | BAAQMD Condition # 7463, Part 2 | NMHC in A-4 exhaust | Replace carbon upon detection of 6 ppmv of NMHC |
| A-5 | Carbon Adsorber (in series with A-5 first followed by A-6) | S-30 | BAAQMD Condition # 7463, Part 2 | NMHC in inlet and in A-5 exhaust | Replace carbon when NMHC removal effi- ciency is less than 90% by volume |
| A-6 | Carbon Adsorber (in series with A-5 first followed by A-6) | S-30 | BAAQMD Condition # 7463, Part 2 | NMHC in A-6 exhaust | Replace carbon upon detection of 6 ppmv of NMHC |

II. Equipment

Table II B – Abatement Devices

| A-# | Description | Source(s) Controlled | Applicable Requirement | Operating Parameters | Limit or Efficiency |
|------------|--|---------------------------------|---|---|---|
| A-8 | Landfill Gas Flare, burning landfill gas, 49.5 MM BTU/hour | S-15 | BAAQMD 8-34-301.3, see also Table IV-B | Minimum combustion zone temperature of 1400 °F (3-hour average), see also Table VII-B | Either 98% destruction of NMOC or < 30 ppmv of NMOC, as CH ₄ , at 3% O ₂ , dry, see also Table VII-B |
| A-11 | Landfill Gas Flare for HWMF, Perennial Energy, Inc., Model # F-58-16-E, burning landfill gas, 5.25 MM BTU/hour (under construction) | S-46 | BAAQMD 8-34-301.3, see also Table IV-G | Minimum combustion zone temperature of 1400 °F (3 hour average), see also Table VII-G | Either 98% destruction of NMOC or < 30 ppmv of NMOC, as CH ₄ , at 3% O ₂ , dry, see also Table VII-G |
| A-50 | Water Mist System (under authority to construct) | S-50 | BAAQMD 6-301, see also Table IV-H | Wet waste as necessary to prevent particulate emissions | |

III. GENERALLY APPLICABLE REQUIREMENTS

The permit holder shall comply with all applicable requirements, including those specified in the BAAQMD and SIP rules and regulations and other federal requirements cited below. These requirements apply in a general manner to the facility and/or to sources exempt from the requirement to obtain a District Permit to Operate. The District has determined that these requirements will not be violated under normal, routine operations, and that no additional periodic monitoring or reporting to demonstrate compliance is warranted. In cases where a requirement, in addition to being generally applicable, is also specifically applicable to one or more sources, the requirement and the source are also included in Section IV, Source-Specific Applicable Requirements, of this permit. This section also contains provisions that may apply to temporary sources.

The dates in parentheses in the Title column identify the versions of the regulations being cited and are, as applicable:

1. BAAQMD regulation(s): The date(s) of adoption or most recent amendment of the regulation by the District Board of Directors
2. Any federal requirement, including a version of a District regulation that has been approved into the SIP: The most recent date of EPA approval of any portion of the rule, encompassing all actions on the rule through that date

The full language of SIP requirements is on EPA Region 9's website. The address is:

<http://yosemite.epa.gov/r9/r9sips.nsf/Agency?ReadForm&count=500&state=California&cat=Bay+Area+Air+Quality+Management+District-Agency-Wide+Provisions>

NOTE:

There are differences between the current BAAQMD rules and the versions of the rules in the SIP. All sources must comply with both versions of the rule until US EPA has reviewed and approved (or disapproved) the District's revision of the regulation.

**Table III
 Generally Applicable Requirements**

| Applicable Requirement | Regulation Title or Description of Requirement | Federally Enforceable (Y/N) |
|-----------------------------|---|-----------------------------|
| BAAQMD Regulation 1 | General Provisions and Definitions (5/2/01) | N |
| SIP Regulation 1 | General Provisions and Definitions (6/28/99) | Y ¹ |
| BAAQMD Regulation 2, Rule 1 | General Requirements (6/15/05) | N |
| BAAQMD 2-1-429 | Federal Emissions Statement (6/7/95) | Y |
| SIP Regulation 2, Rule 1 | General Requirements (1/26/99) | Y ¹ |
| BAAQMD Regulation 2, Rule 5 | New Source Review of Toxic Air Contaminants (6/15/05) | N |
| BAAQMD Regulation 4 | Air Pollution Episode Plan (3/20/91) | N |

III. Generally Applicable Requirements

Table III
Generally Applicable Requirements

| Applicable Requirement | Regulation Title or Description of Requirement | Federally Enforceable (Y/N) |
|-------------------------------|--|------------------------------------|
| SIP Regulation 4 | Air Pollution Episode Plan (8/6/90) | Y ¹ |
| BAAQMD Regulation 5 | Open Burning (3/6/02) | N |
| SIP Regulation 5 | Open Burning (9/4/98) | Y ¹ |
| BAAQMD Regulation 6 | Particulate Matter and Visible Emissions (12/19/90) | Y |
| BAAQMD Regulation 7 | Odorous Substances (3/17/82) | N |
| BAAQMD Regulation 8, Rule 1 | Organic Compounds – General Provisions (6/15/94) | Y |
| BAAQMD Regulation 8, Rule 2 | Organic Compounds – Miscellaneous Operations (7/20/05) | Y |
| BAAQMD Regulation 8, Rule 3 | Organic Compounds - Architectural Coatings (11/21/01) | Y |
| BAAQMD Regulation 8, Rule 4 | Organic Compounds - General Solvent and Surface Coating Operations (10/16/02) | Y |
| BAAQMD Regulation 8, Rule 15 | Organic Compounds – Emulsified and Liquid Asphalts (6/1/94) | Y |
| BAAQMD Regulation 8, Rule 16 | Organic Compounds – Solvent Cleaning Operations (10/16/02) | Y |
| BAAQMD Regulation 8, Rule 40 | Organic Compounds – Aeration of Contaminated Soil and Removal of Underground Storage Tanks (6/15/05) | Y |
| BAAQMD 8-40-116 | Exemption, Small Volume | Y |
| BAAQMD 8-40-117 | Exemption, Accidental Spills | Y |
| BAAQMD Regulation 8, Rule 47 | Organic Compounds – Air Stripping and Soil Vapor Extraction Operations (6/15/05) | Y |
| BAAQMD Regulation 8, Rule 49 | Organic Compounds – Aerosol Paint Products (12/20/95) | N |
| SIP Regulation 8, Rule 49 | Organic Compounds – Aerosol Paint Products (3/22/95) | Y ¹ |
| BAAQMD Regulation 8, Rule 51 | Organic Compounds - Adhesive and Sealant Products (7/17/02) | N |
| SIP Regulation 8, Rule 51 | Organic Compounds - Adhesive and Sealant Products (2/26/02) | Y ¹ |
| BAAQMD Regulation 9, Rule 1 | Inorganic Gaseous Pollutants – Sulfur Dioxide (3/15/95) | N |
| SIP Regulation 9, Rule 1 | Inorganic Gaseous Pollutants - Sulfur Dioxide (6/8/99) | Y ¹ |
| BAAQMD Regulation 11, Rule 1 | Hazardous Pollutants - Lead (3/17/82) | N |
| SIP Regulation 11, Rule 1 | Hazardous Pollutants - Lead (9/2/81) | Y ¹ |
| BAAQMD Regulation 11, Rule 2 | Hazardous Pollutants - Asbestos Demolition, Renovation and Manufacturing (10/7/98) | N |
| BAAQMD Regulation 11, Rule 14 | Hazardous Pollutants – Asbestos-Containing Serpentine (7/17/91) | N |

III. Generally Applicable Requirements

**Table III
 Generally Applicable Requirements**

| Applicable Requirement | Regulation Title or Description of Requirement | Federally Enforceable (Y/N) |
|---|---|------------------------------------|
| BAAQMD Regulation 12, Rule 4 | Miscellaneous Standards of Performance - Sandblasting (7/11/90) | N |
| SIP Regulation 12, Rule 4 | Miscellaneous Standards of Performance - Sandblasting (9/2/81) | Y ¹ |
| California Code of Regulations Title 17, Section 93105 | Asbestos Airborne Toxic Control Measure for Construction, Grading, Quarrying, and Surface Mining Operations (7/26/01) | N |
| California Code of Regulations Title 17, Section 93106 | Asbestos Airborne Toxic Control Measure for Asbestos-Containing Serpentine (7/20/00) | N |
| California Code of Regulations Title 17, Section 93115 | Airborne Toxic Control Measure for Stationary Compression Ignition Engines (11/8/04) | N |
| California Health and Safety Code Section 41750 et seq. | Portable Equipment | N |
| California Health and Safety Code Section 44300 et seq. | Air Toxics "Hot Spots" Information and Assessment Act of 1987 | N |
| 40 CFR Part 61, Subpart A | National Emission Standards for Hazardous Air Pollutants – General Provisions (4/9/04) | Y |
| 40 CFR Part 61, Subpart M | National Emission Standards for Hazardous Air Pollutants – National Emission Standard for Asbestos (7/20/04) | Y |

1. This section has been removed from BAAQMD Regulations because it has been superseded. Nevertheless, the source must comply with this regulation until US EPA has reviewed and approved (or disapproved) the District's revision of the regulation.

IV. SOURCE-SPECIFIC APPLICABLE REQUIREMENTS

The permit holder shall comply with all applicable requirements, including those specified in the BAAQMD and SIP rules and regulations and other federal requirements cited below. The requirements cited in the following tables apply in a specific manner to the indicated source(s).

The dates in parentheses in the Title column identify the versions of the regulations being cited and are, as applicable:

1. BAAQMD regulation(s): The date(s) of adoption or most recent amendment of the regulation by the District Board of Directors
2. Any federal requirement, including a version of a District regulation that has been approved into the SIP: The most recent date of EPA approval of any portion of the rule, encompassing all actions on the rule through that date

The full text of each permit condition cited is included in Section VI, Permit Conditions, of this permit. The full language of SIP requirements is on EPA Region 9's website. The address is:

<http://yosemite.epa.gov/r9/r9sips.nsf/Agency?ReadForm&count=500&state=California&cat=Bay+Area+Air+Quality+Management+District-Agency-Wide+Provisions>

All other text may be found in the regulations themselves.

Table IV – A
Source-Specific Applicable Requirements
S-5 INTERNAL COMBUSTION LEAN BURN ENGINE; AND
S-6 INTERNAL COMBUSTION LEAN BURN ENGINE

| Applicable Requirement | Regulation Title or Description of Requirement | Federally Enforceable (Y/N) | Future Effective Date |
|----------------------------|--|-----------------------------|-----------------------|
| BAAQMD Regulation 1 | General Provisions and Definitions (5/2/01) | | |
| 1-523 | Parametric Monitoring and Recordkeeping Procedures | N | |
| 1-523.1 | Reporting requirement for periods of in-operation > 24 hours | Y | |
| 1-523.2 | Limit on duration of in operation | Y | |
| 1-523.3 | Reporting requirement for violations of any applicable limits | N | |
| 1-523.4 | Records of in-operation, tests, calibrations, adjustments, & maintenance | Y | |
| 1-523.5 | Maintenance and calibration | N | |
| SIP Regulation 1 | General Provisions and Definitions (6/28/99) | | |
| 1-523 | Parametric Monitoring and Recordkeeping Procedures | Y ¹ | |

IV. Source Specific Applicable Requirements

Table IV – A
Source-Specific Applicable Requirements
S-5 INTERNAL COMBUSTION LEAN BURN ENGINE; AND
S-6 INTERNAL COMBUSTION LEAN BURN ENGINE

| Applicable Requirement | Regulation Title or Description of Requirement | Federally Enforceable (Y/N) | Future Effective Date |
|-------------------------------------|--|------------------------------------|------------------------------|
| 1-523.3 | Reports of Violations | Y ¹ | |
| BAAQMD Regulation 6 | Particulate Matter and Visible Emissions (12/19/90) | | |
| 6-301 | Ringelmann No. 1 Limitation | Y | |
| 6-305 | Visible Particles | Y | |
| 6-310 | Particle Weight Limitation | Y | |
| 6-401 | Appearance of Emissions | Y | |
| BAAQMD Regulation 8, Rule 34 | Organic Compounds - Solid Waste Disposal Sites (6/15/05) | | |
| 8-34-113 | Limited Exemption, Inspection and Maintenance | Y | |
| 8-34-113.1 | Emission Minimization Requirement | Y | |
| 8-34-113.2 | Shutdown Time Limitation | Y | |
| 8-34-113.3 | Record keeping Requirement | Y | |
| 8-34-301 | Landfill Gas Collection and Emission Control System Requirements | Y | |
| 8-34-301.1 | Continuous Operation | Y | |
| 8-34-301.2 | Collection and Control Systems Leak Limitations | Y | |
| 8-34-301.4 | Limits for Other Emission Control Systems | Y | |
| 8-34-412 | Compliance Demonstration Tests | Y | |
| 8-34-413 | Performance Test Report | Y | |
| 8-34-501 | Operating Records | Y | |
| 8-34-501.2 | Emission Control System Downtime | Y | |
| 8-34-501.4 | Testing | Y | |
| 8-34-501.6 | Leak Discovery and Repair Records | Y | |
| 8-34-501.10 | Gas Flow Rate Records for All Emission Control Systems | Y | |
| 8-34-501.11 | Records of Key Emission Control System Operating Parameters | Y | |
| 8-34-501.12 | Records Retention for 5 Years | Y | |
| 8-34-503 | Landfill Gas Collection and Emission Control System Leak Testing | Y | |
| 8-34-504 | Portable Hydrocarbon Detector | Y | |
| 8-34-508 | Gas Flow Meter | Y | |
| 8-34-509 | Key emission control system operating parameters | Y | |

IV. Source Specific Applicable Requirements

Table IV – A
Source-Specific Applicable Requirements
S-5 INTERNAL COMBUSTION LEAN BURN ENGINE; AND
S-6 INTERNAL COMBUSTION LEAN BURN ENGINE

| Applicable Requirement | Regulation Title or Description of Requirement | Federally Enforceable (Y/N) | Future Effective Date |
|------------------------------------|--|------------------------------------|------------------------------|
| BAAQMD Regulation 9, Rule 1 | Inorganic Gaseous Pollutants – Sulfur Dioxide (3/15/95) | | |
| 9-1-301 | Limitations on Ground Level Concentrations | Y | |
| 9-1-302 | General Emission Limitations | Y | |
| BAAQMD Regulation 9, Rule 2 | Inorganic Gaseous Pollutants – Hydrogen Sulfide (10/6/99) | | |
| 9-2-301 | Limitations on Hydrogen Sulfide | N | |
| BAAQMD Regulation 9 Rule 8 | Inorganic Gaseous Pollutants – Nitrogen Oxides and Carbon Monoxide from Stationary Internal Combustion Engines (8/1/01) | | |
| 9-8-302 | Emission Limits – Waste Derived Fuel Gas | Y | |
| 9-8-302.1 | Lean-Burn Engines: NOx Emission Limit | Y | |
| 9-8-302.3 | CO Emission Limit | Y | |
| 40 CFR Part 60, Subpart A | Standards of Performance for New Stationary Sources – General Provisions (5/4/98) | | |
| 60.4(b) | Requires Submission of Requests, Reports, Applications, and Other Correspondence to the Administrator | Y | |
| 60.7 | Notification and Record Keeping | Y | |
| 60.8 | Performance Tests | Y | |
| 60.11 | Compliance with Standards and Maintenance Requirements | Y | |
| 60.11(a) | Compliance determined by performance tests | Y | |
| 60.11(d) | Good air pollution control practice | Y | |
| 60.12 | Circumvention | Y | |
| 60.13 | Monitoring Requirements | Y | |
| 60.13(a) | Applies to all continuous monitoring systems | Y | |
| 60.13(b) | Monitors shall be installed and operational before performing performance tests | Y | |
| 60.13(e) | Continuous monitors shall operate continuously | Y | |
| 60.13(f) | Monitors shall be installed in proper locations | Y | |
| 60.13(g) | Requires multiple monitors for multiple stacks | Y | |

IV. Source Specific Applicable Requirements

Table IV – A
Source-Specific Applicable Requirements
S-5 INTERNAL COMBUSTION LEAN BURN ENGINE; AND
S-6 INTERNAL COMBUSTION LEAN BURN ENGINE

| Applicable Requirement | Regulation Title or Description of Requirement | Federally Enforceable (Y/N) | Future Effective Date |
|------------------------------------|--|------------------------------------|------------------------------|
| 60.14 | Modification | Y | |
| 60.15 | Reconstruction | Y | |
| 60.19 | General Notification and Reporting Requirements | Y | |
| 40 CFR Part 60, Subpart WWW | Standards of Performance for New Stationary Sources – Standards of Performance for Municipal Solid Waste Landfills (2/24/99) | | |
| 60.752 | Standards for Air Emissions from Municipal Solid Waste Landfills | Y | |
| 60.752(b) | Comply with paragraph (b)(2) or calculate NMOC emission rate | Y | |
| 60.752(b)(2) | Comply with all requirements in sections (b)(2)(i through iv) | Y | |
| 60.752 (b)(2)(i) | Submit a collection and control system design plan | Y | |
| 60.752 (b)(2)(ii) | Install a collection and control system | Y | |
| 60.752 (b)(2)(iii) | Route collected gases to a control system | Y | |
| 60.752 (b)(2)(iii)(B) | Reduce NMOC emissions by 98% by weight or reduce NMOC outlet concentration to less than 20 ppmv as hexane at 3% O ₂ , dry basis | Y | |
| 60.752 (b)(2)(iv) | Operate in accordance with 60.753, 60.755, and 60.756 | Y | |
| 60.753 | Operational Standards for Collection and Control Systems | Y | |
| 60.753(e) | Vent all collected gases to a control system complying with 60.752(b)(2)(iii) | Y | |
| 60.753(f) | Operate the control system at all times when collected gas is Routed to the control system | Y | |
| 60.754 | Test Methods and Procedures | Y | |
| 60.754(d) | Test Methods for Performance Test (Method 18 or 25C) | Y | |
| 60.755 | Compliance Provisions | Y | |
| 60.755(e) | Provisions apply at all times except during startup, shutdown, or malfunction, provided the duration of these shall not exceed 5 days for collection systems or 1 hour for control systems | Y | |
| 60.756 | Monitoring of Operations | Y | |

IV. Source Specific Applicable Requirements

Table IV – A
Source-Specific Applicable Requirements
S-5 INTERNAL COMBUSTION LEAN BURN ENGINE; AND
S-6 INTERNAL COMBUSTION LEAN BURN ENGINE

| Applicable Requirement | Regulation Title or Description of Requirement | Federally Enforceable (Y/N) | Future Effective Date |
|----------------------------------|---|------------------------------------|------------------------------|
| 60.756(d) | Approval of other control devices | Y | |
| 60.756(e) | Procedures for requesting alternative monitoring parameters | Y | |
| 60.757 | Reporting Requirements | Y | |
| 60.757(c) | Submit a Collection and Control System Design Plan | Y | |
| 60.757(e) | Submit Equipment Removal Report 30 days prior to removal or cessation of operation of the control equipment | Y | |
| 60.757(f) | Submit Annual Reports containing information required by (f)(1), (f)(2), and (f)(3) | Y | |
| 60.757(f)(1) | Value and length of time for exceedance of parameters monitored per 60.756(b) or (e) | Y | |
| 60.757(f)(2) | Description and duration of all periods when gas is diverted from the control device by a by-pass line | Y | |
| 60.757(f)(3) | Description and duration of all periods when control device was not operating for more than 1 hour | Y | |
| 60.758 | Recordkeeping Requirements | Y | |
| 60.758(b) | Control Equipment Records (Control Device Vendor Specifications) Note: Subsections 1 through 4 do not apply. | Y | |
| 60.758(c) | Records of parameters monitored pursuant to 60.756 (e) | Y | |
| 60.758(e) | Records of any exceedance of 60.753(e) or (f) | Y | |
| 40 CFR Part 62 | Approval and Promulgation of State Plans for Designated Facilities and Pollutants (6/9/03) | | |
| 62.1100 | Identification of Plan | Y | |
| 62.1115 | Identification of Sources | Y | |
| 40 CFR Part 63, Subpart A | National Emission Standards for Hazardous Air Pollutants: General Provisions (4/22/04) | | |
| 63.4 | Prohibited activities and circumvention | Y | |
| 63.5(b) | Requirements for existing, newly constructed, and reconstructed sources | Y | |
| 63.6(e) | Operation and maintenance requirements and SSM Plan | Y | |
| 63.6(f) | Compliance with non-opacity emission standards | Y | |

IV. Source Specific Applicable Requirements

Table IV – A
Source-Specific Applicable Requirements
S-5 INTERNAL COMBUSTION LEAN BURN ENGINE; AND
S-6 INTERNAL COMBUSTION LEAN BURN ENGINE

| Applicable Requirement | Regulation Title or Description of Requirement | Federally Enforceable (Y/N) | Future Effective Date |
|-------------------------------------|---|------------------------------------|------------------------------|
| 63.10(b)(2)(i-v) | Records for startup, shutdown, malfunction, and maintenance | Y | |
| 63.10(d)(5) | Startup, Shutdown, and Malfunction (SSM) Reports | Y | |
| 40 CFR Part 63, Subpart AAAA | National Emission Standards for Hazardous Air Pollutants: Municipal Solid Waste Landfills (1/16/03) | | |
| 63.1945 | When do I have to comply with this subpart? | Y | |
| 63.1945(b) | Compliance date for existing affected landfills | Y | |
| 63.1955 | What requirements must I meet? | Y | |
| 63.1955(a)(2) | Comply with State Plan that implements 40 CFR Part 60, Subpart Cc | Y | |
| 63.1955(b) | Comply with 63.1960-63.1985, if a collection and control system is required by 40 CFR Part 60, Subpart WWW or a State Plan implementing 40 CFR Part 60, Subpart Cc | Y | |
| 63.1955(c) | Comply with all approved alternatives to standards for collection and control systems plus all SSM requirements and 6 month compliance reporting requirements | Y | |
| 63.1960 | How is compliance determined? | Y | |
| 63.1965 | What is a deviation? | Y | |
| 63.1975 | How do I calculate the 3-hour block average used to demonstrate compliance? | Y | |
| 63.1980 | What records and reports must I keep and submit? | Y | |
| 63.1980(a) | Comply with all record keeping and reporting requirements in 40 CFR Part 60, Subpart WWW or the State Plan implementing 40 CFR Part 60, Subpart Cc, except that the annual report required by 40 CFR 60.757(f) must be submitted every 6 months | Y | |
| 63.1980(b) | Comply with all record keeping and reporting requirements in 40 CFR Part 60, Subpart A and 40 CFR Part 63, Subpart A, including SSM Plans and Reports | Y | |
| BAAQMD Condition # 5771 | | | |
| Part 1 | Fuel Restrictions (Cumulative Increase) | Y | |

IV. Source Specific Applicable Requirements

Table IV – A
Source-Specific Applicable Requirements
S-5 INTERNAL COMBUSTION LEAN BURN ENGINE; AND
S-6 INTERNAL COMBUSTION LEAN BURN ENGINE

| Applicable Requirement | Regulation Title or Description of Requirement | Federally Enforceable (Y/N) | Future Effective Date |
|-------------------------------|--|------------------------------------|------------------------------|
| Part 2 | Diverter Valve Requirement (Regulation 8-34-301) | Y | |
| Part 3 | Gas Flow Meter Requirement (Cumulative Increase and Regulation 8-34-508) | Y | |
| Part 4 | NOx Emissions Limit (BACT, Offsets) | Y | |
| Part 5 | CO Emissions Limit (BACT) | Y | |
| Part 6 | NMOC Emissions Limit (BACT and Regulation 8-34-301.4) | Y | |
| Part 7 | Annual Source Test Requirement (BACT and Regulations 8-34-301.4, 8-34-412, 9-8-302.1, and 9-8-302.3) | Y | |
| Part 8 | Heat Input Limitation (Regulation 2-1-301, Offsets) | Y | |
| Part 9 | Daily Record Keeping Requirement (Cumulative Increase and Regulations 2-1-301, 2-6-501, and 8-34-301) | Y | |
| Part 10 | Engine Temperature Limit and Temperature Monitoring Requirements (Regulations 8-34-301, 8-34-501.11, and 8-34-509) | Y | |

- 1 This section has been removed from BAAQMD Regulations because it has been superseded. Nevertheless, the source must comply with this regulation until US EPA has reviewed and approved (or disapproved) the District's revision of the regulation.

IV. Source Specific Applicable Requirements

Table IV – B
Source-Specific Applicable Requirements
S-15 WEST CONTRA COSTA SANITARY LANDFILL; AND
A-8 LANDFILL GAS FLARE

| Applicable Requirement | Regulation Title or Description of Requirement | Federally Enforceable (Y/N) | Future Effective Date |
|-------------------------------------|--|------------------------------------|------------------------------|
| BAAQMD Regulation 1 | General Provisions and Definitions (5/2/01) | | |
| 1-523 | Parametric Monitoring and Recordkeeping Procedures | N | |
| 1-523.1 | Reporting requirement for periods of inoperation > 24 hours | Y | |
| 1-523.2 | Limit on duration of inoperation | Y | |
| 1-523.3 | Reporting requirement for violations of any applicable limits | N | |
| 1-523.4 | Records of inoperation, tests, calibrations, adjustments, & maintenance | Y | |
| 1-523.5 | Maintenance and calibration | N | |
| SIP Regulation 1 | General Provisions and Definitions (6/28/99) | | |
| 1-523 | Parametric Monitoring and Recordkeeping Procedures | Y ¹ | |
| 1-523.3 | Reports of Violations | Y ¹ | |
| BAAQMD Regulation 6 | Particulate Matter and Visible Emissions (12/19/90) | | |
| 6-301 | Ringelmann No. 1 Limitation | Y | |
| 6-305 | Visible Particles | Y | |
| 6-310 | Particle Weight Limitation (applies to A-8 Flare only) | Y | |
| 6-401 | Appearance of Emissions | Y | |
| BAAQMD Regulation 8, Rule 2 | Organic Compounds – Miscellaneous Operations (7/20/05) | | |
| 8-2-301 | Miscellaneous Operations (applies to low VOC soil handling and disposal activities only) | Y | |
| BAAQMD Regulation 8, Rule 34 | Organic Compounds – Solid Waste Disposal Sites (6/15/05) | | |
| 8-34-113 | Limited Exemption, Inspection and Maintenance | Y | |
| 8-34-113.1 | Emission Minimization Requirement | Y | |
| 8-34-113.2 | Shutdown Time Limitation | Y | |
| 8-34-113.3 | Recordkeeping Requirement | Y | |
| 8-34-116 | Limited Exemption, Well Raising | Y | |
| 8-34-116.1 | New Fill | Y | |

IV. Source Specific Applicable Requirements

Table IV – B
Source-Specific Applicable Requirements
S-15 WEST CONTRA COSTA SANITARY LANDFILL; AND
A-8 LANDFILL GAS FLARE

| Applicable Requirement | Regulation Title or Description of Requirement | Federally Enforceable (Y/N) | Future Effective Date |
|-------------------------------|---|------------------------------------|------------------------------|
| 8-34-116.2 | Limits on Number of Wells Shutdown | Y | |
| 8-34-116.3 | Shutdown Duration Limit | Y | |
| 8-34-116.4 | Capping Well Extensions | Y | |
| 8-34-116.5 | Well Disconnection Records | Y | |
| 8-34-117 | Limited Exemption, Gas Collection System Components | Y | |
| 8-34-117.1 | Necessity of Existing Component Repairs/Adjustments | Y | |
| 8-34-117.2 | New Components are Described in Collection and Control System Design Plan | Y | |
| 8-34-117.3 | Meets Section 8-34-118 Requirements | Y | |
| 8-34-117.4 | Limits on Number of Wells Shutdown | Y | |
| 8-34-117.5 | Shutdown Duration Limit | Y | |
| 8-34-117.6 | Well Disconnection Records | Y | |
| 8-34-118 | Limited Exemption, Construction Activities | Y | |
| 8-34-118.1 | Construction Plan | Y | |
| 8-34-118.2 | Activity is Required to Maintain Compliance with this Rule | Y | |
| 8-34-118.3 | Required or Approved by Other Enforcement Agencies | Y | |
| 8-34-118.4 | Emission Minimization Requirement | Y | |
| 8-34-118.5 | Excavated Refuse Requirements | Y | |
| 8-34-118.6 | Covering Requirements for Exposed Refuse | Y | |
| 8-34-118.7 | Installation Time Limit | Y | |
| 8-34-118.8 | Capping Required for New Components | Y | |
| 8-34-118.9 | Construction Activity Records | Y | |
| 8-34-301 | Landfill Gas Collection and Emission Control System Requirements | Y | |
| 8-34-301.1 | Continuous Operation | Y | |
| 8-34-301.2 | Collection and Control Systems Leak Limitations | Y | |
| 8-34-301.3 | Limits for Enclosed Flares | Y | |
| 8-34-303 | Landfill Surface Requirements | Y | |
| 8-34-304 | Gas Collection System Installation Requirements | Y | |
| 8-34-304.1 | Based on Waste Age For Inactive or Closed Areas | Y | |
| 8-34-304.2 | Based on Waste Age For Active Areas | Y | |
| 8-34-304.3 | Based on Amount of Decomposable Waste Accepted | Y | |
| 8-34-304.4 | Based on NMOC Emission Rate | Y | |

IV. Source Specific Applicable Requirements

Table IV – B
Source-Specific Applicable Requirements
S-15 WEST CONTRA COSTA SANITARY LANDFILL; AND
A-8 LANDFILL GAS FLARE

| Applicable Requirement | Regulation Title or Description of Requirement | Federally Enforceable (Y/N) | Future Effective Date |
|-------------------------------|---|------------------------------------|------------------------------|
| 8-34-305 | Wellhead Requirements | Y | |
| 8-34-305.1 | Operate Under Vacuum | Y | |
| 8-34-305.2 | Temperature < 55 °C | Y | |
| 8-34-305.3 | Nitrogen < 20% or | Y | |
| 8-34-305.4 | Oxygen < 5% | Y | |
| 8-34-405 | Design Capacity Reports | Y | |
| 8-34-408 | Collection and Control System Design Plans | Y | |
| 8-34-408.2 | Sites With Existing Collection and Control Systems | Y | |
| 8-34-411 | Annual Report | Y | |
| 8-34-412 | Compliance Demonstration Tests | Y | |
| 8-34-413 | Performance Test Report | Y | |
| 8-34-414 | Repair Schedule for Wellhead Excesses | Y | |
| 8-34-414.1 | Records of Excesses | Y | |
| 8-34-414.2 | Corrective Action | Y | |
| 8-34-414.3 | Collection System Expansion | Y | |
| 8-34-414.4 | Operational Due Date for Expansion | Y | |
| 8-34-415 | Repair Schedule for Surface Leak Excesses | Y | |
| 8-34-415.1 | Records of Excesses | Y | |
| 8-34-415.2 | Corrective Action | Y | |
| 8-34-415.3 | Re-monitor Excess Location Within 10 Days | Y | |
| 8-34-415.4 | Re-monitor Excess Location Within 1 Month | Y | |
| 8-34-415.5 | If No More Excesses, No Further Re-Monitoring | Y | |
| 8-34-415.6 | Additional Corrective Action | Y | |
| 8-34-415.7 | Re-monitor Second Excess Within 10 days | Y | |
| 8-34-415.8 | Re-monitor Second Excess Within 1 Month | Y | |
| 8-34-415.9 | If No More Excesses, No Further Re-monitoring | Y | |
| 8-34-415.10 | Collection System Expansion for Third Excess in a Quarter | Y | |
| 8-34-415.11 | Operational Due Date for Expansion | Y | |
| 8-34-416 | Cover Repairs | Y | |
| 8-34-501 | Operating Records | Y | |
| 8-34-501.1 | Collection System Downtime | Y | |
| 8-34-501.2 | Emission Control System Downtime | Y | |

IV. Source Specific Applicable Requirements

Table IV – B
Source-Specific Applicable Requirements
S-15 WEST CONTRA COSTA SANITARY LANDFILL; AND
A-8 LANDFILL GAS FLARE

| Applicable Requirement | Regulation Title or Description of Requirement | Federally Enforceable (Y/N) | Future Effective Date |
|------------------------------------|---|------------------------------------|------------------------------|
| 8-34-501.3 | Continuous Temperature Records for Enclosed Combustors | Y | |
| 8-34-501.4 | Testing | Y | |
| 8-34-501.6 | Leak Discovery and Repair Records | Y | |
| 8-34-501.7 | Waste Acceptance Records | Y | |
| 8-34-501.8 | Non-decomposable Waste Records | Y | |
| 8-34-501.9 | Wellhead Excesses and Repair Records | Y | |
| 8-34-501.10 | Gas Flow Rate Records for All Emission Control Systems | Y | |
| 8-34-501.12 | Records Retention for 5 Years | Y | |
| 8-34-503 | Landfill Gas Collection and Emission Control System Leak Testing | Y | |
| 8-34-504 | Portable Hydrocarbon Detector | Y | |
| 8-34-505 | Well Head Monitoring | Y | |
| 8-34-506 | Landfill Surface Monitoring | Y | |
| 8-34-507 | Continuous Temperature Monitor and Recorded | Y | |
| 8-34-508 | Gas Flow Meter | Y | |
| 8-34-510 | Cover Integrity Monitoring | Y | |
| BAAQMD Regulation 9, Rule 1 | Inorganic Gaseous Pollutants – Sulfur Dioxide (3/15/95) | | |
| 9-1-301 | Limitations on Ground Level Concentrations | Y | |
| 9-1-302 | General Emission Limitations (applies to A-8 Flare only) | Y | |
| BAAQMD Regulation 9, Rule 2 | Inorganic Gaseous Pollutants – Hydrogen Sulfide (10/6/99) | | |
| 9-2-301 | Limitations on Hydrogen Sulfide | N | |
| 40 CFR Part 60, Subpart A | Standards of Performance for New Stationary Sources – General Provisions (5/4/98) | | |
| 60.4(b) | Requires Submission of Requests, Reports, Applications, and Other Correspondence to the Administrator | Y | |
| 60.7 | Notification and Record Keeping | Y | |
| 60.8 | Performance Tests | Y | |
| 60.11 | Compliance with Standards and Maintenance Requirements | Y | |

IV. Source Specific Applicable Requirements

Table IV – B
Source-Specific Applicable Requirements
S-15 WEST CONTRA COSTA SANITARY LANDFILL; AND
A-8 LANDFILL GAS FLARE

| Applicable Requirement | Regulation Title or Description of Requirement | Federally Enforceable (Y/N) | Future Effective Date |
|------------------------------------|--|------------------------------------|------------------------------|
| 60.11(a) | Compliance determined by performance tests | Y | |
| 60.11(d) | Control devices operated using good air pollution control practice | Y | |
| 60.12 | Circumvention | Y | |
| 60.13 | Monitoring Requirements | Y | |
| 60.13(a) | Applies to all continuous monitoring systems | Y | |
| 60.13(b) | Monitors shall be installed and operational before performing performance tests | Y | |
| 60.13(e) | Continuous monitors shall operate continuously | Y | |
| 60.13(f) | Monitors shall be installed in proper locations | Y | |
| 60.13(g) | Requires multiple monitors for multiple stacks | Y | |
| 60.14 | Modification | Y | |
| 60.15 | Reconstruction | Y | |
| 60.19 | General Notification and Reporting Requirements | Y | |
| 40 CFR Part 60, Subpart WWW | Standards of Performance for New Stationary Sources – Standards of Performance for Municipal Solid Waste Landfills (2/24/99) | | |
| 60.752 | Standards for Air Emissions from Municipal Solid Waste Landfills | Y | |
| 60.752(b) | Requirements for MSW Landfills with Design Capacity equal to or greater than 2.5 million Mg and 2.5 million m ³ (Large Designated Facilities) | Y | |
| 60.752(b)(2) | Comply with all requirements in sections (b)(2)(i through iv) | Y | |
| 60.752 (b)(2)(i) | Submit a Collection and Control System Design Plan | Y | |
| 60.752 (b)(2)(i)(A) | The collection and control system in the Design Plan shall comply with 60.752(b)(2)(ii) | Y | |
| 60.752 (b)(2)(i)(B) | Design Plan shall include all proposed alternatives to 60.753 through 60.758 | Y | |
| 60.752 (b)(2)(i)(C) | Design Plan shall conform to 60.759 (active collection system) or demonstrate sufficiency of proposed alternatives | Y | |
| 60.752 (b)(2)(ii) | Install a collection and control system | Y | |

IV. Source Specific Applicable Requirements

Table IV – B
Source-Specific Applicable Requirements
S-15 WEST CONTRA COSTA SANITARY LANDFILL; AND
A-8 LANDFILL GAS FLARE

| Applicable Requirement | Regulation Title or Description of Requirement | Federally Enforceable (Y/N) | Future Effective Date |
|-------------------------------|--|------------------------------------|------------------------------|
| 60.752 (b)(2)(iii) | Route collected gases to a control system. | Y | |
| 60.752 (b)(2)(iii)(B) | Reduce NMOC emissions by 98% by weight or reduce NMOC outlet concentration to less than 20 ppmv as hexane at 3% O ₂ , dry basis, as demonstrated by initial performance test within 180 days of start-up. | Y | |
| 60.752 (b)(2)(iv) | Operate in accordance with 60.753, 60.755, and 60.756 | Y | |
| 60.752(c) | Title V Operating Permit Requirements | Y | |
| 60.752(c)(1) | Subject date is June 10, 1996 for Landfills new or modified between May 30, 1991 and March 12, 1996 | Y | |
| 60.753 | Operational Standards for Collection and Control Systems | Y | |
| 60.753(a) | Operate a Collection System in each area or cell in which: | Y | |
| 60.753(a)(1) | Active Cell – solid waste in place for 5 years or more | Y | |
| 60.753(a)(2) | Closed/Final Grade – solid waste in place for 2 years or more | Y | |
| 60.753(b) | Operate each wellhead under negative pressure unless: | Y | |
| 60.753(b)(1) | Fire or increased well temperature or to prevent fire | Y | |
| 60.753(b)(2) | Use of geomembrane or synthetic cover (subject to alternative pressure limits) | Y | |
| 60.753(b)(3) | Decommissioned well after approval received for shut-down | Y | |
| 60.753(c) | Operate each wellhead at < 55 °C, and either < 20% N ₂ or < than 5% O ₂ (or other approved alternative levels) | Y | |
| 60.753(c)(1) | N ₂ determined by Method 3C | Y | |
| 60.753(c)(2) | O ₂ determined by 3A and as described in (2)(i-v) | Y | |
| 60.753(d) | Surface Leak Limit is less than 500 ppm methane above background at landfill surface. This section also describes some surface monitoring procedures. | Y | |
| 60.753(e) | Vent all collected gases to a control system complying with 60.752(b)(2)(iii). If collection or control system inoperable, shut down gas mover and close all vents within 1 hour | Y | |
| 60.753(f) | Operate the control system at all times when collected gas is routed to the control system | Y | |

IV. Source Specific Applicable Requirements

Table IV – B
Source-Specific Applicable Requirements
S-15 WEST CONTRA COSTA SANITARY LANDFILL; AND
A-8 LANDFILL GAS FLARE

| Applicable Requirement | Regulation Title or Description of Requirement | Federally Enforceable (Y/N) | Future Effective Date |
|-------------------------------|--|------------------------------------|------------------------------|
| 60.753(g) | If monitoring demonstrates that 60.753(b), (c), or (d) are not being met, corrective action must be taken | Y | |
| 60.754 | Test Methods and Procedures | Y | |
| 60.754(c) | For PSD, NMOC emissions shall be calculated using AP-42 | Y | |
| 60.754(d) | Test Methods for Performance Test (Method 18 or 25C) | Y | |
| 60.755 | Compliance Provisions | Y | |
| 60.755(a) | For Gas Collection Systems | Y | |
| 60.755(a)(1) | Calculation procedures for maximum expected gas generation flow rate | Y | |
| 60.755(a)(1)(i) | Equation for unknown year-to-year waste acceptance rate | Y | |
| 60.755(a)(1)(ii) | Equation for known year-to-year waste acceptance rate | Y | |
| 60.755(a)(2) | Vertical wells and horizontal collectors shall be of sufficient density to meet all performance specifications | Y | |
| 60.755(a)(3) | Measure wellhead pressure monthly. If pressure is positive, take corrective action (final corrective action = expand system within 120 days of initial positive pressure reading) | Y | |
| 60.755(a)(4) | Expansion not required during first 180 days after startup. | Y | |
| 60.755(a)(5) | Monitor wellheads monthly for temperature and either nitrogen or oxygen. If readings exceed limits, take corrective action up to expanding system within 120 days of first excess. | Y | |
| 60.755(b) | Wells shall be placed in cells as described in Design Plan and no later than 60 days after: | Y | |
| 60.755(b)(1) | Five years after initial waste placement in cell, for active cells | Y | |
| 60.755(b)(2) | Two years after initial waste placement in cell, for closed/final grade cells. | Y | |
| 60.755(c) | Procedures for complying with surface methane standard | Y | |
| 60.755(c)(1) | Quarterly monitoring of surface and perimeter | Y | |
| 60.755(c)(2) | Procedure for determining background concentration | Y | |
| 60.755(c)(3) | Method 21 except probe inlet placed 5-10 cm above ground | Y | |
| 60.755(c)(4) | Excess is any reading of 500 ppmv or more. Take corrective action indicated below (i-v). | Y | |

IV. Source Specific Applicable Requirements

Table IV – B
Source-Specific Applicable Requirements
S-15 WEST CONTRA COSTA SANITARY LANDFILL; AND
A-8 LANDFILL GAS FLARE

| Applicable Requirement | Regulation Title or Description of Requirement | Federally Enforceable (Y/N) | Future Effective Date |
|-------------------------------|--|------------------------------------|------------------------------|
| 60.755 (c)(4)(i) | Mark and record location of excess | Y | |
| 60.755 (c)(4)(ii) | Repair cover or adjust vacuum. Re-monitor within 10 calendar days. | Y | |
| 60.755 (c)(4)(iii) | If still exceeding 500 ppmv, take additional corrective action. Re-monitor within 10 calendar days of 2 nd excess. | Y | |
| 60.755 (c)(4)(iv) | Re-monitor within 1 month of initial excess. | Y | |
| 60.755 (c)(4)(v) | For any location with 3 monitored excesses in a quarter, additional collectors (or other approved collection system repairs) shall be operational within 120 days of 1 st excess. | Y | |
| 60.755(c)(5) | Monitor cover integrity monthly and repair as needed. | Y | |
| 60.755(d) | Instrumentation and procedures for complying with 60.755(c). | Y | |
| 60.755(d)(1) | Portable analyzer meeting Method 21 | Y | |
| 60.755(d)(2) | Calibrated with methane diluted to 500 ppmv in air | Y | |
| 60.755(d)(3) | Use Method 21, Section 4.4 instrument evaluation procedures | Y | |
| 60.755(d)(4) | Calibrate per Method 21, Section 4.2 immediately before monitoring. | Y | |
| 60.755(e) | Provisions apply at all times except during startup, shutdown, or malfunction, provided the duration of these shall not exceed 5 days for collection systems or 1 hour for control systems. | Y | |
| 60.756 | Monitoring of Operations | Y | |
| 60.756(a) | For active collection systems, install wellhead sampling port | Y | |
| 60.756(a)(1) | Measure gauge pressure in wellhead on a monthly basis | Y | |
| 60.756(a)(2) | Measure nitrogen or oxygen concentration in wellhead gas on a monthly basis. | Y | |
| 60.756(a)(3) | Measure temperature of wellhead gas on a monthly basis. | Y | |
| 60.756(b) | Enclosed combustors shall comply with (b)(1) and (b)(2) | Y | |
| 60.756(b)(1) | Temperature monitor and continuous recorder (not required for boilers and process heaters with capacity > 44 MW) | Y | |
| 60.756(b)(2) | Device that records flow to or bypass of the control device (i or ii below) | Y | |

IV. Source Specific Applicable Requirements

Table IV – B
Source-Specific Applicable Requirements
S-15 WEST CONTRA COSTA SANITARY LANDFILL; AND
A-8 LANDFILL GAS FLARE

| Applicable Requirement | Regulation Title or Description of Requirement | Federally Enforceable (Y/N) | Future Effective Date |
|-------------------------------|---|------------------------------------|------------------------------|
| 60.756 (b)(2)(i) | Install, calibrate, and maintain a device that records flow to the control device at least every 15 minutes. | Y | |
| 60.756(e) | Procedures for requesting alternative monitoring parameters | Y | |
| 60.756(f) | Monitor surface on a quarterly basis. | Y | |
| 60.757 | Reporting Requirements | Y | |
| 60.757(a)(3) | Amended Design Capacity Report required within 90 days of receiving a permitted increase in design capacity or within 90 days of an annual density calculation that results in a design capacity over the thresholds. | Y | |
| 60.757(b)(3) | Sites with collection and control systems operating in compliance with this subpart are exempt from (b)(1) and (b)(2) above. | Y | |
| 60.757(c) | Submit a Collection and Control System Design Plan within 1 year of first NMOC emission rate report showing NMOC > 50 MG/year, except as follows | Y | |
| 60.757(f) | Submit Annual Reports containing information required by (f)(1) through (f)(6) | Y | |
| 60.757(f)(1) | Value and length of time for exceedance of parameters monitored per 60.756(a), (b) or (d) | Y | |
| 60.757(f)(2) | Description and duration of all periods when gas is diverted from the control device by a by-pass line | Y | |
| 60.757(f)(3) | Description and duration of all periods when control device was not operating for more than 1 hour | Y | |
| 60.757(f)(4) | All periods when collection system was not operating for more than 5 days. | Y | |
| 60.757(f)(5) | Location of each surface emission excess and all re-monitoring dates and concentrations. | Y | |
| 60.757(f)(6) | Location and installation dates for any wells or collectors added as a result of corrective action for a monitored excess. | Y | |
| 60.757(g) | Initial Performance Test Report Requirements (g)(1-6) | Y | |
| 60.757(g)(1) | Diagram of collection system showing positions of all existing collectors, proposed positions for future collectors, and areas to be excluded from control. | Y | |
| 60.757(g)(2) | Basis for collector positioning to meet sufficient density req. | Y | |

IV. Source Specific Applicable Requirements

Table IV – B
Source-Specific Applicable Requirements
S-15 WEST CONTRA COSTA SANITARY LANDFILL; AND
A-8 LANDFILL GAS FLARE

| Applicable Requirement | Regulation Title or Description of Requirement | Federally Enforceable (Y/N) | Future Effective Date |
|-------------------------------|---|------------------------------------|------------------------------|
| 60.757(g)(3) | Documentation supporting percentage of asbestos or non-degradable material claims for areas without a collection system. | Y | |
| 60.757(g)(4) | For areas excluded from collection due to non-productivity, calculations and gas generation rates for each non-productive area and the sum for all nonproductive areas. | Y | |
| 60.757(g)(5) | Provisions for increasing gas mover equipment if current system is inadequate to handle maximum projected gas flow rate. | Y | |
| 60.757(g)(6) | Provisions for control of off-site migration | Y | |
| 60.758 | Recordkeeping Requirements | Y | |
| 60.758(a) | Design Capacity and Waste Acceptance Records (retain 5 years) | Y | |
| 60.758(b) | Collection and Control Equipment Records (retain for life of control equipment except 5 years for monitoring data) | Y | |
| 60.758(b)(1) | Collection System Records | Y | |
| 60.758(b)(1)(i) | Maximum expected gas generation flow rate. | Y | |
| 60.758(b)(1)(ii) | Density of wells and collectors | Y | |
| 60.758(b)(2) | Control System Records - enclosed combustors other than boilers or process heaters with heat input > 44 MW | Y | |
| 60.758(b)(2)(i) | Combustion temperature measured every 15 minutes and averaged over the same time period as the performance test | Y | |
| 60.758(b)(2)(ii) | Percent NMOC reduction achieved by the control device | Y | |
| 60.758(c) | Records of parameters monitored pursuant to 60.756 and periods of operation when boundaries are exceeded (retain for 5 years). | Y | |
| 60.758(c)(1) | Exceedances subject to record keeping are | Y | |
| 60.758(c)(1)(i) | All 3-hour periods when average combustion temperature was more than 28 C below the average combustion temperature during the most recent complying performance test | Y | |
| 60.758(c)(2) | Records of continuous flow to control device or monthly inspection records if seal and lock for bypass valves | Y | |
| 60.758(d) | Plot map showing location of all existing and planned collectors with a unique label for each collector (retain for life of collection system) | Y | |

IV. Source Specific Applicable Requirements

Table IV – B
Source-Specific Applicable Requirements
S-15 WEST CONTRA COSTA SANITARY LANDFILL; AND
A-8 LANDFILL GAS FLARE

| Applicable Requirement | Regulation Title or Description of Requirement | Federally Enforceable (Y/N) | Future Effective Date |
|-------------------------------|--|------------------------------------|------------------------------|
| 60.758(d)(1) | Installation date and location of all newly installed collectors | Y | |
| 60.758(d)(2) | Records of nature, deposition date, amount, and location of asbestos or non-degradable waste excluded from control | Y | |
| 60.758(e) | Records of any exceedance of 60.753, location of exceedance and re-monitoring dates and data (for wellheads and surface). Retain for 5 years. | Y | |
| 60.759 | Specifications for Active Collection Systems | Y | |
| 60.759(a) | Active wells and collectors shall be at sufficient density | Y | |
| 60.759(a)(1) | Collection System in refuse shall be certified by PE to achieve comprehensive control of surface gas emissions | Y | |
| 60.759(a)(2) | Collection Systems (active or passive) outside of refuse shall address migration control | Y | |
| 60.759(a)(3) | All gas producing areas shall be controlled except as described below (i-iii). | Y | |
| 60.759(b) | Gas Collection System Components | Y | |
| 60.759(b)(1) | Must be constructed of PVC, HDPE, fiberglass, stainless steel, or other approved material and of suitable dimensions to convey projected gas amounts and withstand settling, traffic, etc. | Y | |
| 60.759(b)(2) | Collectors shall not endanger liner, shall manage condensate and leachate, and shall prevent air intrusion and surface leaks. | Y | |
| 60.759(b)(3) | Header connection assemblies shall include positive closing throttle valve, seals and couplings to prevent leaks, at least one sampling port, and shall be constructed of PVC, HDPE, fiberglass, stainless steel, or other approved materials. | Y | |
| 60.759(c) | Gas Mover Equipment shall be sized to handle maximum expected gas generation rate over the intended period of use. | Y | |
| 60.759(c)(1) | For existing systems, flow data shall be used to project maximum flow rate. | Y | |
| 60.759(c)(2) | For new systems, gas generation rate shall be calculated per 60.755(a)(1) | Y | |
| 40 CFR Part 62 | Approval and Promulgation of State Plans for Designated Facilities and Pollutants (6/9/03) | | |
| 62.1100 | Identification of Plan | Y | |

IV. Source Specific Applicable Requirements

Table IV – B
Source-Specific Applicable Requirements
S-15 WEST CONTRA COSTA SANITARY LANDFILL; AND
A-8 LANDFILL GAS FLARE

| Applicable Requirement | Regulation Title or Description of Requirement | Federally Enforceable (Y/N) | Future Effective Date |
|--------------------------------------|--|------------------------------------|------------------------------|
| 62.1115 | Identification of Sources | Y | |
| 40 CFR Part 63, Subpart A | National Emission Standards for Hazardous Air Pollutants: General Provisions (4/22/04) | | |
| 63.4 | Prohibited activities and circumvention | Y | |
| 63.5(b) | Requirements for existing, newly constructed, and reconstructed sources | Y | |
| 63.6(e) | Operation and maintenance requirements and SSM Plan | Y | |
| 63.6(f) | Compliance with non-opacity emission standards | Y | |
| 63.10(b)(2)(i-v) | Records for startup, shutdown, malfunction, and maintenance | Y | |
| 63.10(d)(5) | Startup, Shutdown, and Malfunction (SSM) Reports | Y | |
| 40 CFR Part 63, Subpart AAAAA | National Emission Standards for Hazardous Air Pollutants: Municipal Solid Waste Landfills (1/16/03) | | |
| 63.1945 | When do I have to comply with this subpart? | Y | |
| 63.1945(b) | Compliance date for existing affected landfills | Y | |
| 63.1955 | What requirements must I meet? | Y | |
| 63.1955(a)(2) | Comply with State Plan that implements 40 CFR Part 60, Subpart Cc | Y | |
| 63.1955(b) | Comply with 63.1960-63.1985, if a collection and control system is required by 40 CFR Part 60, Subpart WWW or a State Plan implementing 40 CFR Part 60, Subpart Cc | Y | |
| 63.1955(c) | Comply with all approved alternatives to standards for collection and control systems plus all SSM requirements and 6 month compliance reporting requirements | Y | |
| 63.1960 | How is compliance determined? | Y | |
| 63.1965 | What is a deviation? | Y | |
| 63.1975 | How do I calculate the 3-hour block average used to demonstrate compliance? | Y | |
| 63.1980 | What records and reports must I keep and submit? | Y | |

IV. Source Specific Applicable Requirements

Table IV – B
Source-Specific Applicable Requirements
S-15 WEST CONTRA COSTA SANITARY LANDFILL; AND
A-8 LANDFILL GAS FLARE

| Applicable Requirement | Regulation Title or Description of Requirement | Federally Enforceable (Y/N) | Future Effective Date |
|---------------------------------|---|------------------------------------|------------------------------|
| 63.1980(a) | Comply with all record keeping and reporting requirements in 40 CFR Part 60, Subpart WWW or the State Plan implementing 40 CFR Part 60, Subpart Cc, except that the annual report required by 40 CFR 60.757(f) must be submitted every 6 months | Y | |
| 63.1980(b) | Comply with all record keeping and reporting requirements in 40 CFR Part 60, Subpart A and 40 CFR Part 63, Subpart A, including SSM Plans and Reports | Y | |
| BAAQMD Condition # 17821 | | | |
| Part 1 | Waste acceptance rate limits (Regulation 2-1-301, Cumulative Increase) | Y | |
| Part 2 | Acceptance criteria for soils containing VOCs (Regulations 2-1-403 and 8-40-301) | Y | |
| Part 3 | Emission limit for low VOC soils (Regulation 8-2-301) | Y | |
| Part 4 | Particulate emission control measures (Regulations 2-1-403, 6-301, and 6-305) | Y | |
| Part 5 | Control requirements for collected landfill gas (Regulation 8-34-301) | Y | |
| Part 6 | Landfill gas collection system description (Regulations 2-1-301, 8-34-301.1, 8-34-304, and 8-34-305) | Y | |
| Part 7 | Landfill gas collection system operating requirements (Regulation 8-34-301.1) | Y | |
| Part 8 | Flare operating restrictions and heat input limits (Cumulative Increase and Regulation 2-1-301) | Y | |
| Part 9 | Flare temperature limit (Toxic Risk Management Policy and Regulation 8-34-301.3) | Y | |
| Part 10 | Landfill gas sulfur content limit and monitoring requirements (Regulation 9-1-302, Cumulative Increase) | Y | |
| Part 11 | Annual source test (Regulations 8-34-301.3 and 8-34-412) | Y | |
| Part 12 | Annual landfill gas characterization test (Toxic Risk Management Policy, AB-2588 Air Toxics Hot Spots Act, and Regulation 8-34-412) | Y | |
| Part 13 | Toxic compound concentration limits (Toxic Risk Management Policy and AB-2588 Air Toxics Hot Spots Act) | N | |

IV. Source Specific Applicable Requirements

Table IV – B
Source-Specific Applicable Requirements
S-15 WEST CONTRA COSTA SANITARY LANDFILL; AND
A-8 LANDFILL GAS FLARE

| Applicable Requirement | Regulation Title or Description of Requirement | Federally Enforceable (Y/N) | Future Effective Date |
|-------------------------------|---|------------------------------------|------------------------------|
| Part 14 | Record keeping requirements (Cumulative Increase, 2-1-301, 2-6-501, 6-301, 6-305, 8-2-301, 8-34-301, 8-34-304, and 8-34-501) | Y | |
| Part 15 | Reporting periods and report submittal due dates for the Regulation 8, Rule 34 report (Regulation 8-34-411 and 40 CFR 63.1980(a)) | Y | |

- 1 This section has been removed from BAAQMD Regulations because it has been superseded. Nevertheless, the source must comply with this regulation until US EPA has reviewed and approved (or disapproved) the District's revision of the regulation.

IV. Source Specific Applicable Requirements

Table IV – C
Source-Specific Applicable Requirements
S-22 PRIMARY OIL/WATER SEPARATOR, TK-2;
S-23 SECONDARY OIL/WATER SEPARATOR, TK-4;
S-38 SECONDARY OIL/WATER SEPARATOR, TK-4;
A-1 CARBON ADSORBER; AND A-2 CARBON ADSORBER

| Applicable Requirement | Regulation Title or Description of Requirement | Federally Enforceable (Y/N) | Future Effective Date |
|------------------------------------|--|-----------------------------|-----------------------|
| BAAQMD Regulation 8, Rule 8 | Organic Compounds – Wastewater (Oil-Water) Separators (9/15/04) | | |
| 8-8-301 | Waste Water Separators Greater than 760 Liters Per Day and Smaller than 18.9 liters per second | Y | |
| 8-8-301.3 | OC Vapor Recovery System | Y | |
| 8-8-303 | Gauging and Sampling Devices | Y | |
| 8-8-501 | API Separator or Air Flotation Bypassed Wastewater Records | Y | |
| 8-8-503 | Inspection and Repair Records | Y | |
| 8-8-504 | Portable Hydrocarbon Detector | Y | |
| BAAQMD Condition #7463 | | | |
| Part 1 | Abatement requirement for POC emissions (Cumulative Increase and Toxic Risk Management Policy) | Y | |
| Part 3 | Operating restrictions for Secondary Oil/Water Separators (Cumulative Increase) | Y | |
| Part 4 | Operating requirements for Oil/Water Separators (Regulations 8-8-301 and 8-8-303) | Y | |
| Part 5 | Wastewater throughput limits (Cumulative Increase) | Y | |
| Part 6 | POC leak limit for valves, flanges, and pumps (Cumulative Increase) | Y | |
| Part 7 | Replacement requirements for second to last Carbon Adsorber (Cumulative Increase and Toxic Risk Management Policy) | Y | |
| Part 8 | Replacement requirements for last Carbon Adsorber (Cumulative Increase and Toxic Risk Management Policy) | Y | |
| Part 9 | Methane and non-methane measurement method (Cumulative Increase and Toxic Risk Management Policy) | Y | |
| Part 10a-c | Carbon Adsorber monitoring requirements (Cumulative Increase and Toxic Risk Management Policy) | Y | |

IV. Source Specific Applicable Requirements

Table IV – C
Source-Specific Applicable Requirements
S-22 PRIMARY OIL/WATER SEPARATOR, TK-2;
S-23 SECONDARY OIL/WATER SEPARATOR, TK-4;
S-38 SECONDARY OIL/WATER SEPARATOR, TK-4;
A-1 CARBON ADSORBER; AND A-2 CARBON ADSORBER

| Applicable Requirement | Regulation Title or Description of Requirement | Federally Enforceable (Y/N) | Future Effective Date |
|-------------------------------|--|------------------------------------|------------------------------|
| Part 11a-e | Record keeping requirements (Cumulative Increase and Toxic Risk Management Policy) | Y | |
| Part 12 | Permitting requirements for any future proposed revisions of Parts 5 or 8 (Cumulative Increase and Toxic Risk Management Policy) | Y | |

IV. Source Specific Applicable Requirements

Table IV – D
Source-Specific Applicable Requirements
S-24 LOAD EQUALIZATION TANK, TK-7; S-25 PHOTO-OXIDIZER TANK, TK-5;
S-26 NEUTRALIZATION TANK, TK-9; S-27 FIRST STAGE CLARIFIER, TK-8;
S-28 AIR STRIPPER SUMP; S-39 SLUDGE STORAGE TANK, TK-3; AND
S-40 EQUALIZATION TANK, TK-1

| Applicable Requirement | Regulation Title or Description of Requirement | Federally Enforceable (Y/N) | Future Effective Date |
|------------------------------------|--|------------------------------------|------------------------------|
| BAAQMD Regulation 8, Rule 2 | Organic Compounds-Miscellaneous Operation (7/20/05) | Y | |
| 8-2-301 | Miscellaneous Operations | Y | |
| BAAQMD Condition #7463 | | | |
| Part 1 | Abatement requirement for POC emissions (Cumulative Increase and Toxic Risk Management Policy) | Y | |
| Part 5 | Wastewater throughput limits (Cumulative Increase) | Y | |
| Part 6 | POC leak limit for valves, flanges, and pumps (Cumulative Increase) | Y | |
| Part 11a | Record keeping requirements (Cumulative Increase and Toxic Risk Management Policy) | Y | |

IV. Source Specific Applicable Requirements

Table IV – E
Source-Specific Applicable Requirements
S-30 AIR STRIPPER;
A-3 CARBON ADSORBER; A-4 CARBON ADSORBER;
A-5 CARBON ADSORBER; AND A-6 CARBON ADSORBER

| Applicable Requirement | Regulation Title or Description of Requirement | Federally Enforceable (Y/N) | Future Effective Date |
|-------------------------------------|--|------------------------------------|------------------------------|
| BAAQMD Regulation 8, Rule 47 | Air Stripping and Soil Vapor Extraction Operations (6/15/05) | | |
| 8-47-301 | Emission Control Requirement, Specific Compounds | Y | |
| 8-47-302 | Organic Compounds | Y | |
| 8-47-501 | Records | Y | |
| 8-47-501.1 | Water Analysis Records | Y | |
| 8-47-501.2 | Vapor Monitoring Results | Y | |
| 8-47-601 | Air Stripper Water Sampling | Y | |
| BAAQMD Condition #7463 | | | |
| Part 2 | Abatement requirement for POC emissions (Cumulative Increase and Toxic Risk Management Policy) | Y | |
| Part 5 | Wastewater throughput limits (Cumulative Increase) | Y | |
| Part 6 | POC leak limit for valves, flanges, and pumps (Cumulative Increase) | Y | |
| Part 7 | Replacement requirements for second to last Carbon Adsorber (Cumulative Increase and Toxic Risk Management Policy) | Y | |
| Part 8 | Replacement requirements for last Carbon Adsorber (Cumulative Increase and Toxic Risk Management Policy) | Y | |
| Part 9 | Methane and non-methane measurement method (Cumulative Increase and Toxic Risk Management Policy) | Y | |
| Part 10a-c | Carbon Adsorber monitoring requirements (Cumulative Increase and Toxic Risk Management Policy) | Y | |
| Part 11a-e | Record keeping requirements (Cumulative Increase and Toxic Risk Management Policy) | Y | |
| Part 12 | Permitting requirements for any future proposed revisions of Parts 5 or 8 (Cumulative Increase and Toxic Risk Management Policy) | Y | |

IV. Source Specific Applicable Requirements

Table IV – F
Source-Specific Applicable Requirements
S-37 INTERNAL COMBUSTION LEAN BURN ENGINE

| Applicable Requirement | Regulation Title or Description of Requirement | Federally Enforceable (Y/N) | Future Effective Date |
|-------------------------------------|--|------------------------------------|------------------------------|
| BAAQMD Regulation 1 | General Provisions and Definitions (5/2/01) | | |
| 1-523 | Parametric Monitoring and Record keeping Procedures | N | |
| 1-523.1 | Reporting requirement for periods of in-operation > 24 hours | Y | |
| 1-523.2 | Limit on duration of in operation | Y | |
| 1-523.3 | Reporting requirement for violations of any applicable limits | N | |
| 1-523.4 | Records of in-operation, tests, calibrations, adjustments, & maintenance | Y | |
| 1-523.5 | Maintenance and calibration | N | |
| SIP Regulation 1 | General Provisions and Definitions (6/28/99) | | |
| 1-523 | Parametric Monitoring and Recordkeeping Procedures | Y ¹ | |
| 1-523.3 | Reports of Violations | Y ¹ | |
| BAAQMD Regulation 6 | Particulate Matter and Visible Emissions (12/19/90) | | |
| 6-301 | Ringelmann No. 1 Limitation | Y | |
| 6-305 | Visible Particles | Y | |
| 6-310 | Particle Weight Limitation | Y | |
| 6-401 | Appearance of Emissions | Y | |
| BAAQMD Regulation 8, Rule 34 | Organic Compounds - Solid Waste Disposal Sites (6/15/05) | | |
| 8-34-113 | Limited Exemption, Inspection and Maintenance | Y | |
| 8-34-113.1 | Emission Minimization Requirement | Y | |
| 8-34-113.2 | Shutdown Time Limitation | Y | |
| 8-34-113.3 | Record keeping Requirement | Y | |
| 8-34-301 | Landfill Gas Collection and Emission Control System Requirements | Y | |
| 8-34-301.1 | Continuous Operation | Y | |
| 8-34-301.2 | Collection and Control Systems Leak Limitations | Y | |
| 8-34-301.4 | Limits for Other Emission Control Systems | Y | |
| 8-34-412 | Compliance Demonstration Tests | Y | |
| 8-34-413 | Performance Test Report | Y | |
| 8-34-501 | Operating Records | Y | |

IV. Source Specific Applicable Requirements

**Table IV – F
 Source-Specific Applicable Requirements
 S-37 INTERNAL COMBUSTION LEAN BURN ENGINE**

| Applicable Requirement | Regulation Title or Description of Requirement | Federally Enforceable (Y/N) | Future Effective Date |
|------------------------------------|--|------------------------------------|------------------------------|
| 8-34-501.2 | Emission Control System Downtime | Y | |
| 8-34-501.4 | Testing | Y | |
| 8-34-501.6 | Leak Discovery and Repair Records | Y | |
| 8-34-501.10 | Gas Flow Rate Records for All Emission Control Systems | Y | |
| 8-34-501.11 | Records of Key Emission Control System Operating Parameters | Y | |
| 8-34-501.12 | Records Retention for 5 Years | Y | |
| 8-34-503 | Landfill Gas Collection and Emission Control System Leak Testing | Y | |
| 8-34-504 | Portable Hydrocarbon Detector | Y | |
| 8-34-508 | Gas Flow Meter | Y | |
| 8-34-509 | Key emission control system operating parameters | Y | |
| BAAQMD Regulation 9, Rule 1 | Inorganic Gaseous Pollutants – Sulfur Dioxide (3/15/95) | | |
| 9-1-301 | Limitations on Ground Level Concentrations | Y | |
| 9-1-302 | General Emission Limitations | Y | |
| BAAQMD Regulation 9, Rule 2 | Inorganic Gaseous Pollutants – Hydrogen Sulfide (10/6/99) | | |
| 9-2-301 | Limitations on Hydrogen Sulfide | N | |
| BAAQMD Regulation 9 Rule 8 | Inorganic Gaseous Pollutants – Nitrogen Oxides and Carbon Monoxide from Stationary Internal Combustion Engines (8/1/01) | | |
| 9-8-302 | Emission Limits – Waste Derived Fuel Gas | Y | |
| 9-8-302.1 | Lean-Burn Engines: NO _x Emission Limit | Y | |
| 9-8-302.3 | CO Emission Limit | Y | |
| 40 CFR Part 60, Subpart A | Standards of Performance for New Stationary Sources – General Provisions (5/4/98) | | |
| 60.4(b) | Requires Submission of Requests, Reports, Applications, and Other Correspondence to the Administrator | Y | |
| 60.7 | Notification and Record Keeping | Y | |
| 60.8 | Performance Tests | Y | |
| 60.11 | Compliance with Standards and Maintenance Requirements | Y | |
| 60.11(a) | Compliance determined by performance tests | Y | |

IV. Source Specific Applicable Requirements

Table IV – F
Source-Specific Applicable Requirements
S-37 INTERNAL COMBUSTION LEAN BURN ENGINE

| Applicable Requirement | Regulation Title or Description of Requirement | Federally Enforceable (Y/N) | Future Effective Date |
|------------------------------------|--|------------------------------------|------------------------------|
| 60.11(d) | Good air pollution control practice | Y | |
| 60.12 | Circumvention | Y | |
| 60.13 | Monitoring Requirements | Y | |
| 60.13(a) | Applies to all continuous monitoring systems | Y | |
| 60.13(b) | Monitors shall be installed and operation before performing performance tests | Y | |
| 60.13(e) | Continuous monitors shall operate continuously | Y | |
| 60.13(f) | Monitors shall be installed in proper locations | Y | |
| 60.13(g) | Requires multiple monitors for multiple stacks | Y | |
| 60.14 | Modification | Y | |
| 60.15 | Reconstruction | Y | |
| 60.19 | General Notification and Reporting Requirements | Y | |
| 40 CFR Part 60, Subpart WWW | Standards of Performance for New Stationary Sources – Standards of Performance for Municipal Solid Waste Landfills (2/24/99) | | |
| 60.752 | Standards for Air Emissions from Municipal Solid Waste Landfills | Y | |
| 60.752(b) | Comply with paragraph (b)(2) or calculate NMOC emission rate | Y | |
| 60.752(b)(2) | Comply with all requirements in sections (b)(2)(i through iv) | Y | |
| 60.752(b)(2)(i) | Submit a collection and control system design plan | Y | |
| 60.752(b)(2)(ii) | Install a collection and control system | Y | |
| 60.752(b)(2)(iii) | Route collected gases to a control system | Y | |
| 60.752(b)(2)(iii)(B) | Reduce NMOC emissions by 98% by weight or reduce NMOC outlet concentration to less than 20 ppmv as hexane at 3% O ₂ , dry basis | Y | |
| 60.752(b)(2)(iv) | Operate in accordance with 60.753, 60.755, and 60.756 | Y | |
| 60.753 | Operational Standards for Collection and Control Systems | Y | |
| 60.753(e) | Vent all collected gases to a control system complying with 60.752(b)(2)(iii) | Y | |

IV. Source Specific Applicable Requirements

Table IV – F
Source-Specific Applicable Requirements
S-37 INTERNAL COMBUSTION LEAN BURN ENGINE

| Applicable Requirement | Regulation Title or Description of Requirement | Federally Enforceable (Y/N) | Future Effective Date |
|-------------------------------|--|------------------------------------|------------------------------|
| 60.753(f) | Operate the control system at all times when collected gas is Routed to the control system | Y | |
| 60.754 | Test Methods and Procedures | Y | |
| 60.754(d) | Test Methods for Performance Test (Method 18 or 25C) | Y | |
| 60.755 | Compliance Provisions | Y | |
| 60.755(e) | Provisions apply at all times except during startup, shutdown, or malfunction, provided the duration of these shall not exceed 5 days for collection systems or 1 hour for control systems | Y | |
| 60.756 | Monitoring of Operations | Y | |
| 60.756(d) | Approval of other control devices | Y | |
| 60.756(e) | Procedures for requesting alternative monitoring parameters | Y | |
| 60.757 | Reporting Requirements | Y | |
| 60.757(c) | Submit a Collection and Control System Design Plan | Y | |
| 60.757(e) | Submit Equipment Removal Report 30 days prior to removal or cessation of operation of the control equipment | Y | |
| 60.757(f) | Submit Annual Reports containing information required by (f)(1), (f)(2), and (f)(3) | Y | |
| 60.757(f)(1) | Value and length of time for exceedance of parameters monitored per 60.756(b) or (e) | Y | |
| 60.757(f)(2) | Description and duration of all periods when gas is diverted from the control device by a by-pass line | Y | |
| 60.757(f)(3) | Description and duration of all periods when control device was not operating for more than 1 hour | Y | |
| 60.758 | Recordkeeping Requirements | Y | |
| 60.758(b) | Control Equipment Records (Control Device Vendor Specifications) Note: Subsections 1 through 4 do not apply. | Y | |
| 60.758(c) | Records of parameters monitored pursuant to 60.756 (e) | Y | |
| 60.758(e) | Records of any exceedance of 60.753(e) or (f) | Y | |
| 40 CFR Part 62 | Approval and Promulgation of State Plans for Designated Facilities and Pollutants (6/9/03) | | |
| 62.1100 | Identification of Plan | Y | |
| 62.1115 | Identification of Sources | Y | |

IV. Source Specific Applicable Requirements

Table IV – F
Source-Specific Applicable Requirements
S-37 INTERNAL COMBUSTION LEAN BURN ENGINE

| Applicable Requirement | Regulation Title or Description of Requirement | Federally Enforceable (Y/N) | Future Effective Date |
|-------------------------------------|---|------------------------------------|------------------------------|
| 40 CFR Part 63, Subpart A | National Emission Standards for Hazardous Air Pollutants: General Provisions (4/22/04) | | |
| 63.4 | Prohibited activities and circumvention | Y | |
| 63.5(b) | Requirements for existing, newly constructed, and reconstructed sources | Y | |
| 63.6(e) | Operation and maintenance requirements and SSM Plan | Y | |
| 63.6(f) | Compliance with non-opacity emission standards | Y | |
| 63.10(b)(2)(i-v) | Records for startup, shutdown, malfunction, and maintenance | Y | |
| 63.10(d)(5) | Startup, Shutdown, and Malfunction (SSM) Reports | Y | |
| 40 CFR Part 63, Subpart AAAA | National Emission Standards for Hazardous Air Pollutants: Municipal Solid Waste Landfills (1/16/03) | | |
| 63.1945 | When do I have to comply with this subpart? | Y | |
| 63.1945(b) | Compliance date for existing affected landfills | Y | |
| 63.1955 | What requirements must I meet? | Y | |
| 63.1955(a)(2) | Comply with State Plan that implements 40 CFR Part 60, Subpart Cc | Y | |
| 63.1955(b) | Comply with 63.1960-63.1985, if a collection and control system is required by 40 CFR Part 60, Subpart WWW or a State Plan implementing 40 CFR Part 60, Subpart Cc | Y | |
| 63.1955(c) | Comply with all approved alternatives to standards for collection and control systems plus all SSM requirements and 6 month compliance reporting requirements | Y | |
| 63.1960 | How is compliance determined? | Y | |
| 63.1965 | What is a deviation? | Y | |
| 63.1975 | How do I calculate the 3-hour block average used to demonstrate compliance? | Y | |
| 63.1980 | What records and reports must I keep and submit? | Y | |
| 63.1980(a) | Comply with all record keeping and reporting requirements in 40 CFR Part 60, Subpart WWW or the State Plan implementing 40 CFR Part 60, Subpart Cc, except that the annual report required by 40 CFR 60.757(f) must be submitted every 6 months | Y | |

IV. Source Specific Applicable Requirements

Table IV – F
Source-Specific Applicable Requirements
S-37 INTERNAL COMBUSTION LEAN BURN ENGINE

| Applicable Requirement | Regulation Title or Description of Requirement | Federally Enforceable (Y/N) | Future Effective Date |
|---------------------------------|---|------------------------------------|------------------------------|
| 63.1980(b) | Comply with all record keeping and reporting requirements in 40 CFR Part 60, Subpart A and 40 CFR Part 63, Subpart A, including SSM Plans and Reports | Y | |
| BAAQMD Condition # 17812 | | | |
| Part 1 | Fuel Restrictions (Offsets and Cumulative Increase) | Y | |
| Part 2 | Heat Input Limits (Offsets and Cumulative Increase) | Y | |
| Part 3 | Continuous operating requirement (Regulation 8-34-301.1) | Y | |
| Part 4 | Diverter Valve Requirement (Regulation 8-34-301) | Y | |
| Part 5 | NO _x Emission Limit (BACT, Offsets) | Y | |
| Part 6 | CO Emission Limit (BACT) | Y | |
| Part 7 | Gas flow meter and recorder requirement (Offsets and Cumulative Increase) | Y | |
| Part 8 | Annual source test requirement (BACT and Regulations 8-34-301.4, 8-34-412, 9-8-302.1, and 9-8-302.3) | Y | |
| Part 9 | Record keeping requirements (BACT, Offsets, Cumulative Increase, and Regulation 8-34-501) | Y | |
| Part 10 | Engine Temperature Limit and Temperature Monitoring Requirements (8-34-301, 8-34-501.11, 8-34-509) | Y | |

- 1 This section has been removed from BAAQMD Regulations because it has been superseded. Nevertheless, the source must comply with this regulation until US EPA has reviewed and approved (or disapproved) the District's revision of the regulation.

IV. Source Specific Applicable Requirements

Table IV – G
Source-Specific Applicable Requirements
S-46 HAZARDOUS WASTE MANAGEMENT FACILITY WITH LANDFILL GAS COLLECTION
SYSTEM; AND A-11 LANDFILL GAS FLARE FOR HWMF

| Applicable Requirement | Regulation Title or Description of Requirement | Federally Enforceable (Y/N) | Future Effective Date |
|-------------------------------------|---|-----------------------------|------------------------------|
| BAAQMD Regulation 1 | General Provisions and Definitions (5/2/01) | | upon start-up of A-11 |
| 1-523 | Parametric Monitoring and Recordkeeping Procedures | N | |
| 1-523.1 | Reporting requirement for periods of inoperation > 24 hours | Y | |
| 1-523.2 | Limit on duration of inoperation | Y | |
| 1-523.3 | Reporting requirement for violations of any applicable limits | N | |
| 1-523.4 | Records of inoperation, tests, calibrations, adjustments, & maintenance | Y | |
| 1-523.5 | Maintenance and calibration | N | |
| SIP Regulation 1 | General Provisions and Definitions (6/28/99) | | upon start-up of A-11 |
| 1-523 | Parametric Monitoring and Recordkeeping Procedures | Y ¹ | |
| 1-523.3 | Reports of Violations | Y ¹ | |
| BAAQMD Regulation 6 | Particulate Matter and Visible Emissions (12/19/90) | | upon start-up of A-11 |
| 6-301 | Ringelmann No. 1 Limitation (applies to A-11 Flare only) | Y | |
| 6-305 | Visible Particles (applies to A-11 Flare only) | Y | |
| 6-310 | Particle Weight Limitation (applies to A-11 Flare only) | Y | |
| 6-401 | Appearance of Emissions (applies to A-11 Flare only) | Y | |
| BAAQMD Regulation 8, Rule 34 | Organic Compounds – Solid Waste Disposal Sites (6/15/05) | | |
| 8-34-113 | Limited Exemption, Inspection and Maintenance | Y | upon start-up of A-11 |
| 8-34-113.1 | Emission Minimization Requirement | Y | |
| 8-34-113.2 | Shutdown Time Limitation | Y | |
| 8-34-113.3 | Recordkeeping Requirement | Y | |
| 8-34-117 | Limited Exemption, Gas Collection System Components | Y | upon start-up of A-11 |
| 8-34-117.1 | Necessity of Existing Component Repairs/Adjustments | Y | |
| 8-34-117.2 | New Components are Described in Collection and Control System Design Plan | Y | |

IV. Source Specific Applicable Requirements

Table IV – G
Source-Specific Applicable Requirements
S-46 HAZARDOUS WASTE MANAGEMENT FACILITY WITH LANDFILL GAS COLLECTION
SYSTEM; AND A-11 LANDFILL GAS FLARE FOR HWMF

| Applicable Requirement | Regulation Title or Description of Requirement | Federally Enforceable (Y/N) | Future Effective Date |
|-------------------------------|--|------------------------------------|--|
| 8-34-117.3 | Meets Section 8-34-118 Requirements | Y | |
| 8-34-117.4 | Limits on Number of Wells Shutdown | Y | |
| 8-34-117.5 | Shutdown Duration Limit | Y | |
| 8-34-117.6 | Well Disconnection Records | Y | |
| 8-34-118 | Limited Exemption, Construction Activities | Y | upon start-up of A-11 |
| 8-34-118.1 | Construction Plan | Y | |
| 8-34-118.2 | Activity is Required to Maintain Compliance with this Rule | Y | |
| 8-34-118.3 | Required or Approved by Other Enforcement Agencies | Y | |
| 8-34-118.4 | Emission Minimization Requirement | Y | |
| 8-34-118.5 | Excavated Refuse Requirements | Y | |
| 8-34-118.6 | Covering Requirements for Exposed Refuse | Y | |
| 8-34-118.7 | Installation Time Limit | Y | |
| 8-34-118.8 | Capping Required for New Components | Y | |
| 8-34-118.9 | Construction Activity Records | Y | |
| 8-34-301 | Landfill Gas Collection and Emission Control System Requirements | Y | |
| 8-34-301.1 | Continuous Operation | Y | upon start-up of A-11 |
| 8-34-301.2 | Collection and Control Systems Leak Limitations | Y | Upon Installation of Collection Systems and A-11 |
| 8-34-301.3 | Limits for Enclosed Flares | Y | upon start-up of A-11 |
| 8-34-303 | Landfill Surface Requirements | Y | |
| 8-34-304 | Gas Collection System Installation Requirements | Y | |
| 8-34-304.1 | Based on Waste Age For Inactive or Closed Areas | Y | |
| 8-34-304.2 | Based on Waste Age For Active Areas | Y | |
| 8-34-304.3 | Based on Amount of Decomposable Waste Accepted | Y | |
| 8-34-304.4 | Based on NMOC Emission Rate | Y | |
| 8-34-305 | Wellhead Requirements | Y | upon start-up of A-11 |
| 8-34-305.1 | Operate Under Vacuum | Y | |

IV. Source Specific Applicable Requirements

Table IV – G
Source-Specific Applicable Requirements
S-46 HAZARDOUS WASTE MANAGEMENT FACILITY WITH LANDFILL GAS COLLECTION
SYSTEM; AND A-11 LANDFILL GAS FLARE FOR HWMF

| Applicable Requirement | Regulation Title or Description of Requirement | Federally Enforceable (Y/N) | Future Effective Date |
|-------------------------------|---|------------------------------------|------------------------------|
| 8-34-305.2 | Temperature < 55 °C | Y | |
| 8-34-305.3 | Nitrogen < 20% or | Y | |
| 8-34-305.4 | Oxygen < 5% | Y | |
| 8-34-405 | Design Capacity Reports | Y | |
| 8-34-408 | Collection and Control System Design Plans | Y | |
| 8-34-408.2 | Sites With Existing Collection and Control Systems | Y | |
| 8-34-411 | Annual Report | Y | |
| 8-34-412 | Compliance Demonstration Tests | Y | upon start-up of A-11 |
| 8-34-413 | Performance Test Report | Y | upon start-up of A-11 |
| 8-34-414 | Repair Schedule for Wellhead Excesses | Y | upon start-up of A-11 |
| 8-34-414.1 | Records of Excesses | Y | |
| 8-34-414.2 | Corrective Action | Y | |
| 8-34-414.3 | Collection System Expansion | Y | |
| 8-34-414.4 | Operational Due Date for Expansion | Y | |
| 8-34-415 | Repair Schedule for Surface Leak Excesses | Y | |
| 8-34-415.1 | Records of Excesses | Y | |
| 8-34-415.2 | Corrective Action | Y | |
| 8-34-415.3 | Re-monitor Excess Location Within 10 Days | Y | |
| 8-34-415.4 | Re-monitor Excess Location Within 1 Month | Y | |
| 8-34-415.5 | If No More Excesses, No Further Re-Monitoring | Y | |
| 8-34-415.6 | Additional Corrective Action | Y | |
| 8-34-415.7 | Re-monitor Second Excess Within 10 days | Y | |
| 8-34-415.8 | Re-monitor Second Excess Within 1 Month | Y | |
| 8-34-415.9 | If No More Excesses, No Further Re-monitoring | Y | |
| 8-34-415.10 | Collection System Expansion for Third Excess in a Quarter | Y | |
| 8-34-415.11 | Operational Due Date for Expansion | Y | |
| 8-34-416 | Cover Repairs | Y | |
| 8-34-501 | Operating Records | Y | |
| 8-34-501.1 | Collection System Downtime | Y | upon start-up of A-11 |
| 8-34-501.2 | Emission Control System Downtime | Y | upon start-up of A-11 |

IV. Source Specific Applicable Requirements

Table IV – G
Source-Specific Applicable Requirements
S-46 HAZARDOUS WASTE MANAGEMENT FACILITY WITH LANDFILL GAS COLLECTION
SYSTEM; AND A-11 LANDFILL GAS FLARE FOR HWMF

| Applicable Requirement | Regulation Title or Description of Requirement | Federally Enforceable (Y/N) | Future Effective Date |
|------------------------------------|---|------------------------------------|------------------------------|
| 8-34-501.3 | Continuous Temperature Records (applies to A-11 Flare) | Y | upon start-up of A-11 |
| 8-34-501.4 | Testing | Y | |
| 8-34-501.6 | Leak Discovery and Repair Records | Y | |
| 8-34-501.7 | Waste Acceptance Records | Y | |
| 8-34-501.8 | Non-decomposable Waste Records | Y | |
| 8-34-501.9 | Wellhead Excesses and Repair Records | Y | upon start-up of A-11 |
| 8-34-501.10 | Gas Flow Rate Records for All Emission Control Systems | Y | upon start-up of A-11 |
| 8-34-501.12 | Records Retention for 5 Years | Y | |
| 8-34-503 | Landfill Gas Collection and Emission Control System Leak Testing | Y | |
| 8-34-504 | Portable Hydrocarbon Detector | Y | |
| 8-34-505 | Well Head Monitoring | Y | upon start-up of A-11 |
| 8-34-506 | Landfill Surface Monitoring | Y | |
| 8-34-507 | Continuous Temperature Monitor and Recorder (applies to A-11 Flare) | Y | upon start-up of A-11 |
| 8-34-508 | Gas Flow Meter | Y | upon start-up of A-11 |
| 8-34-510 | Cover Integrity Monitoring | Y | |
| BAAQMD Regulation 9, Rule 1 | Inorganic Gaseous Pollutants – Sulfur Dioxide (3/15/95) | | |
| 9-1-301 | Limitations on Ground Level Concentrations | Y | |
| 9-1-302 | General Emission Limitations (applies to A-11 Flare only) | Y | upon start-up of A-11 |
| BAAQMD Regulation 9, Rule 2 | Inorganic Gaseous Pollutants – Hydrogen Sulfide (10/6/99) | | |
| 9-2-301 | Limitations on Hydrogen Sulfide | N | |
| 40 CFR Part 60, Subpart A | Standards of Performance for New Stationary Sources – General Provisions (8/27/01) | | |
| 60.4(b) | Requires Submission of Requests, Reports, Applications, and Other Correspondence to the Administrator | Y | |

IV. Source Specific Applicable Requirements

Table IV – G
Source-Specific Applicable Requirements
S-46 HAZARDOUS WASTE MANAGEMENT FACILITY WITH LANDFILL GAS COLLECTION
SYSTEM; AND A-11 LANDFILL GAS FLARE FOR HWMF

| Applicable Requirement | Regulation Title or Description of Requirement | Federally Enforceable (Y/N) | Future Effective Date |
|------------------------------------|--|------------------------------------|------------------------------|
| 60.7 | Notification and Record Keeping | Y | |
| 60.8 | Performance Tests | Y | upon start-up of A-11 |
| 60.11 | Compliance with Standards and Maintenance Requirements | Y | |
| 60.11(a) | Compliance determined by performance tests | Y | upon start-up of A-11 |
| 60.11(d) | Control devices operated using good air pollution control practice | Y | upon start-up of A-11 |
| 60.12 | Circumvention | Y | |
| 60.13 | Monitoring Requirements | Y | |
| 60.13(a) | Applies to all continuous monitoring systems | Y | upon start-up of A-11 |
| 60.13(b) | Monitors shall be installed and operational before performing performance tests | Y | upon start-up of A-11 |
| 60.13(e) | Continuous monitors shall operate continuously | Y | upon start-up of A-11 |
| 60.13(f) | Monitors shall be installed in proper locations | Y | upon start-up of A-11 |
| 60.13(g) | Requires multiple monitors for multiple stacks | Y | upon start-up of A-11 |
| 60.14 | Modification | Y | |
| 60.15 | Reconstruction | Y | |
| 60.19 | General Notification and Reporting Requirements | Y | |
| 40 CFR Part 60, Subpart WWW | Standards of Performance for New Stationary Sources – Standards of Performance for Municipal Solid Waste Landfills (2/24/99) | | |
| 60.752 | Standards for Air Emissions from Municipal Solid Waste Landfills | Y | |
| 60.752(b) | Requirements for MSW Landfills with Design Capacity equal to or greater than 2.5 million Mg and 2.5 million m ³ (Large Designated Facilities) | Y | |
| 60.752(b)(2) | Comply with all requirements in sections (b)(2)(i through iv) | Y | |
| 60.752(b)(2)(i) | Submit a Collection and Control System Design Plan | Y | |
| 60.752(b)(2)(i)(A) | The collection and control system in the Design Plan shall comply with 60.752(b)(2)(ii) | Y | |

IV. Source Specific Applicable Requirements

Table IV – G
Source-Specific Applicable Requirements
S-46 HAZARDOUS WASTE MANAGEMENT FACILITY WITH LANDFILL GAS COLLECTION
SYSTEM; AND A-11 LANDFILL GAS FLARE FOR HWMF

| Applicable Requirement | Regulation Title or Description of Requirement | Federally Enforceable (Y/N) | Future Effective Date |
|------------------------|--|-----------------------------|-----------------------|
| 60.752 (b)(2)(i)(B) | Design Plan shall include all proposed alternatives to 60.753 through 60.758 | Y | |
| 60.752 (b)(2)(i)(C) | Design Plan shall conform to 60.759 (active collection system) or demonstrate sufficiency of proposed alternatives | Y | |
| 60.752 (b)(2)(ii) | Install a collection and control system | Y | |
| 60.752 (b)(2)(iii) | Route collected gases to a control system. | Y | |
| 60.752 (b)(2)(iii)(B) | Reduce NMOC emissions by 98% by weight or reduce NMOC outlet concentration to less than 20 ppmv as hexane at 3% O ₂ , dry basis, as demonstrated by initial performance test within 180 days of start-up. | Y | |
| 60.752 (b)(2)(iv) | Operate in accordance with 60.753, 60.755, and 60.756 | Y | |
| 60.752(c) | Title V Operating Permit Requirements | Y | |
| 60.752(c)(1) | Subject date is June 10, 1996 for Landfills new or modified between May 30, 1991 and March 12, 1996 | Y | |
| 60.753 | Operational Standards for Collection and Control Systems | Y | |
| 60.753(a) | Operate a Collection System in each area or cell in which: | Y | |
| 60.753(a)(1) | Active Cell – solid waste in place for 5 years or more | Y | |
| 60.753(a)(2) | Closed/Final Grade – solid waste in place for 2 years or more | Y | |
| 60.753(b) | Operate each wellhead under negative pressure unless: | Y | |
| 60.753(b)(1) | Fire or increased well temperature or to prevent fire | Y | |
| 60.753(b)(2) | Use of geomembrane or synthetic cover (subject to alternative pressure limits) | Y | |
| 60.753(b)(3) | Decommissioned well after approval received for shut-down | Y | |
| 60.753(c) | Operate each wellhead at < 55 °C, and either < 20% N ₂ or < than 5% O ₂ (or other approved alternative levels) | Y | |
| 60.753(c)(1) | N ₂ determined by Method 3C | Y | |
| 60.753(c)(2) | O ₂ determined by 3A and as described in (2)(i-v) | Y | |
| 60.753(d) | Surface Leak Limit is less than 500 ppm methane above background at landfill surface. This section also describes some surface monitoring procedures. | Y | |

IV. Source Specific Applicable Requirements

Table IV – G
Source-Specific Applicable Requirements
S-46 HAZARDOUS WASTE MANAGEMENT FACILITY WITH LANDFILL GAS COLLECTION
SYSTEM; AND A-11 LANDFILL GAS FLARE FOR HWMF

| Applicable Requirement | Regulation Title or Description of Requirement | Federally Enforceable (Y/N) | Future Effective Date |
|-------------------------------|--|------------------------------------|------------------------------|
| 60.753(e) | Vent all collected gases to a control system complying with 60.752(b)(2)(iii). If collection or control system inoperable, shut down gas mover and close all vents within 1 hour | Y | |
| 60.753(f) | Operate the control system at all times when collected gas is routed to the control system | Y | |
| 60.753(g) | If monitoring demonstrates that 60.753(b), (c), or (d) are not being met, corrective action must be taken | Y | |
| 60.754 | Test Methods and Procedures | Y | |
| 60.754(c) | For PSD, NMOC emissions shall be calculated using AP-42 | Y | |
| 60.754(d) | Test Methods for Performance Test (Method 18 or 25C) | Y | |
| 60.755 | Compliance Provisions | Y | |
| 60.755(a) | For Gas Collection Systems | Y | |
| 60.755(a)(1) | Calculation procedures for maximum expected gas generation flow rate | Y | |
| 60.755(a)(1)(i) | Equation for unknown year-to-year waste acceptance rate | Y | |
| 60.755(a)(1)(ii) | Equation for known year-to-year waste acceptance rate | Y | |
| 60.755(a)(2) | Vertical wells and horizontal collectors shall be of sufficient density to meet all performance specifications | Y | |
| 60.755(a)(3) | Measure wellhead pressure monthly. If pressure is positive, take corrective action (final corrective action = expand system within 120 days of initial positive pressure reading) | Y | |
| 60.755(a)(4) | Expansion not required during first 180 days after startup. | Y | |
| 60.755(a)(5) | Monitor wellheads monthly for temperature and either nitrogen or oxygen. If readings exceed limits, take corrective action up to expanding system within 120 days of first excess. | Y | |
| 60.755(b) | Wells shall be placed in cells as described in Design Plan and no later than 60 days after: | Y | |
| 60.755(b)(1) | Five years after initial waste placement in cell, for active cells | Y | |
| 60.755(b)(2) | Two years after initial waste placement in cell, for closed/final grade cells. | Y | |
| 60.755(c) | Procedures for complying with surface methane standard | Y | |
| 60.755(c)(1) | Quarterly monitoring of surface and perimeter | Y | |
| 60.755(c)(2) | Procedure for determining background concentration | Y | |
| 60.755(c)(3) | Method 21 except probe inlet placed 5-10 cm above ground | Y | |

IV. Source Specific Applicable Requirements

Table IV – G
Source-Specific Applicable Requirements
S-46 HAZARDOUS WASTE MANAGEMENT FACILITY WITH LANDFILL GAS COLLECTION
SYSTEM; AND A-11 LANDFILL GAS FLARE FOR HWMF

| Applicable Requirement | Regulation Title or Description of Requirement | Federally Enforceable (Y/N) | Future Effective Date |
|-------------------------------|--|------------------------------------|------------------------------|
| 60.755(c)(4) | Excess is any reading of 500 ppmv or more. Take corrective action indicated below (i-v). | Y | |
| 60.755(c)(4)(i) | Mark and record location of excess | Y | |
| 60.755(c)(4)(ii) | Repair cover or adjust vacuum. Re-monitor within 10 calendar days. | Y | |
| 60.755(c)(4)(iii) | If still exceeding 500 ppmv, take additional corrective action. Re-monitor within 10 calendar days of 2 nd excess. | Y | |
| 60.755(c)(4)(iv) | Re-monitor within 1 month of initial excess. | Y | |
| 60.755(c)(4)(v) | For any location with 3 monitored excesses in a quarter, additional collectors (or other approved collection system repairs) shall be operational within 120 days of 1 st excess. | Y | |
| 60.755(c)(5) | Monitor cover integrity monthly and repair as needed. | Y | |
| 60.755(d) | Instrumentation and procedures for complying with 60.755(c). | Y | |
| 60.755(d)(1) | Portable analyzer meeting Method 21 | Y | |
| 60.755(d)(2) | Calibrated with methane diluted to 500 ppmv in air | Y | |
| 60.755(d)(3) | Use Method 21, Section 4.4 instrument evaluation procedures | Y | |
| 60.755(d)(4) | Calibrate per Method 21, Section 4.2 immediately before monitoring. | Y | |
| 60.755(e) | Provisions apply at all times except during startup, shutdown, or malfunction, provided the duration of these shall not exceed 5 days for collection systems or 1 hour for control systems. | Y | |
| 60.756 | Monitoring of Operations | Y | |
| 60.756(a) | For active collection systems, install wellhead sampling port | Y | |
| 60.756(a)(1) | Measure gauge pressure in wellhead on a monthly basis | Y | |
| 60.756(a)(2) | Measure nitrogen or oxygen concentration in wellhead gas on a monthly basis. | Y | |
| 60.756(a)(3) | Measure temperature of wellhead gas on a monthly basis. | Y | |
| 60.756(b) | Enclosed combustors shall comply with (b)(1) and (b)(2) | Y | |
| 60.756(b)(1) | Temperature monitor and continuous recorder (not required for boilers and process heaters with capacity > 44 MW) | Y | |
| 60.756(b)(2) | Device that records flow to or bypass of the control device (i or ii below) | Y | |
| 60.756(b)(2)(i) | Install, calibrate, and maintain a device that records flow to the control device at least every 15 minutes. | Y | |

IV. Source Specific Applicable Requirements

Table IV – G
Source-Specific Applicable Requirements
S-46 HAZARDOUS WASTE MANAGEMENT FACILITY WITH LANDFILL GAS COLLECTION
SYSTEM; AND A-11 LANDFILL GAS FLARE FOR HWMF

| Applicable Requirement | Regulation Title or Description of Requirement | Federally Enforceable (Y/N) | Future Effective Date |
|-------------------------------|---|------------------------------------|------------------------------|
| 60.756(e) | Procedures for requesting alternative monitoring parameters | Y | |
| 60.756(f) | Monitor surface on a quarterly basis. | Y | |
| 60.757 | Reporting Requirements | Y | |
| 60.757(a)(3) | Amended Design Capacity Report required within 90 days of receiving a permitted increase in design capacity or within 90 days of an annual density calculation that results in a design capacity over the thresholds. | Y | |
| 60.757(b)(3) | Sites with collection and control systems operating in compliance with this subpart are exempt from (b)(1) and (b)(2) above. | Y | |
| 60.757(c) | Submit a Collection and Control System Design Plan within 1 year of first NMOC emission rate report showing NMOC > 50 MG/year, except as follows | Y | |
| 60.757(f) | Submit Annual Reports containing information required by (f)(1) through (f)(6) | Y | |
| 60.757(f)(1) | Value and length of time for exceedance of parameters monitored per 60.756(a), (b) or (d) | Y | |
| 60.757(f)(2) | Description and duration of all periods when gas is diverted from the control device by a by-pass line | Y | |
| 60.757(f)(3) | Description and duration of all periods when control device was not operating for more than 1 hour | Y | |
| 60.757(f)(4) | All periods when collection system was not operating for more than 5 days. | Y | |
| 60.757(f)(5) | Location of each surface emission excess and all re-monitoring dates and concentrations. | Y | |
| 60.757(f)(6) | Location and installation dates for any wells or collectors added as a result of corrective action for a monitored excess. | Y | |
| 60.757(g) | Initial Performance Test Report Requirements (g)(1-6) | Y | |
| 60.757(g)(1) | Diagram of collection system showing positions of all existing collectors, proposed positions for future collectors, and areas to be excluded from control. | Y | |
| 60.757(g)(2) | Basis for collector positioning to meet sufficient density req. | Y | |
| 60.757(g)(3) | Documentation supporting percentage of asbestos or non-degradable material claims for areas without a collection system. | Y | |
| 60.757(g)(4) | For areas excluded from collection due to non-productivity, calculations and gas generation rates for each non-productive area and the sum for all nonproductive areas. | Y | |

IV. Source Specific Applicable Requirements

Table IV – G
Source-Specific Applicable Requirements
S-46 HAZARDOUS WASTE MANAGEMENT FACILITY WITH LANDFILL GAS COLLECTION
SYSTEM; AND A-11 LANDFILL GAS FLARE FOR HWMF

| Applicable Requirement | Regulation Title or Description of Requirement | Federally Enforceable (Y/N) | Future Effective Date |
|-------------------------------|--|------------------------------------|------------------------------|
| 60.757(g)(5) | Provisions for increasing gas mover equipment if current system is inadequate to handle maximum projected gas flow rate. | Y | |
| 60.757(g)(6) | Provisions for control of off-site migration | Y | |
| 60.758 | Recordkeeping Requirements | Y | |
| 60.758(a) | Design Capacity and Waste Acceptance Records (retain 5 years) | Y | |
| 60.758(b) | Collection and Control Equipment Records (retain for life of control equipment except 5 years for monitoring data) | Y | |
| 60.758(b)(1) | Collection System Records | Y | |
| 60.758(b)(1)(i) | Maximum expected gas generation flow rate. | Y | |
| 60.758(b)(1)(ii) | Density of wells and collectors | Y | |
| 60.758(b)(2) | Control System Records - enclosed combustors other than boilers or process heaters with heat input > 44 MW | Y | |
| 60.758(b)(2)(i) | Combustion temperature measured every 15 minutes and averaged over the same time period as the performance test | Y | |
| 60.758(b)(2)(ii) | Percent NMOC reduction achieved by the control device | Y | |
| 60.758(c) | Records of parameters monitored pursuant to 60.756 and periods of operation when boundaries are exceeded (retain for 5 years). | Y | |
| 60.758(c)(1) | Exceedances subject to record keeping are | Y | |
| 60.758(c)(1)(i) | All 3-hour periods when average combustion temperature was more than 28 C below the average combustion temperature during the most recent complying performance test | Y | |
| 60.758(c)(2) | Records of continuous flow to control device or monthly inspection records if seal and lock for bypass valves | Y | |
| 60.758(d) | Plot map showing location of all existing and planned collectors with a unique label for each collector (retain for life of collection system) | Y | |
| 60.758(d)(1) | Installation date and location of all newly installed collectors | Y | |
| 60.758(d)(2) | Records of nature, deposition date, amount, and location of asbestos or non-degradable waste excluded from control | Y | |
| 60.758(e) | Records of any exceedance of 60.753, location of exceedance and re-monitoring dates and data (for wellheads and surface). Retain for 5 years. | Y | |
| 60.759 | Specifications for Active Collection Systems | Y | |
| 60.759(a) | Active wells and collectors shall be at sufficient density | Y | |

IV. Source Specific Applicable Requirements

Table IV – G
Source-Specific Applicable Requirements
S-46 HAZARDOUS WASTE MANAGEMENT FACILITY WITH LANDFILL GAS COLLECTION
SYSTEM; AND A-11 LANDFILL GAS FLARE FOR HWMF

| Applicable Requirement | Regulation Title or Description of Requirement | Federally Enforceable (Y/N) | Future Effective Date |
|----------------------------------|--|------------------------------------|------------------------------|
| 60.759(a)(1) | Collection System in refuse shall be certified by PE to achieve comprehensive control of surface gas emissions | Y | |
| 60.759(a)(2) | Collection Systems (active or passive) outside of refuse shall address migration control | Y | |
| 60.759(a)(3) | All gas producing areas shall be controlled except as described below (i-iii). | Y | |
| 60.759(b) | Gas Collection System Components | Y | |
| 60.759(b)(1) | Must be constructed of PVC, HDPE, fiberglass, stainless steel, or other approved material and of suitable dimensions to convey projected gas amounts and withstand settling, traffic, etc. | Y | |
| 60.759(b)(2) | Collectors shall not endanger liner, shall manage condensate and leachate, and shall prevent air intrusion and surface leaks. | Y | |
| 60.759(b)(3) | Header connection assemblies shall include positive closing throttle valve, seals and couplings to prevent leaks, at least one sampling port, and shall be constructed of PVC, HDPE, fiberglass, stainless steel, or other approved materials. | Y | |
| 60.759(c) | Gas Mover Equipment shall be sized to handle maximum expected gas generation rate over the intended period of use. | Y | |
| 60.759(c)(1) | For existing systems, flow data shall be used to project maximum flow rate. | Y | |
| 60.759(c)(2) | For new systems, gas generation rate shall be calculated per 60.755(a)(1) | Y | |
| 40 CFR Part 62 | Approval and Promulgation of State Plans for Designated Facilities and Pollutants (6/9/03) | | |
| 62.1100 | Identification of Plan | Y | |
| 62.1115 | Identification of Sources | Y | |
| 40 CFR Part 63, Subpart A | National Emission Standards for Hazardous Air Pollutants: General Provisions (4/22/04) | | |
| 63.4 | Prohibited activities and circumvention | Y | |
| 63.5(b) | Requirements for existing, newly constructed, and reconstructed sources | Y | |
| 63.6(e) | Operation and maintenance requirements and SSM Plan | Y | upon start-up of A-11 |
| 63.6(f) | Compliance with non-opacity emission standards | Y | upon start-up of A-11 |

IV. Source Specific Applicable Requirements

Table IV – G
Source-Specific Applicable Requirements
S-46 HAZARDOUS WASTE MANAGEMENT FACILITY WITH LANDFILL GAS COLLECTION
SYSTEM; AND A-11 LANDFILL GAS FLARE FOR HWMF

| Applicable Requirement | Regulation Title or Description of Requirement | Federally Enforceable (Y/N) | Future Effective Date |
|-------------------------------------|---|------------------------------------|------------------------------|
| 63.10(b)(2) (i-v) | Records for startup, shutdown, malfunction, and maintenance | Y | upon start-up of A-11 |
| 63.10(d)(5) | Startup, Shutdown, and Malfunction (SSM) Reports | Y | upon start-up of A-11 |
| 40 CFR Part 63, Subpart AAAA | National Emission Standards for Hazardous Air Pollutants: Municipal Solid Waste Landfills (1/16/03) | | |
| 63.1945 | When do I have to comply with this subpart? | Y | |
| 63.1945(b) | Compliance date for existing affected landfills | Y | |
| 63.1955 | What requirements must I meet? | Y | |
| 63.1955(a)(2) | Comply with State Plan that implements 40 CFR Part 60, Subpart Cc | Y | |
| 63.1955(b) | Comply with 63.1960-63.1985, if a collection and control system is required by 40 CFR Part 60, Subpart WWW or a State Plan implementing 40 CFR Part 60, Subpart Cc | Y | upon start-up of A-11 |
| 63.1955(c) | Comply with all approved alternatives to standards for collection and control systems plus all SSM requirements and 6 month compliance reporting requirements | Y | upon start-up of A-11 |
| 63.1960 | How is compliance determined? | Y | |
| 63.1965 | What is a deviation? | Y | |
| 63.1975 | How do I calculate the 3-hour block average used to demonstrate compliance? | Y | upon start-up of A-11 |
| 63.1980 | What records and reports must I keep and submit? | Y | |
| 63.1980(a) | Comply with all record keeping and reporting requirements in 40 CFR Part 60, Subpart WWW or the State Plan implementing 40 CFR Part 60, Subpart Cc, except that the annual report required by 40 CFR 60.757(f) must be submitted every 6 months | Y | upon start-up of A-11 |
| 63.1980(b) | Comply with all record keeping and reporting requirements in 40 CFR Part 60, Subpart A and 40 CFR Part 63, Subpart A, including SSM Plans and Reports | Y | upon start-up of A-11 |
| BAAQMD Condition # 20754 | | | |
| Part 1 | Waste acceptance limits (Regulation 2-1-301) | Y | |
| Part 2 | Landfill gas collection system description (Regulations 2-1-301 and 8-34-301.1) | Y | |

IV. Source Specific Applicable Requirements

Table IV – G
Source-Specific Applicable Requirements
S-46 HAZARDOUS WASTE MANAGEMENT FACILITY WITH LANDFILL GAS COLLECTION
SYSTEM; AND A-11 LANDFILL GAS FLARE FOR HWMF

| Applicable Requirement | Regulation Title or Description of Requirement | Federally Enforceable (Y/N) | Future Effective Date |
|-------------------------------|--|------------------------------------|------------------------------|
| Part 3 | Control requirements for collected landfill gas (Regulations 2-1-301 and 8-34-301) | Y | upon start-up of A-11 |
| Part 4 | Flare temperature limit (Toxic Risk Management Policy and Regulation 8-34-301.3) | Y | upon start-up of A-11 |
| Part 5 | Nox emission limit for flare (RACT and Cumulative Increase) | Y | upon start-up of A-11 |
| Part 6 | CO emission limit for flare (RACT and Cumulative Increase) | Y | upon start-up of A-11 |
| Part 7 | Landfill gas sulfur content limit (RACT and Cumulative Increase) | Y | upon start-up of A-11 |
| Part 8 | Annual source test (Regulations 8-34-301.3 and 8-34-412, RACT, and Cumulative Increase) | Y | upon start-up of A-11 |
| Part 9 | Annual landfill gas characterization test (Toxic Risk Management Policy, AB-2588 Air Toxics Hot Spots Act, and Regulations 8-34-412 and 9-1-302) | Y | upon start-up of A-11 |
| Part 10 | Landfill gas toxic compound concentration limits (Toxic Risk Management Policy and AB-2588 Air Toxics Hot Spots Act) | N | upon start-up of A-11 |
| Part 11 | Record keeping requirements (Regulations 2-1-301, 2-6-501, and 8-34-501) | Y | |
| Part 12 | Reporting periods and report submittal due dates for the Regulation 8, Rule 34 report (Regulation 8-34-411 and 40 CFR 63.1980(a)) | Y | |

- 1 This section has been removed from BAAQMD Regulations because it has been superseded. Nevertheless, the source must comply with this regulation until US EPA has reviewed and approved (or disapproved) the District's revision of the regulation.

IV. Source Specific Applicable Requirements

Table IV – H
Source-Specific Applicable Requirements
S-50 SOLID WASTE TRANSFER STATION
AND A-50 WATER MIST SYSTEM

| Applicable Requirement | Regulation Title or Description of Requirement | Federally Enforceable (Y/N) | Future Effective Date |
|--------------------------------|---|------------------------------------|------------------------------|
| BAAQMD Regulation 6 | Particulate Matter and Visible Emissions (12/19/90) | | |
| 6-301 | Ringelmann No. 1 Limitation | Y | upon start-up of S50 |
| 6-305 | Visibel Particles | Y | upon start-up of S50 |
| 6-401 | Appearance of Emissions | Y | upon start-up of S50 |
| BAAQMD Condition #22792 | | | |
| Part 1 | Waste Acceptance Rate Limits (Cumulative Increase) | Y | upon start-up of S50 |
| Part 2 | Requires That Mixed Wastes, Green Material and Wood Waste Be Removed Within 48 Hours of Being Received (Regulation 1-301) | Y | upon start-up of S50 |
| Part 3 | Visible Emissions – Particulate Fallout Restrictions for Operations at the Transfer Station (Regulations 1-301, 6-301 and 6-305) | Y | upon start-up of S50 |
| Part 4 | Visible Emissions – Maintenance and Cleaning Requirements for Roadways (Regulations 6-301 and 6-305) | Y | upon start-up of S50 |
| Part 5 | Limitations on the Vehicle Traffic to Both S15 and S50 While Waste Continues to Be Accepted at S15. (Cumulative Increase) | Y | upon start-up of S50 |
| Part 6 | Limitations on the Vehicle Traffic to S50 After Waste Ceases ontinues to Be Accepted at S15. (Cumulative Increase) | Y | upon start-up of S50 |
| Part 7 | Recordkeeping Requirements for Waste Accepted and Vehicle Traffic to Both S15 and S50 (Cumulative Increase, Regulations 2-6-501, and 6-305) | Y | upon start-up of S50 |

V. SCHEDULE OF COMPLIANCE

The permit holder shall comply with all applicable requirements cited in this permit. The permit holder shall also comply with applicable requirements that become effective during the term of this permit on a timely basis.

VI. PERMIT CONDITIONS

Any condition that is preceded by an asterisk is not federally enforceable.

Condition # 5771

**For: S-5, INTERNAL COMBUSTION LEAN BURN ENGINE; and
S-6, INTERNAL COMBUSTION LEAN BURN ENGINE:**

1. The Internal Combustion Engines (S-5 and S-6) shall be fired exclusively on landfill gas. (basis: Cumulative Increase)
2. The A-8 Flare shall be operated when one or more Internal Combustion Engines (S-5, S-6, or S-37) are not operating. An automatically controlled landfill gas valve shall be installed and maintained to insure that landfill gas is immediately made available for flaring to the Flare, A-8, when one or more engines are down. Under no circumstances shall raw landfill gas be vented to the atmosphere. This limitation does not apply to unavoidable landfill gas emissions that occur during control system installation, maintenance, or repair that is performed in compliance with Regulation 8, Rule 34, Sections 113, 116, 117, or 118 or to inadvertent component leaks that do not exceed the limits specified in 8-34-301.2. (basis: Regulation 8-34-301)
3. District approved flow meters, to measure landfill gas flow into each engine, shall be installed prior to any operation and maintained in good working condition. (basis: Cumulative Increase and Regulation 8-34-508)
4. Nitrogen Oxide (NO_x) emissions from each Internal Combustion Engine (S-5 and S-6) shall not exceed 63 ppmv, corrected to 15% O₂, dry basis. (basis: BACT, Offsets)
5. Carbon Monoxide (CO) emissions from each Internal Combustion Engine (S-5 and S-6) shall not exceed 376 ppmv, corrected to 15% O, dry basis. (basis: BACT)
6. Each engine shall comply with the NMOC limit in Regulation 8-34-301.4. (basis: BACT and Regulation 8-34-301.4)

VI. Permit Conditions

Condition # 5771

**For: S-5, INTERNAL COMBUSTION LEAN BURN ENGINE; and
S-6, INTERNAL COMBUSTION LEAN BURN ENGINE:**

7. In order to demonstrate compliance with parts #4, #5, and #6 above, Regulation 8, Rule 34, Section 301.4, and Regulation 9, Rule 8, Sections 302.1 and 302.3, the Permit Holder shall ensure that a District approved source test is conducted annually on each Internal Combustion Engine (S-5 and S-6). The Source Test Section of the District shall be contacted to obtain their approval of the source test procedures at least 14 days in advance of each source test. The Source Test Section shall be notified of the scheduled test date at least 7 days in advance of each source test. The source test report shall be submitted to the Compliance and Enforcement Division within 45 days of the test date. The annual source tests shall determine the following:
 - a. landfill gas flow rate to each engine (dry basis);
 - b. concentrations (dry basis) of carbon dioxide (CO₂), nitrogen (N₂), oxygen (O₂), methane (CH₄), and non-methane organic compounds (NMOC) in the landfill gas;
 - c. exhaust gas flow rate from each engine (dry basis);
 - d. concentrations (dry basis) of NO_x, CO, NMOC, SO₂ and O₂ in the exhaust gas from each engine;
 - e. NMOC destruction efficiency achieved by each engine; and
 - f. average cylinder temperature range (or exhaust temperature range measured at an APCO approved location) for each engine that is required to maintain compliance with Parts 4, 5, and 6 above and Regulation 8-34-301.4.
(basis: BACT, Regulations 8-34-301.4, 8-34-412, 9-8-302.1, and 9-8-302.3)

8. The heat input to each internal combustion engine shall not exceed 285.6 million BTU per day nor 104,250 million BTU per year. (basis: Regulation 2-1-301, Offsets)

VI. Permit Conditions

Condition # 5771

**For: S-5, INTERNAL COMBUSTION LEAN BURN ENGINE; and
S-6, INTERNAL COMBUSTION LEAN BURN ENGINE:**

9. Daily records shall be maintained, in a District approved logbook, for the hours of operation of the engines and total amount of landfill gas flow through each engine. On a monthly basis, summarize all daily records for each engine. On a monthly basis, calculate and record the maximum daily and total monthly heat input rate (in BTU) to each engine based on the average methane concentration in the landfill gas (as measured during the most recent source test), a high heating value for methane of 1013 BTU/ft³ at 60 degrees F, and the amount of landfill gas burned in each engine. The logbook shall be kept on site and shall be made available to the District staff upon request. All records shall be retained for at least 5 years from the date of entry. (basis: Cumulative Increase and Regulations 2-1-301, 2-6-501, and 8-34-301)

10. Effective January 1, 2003, the average cylinder temperature for each Internal Combustion Engine shall be maintained at the temperature determined by the most recent annual source, plus or minus 10 degrees F (or other appropriate range established by the source test) and averaged over 3 hours, during all times that the engine is operated. In order to demonstrate compliance with this condition, each engine shall be equipped with at least one thermocouple that will continuously monitor engine cylinder temperature (or engine exhaust temperature at an APCO approved location). The engine cylinder temperature (or average cylinder temperature if more than one thermocouple is used) shall be continuously recorded. These temperature monitors and recorders shall be installed and operating by no later than July 1, 2002. The appropriate temperature range for each engine that is established by the source tests shall be added to this part in accordance with the procedures identified in Regulations 2-6-414 or 2-6-415. (basis: Regulations 8-34-301, 8-34-501.11 and 8-34-509)

VI. Permit Conditions

Condition # 7463

For: S-22, PRIMARY OIL/WATER SEPARATOR, TK-2; S-23, SECONDARY OIL/WATER SEPARATOR, TK-4; S-24, LOAD EQUALIZATION TANK, TK-7; S-25, PHOTO-OXIDIZER TANK, TK-5; S-26, NEUTRALIZATION TANK, TK-9; S-27, FIRST STAGE CLARIFIER, TK-8; S-28, AIR STRIPPER SUMP; S-29, FLOCCULATION/MIXING TANK, TK-8A; S-30, AIR STRIPPER; S-38, SECONDARY OIL/WATER SEPARATOR, TK-4; S-39, SLUDGE STORAGE TANK, TK-3; S-40, EQUALIZATION TANK, TK-1; A-1, CARBON ADSORBER; A-2, CARBON ADSORBER; A-3, CARBON ADSORBER; A-4, CARBON ADSORBER; A-5, CARBON ADSORBER; and A-6, CARBON ADSORBER.

1. The emissions of precursor organic compounds (POC) from the sources S-22, S-23, S-24, S-25, S-26, S-27, S-28, S-29, S-38, S-39, and S-40 shall be abated by the Carbon Adsorbers, A-1 and A-2 arranged in series, during all periods of operations. (basis: Cumulative Increase and Toxic Risk Management Policy)
2. The emissions of POC from the Air Stripper (S-30) shall be abated by the Carbon Adsorbers, either A-3 and A-4 arranged in series, or A-5 and A-6 arranged in series, during all periods of operations. (basis: Cumulative Increase and Toxic Risk Management Policy)
3. The two Secondary Oil/Water Separators (S-23 and S-38) shall not operate concurrently. (basis: Cumulative Increase)
4. The Oil/Water Separators (S-22, S-23, and S-38) shall have all the openings kept closed at all times except when the opening is used for the inspection and maintenance of the separators. (basis: Regulations 8-8-301 and 8-8-303)
5. The wastewater throughput rate to the leachate collection, recovery, and treatment system (LCRTS) shall not exceed 1,700 gallons per hour; nor 40,800 gallons per day; nor 14,892,000 gallons per year. (basis: Cumulative Increase)
6. The detectable POC leak emissions, as measured by a District approved portable monitor, shall not exceed 100 ppm above background at a distance of 1 cm from any of the valves, flanges, or pumps of LCRTS. (basis: Cumulative Increase)
7. The second to last Carbon Adsorber, A-1 and either A-3 or A-5, shall be replaced with fresh carbon upon the detection of 10% of the inlet stream to the Carbon Adsorber as measured by a flame ionization detector (OVA-FID) or other method approved in writing by the APCO. (basis: Cumulative Increase and Toxic Risk Management Policy)

VI. Permit Conditions

Condition # 7463

For: S-22, PRIMARY OIL/WATER SEPARATOR, TK-2; S-23, SECONDARY OIL/WATER SEPARATOR, TK-4; S-24, LOAD EQUALIZATION TANK, TK-7; S-25, PHOTO-OXIDIZER TANK, TK-5; S-26, NEUTRALIZATION TANK, TK-9; S-27, FIRST STAGE CLARIFIER, TK-8; S-28, AIR STRIPPER SUMP; S-29, FLOCCULATION/MIXING TANK, TK-8A; S-30, AIR STRIPPER; S-38, SECONDARY OIL/WATER SEPARATOR, TK-4; S-39, SLUDGE STORAGE TANK, TK-3; S-40, EQUALIZATION TANK, TK-1; A-1, CARBON ADSORBER; A-2, CARBON ADSORBER; A-3, CARBON ADSORBER; A-4, CARBON ADSORBER; A-5, CARBON ADSORBER; and A-6, CARBON ADSORBER.

8. The last Carbon Adsorber, A-2 and either A-4 or A-6, shall be replaced with fresh carbon upon the detection of break-through of 6 ppm as measured with a flame ionization detector (OVA-FID) or other method approved in writing by the APCO. (basis: Cumulative Increase and Toxic Risk Management Policy)
9. The limit set forth in parts 7 and 8 shall apply to non-methane hydrocarbon emissions. To determine the presence of methane in the exhaust stream, a reading shall be taken with and without a carbon filter tip fitted on the OVA-FID probe. Concentrations measured with the carbon filter tip in place shall be considered methane for the purposes of these permit conditions. (basis: Cumulative Increase and Toxic Risk Management Policy)
10. The operator of this system shall monitor with an FID, or other method approved in writing by the APCO, at the following locations and on the schedule described in subpart d. below:
 - a. at the inlet of A-1 and either A-3 or A-5;
 - b. at the exhaust of A-1 and either A-3 or A-5;
 - c. at the exhaust of A-2 and either A-4 or A-6.
 - d. If the time until predicted hydrocarbon breakthrough from the last carbon adsorber (calculated pursuant to Part 11.d. below) is greater than 30 days, then monitoring shall be conducted on a monthly basis. If the time until predicted hydrocarbon breakthrough is between 7 days and 30 days, then monitoring shall be conducted on a weekly basis. If the time until predicted hydrocarbon breakthrough is less than 7 days, then monitoring shall be conducted on a daily basis until the carbon is replaced.
(basis: Cumulative Increase and Toxic Risk Management Policy)

VI. Permit Conditions

Condition # 7463

For: S-22, PRIMARY OIL/WATER SEPARATOR, TK-2; S-23, SECONDARY OIL/WATER SEPARATOR, TK-4; S-24, LOAD EQUALIZATION TANK, TK-7; S-25, PHOTO-OXIDIZER TANK, TK-5; S-26, NEUTRALIZATION TANK, TK-9; S-27, FIRST STAGE CLARIFIER, TK-8; S-28, AIR STRIPPER SUMP; S-29, FLOCCULATION/MIXING TANK, TK-8A; S-30, AIR STRIPPER; S-38, SECONDARY OIL/WATER SEPARATOR, TK-4; S-39, SLUDGE STORAGE TANK, TK-3; S-40, EQUALIZATION TANK, TK-1; A-1, CARBON ADSORBER; A-2, CARBON ADSORBER; A-3, CARBON ADSORBER; A-4, CARBON ADSORBER; A-5, CARBON ADSORBER; and A-6, CARBON ADSORBER.

11. The operator of the LCRTS shall maintain, in a District approved logbook, the following information:
 - a. daily records of wastewater throughput to the LCRTS;
 - b. each monitoring reading and analysis results for the day of operation they were taken;
 - c. calculate and record the frequency of carbon change out necessary to maintain compliance with part 7;
 - d. calculate and record the time of predicted hydrocarbon breakthrough from the last Carbon Adsorbers, to demonstrate compliance with part 8;
 - e. the dates and locations of all carbon bed replacements.
(basis: Cumulative Increase and Toxic Risk Management Policy)

12. The project is restricted to emission limits set forth in part 8, and throughput rates stipulated in part 5. Any relaxation of these conditions that increase the emissions and/or throughput of wastewater will be subject to a full permit review as though construction at the site had not yet commenced. (basis: Cumulative Increase and Toxic Risk Management Policy)

VI. Permit Conditions

Condition # 17812

For: S-37, INTERNAL COMBUSTION LEAN BURN ENGINE

1. The S-37 Internal Combustion Engine shall be fired on landfill gas exclusively. (basis: Offsets and Cumulative Increase)
2. The heat input to S-37 shall not exceed 251.9 million BTUs per day nor 91,951 million BTUs during any consecutive 12-month period. (basis: Offsets and Cumulative Increase)
3. The S-37 Internal Combustion Engine shall operate continuously during all times that landfill gas is vented to the engine. (basis: Regulation 8-34-301.1)
4. In the event of shutdown of S-37, landfill gas shall be automatically diverted to the A-8 Flare. The A-8 Flare shall be operated when one or more Internal Combustion Engines (S-5, S-6, or S-37) are not operating. Raw landfill gas shall not be vented to the atmosphere, except for unavoidable landfill gas emissions that occur during control system installation, maintenance, or repair that is performed in compliance with Regulation 8, Rule 34, Sections 113, 116, 117, or 118 and for inadvertent component leaks that do not exceed the limits specified in 8-34-301.2. (basis: Regulation 8-34-301)
5. S-37 shall emit no more than 63 ppmv of nitrogen oxides on dry basis, corrected to 15% oxygen. (basis: BACT, Offsets)
6. S-37 shall emit no more than 309 ppmv of carbon monoxide, dry basis, corrected to 15% oxygen. (basis: BACT)
7. In order to demonstrate compliance with part 2, the IC Engine shall be equipped with a gas flow meter and recorder that records the gas flow rate at least every 15 minutes. (basis: Offsets and Cumulative Increase)

VI. Permit Conditions

Condition # 17812

For: S-37, INTERNAL COMBUSTION LEAN BURN ENGINE

8. In order to demonstrate compliance with parts 5 and 6 above and Regulations 8-34-301.4, 9-8-302.1, and 9-8-302.3, the Permit Holder shall ensure that a District approved source test is conducted annually on the S-37 Internal Combustion Engine. Source tests shall be conducted no sooner than 9 months and no later than 12 months after the previous source test. The Source Test Section of the District shall be contacted to obtain their approval of the source test procedures at least 14 days in advance of each source test. They shall be notified of the scheduled test date at least 7 days in advance of each source test. The source test report shall be submitted to the Compliance and Enforcement Division within 45 days of the test date.
 - a. landfill gas flow rate to the engine (dry basis);
 - b. concentrations (dry basis) of carbon dioxide (CO₂), nitrogen (N₂), oxygen (O₂), methane (CH₄), and non-methane organic compounds (NMOC) in the landfill gas;
 - c. exhaust gas flow rate from the engine (dry basis);
 - d. concentrations (dry basis) of NO_x, CO, NMOC, , SO₂ and O₂ in the exhaust gas from the engine;
 - e. the NMOC destruction efficiency achieved by the engine; and
 - f. the average cylinder temperature range (or exhaust temperature range measured at an APCO approved location) for each engine that is required to maintain compliance with parts 5 and 6 above and Regulation 8-34-301.4.(basis: BACT, and Regulations 8-34-301.4, 8-34-412, 9-8-302.1, and 9-8-302.3)

9. The Permit Holder shall maintain the following records:
 - a. Records of all start up and shut down dates and times and the reason for any shut downs for S-37.
 - b. Records of landfill gas throughput to S-37.
 - c. On a monthly basis calculate and record the maximum daily and total monthly heat input rate (in BTU) to each engine based on the average methane concentration in the landfill gas (as measured during the most recent source test), a high heating value for methane of 1013 BTU/ft³ at 60 degrees F, and the amount of landfill gas burned in each engine.
 - d. Records of all compliance demonstration test data.All records shall be retained on site for a minimum of 5 years and shall be made available to District staff upon request. (basis: BACT, Offsets, Cumulative Increase, and Regulation 8-34-501)

VI. Permit Conditions

Condition # 17812

For: S-37, INTERNAL COMBUSTION LEAN BURN ENGINE

10. Effective January 1, 2003, the average cylinder temperature for the S-37 Internal Combustion Engine shall be maintained at the temperature determined by the most recent annual source, plus or minus 10 degrees F (or other appropriate range established by the source test) and averaged over 3 hours, during all times that the engine is operated. In order to demonstrate compliance with this condition, the engine shall be equipped with at least one thermocouple that will continuously monitor engine cylinder temperature (or engine exhaust temperature at an APCO approved location). The engine cylinder temperature (or average cylinder temperature if more than one thermocouple is used) shall be continuously recorded. These temperature monitors and recorders shall be installed and operating by no later than July 1, 2002. The appropriate temperature range for the engine that is established by the source tests shall be added to this part via an administrative amendment. (Basis: Regulations 8-34-301, 8-34-501.11 and 8-34-509)

VI. Permit Conditions

Condition # 17821

FOR: S-15, ACTIVE LANDFILL WITH LANDFILL GAS COLLECTION SYSTEM; AND A-8, LANDFILL GAS FLARE

1. Total waste accepted and placed at the landfill shall not exceed 2,500 tons in any single day. The total cumulative amount of all wastes placed in the landfill shall not exceed 13.0 million tons. The maximum design capacity of the landfill (total volume of all wastes and cover materials placed in the landfill, excluding final cover) shall not exceed 21.47 million cubic yards. (basis: Regulation 2-1-301, Cumulative Increase)

 - *2. This facility is not subject to Regulation 8, Rule 40 because the landfill does not accept contaminated soil (soil containing more than 50 ppmw of volatile organic compounds, VOCs). The following types of materials may be accepted:
 - a. Materials for which the Permit Holder has appropriate documentation demonstrating that either the organic content of the soil or the organic concentration above the soil is below the “contaminated” level (as defined in Regulation 8, Rule 40, Sections 205, 207, and 211).
 - b. Materials for which the Permit Holder has no documentation to prove that soil is not contaminated, but source of the soil is known and there is no reason to suspect that the soil might contain organic compounds.
 - c. Materials which the Permit Holder plans to test in order to determine the VOC contamination level in the soil, provided that the material is sample within 24 hours of receipt by this site and is handled as if the soil were contaminated until the Permit Holder receives the test results. The Permit Holder shall collect soil samples in accordance with Regulation 8-40-601. The organic content of the collected soil samples shall be determined in accordance with Regulation 8-40-602.
 - i. If these test results indicate that the soil is still contaminated or if the soil was not sampled within 24 hours of receipt by the facility, the Permit Holder must continue to handle the soil in accordance with Regulation 8, Rule 40, until the soil has been removed from this site or has completed treatment. Storing soil in a temporary stockpile or pit is not considered treatment. Co-mingling, blending, or mixing of soil lots is not considered treatment.
 - ii. If these test results indicate that the soil, as received at this site, has an organic content of 50 ppmw or less, then the soil may be considered to be not contaminated and need not be handled in accordance with Regulation 8, Rule 40 any longer.
- (basis: Regulations 2-1-403 and 8-40-301)

VI. Permit Conditions

Condition # 17821

FOR: S-15, ACTIVE LANDFILL WITH LANDFILL GAS COLLECTION SYSTEM; AND A-8, LANDFILL GAS FLARE

3. The Permit Holder shall limit the quantity of low VOC soil (soil that contains 50 ppmw or less of VOCs) disposed of per day so that no more than 15 pounds of total carbon could be emitted to the atmosphere per day. In order to demonstrate compliance with this condition, the Permit Holder shall maintain the following records in a District approved log.
 - a. Record on a daily basis the amount of low VOC soil disposed of in the landfill or used as cover material in the landfill. This total amount (in units of pounds per day) is Q in the equation in subpart c. below.
 - b. Record on a daily basis the VOC content of all low VOC soils disposed of or used as cover material. This VOC Content (C in the equation below) should be expressed as parts per million by weight as total carbon (or C₁).
 - c. Calculate and record on a daily basis the VOC Emission Rate (E) using the following equation:
$$E = Q * C / 1 E 6$$

(basis: Regulation 8-2-301)
4. Water and/or dust suppressants shall be applied to all unpaved roadways and active soil removal and fill areas associated with this landfill as necessary to prevent visible particulate emissions. Paved roadways at the facility shall be kept sufficiently clear of dirt and debris as necessary to prevent visible particulate emissions from vehicle traffic or wind. (basis: Regulations 2-1-403, 6-301, and 6-305)
5. All collected landfill gas shall be vented to properly operating abatement equipment including the Internal Combustion Engines (S-5, S-6, and S-37) or the Landfill Gas Flare (A-8). Raw landfill gas shall not be vented to the atmosphere, except for unavoidable landfill gas emissions that occur during collection system installation, maintenance, or repair that is performed in compliance with Regulation 8, Rule 34, Sections 113, 116, 117, or 118 and for inadvertent component or surface leaks that do not exceed the limits specified in 8-34-301.2 or 8-34-303. (basis: Regulation 8-34-301)
6. The Permit Holder shall apply for and receive an Authority to Construct before modifying the landfill gas collection system described in Part 6a below. Increasing or decreasing the number of wells or collectors, or significantly changing the length of collectors, or the locations of wells or collectors are all considered to be modifications that are subject to the Authority to Construct requirement.

VI. Permit Conditions

Condition # 17821

FOR: S-15, ACTIVE LANDFILL WITH LANDFILL GAS COLLECTION SYSTEM; AND A-8, LANDFILL GAS FLARE

- a. The Permit Holder has been issued a Permit to Operate for the landfill gas collection system components listed below. Well and collector locations, depths, and lengths are as described in detail in Permit Application # 2417.

| | Required Components |
|--|---------------------|
| Total Number of Vertical Wells: | 53 |
| Total Number of Horizontal Collectors: | 16 |

(basis: Regulations 2-1-301, 8-34-301.1, 8-34-304, 8-34-305)

7. The landfill gas collection system described in Part 6a shall be operated continuously. Wells shall not be shut off, disconnected or removed from operation without written authorization from the District, unless the Permit Holder complies with all applicable requirements of Regulation 8, Rule 34, Sections 113, 116, 117, and 118. (basis: Regulation 8-34-301.1)
8. The A-8 Landfill Gas Flare shall be operated when one or more engines (S-5, S-6, or S-37) are not operating. The Heat Input to the A-8 Landfill Gas Flare shall not exceed 1,188 million BTU per day nor 433,693 million BTU per year. In order to demonstrate compliance with this part, the Permit Holder shall calculate and record on a monthly basis the maximum daily and total monthly heat input to the flare based on the landfill gas flow rate recorded pursuant to part 14, the average methane concentration in the landfill gas based on the most recent source test, and a high heating value for methane of 1013 BTU/ft³ at 60 degrees F. (basis: Cumulative Increase and Regulation 2-1-301)
9. The combustion zone temperature of the A-8 Landfill Gas Flare shall be maintained at a minimum of 1400 degrees Fahrenheit, averaged over any 3-hour period. If a source test demonstrates compliance with all applicable requirements at a different temperature, the APCO may revise this minimum temperature limit in accordance with the procedures identified in Regulation 2-6-414 or 2-6-415, based on the following criteria. The minimum combustion zone temperature for the flare shall be equal to the average combustion zone temperature determined during the most recent complying source test minus 50 degrees F, provided that the minimum combustion zone temperature is not less than 1400 degrees F. (basis: Toxic Risk Management Policy and Regulation 8-34-301.3)

VI. Permit Conditions

Condition # 17821

FOR: S-15, ACTIVE LANDFILL WITH LANDFILL GAS COLLECTION SYSTEM; AND A-8, LANDFILL GAS FLARE

10. Total reduced sulfur compounds in the collected landfill gas shall be monitored as a surrogate for monitoring sulfur dioxide in control system's exhaust. The concentration of total reduced sulfur compounds in the collected landfill gas shall not exceed 300 ppmv (dry). In order to demonstrate compliance with this part, the Permit Holder shall measure the total sulfur content in collected landfill gas on a quarterly basis using a draeger tube. The landfill gas sample shall be taken from the main landfill gas header. The Permit Holder shall follow the manufacturer's recommended procedures for using the draeger tube and interpreting the results. The Permit Holder shall conduct the first draeger tube test no later than 3 months after the issue date of the MFR Permit and quarterly thereafter. (basis: Regulation 9-1-302, Cumulative Increase)

11. In order, to demonstrate compliance with Regulation 8, Rule 34, Sections 301.3 and 412, the Permit Holder shall ensure that a District approved source test is conducted annually on the Landfill Gas Flare (A-8). As a minimum, the annual source test shall determine the following:
 - a. landfill gas flow rate to the flare (dry basis);
 - b. concentrations (dry basis) of carbon dioxide (CO₂), nitrogen (N₂), oxygen (O₂), methane (CH₄), and total non-methane organic compounds (NMOC) in the landfill gas;
 - c. stack gas flow rate from the flare (dry basis);
 - d. concentrations (dry basis) of NO_x, CO, SO₂, NMOC, Benzene, Formaldehyde, Vinyl Chloride, and O₂ in the flare stack gas;
 - e. NMOC destruction efficiency achieved by the flare; and
 - f. the average combustion temperature in the flare during the test period.The first annual source test shall be conducted by no later than October 1, 2002. Subsequent source tests shall be conducted no sooner than 9 months and no later than 12 months after the previous source test. The Source Test Section of the District shall be contacted to obtain their approval of the source test procedures at least 14 days in advance of each source test. They shall be notified of the scheduled test date at least 7 days in advance of each source test. The source test report shall be submitted to the Compliance and Enforcement Division within 45 days of the test date. (basis: Regulations 8-34-301.3 and 8-34-412)

VI. Permit Conditions

Condition # 17821

**FOR: S-15, ACTIVE LANDFILL WITH LANDFILL GAS COLLECTION SYSTEM; AND
A-8, LANDFILL GAS FLARE**

12. The Permit Holder shall conduct a characterization of the landfill gas concurrent with the annual source test required by part 11 above. The landfill gas sample shall be drawn from the main landfill gas header. In addition to the compounds listed in part 11b, the landfill gas shall be analyzed for all the organic compounds listed below. All concentrations shall be reported on a dry basis. The test report shall be submitted to the Compliance and Enforcement Division within 45 days of the test date. (basis: Toxic Risk Management Policy, AB-2588 Air Toxics Hot Spots Act, and Regulation 8-34-412)

Organic Compounds

acrylonitrile
benzene
benzyl chloride
1,3 butadiene
carbon tetrachloride
chlorobenzene
chlorodifluoromethane
chloroform
1,1 dichloroethane
1,1 dichlorethene
1,2 dichloroethane
1,4 dichlorobenzene
dichlorodifluoromethane
dichlorofluoromethane
1,4 dioxane

Organic Compounds

ethylbenzene
ethylene dibromide
fluorotrichloromethane
hexane
isopropyl alcohol
methyl ethyl ketone
methyl tert butyl ether
methylene chloride
perchloroethylene
styrene
toluene
1,1,1 trichloroethane
1,1,2,2 tetrachloroethane
trichloroethylene
vinyl chloride
xylenes

VI. Permit Conditions

Condition # 17821

FOR: S-15, ACTIVE LANDFILL WITH LANDFILL GAS COLLECTION SYSTEM; AND A-8, LANDFILL GAS FLARE

- *13. If the concentrations (dry basis) of toxic air contaminants in the collected landfill gas exceed any of the limits listed below, the Permit Holder shall submit a permit application for a Change of Permit Conditions within 30 days of receiving the test results.

| | | | |
|-------------------|---|-------|------|
| Benzene | = | 8.9 | ppmv |
| Chlorobenzene | = | 1.5 | ppmv |
| Trichloroethylene | = | 0.873 | ppmv |
| Ethylbenzene | = | 41 | ppmv |
| Vinyl Chloride | = | 6.4 | ppmv |
| Xylene | = | 78 | ppmv |
| Toluene | = | 110 | ppmv |
| Perchloroethylene | = | 4 | ppmv |

(basis: Toxic Risk Management Policy and AB-2588 Air Toxics Hot Spots Act)

14. In order to demonstrate compliance with the above conditions, the Permit Holder shall maintain the following records in a District approved logbook.
- Record the total amount of municipal solid waste received at S-15 on a daily basis. Summarize the daily waste acceptance records for each calendar month.
 - For each area or cell that is not controlled by a landfill gas collection system, maintain a record of the date that waste was initially placed in the area or cell. Record the cumulative amount of waste placed in each uncontrolled area or cell on a monthly basis.
 - If the Permit Holder plans to exclude an uncontrolled area or cell from the collection system requirement, the Permit Holder shall also record the types and amounts of all non-decomposable waste placed in the area and the percentage (if any) of decomposable waste placed in the area.
 - Maintain daily records of low VOC soil acceptance rate and emissions, pursuant to part 3.
 - Record of the dates, locations, and frequency per day of all watering activities on unpaved roads or active soil or fill areas. Record the dates, locations, and type of any dust suppressant applications. Record the dates and description of all paved roadway cleaning activities. All records shall be summarized on monthly basis.
 - Record the initial operation date for each new landfill gas well and collector.

VI. Permit Conditions

Condition # 17821

FOR: S-15, ACTIVE LANDFILL WITH LANDFILL GAS COLLECTION SYSTEM; AND A-8, LANDFILL GAS FLARE

- g. Maintain an accurate map of the landfill, which indicates the locations of all refuse boundaries and the locations of all wells and collectors (using unique identifiers) that are required to be operating continuously pursuant to part 6.a. Any areas containing only non-decomposable waste shall be clearly identified. This map shall be updated at least once a year to indicate changes in refuse boundaries and to include any newly installed wells and collectors.
- h. Record the operating times and the landfill gas flow rate to the A-8 Landfill Gas Flare on a daily basis. Summarize these records on a monthly basis. Calculate and record the heat input to A-8, pursuant to part 8.
- i. Maintain continuous records of the combustion zone temperature for the A-8 Landfill Gas Flare during all hours of operation.
- j. Maintain records of all test dates and test results performed to maintain compliance parts 10, 11, and 12 above or to maintain compliance with any applicable rule or regulation.

All records shall be maintained on site or shall be made readily available to District staff upon request for a period of at least 5 years from the date of entry. These record keeping requirements do not replace the record keeping requirements contained in any applicable rules or regulations.

(basis: Cumulative Increase, 2-1-301, 2-6-501, 6-301, 6-305, 8-2-301, 8-34-301, 8-34-304, and 8-34-501)

- 15. The annual report required by BAAQMD Regulation 8-34-411 shall be submitted in two semi-annual increments. The reporting periods and report submittal due dates for the semi-annual increments of the Regulation 8-34-411 report and the MSW Landfill NESHAP report, which is required pursuant to 40 CFR Part 63.1980(a), shall be synchronized with the reporting periods and report submittal due dates for the semi-annual MFR Permit monitoring reports that are required by Section I.F of the MFR Permit for this site. A single report may be submitted to satisfy the requirements of Section I.F, Regulation 8-34-411, and 40 CFR Part 63.1980(a), provided that all items required by each applicable reporting requirement are included in the single report.
(Basis: Regulation 8-34-411 and 40 CFR Part 63.1980(a))

VI. Permit Conditions

Condition # 20754

FOR: S-46 HAZARDOUS WASTE MANAGEMENT FACILITY WITH GAS COLLECTION SYSTEM AND A-11 LANDFILL GAS FLARE FOR HWMF

1. The S-46 Hazardous Waste Management Facility (HWMF) is inactive. The Permit Holder shall apply for and receive a Change of Permit Conditions before accepting any solid waste for disposal at S-46. The total cumulative amount of all decomposable wastes placed in the HWMF shall not exceed 210,700 tons. (Basis: Regulation 2-1-301)
2. The Permit Holder has been issued an Authority to Construct for 19 horizontal collectors. Specific locations, depths, and lengths of associated piping are as described in detail in Permit Application # 2789. The Permit Holder shall apply for and receive an Authority to Construct before modifying this gas collection system. Increasing or decreasing the number of wells or collectors, or significantly changing the length of collectors, or the locations of wells or collectors are all considered to be modifications that are subject to the Authority to Construct requirement. Upon start-up of the A-11 Landfill Gas Flare, this gas collection system shall be operated continuously. Wells shall not be shut off, disconnected or removed from operation without written authorization from the District, unless the Permit Holder complies with all applicable requirements of Regulation 8, Rule 34, Sections 113, 116, 117, and 118. (Basis: Regulations 2-1-301 and 8-34-301.1)
3. Upon start-up of A-11, all collected landfill gas shall be vented to the properly operating A-11 Landfill Gas Flare. Raw landfill gas shall not be vented to the atmosphere, except for unavoidable landfill gas emissions that occur during collection system installation, maintenance, or repair that is performed in compliance with Regulation 8, Rule 34, Sections 113, 116, 117, or 118 and for inadvertent component or surface leaks that do not exceed the limits specified in 8-34-301.2 or 8-34-303. (Basis: Regulations 2-1-301 and 8-34-301)
4. The combustion zone temperature of the A-11 Landfill Gas Flare shall be maintained at a minimum of 1400 degrees Fahrenheit, averaged over any 3-hour period. If a source test demonstrates compliance with all applicable requirements at a different temperature, the APCO may revise this minimum temperature limit in accordance with the procedures identified in Regulation 2-6-414 or 2-6-415, based on the following criteria. The minimum combustion zone temperature for the flare shall be equal to the average combustion zone temperature determined during the most recent complying source test minus 50 degrees F, provided that the minimum combustion zone temperature is not less than 1400 degrees F. (Basis: Toxic Risk Management Policy and Regulation 8-34-301.3)

VI. Permit Conditions

Condition # 20754

FOR: S-46 HAZARDOUS WASTE MANAGEMENT FACILITY WITH GAS COLLECTION SYSTEM AND A-11 LANDFILL GAS FLARE FOR HWMF

5. Nitrogen Oxide (NO_x) emissions from A-11 shall not exceed 0.06 pounds of NO_x (calculated as NO₂) per million BTU. The Permit Holder may demonstrate compliance with this emission rate limit by having a nitrogen oxide concentration in the flare exhaust of no more than 15 ppmv of NO_x, corrected to 15% oxygen, dry basis. (Basis: RACT and Cumulative Increase)
6. Carbon Monoxide (CO) emissions from A-11 shall not exceed 0.30 pounds of CO per million BTU. The Permit Holder may demonstrate compliance with this emission rate limit by having a carbon monoxide concentration in the flare exhaust of no more than 122 ppmv of CO, corrected to 15% oxygen, dry basis. (Basis: RACT and Cumulative Increase)
7. The concentration of total reduced sulfur compounds in the landfill gas vented to A-11 shall not exceed 150 ppmv, expressed as H₂S, dry basis. (Basis: RACT and Cumulative Increase)
8. In order, to demonstrate compliance with Regulation 8, Rule 34, Sections 301.3 and 412 and Parts 5 and 6 above, the Permit Holder shall ensure that a District approved source test is conducted on the A-11 Landfill Gas Flare, within 60 days of initial start-up of A-11 and annually thereafter. As a minimum, the source tests shall determine the following:
 - a. landfill gas flow rate to the flare (dry basis);
 - b. concentrations (dry basis) of carbon dioxide (CO₂), nitrogen (N₂), oxygen (O₂), methane (CH₄), and total non-methane organic compounds (NMOC) in the landfill gas;
 - c. stack gas flow rate from the flare (dry basis);
 - d. concentrations (dry basis) of NO_x, CO, NMOC, and O₂ in the flare stack gas;
 - e. NMOC destruction efficiency achieved by the flare; and
 - f. the average combustion temperature in the flare during the test period.The Source Test Section of the District shall be contacted to obtain their approval of the source test procedures at least 14 days in advance of each source test. The Source Test Section shall be notified of the scheduled test date at least 7 days in advance of each source test. The source test report shall be submitted to the Compliance and Enforcement Division within 45 days of the test date. (Basis: Regulations 8-34-301.3 and 8-34-412, RACT, and Cumulative Increase)

VI. Permit Conditions

Condition # 20754

FOR: S-46 HAZARDOUS WASTE MANAGEMENT FACILITY WITH GAS COLLECTION SYSTEM AND A-11 LANDFILL GAS FLARE FOR HWMF

9. The Permit Holder shall conduct a characterization of the landfill gas concurrent with the annual source test required by Part 8 above. The landfill gas sample shall be drawn from the HWMF landfill gas header. In addition to the compounds listed in part 8b, the landfill gas shall be analyzed for all the organic compounds and sulfur compounds listed below. All concentrations shall be reported on a dry basis. The test report shall be submitted to the Compliance and Enforcement Division within 45 days of the test date. (Basis: Toxic Risk Management Policy, AB-2588 Air Toxics Hot Spots Act, and Regulations 8-34-412 and 9-1-302)

Organic Compounds

acrylonitrile
benzene
benzyl chloride
carbon tetrachloride
chlorobenzene
chlorodifluoromethane
chloroethane
chloroform
1,1 dichloroethane
1,1 dichlorethene
1,2 dichloroethane
1,4 dichlorobenzene
dichlorodifluoromethane
dichlorofluoromethane
ethylbenzene
ethylene dibromide
fluorotrichloromethane
hexane
isopropyl alcohol
methyl ethyl ketone
methylene chloride
perchloroethylene
toluene
1,1,1 trichloroethane
1,1,2,2 tetrachloroethane
trichloroethylene
vinyl chloride
xylenes

VI. Permit Conditions

Condition # 20754

FOR: S-46 HAZARDOUS WASTE MANAGEMENT FACILITY WITH GAS COLLECTION SYSTEM AND A-11 LANDFILL GAS FLARE FOR HWMF

Sulfur Compounds
hydrogen sulfide
carbon disulfide
carbonyl sulfide
dimethyl sulfide
ethyl mercaptan
methyl mercaptan

- *10. If the concentrations (dry basis) of toxic air contaminants in the collected landfill gas exceed any of the limits listed below, the Permit Holder shall submit a permit application for a Change of Permit Conditions within 30 days of receiving the test results.

| | | |
|----------------|---|-----------|
| Acrylonitrile | = | 6.3 ppmv |
| Benzene | = | 4.4 ppmv |
| Vinyl Chloride | = | 90.4 ppmv |

(Basis: Toxic Risk Management Policy and AB-2588 Air Toxics Hot Spots Act)

11. In order to demonstrate compliance with the above conditions, the Permit Holder shall maintain the following records in a District approved logbook.
- record the initial start-up date for each collector in the HWMF collection system,
 - record the initial start-up date for the A-11 Landfill Gas Flare,
 - record the dates, times, durations, and reasons for each shut-down of (i) an individual collector, (ii) the entire collection system, or (iii) the A-11 Flare.
 - maintain records of the test dates and the test results for any tests conducted to demonstrate compliance with these permit conditions.

(Basis: Regulations 2-1-301, 8-34-501, and 2-6-501)

12. The annual report for the S-46 HWMF, which is required by BAAQMD Regulation 8-34-411 and 40 CFR Part 63.1980(a), shall be combined with the annual report for the S-15 Landfill and shall be submitted in accordance with the schedule identified in Condition # 17821, Part 15. (Basis: Regulation 8-34-411 and 40 CFR Part 63.1980(a))

VI. Permit Conditions

Condition # 22792 effective upon start-up

FOR: S-50 SOLID WASTE TRANSFER STATION AND A-50 WATER MIST SYSTEM

1. The total quantity of waste accepted at the waste transfer station, S50, shall not exceed 2000 tons per day or 730,000 tons in any consecutive twelve month period. (Basis: Cumulative Increase)
2. Wastes (mixed wastes, green material and wood wastes) shall be removed from the transfer station within 48 hours after being received at the facility. (Basis: Regulation 1-301)
3. Visible particulate emissions from the operations at S50 shall not exceed Ringelmann 1.0 or result in fallout on neighboring property. (Basis: Regulation 6-301, 6-305, Regulation 1-301)
4. Water and/or dust suppressants shall be applied to all on-site unpaved roadways as necessary to prevent visible particulate emissions. Paved roadways at the facility shall be kept sufficiently clear of dirt and debris as necessary to prevent visible particulate emissions from vehicle traffic or wind. (Basis: Regulations 6-301, and 6-305)
5. Until the owner/operator ceases to accept waste at the landfill source, S15, the sum total of the number of vehicle trips per day to S15 and the number of vehicle trips per day to S50 shall not exceed 601 vehicle trips per day. (Basis: Cumulative increase)
6. Upon termination of waste acceptance at S15, the maximum number of vehicle trips per day to S50 may increase to, but not exceed, 715 vehicle trips per day. Within 10 working days following the termination of waste acceptance at S15, the owner/operator shall submit to the District written confirmation that waste is no longer accepted at S15. (Basis: Cumulative increase)
7. The owner/operator shall maintain records of waste throughput, vehicle route maintenance events (cleaning of paved roads and application of water or dust suppressants on unpaved roads), the number of vehicle trips per day to S15 and the number of vehicle trips per day to S50 in a District-approved log. These records shall be retained on site for a minimum of five years from the date of entry and shall be made available to the District representatives upon request. (Basis: Cumulative Increase, Regulations 2-6-501, and 6-305)

VII. APPLICABLE LIMITS & COMPLIANCE MONITORING REQUIREMENTS

This section has been included only to summarize the applicable emission limits contained in Section IV, Source-Specific Applicable Requirements, of this permit. The following tables show the relationship between each emission limit and the associated compliance monitoring provisions, if any. The monitoring frequency column indicates whether periodic (P) or continuous (C) monitoring is required. For periodic monitoring, the frequency of the monitoring has also been shown, using the following codes: annual (A), quarterly (Q), monthly (M), weekly (W), daily (D), or on an event basis (E). No monitoring (N) has been required if the current applicable rule or regulation does not require monitoring, and the operation is unlikely to deviate from the applicable emission limit based upon the nature of the operation.

Table VII – A
Applicable Limits and Compliance Monitoring Requirements
S-5 INTERNAL COMBUSTION LEAN BURN ENGINE; AND
S-6 INTERNAL COMBUSTION LEAN BURN ENGINE

| Type of Limit | Citation of Limit | FE Y/N | Future Effective Date | Limit | Monitoring Requirement Citation | Monitoring Frequency (P/C/N) | Monitoring Type |
|--|---|--------|-----------------------|---|--|------------------------------|---|
| Opacity | BAAQMD 6-301 | Y | | Ringelmann No. 1 for < 3 minutes/hr | None | N | NA |
| FP | BAAQMD 6-310 | Y | | 0.15 grains/dscf | None | N | NA |
| TOC (Total Organic Compounds Plus Methane) | BAAQMD 8-34-301.2 | Y | | 1000 ppmv as methane (component leak limit) | BAAQMD 8-34-501.6 and 8-34-503 | P/Q | Quarterly Inspection and Records |
| Non-Methane Organic Compounds (NMOC) | BAAQMD 8-34-301.4 and BAAQMD Condition # 5771, Part 6 | Y | | 98% removal by weight OR < 120 ppmv, dry basis @ 3% O ₂ , expressed as methane | BAAQMD 8-34-412 and 8-34-501.4 and BAAQMD Condition # 5771, Part 7 | P/A | Initial and Annual Source Tests and Records |

VII. Applicable Limits and Compliance Monitoring Requirements

Table VII – A
Applicable Limits and Compliance Monitoring Requirements
S-5 INTERNAL COMBUSTION LEAN BURN ENGINE; AND
S-6 INTERNAL COMBUSTION LEAN BURN ENGINE

| Type of Limit | Citation of Limit | FE Y/N | Future Effective Date | Limit | Monitoring Requirement Citation | Monitoring Frequency (P/C/N) | Monitoring Type |
|------------------|---------------------------------|--------|-----------------------|--|---|------------------------------|--|
| NMOC | 40 CFR 60.752(b)(2)(iii)(B) | Y | | 98% removal by weight OR < 20 ppmv dry @ 3% O ₂ , expressed as hexane | 40 CFR 60.8 and 60.752(b)(2)(iii)(B) and 60.758(b)(2) | P/I | Initial Source Test and Records |
| SO ₂ | BAAQMD 9-1-301 | Y | | Property Line Ground Level Limits ≤ 0.5 ppm for 3 minutes, ≤ 0.25 ppm for 60 minutes, and ≤ 0.05 ppm for 24 hours | None | N | NA |
| SO ₂ | BAAQMD 9-1-302 | Y | | ≤ 300 ppm (dry) | BAAQMD Condition # 17821, Part 10 and BAAQMD Condition # 5771, Part 7 | P/Q and P/A | Quarterly Sulfur Analysis of Landfill Gas and Annual Source Test |
| H ₂ S | BAAQMD 9-2-301 | N | | Property Line ground level limits ≤ 0.06 ppm Averaged over 3 minutes and ≤ 0.03 ppm Averaged over 60 minutes | None | N | NA |
| NO _x | BAAQMD 9-8-302.1 | Y | | Waste Fuel Gas, Lean-Burn ≤ 140 ppmv, dry basis @ 15% O ₂ | BAAQMD Condition # 5771, Part 7 | P/A | Annual Source Test |
| NO _x | BAAQMD Condition # 5771, Part 4 | Y | | ≤ 63 ppmv, dry basis @ 15% O ₂ | BAAQMD Condition # 5771, Part 7 | P/A | Annual Source Test |
| CO | BAAQMD 9-8-302.3 | Y | | Waste Fuel Gas: ≤ 2000 ppmv, dry basis @ 15% O ₂ | BAAQMD Condition # 5771, Part 7 | P/A | Annual Source Test |

VII. Applicable Limits and Compliance Monitoring Requirements

Table VII – A
Applicable Limits and Compliance Monitoring Requirements
S-5 INTERNAL COMBUSTION LEAN BURN ENGINE; AND
S-6 INTERNAL COMBUSTION LEAN BURN ENGINE

| Type of Limit | Citation of Limit | FE Y/N | Future Effective Date | Limit | Monitoring Requirement Citation | Monitoring Frequency (P/C/N) | Monitoring Type |
|---------------------------------------|---------------------------------|--------|-----------------------|--|---|------------------------------|---|
| CO | BAAQMD Condition # 5771, Part 5 | Y | | ≤ 376 ppmv, dry basis @ 15% O ₂ | BAAQMD Condition # 5771, Part 7 | P/A | Annual Source Test |
| Heat Input | BAAQMD Condition # 5771, Part 8 | Y | | 285.6 MM BTU per day (each engine) and 104,250 MM BTU per year (each engine) | BAAQMD Condition # 5771, Parts 3 and 9 | C | Gas Flow Meter and Recorder and Records |
| Gas Flow | BAAQMD 8-34-301 and 301.1 | Y | | Vent all collected gases to a properly operating control system and operate control system continuously. | BAAQMD 8-34-501.10 and 508 | C | Gas Flow Meter and Recorder (every 15 minutes) |
| Gas Flow | BAAQMD Condition # 5771, Part 2 | Y | | Upon shut down of an engine (S-5 or S-6), automatically divert excess collected gas the A-8 Flare | BAAQMD Condition # 5771, Part 3 | C | Gas Flow Meter and Recorder |
| Gas Flow | 40 CFR 60.753(a) and (e) | Y | | Vent all collected gases to a properly operating control system and operate control system at all times when gas is vented to it | 40 CFR 60.756(b)(2) (i or ii) and 60.758(c)(2) | C and P/M | Gas Flow Meter and Recorder (every 15 minutes) or Monthly Inspection of Bypass Valve & Lock and Records |
| Emission Control System Shutdown Time | BAAQMD 8-34-113.2 | Y | | 240 hours/year | BAAQMD 8-34-501.2 and BAAQMD Condition # 5771, Part 9 | P/D | Records |

VII. Applicable Limits and Compliance Monitoring Requirements

Table VII – A
Applicable Limits and Compliance Monitoring Requirements
S-5 INTERNAL COMBUSTION LEAN BURN ENGINE; AND
S-6 INTERNAL COMBUSTION LEAN BURN ENGINE

| Type of Limit | Citation of Limit | FE Y/N | Future Effective Date | Limit | Monitoring Requirement Citation | Monitoring Frequency (P/C/N) | Monitoring Type |
|---|----------------------------------|--------|-----------------------|--|--|------------------------------|---|
| Emission Control System Startup Shutdown or Malfunction | 40 CFR 60.755(e) | Y | | ≤ 1 hour per event | 40 CFR 60.7(b), 60.757(f)(2) and (f)(3), and 60.758(e) | P/D | Records of occurrence and duration |
| Startup Shutdown or Malfunction Procedures | 40 CFR 63.6(e) | Y | | Minimize Emissions by Implementing SSM Plan | 40 CFR 63.1980(a-b) | P/E | Records (all occurrences, duration of each, corrective actions) |
| Engine Cylinder or Exhaust Temperature | BAAQMD Condition # 5771, Part 10 | Y | | To be established during first source test conducted after permit issuance | BAAQMD 8-34-507 and 8-34-509 | C | Temperature sensor and continuous recorder |
| Periods of Inoperation for Parametric Monitors | BAAQMD 1-523.2 | Y | | 15 consecutive days/incident and 30 calendar days/12 month period | BAAQMD 1-523.4 | P/D | Records of occurrence and duration |
| Continuous Monitors | 40 CFR 60.13(e) | Y | | Requires Continuous Operation except for breakdowns, repairs, calibration, and required span adjustments | 40 CFR 60.7(b) | P/D | Records of occurrence and duration |

VII. Applicable Limits and Compliance Monitoring Requirements

Table VII – B
Applicable Limits and Compliance Monitoring Requirements
S-15 WEST CONTRA COSTA SANITARY LANDFILL; AND
A-8 LANDFILL GAS FLARE

| Type of Limit | Citation of Limit | FE Y/N | Future Effective Date | Limit | Monitoring Requirement Citation | Monitoring Frequency (P/C/N) | Monitoring Type |
|--------------------------------------|--|--------|-----------------------|---|---|------------------------------|-----------------|
| Collection System Installation Dates | BAAQMD 8-34-304.1 | Y | | For Inactive/Closed Areas: collection system components must be installed and operating by 2 years + 60 days after initial waste placement | BAAQMD 8-34-501.7 and 501.8 and BAAQMD Condition # 17821, Parts 14b-c and 14f-g | P/E | Records |
| Collection System Installation Dates | BAAQMD 8-34-304.2 | Y | | For Active Areas: Collection system components must be installed and operating by 5 years + 60 days after initial waste placement | BAAQMD 8-34-501.7 and 501.8 and BAAQMD Condition # 17821, Parts 14b-c and 14f-g | P/E | Records |
| Collection System Installation Dates | BAAQMD 8-34-304.3 | Y | | For Any Uncontrolled Areas or Cells: collection system components must be installed and operating within 60 days after the uncontrolled area or cell accumulates 1,000,000 tons of decomposable waste | BAAQMD 8-34-501.7 and 501.8 and BAAQMD Condition # 17821, Parts 14a-c and 14f-g | P/E | Records |
| Collection System Installation Dates | 40 CFR 60.753 (a)(2) and 60.755 (b)(2) | Y | | For Inactive/Closed Areas: collection system components must be installed and operating by 2 years + 60 days after initial waste placement | 40 CFR 60.758(a), (d)(1) and (d)(2), and 60.759(a)(3) | P/E | Records |

VII. Applicable Limits and Compliance Monitoring Requirements

Table VII – B
Applicable Limits and Compliance Monitoring Requirements
S-15 WEST CONTRA COSTA SANITARY LANDFILL; AND
A-8 LANDFILL GAS FLARE

| Type of Limit | Citation of Limit | FE Y/N | Future Effective Date | Limit | Monitoring Requirement Citation | Monitoring Frequency (P/C/N) | Monitoring Type |
|--------------------------------------|---|--------|-----------------------|--|---|------------------------------|---|
| Collection System Installation Dates | 40 CFR 60.753 (a)(1) and 60.755 (b)(1) | Y | | For Active Areas: Collection system components must be installed and operating by 5 years + 60 days after initial waste placement | 40 CFR 60.758(a), (d)(1) and (d)(2) | P/E | Records |
| Gas Flow | BAAQMD 8-34-301 and 301.1 | Y | | Landfill gas collection system shall operate continuously and all collected gases shall be vented to a properly operating control system | BAAQMD 8-34-501.10 and 508 | C | Gas Flow Meter and Recorder (every 15 minutes) |
| Gas Flow | BAAQMD Condition # 17821, Parts 5, 6, and 7 | Y | | Landfill gas collection system shall operate continuously and all collected gases shall be vented to a properly operating control system | BAAQMD Condition # 5771, Part 9; BAAQMD Condition # 17812, Part 11; and BAAQMD Condition # 17821, Parts 14f-h | P/D | Records of Landfill Gas Flow Rates, Collection and Control Systems Downtime, and Collection System Components |
| Gas Flow | 40 CFR 60.753(a) and (e) | Y | | Operate a Collection System in each area or cell and vent all collected gases to a properly operating control system | 40 CFR 60.756(b)(2) (i or ii) and 60.758(c)(2) | C or P/M | Gas Flow Meter and Recorder (every 15 minutes) or Monthly Inspection of Bypass Valve and Lock and Records |

VII. Applicable Limits and Compliance Monitoring Requirements

Table VII – B
Applicable Limits and Compliance Monitoring Requirements
S-15 WEST CONTRA COSTA SANITARY LANDFILL; AND
A-8 LANDFILL GAS FLARE

| Type of Limit | Citation of Limit | FE Y/N | Future Effective Date | Limit | Monitoring Requirement Citation | Monitoring Frequency (P/C/N) | Monitoring Type |
|---|-------------------|--------|-----------------------|--|---|------------------------------|---|
| Collection and Control Systems Shutdown Time | BAAQMD 8-34-113.2 | Y | | 240 hours/year nor 5 consecutive days | BAAQMD 8-34-501.1 | P/D | Operating Records |
| Collection and Control System Startup Shutdown or Malfunction | 40 CFR 60.755(e) | Y | | 5 days per event for collection system and 1 hour per event for control system | 40 CFR 60.7(b), 60.757(f)(2), (f)(3) and (f)(4) | P/D | Operating Records (all occurrences and duration of each) |
| Startup Shutdown or Malfunction Procedures | 40 CFR 63.6(e) | Y | | Minimize Emissions by Implementing SSM Plan | 40 CFR 63.1980(a-b) | P/E | Records (all occurrences, duration of each, corrective actions) |
| Periods of Inoperation for Parametric Monitors | BAAQMD 1-523.2 | Y | | 15 consecutive days/incident and 30 calendar days/12 month period | BAAQMD 1-523.4 | P/D | Operating Records for All Parametric Monitors |
| Continuous Monitors | 40 CFR 60.13(e) | Y | | Requires Continuous Operation except for breakdowns, repairs, calibration, and required span adjustments | 40 CFR 60.7(b) | P/D | Operating Records for All Continuous Monitors |
| Wellhead Pressure | BAAQMD 8-34-305.1 | Y | | < 0 psig | BAAQMD 8-34-414, 501.9 and 505.1 | P/M | Monthly Inspection and Records |

VII. Applicable Limits and Compliance Monitoring Requirements

Table VII – B
Applicable Limits and Compliance Monitoring Requirements
S-15 WEST CONTRA COSTA SANITARY LANDFILL; AND
A-8 LANDFILL GAS FLARE

| Type of Limit | Citation of Limit | FE Y/N | Future Effective Date | Limit | Monitoring Requirement Citation | Monitoring Frequency (P/C/N) | Monitoring Type |
|--------------------------------|----------------------------|--------|-----------------------|---|--|------------------------------|--------------------------------|
| Wellhead Pressure | 40 CFR 60.753(b) | Y | | < 0 psig | 40 CFR 60.755(a)(3), 60.756(a)(1), and 60.758(c) and (e) | P/M | Monthly Inspection and Records |
| Temperature of Gas at Wellhead | BAAQMD 8-34-305.2 | Y | | < 55 °C | BAAQMD 8-34-414, 501.9 and 505.2 | P/M | Monthly Inspection and Records |
| Temperature of Gas at Wellhead | 40 CFR 60.753(c) | Y | | < 55 °C | 40 CFR 60.755(a)(5), 60.756(a)(3), and 60.758(c) and (e) | P/M | Monthly Inspection and Records |
| Gas Concentrations at Wellhead | BAAQMD 8-34-305.3 or 305.4 | Y | | N ₂ < 20% OR O ₂ < 5% | BAAQMD 8-34-414, 501.9 and 505.3 or 505.4 | P/M | Monthly Inspection and Records |
| Gas Concentrations at Wellhead | 40 CFR 60.753(c) | Y | | N ₂ < 20% OR O ₂ < 5% | 40 CFR 60.755(a)(5), 60.756(a)(2), and 60.758(c) and (e) | P/M | Monthly Inspection and Records |
| Well Shutdown Limits | BAAQMD 8-34-116.2 | Y | | No more than 5 wells at a time or 10% of total collection system, whichever is less | BAAQMD 8-34-116.5 and 501.1 | P/D | Records |
| Well Shutdown Limits | BAAQMD 8-34-116.3 | Y | | 24 hours per well | BAAQMD 8-34-116.5 and 501.1 | P/D | Records |
| Well Shutdown Limits | BAAQMD 8-34-117.4 | Y | | No more than 5 wells at a time or 10% of total collection system, whichever is less | BAAQMD 8-34-117.6 and 501.1 | P/D | Records |

VII. Applicable Limits and Compliance Monitoring Requirements

Table VII – B
Applicable Limits and Compliance Monitoring Requirements
S-15 WEST CONTRA COSTA SANITARY LANDFILL; AND
A-8 LANDFILL GAS FLARE

| Type of Limit | Citation of Limit | FE Y/N | Future Effective Date | Limit | Monitoring Requirement Citation | Monitoring Frequency (P/C/N) | Monitoring Type |
|--|-------------------|--------|-----------------------|---|--|------------------------------|---|
| Well Shutdown Limits | BAAQMD 8-34-117.5 | Y | | 24 hours per well | BAAQMD 8-34-117.6 and 501.1 | P/D | Records |
| TOC (Total Organic Compounds Plus Methane) | BAAQMD 8-34-301.2 | Y | | 1000 ppmv as methane (component leak limit) | BAAQMD 8-34-501.6 and 503 | P/Q | Quarterly Inspection of collection and control system components with OVA and Records |
| TOC | BAAQMD 8-34-303 | Y | | 500 ppmv as methane at 2 inches above surface | BAAQMD 8-34-415, 416, 501.6, 506 and 510 | P/M, Q, and E | Monthly Visual Inspection of Cover, Quarterly Inspection with OVA of Surface, Various Reinspection Times for Leaking Areas, and Records |

VII. Applicable Limits and Compliance Monitoring Requirements

Table VII – B
Applicable Limits and Compliance Monitoring Requirements
S-15 WEST CONTRA COSTA SANITARY LANDFILL; AND
A-8 LANDFILL GAS FLARE

| Type of Limit | Citation of Limit | FE Y/N | Future Effective Date | Limit | Monitoring Requirement Citation | Monitoring Frequency (P/C/N) | Monitoring Type |
|--------------------------------------|----------------------------------|--------|-----------------------|--|--|------------------------------|---|
| TOC | 40 CFR 60.753(d) | Y | | <500 ppmv as methane at 5-10 cm from surface | 40 CFR 60.755(c)(1), (4) and (5), 60.756(f), and 60.758(c) and (e) | P/M, Q and E | Monthly Visual Inspection of Cover, Quarterly Inspection with Portable Analyzer of Surface, Various Reinspection Times for Leaking Areas, and Records |
| Non-Methane Organic Compounds (NMOC) | BAAQMD 8-34-301.3 | Y | | 98% removal by weight OR < 30 ppmv, dry basis @ 3% O ₂ , expressed as methane (applies to A-8 Flare only) | BAAQMD 8-34-412 and 8-34-501.4 and BAAQMD Condition # 17821, Part 11 | P/A | Initial and Annual Source Tests and Records |
| NMOC | 40 CFR 60.752(b)(2)(iii)(B) | Y | | 98% removal by weight OR < 20 ppmv dry @ 3% O ₂ , expressed as hexane (applies to A-8 Flare only) | 40 CFR 60.8 and 60.752(b)(2)(iii)(B) and 60.758(b)(2)(ii) | P/E | Initial Source Test and Records |
| Temperature of Combustion Zone (CT) | BAAQMD Condition # 17821, Part 9 | Y | | CT ≥ 1400 °F, averaged over any 3-hour period (applies to A-8 Flare only) | BAAQMD 8-34-501.3 and 507, and BAAQMD Condition# 17821, Part 14i | C | Temperature Sensor and Recorder (continuous) |

VII. Applicable Limits and Compliance Monitoring Requirements

Table VII – B
Applicable Limits and Compliance Monitoring Requirements
S-15 WEST CONTRA COSTA SANITARY LANDFILL; AND
A-8 LANDFILL GAS FLARE

| Type of Limit | Citation of Limit | FE Y/N | Future Effective Date | Limit | Monitoring Requirement Citation | Monitoring Frequency (P/C/N) | Monitoring Type |
|----------------------------|----------------------------------|--------|-----------------------|---|--|------------------------------|---|
| CT | 40 CFR 60.758 (c)(1)(i) | Y | | $CT \geq 1475 \text{ }^\circ\text{F}$ (3-hour average) from $(CT \geq CT_{PF} - 28 \text{ }^\circ\text{C})$, where CT_{PF} is the average combustion temperature during the most recent complying performance test (applies to A-8 Flare only) | 40 CFR 60.756(b)(1) and 60.758 (b)(2)(i) | C | Temperature Sensor and Recorder (measured every 15 minutes and averaged over 3 hours) |
| Total Carbon | BAAQMD 8-2-301 | Y | | 15 pounds/day or 300 ppm, dry basis (applies only to aeration of or use as cover soil of soil containing ≤ 50 ppmw of volatile organic compounds) | BAAQMD Condition # 17821, Part 3 | P/D | Records |
| Volatile Organic Compounds | BAAQMD Condition # 17821, Part 2 | N | | Facility shall not accept soil containing more than 50 ppmw of VOC | BAAQMD Condition # 17821, Part 2 | P/E | Records |
| Opacity | BAAQMD 6-301 | Y | | Ringelmann No. 1 for < 3 minutes/hr (applies to S-15 Landfill operations) | BAAQMD Condition #17821, Part 14i | P/E, M | Records of all site watering and road cleaning events |
| Opacity | BAAQMD 6-301 | Y | | Ringelmann No. 1 for < 3 minutes/hr (applies to A-8 Flare) | None | N | NA |
| FP | BAAQMD 6-310 | Y | | ≤ 0.15 grains/dscf (applies to A-8 Flare only) | None | N | NA |

VII. Applicable Limits and Compliance Monitoring Requirements

Table VII – B
Applicable Limits and Compliance Monitoring Requirements
S-15 WEST CONTRA COSTA SANITARY LANDFILL; AND
A-8 LANDFILL GAS FLARE

| Type of Limit | Citation of Limit | FE Y/N | Future Effective Date | Limit | Monitoring Requirement Citation | Monitoring Frequency (P/C/N) | Monitoring Type |
|--------------------------------------|-----------------------------------|--------|-----------------------|--|------------------------------------|------------------------------|---------------------------------|
| SO ₂ | BAAQMD 9-1-301 | Y | | Property Line Ground Level Limits: ≤ 0.5 ppm for 3 minutes and ≤ 0.25 ppm for 60 min. and ≤ 0.05 ppm for 24 hours | None | N | NA |
| SO ₂ | BAAQMD Regulation 9-1-302 | Y | | ≤ 300 ppm (dry basis) (applies to A-8 Flare only) | BAAQMD Condition # 17821, Part 10 | P/A | Source Test |
| Total Sulfur Content in Landfill Gas | BAAQMD Condition # 17821, Part 10 | Y | | ≤ 300 ppmv | BAAQMD Condition # 17821, Part 10 | P/Q | Sulfur analysis of landfill gas |
| H ₂ S | BAAQMD 9-2-301 | N | | Property Line Ground Level Limits: ≤ 0.06 ppm, averaged over 3 minutes and ≤ 0.03 ppm, averaged over 60 minutes | None | N | NA |
| Amount of Waste Accepted | BAAQMD Condition # 17821, Part 1 | Y | | ≤ 2500 tons/day and ≤ 13,000,000 tons (cumulative amount of all wastes) and ≤ 21,470,000 yd ³ (cumulative amount of all wastes and cover materials) | BAAQMD Condition # 17821, Part 14a | P/D | Records |
| Heat Input | BAAQMD Condition # 17821, Part 8 | Y | | ≤ 1,188 MM BTU per day and ≤ 433,693 MM BTU per year | BAAQMD Condition # 17821, Part 8 | P/D | Records |

VII. Applicable Limits and Compliance Monitoring Requirements

Table VII – B
Applicable Limits and Compliance Monitoring Requirements
S-15 WEST CONTRA COSTA SANITARY LANDFILL; AND
A-8 LANDFILL GAS FLARE

| Type of Limit | Citation of Limit | FE Y/N | Future Effective Date | Limit | Monitoring Requirement Citation | Monitoring Frequency (P/C/N) | Monitoring Type |
|------------------------|-----------------------------------|--------|-----------------------|------------------------------|-----------------------------------|------------------------------|------------------------------|
| Toxic Air Contaminants | BAAQMD Condition # 17821, Part 13 | N | | Benzene 8.9 ppmv | BAAQMD Condition # 17821, Part 12 | P/A | Annual Landfill Gas Analysis |
| | | | | Chlorobenzene 1.5 ppmv | | | |
| | | | | Trichloroethylene 0.873 ppmv | | | |
| | | | | Ethylbenzene 41 ppmv | | | |
| | | | | Vinyl Chloride 6.4 ppmv | | | |
| | | | | Xylene 78 ppmv | | | |
| | | | | Toluene 110 ppmv | | | |
| | | | | Perchloroethylene 0.4 ppmv | | | |

VII. Applicable Limits and Compliance Monitoring Requirements

Table VII – C
Applicable Limits and Compliance Monitoring Requirements
S-22 PRIMARY OIL/WATER SEPARATOR, TK-2;
S-23 SECONDARY OIL/WATER SEPARATOR, TK-4;
S-38 SECONDARY OIL/WATER SEPARATOR, TK-4;
A-1 CARBON ADSORBER; AND A-2 CARBON ADSORBER

| Type of Limit | Citation of Limit | FE Y/N | Future Effective Date | Limit | Monitoring Requirement Citation | Monitoring Frequency (P/C/N) | Monitoring Type |
|-------------------|---------------------------------|--------|-----------------------|--|--|------------------------------|---|
| Organic Compounds | BAAQMD 8-8-301.3 | Y | | combined collection and removal efficiency of at least 95% by weight | BAAQMD Condition # 7463, Parts 10a-c and 11a-e | P/D, W, M | Monthly, Weekly, or Daily FID Measurements at Carbon Adsorbers and Daily Records of Wastewater Throughput |
| Organic Compounds | BAAQMD 8-8-303 | Y | | all gauging and sampling devices shall have vapor tight covers, seals, or lids | None | N | NA |
| NMOC | BAAQMD Condition # 7463, Part 7 | Y | | carbon replacement upon detection of an outlet NMOC concentration (from A-1) that is 10% or more of the inlet NMOC concentration | BAAQMD Condition # 7463, Parts 10a, 10b, 11b, 11c, and 11e | P/D, W, M | Monthly, Weekly, or Daily FID Measurements at Carbon Adsorber (inlet and outlet) and Records |

VII. Applicable Limits and Compliance Monitoring Requirements

Table VII – C
Applicable Limits and Compliance Monitoring Requirements
S-22 PRIMARY OIL/WATER SEPARATOR, TK-2;
S-23 SECONDARY OIL/WATER SEPARATOR, TK-4;
S-38 SECONDARY OIL/WATER SEPARATOR, TK-4;
A-1 CARBON ADSORBER; AND A-2 CARBON ADSORBER

| Type of Limit | Citation of Limit | FE Y/N | Future Effective Date | Limit | Monitoring Requirement Citation | Monitoring Frequency (P/C/N) | Monitoring Type |
|--------------------------------|---------------------------------|--------|-----------------------|---|---|------------------------------|---|
| NMOC | BAAQMD Condition # 7463, Part 8 | Y | | carbon replacement upon detection of an outlet NMOC concentration (from A-2) of 6 ppmv | BAAQMD Condition # 7463, Parts 10c, 11b, 11d, and 11e | P/D, W, M | Monthly, Weekly, or Daily FID Measurement at Carbon Adsorber (outlet) and Records |
| POC | BAAQMD Condition # 7463, Part 6 | Y | | Leak Limit for Valves, Flanges, and Pumps of: 100 ppmv of POC above background at 1 cm from any component | None | N | NA |
| Waste-water Through-put Limits | BAAQMD Condition # 7463, Part 5 | Y | | 1,700 Gallons/Hour 40,800 Gallons/Day 14,892,000Gallons/Year | BAAQMD Condition # 7463, Part 11a | P/D | Records |

VII. Applicable Limits and Compliance Monitoring Requirements

Table VII – D
Applicable Limits and Compliance Monitoring Requirements
S-24 LOAD EQUALIZATION TANK, TK-7; S-25 PHOTO-OXIDIZER TANK, TK-5;
S-26 NEUTRALIZATION TANK, TK-9; S-27 FIRST STAGE CLARIFIER, TK-8;
S-28 AIR STRIPPER SUMP; S-39 SLUDGE STORAGE TANK, TK-3; AND
S-40 EQUALIZATION TANK, TK-1

| Type of Limit | Citation of Limit | FE Y/N | Future Effective Date | Limit | Monitoring Requirement Citation | Monitoring Frequency (P/C/N) | Monitoring Type |
|--------------------------------|---------------------------------|--------|-----------------------|---|-----------------------------------|------------------------------|-----------------|
| Total Carbon | BAAQMD 8-2-301 | Y | | 15 Pounds/Day or 300 ppm, dry basis | BAAQMD Condition # 7463, Part 11a | P/D | Records |
| Waste-water Through-put Limits | BAAQMD Condition # 7463, Part 5 | Y | | 1,700 Gallons/Hour 40,800 Gallons/Day 14,892,000 Gallons/Year | BAAQMD Condition # 7463, Part 11a | P/D | Records |
| POC | BAAQMD Condition # 7463, Part 6 | Y | | Leak Limit for Valves, Flanges, and Pumps of: 100 ppmv of POC above background at 1 cm from any component | None | N | NA |

VII. Applicable Limits and Compliance Monitoring Requirements

Table VII –E
Applicable Limits and Compliance Monitoring Requirements
S-30 AIR STRIPPER;
A-3 CARBON ADSORBER; A-4 CARBON ADSORBER;
A-5 CARBON ADSORBER; AND A-6 CARBON ADSORBER

| Type of Limit | Citation of Limit | FE Y/N | Future Effective Date | Limit | Monitoring Requirement Citation | Monitoring Frequency (P/C/N) | Monitoring Type |
|-------------------------------|---------------------------------|--------|-----------------------|---|--|------------------------------|--|
| Total Organic Compounds (TOC) | BAAQMD 8-47-301 and 8-47-302 | Y | | control device shall reduce total organic compound emissions to the atmosphere by at least: 90% by weight | BAAQMD 8-47-501.1, 8-47-501.2, and 8-47-601 and BAAQMD Condition # 7463, Parts 10a-c and 11a-e | P/D, W, M | Monthly, Weekly, or Daily FID Measurements at Carbon Adsorbers, Daily Records of Wastewater Throughput and Monthly Records of Water Analyses |
| NMOC | BAAQMD Condition # 7463, Part 7 | Y | | carbon replacement upon detection of an outlet NMOC concentration (from A-3 or A-5) that is 10% or more of the inlet NMOC concentration | BAAQMD Condition # 7463, Parts 10a, 10b, 11b, 11c, and 11e | P/D, W, M | Monthly, Weekly, or Daily FID Measurements at Carbon Adsorbers (inlet and outlet) and Records |

VII. Applicable Limits and Compliance Monitoring Requirements

Table VII –E
Applicable Limits and Compliance Monitoring Requirements
S-30 AIR STRIPPER;
A-3 CARBON ADSORBER; A-4 CARBON ADSORBER;
A-5 CARBON ADSORBER; AND A-6 CARBON ADSORBER

| Type of Limit | Citation of Limit | FE Y/N | Future Effective Date | Limit | Monitoring Requirement Citation | Monitoring Frequency (P/C/N) | Monitoring Type |
|--------------------------------|---------------------------------|--------|-----------------------|---|---|------------------------------|---|
| NMOC | BAAQMD Condition # 7463, Part 8 | Y | | carbon replacement upon detection of an outlet NMOC concentration (from A-4 or A-6) of 6 ppmv | BAAQMD Condition # 7463, Parts 10c, 11b, 11d, and 11e | P/D, W, M | Monthly, Weekly, or Daily FID Measurements at Carbon Adsorbers (outlet) and Records |
| POC | BAAQMD Condition # 7463, Part 6 | Y | | Leak Limit for Valves, Flanges, and Pumps of: 100 ppmv of POC above background at 1 cm from any component | None | N | NA |
| Waste-water Through-put Limits | BAAQMD Condition # 7463, Part 5 | Y | | 1,700 Gallons/Hour 40,800 Gallons/Day 14,892,000 Gallons/Year | BAAQMD Condition # 7463, Part 11a | P/D | Records |

VII. Applicable Limits and Compliance Monitoring Requirements

Table VII – F
Applicable Limits and Compliance Monitoring Requirements
S-37 INTERNAL COMBUSTION LEAN BURN ENGINE

| Type of Limit | Citation of Limit | FE Y/N | Future Effective Date | Limit | Monitoring Requirement Citation | Monitoring Frequency (P/C/N) | Monitoring Type |
|--|------------------------------|--------|-----------------------|--|---|------------------------------|---|
| Opacity | BAAQMD 6-301 | Y | | Ringelmann No. 1 for < 3 minutes/hr | None | N | NA |
| FP | BAAQMD 6-310 | Y | | 0.15 grains/dscf | None | N | NA |
| TOC (Total Organic Compounds Plus Methane) | BAAQMD 8-34-301.2 | Y | | 1000 ppmv as methane (component leak limit) | BAAQMD 8-34-501.6 and 8-34-503 | P/Q | Quarterly Inspection and Records |
| Non-Methane Organic Compounds (NMOC) | BAAQMD 8-34-301.4 | Y | | 98% removal by weight OR < 120 ppmv, dry basis @ 3% O ₂ , expressed as methane | BAAQMD 8-34-412 and 8-34-501.4 and BAAQMD Condition # 17812, Part 8 | P/A | Initial and Annual Source Tests and Records |
| NMOC | 40 CFR 60.752(b) (2)(iii)(B) | Y | | 98% removal by weight OR < 20 ppmv dry @ 3% O ₂ , expressed as hexane | 40 CFR 60.8 and 60.752(b) (2)(iii)(B) and 60.758(b)(2) | P/I | Initial Source Test and Records |
| SO ₂ | BAAQMD 9-1-301 | Y | | Property Line Ground Level Limits ≤ 0.5 ppm for 3 minutes, ≤ 0.25 ppm for 60 minutes, and ≤ 0.05 ppm for 24 hours | None | N | NA |

VII. Applicable Limits and Compliance Monitoring Requirements

Table VII – F
Applicable Limits and Compliance Monitoring Requirements
S-37 INTERNAL COMBUSTION LEAN BURN ENGINE

| Type of Limit | Citation of Limit | FE Y/N | Future Effective Date | Limit | Monitoring Requirement Citation | Monitoring Frequency (P/C/N) | Monitoring Type |
|------------------|----------------------------------|--------|-----------------------|--|--|------------------------------|--|
| SO ₂ | BAAQMD 9-1-302 | Y | | ≤ 300 ppm (dry) | BAAQMD Condition # 17821, Part 10 and BAAQMD Condition # 17812, Part 8 | P/Q and P/A | Quarterly Sulfur Analysis of Landfill Gas and Annual Source Test |
| H ₂ S | BAAQMD 9-2-301 | N | | Property Line ground level limits ≤ 0.06 ppm Averaged over 3 minutes and ≤ 0.03 ppm Averaged over 60 minutes | None | N | NA |
| NO _x | BAAQMD 9-8-302.1 | Y | | Waste Fuel Gas, Lean-Burn ≤ 140 ppmv, dry basis @ 15% O ₂ | BAAQMD Condition # 17812, Part 8 | P/A | Annual Source Test |
| NO _x | BAAQMD Condition # 17812, Part 5 | Y | | ≤ 63 ppmv, dry basis @ 15% O ₂ | BAAQMD Condition # 17812, Part 8 | P/A | Annual Source Test |
| CO | BAAQMD 9-8-302.3 | Y | | Waste Fuel Gas: ≤ 2000 ppmv, dry basis @ 15% O ₂ | BAAQMD Condition # 17812, Part 8 | P/A | Annual Source Test |
| CO | BAAQMD Condition # 17812, Part 6 | Y | | ≤ 309 ppmv, dry basis @ 15% O ₂ | BAAQMD Condition # 17812, Part 8 | P/A | Annual Source Test |
| Heat Input | BAAQMD Condition # 17812, Part 2 | Y | | 251.9 MM BTU per day and 91,951 MM BTU per consecutive 12-month period | BAAQMD Condition # 17812, Parts 7 and 9c | C | Gas Flow Meter and Recorder and Records |

VII. Applicable Limits and Compliance Monitoring Requirements

Table VII – F
Applicable Limits and Compliance Monitoring Requirements
S-37 INTERNAL COMBUSTION LEAN BURN ENGINE

| Type of Limit | Citation of Limit | FE Y/N | Future Effective Date | Limit | Monitoring Requirement Citation | Monitoring Frequency (P/C/N) | Monitoring Type |
|---------------------------------------|---------------------------------------|--------|-----------------------|--|---|------------------------------|---|
| Gas Flow | BAAQMD 8-34-301 and 301.1 | Y | | Vent all collected gases to a properly operating control system and operate control system continuously. | BAAQMD 8-34-501.10 and 508 | C | Gas Flow Meter and Recorder (every 15 minutes) |
| Gas Flow | BAAQMD Condition # 17812, Parts 3 & 4 | Y | | Operate S-37 continuously; Upon shutdown of S-37 or if any amount of gas exceeds the capacity of S-37, return gas to A-8 Flare automatically | BAAQMD Condition # 17812, Part 7 | C | Gas Flow Meter and Recorder |
| Gas Flow | 40 CFR 60.753(a) and (e) | Y | | Vent all collected gases to a properly operating control system and operate control system at all times when gas is vented to it | 40 CFR 60.756(b)(2) (i or ii) and 60.758(c)(2) | C and P/M | Gas Flow Meter and Recorder (every 15 minutes) or Monthly Inspection of Bypass Valve & Lock and Records |
| Emission Control System Shutdown Time | BAAQMD 8-34-113.2 | Y | | 240 hours/year | BAAQMD 8-34-501.2 and BAAQMD Condition # 17812, Part 9a | P/D | Records |

VII. Applicable Limits and Compliance Monitoring Requirements

Table VII – F
Applicable Limits and Compliance Monitoring Requirements
S-37 INTERNAL COMBUSTION LEAN BURN ENGINE

| Type of Limit | Citation of Limit | FE Y/N | Future Effective Date | Limit | Monitoring Requirement Citation | Monitoring Frequency (P/C/N) | Monitoring Type |
|---|-----------------------------------|--------|-----------------------|--|--|------------------------------|---|
| Emission Control System Startup Shutdown or Malfunction | 40 CFR 60.755(e) | Y | | ≤ 1 hour per event | 40 CFR 60.7(b), 60.757(f)(2) and (f)(3), and 60.758(e) | P/D | Records of occurrence and duration |
| Startup Shutdown or Malfunction Procedures | 40 CFR 63.6(e) | Y | | Minimize Emissions by Implementing SSM Plan | 40 CFR 63.1980(a-b) | P/E | Records (all occurrences, duration of each, corrective actions) |
| Engine Cylinder or Exhaust Temperature | BAAQMD Condition # 17812, Part 10 | Y | | To be established during first source test conducted after permit issuance | BAAQMD 8-34-507 and 8-34-509 | C | Temperature sensor and continuous recorder |
| Periods of Inoperation for Parametric Monitors | BAAQMD 1-523.2 | Y | | 15 consecutive days/incident and 30 calendar days/12 month period | BAAQMD 1-523.4 | P/D | Records of occurrence and duration |
| Continuous Monitors | 40 CFR 60.13(e) | Y | | Requires Continuous Operation except for breakdowns, repairs, calibration, and required span adjustments | 40 CFR 60.7(b) | P/D | Records of occurrence and duration |

VII. Applicable Limits and Compliance Monitoring Requirements

Table VII – G
Applicable Limits and Compliance Monitoring Requirements
S-46 HAZARDOUS WASTE MANAGEMENT FACILITY WITH LANDFILL GAS COLLECTION
SYSTEM; AND A-11 LANDFILL GAS FLARE FOR HWMF

| Type of Limit | Citation of Limit | FE Y/N | Future Effective Date | Limit | Monitoring Requirement Citation | Monitoring Frequency (P/C/N) | Monitoring Type |
|--------------------------------------|--|--------|-----------------------|---|--|------------------------------|-----------------|
| Collection System Installation Dates | BAAQMD 8-34-304.1 | Y | | For Inactive/Closed Areas: collection system components must be installed and operating by 2 years + 60 days after initial waste placement | BAAQMD 8-34-501.7 and 501.8 and BAAQMD Condition # 20754, Part 11a | P/E | Records |
| Collection System Installation Dates | BAAQMD 8-34-304.2 | Y | | For Active Areas: Collection system components must be installed and operating by 5 years + 60 days after initial waste placement | BAAQMD 8-34-501.7 and 501.8 and BAAQMD Condition # 20754, Part 11a | P/E | Records |
| Collection System Installation Dates | BAAQMD 8-34-304.3 | Y | | For Any Uncontrolled Areas or Cells: collection system components must be installed and operating within 60 days after the uncontrolled area or cell accumulates 1,000,000 tons of decomposable waste | BAAQMD 8-34-501.7 and 501.8 and BAAQMD Condition # 20754, Part 11a | P/E | Records |
| Collection System Installation Dates | 40 CFR 60.753 (a)(2) and 60.755 (b)(2) | Y | | For Inactive/Closed Areas: collection system components must be installed and operating by 2 years + 60 days after initial waste placement | 40 CFR 60.758(a), (d)(1) and (d)(2), and 60.759(a)(3) | P/E | Records |
| Collection System Installation Dates | 40 CFR 60.753 (a)(1) and 60.755 (b)(1) | Y | | For Active Areas: Collection system components must be installed and operating by 5 years + 60 days after initial waste placement | 40 CFR 60.758(a), (d)(1) and (d)(2) | P/E | Records |

VII. Applicable Limits and Compliance Monitoring Requirements

Table VII – G
Applicable Limits and Compliance Monitoring Requirements
S-46 HAZARDOUS WASTE MANAGEMENT FACILITY WITH LANDFILL GAS COLLECTION
SYSTEM; AND A-11 LANDFILL GAS FLARE FOR HWMF

| Type of Limit | Citation of Limit | FE Y/N | Future Effective Date | Limit | Monitoring Requirement Citation | Monitoring Frequency (P/C/N) | Monitoring Type |
|--|---|--------|-----------------------|--|--|------------------------------|---|
| Gas Flow | BAAQMD 8-34-301 and 301.1 | Y | Upon Start-Up of A-11 | Landfill gas collection system shall operate continuously and all collected gases shall be vented to a properly operating control system | BAAQMD 8-34-501.10 and 508 | C | Gas Flow Meter and Recorder (every 15 minutes) |
| Gas Flow | BAAQMD Condition # 20754, Parts 2 and 3 | Y | Upon Start-Up of A-11 | Landfill gas collection system shall operate continuously and all collected gases shall be vented to a properly operating control system | BAAQMD Condition # 20754, Part 11a-c | P/D | Records of Landfill Gas Flow Rates, Collection and Control Systems Downtime, and Collection System Components |
| Gas Flow | 40 CFR 60.753(a) and (e) | Y | | Operate a Collection System in each area or cell and vent all collected gases to a properly operating control system | 40 CFR 60.756(b)(2) (i or ii) and 60.758(c)(2) | C or P/M | Gas Flow Meter and Recorder (every 15 minutes) or Monthly Inspection of Bypass Valve and Lock and Records |
| Collection and Control Systems Shutdown Time | BAAQMD 8-34-113.2 | Y | Upon Start-Up of A-11 | 240 hours/year nor 5 consecutive days | BAAQMD 8-34-501.1 | P/D | Operating Records |

VII. Applicable Limits and Compliance Monitoring Requirements

Table VII – G
Applicable Limits and Compliance Monitoring Requirements
S-46 HAZARDOUS WASTE MANAGEMENT FACILITY WITH LANDFILL GAS COLLECTION
SYSTEM; AND A-11 LANDFILL GAS FLARE FOR HWMF

| Type of Limit | Citation of Limit | FE Y/N | Future Effective Date | Limit | Monitoring Requirement Citation | Monitoring Frequency (P/C/N) | Monitoring Type |
|---|-------------------|--------|-----------------------|--|--|------------------------------|---|
| Collection and Control System Startup Shutdown or Malfunction | 40 CFR 60.755(e) | Y | | 5 days per event for collection system and 1 hour per event for control system | 40 CFR 60.7(b), 60.757(f)(2), (f)(3) and (f)(4) | P/D | Operating Records (all occurrences and duration of each) |
| Startup Shutdown or Malfunction Procedures | 40 CFR 63.6(e) | Y | Upon Start-Up of A-11 | Minimize Emissions by Implementing SSM Plan | 40 CFR 63.1980(a-b) | P/E | Records (all occurrences, duration of each, corrective actions) |
| Periods of Inoperation for Parametric Monitors | BAAQMD 1-523.2 | Y | Upon Start-Up of A-11 | 15 consecutive days/incident and 30 calendar days/12 month period | BAAQMD 1-523.4 | P/D | Operating Records for All Parametric Monitors |
| Continuous Monitors | 40 CFR 60.13(e) | Y | Upon Start-Up of A-11 | Requires Continuous Operation except for breakdowns, repairs, calibration, and required span adjustments | 40 CFR 60.7(b) | P/D | Operating Records for All Continuous Monitors |
| Wellhead Pressure | BAAQMD 8-34-305.1 | Y | Upon Start-Up of A-11 | < 0 psig | BAAQMD 8-34-414, 501.9 and 505.1 | P/M | Monthly Inspection and Records |
| Wellhead Pressure | 40 CFR 60.753(b) | Y | | < 0 psig | 40 CFR 60.755(a)(3), 60.756(a)(1), and 60.758(c) and (e) | P/M | Monthly Inspection and Records |

VII. Applicable Limits and Compliance Monitoring Requirements

Table VII – G
Applicable Limits and Compliance Monitoring Requirements
S-46 HAZARDOUS WASTE MANAGEMENT FACILITY WITH LANDFILL GAS COLLECTION
SYSTEM; AND A-11 LANDFILL GAS FLARE FOR HWMF

| Type of Limit | Citation of Limit | FE Y/N | Future Effective Date | Limit | Monitoring Requirement Citation | Monitoring Frequency (P/C/N) | Monitoring Type |
|--|----------------------------|--------|--|---|--|------------------------------|---|
| Temperature of Gas at Wellhead | BAAQMD 8-34-305.2 | Y | Upon Start-Up of A-11 | < 55 °C | BAAQMD 8-34-414, 501.9 and 505.2 | P/M | Monthly Inspection and Records |
| Temperature of Gas at Wellhead | 40 CFR 60.753(c) | Y | | < 55 °C | 40 CFR 60.755(a)(5), 60.756(a)(3), and 60.758(c) and (e) | P/M | Monthly Inspection and Records |
| Gas Concentrations at Wellhead | BAAQMD 8-34-305.3 or 305.4 | Y | Upon Start-Up of A-11 | N ₂ < 20% OR O ₂ < 5% | BAAQMD 8-34-414, 501.9 and 505.3 or 505.4 | P/M | Monthly Inspection and Records |
| Gas Concentrations at Wellhead | 40 CFR 60.753(c) | Y | | N ₂ < 20% OR O ₂ < 5% | 40 CFR 60.755(a)(5), 60.756(a)(2), and 60.758(c) and (e) | P/M | Monthly Inspection and Records |
| Well Shutdown Limits | BAAQMD 8-34-117.4 | Y | Upon Start-Up of A-11 | No more than 5 wells at a time or 10% of total collection system, whichever is less | BAAQMD 8-34-117.6 and 501.1 | P/D | Records |
| Well Shutdown Limits | BAAQMD 8-34-117.5 | Y | Upon Start-Up of A-11 | 24 hours per well | BAAQMD 8-34-117.6 and 501.1 | P/D | Records |
| TOC (Total Organic Compounds Plus Methane) | BAAQMD 8-34-301.2 | Y | Upon Installation of Collection Systems and A-11 | 1000 ppmv as methane (component leak limit) | BAAQMD 8-34-501.6 and 503 | P/Q | Quarterly Inspection of collection and control system components with OVA and Records |

VII. Applicable Limits and Compliance Monitoring Requirements

Table VII – G
Applicable Limits and Compliance Monitoring Requirements
S-46 HAZARDOUS WASTE MANAGEMENT FACILITY WITH LANDFILL GAS COLLECTION
SYSTEM; AND A-11 LANDFILL GAS FLARE FOR HWMF

| Type of Limit | Citation of Limit | FE Y/N | Future Effective Date | Limit | Monitoring Requirement Citation | Monitoring Frequency (P/C/N) | Monitoring Type |
|---------------|-------------------|--------|-----------------------|---|--|------------------------------|---|
| TOC | BAAQMD 8-34-303 | Y | | 500 ppmv as methane at 2 inches above surface | BAAQMD 8-34-415, 416, 501.6, 506 and 510 | P/M, Q, and E | Monthly Visual Inspection of Cover, Quarterly Inspection with OVA of Surface, Various Reinspection Times for Leaking Areas, and Records |
| TOC | 40 CFR 60.753(d) | Y | | <500 ppmv as methane at 5-10 cm from surface | 40 CFR 60.755(c)(1), (4) and (5), 60.756(f), and 60.758(c) and (e) | P/M, Q and E | Monthly Visual Inspection of Cover, Quarterly Inspection with Portable Analyzer of Surface, Various Reinspection Times for Leaking Areas, and Records |

VII. Applicable Limits and Compliance Monitoring Requirements

Table VII – G
Applicable Limits and Compliance Monitoring Requirements
S-46 HAZARDOUS WASTE MANAGEMENT FACILITY WITH LANDFILL GAS COLLECTION
SYSTEM; AND A-11 LANDFILL GAS FLARE FOR HWMF

| Type of Limit | Citation of Limit | FE Y/N | Future Effective Date | Limit | Monitoring Requirement Citation | Monitoring Frequency (P/C/N) | Monitoring Type |
|--------------------------------------|----------------------------------|--------|-----------------------|---|---|------------------------------|---|
| Non-Methane Organic Compounds (NMOC) | BAAQMD 8-34-301.3 | Y | Upon Start-Up of A-11 | 98% removal by weight OR < 30 ppmv, dry basis @ 3% O ₂ , expressed as methane (applies to A-11 Flare) | BAAQMD 8-34-412 and 8-34-501.4 and BAAQMD Condition # 20754, Part 8 | P/A | Initial and Annual Source Tests and Records |
| NMOC | 40 CFR 60.752(b)(2)(iii)(B) | Y | | 98% removal by weight OR < 20 ppmv dry @ 3% O ₂ , expressed as hexane (applies to A-11 Flare only) | 40 CFR 60.8 and 60.752(b)(2)(iii)(B) and 60.758 (b)(2)(ii) | P/E | Initial Source Test and Records |
| Temperature of Combustion Zone (CT) | BAAQMD Condition # 20754, Part 4 | Y | Upon Start-Up of A-11 | CT > 1400 °F, averaged over any 3-hour period (applies to A-11 Flare) | BAAQMD 8-34-501.3 and 507, and BAAQMD Condition# 20754, Part 8f | C | Temperature Sensor and Recorder (continuous) |
| CT | 40 CFR 60.758 (c)(1)(i) | Y | | CT ≥ 1475 °F (3-hour average) from (CT ≥ CT _{PF} – 28 °C), where CT _{PF} is the average combustion temperature during the most recent complying performance test (applies to A-11 Flare only) | 40 CFR 60.756(b)(1) and 60.758 (b)(2)(i) | C | Temperature Sensor and Recorder (measured every 15 minutes and averaged over 3 hours) |
| Opacity | BAAQMD 6-301 | Y | Upon Start-Up of A-11 | Ringelmann No. 1 for < 3 minutes/hour (applies to A-11 Flare) | None | N | NA |
| FP | BAAQMD 6-310 | Y | Upon Start-Up of A-11 | < 0.15 grains/dscf (applies to A-11 Flare only) | None | N | NA |

VII. Applicable Limits and Compliance Monitoring Requirements

Table VII – G
Applicable Limits and Compliance Monitoring Requirements
S-46 HAZARDOUS WASTE MANAGEMENT FACILITY WITH LANDFILL GAS COLLECTION
SYSTEM; AND A-11 LANDFILL GAS FLARE FOR HWMF

| Type of Limit | Citation of Limit | FE Y/N | Future Effective Date | Limit | Monitoring Requirement Citation | Monitoring Frequency (P/C/N) | Monitoring Type |
|--------------------------------------|----------------------------------|--------|-----------------------|---|----------------------------------|------------------------------|---------------------------------|
| SO ₂ | BAAQMD 9-1-301 | Y | Upon Start-Up of A-11 | Property Line Ground Level Limits: < 0.5 ppm for 3 minutes and < 0.25 ppm for 60 min. and <0.05 ppm for 24 hours | None | N | NA |
| SO ₂ | BAAQMD Regulation 9-1-302 | Y | Upon Start-Up of A-11 | < 300 ppm (dry basis) (applies to A-11 Flare only) | BAAQMD Condition # 20754, Part 9 | P/A | Sulfur analysis of landfill gas |
| Total Sulfur Content in Landfill Gas | BAAQMD Condition # 20754, Part 7 | Y | Upon Start-Up of A-11 | < 150 ppmv of TRS, expressed as H ₂ S, dry basis | BAAQMD Condition # 20754, Part 9 | P/A | Sulfur analysis of landfill gas |
| H ₂ S | BAAQMD 9-2-301 | N | | Property Line Ground Level Limits: < 0.06 ppm, averaged over 3 minutes and < 0.03 ppm, averaged over 60 minutes | None | N | NA |
| Amount of Waste Accepted | BAAQMD Condition # 20754, Part 1 | Y | | < 210,700 tons (cumulative amount of all decomposable wastes) | BAAQMD 8-34-501.7 and 501.8 | P/E | Records |
| NO _x | BAAQMD Condition # 20754, Part 5 | Y | Upon Start-Up of A-11 | A-11 Flare Outlet Concentration Limit: < 15 ppmv of NO _x , at 15% O ₂ , dry basis, Unless A-11 Flare Emissions Are: < 0.06 pounds/MM BTU, calculated as NO ₂ | BAAQMD Condition # 20754, Part 8 | P/A | Initial and Annual Source Tests |

VII. Applicable Limits and Compliance Monitoring Requirements

Table VII – G
Applicable Limits and Compliance Monitoring Requirements
S-46 HAZARDOUS WASTE MANAGEMENT FACILITY WITH LANDFILL GAS COLLECTION
SYSTEM; AND A-11 LANDFILL GAS FLARE FOR HWMF

| Type of Limit | Citation of Limit | FE Y/N | Future Effective Date | Limit | Monitoring Requirement Citation | Monitoring Frequency (P/C/N) | Monitoring Type |
|------------------------|-----------------------------------|--------|-----------------------|---|----------------------------------|------------------------------|---------------------------------|
| CO | BAAQMD Condition # 20754, Part 6 | Y | Upon Start-Up of A-11 | A-11 Flare Outlet Concentration Limit: < 122 ppmv of CO, at 15% O ₂ , dry basis, Unless A-11 Flare Emissions Are: < 0.30 pounds/MM BTU | BAAQMD Condition # 20754, Part 8 | P/A | Initial and Annual Source Tests |
| Toxic Air Contaminants | BAAQMD Condition # 20754, Part 10 | N | Upon Start-Up of A-11 | Landfill Gas Concentration Limits: Acrylonitrile 6.3 ppmv Benzene 4.4 ppmv Vinyl Chloride 90.4 ppmv | BAAQMD Condition # 20754, Part 9 | P/A | Annual Landfill Gas Analysis |

Table VII – H
Applicable Limits and Compliance Monitoring Requirements
S-50 SOLID WASTE TRANSFER STATION AND A-50 WATER MIST SYSTEM

| Type of Limit | Citation of Limit | FE Y/N | Future Effective Date | Limit | Monitoring Requirement Citation | Monitoring Frequency (P/C/N) | Monitoring Type |
|---------------------------|---------------------------------------|--------|-----------------------|---|---------------------------------|------------------------------|---|
| Opacity | BAAQMD Regulation 6-301 | Y | upon start-up of S50 | Ringelmann 1.0 for 3 minutes in any hour | BAAQMD Condition #18258, Part 3 | C | Continuous Observation of Source in Operation |
| Amount of Waste Accepted | BAAQMD Condition #22792, Part 1 | Y | upon start-up of S50 | 2000 tons/day or 730,000 tons in any consecutive twelve month period | BAAQMD Condition #18258, Part 7 | P/E | Records |
| Amount of Vehicle Traffic | BAAQMD Condition #22792, Part 5 and 6 | Y | upon start-up of S50 | 601 vehicle trips per day to both S15 and S50 while waste is accepted at S15; 715 vehicle trips per day to S50 after waste is no longer accepted at S15 | BAAQMD Condition #18258, Part 7 | P/E | Records |

VIII. TEST METHODS

The test methods associated with the emission limit of a District regulation are generally found in Section 600 et seq. of the regulation. The following table indicates only the test methods associated with the emission limits included in Section VII, Applicable Emission Limits & Compliance Monitoring Requirements, of this permit.

**Table VIII
 Test Methods**

| Applicable Requirement | Description of Requirement | Acceptable Test Methods |
|-------------------------------|---|---|
| BAAQMD 6-301 | Ringelmann No. 1 Limitation | Manual of Procedures, Volume I, Evaluation of Visible Emissions |
| BAAQMD 6-310 | Particulate Weight Limitation | Manual of Procedures, Volume IV, ST-15, Particulate; or USEPA Method 5, Determination of Particulate Matter Emissions from Stationary Sources |
| BAAQMD 8-2-301 | Organic Compound Emission Limitation for Miscellaneous Operations | Manual of Procedures, Volume IV, ST-7, Organic Compounds; or EPA Reference Method 25 or 25A |
| BAAQMD 8-8-301.3 | OC Vapor Recovery System, collection and removal efficiency limit | Manual of Procedures, Volume IV, ST-7, Organic Compounds; or EPA Reference Method 25 or 25A |
| BAAQMD 8-8-303 | Gauging and Sampling Devices | EPA Reference Method 21, Determination of Volatile Organic Compound Leaks |
| BAAQMD 8-34-114 | Energy Recovery Device and Emission Control System | Manual of Procedures, Volume IV, ST-7, Organic Compounds and ST-14, Oxygen, Continuous Sampling; or EPA Reference Method 18, 25, 25A, or 25C |
| BAAQMD 8-34-301.2 | Collection and Control System Leak Limitations | EPA Reference Method 21, Determination of Volatile Organic Compound Leaks |
| BAAQMD 8-34-301.3 | Limits for Flares | Manual of Procedures, Volume IV, ST-7, Organic Compounds and ST-14, Oxygen, Continuous Sampling; or EPA Reference Method 18, 25, 25A, or 25C |
| BAAQMD 8-34-301.4 | Limits for Other Emission Control Systems | Manual of Procedures, Volume IV, ST-7, Organic Compounds and ST-14, Oxygen, Continuous Sampling; or EPA Reference Method 18, 25, 25A, or 25C |
| BAAQMD 8-34-303 | Landfill Surface Requirements | EPA Reference Method 21, Determination of Volatile Organic Compound Leaks |
| BAAQMD 8-34-305.1 | Wellhead Gauge Pressure | APCO Approved Device |
| BAAQMD 8-34-305.2 | Wellhead Temperature | APCO Approved Device |

VIII. Test Methods

Table VIII
Test Methods

| Applicable Requirement | Description of Requirement | Acceptable Test Methods |
|-------------------------------|---|---|
| BAAQMD 8-34-305.3 | Wellhead Nitrogen | EPA Reference Method 3C, Determination of Carbon Dioxide, Methane, Nitrogen, and Oxygen from Stationary Sources |
| BAAQMD 8-34-305.4 | Wellhead Oxygen | EPA Reference Method 3C, Determination of Carbon Dioxide, Methane, Nitrogen, and Oxygen from Stationary Sources |
| BAAQMD 8-34-412 | Compliance Demonstration Test | EPA Reference Method 18, Measurement of Gaseous Organic Compound Emissions by Gas Chromatography, Method 25, Determination of Total Gaseous Nonmethane Organic Emissions as Carbon, Method 25A, Determination of Total Gaseous Organic Concentration Using a Flame Ionization Analyzer, or Method 25C, Determination of Nonmethane Organic Compounds (NMOC) in MSW Landfill Gases |
| BAAQMD 8-47-301 | Emission Control Requirement, Specific Compounds | Manual of Procedures, Volume IV, ST-7, Organic Compounds; or EPA Reference Method 25 or 25A |
| BAAQMD 8-47-302 | Organic Compounds | Manual of Procedures, Volume IV, ST-7, Organic Compounds; or EPA Reference Method 25 or 25A |
| BAAQMD 9-1-301 | Limitations on Ground Level Concentrations (SO ₂) | Manual of Procedures, Volume VI, Part 1, Ground Level Monitoring for Hydrogen Sulfide and Sulfur Dioxide |
| BAAQMD 9-1-302 | General Emission Limitation (SO ₂) | Manual of Procedures, Volume IV, ST-19A, Sulfur Dioxide, Continuous Sampling |
| BAAQMD 9-2-301 | Limitations on Hydrogen Sulfide | Manual of Procedures, Volume VI, Part 1, Ground Level Monitoring for Hydrogen Sulfide and Sulfur Dioxide |
| BAAQMD 9-8-302.1 | Waste Derived Fuel Gas NO _x Limits for Lean Burn Engines | Manual of Procedures, Volume IV, ST-13A, Oxides of Nitrogen, Continuous Sampling and ST-14, Oxygen, Continuous Sampling |
| BAAQMD 9-8-302.3 | Waste Derived Fuel Gas CO Limits | Manual of Procedures, Volume IV, ST-6, Carbon Monoxide, Continuous Sampling and ST-14, Oxygen, Continuous Sampling |
| 40 CFR 60.8 | Performance Tests | EPA Reference Method 18, Measurement of Gaseous Organic Compound Emissions by Gas Chromatography, Method 25, Determination of Total Gaseous Nonmethane Organic Emissions as Carbon, Method 25A, Determination of Total Gaseous Organic Concentration Using a Flame Ionization Analyzer, or Method 25C, Determination of Nonmethane Organic Compounds (NMOC) in MSW Landfill Gases |

VIII. Test Methods

**Table VIII
 Test Methods**

| Applicable Requirement | Description of Requirement | Acceptable Test Methods |
|----------------------------------|--|---|
| 40 CFR 60.752 (b)(2)(iii)(B) | NMOC Outlet Concentration and Destruction Efficiency Limits | EPA Reference Method 18, Measurement of Gaseous Organic Compound Emissions by Gas Chromatography, Method 25, Determination of Total Gaseous Nonmethane Organic Emissions as Carbon, Method 25A, Determination of Total Gaseous Organic Concentration Using a Flame Ionization Analyzer, or Method 25C, Determination of Nonmethane Organic Compounds (NMOC) in MSW Landfill Gases |
| 40 CFR 60.753(b) | Wellhead Pressure | APCO Approved Device |
| 40 CFR 60.753(c) | Temperature, N ₂ , and O ₂ concentration in wellhead gas | EPA Reference Method 3C, Determination of Carbon Dioxide, Methane, Nitrogen, and Oxygen from Stationary Sources |
| 40 CFR 60.753(d) | Methane Limit at Landfill Surface | EPA Reference Method 21, Determination of Volatile Organic Compound Leaks |
| BAAQMD Condition # 5771, Part 4 | NO _x Emissions Limit | Manual of Procedures, Volume IV, ST-13A, Oxides of Nitrogen, Continuous Sampling and ST-14, Oxygen, Continuous Sampling |
| BAAQMD Condition # 5771, Part 5 | CO Emissions Limit | Manual of Procedures, Volume IV, ST-6, Carbon Monoxide, Continuous Sampling and ST-14, Oxygen, Continuous Sampling |
| BAAQMD Condition # 5771, Part 6 | NMOC Emissions Limit | Manual of Procedures, Volume IV, ST-7, Organic Compounds and ST-14, Oxygen, Continuous Sampling; or EPA Reference Method 18, 25, 25A, or 25C |
| BAAQMD Condition # 5771, Part 7 | Engine Source Test | Outlet: Manual of Procedures, Volume IV, ST-17, Stack Gas Velocity and Volumetric Flow Rate; ST-23 Water Vapor; ST-14, Oxygen, Continuous Sampling; ST-13A, Oxides of Nitrogen, Continuous Sampling; ST-6, Carbon Monoxide, Continuous Sampling; Manual of Procedures, Volume IV, ST-19A, Sulfur Dioxide, Continuous Sampling; and Manual of Procedures, Volume IV, ST-7, Organic Compounds or EPA Reference Methods 18, 25, 25A, or 25C; Inlet: EPA Reference Method 3C |
| BAAQMD Condition # 5771, Part 8 | Heat Input Limits | APCO approved gas flow meter and APCO approved calculation procedure described in BAAQMD Condition # 5771, Part 9 |
| BAAQMD Condition # 5771, Part 10 | Engine Temperature Limit | APCO Approved Thermocouples |
| BAAQMD Condition # 7463, Part 6 | POC Leak Limit for Valves, Flanges, and Pumps | EPA Reference Method 21, Determination of Volatile Organic Compound Leaks |

VIII. Test Methods

Table VIII
Test Methods

| Applicable Requirement | Description of Requirement | Acceptable Test Methods |
|-----------------------------------|---|---|
| BAAQMD Condition # 7463, Part 7 | Replacement requirements for second to last carbon adsorber | APCO Approved Organic Vapor Analyzer, Flame Ionization Detector (OVA-FID) and APCO Approved Procedures Described in BAAQMD Condition # 7463, Parts 9 and 10 |
| BAAQMD Condition # 7463, Part 8 | Replacement requirements for last carbon adsorber | APCO Approved Organic Vapor Analyzer, Flame Ionization Detector (OVA-FID) and APCO Approved Procedures Described in BAAQMD Condition # 7463, Parts 9 and 10 |
| BAAQMD Condition # 17812, Part 2 | Heat Input Limits | APCO approved gas flow meter and APCO approved calculation procedure described in BAAQMD Condition # 17812, Part 11c |
| BAAQMD Condition # 17812, Part 5 | NO _x Emissions Limit | Manual of Procedures, Volume IV, ST-13A, Oxides of Nitrogen, Continuous Sampling and ST-14, Oxygen, Continuous Sampling |
| BAAQMD Condition # 17812, Part 6 | CO Emissions Limit | Manual of Procedures, Volume IV, ST-6, Carbon Monoxide, Continuous Sampling and ST-14, Oxygen, Continuous Sampling |
| BAAQMD Condition # 17812, Part 8 | Engine Source Test | Outlet: Manual of Procedures, Volume IV, ST-17, Stack Gas Velocity and Volumetric Flow Rate; ST-23 Water Vapor; ST-14, Oxygen, Continuous Sampling; ST-13A, Oxides of Nitrogen, Continuous Sampling; ST-6, Carbon Monoxide, Continuous Sampling; Manual of Procedures, Volume IV, ST-19A, Sulfur Dioxide, Continuous Sampling; and Manual of Procedures, Volume IV, ST-7, Organic Compounds or EPA Reference Methods 18, 25, 25A, or 25C; Inlet: EPA Reference Method 3C |
| BAAQMD Condition # 17812, Part 10 | Engine Temperature Limit | APCO Approved Thermocouples |
| BAAQMD Condition # 17821, Part 2 | Acceptance Criteria for Soils containing VOCs (VOC determination) | BAAQMD 8-40-601 and EPA Reference Methods 8015B and 8021B; or EPA Reference Method 21 |
| BAAQMD Condition # 17821, Part 3 | Emission Limit for Low VOC Soils | BAAQMD 8-40-601 and EPA Reference Methods 8015B and 8021B; or EPA Reference Method 21 and APCO Approved Calculation Procedure Described in BAAQMD Condition # 17821, Part 3 |
| BAAQMD Condition # 17821, Part 8 | Heat Input Limits | APCO approved gas flow meter and APCO approved calculation procedure described in BAAQMD Condition # 17821, Part 8 |

VIII. Test Methods

**Table VIII
 Test Methods**

| Applicable Requirement | Description of Requirement | Acceptable Test Methods |
|-----------------------------------|---|---|
| BAAQMD Condition # 17821, Part 9 | Flare Combustion Temperature Limit | APCO Approved Device |
| BAAQMD Condition # 17821, Part 10 | Landfill Gas Sulfur Content Limit | Draeger Tube: used in accordance with manufacturer's recommended procedures |
| BAAQMD Condition # 17821, Part 11 | Flare Source Test | Outlet: Manual of Procedures, Volume IV, ST-17, Stack Gas Velocity and Volumetric Flow Rate; ST-23 Water Vapor; ST-14, Oxygen, Continuous Sampling; ST-13A, Oxides of Nitrogen, Continuous Sampling; ST-6, Carbon Monoxide, Continuous Sampling; Manual of Procedures, Volume IV, ST-19A, Sulfur Dioxide, Continuous Sampling; and Manual of Procedures, Volume IV, ST-7, Organic Compounds or EPA Reference Methods 18, 25, 25A, or 25C; Inlet: EPA Reference Method 3C |
| BAAQMD Condition # 17821, Part 12 | Landfill Gas Characterization Test | EPA Reference Method 18, Measurement of Gaseous Organic Compound Emissions by Gas Chromatography |
| BAAQMD Condition # 17821, Part 13 | Toxic Compound Concentration Limits (in landfill gas) | APCO approved sampling procedures described in BAAQMD Condition # 17821, Part 12 and GC Analysis for all compounds listed in Part 13 |
| BAAQMD Condition # 20754, Part 4 | Flare Combustion Temperature Limit | APCO Approved Device |
| BAAQMD Condition # 20754, Part 5 | Flare NO _x Emissions Limit | Manual of Procedures, Volume IV, ST-13A, Oxides of Nitrogen, Continuous Sampling and ST-14, Oxygen, Continuous Sampling |
| BAAQMD Condition # 20754, Part 6 | Flare CO Emissions Limit | Manual of Procedures, Volume IV, ST-6, Carbon Monoxide, Continuous Sampling and ST-14, Oxygen, Continuous Sampling |
| BAAQMD Condition # 20754, Part 7 | Landfill Gas Sulfur Content Limit | Manual of Procedures, Volume III, Method 44 Determination of Reduced Sulfur Gases and Sulfur Dioxide in Effluent Samples by Gas Chromatographic Methods, or ASTM D 1072-80 or 90, D 3031-81, D 4084-82 or 94, or D 3246-81, 92, or 96 |

VIII. Test Methods

**Table VIII
 Test Methods**

| Applicable Requirement | Description of Requirement | Acceptable Test Methods |
|---|---|---|
| BAAQMD Condition # 20754, Part 8 | Flare Source Test | Outlet: Manual of Procedures, Volume IV, ST-17, Stack Gas Velocity and Volumetric Flow Rate; ST-23 Water Vapor; ST-14, Oxygen, Continuous Sampling; ST-13A, Oxides of Nitrogen, Continuous Sampling; ST-6, Carbon Monoxide, Continuous Sampling; Manual of Procedures, Volume IV, ST-19A, Sulfur Dioxide, Continuous Sampling; and Manual of Procedures, Volume IV, ST-7, Organic Compounds or EPA Reference Methods 18, 25, 25A, or 25C; Inlet: EPA Reference Method 3C |
| BAAQMD Condition # 20754, Part 9 | Landfill Gas Characterization Test | EPA Reference Method 18, Measurement of Gaseous Organic Compound Emissions by Gas Chromatography; and Manual of Procedures, Volume III, Method 44 Determination of Reduced Sulfur Gases and Sulfur Dioxide in Effluent Samples by Gas Chromatographic Methods, or ASTM D 1072-80 or 90, D 3031-81, D 4084-82 or 94, or D 3246-81, 92, or 96 |
| BAAQMD Condition # 20754, Part 10 | Toxic Compound Concentration Limits (in landfill gas) | APCO approved sampling procedures described in BAAQMD Condition # 20754, Part 9 and GC Analysis for all compounds listed in Part 10 |
| BAAQMD Condition # 22792, Part 3 | Ringelmann No. 1 Limitation | Manual of Procedures, Volume I, Evaluation of Visible Emissions |

IX. PERMIT SHIELD

Not Applicable

X. REVISION HISTORY

Title V Permit Issuance (Application # 25834):

May 29, 2002

Reopening (Application # 10391):

September 29, 2004

- Correct contact information on the title page.
- Update standard language in Sections I, III, and VIII.
- Correct regulatory references and amendment dates in Section I and Tables III, IV-A, IV-B, IV-C, IV-D, IV-E, and IV-F.
- Delete outdated SIP requirements and future effective dates that have passed in Tables II-B, III, IV-A, IV-B, IV-F, VII-A, VII-B, VII-F, and VIII.
- Incorporate new BAAQMD amendments and SIP requirements in Tables III, IV-A, IV-B, and IV-F.
- Add several recently identified generally applicable regulations to Table III.
- Add MSW Landfill NESHAP requirements to Tables IV-A, IV-B, IV-F, VII-A, VII-B, and VII-F.
- Correct errors by deleting Regulation 8-34-501.3 and 507 from the applicable requirements for landfill gas fired engines in Tables IV-A, IV-F, VII-A, and VII-F and the basis for Conditions # 5771, Part 10 and # 17812, Part 10.
- Delete obsolete NMOC and THC requirements from Condition # 5771, Parts 6 and 7 and Table VIII.
- Revise Condition # 5771, Part 10 for consistency with MFR permit revision procedures in Regulation 2, Rule 6.
- Clarify text in Condition # 17812, Part 4.
- Delete Condition # 17812, Parts 5 and 8 and associated test methods in Table VIII, because these POC and THC requirements are obsolete. Revise subsequent part numbers in Condition # 17812 and Tables IV-F, VII-F, and VIII. Revise the new Condition # 17821, Part 8 to eliminate obsolete THC testing requirements.
- Revise Condition # 17821, Parts 2, 12, and 13 and Table IV-B to correct the basis for these parts.
- Clarify an equation in Condition # 17821, Part 3.
- Clarify text in Condition # 17821, Part 5.
- Revise Condition # 17821, Part 9 for consistency with MFR permit revision procedures in Regulation 2, Rule 6.
- Revise Condition # 17821, Part 11 to eliminate obsolete THC testing requirements.

X. Revision History

- Clarify Condition # 17821, Part 12 by specifically listing the organic compounds requiring analysis (instead of referring to the AP-42 table) and adding the AB-2588 Hot Spots Act to the basis.
- Revise Condition # 17821 and Table IV-A by adding Part 15. This part requires semi-annual reports pursuant to the above NESHAP requirements and allows these reports to be combined with the Title V semi-annual monitoring reports.
- An alternate method was added for BAAQMD Regulation 6-310, Particle Weight Limitation.
- In Table VIII, delete an obsolete test method reference for sulfur dioxide, and add the missing test method references for Conditions # 5771, Part 7, # 17812, Part 8, and # 17821, Parts 11 and 12.
- Add Section X Revision History and revise subsequent section numbers.
- Add and correct several terms in Section XI Glossary.

Administrative Amendment (Application # 10516):

September 29, 2004

- Replace the Responsible Official for this site.

Minor Revision (Applications # 2789 and # 8514):

October 26, 2005

- Correct the District contact person on the Title Page.
- Update regulatory amendment dates in Section I.A.
- Clarify standard conditions by adding Section I.B.12 and by revising Section I.G.
- Correct the bases for Sections I.B.11, I.E.2, and I.F.
- Add S-46 to Table II-A.
- Add A-11 and correct a limit for A-8 in Table II-B.
- Correct a typographical error and add web site address to Section III.
- Correct errors, update regulatory amendment dates, and include new non-federally enforceable generally applicable requirements in Table III.
- Correct a typographical error and add web site address to Section IV.
- Update regulatory amendment dates in Tables IV-A, IV-B, IV-E, and IV-F.
- Add Table IV-G for S-46 and A-11.
- Delete subpart b of Condition # 17821, Part 6, because the

X. Revision History

subpart is no longer necessary.

- Add Condition # 20754 for S-46 and A-11.
- Add Table VII-G for S-46 and A-11.
- Add all applicable test methods for S-46 and A-11 to Table VIII.
- Update the revision history in Section X.
- Add several terms to the glossary in Section XI.
- Correct the web site address listed in Section XII.

Significant Revision (Applications # 11375 and 13247):

October 17, 2006

- Correct responsible official, contact person, type of facility and Division name on the title page
- Update S5, S6, S15, S22 through S30, S37, and S38 through S40 operating capacity limits in Table II-A, Section VI Permit Condition #5771 Part 8, #7463 Part 5, Condition #17812 Part 2, Condition #17821 Part 1 and Tables VII-A through F
- Add S50 in Tables II-A, IV-H and VII-H, and Section VI Permit Condition #22792 for S50 and A50
- Add A50 in Table II-B
- Correct typo for Condition Part reference in the Applicable Requirement column for A1 through A6 in Table II-B
- Update A8 operating capacity in Tables II-B and Section VI Permit Condition #17821 Part 8 and Table VII-B
- Update regulatory amendment dates for BAAQMD Regulation 8, Rule 2 and 40CFR Part 61, Subpart A and M in Table III
- Delete references to 40 CFR Part 60, Subpart Cc and add references to 40 CFR Part 60, Subpart WWW in Table IV-A, B, F, G
- Update regulatory amendment date for 40 CFR Part 63, Subpart A in Tables IV-A, IV-B and IV-F, for BAAQMD Regulation 8 Rule 2 in Tables IV-B, IV-D, and for BAAQMD Regulation 8 Rule 8 in Tables IV-C
- Add Offsets as a basis for BAAQMD Condition #5771 Parts 4 and 8 in Table IV-A and Section VI, BAAQMD Condition # 17812 Part 5 in Table IV-F and Section VI
- Add Cumulative Increase as a basis for BAAQMD Condition #17821, Parts 1 and 10 in Table IV-B and Section VI
- Modify Section VI Permit Condition #5771 Part 2,

X. Revision History

Condition #17812 Part 4 and Condition #17821, Part 8 to allow the concurrent operation of the flare, A8, and engines, S5, S6 and S37

- Modify Section VI Permit Condition #5771 Part 4 and Condition #17812 Part 5, and Table VII-A and Table VII-F to reduce NOx emission limit from the engines.
- Modify Section VI Permit Condition #17821 Part 10 and Table VII-B to limit total reduced sulfur in the collected landfill gas
- Modify Section VI Permit Condition #17821 Part 12 to specify organic compounds to be analyzed for in the landfill gas; and Part 13 to add Perchloroethylene to the list of specific organic compounds limits that would trigger the requirement for a permit application for a change in conditions
- Add applicable limits and compliance monitoring requirements of 40 CFR Part 60, Subpart WWW to Tables VII-A, B, F and G
- Correct CO emission limit in Table VII-A
- Add test methods for the applicable requirements of 40 CFR Part 60, Subpart WWW and BAAQMD Condition #22792, Part 3 to Tables VIII

XI. GLOSSARY

ACT

Federal Clean Air Act

APCO

Air Pollution Control Officer: Head of Bay Area Air Quality Management District

ARB

Air Resources Board

ATCM

Airborne Toxic Control Measure

BAAQMD

Bay Area Air Quality Management District

BACT

Best Available Control Technology

BARCT

Best Available Retrofit Control Technology

Basis

The underlying authority which allows the District to impose requirements.

CAA

The federal Clean Air Act

CAAQS

California Ambient Air Quality Standards

CAPCOA

California Air Pollution Control Officers Association

CARB

California Air Resources Board (same as ARB)

CEQA

California Environmental Quality Act

CEM

A "continuous emission monitor" is a monitoring device that provides a continuous direct measurement of some pollutant (e.g. NO_x concentration) in an exhaust stream.

XI. Glossary

CFR

The Code of Federal Regulations. 40 CFR contains the implementing regulations for federal environmental statutes such as the Clean Air Act. Parts 50-99 of 40 CFR contain the requirements for air pollution programs.

CH₄ or CH₄

Methane

CO

Carbon Monoxide

CO₂ or CO₂

Carbon Dioxide

CT

Combustion Zone Temperature

Cumulative Increase

The sum of permitted emissions from each new or modified source since a specified date pursuant to BAAQMD Regulation 2-1-403, Permit Conditions (as amended by the District Board on 7/17/91) and SIP Regulation 2-1-403, Permit Conditions (as approved by EPA on 6/23/95). Used to determine whether threshold-based requirements are triggered.

District

The Bay Area Air Quality Management District

E 6

Very large or very small number values are commonly expressed in a form called scientific notation, which consists of a decimal part multiplied by 10 raised to some power. For example, 4.53 E 6 equals $(4.53) \times (10^6) = (4.53) \times (10 \times 10 \times 10 \times 10 \times 10 \times 10) = 4,530,000$. Scientific notation is used to express large or small numbers without writing out long strings of zeros.

EG

Emission Guidelines

EO

Executive Order

EPA

The federal Environmental Protection Agency.

Excluded

Not subject to any District Regulations.

Federally Enforceable, FE

XI. Glossary

All limitations and conditions which are enforceable by the Administrator of the EPA including those requirements developed pursuant to 40 CFR Part 51, subpart I (NSR), Part 52.21 (PSD), Part 60 (NSPS) Part 61, (NESHAPs), Part 63 (HAP), and Part 72 (Permits Regulation, Acid Rain), and also including limitations and conditions contained in operating permits issued under an EPA-approved program that has been incorporated into the SIP.

FID

Flame Ionization Detector

FP

Filterable particulate as measured by BAAQMD Method ST-15, Particulate.

FR

Federal Register

GDF

Gasoline Dispensing Facility

GLM

Ground Level Monitor

H₂S or H₂S

Hydrogen Sulfide

HAP

Hazardous Air Pollutant. Any pollutant listed pursuant to Section 112(b) of the Act. Also refers to the program mandated by Title I, Section 112, of the Act and implemented by 40 CFR Part 63.

Hg

Mercury

HHV

Higher Heating Value. The quantity of heat evolved as determined by a calorimeter where the combustion products are cooled to 60 °F and all water vapor is condensed to liquid.

HWMF

Hazardous Waste Management Facility

LFG

Landfill Gas

LHV

Lower Heating Value. Similar to the higher heating value (see HHV) except that the water produced by the combustion is not condensed but retained as vapor at 60 °F.

Major Facility

XI. Glossary

A facility with potential emissions of: (1) at least 100 tons per year of any regulated air pollutant, (2) at least 10 tons per year of any single hazardous air pollutant, and/or (3) at least 25 tons per year of any combination of hazardous air pollutants, or such lesser quantity of hazardous air pollutants as determined by the EPA administrator.

MAX or Max.

Maximum

MFR

Major Facility Review. The District's term for the federal operating permit program mandated by Title V of the Act and implemented by District Regulation 2, Rule 6.

MIN or Min.

Minimum

MOP

The District's Manual of Procedures.

MSDS

Material Safety Data Sheet

MSW

Municipal solid waste

MW

Molecular weight

N2 or N₂

Nitrogen

NA

Not Applicable

NAAQS

National Ambient Air Quality Standards

NESHAPs

National Emission Standards for Hazardous Air Pollutants. See in 40 CFR Parts 61 and 63.

NMHC

Non-methane Hydrocarbons (same as NMOC).

XI. Glossary

NMOC

Non-methane Organic Compounds (same as NMHC).

NO_x or NO_x

Oxides of nitrogen.

NSPS

Standards of Performance for New Stationary Sources. Federal standards for emissions from new stationary sources. Mandated by Title I, Section 111 of the Act, and implemented by 40 CFR Part 60 and District Regulation 10.

NSR

New Source Review. A federal program for pre-construction review and permitting of new and modified sources of air pollutants for which the District is classified "non-attainment". Mandated by Title I of the Clean Air Act and implemented by 40 CFR Parts 51 and 52 as well as District Regulation 2, Rule 2. (Note: There are additional NSR requirements mandated by the California Clean Air Act.)

O₂ or O₂

Oxygen

Offset Requirement

A New Source Review requirement to provide federally enforceable emission offsets at a specified ratio for the emissions from a new or modified source and any pre-existing cumulative increase minus any onsite contemporaneous emission reduction credits. Applies to emissions of POC, NO_x, PM₁₀, and SO₂.

Phase II Acid Rain Facility

A facility that generates electricity for sale through fossil-fuel combustion and is not exempted by 40 CFR 72 from Titles IV and V of the Clean Air Act.

POC

Precursor Organic Compounds

PM

Total Particulate Matter

PM₁₀ or PM₁₀

Particulate matter with aerodynamic equivalent diameter of less than or equal to 10 microns

PSD

Prevention of Significant Deterioration. A federal program for permitting new and modified sources of air pollutants for which the District is classified "attainment" of the National Air Ambient Quality Standards. Mandated by Title I of the Act and implemented by both 40 CFR Part 52 and District Regulation 2, Rule 2.

XI. Glossary

PV or P/V Valve

Pressure / Vacuum Valve

RMP

Risk Management Plan

S

Sulfur

SIP

State Implementation Plan. State and District programs and regulations approved by EPA and developed in order to attain the National Air Ambient Quality Standards. Mandated by Title I of the Act.

SO₂ or SO₂

Sulfur dioxide

SSM

Startup, Shutdown, or Malfunction

SSM Plan

A plan, which states the procedures that will be followed during a startup, shutdown, or malfunction, that is prepared in accordance with the general NESHAP provisions (40 CFR Part 63, Subpart A) and maintained on site at the facility.

THC

Total Hydrocarbons includes all NMHC plus methane (same as TOC).

Title V

Title V of the federal Clean Air Act. Requires a federally enforceable operating permit program for major and certain other facilities.

TOC

Total Organic Compounds includes all NMOC plus methane (same as THC).

TPH

Total Petroleum Hydrocarbons

TRMP

Toxic Risk Management Policy

TRS

Total Reduced Sulfur

XI. Glossary

TSP

Total Suspended Particulate

VOC

Volatile Organic Compounds

Symbols:

| | | |
|---|---|--------------------------|
| < | = | less than |
| > | = | greater than |
| ≤ | = | less than or equal to |
| ≥ | = | greater than or equal to |

Units of Measure:

| | | |
|-----------------|---|---------------------------------------|
| bbbl | = | barrel of liquid (1 bbl = 42 gallons) |
| bhp | = | brake-horsepower |
| btu | = | British Thermal Unit |
| BTU | = | British Thermal Unit |
| °C | = | degrees Centigrade |
| cfm | = | cubic feet per minute |
| dscf | = | dry standard cubic feet |
| °F | = | degrees Fahrenheit |
| ft ³ | = | cubic feet |
| g | = | grams |
| gal | = | gallon |
| gpm | = | gallons per minute |
| gr | = | grains (7000 grains = 1 pound) |
| hp | = | horsepower |
| hr | = | hour |
| in | = | inches |
| kg | = | kilograms |
| lb | = | pound |
| lbmol | = | pound-mole |
| M | = | thousand |
| m ² | = | square meter |
| m ³ | = | cubic meters |
| Mg | = | mega-grams, 1000 kilograms |
| min | = | minute |
| mm | = | millimeter |
| MM | = | million |
| MM BTU | = | million BTU |
| MM cf | = | million cubic feet |

XI. Glossary

| | | |
|-----------------|---|------------------------------------|
| mm Hg | = | millimeters of mercury (pressure) |
| MW | = | megawatts |
| µg | = | microgram, one millionth of a gram |
| ppb | = | parts per billion |
| ppbv | = | parts per billion by volume |
| ppm | = | parts per million |
| ppmv | = | parts per million, by volume |
| ppmw | = | parts per million, by weight |
| psia | = | pounds per square inch, absolute |
| psig | = | pounds per square inch, gauge |
| scf | = | standard cubic feet |
| scfm | = | standard cubic feet per minute |
| sdcf | = | standard dry cubic feet |
| sdcfm | = | standard dry cubic feet per minute |
| therms | = | 1 therm = 100,000 BTU |
| yd | = | yard |
| yd ³ | = | cubic yards |
| yr | = | year |

XII. APPLICABLE STATE IMPLEMENTATION PLAN

The Bay Area Air Quality Management District's portion of the State Implementation Plan can be found at EPA Region 9's website. The address is:

<http://yosemite.epa.gov/r9/r9sips.nsf/Agency?ReadForm&count=500&state=California&cat=Bay+Area+Air+Quality+Management+District-Agency-Wide+Provisions>