

**Pacific Atlantic Terminals – Martinez Terminal – Facility #A7034
Semi-Annual Monitoring Report
Period: 1 MAR 12 Through 31 AUG 12**

**Table VII- A
S-1 Through S-10 - Fixed Roof Tanks**

Type of Limit	Citation of Limit	FE Y/N	Periods of Deviation	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type
POC	BAAQMD 8-5-303.1	Y	None	PV valve set pressure within 10% of working pressure or at least 0.5 psig	BAAQMD 8-5-403	P/SA	Inspection
POC	BAAQMD 8-5-303.2	Y	None	gas tight (< 500 ppm) except when operating pressure exceeds the valve set pressure	BAAQMD 8-5-403	P/SA	Inspection
POC	BAAQMD 8-5-306	Y	NOV A51594 3/29/12/S- 2,3,5,6,9,10 DEV. 06F30 5/18/12/S- 2,3,5,6,7,9,10 DEV. 06F80 6/20/12/S- 2,3,5,6,7,9,10	Controlled \geq 95% weight	BAAQMD Condition # 1253, part IV, Section 3b	C/A	Continuous Temperature Monitor and Source Test
POC	BAAQMD 8-5-328.1.2	Y	None	Tank cleaning \geq 90% control, POC concentration < 10,000 ppm	BAAQMD 8-5-602	P/A	Source Test
POC	Subpart K 40 CFR 60.112(a) (1)	Y	None	Vapor Recovery System	Subpart K 40 CFR 60.113(d) (2)	None	None
POC	BAAQMD Condition # 1253, part 1B	Y	None	94.811 tpy for all sources	BAAQMD Condition # 1253, part IIID	P/A	Records
POC	BAAQMD Condition # 1253, part IIID	Y	None	1.44 pounds/1000 barrels	BAAQMD Condition # 1253, part IV, Section 3	C	Continuous Temperature Monitor and Source Test
POC	BAAQMD Condition # 1253, part IID	Y	None	1400F in outlet or as determined by source test	BAAQMD Condition # 1253, part IID.1	C	Temperature Monitoring

**Table VII - B
S-11 – Fixed Roof Tanks**

Type of Limit	Citation of Limit	FE Y/N	Periods of Deviation	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type
POC	BAAQMD 8-5-303.1	Y	None	PV valve set pressure within 10% of working pressure or at least 0.5 psig	BAAQMD 8-5-403	P/SA	Inspection
POC	BAAQMD 8-5-303.2	Y	None	gas tight (< 500 ppm) except when operating pressure exceeds the valve set pressure	BAAQMD 8-5-403	P/SA	Inspection
POC	BAAQMD Condition # 1253, part 1B	Y	None	94.811 tpy for all sources	BAAQMD Condition # 1253, part IIID	P/A	Records
POC	BAAQMD Condition # 1253, part IID	Y	None	1400F in outlet or as determined by source test	BAAQMD Condition # 1253, part IID.1	C	Temperature Monitoring

Pacific Atlantic Terminals – Martinez Terminal – Facility #A7034
Semi-Annual Monitoring Report
Period: 1 MAR 12 Through 31 AUG 12

Table VII - C
S-12, S-18, and S-19 - Fixed Roof Tanks

Type of Limit	Citation of Limit	FE Y/N	Periods of Deviations	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type
POC	BAAQMD 8-5-303.1	Y	None	PV valve set pressure within 10% of working pressure or at least 0.5 psig	BAAQMD 8-5-403	P/SA	Inspection
POC	BAAQMD 8-5-303.2	Y	None	gas tight (< 500 ppm) except when operating pressure exceeds the valve set pressure	BAAQMD 8-5-403	P/SA	Inspection
POC	BAAQMD 8-5-306	Y	None	Controlled \geq 95% weight	BAAQMD Condition # 1253, part IV, Section 3b	C/A	Continuous Temperature Monitor and Source Test
POC	BAAQMD 8-5-328.1.2	Y	None	Tank cleaning \geq 90% control, POC concentration < 10,000 ppm	BAAQMD 8-5-502	P/A	Source Test
POC	BAAQMD Condition # 1253, part 1B	Y	None	94.811 tpy for all sources	BAAQMD Condition # 1253, part 11ID	P/A	Records
POC	BAAQMD Condition # 1253, part 11ID	Y	None	1.44 pounds/1000 barrels	BAAQMD Condition # 1253, part IV, Section 3	C/A	Continuous Temperature Monitor and Source Test
NOx	BAAQMD Condition # 1253, part 1B	Y	None	129.5 tpy for all sources	BAAQMD Condition # 1253, part 11ID	P/A	Records
NOx	BAAQMD Condition # 1253, part 11ID, schedule D	Y	None	9.66 lb/day plus 0.1744 pounds/1000 barrels	None	None	Source test
CO	BAAQMD Condition # 1253, part 1B	Y	None	52.2 tpy for all sources	BAAQMD Condition # 1253, part 11ID	P/A	Records
SO2	BAAQMD Condition # 1253, part 1B	Y	None	63.5 tpy for all sources	BAAQMD Condition # 1253, part 11ID	P/A	Records
FP	BAAQMD Condition # 1253, part 1B	Y	None	25.8 tpy for all sources	BAAQMD Condition # 1253, part 11ID	P/A	Records
POC	BAAQMD Condition # 1253, part 11D	Y	None	1400F. in outlet or as determined by source test	BAAQMD Condition # 1253, part IV, Section 3	C	Temperature Monitoring

Table VII - D
S-13, S-14, S-15, S-16 – External Floating Roof Tanks

Type of Limit	Citation of Limit	FE Y/N	Periods of Deviation	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type
POC	BAAQMD 8-5-320.3 1	Y	None	Gasketed cover, seal or lid with gap \leq 0.32 cm (1/8 in)	BAAQMD 8-5-401.2, 8-5-404	P/twice/yr	Inspection Certification

Pacific Atlantic Terminals – Martinez Terminal – Facility #A7034
Semi-Annual Monitoring Report
Period: 1 MAR 12 Through 31 AUG 12

Table VII - D							
S-13, S-14, S-15, S-16 – External Floating Roof Tanks							
Type of Limit	Citation of Limit	FE Y/N	Periods of Deviation	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type
	BAAQMD 8-5-320.4.2	Y	None	Well with cover, seal or lid with gap \leq 0.32 cm (1/8 in)	BAAQMD 8-5-401.2, 8-5-404	P/twice/yr	Inspection Certification
	BAAQMD 8-5-320.4.3	Y	None	Gap between well and roof less than 1.3 cm (1/2 in)	BAAQMD 8-5-401.2, 8-5-404	P/twice/yr	Inspection Certification
POC	BAAQMD 8-5-320.5.2	Y	None	Well with cover gasket, a pole sleeve, pole wiper, and internal float with gap \leq 1.3 cm (1/2 in), or zero gap pole wiper seal	BAAQMD 8-5-401.2, 8-5-404	P/twice/yr	Inspection Certification
	BAAQMD 8-5-320.5.3	Y	None	Gap between well and roof less than 1.3 cm (1/2 in)	BAAQMD 8-5-401.2, 8-5-404	P/twice/yr	Inspection Certification
POC	BAAQMD 8-5-321.3	Y	None	Primary seal metallic shoe extends a minimum 61 cm (24 in) above liquid surface	BAAQMD 8-5-401.1, 8-5-404	P/twice/yr	Inspection Certification
POC	BAAQMD 8-5-321.3.1	Y	None	Gap between shoe and tank shell is no greater than 46 cm (18 in)	BAAQMD 8-5-401.1, 8-5-404	P/twice/yr	Inspection Certification
POC	BAAQMD 8-5-321.3.2	Y	None	Gap between tank shell and the primary seal $<$ 3.8 cm (1 1/2 in). No continuous gap $>$ 0.32 cm (1/8 in) shall exceed 10% of circumference. The cumulative length of all seal gaps exceeding 1.3 cm (1/2 in) $<$ 10% of circumference and the cumulative length of all seal gaps exceeding 0.32 cm (1/8 in) $<$ 40% of circumference	BAAQMD 8-5-401.1, 8-5-404	P/twice/yr	Inspection Certification
POC	BAAQMD 8-5-322.2	Y	None	Secondary seal shall allow insertion up to 3.8 cm (1 1/2 in) in width	BAAQMD 8-5-401.1, 8-5-404	P/twice/yr	Inspection Certification
POC	BAAQMD 8-5-322.3	Y	None	Gap between tank shell and the secondary seal shall not exceed 1.3 cm (1/2 in)	BAAQMD 8-5-401.1, 8-5-404	P/10 yr P/twice/yr	Inspection Certification
POC	Subpart K, 40 CFR 60.112(a)(1)	Y	None	Floating Roof requirement	40 CFR 60.112(a),(b),(c)	None	Records
POC	BAAQMD Condition # 1253, part 1B	Y	None	94.811 tpy for all sources	BAAQMD Condition # 1253, part IID	P/A	Records

Table VII - F
S-21 – Marine Vessel Wharf

Type of Limit	Citation of Limit	FE Y/N	Periods of Deviation	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type
---------------	-------------------	--------	----------------------	-------	---------------------------------	------------------------------	-----------------

Pacific Atlantic Terminals – Martinez Terminal – Facility #A7034
Semi-Annual Monitoring Report
Period: 1 MAR 12 Through 31 AUG 12

Table VII - F
S-21 – Marine Vessel Wharf

Type of Limit	Citation of Limit	FE Y/N	Periods of Deviation	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type
POC	BAAQMD 8-44-304	Y	None	POC Emission \leq 5.7 grams per cubic meter (2 lb/1000 barrel) loaded, or emission control $>$ 95%	BAAQMD Condition # 1253, part IV, Section 3c	C/A	Continuous Temperature Monitor and Source Test
POC	SIP BAAQMD 8-44-301.1	Y	None	POC Emission \leq 5.7 grams per cubic meter (2 lb/1000 barrel) loaded, or	BAAQMD Condition # 1253, part IV, Section 3c	C/A	Continuous Temperature Monitor and Source Test
POC	SIP BAAQMD 8-44-301.2	Y	None	Controlled \geq 95% Weight	BAAQMD Condition # 1253, part IV, Section 3c	C/A	Continuous Temperature monitor and Source Test
POC	Subpart Y 40 CFR 63.562(c)(2)(III)	Y	None	Vapor tight	40 CFR 63.563(b)(4)	P/A	Leak test
POC	Subpart Y 40 CFR 63.562(c)(3)	Y	None	RACT existing source, controlled \geq 98% weight by combustion device	40 CFR 63.563(b)(5)(I)(A), 63.564(a)(3)	C/A	Continuous Temperature Monitor and Source Test
POC	Subpart Y 40 CFR 63.562(c)(4)	Y	None	VOC \leq 1000 ppmv	40 CFR 63.564(g)(1), BAAQMD Condition # 1253, part IV, Section 3c	C/A	Continuous Temperature Monitor and Source Test
POC	BAAQMD Condition # 1253, part 1B	Y	None	94.811 tpy for all sources	BAAQMD Condition # 1253, part III D	P/A	Records
POC	BAAQMD Condition # 1253 part IV, section 2	Y	None	95% controlled efficiency or 2 lb/ 1000 barrels of gasoline loaded	BAAQMD Condition # 1253, part IV, Section 2	C/A	Continuous Temperature Monitor and Source Test
POC	BAAQMD Condition # 1253 part IV, section 7	Y	None	Operating temperature \geq 1400°F unless modified by the District, based on source test results	BAAQMD Condition # 1253, part IV, Section 3c	C	Continuous temperature monitor
POC	BAAQMD Condition # 1253 part IV, section 9	Y	None	Loading pressure shall not exceed 80% of the lowest relief valve set pressure	None	None	Inspection
SO2	BAAQMD Regulation 9-1-303	Y	None	SO2 $<$ 2000 ppm, or Sulfur $<$ 3.34% by weight	BAAQMD Condition # 1253, part III D, schedule F	P/Q	Analysis reports
Temperature limit	BAAQMD Condition #1253, part III D	Y	None	1400F in outlet or as determined by source test	BAAQMD Condition # 1253, part IV, Section 3	C	Temperature monitoring

Table VII - G
S-23, S-24 – Oily Water Separators

Pacific Atlantic Terminals – Martinez Terminal – Facility #A7034
Semi-Annual Monitoring Report
Period: 1 MAR 12 Through 31 AUG 12

Type of Limit	Citation of Limit	FE Y/N	Periods of Deviation	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type
POC	BAAQMD Condition # 1253, part 1B	Y	None	94.811 tpy for all sources	BAAQMD Condition # 1253, part IID	P/A	Records
POC	BAAQMD 8-8-301.1	Y	None	<1/8" gap on OWS	NA	P	Inspection

Table VII – H
S-27, and S-28 - Fixed Roof Tanks

Type of Limit	Citation of Limit	FE Y/N	Periods of Deviation	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type
POC	BAAQMD 8-5-303.1	Y	None	PV valve set pressure within 10% of working pressure or at least 0.5 psig	BAAQMD 8-5-403	P/A	Inspection
POC	BAAQMD 8-5-303.2	Y	None	gas tight (< 500 ppm) except when operating pressure exceeds the valve set pressure	BAAQMD 8-5-403	P/A	Inspection
POC	BAAQMD 8-5-306	Y	NOV A51594 3/29/12/S-27,28 DEV. 06F30 5/18/12/S-27,28 DEV. 06F80 6/20/12/S-27	Controlled \geq 95% weight	BAAQMD Condition # 1253, part IV, Section 3b	C/A	Continuous Temperature Monitor and Source Test
POC	BAAQMD 8-5-328.1.2	Y	None	Tank cleaning \geq 90% control. POC concentration < 10,000 ppm	BAAQMD 8-5-502	P/A	Source Test
POC	Subpart Ka 40 CFR 60.112(a) (a)(3)	Y	NOV A51594 3/29/12/S-27,28 DEV. 06F30 5/18/12/S-27,28 DEV. 06F80 6/20/12/S-27	Controlled \geq 95%	N	N	None
POC	BAAQMD Condition # 1253, part 1B	Y	None	94.811 tpy for all sources	BAAQMD Condition # 1253, part IID	P/A	Records
POC	BAAQMD Condition # 1253, part IID	Y	None	1.44 pounds/1000 barrels	BAAQMD Condition # 1253, part IV, Section 3	C/A	Continuous Temperature Monitor and Source Test
NOx	BAAQMD Condition # 1253, part 1B	Y	None	129.5 tpy for all sources	BAAQMD Condition # 1253, part IID	P/A	Records
NOx	BAAQMD Condition # 1253, part IID, schedule D	Y	None	9.68 lb/day plus 0.1744 pounds/1000 barrels	None	C/A	Continuous Temperature Monitor and Source Test
CO	BAAQMD Condition # 1253, part 1B	Y	None	52.2 tpy for all sources	BAAQMD Condition # 1253, part IID	P/A	Records
SO2	BAAQMD Condition # 1253, part 1B	Y	None	33.5 tpy for all sources	BAAQMD Condition # 1253, part IID	P/A	Records

**Pacific Atlantic Terminals – Martinez Terminal – Facility #A7034
Semi-Annual Monitoring Report
Period: 1 MAR 12 Through 31 AUG 12**

**Table VII - H
S-27, and S-28 - Fixed Roof Tanks**

Type of Limit	Citation of Limit	FE Y/N	Periods of Deviation	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type
FP	BAAQMD Condition # 1253, part IB	Y	None	25.6 tpy for all sources	BAAQMD Condition # 1253, part IID	P/A	Records
POC	BAAQMD Condition # 1253, part IID	Y	None	1400F in outlet or as determined by source test	BAAQMD Condition # 1253, part IV, Section 3	C	Temperature monitoring

**Table VII - I
S-73 - Direct Fired Heater**

Type of Limit	Citation of Limit	FE Y/N	Periods of Deviation	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type
Usage	BAAQMD Condition # 13720, part 1	Y	None	Natural gas < 90 M SCF/ 12 months	BAAQMD Condition # 13720, part B	P/M	Flow meter
SO2	BAAQMD Regulation 9-1-301	Y	None	GLC > 0.5 ppm continuously for 3 consecutive minutes or 0.25 ppm averaged over 60 consecutive minutes or 0.05 ppm averaged over 24 hrs	None	N	None
SO2	SIP BAAQMD Regulation 9-1-302	Y	None	≤ 300 ppm SO2, dry	None	N	None
SO2	SIP BAAQMD Regulation 9-1-304	Y	None	≤ 0.5% by weight, fuel sulfur concentration	BAAQMD Condition # 13720, part 7	P/E	Sulfur certification or analysis
SO2	BAAQMD Condition # 1253, part IB	Y	None	33.5 tpy for all sources	BAAQMD Condition # 1253, part IID	P/A	Records
SO2	BAAQMD Condition # 1253, part IID, schedule D	Y	None	0.6 lb/MM cu ft of natural gas burned	BAAQMD Condition # 13720, part 7	P/E	Sulfur certification or analysis
NOx	BAAQMD Regulation 9-7-301.1	N	None	30 ppmv dry, @ 3% O2	BAAQMD Condition # 13720, part 5	P/A	Source Test
NOx	BAAQMD Regulation 9-7-305.1	N	None	150 ppmv dry, @ 3% O2	BAAQMD Condition # 13720, part 5	P/A	Source Test
NOx	BAAQMD Regulation 9-7-308.1	N	None	150 ppmv dry, @ 3% O2	BAAQMD Condition # 13720, part 5	P/A	Source test
NOx	BAAQMD Condition # 1253, part IB	Y	None	129.5 tpy for all sources	BAAQMD Condition # 1253, part IID	P/A	Records

Pacific Atlantic Terminals – Martinez Terminal – Facility #A7034
Semi-Annual Monitoring Report
Period: 1 MAR 12 Through 31 AUG 12

Table VII - I
S-73 – Direct Fired Heater

Type of Limit	Citation of Limit	FE Y/N	Periods of Deviation	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type
NOx	BAAQMD Condition # 1253, part IID, schedule D	Y	None	100 lb/MM cu ft of natural gas burned	BAAQMD Condition # 1253, part IID	P/A	Records
NOx	BAAQMD Condition # 13720, Part 2	Y	None	20 ppm @ 3% O2	BAAQMD Condition # 13720, part 5	P/A	Source Test
CO	BAAQMD Regulation 8-7-301.2	N	None	400 ppmv dry, @ 3% CO2	BAAQMD Condition # 13720, part 5	P/A	Source Test
CO	BAAQMD Regulation 9-7-305.2	N	None	400 ppmv dry, @ 3% CO2	BAAQMD Condition # 13720, part 5	P/A	Source Test
CO	BAAQMD Regulation 9-7-306.2	N	None	400 ppmv dry, @ 3% CO2	BAAQMD Condition # 13720, part 5	P/A	Source Test
CO	BAAQMD Condition # 1253, part IB	Y	None	52.2 tpy for all sources	BAAQMD Condition # 1253, part IID	P/A	Records
CO	BAAQMD Condition # 1253, part IID, Schedule D	Y	None	84 lb/MM cu ft of natural gas burned	BAAQMD Condition #1253, part IID	P/A	Records
CO	BAAQMD Condition # 13720, part 3	Y	None	50 ppmv @ 3 % O2	BAAQMD Condition # 13720, part 5	P/A	Source test
POC	BAAQMD Condition # 1253, part 1B	Y	None	94.611 tpy for all sources	BAAQMD Condition # 1253, part IID	P/A	Records
POC	BAAQMD Condition # 1253, part IID, schedule D	Y	None	5.5 lb/MM cu ft of natural gas burned	BAAQMD Condition # 1253, part IID	P/A	Records
FP	BAAQMD 6-301	Y	None	Visible emission must not be dark or darker than Ringelmann No. 1 for a period of more than 3 minutes in any hour	None	N	N
FP	BAAQMD 6-304	Y	None	During tube cleaning, visible emissions must not be dark or darker than Ringelmann No. 2 for a period of more than 6 minutes in 24 hours	None	N	N
FP	BAAQMD 6-310.3	Y	None	Particulate Matter < 343 mg per decm (0.15 gr/dscf) @ 6% oxygen volume	None	N	N
FP	BAAQMD Condition # 1253, part IB	Y	None	25.9 tpy for all sources	BAAQMD Condition # 1253, part IID	P/A	Records

Pacific Atlantic Terminals – Martinez Terminal – Facility #A7D34
Semi-Annual Monitoring Report
Period: 1 MAR 12 Through 31 AUG 12

Table VII - J
S-74 and S-75 Emergency Diesel Generators

Type of Limit	Citation of Limit	FE Y/N	Periods of Deviation	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type
FP	BAAQMD Regulation 6-303.1	Y	None	Ringelmann 2.0	BAAQMD Regulation 6-401	C	Visible Inspection
FP	BAAQMD Regulation 6-310.1	Y	None	0.15 gr/dscf	None	N	N/A
SO ₂	BAAQMD Regulation 9-1-301	Y	None	Property Line Ground Level Limits: < 0.5 ppm for 3 minutes and < 0.25 ppm for 80 min. and < 0.05 ppm for 24 hours	None	N	N/A
SO ₂	BAAQMD Regulation 9-1-304	Y	None	Fuel Sulfur Limit 0.5%	None	P/M	Vendor Certification
Operating time	BAAQMD Condition # 19306, Part 2	Y	None	100 hours per year	BAAQMD Condition # 19306, Part 4	P/D	Records
Operating Time	ATCM Section 93115, Title 17	Y	None	If gr/bhp-hr>0.40 allows 20 hr/yr; If gr/bhp-hr>0.15 and < 0.40 allows 21-30 hr/yr; If gr/bhp-hr>0.01 and < 0.15 allows 51-50 hrs/yr; If gr/bhp-hr<0.01 allows 51-100 hrs/yr	ATCM Section 93115, Title 17	P/E	Records

Table VII - K
S-76, S-77 and S-78 - Internal Floating Roof Tanks

Type of Limit	Citation of Limit	FE Y/N	Periods of Deviation	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type
POC	BAAQMD 8-5-303.1	Y	None	PSV set within 10% of max. pressure or 25.8 mmHg (0.5 psia)	BAAQMD 8-5-403 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification
POC	BAAQMD 8-5-320.3.1	Y	None	Gasket cover ≤ 0.32 cm (1/8 in) gap	BAAQMD 8-5-402.3 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification
POC	BAAQMD 8-5-320.3.2	Y	None	Inaccessible opening no visible gap	BAAQMD 8-5-402.3 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification
POC	BAAQMD 8-5-320.4.2	Y	None	Solid sampling or gauging wells. In closed position with cover, seal or lid ≤ 0.32 cm (1/8 in)	BAAQMD 8-5-402.3 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification
POC	BAAQMD 8-5-320.4.3	Y	None	Solid sampling or gauging wells: Gap between well and roof shall be added to gaps measured ≤ 1.3 cm (1/2 in)	BAAQMD 8-5-402.3 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification

Pacific Atlantic Terminals – Martinez Terminal – Facility #A7034
Semi-Annual Monitoring Report
Period: 1 MAR 12 Through 31 AUG 12

Table VII - K
S-76, S-77 and S-78 - Internal Floating Roof Tanks

Type of Limit	Citation of Limit	FE Y/N	Periods of Deviation	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type
POC	BAAQMD 8-5-320.5.2	Y	None	Slotted sampling or gauging wells in closed position with cover, seal or lid \leq 1.3 cm (1/2 in)	BAAQMD 8-5-402.2 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification
POC	BAAQMD 8-5-320.5.3	Y	None	Slotted sampling or gauging wells: Gap between well and roof shall be added to gaps measured \leq 1.3 cm (1/2 in)	BAAQMD 8-5-402.2 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification
POC	BAAQMD 8-5-320.6	Y	None	Emergency roof drain with slotted membrane fabric cover \geq 90% opening area	BAAQMD 8-5-402 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification
POC	BAAQMD 8-5-321.1	Y	None	No holes, tears or other openings in the primary seal fabric	BAAQMD 8-5-402.2 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification
POC	BAAQMD 8-5-321.2	Y	None	Primary seal metallic shoe or liquid mounted type	BAAQMD 8-5-402.1 & 8-5-404	P/10 yr P/10 yr	Inspection Certification
POC	BAAQMD 8-5-321.3	Y	None	Primary seal metallic shoe extends minimum 51 cm (24 in) for external floating and 18 in for internal Floating Roof tank above liquid surface	BAAQMD 8-5-401, & 8-5-404	P/10 yr P/10 yr	Inspection Certification
POC	BAAQMD 8-5-321.3.1	Y	None	Gap between shoe and tank shell is no greater than 46 cm (18 in)	BAAQMD 8-5-401, & 8-5-404	P/10 yr P/10 yr	Inspection Certification
POC	BAAQMD 8-5-321.3.2	Y	None	For welded tanks, gap between tank shell and the primary seal $<$ 3.8 cm (1 1/2 in). No continuous gap $>$ 0.32 cm (1/8 in) shall exceed 10% of circumference. The cumulative length of all seal gaps exceeding 1.3 cm (1/2 in) $<$ 10% of circumference and the cumulative length of all seal gaps exceeding 0.32 cm (1/8 in) $<$ 40% of circumference	BAAQMD 8-5-401, & 8-5-404	P/10 yr P/10 yr	Inspection Certification
POC	BAAQMD 8-5-322.1	Y	None	No holes, tears, or other openings	BAAQMD 8-5-402.2 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification
POC	BAAQMD 8-5-322.2	Y	None	Secondary seal shall allow insertion up to 3.8 cm (1 1/2 in) in width	BAAQMD 8-5-402.1 & 8-5-404	P/10 yr P/10 yr	Inspection Certification
POC	BAAQMD 8-5-322.3	Y	None	Gap between tank shell and the secondary seal shall not exceed 1.3 cm (1/2 in)	BAAQMD 8-5-402.1 & 8-5-404	P/10 yr P/10 yr	Inspection Certification
POC	BAAQMD 8-5-328.1.1	Y	None	Tank \geq 75 m ³ , tank cleaning shall have liquid balancing with \leq 0.5 psia	None	N	None

Pacific Atlantic Terminals – Martinez Terminal – Facility #A7034
Semi-Annual Monitoring Report
Period: 1 MAR 12 Through 31 AUG 12

Table VII - K
S-76, S-77 and S-78 - Internal Floating Roof Tanks

Type of Limit	Citation of Limit	FE Y/N	Periods of Deviation	Limit	Monitoring Requirement Citation	Monitoring Frequency (PIC/N)	Monitoring Type
POC	BAAQMD 8-5-320.1.2	Y	None	Tank ≥ 75 m ³ . Tank cleaning 90% control, POC concentration < 10,000 ppm	BAAQMD 8-5-502	P/A	Source Test
POC	Subpart Kb 40 CFR 60.113b (a)(2)	Y	None	No holes, tears or other openings	40 CFR 60.113b(a) (4)	P/A (Exempted and degassed)	Inspection
POC	BAAQMD Condition # 1253, part 1B	Y	None	94.611 tpy for all sources	BAAQMD Condition # 1253, part IIID	P/A	Records
POC	BAAQMD Condition # 20060, part 1	Y	None	Gasoline or other hydrocarbon liquids throughput < 105 million gal/yr for S-76, 77 and 78	BAAQMD Condition # 20060, part 6	P/M	Records
POC	BAAQMD Condition # 20060, part 2	Y	None	Gasoline or other hydrocarbon liquids throughput < 4.2 million gal/day for S-76, 77 and 78	BAAQMD # 20060, part 6	P/M	Records
POC	BAAQMD Condition # 20060, part 5	Y	None	S-76, 77, and 78 shall be abated by liquid mounted primary seal, and rim mounted secondary seal	BAAQMD 8-5-303	C	Install internal floating roof
POC	BAAQMD Condition # 20060, part 3	N	None	Benzene concentration < 1.8 % wt.	BAAQMD Condition # 20060, part 3	P/6 months	Sample
% circumference	BAAQMD 8-5-402.2	Y	None	Inspect entire circumference of secondary seal	BAAQMD 8-5-402.2	P/4 times per year	Inspection

Table VII - L
S-79 and S-80 - Internal Floating Roof Tanks

Type of Limit	Citation of Limit	FE Y/N	Periods of Deviation	Limit	Monitoring Requirement Citation	Monitoring Frequency (PIC/N)	Monitoring Type
POC	BAAQMD 8-5-303.1	Y	None	PSV set within 10% of max. pressure or 25.8 mmHg (0.5 psia)	BAAQMD 8-5-403 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification
POC	BAAQMD 8-320.3.1	Y	None	Gasket cover \leq 0.32 cm (1/8 in) gap	BAAQMD 8-5-402.3 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification
POC	BAAQMD 8-320.3.2	Y	None	Inaccessible opening no visible gap	BAAQMD 8-5-402.3 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification
POC	BAAQMD 8-5-320.4.2	Y	None	Solid sampling or gauging wells in closed position with cover, seal or lid \leq 0.32 cm (1/8 in)	BAAQMD 8-5-402.3 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification
POC	BAAQMD 8-5-320.4.3	Y	None	Solid sampling or gauging wells: Gap between well and roof shall be added to gaps measured \leq 1.3 cm (1/2 in)	BAAQMD 8-5-402.3 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification

Pacific Atlantic Terminals – Martinez Terminal – Facility #A7034
Semi-Annual Monitoring Report
Period: 1 MAR 12 Through 31 AUG 12

Table VII - L
S-79 and S-80 - Internal Floating Roof Tanks

Type of Limit	Citation of Limit	FE Y/N	Periods of Deviation	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type
POC	BAAQMD 8-5-320.5.2	Y	None	Slotted sampling or gauging wells in closed position with cover, seal or lid \leq 1.3 cm (1/2 in)	BAAQMD 8-5-402.2 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification
POC	BAAQMD 8-5-320.5.3	Y	None	Slotted sampling or gauging wells: Gap between well and roof shall be added to gaps measured \leq 1.3 cm (1/2 in)	BAAQMD 8-5-402.2 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification
POC	BAAQMD 8-5-320.6	Y	None	Emergency roof drain with slotted membrane fabric cover \geq 90% opening area	BAAQMD 8-5-402 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification
POC	BAAQMD 8-5-321.1	Y	None	No holes, tears or other openings in the primary seal fabric	BAAQMD 8-5-402.2 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification
POC	BAAQMD 8-5-321.2	Y	None	Primary seal metallic shoe or liquid mounted type	BAAQMD 8-5-402.1 & 8-5-404	P/10 yr P/10 yr	Inspection Certification
POC	BAAQMD 8-5-321.3	Y	None	Primary seal metallic shoe extends minimum 61 cm (24 in) for external floating and 18 in for internal Floating Roof tank above liquid surface	BAAQMD 8-5-401, & 8-5-404	P/10 yr P/10 yr	Inspection Certification
POC	BAAQMD 8-5-321.3.1	Y	None	Gap between shoe and tank shell is no greater than 46 cm (18 in)	BAAQMD 8-5-401, & 8-5-404	P/10 yr P/10 yr	Inspection Certification
POC	BAAQMD 8-5-321.3.2	Y	None	For welded tanks, gap between tank shell and the primary seal $<$ 3.8 cm (1 1/2 in). No continuous gap $>$ 0.32 cm (1/8 in) shall exceed 10% of circumference. The cumulative length of all seal gaps exceeding 1.3 cm (1/2 in) $<$ 10% of circumference and the cumulative length of all seal gaps exceeding 0.32 cm (1/8 in) $<$ 40% of circumference	BAAQMD 8-5-401, & 8-5-404	P/10 yr P/10 yr	Inspection Certification
POC	BAAQMD 8-5-322.1	Y	None	No holes, tears, or other openings	BAAQMD 8-5-402.2 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification
POC	BAAQMD 8-5-322.2	Y	None	Secondary seal shall allow insertion up to 3.8 cm (1 1/2 in) in width	BAAQMD 8-5-402, & 8-5-404	P/10 yr P/10 yr	Inspection Certification
POC	BAAQMD 8-5-322.3	Y	None	Gap between tank shell and the secondary seal shall not exceed 1.3 cm (1/2 in)	BAAQMD 8-5-402, & 8-5-404	P/10 yr P/10 yr	Inspection Certification
POC	BAAQMD 8-5-328.1	Y	None	Tank \geq 75 m ³ , tank degassing until less than 10,000 ppm	None	N	None

Pacific Atlantic Terminals – Martinez Terminal – Facility #A7034
Semi-Annual Monitoring Report
Period: 1 MAR 12 Through 31 AUG 12

Table VII - L
S-79 and S-80 - Internal Floating Roof Tanks

Type of Limit	Citation of Limit	FE Y/N	Periods of Deviation	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type
POC	BAAQMD 8-5-328.2	Y	None	Tank ≥ 75 m ³ , Tank cleaning 90% control, POC concentration < 10,000 ppm	BAAQMD 8-5-502	P/A	Source Test
POC	Subpart Kb 40 CFR 60.113b (a)(2)	Y	None	No holes, tears or other openings	40 CFR 60.113b(a) (4)	P/A/ E(emptied and degassed)	Inspection
POC	BAAQMD Condition # 1253, part 1B	Y	None	94.811 tpy for all sources	BAAQMD Condition # 1253, part IIIID	P/A	Records
POC	BAAQMD Condition # 21829, part 1	Y	None	Gasoline or other hydrocarbon liquids throughput < 403.2 million gal/yr for S-79 and 80	BAAQMD Condition # 21829, part 6	P/M	Records
POC	BAAQMD Condition # 21829, part 2	Y	None	Gasoline or other hydrocarbon liquids throughput < 8,556 lb/yr for S-79 and 80	BAAQMD # 21829, part 6	P/M	Records
POC	BAAQMD Condition # 21829, part 3	Y	None	S-79 and 80 shall be abated by liquid mounted primary seal, and rim mounted secondary seal	BAAQMD 8-5-303	C	Install internal floating roof
POC	BAAQMD Condition # 21829, part 4	N	None	Benzene concentration < 1.4 % wt.	BAAQMD Condition # 21829, part 4	P/6 months	Sample
% circumference	BAAQMD 8-5-402.2	Y	None	Inspect entire circumference of secondary seal	BAAQMD 8-5-402.2	P/4 times per year	Inspection

Table VII - M
Applicable Limits and Compliance Monitoring Requirements
S-81, S-82, AND S-83 - INTERNAL FLOATING ROOF TANKS

Type of Limit	Citation of Limit	FE Y/N	Periods of Deviation	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type
POC	BAAQMD 8-5-303.1	Y	None	PSV set within 10% of max pressure or 25.8 mmHg (0.5 psia)	BAAQMD 8-5-403 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification
POC	BAAQMD 8-320.3.1	Y	None	Gasket cover \leq 0.32 cm (1/8 in) gap	BAAQMD 8-5-402.3 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification
POC	BAAQMD 8-320.3.2	Y	None	Inaccessible opening no visible gap	BAAQMD 8-5-402.3 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification
POC	BAAQMD 8-5-320.4.2	Y	None	Solid sampling or gauging walls in closed position with cover, seal or lid \leq 0.32 cm (1/8 in)	BAAQMD 8-5-402.3 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification
POC	BAAQMD 8-5-320.4.3	Y	None	Solid sampling or gauging walls: Gap between wall and roof shall be added to gaps measured \leq 1.3 cm (1/2 in)	BAAQMD 8-5-402.3 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification
POC	BAAQMD 8-5-320.5.2	Y	None	Sloped sampling or gauging walls in closed position with cover, seal or lid \leq 1.3 cm (1/2 in)	BAAQMD 8-5-402.2 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification

Pacific Atlantic Terminals – Martinez Terminal – Facility #A7034
Semi-Annual Monitoring Report
Period: 1 MAR 12 Through 31 AUG 12

Table VII – M
Applicable Limits and Compliance Monitoring Requirements
S-81, S-82, AND S-83 - INTERNAL FLOATING ROOF TANKS

Type of Limit	Citation of Limit	FE Y/N	Periods of Deviation	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type
POC	BAAQMD 8-5-320.5.3	Y	None	Slotted sampling or gauging wells: Gap between well and roof shall be added to gaps measured ≤ 1.3 cm (1/2 in)	BAAQMD 8-5-402.2 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification
POC	BAAQMD 8-5-320.6	Y	None	Emergency roof drain with slotted membrane fabric cover $> 90\%$ opening area	BAAQMD 8-5-402 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification
POC	BAAQMD 8-5-321.1	Y	None	No holes, tears or other openings in the primary seal fabric	BAAQMD 8-5-402.2 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification
POC	BAAQMD 8-5-321.2	Y	None	Primary seal metallic shoe or liquid mounted type	BAAQMD 8-5-402.1 & 8-5-404	P/10 yr P/10 yr	Inspection Certification
POC	BAAQMD 8-5-321.3	Y	None	Primary seal metallic shoe extends minimum 61 cm (24 in) for external floating and 18 in for internal floating roof tank above liquid surface	BAAQMD 8-5-401, 8-5-404	P/10 yr P/10 yr	Inspection Certification
POC	BAAQMD 8-5-321.3.1	Y	None	Gap between shoe and tank shell is no greater than 46 cm (18 in)	BAAQMD 8-5-401, 8-5-404	P/10 yr P/10 yr	Inspection Certification
POC	BAAQMD 8-5-321.3.2	Y	None	For welded tanks, gap between tank shell and the primary seal < 3.8 cm (1 1/2 in). No continuous gap > 0.32 cm (1/8 in) shall exceed 10% of circumference. The cumulative length of all seal gaps exceeding 1.3 cm (1/2 in) $< 10\%$ of circumference and the cumulative length of all seal gaps exceeding 0.32 cm (1/8 in) $< 40\%$ of circumference	BAAQMD 8-5-401, 8-5-404	P/10 yr P/10 yr	Inspection Certification
POC	BAAQMD 8-5-322.1	Y	None	No holes, tears, or other openings	BAAQMD 8-5-402.2 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification
POC	BAAQMD 8-5-322.2	Y	None	Secondary seal shall allow insertion up to 3.8 cm (1 1/2 in) in width	BAAQMD 8-5-402, & 8-5-404	P/10 yr P/10 yr	Inspection Certification
POC	BAAQMD 8-5-322.3	Y	None	Gap between tank shell and the secondary seal shall not exceed 1.3 cm (1/2 in)	BAAQMD 8-5-402, & 8-5-404	P/10 yr P/10 yr	Inspection Certification
POC	BAAQMD 8-5-328.1.1	Y	None	Tank ≥ 75 m ³ , tank cleaning shall have liquid balancing with < 0.5 psia	None	N	None
POC	BAAQMD 8-5-328.1.2	Y	None	Tank ≥ 75 m ³ , Tank cleaning 80% control, POC concentration $< 10,000$ ppm	BAAQMD 8-5-502	P/A	Source Test
POC	Subpart Kb 40 CFR 60.113b (B)(2)	Y	None	No holes, tears or other openings	40 CFR 60.113b(a) (4)	P/A/ E (emptied and degassed)	Inspection
POC	BAAQMD Condition # 1253, part IB	Y	None	84.811 tpy for all sources	BAAQMD Condition # 1253, part IID	P/A	Records

Pacific Atlantic Terminals – Martinez Terminal – Facility #A7034
Semi-Annual Monitoring Report
Period: 1 MAR 12 Through 31 AUG 12

Table VII – M
Applicable Limits and Compliance Monitoring Requirements
S-81, S-82, AND S-83 - INTERNAL FLOATING ROOF TANKS

Type of Limit	Citation of Limit	FE Y/N	Periods of Deviation	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type
POC	BAAQMD Condition # 22788, part 1	Y	None	Non-exempt organic liquids throughput \leq 453.6 million gal/yr for S-81, 82, and 83	BAAQMD Condition # 22788, part 7	P/M	Records
POC	BAAQMD Condition # 22788, part 2	Y	None	Gasoline or other organic liquids POC emission \leq 13.56t lb/yr for S-81, 82, and 83	BAAQMD # 22788, part 7	P/M	Records
POC	BAAQMD Condition # 22788, part 3	Y	None	S-81, 82, and 83 shall be abated by liquid mounted primary seal, and rim mounted secondary seal	BAAQMD 8-5-305	C	Install Internal Floating roof
POC	BAAQMD Condition # 22788, part 4	N	None	Benzene concentration \leq 1.4 % wt.	BAAQMD Condition # 22788, part 4	P/6 months	Sample
% circumference	BAAQMD 8-5-402.2	Y	None	Inspect entire circumference of secondary seal	BAAQMD 8-5-402.2	P/4 times per year	Inspection

Table VII – N
Applicable Limits and Compliance Monitoring Requirements
S-84, S-85, S-86, S-87, S-88, S-89, AND S-90 - INTERNAL FLOATING ROOF TANKS

Type of Limit	Citation of Limit	FE Y/N	Periods of Deviation	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type
POC	BAAQMD 8-5-303.1	Y	None	PSV set within 10% of max pressure or 25.8 mmHg (0.5 psia)	BAAQMD 8-5-403 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification
POC	BAAQMD 8-5-320.3.1	Y	None	Gasket cover \leq 0.32 cm (1/8 in) gap	BAAQMD 8-5-402.3 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification
POC	BAAQMD 8-5-320.3.2	Y	None	Inaccessible opening no visible gap	BAAQMD 8-5-402.3 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification
POC	BAAQMD 8-5-320.4.2	Y	None	Solid sampling or gauging wells in closed position with cover, seal or lid \leq 0.32 cm (1/8 in)	BAAQMD 8-5-402.3 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification
POC	BAAQMD 8-5-320.4.3	Y	None	Solid sampling or gauging wells: Gap between well and roof shall be added to gaps measured \leq 1.3 cm (1/2 in)	BAAQMD 8-5-402.3 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification
POC	BAAQMD 8-5-320.5.2	Y	None	Slotted sampling or gauging wells in closed position with cover, seal or lid \leq 1.3 cm (1/2 in)	BAAQMD 8-5-402.2 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification
POC	BAAQMD 8-5-320.5.3	Y	None	Slotted sampling or gauging wells: Gap between well and roof shall be added to gaps measured \leq 1.3 cm (1/2 in)	BAAQMD 8-5-402.2 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification
POC	BAAQMD 8-5-320.6	Y	None	Emergency roof drain with slotted membrane fabric cover $>$ 80% opening area	BAAQMD 8-5-402 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification
POC	BAAQMD 8-5-321.1	Y	None	No holes, tears or other openings in the primary seal fabric	BAAQMD 8-5-402.2 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification

Pacific Atlantic Terminals – Martinez Terminal – Facility #A7034
Semi-Annual Monitoring Report
Period: 1 MAR 12 Through 31 AUG 12

Table VII – N
Applicable Limits and Compliance Monitoring Requirements
S-84, S-85, S-86, S-87, S-88, S-89, AND S-90 - INTERNAL FLOATING ROOF TANKS

Type of Limit	Citation of Limit	FE Y/N	Periods of Deviation	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type
POC	BAAQMD 8-5-321.2	Y	None	Primary seal metallic shoe or liquid mounted type	BAAQMD 8-5-402.1 & 8-5-404	P/10 yr P/10 yr	Inspection Certification
POC	BAAQMD 8-5-321.3	Y	None	Primary seal metallic shoe extends minimum 61 cm (24 in) for external floating and 18 in for internal floating roof tank above liquid surface	BAAQMD 8-5-401, 8-5-404	P/10 yr P/10 yr	Inspection Certification
POC	BAAQMD 8-5-321.3.1	Y	None	Gap between shoe and tank shell is no greater than 46 cm (18 in)	BAAQMD 8-5-401, 8-5-404	P/10 yr P/10 yr	Inspection Certification
POC	BAAQMD 8-5-321.3.2	Y	None	For welded tanks, gap between tank shell and the primary seal < 3.8 cm (1 1/2 in). No continuous gap > 0.32 cm (1/8 in) shall exceed 10% of circumference. The cumulative length of all seal gaps exceeding 1.3 cm (1/2 in) < 10% of circumference and the cumulative length of all seal gaps exceeding 0.32 cm (1/8 in) < 40% of circumference	BAAQMD 8-5-401, 8-5-404	P/10 yr P/10 yr	Inspection Certification
POC	BAAQMD 8-5-322.1	Y	None	No holes, tears, or other openings	BAAQMD 8-5-402.2 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification
POC	BAAQMD 8-5-322.2	Y	None	Secondary seal shall allow insertion up to 3.8 cm (1 1/2 in) in width	BAAQMD 8-5-402, & 8-5-404	P/10 yr P/10 yr	Inspection Certification
POC	BAAQMD 8-5-322.3	Y	None	Gap between tank shell and the secondary seal shall not exceed 1.3 cm (1/2 in)	BAAQMD 8-5-402, & 8-5-404	P/10 yr P/10 yr	Inspection Certification
POC	BAAQMD 8-5-328.1.1	Y	None	Tank ≥ 75 m ³ , tank cleaning shall have liquid balancing with < 0.5 psia	None	N	None
POC	BAAQMD 8-5-328.1.2	Y	None	Tank ≥ 75 m ³ , Tank cleaning 90% control, POC concentration < 10,000 ppm	BAAQMD 8-5-502	P/A	Source Test
POC	Subpart Kb 40 CFR 60.113b (a)(2)	Y	None	No holes, tears or other openings	40 CFR 60.113b(a) (4)	P/A/ E (emptied and degassed)	Inspection
POC	BAAQMD Condition # 1253, part IB	Y	None	94.811 tpy for all sources	BAAQMD Condition # 1253, part IID	P/A	Records
POC	BAAQMD Condition # 23338, part 1	Y	None	Non-exempt organic liquids throughput ≤ 856.8 million gal/yr for S-84 through 90	BAAQMD Condition # 23338, part 7	P/M	Records
POC	BAAQMD Condition # 23338, part 2	Y	None	Gasoline or other organic liquids POC emission ≤ 33,178 lb/yr for S-84 through 90	BAAQMD # 23338, part 7	P/M	Records

**Pacific Atlantic Terminals – Martinez Terminal – Facility #A7034
Semi-Annual Monitoring Report
Period: 1 MAR 12 Through 31 AUG 12**

**Table VII – N
Applicable Limits and Compliance Monitoring Requirements
S-84, S-85, S-86, S-87, S-88, S-89, AND S-90 - INTERNAL FLOATING ROOF TANKS**

Type of Limit	Citation of Limit	FE Y/N	Periods of Deviation	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type
POC	BAAQMD Condition # 23336, part 3	Y	None	S-84 through 90 shall be abated by liquid mounted primary seal, and rim mounted secondary seal	BAAQMD 8-5-305	C	Install Internal floating roof
POC	BAAQMD Condition # 23336, part 4	N	None	Benzene concentration < 1.4 % wt.	BAAQMD Condition # 23336, part 4	P/6 months	Sample
% circumference	BAAQMD 8-5-402.2	Y	None	Inspect entire circumference of secondary seal	BAAQMD 8-5-402.2	P/4 times per year	Inspection

**Table VII - O
A-1- Thermal Oxidizer**

Type of Limit	Citation of Limit	FE Y/N	Periods of Deviation	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type
SO2	BAAQMD Regulation 9-1-301	Y	None	GLC > 0.5 ppm continuously for 3 consecutive minutes or 0.25 ppm averaged over 60 consecutive minutes or 0.05 ppm averaged over 24 hrs	None	N	
SO2	SIP BAAQMD Regulation 9-1-302	Y	None	≤ 300 ppm SO2, dry	None	N	
SO2	BAAQMD Condition # 1253, part 1B	Y	None	83.5 tpy for all sources	BAAQMD Condition # 1253, part 11D	P/A	Records
NOx	BAAQMD Condition # 1253, part 1B	Y	None	129.5 tpy for all sources	BAAQMD Condition # 1253, part 11D	P/A	Records
CO	BAAQMD Condition # 1253, part 1B	Y	None	52.2 tpy for all sources	BAAQMD Condition # 1253, part 11D	P/A	Records
POC	BAAQMD Condition # 1253, part 1B	Y	None	94.811 tpy for all sources	BAAQMD Condition # 1253, part 11D	P/A	Records
FP	BAAQMD 8-310.3	Y	None	Particulate Matter < 343 mg per dscm (0.15 gr/dscf)	None	N	N
FP	BAAQMD Condition # 1253, part 1B	Y	None	25.8 tpy for all sources	BAAQMD Condition # 1253, part 11D	P/A	Records

**Table VII - P
FACILITY**

Pacific Atlantic Terminals – Martinez Terminal – Facility #A7034
Semi-Annual Monitoring Report
Period: 1 MAR 12 Through 31 AUG 12

Type of Limit	Citation of Limit	FE Y/N	Periods of Deviation	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type
FP	BAAQMD Regulation 6-301	Y	None	Ringelmann 1 Limitation	BAAQMD Regulation 6-401	C	Visual Inspection
SO2	BAAQMD Regulation 9-1-301	Y	None	GLC > 0.5 ppm continuously for 3 consecutive minutes or 0.25 ppm averaged over 60 consecutive minutes or 0.05 ppm averaged over 24 hrs	None	N	Fuel Type
POC	BAAQMD Condition # 1253, part 1B	Y	None	94.811 tpy for all sources (except S-74 and S-75 Diesel IC Emergency Generator)	BAAQMD Condition # 1253, part 11D	P/A	Records
NOx	BAAQMD Condition # 1253, part 1B	Y	None	129.5 tpy for all sources (except S-74 and S-75 Diesel IC Emergency Generator)	BAAQMD Condition # 1253, part 11D	P/A	Records
CO	BAAQMD Condition # 1253, part 1B	Y	None	52.2 tpy for all sources (except S-74 and S-75 Diesel IC Emergency Generator)	BAAQMD Condition # 1253, part 11D	P/A	Records
SO2	BAAQMD Condition # 1253, part 1B	Y	None	83.5 tpy for all sources (except S-74 and S-75 Diesel IC Emergency Generator)	BAAQMD Condition # 1253, part 11D	P/A	Records
FP	BAAQMD Condition # 1253, part 1B	Y	None	25.8 tpy for all sources (except S-74 and S-75 Diesel IC Emergency Generator)	BAAQMD Condition # 1253, part 11D	P/A	Records

Table VII - Q
COMPONENTS

Type of Limit	Emission Limit Citation	FE Y/N	Periods of Deviation	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type
POC	BAAQMD Regulation 8-18-301	Y	None	Equipment leaks ≤ 100 ppm, except for valves, pumps, compressors, connections and pressure relief devices	BAAQMD Regulation 8-18-401	P/Q	Portable hydrocarbon detector, records
POC	BAAQMD Regulation 8-18-302	Y	None	Valves leaks ≤ 100 ppm	BAAQMD Regulation 8-18-401	P/Q	Portable hydrocarbon detector, records
POC	BAAQMD Regulation 8-18-303	Y	None	Pump, compressor leaks ≤ 500 ppm	BAAQMD Regulation 8-18-401	P/Q	Portable hydrocarbon detector, records
POC	BAAQMD Regulation 8-18-304	N	None	Connection leaks ≤ 100 ppm	BAAQMD Regulation 8-18-401	P/Q	Portable hydrocarbon detector, records
POC	BAAQMD Regulation 8-18-305	Y	None	Pressure relief valves ≤ 500 ppm	BAAQMD Regulation 8-18-401	P/Q	Portable hydrocarbon detector, records
POC	BAAQMD Regulation 8-18-306.1	Y	None	Non-repairable be replaced within 5 years or at next scheduled turnaround	None	N	
POC	BAAQMD Regulation 8-18-306.2	Y	None	Number awaiting repair < 0.5% valves, 1% pressure relief valves, 1% pump and compressor	None	N	

Pacific Atlantic Terminals – Martinez Terminal – Facility #A7034
Semi-Annual Monitoring Report
Period: 1 MAR 12 Through 31 AUG 12

Table VII - Q
COMPONENTS

Type of Limit	Emission Limit Citation	FE Y/N	Periods of Deviation	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type
POC	BAAQMD Regulation 8-18-306.3.2	Y	None	Valves < 0.1 lb/day and number awaiting repair (NAR) < 1.0%; Pressure relief valves < 0.2 lb/day and (NAR) < 5%; Pumps, compressors < 0.2 lb/day and (NAR) < 5%.	None	N	
POC	SIP BAAQMD Regulation 8-18-302	Y	None	Valves ≤ 100 ppm	SIP BAAQMD Regulation 8-18-401	P/Q	Portable hydrocarbon detector, records
POC	SIP BAAQMD Regulation 8-18-303	Y	None	Connectors ≤ 100 ppm	SIP BAAQMD Regulation 8-18-401	P/Q	Portable hydrocarbon detector, records
POC	SIP BAAQMD Regulation 8-18-304	Y	None	Non repairable valves ≤ 0.5 %	SIP BAAQMD Regulation 8-18-401	P/Q	Portable hydrocarbon detector, records
POC	SIP BAAQMD Regulation 8-25-302	Y	None	Pumps ≤ 500 ppm	SIP BAAQMD Regulation 8-25-401	P/Q	Portable hydrocarbon detector, records
POC	SIP BAAQMD Regulation 8-25-303	Y	None	Compressors ≤ 500 ppm	SIP BAAQMD Regulation 8-25-401	P/Q	Portable hydrocarbon detector, records
POC	SIP BAAQMD Regulation 8-25-304.1	Y	None	Pumps and compressors repair or replaced within 5 years or at the next scheduled turnaround	SIP BAAQMD Regulation 8-25-401	P/Q	Portable hydrocarbon detector, records
POC	SIP BAAQMD Regulation 8-25-304.2	Y	None	Non repairable pumps and compressors ≤ 1 %	SIP BAAQMD Regulation 8-25-401	P/Q	Portable hydrocarbon detector, records
POC	SIP BAAQMD Regulation 8-18-305	Y	None	New replaced pumps and compressor ≤ 500 ppm for 4 consecutive quarters	SIP BAAQMD Regulation 8-25-401	P/Q	Portable hydrocarbon detector, records
POC	SIP BAAQMD Regulation 8-25-305	Y	None	Repeat leakers ≤ 2 times in 12 months	SIP BAAQMD Regulation 8-25-401	P/Q	Portable hydrocarbon detector, records
POC	Subpart R 40 CFR 63.424(a)	Y	None	Vapor tight	40 CFR 63.563(a)(4)	P/A	Leak test

LEGEND


A = annual
C = continuous
CO = carbon monoxide
D = daily
E = event
FP = filterable particulate
M = monthly

N = no monitoring
P = periodic
POC = precursor organic compound
Q = quarterly
SA = semiannually
SIP = State Implementation Plan
SO₂ = sulfur dioxide

Pacific Atlantic Terminals – Martinez Terminal – Facility #A7034
Semi-Annual Monitoring Report
Period: 1 MAR 12 Through 31 AUG 12

Certification

The statements contained in this document are true, accurate, and complete based on information and belief formed after reasonable inquiry.



Troy E. Valenzuela
Vice President – EH&S

9-12-12
Date