

November 18, 2008

Ms. Deborah Jordan
Director, Air Division
United States Environmental Protection Agency
75 Hawthorne Street
San Francisco, CA 94105

Dear Ms. Jordan:

This is to advise you that the Bay Area Air Quality Management District is issuing the renewal Major Facility Review Permit for the following facility.

Facility	Facility Name	Application	Permit Engineer	City	County
A8664	Crockett Cogeneration, a California Limited Partnership	13143	K. Truesdell	Crockett	Contra Costa

The public comment and EPA review periods on the proposed renewal permit ran concurrently and ended on September 9, 2008. No comments were received from the public, EPA, or ARB. Crockett Cogeneration submitted comments requesting corrections to the following, which were made to the final revised permit:

- Telephone number for the Responsible Official
- Facility Contact name
- Primary SIC
- Table IV-B and Table IV-C BAAQMD Regulation 6, Rule 1 are not federally enforceable
- Table IV-C 40 CFR 60.46b(e)(1) requires performance test for NOx to be on a 30-day basis
- Table IV-C NSPS NOx CEMS citation is 40 CFR 60.48b(b)(1)
- Table VII-A 40 CFR 60.332(a)(1) NOx standard was recalculated based on performance test report submitted by Crockett Cogeneration and using the equation in 40 CFR 60.332(a)(1). The NOx standard was changed to 155.2 ppmvd @ 15% O2. The associated monitoring requirement was revised to 40 CFR 60.334(c), monitoring frequency was revised to continuous, monitoring type was revised to CEM.
- Table VII-B NSPS monitoring requirement was corrected to 40 CFR 60.49Da(o).

The following corrections and updates were made due to amended BAAQMD Regulation 9, Rule 9 and Rule 7.

- Table IV-A BAAQMD Regulation 9-9-301.2 was added
- Table IV-C BAAQMD Regulation 9-7 future effective requirements were added. SIP Regulation 9-7 was added for applicable federally enforceable sections.

ALAMEDA COUNTY

Tom Bates
Scott Haggerty
Janet Lockhart
Nate Miley

CONTRA COSTA COUNTY

John Gioia
Mark Ross
Michael Shimansky
Gayle B. Uilkema

MARIN COUNTY

Harold C. Brown, Jr.

NAPA COUNTY

Brad Wagenknecht
(Secretary)

SAN FRANCISCO COUNTY

Chris Daly
Jake McGoldrick
Gavin Newsom

SAN MATEO COUNTY

Jerry Hill
(Chair)
Carol Klatt

SANTA CLARA COUNTY

Erin Garner
Yoriko Kishimoto
Liz Kniss
Ken Yeager

SOLANO COUNTY

John F. Silva

SONOMA COUNTY

Tim Smith
Pamela Torliatt
(Vice-Chair)

Jack P. Broadbent
EXECUTIVE OFFICER/APCO

The District has decided to issue the renewal permit. The final permit can be viewed and/or downloaded on the BAAQMD website at http://www.baaqmd.gov/pmt/title_v/public_notices.htm . We will also send the final permit to you via the Electronic Permit Submittal System. If you have any questions regarding this permit, please call Barry Young, Air Quality Engineering Manager, at (415) 749-4721.

Sincerely yours,

Signed by Jeff McKay for Jack P. Broadbent
Jack P. Broadbent
Executive Officer/Air Pollution Control Officer

JPB:BFB:DTJ

H:\Engineering\TITLE V Permit Appls\1 ALL T5 Application Files here\A8664\Renew -13143\1.0 Working docs\A8664_13143_Issltr.DOC