

April 23, 2007

Ms. Deborah Jordan
Director, Air Management Division
United States Environmental Protection Agency
75 Hawthorne Street
San Francisco, CA 94105

Dear Ms. Jordan:

This to advise you that the Bay Area Air Quality Management District is issuing a significant revision to the Major Facility Review Permit for the following facility.

ALAMEDA COUNTY

Tom Bates
Scott Haggerty
Janet Lockhart
Nate Miley

| Facility | Facility Name | Application | Permit Engineer | City | County |
|----------|--------------------------------|-------------|-----------------|-------------|--------|
| B4416 | Goose Haven Energy Center, LLC | 11004 | A. Chiu | Suisun City | Solano |

CONTRA COSTA COUNTY

John Gioia
Mark Ross
(Chair)
Michael Shimansky
Gayle B. Uilkema

The purpose of the significant revision (Application #11004) was to make the following changes:

1. Clarify the definition of hours to "Clock" hours with any consecutive 60 minute period "beginning on the hour"
2. Condition #20057, part 18.2. Revise the ammonia slip monitoring language to agree with standard language in other Calpine power plant permits. The revised language will allow the use of a District-approved calculation method to monitor ammonia slip. This is not a relaxation of monitoring, but replaces the original calculation method that was inaccurate. In addition, the basis of the permit condition will be changed from "BACT" to "TRMP" (Toxic Risk Management Plan), since the ammonia slip limit was based upon the District health risk assessment policies and not the BACT provision of NSR.
3. Condition #20057, part 24. Change the required source test frequency for the gas turbine from annual to every 8000 hours of gas turbine operation or once every 3 years, whichever comes first. This is a relaxation of monitoring and therefore is considered a significant revision pursuant to Regulation 2-6-226.3.

MARIN COUNTY

Harold C. Brown, Jr.

NAPA COUNTY

Brad Wagenknecht

SAN FRANCISCO COUNTY

Chris Daly
Jake McGoldrick
Gavin Newsom

The public comment period ended on March 9, 2007. The EPA comment period ended on March 16, 2007. No comments on this proposed significant revision were received from the public, EPA, or the facility.

SAN MATEO COUNTY

Jerry Hill
(Vice-Chair)
Carol Klatt

SANTA CLARA COUNTY

Erin Garner
Yoriko Kishimoto
Liz Kniss
Patrick Kwok

The District has decided to issue the revised permit incorporating the proposed significant revision. The final permit can be viewed and/or downloaded on the BAAQMD website at http://www.baaqmd.gov/pmt/title_v/public_notices.htm. We will also send the final permit via the Electronic Permit Submittal System. If you have any questions regarding this permit, please call Barry Young, Air Quality Engineering Manager, at: (415) 749-4721.

Sincerely yours,

SOLANO COUNTY

John F. Silva

SONOMA COUNTY

Tim Smith
Pamela Torliatt
(Secretary)

Signed by Jack P. Broadbent

Jack P. Broadbent
Executive Officer/Air Pollution Control Officer

Jack P. Broadbent
EXECUTIVE OFFICER/APCO

JPB:BFB:DTJ

H:\Engineering\TITLE V Permit Appls\1 ALL T5 Application Files here\B4416\Sig Revision-11004\1.0 Working docs\B4416_11004_Issltr.DOC