

# Goose Haven Energy Center, LLC

---

2425 Cordelia Road  
Fairfield, CA 94534

June 13, 2011

Madhav Patil  
Air Quality Engineer  
Bay Area Air Quality Management District  
939 Ellis Street  
San Francisco CA 94109

Application Number: 16647  
Plant Number: B4416  
Equipment Location: 3853 Goose Haven Road Suisun City, CA 94585

Dear Mr. Patil:

Enclosed are our comments and suggested corrections to the draft renewal Major Facility (Title V) permit for Goose Haven Energy Center:

1. Add Nominal 49.9MW to S1 description on page 6 and delete 49.9MW from capacity column.
2. Condition 20 on page 34 need to be revised to be consistent with the shutdown definition on page 28.
3. Condition 23 (b) on page 35 should read “ The ammonia injection system shall be equipped with an operational ammonia flowmeter accurate to plus or minus five percent at full scale and calibrated once every twelve months, and injection pressure indicator.”
4. Word annual should change to periodic in VI Permit Conditions on page 36.
5. In table VII-A in page 43, we like change the unit Limit for SO2 from 300 ppm(dry) to 1grains/100scf.
6. In section IX Title IV Acid Rain Permit Page 56, the effective start date should read the same as Title V start date.

Please contact me directly should you have any questions at (707) 399-4393.

Sincerely



Fernando Parra  
Plant Manager