

Table VII – A
Applicable Limits and Compliance Monitoring Requirements
S-1, TURBINE #1
JULY 1, 2012 THROUGH DECEMBER 31, 2012

Type of Limit	Criterion or Limit	FE N/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance	
								Yes	No
NOx	BAAQMD 9-9-301.3	Y		9 ppmv @ 15% O2, dry	BAAQMD 9-9-501 and BAAQMD condition #19684, part 23c	C	CEM	X	
	BAAQMD 9-9-301.3	Y		9 ppmv @ 15% O2, dry	BAAQMD condition #19684, part 24a	P/A	Source Test	X	
	None	Y		None	40 CFR 75.10	C	CEM	X	
NOx	NSPS, 40 CFR 60.332 (a)(1)	Y		99ppmv @ 15% O2, dry	NSPS 40 CFR 60.334 (b)(1) and BAAQMD Condition 19684, part 26	N		X	
NOx	BAAQMD condition #19684, part 18.1	Y		2.5 ppm @15% O2, dry 3-hr average except during turbine startup or shutdown	BAAQMD condition #19684, part 18.1	C	CEM	X	
NOX	BAAQMD condition #19684, part 18.1	Y		2.5 ppm @15% O2, dry 3-hr average except during turbine startup or shutdown	BAAQMD condition #19684, part 24a	P/A	Source Test	X	
	BAAQMD condition #19684, part 21	Y		109 lb/ day (as NO2)	BAAQMD condition #19684, part 23c	C	CEM	X	

VII. Applicable Limits and Compliance Monitoring Requirements

Type of Limit	Creation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance	
								Yes	No
NOx	BAAQMD condition #19684, part 21	Y		14.7 tons per year (as NO2)	BAAQMD condition #19684, part 23c	C	CEM	X	
CO	BAAQMD condition #19684, part 18.3	Y		6 ppmv, @ 15% O ₂ , dry, 3-hr average except during turbine startup or shutdown	BAAQMD condition #19684, parts 18.3 and 23c	C	CEM	X	
	BAAQMD condition #19684, part 18.3	Y		6 ppmv, @ 15% O ₂ , dry, 3-hr average except during turbine startup or shutdown	BAAQMD condition #19684, part 24c	P/A	Source Test	X	
	BAAQMD condition #19684, part 21	Y		159 lb/ day	BAAQMD condition #19684, part 23c	C	CEM	X	
CO	BAAQMD condition #19684, part 21	Y		21.5 tons per year	BAAQMD condition #19684, part 23c	C	CEM	X	
CO ₂		Y		None	40 CFR 75.10	C	CEM (CO ₂) or CEM (O ₂) or fuel flow monitor	X	

VII. Applicable Limits and Compliance Monitoring Requirements

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance	
								Yes	No
SO2	BAAQMD 9-1-301	Y		GLC ¹ of 0.5 ppm for 3 min or 0.25 ppm for 60 min or 0.05 ppm for 24 hours		N		X	
	BAAQMD 9-1-302	Y		300 ppm (dry)	BAAQMD condition #19684, part 23c	P/Q	Fuel Gas Total sulfur content analysis	X	
SO2	NSPS 40 CFR 60.333(a)	Y		0.015% (vol) @ 15% O ₂ (dry)	NSPS 40 CFR 60.334(b)(1) and BAAQMD Condition 19684, Part 26	P/twice per month for six months, followed by quarterly for one year, followed by a semiannual frequency	Sulfur analysis	X	
SO2	None	Y		None	40 CFR 75.11, 40 CFR 75, Appendix D, part 2.3		Fuel measurements, calculations	X	
	BAAQMD condition #19684, part 18.6	Y		1.38 lb/hr	BAAQMD condition #19684, part 23e	P/Q	Fuel gas Total sulfur content analysis	X	
SO2	BAAQMD condition #19684, part 18.6	Y		1.38 lb/hr	BAAQMD condition #19684, part 24f	P/A	Source test	X	
	BAAQMD condition #19684, part 21	Y		32 lb/ day	BAAQMD condition #19684, part 23e	P/Q	Fuel Gas Total sulfur content analysis	X	

VII. Applicable Limits and Compliance Monitoring Requirements

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance	
								Yes	No
SO2	BAAQMD condition #19684, part 21	Y		4.5 tons/year	BAAQMD condition #19684, part 23e	P/Q	Fuel Gas Total sulfur content analysis	X	
Opacity	BAAQMD 6-301	Y		> Ringelmann No.1 for no more than 3 minutes in any hour		N		X	
Opacity	BAAQMD condition #19684, part 18	Y		> Ringelmann No.1 for no more than 3 minutes in any hour or equivalent 20% opacity		N		X	
FP	BAAQMD 6-310	Y		0.15 grains/dscf		N		X	
PM10	BAAQMD condition #19684, part 18.5	Y		3 lb/hr	BAAQMD condition #19684, part 24c	P/A	Source Test	X	
	BAAQMD condition #19684, part 21	Y		72 lb/day	BAAQMD condition #19684, parts 23d, 24e	P/A	Source Test	X	
PM10	BAAQMD condition #19684, part 21	Y		9.8 tons/year	BAAQMD condition #19684, part 24e	P/A	Source Test	X	

VII. Applicable Limits and Compliance Monitoring Requirements

Type of Limit	Citation of Limit	EE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance	
								Yes	No
POC	BAAQMD condition #19684, part 18.4	Y		2 ppmv @ 15% O ₂ , dry, 1-hr average except during turbine startup or shutdown	BAAQMD condition #19684, part 24d	C	Source Test	X	
POC	BAAQMD condition #19684, part 18.4	Y		2 ppmv @ 15% O ₂ , dry, 1-hr average except during turbine startup or shutdown	BAAQMD condition #19684, part 24d	P/A	Source Test	X	
POC	BAAQMD condition #19684, part 21	Y		31 lb/calendar day	BAAQMD condition #19684, part 24d	P/A	Source Test	X	
	BAAQMD condition #19684, part 21	Y		4.1 ton/year	BAAQMD condition #19684, part 24d	P/A	Source Test	X	
NH ₃	BAAQMD condition #19684, part 18.2	N		10ppmv @15% O ₂ , dry, averaged over 1 hr except during turbine startup or shutdown	BAAQMD condition #19684, parts 18.2 and 23b	C	Measurement ratio NH ₃ to NOX inlet rate at SCR	X	

VII. Applicable Limits and Compliance Monitoring Requirements

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance	
								Yes	No
	BAAQMD condition #19684, part 18.2	N		10ppmv @15% O ₂ , dry, averaged over 1 hr except during turbine startup or shutdown	BAAQMD condition #19684, part 24b	P/A	Source Test	X	
Heat input limit	BAAQMD condition #19684, part 22	Y		500 MMBTU/hr (HHV)	BAAQMD condition #19684, part 23d	C	Fuel meter, firing monitor	X	
	BAAQMD condition #19684, part 22	Y		500 MMBTU/hr (HHV)	BAAQMD condition #19684, part 23d	P/Q	Fuel composition analysis	X	
	BAAQMD condition #19684, part 22	Y		500 MMBTU/hr (HHV)	BAAQMD condition #19684, part 24g	P/A	Source test	X	
	BAAQMD condition #19684, part 22	Y		12,000 MMBTU/day (HHV)	BAAQMD condition #19684, part 23d	C	Fuel meter, firing monitor, calculations	X	
Heat input limit	BAAQMD condition #19684, part 22	Y		12,000 MMBTU/day (HHV)	BAAQMD condition #19684, part 23d	P/Q	Fuel composition analysis	X	
	BAAQMD condition #19684, part 22	Y		3,250,000 MMBTU/yr (HHV)	BAAQMD condition #19684, part 23d	C	Fuel meter, firing monitor, calculations	X	
	BAAQMD condition #19684, part 22	Y		3,250,000 MMBTU/yr (HHV)	BAAQMD condition #19684, part 24d	P/Q	Fuel composition analysis	X	

VII. Applicable Limits and Compliance Monitoring Requirements

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance	
								Yes	No
Unabated firing	BAAQMD condition #19684, part 8	Y		100 hours during commissioning	BAAQMD condition #19684, part 8	P/H	Records	X	
MW				None	BAAQMD condition #19684, part 24h	P/A	Source test	X	
Exhaust Gas temperature				None	BAAQMD condition #19684, part 24j	P/A	Source test	X	
Stack gas flow rate				None	BAAQMD condition #19684, part 24i	P/A	Source test	X	
NH3 injection rate				None	BAAQMD condition #19684, part 24k	P/A	Source test	X	
Start-up Period	BAAQMD condition #19684, part 19			60 minutes per start-up	BAAQMD condition #19684, part 30(b)	P/E	Records	X	
Shutdown Period	BAAQMD condition #19684, part 20			30 minutes per shutdown	BAAQMD condition #19684, part 30(b)	P/E	Records	X	

VII. Applicable Limits and Compliance Monitoring Requirements

**Table VII - B
 Applicable Limits and Compliance Monitoring Requirements
 S2 - COOLING TOWER**

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance	
								Yes	No
Opacity	BAAQMD Regulation 6-301	Y		< Ringelmann 1 for more than 3 min/hr		N		X	
Particulate Weight	BAAQMD Regulation 6-301	Y		0.15 grains per dscf		N		X	