

NOTICE INVITING WRITTEN PUBLIC COMMENTS

NOTICE is hereby given that the Executive Officer/Air Pollution Control Officer of the Bay Area Air Quality Management District invites interested persons to submit written public comments on the proposed Significant Revision to a Major Facility Review Permit for the following Facility:

Application	Facility #	Facility Name	Address	Type of Operation
10569	B4512	Gilroy Energy Center, LLC for the Riverview Energy Center	795 Minaker Road Antioch, CA 94565	Generation of Electricity

The primary purpose of this revision is to institute permit condition changes that were previously approved under permit application 10568. The changes include the following:

Increase the daily facility mass emission limits for NOx and CO to reflect the potential operating scenario of 4 gas turbine start-ups per day.

Revise the ammonia slip monitoring language to agree with standard language in other Calpine power plant permits.

Change the required source test frequency for the gas turbine from annual to once every 8000 hours of gas turbine operation or once every 3 years, whichever comes first.

Delete obsolete permit conditions that apply to the commissioning period only.

The definition of hour will be revised to clock hour since the facility monitors emissions on a clock hour basis.

The facility name will be changed to "Gilroy Energy Center, LLC for the Riverview Energy Center".

There is no increase in annual facility emissions associated with the proposed changes to the permit. However, this proposal constitutes a Significant Permit Revision as defined by Regulation 2-6-226.3 because it includes a relaxation of an applicable monitoring condition.

The Executive Officer/Air Pollution Control Officer invites written comment on the proposed significant revision described above. Comments must be received by April 23, 2006. The public may also request a public hearing for this significant revision.

Significant revisions of Major Facility Review Permits are also subject to review and approval by US EPA. If US EPA has not objected to a proposed significant revision and District has not addressed a public comment in a satisfactory manner, the public may petition US EPA, Region IX, Operating Permits Section at 75 Hawthorne Street, San Francisco, CA 94105, within 60 days after the end of US EPA's review, to reconsider the issuance of the permit. The beginning and end of EPA's review period can be found on EPA Region IX's website at: <http://www.epa.gov/region09/air/permit/index.html>.

The proposed revised Major Facility Review permit, application, and evaluation report are available for public inspection at the District Headquarters, 939 Ellis Street, San Francisco, CA, in the Permit Services Division, 3rd Floor. For an appointment, please call May Leung at (415) 749-4729. The proposed permit and evaluation report are also available on the District webpage at the following address: http://www.baaqmd.gov/pmt/title_v/public_notices.htm. Written comments should be directed to Dennis Jang at Bay Area Air Quality Management District, 939 Ellis Street, San Francisco, CA 94109 or by email to djang@baaqmd.gov. Any request for information or for a public hearing should be directed to Allan Chiu at (415) 749-4648.

Dated at San Francisco, the 10th day of March 2006.

Peter Hess for

Jack P. Broadbent

Executive Officer/

Air Pollution Control Officer

Bay Area Air Quality Management District