

August 10, 2006

Ms. Deborah Jordan
Director, Air Division
United States Environmental Protection Agency
75 Hawthorne Street
San Francisco, CA 94105

ALAMEDA COUNTY
Tom Bates
Scott Haggerty
Janet Lockhart
Nate Miley

Dear Ms. Jordan:

This is to advise you that the Bay Area Air Quality Management District is issuing a significant revision to the Major Facility Review Permit for Facility #B4512 pursuant to Application #10569.

CONTRA COSTA COUNTY
Mark DeSaulnier
Mark Ross
(Vice-Chair)
Michael Shimansky
Gayle B. Uilkema
(Chair)

The District proposed a significant permit revision for this facility on March 13, 2006. The purpose of this revision is to institute permit condition changes that were previously approved under permit application 10568.

MARIN COUNTY
Harold C. Brown, Jr.

The public comment period for the proposed significant revision ended on April 23, 2006. No comments were received from the public.

NAPA COUNTY
Brad Wagenknecht

We received minor comments from the facility and where appropriate, have made the following corrections to the permit in response to those comments.

SAN FRANCISCO COUNTY
Chris Daly
Jake McGoldrick
Gavin Newsom

- The responsible official and facility contact have been changed to Brent Colbert and the mailing address has been changed
- The designated representative and alternate designated representative for the Acid Rain permit have been changed to Michael J. Sommer and C. David Zeiger, respectively, in accordance with the revised Certificate of Representation that Calpine submitted to EPA on December 30, 2004.
- Condition #20010, part 24 has been revised to allow 60 days for the submittal of source test results instead of the current 30 day allowance. This change is necessary because source testing firms typically cannot deliver a final report within 30 days of the testing date.
- Table VII-A has been corrected to show daily NOx and CO emission limits of 121 lb/day and 163 lb/day, respectively. This agrees with condition #20010, part 21.
- Condition #20100, part 26 has been deleted. This condition specified an EPA-approved custom schedule for fuel sulfur content monitoring to satisfy Subpart GG. Due to revisions to Subpart GG, this custom schedule is obsolete and has been replaced with natural gas fuel certification that is satisfied with quarterly fuel testing.

SAN MATEO COUNTY
Jerry Hill
(Secretary)
Carol Klatt

SANTA CLARA COUNTY
Erin Garner
Yoriko Kishimoto
Liz Kniss
Patrick Kwok

SOLANO COUNTY
John F. Silva

SONOMA COUNTY
Tim Smith
Pamela Torliatt

The EPA comment period on the significant revision ended on April 29, 2006. The District received no comments from EPA on the proposed revisions.

Jack P. Broadbent
EXECUTIVE OFFICER/APCO

Ms. Deborah Jordan
Page 2

Enclosed is a copy of the final revised permit. If you have any questions regarding this permit, please call Dennis Jang, Senior Air Quality Engineer, at (415) 749-4707.

Sincerely yours,

Jack P. Broadbent
Executive Officer/Air Pollution Control Officer

Enclosure

BFB:DTJ

H:\Engineering\TITLE V Permit Appls\1 ALL T5 Application Files here\B4512\Sig Rev -10569\1.0 Working docs\B4512_10569-Sigrev_Issltr.DOC