

Bay Area Air Quality Management District

939 Ellis Street
San Francisco, CA 94109
(415) 771-6000

**Permit Evaluation
and
Statement of Basis
for the**

MAJOR FACILITY REVIEW PERMIT

for

**Air Liquide Large Industries, US LP
Facility #B7419**

Facility Address:

1391 San Pablo Avenue
Rodeo, CA 94572

Mailing Address:

1391 San Pablo Avenue
Rodeo, CA 94572

April 2009

Application Engineer: Brenda Cabral
Site Engineer: Sanjeev Kamboj

Application: 14738

TABLE OF CONTENTS

| | |
|--|-----------|
| A. Background..... | 3 |
| B. Facility Description..... | 5 |
| C. Permit Content | 5 |
| I. Standard Conditions | 5 |
| II. Equipment | 6 |
| III. Generally Applicable Requirements | 8 |
| IV. Source-Specific Applicable Requirements | 8 |
| V. Schedule of Compliance | 14 |
| VI. Permit Conditions | 15 |
| VII. Applicable Limits and Compliance Monitoring Requirements | 16 |
| VIII. Test Methods | 17 |
| IX. Permit Shield: | 17 |
| X. Revision History | 17 |
| XI. Glossary | 17 |
| D. Alternate Operating Scenarios:..... | 17 |
| E. Compliance Status: | 17 |
| APPENDIX A GLOSSARY | 19 |
| APPENDIX B Engineering Evaluation Application 13678..... | 23 |
| APPENDIX C Engineering Evaluation Application 13424..... | 99 |

Title V Statement of Basis

A. Background

This facility is subject to the Operating Permit requirements of Title V of the federal Clean Air Act, Part 70 of Title 40 of the Code of Federal Regulations (CFR), and BAAQMD Regulation 2, Rule 6, Major Facility Review because it is a major facility as defined by BAAQMD Regulation 2-6-212. It is a major facility because it has the “potential to emit,” as defined by BAAQMD Regulation 2-6-218, of more than 100 tons per year of a regulated air pollutant.

Major Facility Operating permits (Title V permits) must meet specifications contained in 40 CFR Part 70 as contained in BAAQMD Regulation 2, Rule 6. The permits must contain all applicable requirements (as defined in BAAQMD Regulation 2-6-202), monitoring requirements, recordkeeping requirements, and reporting requirements. The permit holders must submit reports of all monitoring at least every six months and compliance certifications at least every year.

In the Bay Area, state and District requirements are also applicable requirements and are included in the permit. These requirements can be federally enforceable or non-federally enforceable. All applicable requirements are contained in Sections I through VI of the permit.

A facility may be made up of several sites. Each site in the Bay Area is assigned a site identifier that consists of a letter and a 4-digit number. This identifier is also considered to be the identifier for the permit. The identifier for this site is B7419.

Air Liquide Large Industries, US LP submitted Application 13678 for an Authority to Construct on October 28, 2005. The Authority to Construct was granted on October 5, 2007. Air Liquide submitted Application 14738 for a Title V permit on June 5, 2006. This is the Permit Evaluation/Statement of Basis for Application 14738.

This application is related to Applications 13427 and 17331, which were submitted by ConocoPhillips Refinery, Site A0016, and ConocoPhillips Carbon Plant, Site A0022, on September 12, 2005 and January 15, 2008, respectively.

In turn, Application 13427 is related to pre-construction review Application 13424 and Application 17331 is related to pre-construction review Application 15328.

Air Liquide is building a hydrogen plant on property owned by ConocoPhillips. The hydrogen plant will be independently owned, operated and maintained by Air Liquide. The District is issuing a separate permit to the hydrogen plant and Air Liquide will be responsible for certifying compliance with all permit conditions. The hydrogen plant will provide hydrogen, steam and power to the refinery but will retain the option to contract commercial sales of hydrogen to third parties. The production of hydrogen will be under the direction of Air Liquide personnel.

The hydrogen plant will receive raw materials from the refinery and produce hydrogen, steam, and electricity for the refinery. The District has determined that the hydrogen plant and associated equipment is part of the refinery. However, the District is issuing a separate permit to the hydrogen plant and a separate responsible official will certify compliance because different personnel will be in charge of the hydrogen plant operations. The hydrogen plant is considered to be under ConocoPhillips' control because the refinery will direct how much hydrogen the plant will make at any time and the hydrogen plant is on refinery property, completely surrounded by the refinery. Moreover, for the purposes of the Prevention of Significant Deterioration program, the refinery's project and construction of the hydrogen plant are considered to be one project.

When the application was declared complete on September 15, 2006, the project as described was subject to the Prevention of Significant Deterioration program because the proposed increase in PM10 was greater than 15 tons per year and the facility had pre-existing of more than 100 tons per year. The participants in the project decided to lower the PM10 emissions so that the project would not be subject to PSD. The facility will either demonstrate compliance with the PM10 limit through initial source tests or through reduced utilization if compliance cannot be demonstrated through the source tests.

Although the project is not subject to PSD, modeling was submitted that showed that the NO2 and the PM10 ambient air quality standards would not be exceeded.

Following is the total change in emissions due to Application 13678.

| Pollutant | Amount, tons/year |
|-----------|-------------------|
| POC | 13.9 |
| NOx | 30.9 |
| SO2 | 5.0 |
| CO | 46.2 |
| PM10 | 13.8 |
| NH3 | 26.9 |
| H2S04 | 0.4 |

Following is the total change in emissions due to Application 13424.

| Pollutant | Amount, tons/year |
|-----------|-------------------|
| POC | -25.0 |
| NOx | -25.1 |
| SO2 | 35.6 |
| CO | -2.5 |
| PM10 | 0.7 |
| NH3 | 6.35 |
| H2SO4 | 6.3 |
| H2S | 1.0 |

Following is the total change in emissions due to Application 15328.

| Pollutant | Amount, tons/year |
|-----------|-------------------|
| SO2 | -42 |

The emissions are shown for the pollutants that the facilities will emit in quantities over one ton per year. The detail for other hazardous air pollutants is included in Applications 13424 and 13678, which form part of this statement of basis, and are included in Appendices B and C.

B. Facility Description

This site is a hydrogen plant. The hydrogen plant consists of the following equipment:

- S1, Hydrogen Plant, 120 MMscf/day, including HRSG and steam turbine generator (12 MW)
- S2, Hydrogen Plant Furnace, 1,072 MMbtu/hr abated by A1, SCR
- S3, Hydrogen Plant Flare, 2200 MMbtu/hr
- S4, Cooling Tower, 3,700 gpm
- S5, Ammonia Tank, 10,000 gal-19% aqueous ammonia
- A1, Selective Catalytic Reduction Unit abating S2, Hydrogen Plant Furnace

The hydrogen plant uses the steam-methane reforming process to take water and hydrocarbons, strip the hydrogen from the water and hydrocarbons, and convert the remaining carbon into carbon monoxide and carbon dioxide. The waste from the process is burned in the hydrogen plant furnace to provide process heat. Most of the carbon monoxide that is generated is burned to form carbon dioxide.

The excess heat is used to make steam in the heat recovery steam generator (HRSG). The steam will be used in the steam turbine generator to generate electricity that will be used by Air Liquide and by ConocoPhillips exclusively.

Air Liquide will install a flare so that hydrogen and off-gas can be burned safely in the case of a shutdown or turndown. The flare will burn clean gas from the hydrogen plant, not refinery fuel gas.

The cooling tower will be used to cool the hydrogen process.

The ammonia tank will provide 19% aqueous ammonia for NOx control in A1, Selective Catalytic Reduction Unit.

C. Permit Content

The legal and factual basis for the permit revision follows. The permit sections are described in the order presented in the permit.

I. Standard Conditions

This section contains administrative requirements and conditions that apply to all facilities. If the Title IV (Acid Rain) requirements for certain fossil-fuel fired electrical generating facilities or the accidental release (40 CFR § 68) programs apply, the section will contain a standard condition pertaining to these programs. Many of these conditions

derive from 40 CFR § 70.6, Permit Content, which dictates certain standard conditions that must be placed in the permit. The language that the District has developed for many of these requirements has been adopted into the BAAQMD Manual of Procedures, Volume II, Part 3, Section 4, and therefore must appear in the permit.

The standard conditions also contain references to BAAQMD Regulation 1 and Regulation 2. These are the District's General Provisions and Permitting rules.

II. Equipment

This section of the permit lists all permitted or significant sources. Each source is identified by an S and a number (e.g., S24).

Permitted sources are those sources that require a BAAQMD operating permit pursuant to BAAQMD Rule 2-1-302.

Significant sources are those sources that have a potential to emit of more than 2 tons of a "regulated air pollutant," as defined in BAAQMD Rule 2-6-222, per year or 400 pounds of a "hazardous air pollutant," as defined in BAAQMD Rule 2-6-210, per year.

All abatement (control) devices that control permitted or significant sources are listed. Each abatement device whose primary function is to reduce emissions is identified by an A and a number (e.g., A24).

The equipment section is considered to be part of the facility description. It contains information that is necessary for applicability determinations, such as fuel types, contents or sizes of tanks, etc. This information is part of the factual basis of the permit.

Each of the permitted sources has previously been issued a permit to operate pursuant to the requirements of BAAQMD Regulation 2, Permits. These permits are issued in accordance with state law and the District's regulations. The capacities in the permitted sources table are the maximum allowable capacities for each source, pursuant to Standard Condition I.J and Regulation 2-1-403.

Table II A - Permitted Sources

Each of the following sources has been issued an authority to construct or a permit to operate pursuant to the requirements of BAAQMD Regulation 2, Permits. The capacities in this table are the maximum allowable capacities for each source, pursuant to Standard Condition I.J and Regulation 2-1-301.

| S-# | Description | Make or Type | Model | Capacity |
|--|------------------------|--------------|-------|----------------|
| 1 | Hydrogen Plant | Air Liquide | | 120 MMscf/day |
| 2 | Hydrogen Plant Furnace | | | 1,072 MMbtu/hr |
| 3 | Hydrogen Plant Flare | | | 2200 MMbtu/hr |
| The above sources do not have final permits to operate as of the date of issuance of the significant revision. This note will be removed using administrative amendment procedures when the District permits are issued. | | | | |

Table II B – Abatement Devices

| A-# | Description | Source(s) Controlled | Applicable Requirement | Operating Parameters | Limit or Efficiency |
|-----|-------------------------------|----------------------|-----------------------------------|----------------------|---|
| 1 | Selective Catalytic Reduction | S2 | BAAQMD Condition 23179, part 5a | None | 5 ppmv NOx @ 3% O2 on a clock hour basis |
| | | | BAAQMD Condition 23179, part 7a.1 | None | 7.5 lb NOx/clock hr |
| | | | BAAQMD Condition 23179, part 7a.1 | None | 50 lb NOx/clock hour during startup, shutdown, drying of refractory |
| 1 | Selective Catalytic Reduction | S2 | BAAQMD Condition 23179, part 10a | None | 28.1 tons NOx per any consecutive 12 months |

Table II C – Significant Sources

The following source is exempt from the requirement to obtain an authority to construct and permit to operate, but is defined as a significant source pursuant to BAAQMD Regulation 2-6-239.

| S-# | Description | Make or Type | Model | Capacity |
|-----|---------------|--------------|-------|-----------|
| 4 | Cooling Tower | | | 3,700 gpm |

III. Generally Applicable Requirements

This section of the permit lists requirements that generally apply to all sources at a facility including insignificant sources and portable equipment that may not require a District permit. If a generally applicable requirement applies specifically to a source that is permitted or significant, the standard will also appear in Section IV and the monitoring for that requirement will appear in Sections IV and VII of the permit. Parts of this section apply to all facilities (e.g., particulate, architectural coating, odorous substance, and sandblasting standards). In addition, standards that apply to insignificant or unpermitted sources at a facility (e.g., refrigeration units that use more than 50 pounds of an ozone-depleting compound) are placed in this section.

Unpermitted sources are exempt from normal District permits pursuant to an exemption in BAAQMD Regulation 2, Rule 1. They may, however, be specifically described in a Title V permit if they are considered significant sources pursuant to the definition in BAAQMD Rule 2-6-239.

IV. Source-Specific Applicable Requirements

This section of the permit lists the applicable requirements that apply to permitted or significant sources. These applicable requirements are contained in tables that pertain to one or more sources that have the same requirements. The order of the requirements is:

- District Rules
- SIP Rules (if any) are listed following the corresponding District rules. SIP rules are District rules that have been approved by EPA for inclusion in the California State Implementation Plan. SIP rules are “federally enforceable” and a “Y” (yes) indication will appear in the “Federally Enforceable” column. If the SIP rule is the current District rule, separate citation of the SIP rule is not necessary and the “Federally Enforceable” column will have a “Y” for “yes”. If the SIP rule is not the current District rule, the SIP rule or the necessary portion of the SIP rule is cited separately after the District rule. The SIP portion will be federally enforceable; the non-SIP version will not be federally enforceable, unless EPA has approved it through another program.
- Other District requirements, such as the Manual of Procedures, as appropriate.
- Federal requirements (other than SIP provisions)
- BAAQMD permit conditions. The text of BAAQMD permit conditions is found in Section VI of the permit.

- Federal permit conditions. The text of Federal permit conditions, if any, is found in Section VI of the permit.

Section IV of the permit contains citations to all of the applicable requirements. The text of the requirements is found in the regulations, which are readily available on the District's or EPA's websites, or in the permit conditions, which are found in Section VI of the permit. All monitoring requirements are cited in Section IV. Section VII is a cross-reference between the limits and monitoring requirements. A discussion of monitoring is included in Section C.VII of this permit evaluation/statement of basis.

Most of the applicable requirements are fully discussed in the pre-construction Application 13678, attached, which forms part of this statement of basis.

PSD

The discussion of the PSD analysis is contained in the engineering evaluation for Application 13424 and is hereby incorporated by reference. However, the conclusion will be restated here.

The combined project for the ConocoPhillips refinery, the Air Liquide hydrogen plant, and the ConocoPhillips Carbon Plant was subject to PSD because the emissions increase for PM10 was over 15 tons per year. After the permit was proposed, the applicants decided to reduce the PM10 emissions by 2 tons per year, which may be accomplished either by lowering the PM10 concentration or by curtailing operations, and to withdraw the PSD application. Therefore, the project is no longer a PSD project.

The first table, Table IV-All Sources, is a compilation of requirements that apply generally to the site. The area monitoring requirements in Regulation 1, and Regulation 9, Rules 1 and 2, are in this table. Also in this table are the annual mass emission limits, the requirement to notify the Compliance and Enforcement Division of planned startup and shutdowns, and the requirement to maintain the ammonia concentration below 20%. Air Liquide has agreed to this last requirement so that they are not subject to 40 CFR 68, Chemical Accidental Release Provisions.

Storage of more than 10,000 lb of hydrogen would also be subject 40 CFR 68. Air Liquide has stated that they do not intend to store more than 10,000 lb of hydrogen at one time.

S1, Hydrogen Plant

The hydrogen plant has a small vent that emits methanol and ammonia, so the hydrogen plant is subject to BAAQMD Regulation 7, Odorous Substances, and Regulation 8, Rule 2, Miscellaneous Operations.

The vessels in the hydrogen plant are subject to BAAQMD and SIP Regulations 8, Rule 10, Process Vessel Depressurization.

The hydrogen plant is also subject to BAAQMD Condition 23178, which includes throughput limits, mass emission limits, and requirements for control of fugitive emissions of POC.

The vent at the hydrogen plant is not subject to 40 CFR 63, Subpart CC, National Emissions Standards for Hazardous Air Pollutants from Petroleum Refineries, because 40 CFR 63.641 states that the following is not a miscellaneous process vent

(14) Hydrogen production plant vents through which carbon dioxide is removed from process streams or through which steam condensate produced or treated within the hydrogen plant is degassed or deaerated

The source is not subject to 40 CFR 60, Subpart VV, Standards of Performance for Equipment Leaks, directly because the site does not manufacture any of the chemicals listed in Section 60.489. However, the source is subject to Standards of Performance for Equipment Leaks of VOC in Petroleum Refineries for Which Construction, Reconstruction, or Modification Commenced After November 7, 2006, which refers to 40 CFR 60, Subpart VV.

The source is not subject to 40 CFR 61, Subpart J, National Emission Standard for Equipment Leaks of Benzene because not it is not in benzene service, which is defined in 40 CFR 61.111 as handling streams that contain more than 10% benzene.

The source is not subject to 40 CFR 61, Subpart V because the hydrogen plant is not in VHAP service, which means handling streams that are not more than 10 % VHAP. VHAP is defined in 40 CFR 61.241 as benzene and vinyl chloride.

S2, Hydrogen Plant Furnace

All combustion sources are subject to BAAQMD Regulation 6, Rule 1, Particulate Matter-General Requirements and SIP Regulation 6, Particulate Matter and Visible Emissions.

The refinery complies with BAAQMD Regulation 9, Rule 1, Sulfur Dioxide, by monitoring ground-level SO₂. Therefore, the furnace is not subject to the general limit of 300 ppm SO₂ in Section 9-1-302.

The furnace is not subject to BAAQMD Regulation 9, Rule 7, Nitrogen Oxides And Carbon Monoxide from Industrial, Institutional, and Commercial Boilers, Steam Generators, And Process Heaters, because Section 9-7-110.3 exempts heaters used at petroleum refineries.

The furnace is not subject to BAAQMD Regulation 9, Rule 9, Nitrogen oxides And Carbon Monoxide from Boilers, Steam Generators and Process Heaters in Petroleum Refineries, because Sections 9-10-201 and 9-10-220 do not include units that received an authority to construct after January 5, 1994. The reason is that new units are subject to New Source Review and are expected to have NO_x and CO limits that are lower than those in the rule. Since the limits in the rule are based on a refinery-wide average,

allowing new units into the pool of units controlled by the rule would lower the average without achieving control from the older units.

The Hydrogen Plant Furnace is not subject to NSPS, Subpart D, Standards of Performance for Fossil-Fuel-Fired Steam Generators for Which Construction Is Commenced After August 17, 1971, because its primary function is not generation of steam.

The furnace is not subject to NSPS, Subpart Da, Standards of Performance for Electric Utility Steam Generating Units for Which Construction is Commenced After September 18, 1978, because it generates less than 25 MW of electricity.

The furnace is not subject to NSPS, Subpart Db, Standards of Performance for Industrial-Commercial-Institutional Steam Generating Units, because it excludes process heaters.

The furnace is not subject to NSPS, Subpart Dc, Standards of Performance for Small Industrial-Commercial-Institutional Steam Generating Units, because it excludes process heaters and because its capacity is more than 100 MMBtu/hr.

The unit is subject to the NSPS, Subpart Ja, Standards of Performance for Petroleum Refineries for which Construction, Reconstruction, or Modification Commenced After May 14, 2007, which was promulgated on June 24, 2008. On December 22, 2008, EPA stayed the following sections: 60.100a(c), 60.101a-definition of flare, 60.102a(g), and 60.107a(d) and (e). Section 60.102a(g)(1) and (2) contain the SO₂ and NO_x standards for fuel combustion devices. The standards are stayed but the monitoring requirements have not been stayed. BAAQMD Condition 23179 has been amended to reflect the fact that the furnace is subject to Subpart Ja, not Subpart J.

For combustion sources, NSPS, Subpart Ja, requires continuous monitoring for H₂S in fuel or SO₂ in combustion gases, except for “fuel gas streams that are inherently low in sulfur content.” Air Liquide has chosen to monitor SO₂ because not all of the fuel that is burned in the hydrogen plant is inherently low in sulfur. Therefore, the sulfur limits and monitoring in the following conditions are unnecessary and have been deleted.

- Condition 23178, part 7: monitoring of sulfur in feed to the hydrogen plant
- Condition 23178, part 8: monitoring of sulfur at outlet of zinc oxide feed treatment system
- Condition 23179, part 4: limit on sulfur in feed to hydrogen plant furnace
- Condition 23179, part 14a: total sulfur monitoring for refinery fuel gas
- Condition 23179, part 15: continuous H₂S monitor on feed to hydrogen plant furnace

The CEM provisions in Condition 23179, part 19, have been expanded to include the SO₂ CEM.

40 CFR 63, Subpart DDDDD

S2, Hydrogen Plant Furnace, is subject to 40 CFR 63, Subpart DDDDD, National Emission Standards for Hazardous Air Pollutants for Industrial, Commercial, and

Institutional Boilers and Process Heaters. The DC Circuit Court vacated the standard on June 8, 2007. Where there is no MACT for a new source and the deadline for promulgation of a standard by EPA is past, local agencies must determine case-by-case MACT for the new source, in accordance with 40 CFR 63.52(a). The emission limit for S2 in the standard was 400 ppm CO. There were no other limits for gaseous-fueled boilers. A CO CEM was required for units over 100 MMbtu/hr.

The reason that the court gave for vacating the MACT was that EPA had inappropriately classified solid waste incineration units that were subject to Section 129 of the Clean Air Act as solid fuel units that were subject to the MACT. This classification greatly increased the number of units subject to the MACT and therefore skewed the determination of the MACT floor. The court stated that the "universe of units ... will be far smaller and more homogenous [sic]" after the solid waste units were taken out of the group of units affected. The court expects that the rule will change substantially when EPA considers the smaller pool of units.

One possible outcome is that the standards may become more stringent because the HAP emissions from the solid waste incineration units are expected to be higher. The MACT "floor" is based on the performance of the top 12 percent of the units in a category.

EPA had determined that CO was an appropriate surrogate for organic HAPs. The argument was that high CO was indicative of poor combustion and therefore, poor destruction of organic HAPs. This is a reasonable assumption.

Following are the CO limits proposed by EPA:

- New, large and limited use solid fuel units: 400 PPM @ 7% O₂
- Small solid fuel units: None
- New, large and limited use liquid fuel units: 400 PPM @ 3% O₂
- Small liquid fuel units: None
- New, large and limited use gaseous fuel units: 400 PPM @ 3% O₂
- Small gaseous fuel units: None
- Existing units: None

Small units are defined as units with a capacity less than 10 MMbtu/hr.

Gaseous-fueled units are not expected to be sources of metallic or inorganic HAP.

The MACT limit for S2, therefore, was 400 PPM @ 3% O₂, which is equivalent to the BAAQMD Regulation 9, Rule 7, Nitrogen Oxides and Carbon Monoxide from Industrial, Institutional, and Commercial Boilers, Steam Generators, and Process Heaters, which was adopted in 1992.

The District does not have the resources to survey all industrial, commercial, and institutional boilers and process heaters in the United States and determine the MACT "floor." However, the District notes that the CO BACT limit in the District's BACT workbook for boilers over 50 MMbtu/hr has been 50 ppmv since 2005. For refinery process heaters over 50 MMbtu/hr, the BACT limit has been 50 ppmv since 1994. The South Coast AQMD has had BACT limits for CO of 50 ppm for boilers since 2000.

On page 1680, column 3, second paragraph, of the MACT proposal published on January 13, 2003, EPA states:

"The approach that we use to calculate the MACT floors for new sources is somewhat different from the approach that we use to calculate the MACT floors for existing sources. While the MACT floors for existing units are intended to reflect the average performance achieved by a representative group of sources, the MACT floors for new units are meant to reflect the emission control that is achieved in practice by the best controlled source. Thus, for existing units, we are concerned about estimating the central tendency of a set of multiple units, while for new units, we are concerned about estimating the level of control that is representative of that achieved by a single best controlled source."

If we agree with EPA that low CO levels indicate low levels of organic HAPs, then lower CO levels are better than higher CO levels. Considering that the "best controlled sources" have CO levels that are 50 ppm or lower, 400 ppm cannot be considered to be the proper MACT limit for a new gaseous-fueled source. The source is subject to a BACT CO limit of 10 ppm CO @ 3% O₂. This level will be considered to be presumptive MACT for this source until EPA re-proposes and re-promulgates MACT. Since it is not expected that EPA will propose a limit that is lower than this limit, the source incurs no risk from this determination. Due to the size of the source, the CEM for CO will still be required.

40 CFR 64, Compliance Assurance Monitoring

Per 40 CFR 64.2(a), the furnace is subject to 40 CFR 64, Compliance Assurance Monitoring, if the unit is subject to a federally enforceable requirement for a pollutant, the pollutant is controlled by an abatement device, and the emissions of the pollutant before abatement are more than 100% of the major source thresholds.

The furnace has a control device for NO_x, A1, Selective Catalytic Reforming, and is subject to federally enforceable NO_x limits. It will be subject to the standard because the emissions of NO_x before abatement will be more than 100 tons per year.

The furnace is also subject to 40 CFR 60, Subpart Ja, Standards of Performance for Petroleum Refineries for which Construction, Reconstruction, or Modification Commenced After May 14, 2007, which was promulgated on June 24, 2008. 40 CFR 64.2(b)(1) exempts units that are subject to an "Emission limitations or standards proposed by the Administrator after November 15, 1990 pursuant to section 111 or 112 of the Act." 40 CFR 60, Subpart Ja, is a standard proposed after November 15, 1990 pursuant to section 111 of the Act. The standard was proposed on May 14, 2007, and promulgated on June 24, 2008. Although the NO_x limit in the standard has been stayed until further notice, the monitoring has not been stayed, and is presumed to be acceptable for the purpose of the exemption in Section 40 CFR 64.2(b)(1).

40 CFR 72-78, ACID RAIN

Electricity will be generated using excess heat at the hydrogen plant. The hydrogen plant will not be subject to 40 CFR 72-78 because it will not sell electricity. The hydrogen

plant or ConocoPhillips will consume all electricity that is produced. The standards apply only to "utilities," which are defined in 40 CFR 72.2 as "any person who sells electricity."

Flare

The flare is not subject to BAAQMD Regulation 12, Rules 11, Flare Monitoring at Petroleum Refineries, or 12, Flares at Petroleum Refineries, because the hydrogen plant does not process petroleum and therefore, the flare is not considered to be a refinery flare as defined by the rules. The flare will not burn refinery fuel gas. It will only burn the effluent of the hydrogen plant (PSA gas) under certain circumstances. This gas has no sulfur and very little POC. It is composed mostly of carbon dioxide, methane, carbon monoxide, and hydrogen. Nonetheless, to ensure that the NOx and CO emissions of the flare are within the limits allowed by the permit, the owner/operator will monitor flow to the flare using a flowmeter that complies with BAAQMD Regulation 12, Rule 11.

EPA promulgated 40 CFR 63, Subpart Ja, Standards of Performance for Petroleum Refineries for which Construction, Reconstruction, or Modification Commenced After May 14, 2007, on June 24, 2008. Section 60.107a(3)(iii) does not require H2S monitoring for "fuel gas streams produced in process units that are intolerant to sulfur contamination, such as fuel gas streams produced in the hydrogen plant." Since the flare is only allowed to burn hydrogen, syn-gas, ammonia, and PSA off-gas, it is not subject to the H2S monitoring and parts 11 and 12 of Condition 23180 have been deleted.

Accidental Release

The facility will not be subject to 40 CFR 68, Accidental Release, because they will use aqueous ammonia with a concentration of 19% ammonia. Section 68.130, List of Substances, states that aqueous ammonia with a concentration of 20% or higher is subject if 20,000 pounds or more are stored.

V. Schedule of Compliance

A schedule of compliance is required in all Title V permits pursuant to BAAQMD Regulation 2-6-409.10 which provides that a major facility review permit shall contain the following information and provisions:

"409.10 A schedule of compliance containing the following elements:

- 10.1 A statement that the facility shall continue to comply with all applicable requirements with which it is currently in compliance;
- 10.2 A statement that the facility shall meet all applicable requirements on a timely basis as requirements become effective during the permit term; and
- 10.3 If the facility is out of compliance with an applicable requirement at the time of issuance, revision, or reopening, the schedule of compliance shall contain a plan by which the facility will achieve compliance. The plan shall contain deadlines for each item in the plan. The schedule of compliance shall also contain a requirement for submission of progress reports by the facility at least every six months. The progress reports shall contain the dates by which each item in the plan was achieved and an explanation of why any dates in the schedule of compliance were not or will not be met, and any preventive or corrective measures adopted."

VI. Permit Conditions

The Major Facility Review permit contains conditions that are derived from previously issued District Authorities to Construct (A/C) or Permits to Operate (P/O). Permit conditions may also be imposed or revised as part of the annual review of the facility by the District pursuant to California Health and Safety Code (H&SC) § 42301(e), through a variance pursuant to H&SC § 42350 et seq., an order of abatement pursuant to H&SC § 42450 et seq., or as an administrative revision initiated by District staff. After issuance of the Title V permit, permit conditions will be revised using the procedures in Regulation 2, Rule 6, Major Facility Review.

When necessary to meet Title V requirements, additional monitoring, recordkeeping, or reporting has been added to the permit.

Each permit condition is identified with a unique numerical identifier, up to five digits.

All changes to existing permit conditions that are proposed in this action are clearly shown in “strike-out/underline” format in the proposed permit. When the permit is issued, all ‘strike-out’ language will be deleted and all “underline” language will be retained, subject to consideration of comments received.

The basis for of the permit conditions is explained in the permit evaluation for Application 13678, attached, which forms part of this statement of basis. Explanations of any changes made after issuance of the Authority to Construct pursuant to Application 13678 are provided in this section.

Hydrogen Plant Condition 23178

Part 1 of Condition 23178 has been amended to add periodic monitoring of hydrogen production to comply with BAAQMD Regulation 2-6-503.

Part 2 of Condition 23178 has been amended to add periodic monitoring of electrical production to comply with BAAQMD Regulation 2-6-503.

Parts 7 and 8 of Condition 23178 have been deleted. These conditions were for monitoring of sulfur in feed to ensure that the emissions of SO₂ at the hydrogen plant furnace were not exceeded. See a fuller explanation below in the discussion of Condition 23179 for the hydrogen plant furnace.

Part 9 of Condition 23178 has been split into part 9a and 9b because the POC monitoring is federally enforceable and the ammonia monitoring is not. The basis for the ammonia monitoring has been changed to BAAQMD Regulation 2, Rule 5.

Hydrogen Plant Furnace Condition 23179

Mention of 40 CFR 63, Subpart DDDDD, has been deleted from part 19 of Condition 23179 concerning the CO CEM because the subpart has been vacated. Compliance with BAAQMD Manual of Procedures, Volume V, Continuous Emission Monitoring, will ensure adequate performance for the monitors.

For combustion sources, NSPS, Subpart Ja, requires continuous monitoring for H₂S in fuel or SO₂ in combustion gases, except for “fuel gas streams that are inherently low in sulfur content.” Air Liquide has chosen to monitor SO₂ because not all of the fuel that is burned in the hydrogen plant is inherently low in sulfur. Therefore, the sulfur limits and monitoring in the following conditions are unnecessary and have been deleted.

- Condition 23178, part 7: monitoring of sulfur in feed to the hydrogen plant
- Condition 23178, part 8: monitoring of sulfur at outlet of zinc oxide feed treatment system
- Condition 23179, part 4: limit on sulfur in feed to hydrogen plant furnace
- Condition 23179, part 14a: total sulfur monitoring for refinery fuel gas
- Condition 23179, part 15: continuous H₂S monitor on feed to hydrogen plant furnace

The CEM provisions in Condition 23179, part 19, have been expanded to include the SO₂ CEM.

Flare Condition 23180

Part 11 of the condition has been deleted because the citations for 40 CFR 60, Subpart J or Ja will be incorporated into the Major Facility Review permit.

Part 12 of the condition has been deleted because 40 CFR 60, Subpart J, as amended on June 30, 2008, no longer requires H₂S monitoring for “streams that are inherently low in H₂S.”

Facility Condition 23181

In Part B.6, the designation for the sulfur recovery unit at Facility A0016 was changed from S1004 to S1010.

Part B.7 of Condition 23181 was included to ensure that the plant was aware that the facility is subject to BAAQMD Regulation 8, Rule 18. Since the citations are being included in the Major Facility Review permit, part 7 will be deleted.

VII. Applicable Limits and Compliance Monitoring Requirements

This section of the permit is a summary of numerical limits and related monitoring requirements for each source. The summary includes a citation for each monitoring requirement, frequency of monitoring, and type of monitoring. The applicable requirements for monitoring are completely contained in Sections IV, Source-Specific Applicable Requirements, and VI, Permit Conditions, of the permit.

A discussion of the adequacy of monitoring is contained in the Engineering Evaluation for Application 13678, which is found in Appendix B, and forms part of this statement of basis.

VIII. Test Methods

This section of the permit lists test methods that are associated with standards in District or other rules. It is included only for reference. In most cases, the test methods in the rules are source test methods that can be used to determine compliance but are not required on an ongoing basis. They are not applicable requirements.

If a rule or permit condition requires ongoing testing, the requirement will also appear in Section IV of the permit.

IX. Permit Shield:

The District rules allow two types of permit shields. The permit shield types are defined as follows: (1) A provision in a major facility review permit explaining that specific federally enforceable regulations and standards do not apply to a source or group of sources, or (2) A provision in a major facility review permit explaining that specific federally enforceable applicable requirements for monitoring, recordkeeping and/or reporting are subsumed because other applicable requirements for monitoring, recordkeeping, and reporting in the permit will assure compliance with all emission limits.

The second type of permit shield is allowed by EPA's White Paper 2 for Improved Implementation of the Part 70 Operating Permits Program. The District uses the second type of permit shield for all streamlining of monitoring, recordkeeping, and reporting requirements in Title V permits. The District's program does not allow other types of streamlining in Title V permits.

No permit shield has been requested for this facility.

X. Revision History

The Revision History section contains a list of all of the instances that the permit is issued, the type of action (initial issuance, renewals, administrative amendments, minor or significant revisions, and reopenings), the application number, and the date of the action.

XI. Glossary

A glossary of terms has been provided for both the permit and the statement of basis.

D. Alternate Operating Scenarios:

No alternate operating scenario has been requested for this facility.

E. Compliance Status:

Construction of the facility is not yet complete, so no compliance issues have been identified. It is expected that the permit conditions will assure compliance with all applicable requirements.

H:\pub_data\title V permit appls\1.0 all ...a0016\sig-13427\13678\B7459 sob

APPENDIX A

GLOSSARY

ARB

Air Resources Board

BAAQMD

Bay Area Air Quality Management District

BACT

Best Available Control Technology

Basis

The underlying authority that allows the District to impose requirements.

CAA

The federal Clean Air Act

CAAQS

California Ambient Air Quality Standards

CEM

Continuous Emission Monitor

CEQA

California Environmental Quality Act

CFEP

Clean Fuel Expansion Project

CFR

The Code of Federal Regulations 40 CFR contains the implementing regulations for federal environmental statutes such as the Clean Air Act. Parts 50-99 of 40 CFR contain the requirements for air pollution programs.

CO

Carbon Monoxide

Cumulative Increase

The sum of permitted emissions from each new or modified source since a specified date pursuant to BAAQMD Rule 2-1-403, Permit Conditions (as amended by the District Board on 7/17/91) and SIP Rule 2-1-403, Permit Conditions (as approved by EPA on 6/23/95). Cumulative increase is used to determine whether threshold-based requirements are triggered.

District

The Bay Area Air Quality Management District

dscf

Dry Standard Cubic Feet

EPA

The federal Environmental Protection Agency.

EFRT

External Floating Roof Tank

Federally Enforceable, FE

All limitations and conditions which are enforceable by the Administrator of the EPA including those requirements developed pursuant to 40 CFR Part 51, subpart I (NSR), Part 52.21 (PSD), Part 60 (NSPS), Part 61 (NESHAPs), Part 63 (MACT), and Part 72 (Permits Regulation, Acid Rain), including limitations and conditions contained in operating permits issued under an EPA approved program that has been incorporated into the SIP.

FP

Filterable Particulate as measured by BAAQMD Method ST-15, Particulate.

MOP

The District's Manual of Procedures.

NAAQS

National Ambient Air Quality Standards

NESHAPS

National Emission Standards for Hazardous Air Pollutants. See in 40 CFR Parts 61 and 63.

NH3

Ammonia

NOx

Oxides of nitrogen.

NSPS

Standards of Performance for New Stationary Sources. Federal standards for emissions from new stationary sources. Mandated by Title I, Section 111 of the Federal Clean Air Act, and implemented by 40 CFR Part 60 and District Regulation 10.

NSR

New Source Review. A federal program for pre-construction review and permitting of new and modified sources of pollutants for which criteria have been established in accordance with Section 108 of the Federal Clean Air Act. Mandated by Title I of the Federal Clean Air Act and implemented by 40 CFR Parts 51 and 52 and District Regulation 2, Rule 2. (Note: There are additional NSR requirements mandated by the California Clean Air Act.)

Offset Requirement

A New Source Review requirement to provide federally enforceable emission offsets for the emissions from a new or modified source. Applies to emissions of POC, NOx, PM10, and SO2.

POC

Precursor Organic Compounds

PM

Particulate Matter

PM10

Particulate matter with aerodynamic equivalent diameter of less than or equal to 10 microns

PSD

Prevention of Significant Deterioration. A federal program for permitting new and modified sources of those air pollutants for which the District is classified "attainment" of the National Air Ambient Quality Standards. Mandated by Title I of the Act and implemented by both 40 CFR Part 52 and District Regulation 2, Rule 2.

SCR

Selective Catalytic Reduction

SIP

State Implementation Plan. State and District programs and regulations approved by EPA and developed in order to attain the National Air Ambient Quality Standards. Mandated by Title I of the Act.

SO2

Sulfur dioxide

Title V

Title V of the federal Clean Air Act. Requires a federally enforceable operating permit program for major and certain other facilities.

TRMP

Toxic Risk Management Plan

VOC

Volatile Organic Compounds

Units of Measure:

| | | |
|----------------|---|----------------------------------|
| bhp | = | brake-horsepower |
| btu | = | British Thermal Unit |
| cfm | = | cubic feet per minute |
| g | = | grams |
| gal | = | gallon |
| gpm | = | gallons per minute |
| hp | = | horsepower |
| hr | = | hour |
| lb | = | pound |
| in | = | inches |
| max | = | maximum |
| m ² | = | square meter |
| min | = | minute |
| mm | = | million |
| MMbtu | = | million btu |
| MMcf | = | million cubic feet |
| ppmv | = | parts per million, by volume |
| ppmw | = | parts per million, by weight |
| psia | = | pounds per square inch, absolute |
| psig | = | pounds per square inch, gauge |
| scfm | = | standard cubic feet per minute |
| yr | = | year |

APPENDIX B

Engineering Evaluation Application 13678

FINAL: October 5, 2007

Evaluation Report, Application No. 13678, Air Liquide Large Industries US L.P., Facility B7419

FINAL

**ENGINEERING EVALUATION
Air Liquide Large Industries, U.S. LP; Facility B7419
APPLICATION NO. 13678**

October 5, 2007

Table of Contents

1. BACKGROUND 26

2. EMISSIONS..... 28

3. Best available Control Technology (BACT)..... 37

4. CUMULATIVE INCREASE AND OFFSETS 41

5. STATEMENT OF COMPLIANCE 42

6. RECOMMENDATIONS..... 55

7. PERMIT CONDITIONS..... 55

Appendix A..... 69

APPENDIX B 80

Appendix C 93

1. BACKGROUND

Air Liquide has submitted an application to build a hydrogen plant at the ConocoPhillips refinery in Rodeo. This is part of ConocoPhillips "Clean Fuel Expansion Project (CFEP)." The purpose of the project is to process heavy gas oil that ConocoPhillips produces at the coker crude unit, coker, and pre-fractionator into gasoline and diesel fuel.

ConocoPhillips needs more hydrogen than it can currently produce to process the heavy gas oil. Air Liquide will build a new hydrogen plant on site and will retain ownership of the plant and operate it. However, ConocoPhillips will use all of the facility's output. BAAQMD Regulation 2-1-213 defines facility as:

"Any property, building, structure or installation (or any aggregation of facilities) located on one or more contiguous or adjacent properties and under common ownership or control of the same person..."

The hydrogen plant will be on ConocoPhillips property, so it meets the conditions of "contiguous or adjacent." In addition, the hydrogen plant will take its feed from the refinery. ConocoPhillips will direct the hydrogen plant to produce the amount of hydrogen that it needs at any time, so the hydrogen plant is considered to be under Conoco's control. Therefore, the hydrogen plant will be considered to be part of the refinery.

Since it is part of the refinery, the two projects (CFEP and hydrogen plant) will be considered as one project for the purposes of NSR, PSD, Major Facility Review (Title V), offsets, NSPS, NESHAPS, and any other applicable requirements.

The Title V regulations in 40 CFR 70 allow agencies to issue more than one Title V permit to a facility. Because the hydrogen plant will be owned and operated by Air Liquide, it will have a separate plant number, B7419, and a separate application, No. 13678.

The ConocoPhillips Carbon Plant, Plant A0022, is owned and operated by ConocoPhillips. It is contiguous to the refinery. Although it has a separate plant number and Title V permit, it is also considered part of the facility. The applicant will reduce emissions at the carbon plant to obtain reductions in actual emissions of PM10 for the purposes of CEQA and contemporaneous offsets of SO2.

The list of equipment at the proposed Air Liquide plant is shown below:

- S1, Hydrogen Plant, 120 MMscf/day, including HRSG and steam turbine generator (12 MW)
- S2, Hydrogen Plant Furnace, 1,072 MMbtu/hr abated by A1, SCR
- S3, Hydrogen Plant Flare, 2200 MMbtu/hr
- S4, Cooling Tower, 3,700 gpm
- S5, Ammonia Tank, 10,000 gal-19% aqueous ammonia
- A1, Selective Catalytic Reduction Unit abating S2, Hydrogen Plant Furnace

S4, Cooling Tower, is exempt from permits because BAAQMD Regulation 2-1-128.4 exempts water cooling towers provided that the source does not require permitting pursuant to BAAQMD Regulation 2-1-319. This section would require permits if the source emits more than 5 tons per year of any regulated air pollutant. Some large cooling towers emit enough POC or PM10 to require permits. This cooling tower will have permit conditions requiring monitoring to ensure that the emissions of POC and PM10 each do not exceed the amounts stated in the application.

S5, Ammonia Tank, is exempt from permits because BAAQMD Regulation 2-1-113.2 exempts vessels used exclusively for the storage of any aqueous solution containing less than 1% organic compounds by weight provided that the source does not require permitting pursuant to BAAQMD Regulation 2-1-319. This section would require permits if the source emits more than more than 5 tons per year of any regulated air pollutant or the source emits more than the trigger level for any toxic air contaminant. The tank is a pressure tank and is unlikely to emit more than the trigger level of ammonia (7,700 lb) in any year.

Air Liquide will use the excess heat generated at the hydrogen plant to make steam and will provide steam to ConocoPhillips. This will enable ConocoPhillips to shut down an older 256 MMbtu/hr boiler, S8. Air Liquide will also use steam to power a steam turbine to generate electricity for its own use and for ConocoPhillips. A maximum of 12 MW will be generated; the new hydrogen plant will use 4.5 MW. ConocoPhillips will use the remainder.

2. EMISSIONS

Following is a summary of the original proposed emissions of NO_x, SO₂, PM₁₀, POC, and CO in tons per year from the proposed Air Liquide hydrogen plant. The annual emissions were calculated for the average operating rate of 975 MMbtu/hr. The maximum daily emissions were calculated for the maximum operating rate of 1,072 MMbtu/hr.

Summary of Hydrogen Plant Emissions

| Source | Tons per Year | | | | |
|-----------------------|-----------------|-----------------|------------------|-------------|-------------|
| | NO _x | SO ₂ | PM ₁₀ | POC | CO |
| New SMR Furnace | 28.1 | 5.0 | 15.8 | 11.5 | 34.2 |
| Deaerator Vent | -- | -- | -- | 0.8 | -- |
| Flare Pilots/NG Purge | 0.12 | 0.004 | -- | -- | 1.1 |
| Startup/Shutdown | 2.7 | 0 | 0 | 0.1 | 11 |
| Cooling Tower | | | 0.5 | 1.5 | |
| Fugitives | -- | -- | -- | 1.5 | -- |
| Total | 30.9 | 5.0 | 16.3 | 15.4 | 46.2 |

(975 MMbtu/hr, annual average)

| Source | Lb per Day | | | | |
|-----------------------|-----------------|-----------------|------------------|-------------|------------|
| | NO _x | SO ₂ | PM ₁₀ | POC | CO |
| New SMR Furnace | 169 | 30 | 95 | 69 | 206 |
| Deaerator Vent | -- | -- | -- | 4.4 | -- |
| Flare Pilots/NG Purge | 0.68 | 0.022 | -- | -- | 5.9 |
| Cooling Tower | | | 2.5 | 8 | |
| Fugitives | -- | -- | -- | 8.2 | -- |
| Total | 170 | 30 | 97.5 | 89.9 | 212 |

(1072 MMbtu/hr, hourly maximum)

Air Liquide's final proposal is to reduce the particulate emissions from the new SMR furnace to 13.8 tons per year. Air Liquide may comply by showing that the particulate emission factor is less than 0.0037 lb/MMbtu or by curtailing operations. The resulting annual emissions are:

Summary of Hydrogen Plant Annual Emissions

| Source | Tons per Year | | | | |
|-----------------------|---------------|-------|------|------|------|
| | NOx | SO2 | PM10 | POC | CO |
| New SMR Furnace | 28.1 | 5.0 | 13.8 | 11.5 | 34.2 |
| Deaerator Vent | -- | -- | -- | 0.8 | -- |
| Flare Pilots/NG Purge | 0.12 | 0.004 | -- | -- | 1.1 |
| Startup/Shutdown | 2.7 | 0 | 0 | 0.1 | 11 |
| Cooling Tower | | | 0.5 | 1.5 | |
| Fugitives | -- | -- | -- | 1.5 | -- |
| Total | 30.9 | 5.0 | 14.3 | 15.4 | 46.2 |

Air Liquide has calculated the maximum daily emissions for the flare. If the pressure swing absorption process malfunctions, up to 7.74 MMscf/hr of syngas could be sent to the flare for 5.3 hours/event. The composition of syngas is mainly hydrogen, methane, and CO, as shown below: (This paragraph has been amended to be consistent with the flare emission calculations in Appendix A.)

FINAL: October 5, 2007

Evaluation Report, Application No. 13678, Air Liquide Large Industries US L.P., Facility B7419

| Component | % by Weight | % by Volume |
|-----------------|-------------|-------------|
| Hydrogen | 13.4 | 73 |
| Nitrogen | 0.2 | <0.09 |
| Carbon Dioxide | 68.5 | 17 |
| Carbon Monoxide | 10.3 | 4 |
| Methane | 7.3 | 5 |
| Ethane | <0.001 | <0.0001 |
| Water | 0.3 | 0.2 |

In this case, approximately 686 lb NO_x/day would be emitted and 3,537 lb CO/day would be emitted. In this case, the hydrogen plant and hydrogen plant furnace would shut down, so normal emissions would not be emitted concurrently with the flare emissions.

| | Lb per Highest Day | | | | |
|--------|--------------------|-----------------|------------------|-----|-------|
| Source | NO _x | SO ₂ | PM ₁₀ | POC | CO |
| Flare | 686 | 0 | negligible | 0 | 3,537 |

The detailed calculations of the flare emissions are in Appendix A.

Following is the detail of the emissions of toxic air contaminants on which the health risk screening analysis was based. These emissions were based on a heat input rate of 1,100 MMbtu/hr to S2, Hydrogen Plant Furnace. The average hourly rate has been reduced to 975 MMbtu/hr, so the typical emissions will be lower. Also the proposed emissions of methanol have been reduced to 0.61 lb/day or 223 lb/yr. Emission factors from WSPA/API's Air Toxic Emission Factors for Combustion Sources Using Petroleum-Based Fuels, final report, Volume 2, Appendix B, April 14, 1998 have been used for the calculations of all emissions from the heater except ammonia and sulfuric acid mist. The ammonia calculations are based on the "ammonia slip", the ammonia that is lost when injected into A1, SCR, for NOx control. The sulfuric acid mist is based on the assumption that the ratio of SO2 to SO3 in combustion is 20:1, and that all SO3 becomes sulfuric acid mist. The detailed calculations are in Appendix B of the engineering evaluation for Application 13424.

| Substance | Emissions (lb/yr) | | | | | | |
|----------------------|----------------------------|--------------|----------------|----------------------------|--------------------------|--------------------------------|------------------------------|
| | S2, Hydrogen Plant Furnace | Flare Pilots | Deaerator Vent | Cooling Tower ^a | Hydrogen Plant Fugitives | Total Annual Emissions (lb/yr) | BAAQMD Trigger Level (lb/yr) |
| | Acenaphthene | 2.27E-02 | | | | | 2.27E-02 |
| Acenaphthylene | 1.49E-02 | | | | | 1.49E-02 | |
| Acetaldehyde | 1.47E+02 | 2.02E-01 | | | | 1.48E+02 | 6.40E+01 |
| Acrolein | | 4.69E-02 | | | | 4.69E-02 | 2.30E+00 |
| Ammonia | 4.82E+04 | | 5.59E+03 | | 0.00E+00 | 5.38E+04 | 7.70E+03 |
| Antimony | 4.98E+00 | | | | | 4.98E+00 | 7.70E+00 |
| Arsenic | 8.19E+00 | | | | | 8.19E+00 | 1.20E-02 |
| Benzene | 6.23E+02 | 7.46E-01 | | | | 6.24E+02 | 6.40E+00 |
| Benzo(a)anthracene | 3.09E-01 | | | | | 3.09E-01 | 0.011 ^b |
| Benzo(a)pyrene | 8.63E-01 | | | | | 8.63E-01 | 0.011 ^b |
| Benzo(b)fluoranthene | 3.89E-01 | | | | | 3.89E-01 | 0.011 ^b |
| Benzo(k)fluoranthene | 2.32E-01 | | | | | 2.32E-01 | 0.011 ^b |

| Substance | Emissions (lb/yr) | | | | | | | BAAQMD Trigger Level (lb/yr) |
|------------------------|----------------------------|--------------|---------------------|----------------------------|--------------------------|--------------------------------|----------|------------------------------|
| | S2, Hydrogen Plant Furnace | Flare Pilots | Deaerator Vent | Cooling Tower ^a | Hydrogen Plant Fugitives | Total Annual Emissions (lb/yr) | | |
| | 1,3-Butadiene | | | | | 4.84 | 4.84E+00 | |
| Cadmium | 9.52E+00 | | | | | 9.52E+00 | 4.50E-02 | |
| Chlorine | | | | 3.95E-02 | | 3.95E-02 | 7.70E+00 | |
| Chloroform | | | | 9.94E+00 | | 9.94E+00 | 3.40E+01 | |
| Chromium (Total) | 1.03E+01 | | | | | 1.03E+01 | 1.30E-03 | |
| Chrysene | 1.57E-02 | | | | | 1.57E-02 | | |
| Copper | 4.06E+01 | | | | | 4.06E+01 | 9.30E+01 | |
| Ethylbenzene | 2.91E+02 | 6.78E+00 | | | | 2.98E+02 | 7.70E+04 | |
| Fluoranthene | 2.95E-02 | | | | | 2.95E-02 | | |
| Fluorene | 1.04E-01 | | | | | 1.04E-01 | | |
| Formaldehyde | 1.07E+03 | 5.48E+00 | | | | 1.08E+03 | 3.00E+01 | |
| n-Hexane | | 1.36E-01 | | | 7.50E+00 | 7.63E+00 | 2.70E+05 | |
| Indeno(1,2,3-cd)pyrene | 9.93E-01 | | | | | 9.93E-01 | 0.011* | |
| Lead | 4.71E+01 | | | | | 4.71E+01 | 5.40E+00 | |
| Manganese | 6.56E+01 | | | | | 6.56E+01 | 7.70E+00 | |
| Mercury | 1.73E+00 | | | | | 1.73E+00 | 5.60E-01 | |
| Methanol | | | 1.75E+04 2.23+02 | | | 1.75E+04 | 1.50E+05 | |
| Naphthalene | 3.02E+00 | 6.57E-02 | | | | 3.08E+00 | 5.30E+00 | |
| Nickel | 9.08E+01 | | | | | 9.08E+01 | 7.30E-01 | |
| Phenanthrene | 1.41E-01 | | | | | 1.41E-01 | | |
| Phenol | 5.43E+01 | | | | | 5.43E+01 | 7.70E+03 | |
| Propylene | 2.09E+01 | 1.14E+01 | | | | 3.24E+01 | 1.20E+05 | |
| Pyrene | 2.39E-02 | | | | | 2.39E-02 | | |

| Substance | Emissions (lb/yr) | | | | | | |
|------------------------|-------------------------------------|--------------|-------------------|-------------------------------|--------------------------------|--------------------------------------|------------------------------------|
| | S2, Hydrogen Plant Furnace | Flare Pilots | Deaerator Vent | Cooling Tower ^a | Hydrogen Plant Fugitives | Total Annual Emissions (lb/yr) | BAAQMD Trigger Level (lb/yr) |
| | Selenium | 1.89E-01 | | | | | 1.89E-01 |
| Silver | 1.55E+01 | | | | | 1.55E+01 | |
| Sulfuric Acid Mist | 8.6E+02 | | | | | 8.6E+02 | 3.9E+01 |
| Toluene | 1.03E+03 | 2.72E-01 | | | | 1.03E+03 | 1.20E+04 |
| 1,2,4-Trimethylbenzene | | | | | | | |
| Xylene (Total) | 3.59E+02 | 1.36E-01 | | | | 3.60E+02 | 2.70E+04 |
| Zinc | 2.00E+02 | | | | | 2.00E+02 | 1.40E+03 |

^a Chloroform emissions from the cooling tower were calculated using an emission factor of 0.0034 lb CHCl₃ per lb of Cl₂ used to chlorinate the cooling waters. Emission factor is from *Proposed Identification of Chloroform as a Toxic Air Contaminant* (CARB, September 1990. http://www.arb.ca.gov/toxics/summary/chloroform_A.pdf). Cl₂ usage based on bleach density of 10 lb/gal, 12.5 wt% NaOCl (avg. of 9-16% bleach solution), 0.3 lb Cl₂/gal.

^b These substances are PAH derivatives that have OEHHA-developed Potency Equivalency Factors. These PAHs should be evaluated as benzo(a)pyrene equivalents. This evaluation process consists of multiplying individual PAH-specific emission levels with their Potency Equivalency Factor, which is 0.1. The sum of these products is the benzo(a)pyrene equivalent level and should be compared to the benzo(a)pyrene equivalent trigger level.

This table shows the average hourly emissions of toxic air contaminants:

| Substance | Emissions (lb/hr) | | | | | | BAAQMD Trigger Level (lb/hr) |
|----------------------|-------------------|--------------|----------------|---------------|--------------------------|--------------------------------|------------------------------|
| | SMR Furnace | Flare Pilots | Deaerator Vent | Cooling Tower | Hydrogen Plant Fugitives | Total Hourly Emissions (lb/hr) | |
| Acenaphthene | 3.07E-06 | | | | | 3.07E-06 | |
| Acenaphthylene | 2.02E-06 | | | | | 2.02E-06 | |
| Acetaldehyde | 1.99E-02 | 2.30E-05 | | | | 1.99E-02 | |
| Acrolein | | 5.36E-06 | | | | 5.36E-06 | 4.20E-04 |
| Ammonia | 6.50E+00 | | 6.40E-01 | | 0.00E+00 | 7.14E+00 | 7.10E+00 |
| Antimony | 6.72E-04 | | | | | 6.72E-04 | |
| Arsenic | 1.11E-03 | | | | | 1.11E-03 | 4.20E-04 |
| Benzene | 8.41E-02 | 8.52E-05 | | | | 8.42E-02 | 2.90E+00 |
| Benzo(a)anthracene | 4.17E-05 | | | | | 4.17E-05 | |
| Benzo(a)pyrene | 1.16E-04 | | | | | 1.16E-04 | |
| Benzo(b)fluoranthene | 5.25E-05 | | | | | 5.25E-05 | |
| Benzo(k)fluoranthene | 3.13E-05 | | | | | 3.13E-05 | |
| 1,3-Butadiene | | | | | 5.53E-04 | 5.53E-04 | |
| Cadmium | 1.28E-03 | | | | | 1.28E-03 | |
| Chlorine | | | | 4.50E-06 | | 4.50E-06 | 4.60E-01 |
| Chloroform | | | | 1.13E-03 | | 1.13E-03 | 3.30E-01 |
| Chromium (Total) | 1.39E-03 | | | | | 1.39E-03 | |
| Chrysene | 2.12E-06 | | | | | 2.12E-06 | |
| Copper | 5.47E-03 | | | | | 5.47E-03 | 2.20E-01 |
| Ethylbenzene | 3.93E-02 | 7.73E-04 | | | | 4.00E-02 | |
| Fluoranthene | 3.98E-06 | | | | | 3.98E-06 | |

| Substance | Emissions (lb/hr) | | | | | | BAAQMD Trigger Level (lb/hr) |
|------------------------|-------------------|--------------|----------------|---------------|--------------------------|--------------------------------|------------------------------|
| | SMR Furnace | Flare Pilots | Deaerator Vent | Cooling Tower | Hydrogen Plant Fugitives | Total Hourly Emissions (lb/hr) | |
| Fluorene | 1.40E-05 | | | | | 1.40E-05 | |
| Formaldehyde | 1.44E-01 | 6.26E-04 | | | | 1.45E-01 | 2.10E-01 |
| n-Hexane | | 1.55E-05 | | | 8.56E-04 | 8.72E-04 | |
| Indeno(1,2,3-cd)pyrene | 1.34E-04 | | | | | 1.34E-04 | |
| Lead | 6.36E-03 | | | | | 6.36E-03 | |
| Manganese | 8.85E-03 | | | | | 8.85E-03 | |
| Mercury | 2.34E-04 | | | | | 2.34E-04 | 4.00E-03 |
| Methanol | | | 2.55E-02 | | | 2.00E+00 | 6.20E+01 |
| Naphthalene | 4.07E-04 | 7.50E-06 | | | | 4.14E-04 | |
| Nickel | 1.22E-02 | | | | | 1.22E-02 | 1.30E-02 |
| Phenanthrene | 1.90E-05 | | | | | 1.90E-05 | |
| Phenol | 7.32E-03 | | | | | 7.32E-03 | 1.30E+01 |
| Propylene | 2.82E-03 | 1.31E-03 | | | | 4.13E-03 | |
| Pyrene | 3.22E-06 | | | | | 3.22E-06 | |
| Selenium | 2.55E-05 | | | | | 2.55E-05 | |
| Silver | 2.09E-03 | | | | | 2.09E-03 | |
| Sulfuric Acid Mist | 9.8E-02 | | | | | 9.8E-02 | 2.6E-01 |
| Toluene | 1.39E-01 | 3.11E-05 | | | | 1.39E-01 | 8.20E+01 |
| 1,2,4-Trimethylbenzene | | | | | | | |
| Xylene (Total) | 4.85E-02 | 1.55E-05 | | | | 4.85E-02 | 4.90E+01 |
| Zinc | 2.70E-02 | | | | | 2.70E-02 | |

The detailed emission calculations for each source are in Attachment A.

FINAL: October 5, 2007

Evaluation Report, Application No. 13678, Air Liquide Large Industries US L.P., Facility B7419

The summary of the emissions for the whole project, which includes Applications No. 13424 for Facility A0016, ConocoPhillips, No. 13678 for Air Liquide, and No. 15328 for contemporaneous offsets from Facility A0022, ConocoPhillips Carbon Plant, are contained in Application No. 13424. The discussion of emissions for the purposes of PSD applicability, CEQA, offsets, and BACT are also contained in Application No. 13424.

3. Best available Control Technology (BACT)

Following are the maximum daily emissions for the various sources:

| Source | Lb per Highest Day | | | | |
|----------------------|--------------------|-----|------|------|-------|
| | NOx | SO2 | PM10 | POC | CO |
| New SMR Furnace | 169 | 30 | 95 | 69 | 206 |
| Hydrogen Plant | -- | -- | -- | 12.6 | -- |
| Hydrogen Plant Flare | 686 | | | | 3,537 |
| Cooling Tower | | | 2.5 | 8 | |

S1, Hydrogen Plant, is subject to BACT because it will emit more than 10 lb/highest day of POC.

S2, Hydrogen Plant Furnace, is subject to BACT because it will emit more than 10 lb/highest day of these pollutants: NOx, SO2, POC, CO, and PM10.

S3, Hydrogen Plant Flare, is subject to BACT because it will emit more than 10 lb/highest day of these pollutants: NOx and CO.

The following source is not subject to BACT because it will not emit more than 10 lb/day of NOx, SO2, POC, CO, or PM10:

S5, Ammonia Tank

The following source is not subject to BACT because it is exempt from permitting in accordance with BAAQMD Regulation 2-1-128.4.

S4, Cooling Tower

If the source emits more than 5 tons per year of any regulated air pollutant, it would still be subject to permitting in spite of the exemption.

The applicant estimates that emissions of POC from S4 will be less than 8.0 lb/day (1.5 tpy) and the emissions of PM10 will be less than 2.5 lb/day. POC levels in cooling towers can spike, however, if there is a leak in a heat exchanger. The permit will contain monitoring conditions to ensure that the POC emissions remain under 5 tons per year. It is far less likely that PM10 emission will be over 5 tons per year, especially with limits on dissolved solids content of the water.

S5, Ammonia Tank, will not have emissions of NOx, SO2, POC, CO, or PM10 and therefore is not subject to BACT.

S1, Hydrogen Plant

FINAL: October 5, 2007

Evaluation Report, Application No. 13678, Air Liquide Large Industries US L.P., Facility B7419

The components (valves, flanges, pumps, compressors, etc.) at the hydrogen plant and the deaerator vent are subject to BACT because they are estimated to emit more than 10 lb POC/highest day. BACT for petroleum refinery fugitive emissions in accordance with the Section 3 of the District's BACT handbook is:

- Graphitic gaskets for flanges
- Live loaded packing systems and polished stems, or equivalent, for valves
- "Wet" dual mechanical seals with a heavy liquid barrier fluid, or dual dry gas mechanical seals buffered with inert gas for hydrocarbon centrifugal compressors
- Seal-less design or dual mechanical seals with a heavy liquid barrier fluid, or equivalent, for pumps
- Fugitive equipment monitoring and repair program for all components

BACT for the deaerator vent at hydrogen plants has not been hitherto defined. Air Liquide has proposed emissions of 4.35 lb POC/day at the vent. No other hydrogen plants in the Bay Area have mass emission limits on the deaerator vents. Source tests of the vents have shown much higher emissions. No BACT determinations or limits for deaerator vents were found in the EPA, ARB, or SCAQMD BACT Clearinghouses. SCAQMD does have Rule 1189 with a limit of 0.5 lb VOC/MMscf of H₂ produced. This would be equivalent to 60 lb POC/day at the vent.

An emission rate of 4.35 lb/hr will be considered to be BACT for this source.

S2, Hydrogen Plant Furnace

Air Liquide has proposed the following BACT levels for S2, Hydrogen Plant Furnace:

| Pollutant | Concentration | Emission Factor, lb/MMbtu | Reference for BACT |
|-----------------|------------------------------|---------------------------|---|
| NOx | 5 ppmvd @ 3% O ₂ | 0.00658 | *SCAQMD BACT |
| SO ₂ | 35 ppmv total S in RFG/NG | 0.0012 | BAAQMD BACT (PSA/fuel gas Mix) |
| PM10 | 3.8 lb/MMcf (natural gas) | 0.0037 | AP42 Section 1.4, Natural Gas Combustion (apply 1/2 value since 50% H ₂ in fuel) |
| POC | 2.75 lb/MMcf (natural gas) | 0.0027 | AP42 Section 1.4, Natural Gas Combustion (apply 1/2 value since 50% H ₂ in fuel) |
| CO | 10 ppmvd @ 3% O ₂ | 0.0080 | SCAQMD BACT |

*South Coast Air Quality Management District

These levels are lower than the levels in the District BACT/TBACT handbook. Air Liquide is relying on a top-down analysis of BACT for NOx and PM10 at the hydrogen plant that was performed by ConocoPhillips for Application 13424. This analysis is required as part of the PSD analysis. This analysis is attached in Appendix B. The furnace is compared to various recent hydrogen plant furnaces. These furnaces burn primarily pressure swing absorption gas (PSA gas), which results in lower emissions of NOx and CO than natural gas and refinery fuel gas (RFG). The applicant estimates that this furnace will burn approximately 85% PSA gas and 15% RFG/natural gas.

There are 4 BACT determinations by the SCAQMD for hydrogen plant furnaces with levels for NOx of 5 ppmdv @ 3% O₂. This is the lowest NO_x emission limit achieved in practice. BACT will be achieved by using SCR and by burning mostly PSA gas.

For particulate matter, the conclusion drawn by the top-down analysis was that only good combustion practice is considered to be BACT for controlling PM10 from gas-fired heaters. The level proposed by the applicant is equivalent to 0.0025 gr/dscf (assuming that the F-factor is the same as the F-factor for natural gas). This is lower than the 0.01 proposed for a 2,088 MMbtu/hr natural gas fired boiler proposed in SCAQMD BACT determination #427061 in 2006.

Also, SCAQMD BACT determination #411357 established that 0.0065 lb PM10/MMbtu was BACT (based on a limit of 3642 lb/mo, 780 MMbtu/hr, an assumption of 720 hr/mo. operation). Air Liquide has proposed 0.0037 lb PM10/MMbtu for this application.

For SO₂, the level proposed compares favorably with the 40 ppm S in fuel as H₂S in SCAQMD BACT determination #411357 for a 780 MMbtu/hr steam reformer furnace with similar fuels, and very favorably with the 0.2 lb/MMbtu level

FINAL: October 5, 2007

Evaluation Report, Application No. 13678, Air Liquide Large Industries US L.P., Facility B7419

in SCAQMD BACT determination #427061 for a 2,088 MMbtu/hr natural gas-fired boiler.

The proposed CO concentration of 10 ppm@ 3% O₂ is equivalent to the last SCAQMD BACT determination #411357.

For POC, SCAQMD BACT determination #411357 determined that 0.0061 lb POC/MMbtu was BACT (based on a limit of 3399 lb/mo, 780 MMbtu/hr, an assumption of 720 hr/mo operation). Air Liquide has proposed 0.0027 lb POC/MMbtu for this application.

The District concludes that the levels proposed for S2, Hydrogen Plant Furnace, represent BACT.

Air Liquide is relying on a top-down analysis of BACT for NO_x and PM₁₀ at the hydrogen plant furnace that was performed by ConocoPhillips for Application 13424. This analysis is required as part of the PSD analysis. The analysis is attached in Appendix B.

Air Liquide has also proposed a maximum emission rate during start-up, shutdown, and malfunction of 50 lb NO_x/clock hour.

S3, Hydrogen Plant Flare

The main purpose of the flare is to dispose of hydrogen and CO in an emergency for safety reasons. Hydrogen is not a pollutant.

The flare's emissions on the highest day may be up to 686 lb NO_x/day and 3,537 lb CO/day, as shown in the flare calculations in Appendix A. However, the flare will only be used occasionally when there is a shutdown, malfunction, during maintenance, or when there is a sudden drop in the refinery's use of hydrogen. The total annual emissions from the flare are estimated at 2.7 tpy NO_x and 11 tpy CO. There are also small ongoing emissions from the flare pilots, which ensure that a flame is present at all times. Because the emissions of NO_x and CO will be more than 10 lb/day on the highest day, the flares are subject to BACT.

The District's BACT/TBACT Workbook states that an enclosed ground level flare with a control efficiency of 98.5% for POC is BACT1. BACT1 for CO is undetermined at this point.

The applicant has stated that the flare is not subject to BACT for POC because the gases sent to the flare do not contain more than 10 lb POC/day. Following is the gas composition:

| Component | % by Weight | % by Volume |
|-----------------|-------------|-------------|
| Hydrogen | 13.4 | 73 |
| Nitrogen | 0.2 | <0.09 |
| Carbon Dioxide | 68.5 | 17 |
| Carbon Monoxide | 10.3 | 4 |
| Methane | 7.3 | 5 |
| Ethane | <0.001 | <0.0001 |
| Water | 0.3 | 0.2 |

Because none of the components is considered to be POC, the flare is not subject to BACT for POC.

As shown in the flare calculations, the flare is a control device for CO and a generator of NOx. The calculations assume 98% control of CO.

Testing is not feasible for elevated flares because they are open and have no stack. If the flare were enclosed, it might be possible to test for destruction efficiency. It is likely that if the flare were enclosed, NOx emissions would rise and CO emissions would drop due to increased residence time. It is not sensible to specify an enclosed ground level flare simply to enable testing. Moreover, enclosed ground level flares are generally small. For example, the largest enclosed ground level flare at a landfill in the District, where these flares are commonly used, has a capacity of 120 MMbtu/hr.

Due to the capacity of this flare (2,220 MMbtu/hr), District staff concluded that a ground-level enclosed flare was not feasible in this case. The facility will install an elevated flare. These flares are considered to have a control efficiency of 98% for CO.

4. CUMULATIVE INCREASE AND OFFSETS

The cumulative increase for the facility is shown below.

| | Tons per Year | | | | |
|-------|---------------|-----|-------|-------|------|
| | NOx | SO2 | PM10 | POC | CO |
| Total | 30.9 | 5.0 | 13.8* | 13.9* | 46.2 |

*The emissions from the exempt cooling tower at the hydrogen plant are not considered to be part of the cumulative increase and are not subject to offsets.

BAAQMD Regulation 2-2-302 requires offsets for NOx and POC because the emissions of the facility, which includes the ConocoPhillips refinery (Facility

FINAL: October 5, 2007

Evaluation Report, Application No. 13678, Air Liquide Large Industries US L.P., Facility B7419

A0016) and the ConocoPhillips carbon plant (Facility A0022), will be greater than 35 tons per year. The refinery emitted approximately 335 tons NOx and 283 tons POC and the carbon plant emitted approximately 532 tons NOx in 2005 according to District estimates.

In accordance with BAAQMD Regulation 2-2-302.2, POC credits shall be used to offset part of the NOx increases.

BAAQMD Regulation 2-2-303 requires offsets for SO2 and PM10 at major facilities. ConocoPhillips is a major facility for PM10 because the refinery emitted approximately 126 tons PM10 and the carbon plant emitted approximately 63 tons PM10 in 2005 according to District estimates. It is a major facility for SO2 because the refinery emitted approximately 424 tons SO2 and the carbon plant emitted approximately 1212 tons SO2 in 2005 according to District estimates.

The discussion of offsets required and provided for this project can be found in the engineering evaluation for Application 13424.

The PM10 offsets will come from the following certificates:

| Certificate Number | Owner of Record | Amount tpy |
|--------------------|-----------------|--------------|
| 920 | ConocoPhillips | 6.650 |
| 979 | Air Liquide | 18.600 |
| 1032 | Air Liquide | <u>4.200</u> |
| Total | | 29.45 |

5. STATEMENT OF COMPLIANCE

BAAQMD Regulation 1, General Provisions

The District requires NOx CEMs from sources that use SCR for control, therefore S2, Hydrogen Plant Furnace, is subject to 1-521 and 1-522. The source will also be required to have a CO CEM.

S2, Hydrogen Plant Furnace, will be subject to flow and ammonia injection monitoring and therefore will be subject to the parametric monitoring requirements in Section 1-523.

BAAQMD Regulation 2, Rule 1, General Requirements

S4, Cooling Tower, is exempt from permits because BAAQMD Regulation 2-1-128.4 exempts water cooling towers provided that the source does not require permitting pursuant to BAAQMD Regulation 2-1-319. This section would require permits if the source emits more than more than 5 tons per year of any regulated air pollutant. Some cooling towers emit enough POC or PM10 to require permits. This cooling tower will have permit conditions requiring monitoring to ensure that the emissions of POC and PM10 each do not exceed the amounts stated in the application, which were 1.5 tons per year and 0.5 tons per year, respectively.

S5, Ammonia Tank, 10,000 gal, is not required to have a permit because the storage of aqueous solutions that contains less than one percent by weight organic compounds is exempt in accordance with Section 123.2. The tank will be a pressure vessel with a nitrogen blanket. It will store 19% aqueous ammonia. The ammonia concentration will be limited to 19% because storage of higher concentrations is subject to 40 CFR 68, Accidental Release.

BAAQMD Regulation 2, Rule 5, New Source Review Of Toxic Air Contaminants

In accordance with BAAQMD Regulation 2, Rule 5, health risk assessment analysis was prepared by the facility and reviewed by District Staff. The project risk, including Plant A0016, ConocoPhillips refinery, meets the requirements as follows:

- Project cancer risk is less than 10.0 in a million;
- Project chronic hazard index is less than 1.0; and
- Project acute hazard index is less than 1.0.

The cancer risk for S2, Hydrogen Plant Furnace, is greater than 1.0 in a million. Therefore, the source is subject to TBACT in accordance with Section 2-5-301 of the rule. TBACT is the use of extremely clean fuels. Approximately 85% of the fuel that will be burned in the Heater will be PSA gas, which is extremely clean and has very little sulfur.

Also, the risk assessment for S2 is conservative, because it was based on an average heat input rate of 1,100 MMbtu/hr, but the final average heat input rate will be 975 MMbtu/hr, which is 12.8% less.

The chronic health index for all sources is below 0.2.

BAAQMD Regulation 6, Particulate Matter and Visible Emissions

The following sources are the new sources of particulate matter in this application:

FINAL: October 5, 2007

Evaluation Report, Application No. 13678, Air Liquide Large Industries US L.P., Facility B7419

S2, Hydrogen Plant Furnace abated by A1, SCR
S3, Hydrogen Plant Flare, 2200 MMbtu/hr
S4, Cooling Tower, 3,700 gpm

S2, Hydrogen Plant Furnace, and A1, SCR, are subject to Sections 6-301, 6-305, and 6-310.3 of the regulation. Section 6-301 is a requirement that visible emissions may not exceed 1.0 Ringelmann for more than 3 min/hr. Section 6-305 is a requirement that a unit may not emit visible particles that fall outside of the facility's property. Section 6-310.3 is the grain-loading limit for heat transfer operations of 0.15 gr filterable particulate/dscf @ 6% O₂. (The "gr" used in this section means "grains," which are equal to 1/7000 of a pound.) S2 burns gaseous fuels and is expected to comply with these requirements.

S3, Hydrogen Plant Flare, is subject to Sections 6-301, 6-305, and 6-310 of the regulation. Section 6-310 is the general grain-loading limit of 0.15 gr filterable particulate/dscf. S3 burns gases and is expected to comply with these requirements.

S4, Cooling Tower, is subject to Sections 6-301, 6-305, 6-310, and 6-311 of the regulation. The cooling tower is expected to comply with these requirements. Previous analysis for Application 10349 shows that, for cooling towers, the amount of particulate matter is so small and the airflow is so large that compliance with 6-301, 6-310, and 6-310 is assured.

Compliance with Section 6-311 is on a process weight basis. The flow rate of water for the cooling tower is 3,700 gal/min. This is equivalent to 1.85 million lb/hr. If the process weight is over 57,320 lb/hr, the limit is 40 lb filterable particulate/hr. The emission rate shown in the calculations in Appendix A is 0.1 lb/hr, therefore the source will comply with Section 6-311.

BAAQMD Regulation 7, Odorous Emissions

The purpose of Regulation 7 is the general control of odorous compounds. Most odorous pollutants are handled generally. A few are mentioned by name. One of these is ammonia.

S1 Hydrogen Plant, and S2, Hydrogen Plant Furnace, are sources of ammonia. Section 7-303 limits concentration of ammonia from Type A emission points to 5000 ppm. Ammonia is used at S2 in the SCR for abatement of NO_x. The hydrogen plant will emit up to 10 ppm of ammonia from the deaerator vent. The heater will comply because it has a limit of 10 ppmv ammonia @ 3% oxygen, as will the hydrogen plant because the concentration at the vent is low. The concentration of ammonia in the stacks of both sources will be measured by source test after construction.

BAAQMD Regulation 8, Rule 2, Miscellaneous Operations

The deaerator vent at the Hydrogen Plant, S1, and the cooling tower, S4, will be subject to this rule. Section 301 has the following limit:

"A person shall not discharge into the atmosphere from any miscellaneous operation an emission containing more than 6.8 kg. (15 lbs.) per day and containing a concentration of more than 300 PPM total carbon on a dry basis."

If the emissions at the deaerator meet 4.35 lb/day as stated by the applicant, the deaerator will comply easily. Annual source tests will be required to ensure compliance.

Cooling towers are exempt from this rule, in accordance with Section 8-2-114, if best modern practices are used. The District has determined "best modern practices" for cooling towers and has documented them in the engineering evaluation for ConocoPhillips' Application 10349 as follows:

"... daily visual inspection, plus water sampling and analysis for indicators of hydrocarbon leaks once per shift, is the best modern practice."

S4, Cooling Tower, will not comply with best modern practices, and therefore is subject to Regulation 8, Rule 2. The engineering evaluation also determined that the margin of compliance for most refinery cooling towers is 1000:1. Therefore, the cooling tower will comply with Regulation 8, Rule 2.

BAAQMD Regulation 8, Rule 10, Process Vessel Depressurization

The Hydrogen Plant, S1, will be subject to this rule. Section 301 of the rule requires that the emissions during depressurizing be controlled by an abatement device or the fuel gas system until the vessel is as close to atmospheric pressure as possible, but at least until the partial pressure of organic compounds in that vessel is less than 4.6 psig.

Section 302 requires that no process vessel may be opened to the atmosphere unless the internal concentration of total organic compounds has been reduced prior to release to atmosphere to less than 10,000 parts per million (ppm), with the following exception. Vessels may be opened when the concentration of total organic compounds is 10,000 ppm or greater provided that the total number of such vessels opened with such concentration during any consecutive five year period does not exceed 10% of the total process vessel population, the organic compound emissions from the opening of these vessels does not exceed 15 pounds per day and the vessels are not opened on any day on which the APCO predicts an exceedance of a National Ambient Air Quality Standard for ozone or declares a Spare the Air Day.

S1 is expected to comply with these requirements.

FINAL: October 5, 2007

Evaluation Report, Application No. 13678, Air Liquide Large Industries US L.P., Facility B7419

BAAQMD Regulation 8, Rule 18, Equipment Leaks

The components-valves, flanges, pumps, compressors, pressure relief devices-are subject to this rule. The rule has total organic leak limits of 100 ppm for valves and flanges and 500 ppm for pumps, compressors, and pressure relief devices. This is a "work-practice" standard. The facility is obligated to test the components for leaks on a periodic basis and repair the leaks. A small percentage of non-repairable leaks are allowed until the next turnaround or five years, whichever is sooner.

The facility will have an inspection program for this regulation and is expected to comply with these standards.

BAAQMD Regulation 8, Rule 28, Episodic Releases from Pressure Relief Devices at Petroleum Refineries and Chemical Plants

This regulation applies to pressure relief devices (PRDs) installed on refinery equipment. Section 8-28-302 applies to PRDs on new or modified equipment. It requires that these PRDs comply with all requirements of BAAQMD Regulation 2, Rule 2, including BACT. BACT1 at this time is a rupture disk with a vent to a fuel gas recovery system, furnace, or flare with a recovery/destruction efficiency of 98%. All new PRDs installed pursuant to this project are subject to this standard. The applicant has determined that the use of rupture disks is not feasible at the hydrogen plant because of the high number of pressure cycles and high temperatures. The hydrogen plant will be required to comply with BACT2, the requirement to vent to a fuel gas recovery system, furnace, or flare with a recovery/destruction efficiency of 98%.

Permit conditions with the BACT requirement will be added to these units. The facility is expected to comply with this requirement.

BAAQMD Regulation 9, Rule 1, Sulfur Dioxide

S2, Hydrogen Plant Furnace, and S3, Hydrogen Plant Flare, are small sources of SO₂ emissions. These sources are not subject to the 300-ppm limit in Section 9-1-301 of the rule because the refinery complies with the exemption in Section 9-1-110. The exemption requires ground level monitoring and compliance with the ground level concentration limit.

BAAQMD Regulation 9, Rule 3, Nitrogen Oxides from Heat Transfer Operations

S2, Hydrogen Plant Furnace, is subject to the rule because it applies to new heat transfer operations with a maximum heat input greater than 250 MMbtu/hr, per

FINAL: October 5, 2007

Evaluation Report, Application No. 13678, Air Liquide Large Industries US L.P., Facility B7419

Section 9-3-303. The source will easily comply with the 125 ppm limit for gaseous fuels because it is designed to comply with the 5 ppm @ 3% O₂ BACT limit.

BAAQMD Regulation 9, Rule 10, Nitrogen Oxides and Carbon Monoxide from Boilers, Steam Generators and Process Heaters in Petroleum Refineries

S2, Hydrogen Plant Furnace, is not subject to this regulation because it applies to affected units. Affected units are defined by Section 9-10-220 as "any petroleum refinery boiler, steam generator, or process heater... having an Authority to Construct or a Permit to Operate prior to January 5, 1994." This heater will be subject to current BACT limits for NO_x and CO, which are more stringent, instead of the Regulation 9, Rule 10, limits.

BAAQMD Regulation 12, Rule 11, Flare Monitoring at Petroleum Refineries and BAAQMD Regulation 12, Rule 12, Flares at Petroleum Refineries

S1, Hydrogen Plant, will have a hydrogen plant flare for the purpose of flaring hydrogen and pressure swing absorption gas if there is an upset. BAAQMD Regulation 12, Rules 11 and 12, apply to petroleum refineries, which are defined for the purposes of the rule as:

"A facility that processes petroleum, as defined in the North American Industrial Classification Standard No. 32411 and including any associated sulfur recovery plant."

Because the hydrogen plant will not process petroleum, the hydrogen plant flare will not be subject to BAAQMD Regulation 12, Rules 11 and 12. The flare will be used exclusively to burn hydrogen, pressure swing absorption gas that is generated by the plant, and natural gas in the pilots for the flare. All three of these material are low in sulfur because the feed to the hydrogen plant is low in sulfur and sulfur is removed from the feed by a zinc oxide catalyst. If the feed to the hydrogen plant or the hydrogen plant furnace must be flared due to an upset, it will be burned in the refinery flares.

NSPS

Subpart D

This subpart applies to fossil-fuel fired steam generating units with a heat input over 250 MMbtu/hr. The definition of fossil-fuel fired steam generating unit in Section 60.41(a) is "a furnace or boiler used in the process of burning fossil fuel for the purpose of producing steam by heat transfer." S2, Hydrogen Plant Furnace, is not subject to 40 CFR 60, Subpart D, because it is primarily a furnace instead of a steam generating unit, although it does generate steam. In any case, S2 would easily comply with the 0.1 lb particulate matter/MMbtu standard

FINAL: October 5, 2007

Evaluation Report, Application No. 13678, Air Liquide Large Industries US L.P., Facility B7419

in Section 60.42(a)(1) the 20% opacity standard in Section 60.42(a)(2), and the 0.2 lb NO_x/MMbtu. S2 is expected to emit about 0.0037 lb PM₁₀/MMbtu and 0.00658 lb NO_x/MMbtu. Since the fuel will be very clean, it is not expected to have any visible emissions.

The standard does not contain a limit for sulfur dioxide for gaseous-fueled heaters.

Subpart Da

This subpart applies to electric utility steam-generating units with an electrical output that is higher than 25 MW per Sections 60.40Da and 60.41Da. Electricity will be generated at the hydrogen plant, but the output will be about 12 MW so S2, Hydrogen Plant Furnace, is not subject to the standard.

Subpart Db

This subpart applies to steam generating units with a heat input over 100 MMbtu/hr. The definition of steam generating units in Section 60.41b excludes process heaters, so S2, Hydrogen Plant Furnace, is not subject to the standard.

Subpart Dc

This subpart applies to steam generating units with a heat input over 10 MMbtu/hr and under 100 MMbtu/hr. The definition of steam generating units in Section 60.41c excludes process heaters, so S2, Hydrogen Plant Furnace, is not subject to the standard.

NSPS, Subpart J

S2, Hydrogen Plant Furnace, and S3, Flare, will be subject to 40 CFR 60, Subpart J, Standards of Performance for Petroleum Refineries because they will burn fuel gas as defined by the NSPS: "any gas which is generated at a petroleum refinery and which is combusted."

The heater will be subject to the H₂S limit for fuel in Section 60.104(a)(1) of 0.10 gr/dscf or approximately 160 ppm. S2 will comply with the limit because it will burn either complying refinery fuel gas that will be supplied by the refinery, natural gas, or PSA gas, which is derived from the complying refinery fuel gas or natural gas and therefore cannot contain more H₂S than the limit.

Air Liquide will be responsible for continuously monitoring the H₂S content of the refinery, natural gas, and PSA gas at S2, Hydrogen Plant Furnace, as required by Section 60.105(a)(4). The permit conditions will also allow Air Liquide to install an SO₂ CEM instead of monitoring the sulfur in the furnace and hydrogen plant feed as allowed by 40 CFR 60.105(a)(3).

The flare will also be subject to the H₂S limit for fuel in Section 60.104(a)(1). The standard states:

FINAL: October 5, 2007

Evaluation Report, Application No. 13678, Air Liquide Large Industries US L.P., Facility B7419

a) No owner or operator subject to the provisions of this subpart shall:
(1) Burn in any fuel gas combustion device any fuel gas that contains hydrogen sulfide (H₂S) in excess of 230 mg/dscm (0.10 gr/dscf). The combustion in a flare of process upset gases or fuel gas that is released to the flare as a result of relief valve leakage or other emergency malfunctions is exempt from this paragraph.

Process upset gases are defined in Section 60.101 as:

Process upset gas means any gas generated by a petroleum refinery process unit as a result of start-up, shut-down, upset or malfunction.

When the hydrogen plant sends gases to the flare due to a start-up, shut-down, upset or malfunction, the flare will not be subject to Section 60.104(a)(1). However, when the hydrogen plant sends gases to the flare due to “customer constraint”, “contractual outage”, or planned maintenance, the flare will be subject.

In any case, the flare will comply with the standard because it will only burn clean hydrogen or PSA gas. In those cases where the flare is subject to the standard, the facility will be required to monitor the H₂S content of the gas continuously in accordance with Section 60.104, unless the facility obtains an alternative monitoring plan from USEPA.

EPA proposed changes to Subpart J on May 14, 2007, and intends to finalize changes by April 2008. If these changes allow the facility to monitor the H₂S content in a different way or exempts some fuels from monitoring, the permit condition will allow Air Liquide to take advantage of changes in the standard when the changes are finalized.

MONITORING ANALYSIS

S1, Hydrogen Plant is subject to an annual throughput limit, cumulative increase limits of 4.35 lb POC/day from the deaerator vent and 8.2 lb fugitive POC/day, an ammonia limit of 0.64 lb/hr from the deaerator vent, and a limit on total sulfur in the feed to the hydrogen plant. The hydrogen plant is also subject to the combined organic compound limit in BAAQMD Regulation 8, Rule 2. The hydrogen plant will be subject to an annual source test to determine compliance with the deaerator vent limits. The owner/operator will determine compliance with the fugitive POC limit by using the methods in BAAQMD Regulation 8, Rule 18, Equipment Leaks. The total sulfur content of the feed to the hydrogen plant will be determined once per week at the outlet of the zinc oxide feed treatment system in the hydrogen plant by taking a grab sample and measuring it once per week. Alternately, the owner/operator may install an SO₂ CEM on S2, Hydrogen Plant Furnace stack. Sulfur in the hydrogen plant feed is removed by the zinc oxide feed treatment system. The plant has two beds of zinc oxide and monitors

FINAL: October 5, 2007

Evaluation Report, Application No. 13678, Air Liquide Large Industries US L.P., Facility B7419

sulfur at the outlet periodically. If the sulfur is removed from the feed, the syngas (PSA gas) that is fed to the hydrogen plant furnace and that provides approximately 85% of the heat input to the furnace should have no sulfur. Therefore, monitoring for sulfur in the feed is an effective method of ensuring that the syngas has no sulfur. Since the amount of zinc oxide should last at least nine months, monitoring on a weekly basis is sufficient monitoring. The owner/operator also has the option of installing an SO₂ CEM on the S2, Hydrogen Plant Furnace, stack.

S2, Hydrogen Plant Furnace, has limits on hourly and annual heat input, concentration limits on NO_x, CO, and NH₃, lb/MMbtu limits on POC, SO₂, and PM₁₀, hourly and annual mass emission limits on NO_x, CO, POC, PM₁₀, and SO₂, NH₃, and sulfuric acid mist, and sulfur and H₂S limits on the fuel. The heater will have a fuel meter to ensure compliance with the heat input limits. Since the heater is abated by SCR, it will have a NO_x CEM to ensure that the abatement device is in compliance. A CO CEM was required by 40 CFR 63, Subpart DDDDD, before it was vacated by the DC Circuit Court on June 8, 2007. The District will require a CO CEM as part of case-by-case MACT pursuant to 40 CFR 63.52(a). The fuel gas will be monitored for H₂S with a continuous emission monitor as required by 40 CFR 60, Subpart J, unless EPA amends the standard to allow another monitoring method. In addition, total sulfur will be monitored 3 times/day. The owner/operator will perform an annual test for compliance with the POC, PM₁₀, SO₂, sulfuric acid mist, and ammonia limits. Non-compliance with the POC and PM₁₀ limits are not expected at this source. Since the source will be permitted to emit about 24 tpy of ammonia, the owner/operator will develop a correlation between the ammonia concentration and the ammonia injection rate. After the correlation is developed, the owner/operator will monitor ammonia continuously via the injection rate.

S3, Hydrogen Plant Flare

The flare is subject to annual limits for NO_x, CO, POC, PM₁₀, SO₂ and a daily limit for NO_x. Emissions will be monitored by installing a flow meter at the inlet to the flare and calculating the emissions for each event in the same manner as shown in Appendix A.

If gases are sent to the flare that are not considered to be startup, shutdown, malfunction, or upset gases, the facility must monitor the gases continuously for H₂S in accordance with 40 CFR 60.104.

In addition, the flare is subject to standard conditions to determine if the 1.0 Ringelmann limit in BAAQMD Regulation 6-301 is exceeded during flaring events.

S4, Cooling Tower, is subject to monitoring of dissolved solids to ensure that the particulate matter emissions are as described in the permit application. It is also

FINAL: October 5, 2007

Evaluation Report, Application No. 13678, Air Liquide Large Industries US L.P., Facility B7419

subject to visual monitoring, and chlorine content monitoring to ensure that POC emissions are as described. If POC emissions are found, the owner/operator must measure the POC emissions using EPA Laboratory Method 8015.

S5, Ammonia Tank: The tank is not expected to have emissions, so no monitoring has been imposed.

Overall annual emission limits have been imposed in Condition 23181, parts B.1-B.3, to ensure that the emissions of the project are less than the emissions proposed by the applicant. The reason that this condition has been imposed is to allow the facility to exceed certain limits during startup and shutdown and still comply with the annual limits. Part B.4 contains the monitoring and reporting for these limits.

CEQA

The California Environmental Quality Act (CEQA) calls for a review of potential significant environmental impacts from proposed projects. This project has been determined to be subject to CEQA by the Contra Costa County Community Development Department (CCCCDD). The CCCCDD is the Lead Agency for CEQA for this project. In accordance with Regulation 2-1-310.3, the District may not issue an Authority to Construct for this project until final action has been taken by the Lead Agency. A draft Environmental Impact Report (EIR) was prepared by the CCCCDD in November, 2006. This EIR includes all sources and activities that are the subject of this application. The District is a responsible agency under CEQA and has provided comments to the CCCCDD on the draft EIR. These comments, as well as others received by CCCCDD have been addressed in a revised EIR.

On September 25, 2007, the final EIR was certified by the Contra Costa County Board of Supervisors. The District must act on the application within 30 days of the certification.

As a responsible agency, the District has prepared findings for the purposes of CEQA. They are attached in Appendix C.

NESHAPS

40 CFR 63, Subpart CC

The deaerator vents at the hydrogen plants are not considered miscellaneous process vents according to Section 60.641.

Relief valve discharges are not considered miscellaneous process vents.

40 CFR 63, Subpart DDDDD

S2, Hydrogen Plant Furnace, is subject to 40 CFR 63, Subpart DDDDD, National Emission Standards for Hazardous Air Pollutants for Industrial, Commercial, and

FINAL: October 5, 2007

Evaluation Report, Application No. 13678, Air Liquide Large Industries US L.P., Facility B7419

Institutional Boilers and Process Heaters. The DC Circuit Court vacated the standard on June 8, 2007. Where there is no MACT for a new source and the deadline for promulgation of a standard by EPA is past, local agencies must determine case-by-case MACT for the new source, in accordance with 40 CFR 63.52(a). The emission limit for S2 in the standard was 400 ppm CO. There were no other limits for gaseous-fueled boilers. A CO CEM was required for units over 100 MMBtu/hr.

The reason that the court gave for vacating the MACT was that EPA had inappropriately classified solid waste incineration units that were subject to Section 129 of the Clean Air Act as solid fuel units that were subject to the MACT. This classification greatly increased the number of units subject to the MACT and therefore skewed the determination of the MACT floor. The court stated that the "universe of units ... will be far smaller and more homogenous [sic]" after the solid waste units were taken out of the group of units affected. The court expects that the rule will change substantially when EPA considers the smaller pool of units.

One possible outcome is that the standards may become more stringent because the HAP emissions from the solid waste incineration units are expected to be higher. The MACT "floor" is based on the performance of the top 12 percent of the units in a category.

EPA had determined that CO was an appropriate surrogate for organic HAPs. The argument was that high CO was indicative of poor combustion and therefore, poor destruction of organic HAPs. This is a reasonable assumption.

Following are the CO limits proposed by EPA:

- New, large and limited use solid fuel units: 400 PPM @ 7% O₂
- Small solid fuel units: None
- New, large and limited use liquid fuel units: 400 PPM @ 3% O₂
- Small liquid fuel units: None
- New, large and limited use gaseous fuel units: 400 PPM @ 3% O₂
- Small gaseous fuel units: None
- Existing units: None

Small units are defined as units with a capacity less than 10 MMBtu/hr.

Gaseous-fueled units are not expected to be sources of metallic or inorganic HAP.

The MACT limit for S2, therefore, was 400 PPM @ 3% O₂, which is equivalent to the BAAQMD Regulation 9, Rule 7, Nitrogen Oxides and Carbon Monoxide from Industrial, Institutional, and Commercial Boilers, Steam Generators, and Process Heaters, which was adopted in 1992.

The District does not have the resources to survey all industrial, commercial, and institutional boilers and process heaters in the United States and determine the MACT "floor." However, the District notes that the CO BACT limit in the District's BACT workbook for boilers over 50 MMbtu/hr has been 50 ppmv since 2005. For refinery process heaters over 50 MMbtu/hr, the BACT limit has been 50 ppmv since 1994. The South Coast AQMD has had BACT limits for CO of 50 ppm for boilers since 2000.

On page 1680, column 3, second paragraph, of the MACT proposal published on January 13, 2003, EPA states:

"The approach that we use to calculate the MACT floors for new sources is somewhat different from the approach that we use to calculate the MACT floors for existing sources. While the MACT floors for existing units are intended to reflect the average performance achieved by a representative group of sources, the MACT floors for new units are meant to reflect the emission control that is achieved in practice by the best controlled source. Thus, for existing units, we are concerned about estimating the central tendency of a set of multiple units, while for new units, we are concerned about estimating the level of control that is representative of that achieved by a single best controlled source."

If we agree with EPA that low CO levels indicate low levels of organic HAPs, then lower CO levels are better than higher CO levels. Considering that the "best controlled sources" have CO levels that are 50 ppm or lower, 400 ppm cannot be considered to be the proper MACT limit for a new gaseous-fueled source. The source is subject to a BACT CO limit of 10 ppm CO @ 3% O₂. This level will be considered to be presumptive MACT for this source until EPA re-proposes and re-promulgates MACT. Since it is not expected that EPA will propose a limit that is lower than this limit, the source incurs no risk from this determination. Due to the size of the source, the CEM for CO will still be required.

40 CFR 70, Title V

The facility is subject to the Title V program because it is part of a major facility (the ConocoPhillips Refinery and Carbon Plant) as defined by BAAQMD Regulation 2-6-206. The definition of "Part 70 permit" in Section 70.2 acknowledges that a "group of permits" may cover a "source." (EPA's definition of "source" is similar to the District's definition of "facility.") Because more than one permit may be given to a facility, the District may grant a separate permit to Air Liquide.

The District will propose the Title V permit after the District has received public comment on and finalized the conditions.

FINAL: October 5, 2007

Evaluation Report, Application No. 13678, Air Liquide Large Industries US L.P., Facility B7419

40 CFR 72-78, ACID RAIN

Electricity will be generated using excess heat at the hydrogen plant. The hydrogen plant will not be subject to 40 CFR 72-78 because it will not sell electricity. The hydrogen plant or ConocoPhillips will consume all electricity that is produced. The standards apply only to "utilities," which are defined in 40 CFR 72.2 as "any person who sells electricity."

PSD

The discussion of the PSD analysis is contained in the engineering evaluation for Application 13424 and is hereby incorporated by reference. However, the conclusion will be restated here.

The combined project for the ConocoPhillips refinery, the Air Liquide hydrogen plant, and the ConocoPhillips Carbon Plant was subject to PSD because the emissions increase for PM10 was over 15 tons per year. After the permit was proposed, the applicants decided to reduce the PM10 emissions by 2 tons per year, which may be accomplished either by lowering the PM10 concentration or by curtailing operations, and to withdraw the PSD application. Therefore, the project is no longer a PSD project.

6. RECOMMENDATIONS

Issue a conditional authority to construct for the following sources:

- S1, Hydrogen Plant (120 MMscf/day) including HRSG and steam turbine generator (12 MW)
- S2, Hydrogen Plant Furnace, 1072 MMbtu/hr abated by A1, SCR
- S3, Hydrogen Plant Flare, 2200 MMbtu/hr

Issue a letter of exemption to the following sources:

- S4, Cooling Tower, 3,700 gpm (exempt per BAAQMD Regulation 2-1-128.4)
- S5, Ammonia Tank, 10,000 gal 19% aqueous solution (exempt per BAAQMD Regulation 2-1-113.2)

7. PERMIT CONDITIONS

Any condition that is preceded by an asterisk is not federally enforceable.

"BAAQMD Regulation 2, Rule 5" replaces the following basis for permit conditions: "Toxics Risk Management."

CONDITION 23178

S1, Hydrogen Plant

1. The production of S1, Hydrogen Plant, shall not exceed 120 MMscf H₂/day, averaged over any consecutive 12-months. [Cumulative Increase]
2. The owner/operator of the electrical generator associated with the hydrogen plant shall not generate more than 12 MW at any time. The owner/operator shall ensure that the hydrogen plant or the refinery consumes all of the electricity that is produced by the generator. [2-1-301, 2-1-305]
3. The owner/operator shall not burn any fuel in the HRSG associated with the S1, Hydrogen Plant. [2-1-301, 2-1-305]
4. The owner/operator shall ensure that the emissions of POC from the deaerator vent at S1 do not exceed 4.35 lb/day. [2-1-301, 2-1-305, Cumulative Increase]
5. The owner/operator shall ensure that the emissions of NH₃ from the deaerator vent at S1 do not exceed 0.64 lb/hr. [Regulation 2, Rule 5]
6. The owner/operator shall ensure that the fugitive emissions of POC from the components (valves, flanges, pumps, compressors, connectors, sample points, etc.) at the hydrogen plant do not exceed 3,000 lb/year. [Cumulative Increase, 2-1-305]

7. The owner/operator shall ensure that the concentration of total sulfur in the feed to the hydrogen plant does not exceed 35 ppmv. [Cumulative Increase, 2-1-305]
8. The owner/operator shall measure total sulfur at the outlet of the zinc oxide feed treatment system in the hydrogen plant by taking a grab sample and measuring it once per week. Alternately, the owner/operator may install an SO₂ CEM on S2, Hydrogen Plant Furnace stack. [BACT, Cumulative Increase]
9. No later than 90 days from the startup of S1 and every year thereafter, the owner/operator shall conduct a District-approved source test to determine compliance with the limit in Parts 4 and 5 for POC and NH₃. The owner/operator shall conduct the POC source tests in accordance with the Manual of Procedures, Volume IV, Method ST-7 or EPA Method 25 or 25A. The owner/operator shall conduct the NH₃ source tests in accordance with the Manual of Procedures, Volume IV, Method ST-1B. The owner/operator shall submit the source test results to the District staff no later than 60 days after the source test. [Cumulative Increase, 2-1-305]
10. The owner/operator shall ensure that all pressure relief devices on the process unit are vented to a fuel gas recovery system, furnace, or flare with a recovery/destruction efficiency of 98%. [8-28-302, BACT]

Fugitive Components at S1, Hydrogen Plant, and S2, Hydrogen Plant Furnace

- 11a. The owner/operator shall equip all new light hydrocarbon control valves installed at S1 and S2 with live loaded packing systems and polished stems, or equivalent.
[BACT]
- 11b. The owner/operator shall comply with a leak standard of 100 ppm of TOC (measured as C1) at any new valve installed at S1 and S2. The owner/operator shall not be considered in violation of the leak standard if the owner/operator complies with the applicable minimization and repair provisions contained in Regulation 8, Rule 18. [BACT, Regulation 8, Rule 18]
12. The owner/operator shall equip all new flanges/connectors installed in the light hydrocarbon piping systems at S1 and S2 with graphitic-based gaskets unless the service requirements prevent this material. [BACT]
13. The owner/operator shall equip all new hydrocarbon centrifugal compressors installed at S1 and S2 with "wet" dual mechanical seals with a heavy liquid barrier fluid, or dual dry gas mechanical seals buffered with inert gas.
[BACT]

14. The owner/operator shall equip all new light hydrocarbon centrifugal pumps installed at S1 and S2 with a seal-less design or with dual mechanical seals with a heavy liquid barrier fluid, or equivalent. [BACT]
15. The owner/operator shall comply with a leak standard of 100 ppm of TOC (measured as C1) at any new pumps and/or compressors installed at S1 and S2. The owner/operator shall not be considered in violation of the leak standard if the owner/operator complies with the applicable minimization and repair provisions contained in Regulation 8-18. All pumps and/or compressors subject to the leak standard of 100 ppm TOC shall be included in the total number of pumps and compressors used in Regulation 8-18-306.2 to determine the total number of non-repairable pumps and compressors allowed. [BACT] [BACT]
16. The Owner/Operator shall submit a count of installed pumps, compressors, valves, and flanges/connectors every 180 days starting the startup date of the first unit, S1 or S2, until construction is complete. For flanges/connectors, the owner/operator shall also provide a count of the number of graphitic-based and non-graphitic gaskets used. The owner/operator has been permitted to install fugitive components (948 valves in gas service, 48 valves in light liquid service, 4,193 flanges in gas service, 98 flanges in light liquid service, 5 pumps in light liquid service, 4 sample connections in gas service, 3 compressors in gas service) with a total POC emission rate of 1.5 ton/yr. The exact number of components may change without penalty. If there is an increase in the total fugitive component emissions, the plant's cumulative emissions for the project shall be adjusted to reflect the difference between emissions based on predicted versus actual component counts. The owner/operator shall provide to the District all additional required offsets at an offset ratio of 1.15:1 no later than 14 days after the submittal of the final POC fugitive equipment count. If the actual component count is less than the predicted, at the completion of the project, the total will be adjusted accordingly and all emission offsets applied by the owner/operator in excess of the actual total fugitive emissions will be credited back to owner/operator prior to issuance of the permits. [BACT, Cumulative Increase, Regulation 2, Rule 5]

(The sentence about changes in the exact number of components has been added in response to a comment by the applicant. This note will be removed in the final permit conditions.)

17. Inspections

The owner/operator shall conduct inspections of new fugitive components installed at S1 and S2 in light hydrocarbon service with an initial boiling point less than or equal to 302 degree F in accordance with the frequency listed below:

Pumps: Quarterly
Compressors: Quarterly
Valves: Quarterly

Connectors (Not Flanges): Annual
Flanges: Annual
[BACT, Regulation 8, Rule 18]

18. In order to determine compliance with part 6, the owner/operator shall determine the daily emissions of fugitive components within 90 days of start-up, and within 30 days of the end of every calendar quarter thereafter. The owner/operator shall use the last concentration measured in accordance with BAAQMD Regulation 8, Rule 18, for each component. The owner/operator shall use the equations in ARB publication California Implementation Guidelines for Estimating Mass Emissions of Fugitive Hydrocarbon Leaks at Petroleum Facilities. [Cumulative Increase, Regulation 2-1-305]

CONDITION 23179

S2, Hydrogen Plant Furnace

1. S2 shall use only pressure swing adsorption (PSA) off gas, refinery fuel gas and pipeline quality natural gas as fuel. [Cumulative Increase]
2. Total fuel firing at S2 shall not exceed 9,636,000 MMbtu (HHV) over any consecutive 12-month period. [Cumulative Increase]
3. Total fuel firing at S2 shall not exceed 1,072 MMbtu (HHV) during any clock hour. [Cumulative Increase]
4. The owner/operator shall ensure that the feed to S2 does not contain more than 35 ppmv total sulfur. [BACT, Cumulative Increase, 2-1-305]
5. The following emission concentration limits from S2 shall not be exceeded. These limits shall not apply during startup periods not exceeding 24 hours (120 hours when drying refractory or during the first startup following catalyst replacement) and shutdown periods not exceeding 24 hours. The District may approve other startup and shutdown durations.
 - a. NOx: 5 ppmv @ 3% oxygen, averaged over any clock hour [BACT]
 - b. CO: 10 ppmv @ 3% oxygen, averaged over any 1 hour period [BACT, 40 CFR 63.52(a)]
 - c. POC: 0.0027 lb/MMbtu, averaged over any 1 hour period [BACT]
 - d. PM10: 0.0037 lb/MMbtu, averaged over any 1 hour period [BACT]
 - e. SO2: 0.0012 lb/MMbtu, averaged over any 1 hour period [BACT]
[BACT](The manufacturer requires 120 hours for the drying of refractory or after a catalyst change. This is allowable because the emissions will be within the annual limits. This note will be removed in the final permit conditions.)
6. *The following emission concentration limits from S2 shall not be exceeded.
NH3: 10 ppmv @ 3% oxygen (8 hr average) [Regulation 2, Rule 5]

- 7a. The following hourly mass emission limits from S2 shall not be exceeded. These limits shall not apply during startup periods not exceeding 24 hours (120 hours when drying refractory or during the first startup following catalyst replacement) and shutdown periods not exceeding 24 hours. The District may approve other startup and shutdown durations.
 - a. NO_x: 7.5 lb per clock hour [BACT]
 - b. CO: 9.1 lb per clock hour [BACT]
 - c. POC: 3.5 lb per clock hour [BACT]
 - d. PM₁₀: 4.8 lb per clock hour [BACT]
 - e. SO₂: 1.5 lb per clock hour [BACT]
- 7b. The following hourly mass emission limit from S2 shall not be exceeded.
 - a. NO_x: 50 lb per clock hour [BACT]
[BACT]
8. *The following hourly mass emission limit from S2 shall not be exceeded.
 - a. NH₃: 6.5 lb per clock hour
[Regulation 2, Rule 5]
9. The following hourly mass emission limit from S2 shall not be exceeded.
 - a. Sulfuric acid mist: 0.098 lb per clock hour
[Regulation 2, Rule 5, PSD]
10. The following annual mass emission limits from S2 shall not be exceeded including periods of startup, shutdown, upset and malfunction:
 - a. NO_x: 28.1 tons per any consecutive 12 months [BACT]
 - b. CO: 34.2 tons per any consecutive 12 months [BACT]
 - c. POC: 11.5 tons per any consecutive 12 months [BACT]
 - d. PM₁₀: 13.8 tons per any consecutive 12 months [BACT]
 - e. SO₂: 5.0 tons per any consecutive 12 months [BACT]
[Cumulative Increase]
11. *The following annual mass emission limits from S2 shall not be exceeded including periods of startup, shutdown, upset and malfunction.
 - a. NH₃: 48,200 lb per any consecutive 12 months
[Regulation 2, Rule 5]
12. The following annual mass emission limits from S2 shall not be exceeded including periods of startup, shutdown, upset and malfunction.
 - a. Sulfuric acid mist: 860 lb any consecutive 12 months
[2-1-305, Regulation 2, Rule 5, PSD]
13. A1, SCR unit, shall abate the S2, Hydrogen Plant Furnace, at all times, with the following exceptions. Operation of A1 is not required for limited periods during startup and shutdown. S2 may operate without SCR abatement on a temporary basis for periods of planned or emergency maintenance. A District-approved NO_x CEM shall monitor and record the S2 NO_x emission rate whenever S2 operates without abatement. All emission limits

applicable to S2 shall remain in effect even if it is not operated with SCR abatement. [BACT, Cumulative Increase]

- 14a. The owner/operator shall test refinery fuel gas prior to combustion at S2 to determine total sulfur concentration with a total sulfur analyzer (Houston Atlas or equivalent) at least once per 8-hour shift (3 times per calendar day). At least 90% of these samples shall be taken each calendar month. No readable samples or sample results shall be omitted. To demonstrate compliance with Part 4, the owner/operator shall measure and record the daily average sulfur content. The owner/operator shall keep records of sulfur content in fuel gas for at least five years and shall make these records available to the District upon request. The owner/operator is not required to test PUC-quality natural gas for total sulfur. If the sulfur content of feed to S1, Hydrogen Plant, is monitored in accordance with Condition 23178, part 8, and the sulfur content is less than 35 ppmv, the owner/operator is not required to test PSA gas for total sulfur. [BACT, Cumulative Increase]
- 14b. If the owner/operator elects to install a SO₂ CEM at the S2, Hydrogen Plant Furnace, stack, the owner/operator is not required to perform the monitoring in Condition 23178, parts 7 and 8 and Condition 23179, parts 4, 14a, and 15. In this case, the monitor shall comply with BAAQMD Manual of Procedures, Volume V, and 40 CFR 60.105(a)(3). The monitor shall be used to determine compliance with the SO₂ limits in 40 CFR 60.105(a)(3) of 20 ppmdv @ 0% O₂, the lb/MMbtu limit in part 5e, the hourly limit in part 7a, and the annual limits in part 10 and Condition 23181, part B.2.
(Parts 14b has been amended at the applicant's request to allow the use of SO₂ CEM monitoring that is allowed by Condition 23179, part 14b, to determine compliance with the annual limits. This note will not appear in the final permit conditions.)
15. The owner/operator shall install, calibrate, maintain, and operate a District-approved continuous monitoring system and recorder for H₂S in the gas that is burned by the heater. The owner/operator shall keep the H₂S data for at least five years and shall make these records available to the District upon request. If USEPA amends 40 CFR 60, Subpart J, such that a continuous monitoring system is not required for this heater, the owner/operator will not be required to install the system. If the system has been installed, the owner/operator may remove the system. [40 CFR 60.105(a)(4), Cumulative Increase]
16. No later than 90 days from the startup of S2, the owner/operator shall conduct District-approved source tests to determine initial compliance with the limits in Parts 5, 6, 7, 8, and 9 for NO_x, CO, POC, PM₁₀, NH₃, SO₂, sulfuric acid mist, and POC. The owner/operator shall conduct the source tests in accordance with Part 18. The owner/operator shall submit the

source test results to the District source test manager and the District Director of Compliance and Enforcement no later than 60 days after the source test. [BACT, Cumulative Increase, PSD]

17. On an annual basis, the owner/operator shall conduct District-approved source tests to determine compliance with the limits in Parts 5c, 5d, 5e, 7c, 7e, 7e, 8, and 9 for POC, PM10, NH3, SO2, and sulfuric acid mist. The owner/operator shall conduct the source tests in accordance with Part 18. The owner/operator shall submit the source test results to the District source test manager and the District Director of Compliance and Enforcement no later than 60 days after the source test. [BACT, Cumulative Increase, PSD, Regulation 2, Rule 5]
18. The owner/operator shall submit protocols for all source test procedures to the District's Source Test Section prior to conducting any tests. The owner/operator shall comply with all applicable testing requirements for continuous emissions monitors as specified in Volume V of the District's Manual of Procedures. The owner/operator shall notify the District's Source Test Section, in writing, of the source test protocols and projected test dates at least 7 days prior to testing. [BACT, Cumulative Increase, PSD]
19. The following instruments shall be installed and maintained to demonstrate compliance with Parts 5a, 5b, 7a, 7b, 9a and 9b, BAAQMD Regulation 1-520 and 40 CFR 63.52:
 - a. continuous NOx analyzer/recorder
 - b. continuous CO analyzer/recorder
 - c. continuous O2 or CO2 analyzer/recorderThe instruments shall operate at all times of operation of S2 including start-up, shutdown, upset, and malfunction, except as allowed by BAAQMD Regulation 1-522, BAAQMD Manual of Procedures, Volume V, and 40 CFR 63, Subpart DDDDD. If necessary to comply with this requirement, the owner/operator shall install dual-span monitors. [1-520, BACT, Cumulative Increase, 40 CFR 63.52(a)]
20. The owner/operator shall equip S2 with a District-approved continuous fuel flow monitor and recorder in order to determine fuel consumption. A parametric monitor as defined in Regulation 1-238 is not acceptable. The owner/operator shall keep continuous fuel flow records for at least five years and shall make these records available to the District upon request. [Cumulative Increase]
21. Ammonia (NH3) emission concentrations at the hydrogen plant stack shall not exceed 10 ppmv, on a dry basis, corrected to 3% O2, on a clock hour basis. This ammonia emission concentration shall be verified by the continuous recording of the ammonia solution injection rate to A1, SCR. The correlation between the heat input rates, the SCR ammonia solution injection rates, and corresponding ammonia emission concentration at the hydrogen plant stack shall be determined in accordance with permit condition 23. (Regulation 2, Rule 5)

22. The owner/operator shall demonstrate compliance with part 21 by using a properly operated and maintained continuous monitor (during all hours of operation including start-up and shutdown periods) for the ammonia solution injection rate. The owner/operator shall record the ammonia solution injection rate every 15 minutes (excluding normal calibration periods) and shall summarize the ammonia solution injection rate for each clock hour. (Regulation 2, Rule 5)
23. Within 60 days of start-up of the hydrogen plant furnace, the owner/operator shall conduct a District-approved source test on at the hydrogen plant stack to determine the corrected ammonia emission concentration to determine compliance with part 21. The source test shall determine the correlation between the heat input rates of the hydrogen plant furnace, the ammonia solution injection rate, and the corresponding ammonia emission concentration at the emission point. The source test shall be conducted over the expected operating range of the hydrogen plant furnace to establish the range of ammonia solution injection rates necessary to achieve NOx emission reductions while maintaining ammonia slip levels. Source testing shall be repeated on an annual basis thereafter. Ongoing compliance with part 21 shall be demonstrated through calculations of corrected ammonia concentrations based upon the source test correlation and continuous records of ammonia solution injection rate. Source test results shall be submitted to the District within 45 days of conducting the tests. (Regulation 2, Rule 5)

CONDITION 23180

S3, Hydrogen Plant Flare

1. The owner/operator shall ensure that only the following streams are sent to S3, Hydrogen Plant Flare:
 - a. Hydrogen
 - b. Syn-gas
 - c. Venting from the ammonia tank
 - d. PSA OffgasThe owner/operator shall ensure that any feed for S1, Hydrogen Plant, or any fuel including natural gas that is provided to S2, Hydrogen Plant Furnace, is not flared in S3, Hydrogen Plant Flare. [2-1-305]
2. S3, Hydrogen Plant Flare, may be used during startup, shutdown, upset, or malfunction of S1, Hydrogen Plant, loss of the PSA process, PSA maintenance, contractual outage, and customer constraint, as long as the emissions do not exceed the limits in part 4. [2-1-305, Cumulative Increase]

3. The owner/operator shall install a flow meter to determine the flow of gases to the flare. The flow meter shall comply with the requirements for flow meters in BAAQMD Regulation 12, Rule 11. [Cumulative increase]
4. The owner/operator shall ensure that the emissions of S3, Hydrogen Plant Flare, do not exceed the following limits:
 - a. NOx: 2.8 tons/any consecutive 12 months [Cumulative increase]
 - b. CO: 12.1 tons/any consecutive 12 months [Cumulative increase]
 - c. NOx: 129 lb/any consecutive 60 minutes [2-1-403, CAAQS]
5. The owner/operator shall estimate the emissions every month by using the flow data to the flare and estimating emissions using the emission factors provided in Application 13678. [Cumulative increase]
6. If the limits in parts 4a and 4b are exceeded, the owner/operator shall apply to increase the annual limit within 60 days of determining that the limit has been exceeded, and shall provide offsets for the increase in the limits. If the limit in part 4c is exceeded, the owner/operator shall determine using PSD modeling if the CAAQS or NAAQS for NO₂ was exceeded during the event, and if so, shall report the exceedance to the BAAQMD Director of Enforcement and Compliance. [2-1-403, CAAQS, Cumulative increase]
7. For the purposes of these conditions, a flaring event is defined as a flow rate of vent gas flared in any consecutive 15 minutes period that continuously exceeds 330 standard cubic feet per minute (scfm). If during a flaring event, the vent gas flow rate drops below 330 scfm and then increases above 330 scfm within 30 minutes, that shall still be considered a single flaring event, rather than two separate events. For each flaring event during daylight hours (between sunrise and sunset), the owner/operator shall inspect the flare within 15 minutes of determining the flaring event, and within 30 minutes of the last inspection thereafter, using video monitoring or visible inspection following the procedure described in Part 8. [Regulation 2-6-409.2]
8. The owner/operator shall use the following procedure for the initial inspection and each 30-minute inspection of a flaring event.
 - ~~a. If the owner/operator can determine that there are no visible emissions using video monitoring, then no further monitoring is necessary for that particular inspection.~~
 - b. If the owner/operator cannot determine that there are no visible emissions using video monitoring, the owner/operator shall conduct a visual inspection outdoors using either:
 - i. EPA Reference Method 9; or
 - ii. Survey the flare by selecting a position that enables a clear view of the flare at least 15 feet, but not more than 0.25 miles, from the emission source, where the sun is not directly in the observer's eyes.

FINAL: October 5, 2007

Evaluation Report, Application No. 13678, Air Liquide Large Industries US L.P., Facility B7419

- c. If a visible emission is observed, the owner/operator shall continue to monitor the flare for at least 3 minutes, or until there are no visible emissions, whichever is shorter.
 - d. The owner/operator shall repeat the inspection procedure for the duration of the flaring event, or until a violation is documented in accordance with Part 9. After a violation is documented, no further inspections are required until the beginning of a new calendar day.
[Regulation 6-301, 2-1-403]
9. The owner/operator shall comply with one of the following requirements if visual inspection is used:
- ~~a. If EPA Method 9 is used, the owner/operator shall comply with Regulation 6-301 when operating the flare.~~
 - ~~b. If the procedure of Part 8.b.ii is used, the owner/operator shall not operate a flare that has visible emissions for three consecutive minutes.~~
[Regulation 2-1-403]
10. The owner/operator shall keep records of all flaring events, as defined in Part 7. The owner/operator shall include in the records the name of the person performing the visible emissions check, whether video monitoring or visual inspection (EPA Method 9 or visual inspection procedure of Part 8) was used, the results of each inspection, and whether any violation of this condition (using visual inspection procedure in Part 8) or Regulation 6-301 occurred (using EPA Method 9). [Regulation 2-1-403]
11. The owner/operator will ensure that S3, Flare, complies with all applicable provisions of 40 CFR 60, Subpart J. This provision will be deleted when the applicable citations from this standard are incorporated into the Major Facility Review permit. [40 CFR 60, Subpart J]
12. The owner/operator shall install, calibrate, maintain, and operate a District-approved continuous monitoring system and recorder for H₂S in the gas that is burned by the flare. The owner/operator shall keep the H₂S data for at least five years and shall make these records available to the District upon request. If USEPA amends 40 CFR 60, Subpart J, such that a continuous monitoring system is not required for this flare, the owner/operator will not be required to install the system. If the system has been installed, the owner/operator may remove the system. [40 CFR 60.105(a)(4), Cumulative Increase]

An annual PM₁₀ limit for sources in Facilities A0016 and B7419 was added to ensure that the CFEP project does not exceed PSD thresholds for PM₁₀.

CONDITION 23181

A. Facility Conditions

- 1. *The owner/operator shall notify the District in writing by fax or email no less than three calendar days in advance of any scheduled startup or shutdown

of any process unit, and, for any unscheduled startup or shutdown of a process unit, within 48 hours or within the next normal business day. The notification shall be sent in writing by fax or email to the Director of Enforcement and Compliance. This requirement is not federally enforceable. [Regulation 2-1-403]

2. The owner/operator shall ensure that the concentration of ammonia in the ammonia tank is less than 20% by weight so that 40 CFR 68, Accidental Release, does not apply. [2-1-305]

B. Project Mass Emission Limits

1. Following are the sources that are subject to the project mass emission limits:
S1, Hydrogen Plant including HRSG and steam turbine generator
S2, Hydrogen Plant Furnace
S3, Hydrogen Plant Flare
[Cumulative Increase, 2-1-403]
2. The owner/operator shall ensure that the annual emissions of the above sources do not exceed the following annual emission limits, including periods of startup, shutdown, malfunction, and upset emissions.
 - a. NOx 30.9 tpy [Cumulative Increase, 2-1-403]
 - b. SO2 5.0 tpy [Cumulative Increase, 2-1-403]
 - c. PM10 13.8 tpy [Cumulative Increase, 2-1-403]
 - d. POC 13.9 tpy [Cumulative Increase, 2-1-403]
 - e. CO 46.2 tpy [Cumulative Increase, 2-1-403]
 - f. Sulfuric acid mist 0.43 tpy [PSD]
 - *g. Ammonia 26.9 tpy [Regulation 2, Rule 5]
3. The owner/operator shall ensure that the daily emissions of the above sources do not exceed the following daily emission limit, including periods of startup, shutdown, malfunction, and upset emissions.
 - a. Sulfuric acid mist 2.35 lb/day [PSD]
4. The owner/operator shall determine whether the emissions are below the allowable mass emissions for the above sources as shown below. The owner/operator calculate and report the emissions of NOX, SO2, PM10, POC, CO, ammonia, and sulfuric acid mist on an annual basis in the following manner.
 - a. The owner/operator shall the use the POC emission rate determined by the annual source test data at the deaerator for S1.
 - b. The owner/operator shall use the data generated by the BAAQMD Regulation 8, Rule 18, monitoring to determine the annual POC emission rate for the components.
 - c. The owner/operator shall use the mass emissions data generated by the NOx and CO CEMs at S2.
 - d. The owner/operator shall use the monitoring for total sulfur in the feed to the hydrogen plant or CEM monitoring of SO2 at the outlet of the hydrogen plant furnace.

- e. The owner/operator shall use the monitoring for total sulfur in the feed to the hydrogen plant furnace or CEM monitoring of SO₂ at the outlet of the hydrogen plant furnace.
- f. The owner/operator shall use the emission rates of sulfuric acid mist, PM₁₀, POC, and CO determined in annual source tests at S2 and the records of heat input to calculate emissions of sulfuric acid mist, PM₁₀, POC, and CO.
- g. The owner/operator shall use the ammonia injection monitoring and the records of heat input to calculate emissions of ammonia.
- h. The owner/operator shall use the calculations of flare emissions required by BAAQMD Condition 23180, part 5.

[2-1-305]

(Parts 4d and 4e have been amended to allow the use of SO₂ CEM monitoring that is allowed by Condition 23179, part 14b. This note will not appear in the final permit conditions.)

5. If the annual emissions, as determined in part B.4, are above the allowable emissions for the project, the owner/operator shall supply additional offsets, where applicable, and perform additional analysis for PSD, if necessary. The results of the analysis shall be submitted to the Director of Compliance and Enforcement on an annual basis on the anniversary of the startup of S2, Hydrogen Plant Furnace. [2-1-403]
6. The annual emissions of the following sources shall not exceed 16.3 tons PM₁₀/yr: S45, S434, and S1004 at Facility A0016, and S2 and S3 at Facility B7419. If the emissions exceed 16.3 tons in any consecutive 12 month period, the owners/operators of Facilities A0016 and B7419 shall provide contemporaneous offsets of PM₁₀ that comply with BAAQMD Regulations 2-2-201 and 2-2-605. [1-104, 2-2-304]
7. The owner/operator shall comply with the requirements of BAAQMD Regulation 8, Rule 18. (This part will be deleted after the Title V permit is issued.) [BAAQMD Regulation 8, Rule 18]

CONDITION 23414

S4, Cooling Tower

1. The owner/operator shall ensure that the cooling tower is designed to have a drift of no more than 0.005% of total cooling water flow. [Cumulative Increase]
2. The owner/operator shall ensure that the dissolved solids content in the cooling water at S4, Cooling Tower, does not exceed 3000 ppm total dissolved solids. [Cumulative Increase]
3. The owner/operator shall take a sample and perform a visual inspection of the cooling tower water at the cooling tower on a daily basis to check for signs of hydrocarbon in the cooling water. (Regulation 2-6-503)

4. The owner/operator shall take a sample of the cooling tower water 3 times per week at the cooling tower and analyze for chlorine content as an indicator of hydrocarbon leakage into the cooling water. On a monthly basis, the owner/operator shall sample the water in the inlet line and in the return line of the cooling tower and determine the VOC content in each line using EPA laboratory method 8015. (Regulation 2-6-503)
5. The owner/operator shall maintain monthly records of sodium hypochlorite usage at each cooling tower above. (Regulation 2-6-501)
6. The owner/operator shall sample the cooling tower water at least once per month and subject the sample to a District approved laboratory analysis to determine its total dissolved solids content. (Regulations 2-6-503)
7. If the monitoring in part 3 or part 4 indicates that there is a hydrocarbon leak into the cooling water, the owner/operator shall submit a report to the Enforcement and the Engineering divisions at the District. The owner/operator shall submit reports on a weekly basis until the monitoring indicates that no hydrocarbon leaks into the cooling water. (Regulation 1-441)
8. If the monitoring in part 3 or part 4 indicates a hydrocarbon leak, the owner/operator shall estimate the daily amount of VOC emitted using the following procedure. The owner/operator shall sample the water in the inlet line and in the return line and determine the VOC content in each line using EPA laboratory method 8015. This analysis shall be performed each week until VOC levels return to normal. The owner/operator shall report the VOC estimates to the Enforcement and the Engineering divisions at the District on a monthly basis. The owner/operator shall use the VOC estimates to confirm that no more than 5 tons VOC per year was emitted at the source. If more than 5 tons VOC per year is emitted at the source, the facility shall submit an application for a District permit within 90 days of determining that the source is subject to District permits. If the source requires a permit, the source shall be subject to BACT and offsets. (Regulations 1-441, 2-1-424, 2-6-416.2, 2-6-501, 2-6-503)

FINAL: October 5, 2007

Evaluation Report, Application No. 13678, Air Liquide Large Industries US L.P., Facility B7419

9. The owner/operator shall maintain the following records for five years from the date of record:
 - a. Records of daily visual inspection
 - b. Records of chlorine content 3 times per week
 - c. Records of monthly usage of sodium hypochlorite
 - d. Records of monthly determination of total dissolved solids
 - e. Records of any indications of hydrocarbon leaks
 - f. Records of any analyses of VOC content in cooling tower inlet and outlet
(Regulation 2-6-501)

By: _____ October 5, 2007
Brenda Cabral Date
Supervising Air Quality Engineer

FINAL: October 5, 2007

Evaluation Report, Application No. 13678, Air Liquide Large Industries US L.P., Facility B7419

Appendix A

FINAL: October 5, 2007

Evaluation Report, Application No. 13678, Air Liquide Large Industries US L.P., Facility B7419

S1, Hydrogen Plant Emissions

The detailed calculations are available in electronic format upon request.

S2, Hydrogen Plant Furnace Emissions

The following emission calculations have been submitted by the applicant.

Hydrogen Plant Furnace Criteria Pollutant Emission Factors
Air Liquide Hydrogen Plant Operational Emissions

| Pollutant | Emission Factor | EF (lb/MMBtu) | Reference |
|-----------------|------------------------------|---------------|---|
| NOx | 5 ppmvd @ 3% O ₂ | 0.00658 | SCAQMD BACT |
| SO ₂ | 35 ppmv total S in RFG/NG | 0.0012 | BAAQMD BACT (PSA/fuel gas Mix) |
| PM10 | 3.8 lb/MMcf (natural gas) | 0.0037 | AP42 Section 1.4, Natural Gas Combustion (apply 1/2 value since 50% H2 in fuel) |
| POC | 2.75 lb/MMcf (natural gas) | 0.0027 | AP42 Section 1.4, Natural Gas Combustion (apply 1/2 value since 50% H2 in fuel) |
| CO | 10 ppmvd @ 3% O ₂ | 0.0080 | SCAQMD BACT |

Assumptions for emissions factor table above:

(1) NOx, CO, and NH3 "ppm" emission factors converted to "lb/MMBtu" as follows:

$$(x \text{ [lb/MMBtu]}) = (y \text{ ppm @ 3\% O}_2) * (21\% - 0\%) / (21\% - 3\%) * (\text{EPA Fd Factor [ft}^3\text{/MMBtu]}) / (\text{Molar Volume [ft}^3\text{/lbmol]}) * (\text{Molecular weight [lb/lbmol]})$$

PM10 and POC "lb/MMcf" emission factors converted to "lb/MMBtu" as follows:

$$(x \text{ [lb/MMBtu]}) = (\text{Emission factor [lb/MMcf]}) / (\text{Natural gas heat content [Btu/scf]})$$

FINAL: October 5, 2007

Evaluation Report, Application No. 13678, Air Liquide Large Industries US L.P., Facility B7419

Fd Factor: 9290 ft³/MMBtu (Air Liquide)
 Molar volume: 379 ft³/lbmol (at STP: 25 C, 1 atm)
 NOx MW: 46 lb/lbmol
 CO MW: 28 lb/lbmol
 NH3 MW: 17 lb/lbmol
 SO2 MW: 64 lb/lbmol
 PSA gas: 235 Btu/scf (ConocoPhillips)
 Refinery Fuel Gas: 1340 Btu/scf (ConocoPhillips 3 year average)
 Natural Gas: 1020 Btu/scf (AP42 basis)

New Hydrogen Plant Furnace Criteria Pollutant Emissions

| Criteria Pollutant | Emissions | | |
|--------------------|----------------------|-----------------------|--------|
| | lb/hr ⁽¹⁾ | lb/day ⁽¹⁾ | ton/yr |
| NOx | 7.1 | 169 | 28.1 |
| SO ₂ | 1.2 | 30 | 5.0 |
| PM10 | 4.0 | 95 | 15.8 |
| POC | 2.9 | 69 | 11.5 |
| CO | 8.6 | 206 | 34.2 |

Notes:

(1) Assumed heater rating:

| | | |
|--------------------------|-------|-----------|
| Maximum daily: | 1,072 | MMBtu/hr |
| annual: | 975 | MMBtu/hr |
| Hydrogen plant capacity: | 120 | MMscf/day |

The emission estimates above are based on an annual average heat input of 975 MMBtu/hr for 8760 hours per day. The facility has decided to limit the PM10 emissions at the furnace to 13.8 tons per year, which will either be accomplished by demonstrating that emissions are lower than 0.0037 lb/MMBtu or by curtailing operations. The resulting emissions are:

Revised New Hydrogen Plant Furnace Criteria Pollutant Emissions

| Criteria Pollutant | Emissions | | |
|--------------------|----------------------|-----------------------|-------------------|
| | lb/hr ⁽¹⁾ | lb/day ⁽¹⁾ | ton/yr |
| NOx | 7.1 | 169 | 28.1 |
| SO ₂ | 1.2 | 30 | 5.0 |
| PM10 | 4.0 | 95 | 13.8 ² |
| POC | 2.9 | 69 | 11.5 |
| CO | 8.6 | 206 | 34.2 |

Notes:

(1) Assumed heater rating:

| | | |
|----------------|-------|----------|
| Maximum daily: | 1,072 | MMBtu/hr |
| annual: | 975 | MMBtu/hr |

| | | |
|--------------------------|-----|-----------|
| Hydrogen plant capacity: | 120 | MMscf/day |
|--------------------------|-----|-----------|

(2) Based on permit limit

S3, Hydrogen Plant Flare Emissions

The following emission calculations have been submitted by the applicant.

Estimated Flare Emissions Air Liquide Hydrogen Plant Operational Emissions

I. NOx and CO Factors

lb NOx/MMBtu (TCEQ factor for non-steam assist, low-Btu flare,
0.0641 LHV)
0.5496 lb CO/MMBtu (TCEQ factor for non-steam assist, low-Btu flare, LHV)
98% DRE for CO

II. Summary

| Source | Pollutant | lb/hr | tpy |
|-----------------------|-----------|--------|-------|
| Pilot/Sweep Emissions | NOx | 0.03 | 0.12 |
| | CO | 0.24 | 1.07 |
| | SO2 | 0.0004 | 0.004 |

III. Calculations

A. Pilot Emissions

4 Pilots
91.9 scfh/pilot, Natural Gas
367.6 scfh total for pilots

FINAL: October 5, 2007

Evaluation Report, Application No. 13678, Air Liquide Large Industries US L.P., Facility B7419

116.7 scfh sweep gas, Natural Gas
 484.3 scfh total for pilots and sweep gas
 919 Btu/scf, Natural Gas LHV
 10 Ppmv Sulfur in NG

| | | | | | | | | | |
|------------|--------|-------|--------|--------|---------|---------|---------|---|-------------------|
| <u>NOx</u> | | | | | | | | | |
| 484.3 | scf NG | 919 | Btu | 0.0641 | lb NOx | 1 | MMBtu | = | 0.028529 lb NOx |
| | hr | | scf NG | | MMBtu | 1000000 | Btu | | hr |
| 0.03 | lb NOx | 8760 | hr | 1 | ton | | | = | 0.124957 tons NOx |
| | hr | | yr | 2000 | lb | | | | yr |
| <u>CO</u> | | | | | | | | | |
| 484.3 | scf NG | 919 | Btu | 0.5496 | lb CO | 1 | MMBtu | = | 0.244611 lb CO |
| | hr | | scf NG | | MMBtu | 1000000 | Btu | | hr |
| 0.24 | lb CO | 8760 | hr | 1 | ton | | | = | 1.071398 tons CO |
| | hr | | yr | 2000 | lb | | | | yr |
| <u>SO2</u> | | | | | | | | | |
| 10 | ft3 S | 484.3 | scf NG | 1 | lbmol S | 32 | lb S | = | 0.000402 lb S |
| 1000000 | ft3 NG | | hr | 385.3 | ft3 S | | lbmol S | | hr |
| 0.0004 | lb S | 64 | lb SO2 | | | | | = | 0.001 lb SO2 |
| | hr | 32 | lb S | | | | | | hr |
| 0.00 | lb SO2 | 8760 | hr | 1 | ton | | | = | 0.004 tons SO2 |
| | hr | | yr | 2000 | lb | | | | yr |

B. Customer Constraint

FINAL: October 5, 2007

Evaluation Report, Application No. 13678, Air Liquide Large Industries US L.P., Facility B7419

2.79 mmscfh of hydrogen
 6 events per year
 3.75 Hours per event
 274 Btu/scf, HHV Hydrogen

| | | | | | | | | | | |
|------------|----------|------|-------|--------|--------|------|-------|---------------|------|-----------------|
| <u>NOx</u> | | | | | | | | | | |
| 2.79 | mmscf H2 | 274 | MMBtu | 0.0641 | lb CO | = | 49.00 | <u>lb NOx</u> | | hr |
| | hr | | mmscf | | MMBtu | | | hr | | |
| | | | | | | | | | | |
| 49.00 | lb NOx | 3.75 | hours | 6 | events | 1 | ton | = | 0.55 | <u>tons NOx</u> |
| | hr | | event | | yr | 2000 | lbs | | | yr |

C. Loss of PSA

7.74 mmscfh syngas
 0.0516 scf Methane/scf Syngas
 909 Btu/scf, methane
 261.1 Btu/scf, syngas
 835.31 Lbmol/hr CO
 28 lb CO/lbmol
 98% DRE for CO
 1 Event/yr
 5.3 hrs/event

| | | | | | | | | | | |
|----------------|--------------|--------|-------------|-----|-------|--------|-------|---|--------|--------------|
| <u>CO</u> | | | | | | | | | | |
| <i>thermal</i> | | | | | | | | | | |
| 7.74 | mmscf Syngas | 0.0516 | scf Methane | 909 | MMBtu | 0.5496 | lb CO | = | 199.53 | <u>lb CO</u> |
| | hr | | scf Syngas | | MMscf | | MMBtu | | | hr |

| | | | | | | | | | | |
|------------------|----------|----|-------|------|-----|---|--------|--------------|--|--|
| <i>destroyed</i> | | | | | | | | | | |
| 835.31 | lbmol CO | 28 | lb CO | 0.98 | DRE | = | 467.77 | <u>lb CO</u> | | |

FINAL: October 5, 2007

Evaluation Report, Application No. 13678, Air Liquide Large Industries US L.P., Facility B7419

| | | | | | | | |
|--------|-------|--|----------|--|---------|----------|--------------|
| | hr | | lbmol CO | | | hr | |
| 667.30 | lb CO | | 1 event | | 5.3 hrs | 1 ton | 1.77 tons CO |
| | hr | | yr | | event | 2000 lbs | yr |

NOx

| | | | | | | | |
|------|--------------|--|-------------|--|---------------|--|---------------|
| 7.74 | mmscf Syngas | | 261.1 MMBtu | | 0.0641 lb NOx | | 129.54 lb NOx |
| | hr | | MMScf SG | | MMBtu | | hr |

| | | | | | | | |
|--------|--------|--|---------|--|---------|----------|---------------|
| 129.54 | lb NOx | | 1 event | | 5.3 hrs | 1 ton | 0.34 tons NOx |
| | hr | | yr | | event | 2000 lbs | yr |

D. PSA Maintenance

Since the PSA has 12 beds, emissions are estimated by taking 2/12ths of the emissions from losing the entire PSA.

6 events/yr
1 hr/event

| | |
|-----|-------------|
| NOx | 21.59 lb/hr |
| | 0.06 Tpy |

| | |
|----|--------------|
| CO | 111.22 lb/hr |
| | 0.33 Tpy |

E. Plant Maintenance

Maximum flaring will occur when the plant is operating at 50% capacity. Therefore, emissions are estimated by taking 1/2 of the Loss of PSA case.

2 events/yr
9 hrs/event

FINAL: October 5, 2007

Evaluation Report, Application No. 13678, Air Liquide Large Industries US L.P., Facility B7419

| | | |
|-----|--------|-------|
| NOx | 64.77 | lb/hr |
| | 0.57 | tpy |
| CO | 333.65 | lb/hr |
| | 2.94 | tpy |

F. Contractual Outage

Maximum flaring will occur when the plant is operating at 50% capacity. Therefore, emissions are estimated by taking 1/2 of the Loss of PSA case.

4 events/yr
9 hrs/event

| | | |
|-----|--------|-------|
| NOx | 64.77 | lb/hr |
| | 1.15 | tpy |
| CO | 333.65 | lb/hr |
| | 5.94 | tpy |

Total Estimated Flare Process Emissions

| | | |
|-----|-------|-----|
| NOx | 2.68 | tpy |
| CO | 10.98 | tpy |

S4, Cooling Tower

Table 3-7

Estimated Hydrogen Plant Cooling Tower Emissions

| Operations parameter | Value |
|---|--------------|
| Tower Capacity, MM gal/day | 5.3 |
| Maximum water hardness, ppm TDS | 1300 |
| Drift Loss, % of flow capacity ¹ | 0.0044% |
| Weight of water, lb/gal | 8.34 |
| Maximum PM10 emissions, lb/yr ² | 927.7 |
| Maximum PM10 emissions, ton/yr ² | 0.46 |
| POC Emission Factor ³ | 1.50 |
| Maximum POC emissions, lb/day | 8.0 |
| Maximum POC emissions, lb/yr | 2917 |
| Maximum POC emissions, ton/yr | 1.5 |

¹Vender Estimate

²Calculation method from Section VI (Engineering Evaluation Template) of BAAQMD Permit Handbook Chapters, Cooling Towers

³EPA AP-42 Table 5.1-2. Uncontrolled emission factor is 6 lbs POC/MMgal. Emission factor reduced to 1/4 of referenced value due to POC content of stream.

APPENDIX B

ConocoPhillips Analysis of BACT for NO_x and PM₁₀ for Facility A0016, ConocoPhillips Refinery, and Facility B7419, Air Liquide

Following is ConocoPhillips' review of Best Available Control Technology for S45, Heater, S1004, Sulfur Recovery Unit, and Facility B7149, S2, Heater from Prevention of Significant Deterioration Application submitted on June 2, 2006

4.0 BEST AVAILABLE CONTROL TECHNOLOGY

This section addresses BACT requirements for the proposed ConocoPhillips CFEP, as well as the related new Hydrogen Plant on the Refinery site to be owned and operated by Air Liquide Large Industries U.S. LP.

BAAQMD Rule 2-2-301 requires BACT to be applied to:

"...any new or modified source which results in an emission from a new source, or an increase in emissions from a modified source, and which has the potential to emit 10.0 pounds or more per highest day of precursor organic compounds (POC), non-precursor organic compounds (NPOC), nitrogen oxides (NO_x), sulfur dioxide (SO₂), PM₁₀, or carbon monoxide (CO)."

Proposed controlled emission levels to meet BAAQMD BACT requirements, from recent BAAQMD BACT determinations and the BAAQMD BACT Guidelines (BAAQMD 2005) can be found in the *Clean Fuels Project Application for Authority to Construct and Significant Revision to Major Facility* (ConocoPhillips 2006) and the *Hydrogen Plant Project Application for Authority to Construct and Major Facility Review Permit* (Air Liquide 2005).

Included in BAAQMD Regulation 2, Rule 2, are provisions that implement federal PSD requirements. USEPA policy includes a "top-down" BACT analysis for all pollutants emitted in PSD-significant quantities from new and modified emissions. As described in Section 3.0, PSD requirements apply to NO_x and PM₁₀ in this proposed action. To supplement the BACT analysis presented in the above-referenced BAAQMD Authority to Construct (ATC) Applications, the remainder of this section presents "top-down" BACT analyses for the proposed new and modified sources of NO_x and PM₁₀, based on the USEPA RACT/BACT/LAER Clearinghouse (RBLC), California Air Resources Board (CARB) BACT Clearinghouse, and available information on other recently issued permits. USEPA guidance for a "top-down" BACT analysis requires reviewing all possible control options starting at the top level of control efficiency. In the course of the BACT analysis, one or more options may be eliminated from consideration because they are demonstrated to be technically infeasible or have unacceptable energy, economic, or environmental impacts on a case-by-case (site-specific) basis. The steps required for a "top-down" BACT review are:

1. Identify All Available Control Technologies
2. Eliminate Technically Infeasible Options

3. Rank Remaining Technologies
4. Evaluate Remaining Technologies (in terms of economic, energy, and environmental impacts)
5. Select BACT (the most efficient technology that cannot be rejected for economic, energy, or environmental impact reasons is BACT)

4.1 U246 HEAVY GAS OIL (HGO) FEED HEATER

The proposed new U246 HGO Feed Heater supporting the modified Unit 240/246 Unicracker is proposed to be fired on refinery fuel gas (RFG), with natural gas as a backup fuel. The new HGO Feed Heater would be a natural draft process heater rated at 85 million British thermal units per hour (MMBtu/hr).

4.1.1 NO_x BACT – U246 HGO Feed Heater

1. Identify All Available Control Technologies

Table 3 lists the technologies identified for controlling NO_x emissions from process heaters fired on RFG or natural gas.

Table 3 **NO_x Control Technologies**

| Control Technology |
|---|
| No Controls (Base Case) |
| Water/Steam Injection |
| Selective Non-Catalytic Reduction (SNCR) |
| Combustion Controls (Low-NO _x Burners) |
| Selective Catalytic Reduction (SCR) |
| Low-NO _x Burners and SNCR |
| Low-NO _x Burners and SCR |
| SCONOX |



2. Eliminate Technically Infeasible Options

All the control methods identified in Table 3 are considered technically feasible for a process heater fired on RFG, except SCONOx™, SNCR, and water/steam injection.

SCONOx. SCONOx™ uses a potassium carbonate (K₂CO₃) coated catalyst to reduce NO_x emissions. The catalyst oxidizes carbon monoxide (CO) to carbon dioxide (CO₂), and nitric oxide (NO) to NO₂. The CO₂ is exhausted while the NO₂ absorbs onto the catalyst to form potassium nitrite (KNO₂) and potassium nitrate (KNO₃). Dilute hydrogen gas is passed periodically across the surface of the catalyst to convert the KNO₂ and KNO₃ to K₂CO₃, water (H₂O), and elemental nitrogen (N₂), thereby regenerating the K₂CO₃ coating for further absorption. The H₂O and N₂ are exhausted.

SCONOx has not been demonstrated on RFG-fired process heaters (Arizona Department of Environmental Quality [ADEQ] 2005). It has only been demonstrated on combustion sources burning exclusively natural gas. The performance of SCONOx is sensitive to sulfur in the exhaust stream. In addition, the heat ratings on natural gas burners demonstrated with SCONOx are lower than the proposed HGO Feed Heater. Thus, there are significant technical differences between the proposed source and those few sources where SCONOx has been demonstrated in practice. These preclude a finding that SCONOx has been demonstrated to function efficiently on sources identical or similar to the proposed process heater.

Selective Non-Catalytic Reduction (SNCR). SNCR is a post-combustion NO_x control technology based on the reaction of urea or ammonia (NH₃) and NO_x. SNCR involves injecting urea/NH₃ into the combustion gas path to reduce the NO_x to nitrogen and water. This is described by the following chemical equations:



Temperatures ranging from 1,200°F to 2,000°F are required for optimum SNCR performance. Operation at temperatures below this range results in NH₃ slip, while operation above this temperature range results in oxidation of NH₃, forming additional NO_x. Exhaust temperatures of process heaters are typically below the optimum temperature range. In addition, the urea/ammonia must have sufficient residence time, approximately 3 to 5 seconds, at the optimum operating temperatures for efficient NO_x reduction.

SNCR can only be used in induced draft process heaters because of the need to recirculate the flue gas. The HGO Feed Heater will be a natural draft process heater. In addition, existing information on SCNR systems indicate they achieve NO_x reductions ranging from 30 to 75 percent (USEPA 2001), thus SNCR is an

inferior control technology to either SCR or modern combustion controls for an RFG-fired process heater. Therefore, SNCR is considered infeasible for this review.

Water/Steam Injection. The injection of steam or water into the combustion zone can decrease peak flame temperatures, thus reducing thermal NO_x formation. Steam injection is predominantly used with gas turbines. There is little data available to document the effectiveness of water/steam injection for process heaters and no application of this type could be found. Steam injection has been specified as a control method for boilers on a very limited basis. Only one was listed in the USEPA RBLC database during the ADEQ's recent review of the Arizona Clean Fuels Yuma, LLC project (ADEQ 2005). This review showed a controlled emission rate higher than low NO_x burners produced today. Additionally, there are operating issues concerning flame stability using low NO_x burners with steam injection. Therefore, water/steam injection is considered infeasible for this review.

3. Rank Remaining Technologies

Technically feasible NO_x control technologies are listed in Table 4 with typical emission levels, ranked from most efficient to least efficient.

Combustion Controls. Combustion controls reduce NO_x emissions by controlling the combustion temperature or the availability of oxygen (O₂). These are referred to as "low NO_x burners" or "ultra-low NO_x burners." There are several designs of low/ultra-low NO_x burners currently available. These burners combine two NO_x reduction steps into one burner, typically staged air with internal flue gas recirculation (IFGR) or staged fuel with IFGR, without any external equipment.

In staged air burners with IFGR, fuel is mixed with part of the combustion air to create a fuel-rich zone. High-pressure atomization of the fuel creates the recirculation. Secondary air is routed by means of pipes or ports in the burner block to optimize the flame and complete combustion. This design is predominantly used with liquid fuels.

Table 4 *NO_x Control Hierarchy for Process Heaters Fired on Refinery Fuel Gas*

| Technology | Typical Emission Level | |
|--|------------------------|-----------------------|
| | ppmv ¹ | lb/MMBtu ² |
| Combustion Controls and SCR ³ | 7 | 0.0085 |
| Selective Catalytic Reduction (SCR) | 18 | 0.022 |

| | | |
|--------------------------|----|-------|
| Combustion Controls | 29 | 0.035 |
| No Controls ⁴ | 89 | 0.11 |

Source: *Petroleum Refinery Tier 2 BACT Analysis Report, Final Report* (EPA, 2001).

¹ Parts per million by volume (ppmv), dry basis, corrected to 3% oxygen.

² Pounds (lbs) of NO_x produced per MMBtu of fuel heat input.

³ Recent data show a range of values, with 7 ppmv representing the low end of current permitted levels on RFG-fired refinery heaters. See discussion of current BACT determinations in text for more details.



⁴ Emission level shown is for a natural draft heater; an induced draft heater would typically have higher uncontrolled NO_x levels, on the order of 179 ppmv at 3% O₂, dry (USEPA 2001).

In staged fuel burners with IFGR, fuel pressure induces the IFGR, which creates a fuel lean zone and a reduction in oxygen partial pressure. This design is predominantly used for gas fuel applications.

The range of performance achieved in practice for the best combustion controls is 25 to 29 ppmv at 3% O₂, dry (0.03 to 0.035 lb/MMBtu), with the upper end of range representing heaters firing gas with high hydrogen content (USEPA 2001). Burners that could achieve 10 ppmv or lower are under development, but are not currently available for process heaters.

RFG is high in hydrogen content, so for heaters burning RFG or a mixture of RFG and natural gas, the upper end of the demonstrated range (29 ppmv at 3% O₂, dry, or 0.035 lb/MMBtu) would be appropriate as the achievable performance level for combustion controls on RFG-fired process heaters.

Selective Catalytic Reduction (SCR). SCR is a process that involves post-combustion removal of NO_x from flue gas with a catalytic reactor. In the SCR process, ammonia injected into the exhaust gas reacts with nitrogen oxides and oxygen to form nitrogen and water. SCR converts nitrogen oxides to nitrogen and water by the following reactions:



The reactions take place on the surface of a catalyst. The function of the catalyst is to effectively lower the activation energy of the NO_x decomposition reaction. Technical factors related to this technology include the catalyst reactor design, optimum operating temperature, sulfur content of the fuel, catalyst deactivation due to aging, ammonia slip emissions, and design of the NH₃ injection system. The most common catalysts are composed of vanadium, titanium, molybdenum, and zeolite. Sulfur dioxide and sulfur trioxide are generated in the flue gas when sulfur-containing compounds in fuel are combusted. Catalyst systems promote

partial oxidation of sulfur dioxide (from sulfur and mercaptans in the fuel) to sulfur trioxide, which combines with water to form sulfuric acid, causing corrosion over time. In addition, sulfur trioxide and sulfuric acid reacts with excess ammonia to form ammonium salts. These ammonium salts may condense as the flue gases are cooled, which over time can accumulate on the catalyst causing “plugging” and catalyst deterioration, often referred to as “fouling.” These effects can be minimized by proper operation, including:

Controlling the amount of sulfur in the fuel.

Using a properly designed ammonia injection system to maximize the efficient mixing of ammonia and flue gas without colder surfaces present on which ammonium salts can condense.

Operating with the lowest amount of ammonia needed to achieve the desired performance. To achieve high NO_x reduction rates, SCR vendors suggest a higher ammonia injection rate than stoichiometrically required, which necessarily results in ammonia slip. Thus, an emissions tradeoff between NO_x and ammonia occurs in high NO_x reduction applications.

Operating at temperatures above the dew point of ammonium salts and sulfuric acid.

Optimal operating temperatures vary by catalyst but generally range from 500 to 800°F. Operating above the maximum temperature results in oxidation of NH₃ to either nitrogen oxides (thereby adding NO_x emissions) or ammonium nitrate. Operating below the optimal temperature increases ammonia slip and catalyst fouling. Refinery process heaters typically operate in the range of 450 to 700°F, thus would be expected to operate above the dew point of ammonium salts and sulfuric acid to minimize fouling and corrosion. SCR systems have been used on process heaters burning mixtures of RFG and natural gas.

SCR systems achieve 80 to 90 percent reductions in NO_x emissions (USEPA 2001). The 90 percent reduction is relative to an uncontrolled induced draft heater since the higher NO_x emissions (approximately 179 ppmv at 3% O₂, dry, or 0.22 lb/MMBtu) versus a natural draft heater (approximately 89 ppmv at 3% O₂, dry, 0.11 lb/MMBtu) provides a greater driving force for increased mass transfer and also enhances the SCR's mechanical draft requirements. This yields an outlet NO_x emission level of approximately 18 ppmv at 3% O₂, dry, or 0.011 lb/MMBtu. For a natural draft heater, maximum SCR control efficiency is on the order of 80 percent due to lower uncontrolled emission rates, yielding approximately the same controlled NO_x emission rate. Thus, a typical achievable performance level for SCR systems on RFG-fired process heaters is 18 ppmv at 3% O₂, dry, or 0.011 lb/MMBtu.

SCR and Combustion Controls. This control option uses SCR downstream of combustion controls to reduce NO_x emissions. With this combination, the inlet NO_x level to the SCR is lower, so lower outlet NO_x can be achieved. However, the SCR may not achieve the same percent reduction performance compared to

no upstream combustion controls because of the lower NO_x inlet levels. As is discussed further below, a review of the USEPA RBLC and CARB BACT Clearinghouse showed permit limits of 7 ppmv NO_x at 3% O₂, dry, as the lowest level achieved in practice on refinery process heaters with SCR and combustion controls fired on a combination of RFG and natural gas. Therefore, the achievable performance level for SCR and combustion controls on RFG-fired process heaters is 7 ppmv at 3% O₂, dry, or about 0.0085 lb/MMBtu.

4. Evaluate Remaining Technologies

Technically feasible technologies are reviewed on a case-by-case basis taking into consideration energy, environmental, and economic impacts beginning with the top option. If the top option is not selected as BACT, the next most effective control is evaluated until it cannot be ruled out for energy, environmental, or economic reasons.

In this case, the top technically feasible control option, SCR with combustion controls, is the proposed control technology. Therefore, the selection of BACT consists of establishing the lowest controlled NO_x emission level achievable with this control technology, taking into consideration the lowest controlled NO_x emissions currently achieved in practice, and if necessary, energy, environmental and economic impacts between different potential controlled emission levels using this technology.

A review of the USEPA RLBC and CARB BACT Clearinghouse was conducted. These reviews resulted in the lowest NO_x emission limits for refinery heaters fired on RFG/natural gas found in the South Coast Air Quality Management District (SCAQMD). A review of the BACT Determinations published by the SCAQMD provided further details.

There were three SCAQMD BACT Determinations for 7 ppmv NO_x at 3% O₂, dry, documented in the USEPA *Petroleum Refinery Tier 2 BACT Analysis Report* (USEPA 2001) for process heaters burning natural gas or a combination of RFG and natural gas. These were for: (1) Chevron El Segundo Refinery (Permit No. D64697, D62860, D64621); (2) TOSCO Refinery, Wilmington (Application 326118);¹ and (3) CENCO Refinery, Santa Fe Springs (Application 352869).

The ADEQ (2005) recently issued a permit for a similar project, Arizona Clean Fuels Yuma, LLC (ADEQ Permit Number 1001205). In their top-down BACT finding issued on 3 February 2005, the ADEQ summarized the following findings for the highest efficiencies achievable with SCR and combustion controls on RFG-fired process heaters (all 3-hour averages):

High-Efficiency SCR:

NO_x: 0.0085 lb/MMBtu (7 ppmv at 3% O₂, dry)²

¹ Noted in the SCAQMD BACT Determinations to be for a 460-MMBtu/hr Hydrogen Reforming Furnace also combusting Pressure Swing Absorption (PSA) off gas.

² Although the NO_x permit limit for Arizona Clean Fuels Yuma LLC is presented as ppm corrected to 3% O₂, dry, the ADEQ Technical Report presents results in ppm corrected to

Moderate-Efficiency SCR:

NO_x: 0.0125 lb/MMBtu (10 ppmv at 3%O₂, dry)

The ADEQ concluded for Arizona Clean Fuels Yuma LLC that the beneficial environmental impacts of increased NO_x control for the high-efficiency SCR was outweighed by adverse environmental impacts of increased ammonia slip. Therefore, the NO_x emissions level found to be BACT was 10 ppmv at 3% O₂, dry.

The proposed NO_x emission limit for the ConocoPhillips HGO Feed Heater is 7 ppmv at 3% O₂, dry. This is equivalent to the high-efficiency SCR option that was ruled out by ADEQ, and matches the lowest NO_x emission limit achieved in practice. No further energy, environmental, or economic impact assessment is needed.

5. Select BACT/ Document the Selection is BACT

Based on this review, NO_x BACT is proposed as SCR with combustion controls (low NO_x burners) at 7 ppmv at 3% O₂, dry, or 0.0086 lb/MMBtu.³

4.1.2 PM₁₀ BACT – U246 HGO Feed Heater

1. Identify All Available Control Technologies

Table 5 lists the control technologies identified for controlling PM₁₀ emissions from process heaters fired on natural gas or RFG.

Table 5 *PM₁₀ Control Technologies*

| Control Technology |
|--|
| Good Combustion Practice |
| Cyclone |
| Wet Gas Scrubber |
| Electrostatic Precipitator |
| Baghouse/Fabric Filters |
| Good Combustion Practice. By maintaining heaters in good working order and limiting the sulfur in the feed fuels, PM ₁₀ emissions are controlled. |
| Cyclone. A cyclone operates on the principle of centrifugal force. Exhaust gas enters tangentially at the top of the cyclone and spirals towards the bottom. As the gas spins, heavier particles hit the outside wall and are collected at the bottom. Cleaned gas escapes through an inner tube. |

0% O₂, dry. These have been converted to 3% O₂, dry, for the purposes of the ConocoPhillips analysis.

³ Slight difference from the previous conversions from 7 ppmv at 3% O₂, dry, due to fuel heat value assumptions and/or rounding.

Wet Gas Scrubber. A wet gas scrubber uses gas/liquid contacting to remove particles primarily by inertial impaction on liquid droplets, followed by collection of the larger liquid droplets as liquid waste.

Electrostatic Precipitator (ESP). An ESP uses an electric field to charge and collect particles in a gas stream, followed by collection of the particles on oppositely charged plates.

Baghouse/Fabric Filter. A baghouse is a metal housing containing many fabric bags. A partial vacuum pulls the dirty air through the fabric bags, filtering the particles from the exhaust stream.

2. Eliminate Technically Infeasible Options

All options in Table 5 are technically feasible.

3. Rank Remaining Technologies

See next (Step 4) discussion.

4. Evaluate Remaining Technologies

While the listed control technologies are all technically feasible, only good combustion practice is used for controlling PM₁₀ emissions from gas-fired heaters. The other technologies are not used because of inherently low PM₁₀ emissions from gaseous fuel combustion. A cyclone would be ineffective in capturing the extremely small particles generated from gaseous fuel combustion, and costs associated with designing the other add-on systems to capture minute particles in low concentrations would be economically infeasible. This is a well-accepted finding of all past BACT determinations for the control of PM₁₀ from combustion of gaseous fuels.

A review of the USEPA RLBC and CARB BACT Clearinghouse was conducted for currently achieved control levels. Findings were the same as summarized by the ADEQ for the Arizona Clean Fuels Yuma LLC (ADEQ 2005). ADEQ proposed a PM₁₀ emission limit of 0.0075 lb/MMBtu as representative of good combustion practice with gas-fired process heaters, based on the AP-42 emission factor (USEPA 1995a et seq.) for natural gas combustion and typical natural gas heat content. This is consistent with the lowest level achieved in practice.

5. Select BACT/ Document the Selection is BACT

Based on this review, PM₁₀ BACT is proposed as good combustion practice. The USEPA AP-42 natural gas combustion factor was adjusted with the estimated fuel heat content of the proposed RFG/natural gas mixture to calculate a proposed PM₁₀ BACT emission level of 0.0057 lb/MMBtu.

4.2 HYDROGEN PLANT REFORMER Furnace

The proposed new Hydrogen Plant Steam Methane Reformer (SMR) Furnace is proposed to be fired on a mix of approximately 85 percent Pressure Swing Absorption (PSA) off gas and 15 percent RFG/natural gas.

4.2.1 NO_x BACT – Hydrogen Plant Reformer Furnace

1. Identify All Available Control Technologies

The available technologies are the same as listed in Table 3 of Section 4.1.1.

2. Eliminate Technically Infeasible Options

All the control methods identified in Table 3 are considered technically feasible for a Hydrogen Plant Reformer fired on the proposed mix of fuels, except SCONO_x, SNCR, and water/steam injection, for the same reasons provided for a refinery process heater in Section 4.1.1.

3. Rank Remaining Technologies

Technically feasible NO_x control technologies are the same as listed in Table 4 of Section 4.1.1. Since the proposed mix of fuels includes natural and RFG, the emission levels presented in Table 4 can still be considered typical for this application. Inclusion of PSA off gas, however, affects combustion characteristics, and hence, can impact the actual achievable emission levels. Consideration of PSA off gas is included in the following BACT evaluation discussion.

4. Evaluate Remaining Technologies

Technically feasible technologies are reviewed on a case-by-case basis taking into consideration energy, environmental, and economic impacts beginning with the top option. If the top option is not selected as BACT, the next most effective control is evaluated until it cannot be ruled out for energy, environmental, or economic reasons.

In this case, the top technically feasible control option, SCR with combustion controls, is the proposed control technology. Therefore, the selection of BACT consists of establishing the lowest controlled NO_x emission level achievable with this control technology, taking into consideration the lowest controlled NO_x emissions currently achieved in practice, and if necessary, energy, environmental and economic impacts between different potential controlled emission levels using this technology.

A review of the USEPA RLBC and CARB BACT Clearinghouse was conducted. These reviews resulted in the lowest NO_x emission limits for hydrogen reformer furnaces fired on PSA off gas and RFG/natural gas found in the SCAQMD. A review of the SCAQMD BACT Determinations provided further details.

PSA off gas is high in hydrogen content, and therefore has the potential to form less NO_x and PM₁₀. There were five SCAQMD BACT Determinations for hydrogen reformer furnaces. In reverse chronological order, these NO_x emission limits were: (1) Chevron El Segundo Refinery (Application 411357, 5/19/2004, 5 ppmv at 3% O₂, dry); (2) Praxair, Ontario (Application 389926, 7/17/2002, 5 ppmv at 3% O₂, dry); (3) TOSCO Refinery, Wilmington (Application 326118, 9/9/1999, 7 ppmv at 3% O₂, dry); (4) Chevron El Segundo Refinery (Application 341340, 7/14/1999, 5 ppmv at 3% O₂, dry) and (5) Air Products and Chemicals, Inc. (Application 337979, 6/16/1999, 5 ppmv at 3% O₂, dry).

The proposed NO_x emission limit for the Air Liquide Hydrogen Reformer is 5 ppmv at 3% O₂, dry. Since this is the lowest NO_x emission limit achieved in practice, no further energy, environmental, or economic impact assessment is needed.

5. Select BACT/ Document the Selection is BACT

Based on this review, NO_x BACT is proposed as SCR with combustion controls (low NO_x burners) at 5 ppmv at 3% O₂, dry, or 0.0058 lb/MMBtu.

4.2.2 PM₁₀ BACT – Hydrogen Plant Reformer Furnace

1. Identify All Available Control Technologies

The available technologies are the same as listed in Table 5 of Section 4.1.2.

2. Eliminate Technically Infeasible Options

All options in Table 5 are technically feasible.

3. Rank Remaining Technologies

See next (Step 4) discussion.

4. Evaluate Remaining Technologies

While the listed control technologies are all technically feasible, only good combustion practice is used for controlling PM₁₀ emissions from gas-fired heaters, as described in Section 4.1.2.

A review of the USEPA RLBC and CARB BACT Clearinghouse was conducted for currently achieved control levels. No applicable PM₁₀ BACT emission levels were found. The five SCAQMD BACT Determinations for hydrogen reformer furnaces did not include PM₁₀, thus, from Section 4.1.2, a PM₁₀ emission limit of 0.0075 lb/MMBtu is representative of good combustion practice with gas-fired process heaters. In this case, the proposed Hydrogen Reformer will fire up to 85 percent PSA off gas, which produces less PM₁₀ emissions due to high hydrogen content. It is proposed that with the inclusion of PSA off gas, a reasonable PM₁₀ emission limit would be half the amount produced by natural gas alone, or 0.0037 lb/MMBtu.

5. Select BACT/ Document the Selection is BACT

Based on this review, PM₁₀ BACT is proposed as good combustion practice at 0.0037 lb/MMBtu. The proposed PM₁₀ emissions level is consistent with the lowest level achieved in practice, with further consideration given for the PSA off gas in the fuel mixture.

4.3 SULFUR RECOVERY UNIT (SRU)

The proposed new Unit 235 SRU will be a closed Claus process supported by an amine-based TGTU to convert unreacted hydrogen sulfide (H₂S) from the Claus process. The TGTU is also a closed process. Any unreacted H₂S in the tail gas passing through the TGTU will be oxidized in a new tail gas incinerator, which is the emission point for the process. Vents from the new sulfur loading rack will also be routed to the tail gas incinerator for oxidation of H₂S. Therefore, BACT for the SRU was assessed for NO_x and PM₁₀ from the tail gas incinerator.

4.3.1 NO_x BACT – SRU Tail Gas Incinerator

1. Identify All Available Control Technologies

The available technologies are the same as listed in Table 3 of Section 4.1.1.

2. Eliminate Technically Infeasible Options

The only option listed in Table 3 that is technically feasible for an SRU tail gas incinerator is combustion control with low-NO_x burners. The other technologies are either based on lowering flame temperature, which is not compatible with the primary function of the incinerator (i.e., efficient oxidation of reduced sulfur compounds), or add-on controls that have not been demonstrated technically feasible for a thermal oxidizer. There are significant technical differences between thermal oxidizers and the combustion sources for which these technologies have been demonstrated in practice.

3. Rank Remaining Technologies

The only technically feasible NO_x control technology is combustion control with low-NO_x burners.

4. Evaluate Remaining Technologies

Technically feasible technologies are reviewed on a case-by-case basis taking into consideration energy, environmental, and economic impacts beginning with the top option. If the top option is not selected as BACT, the next most effective control is evaluated until it cannot be ruled out for energy, environmental, or economic reasons.

In this case, a review of the USEPA RLBC and CARB BACT Clearinghouse was conducted for the most efficient low-NO_x burners achieved in practice for tail gas thermal oxidizers for SRU TGTUs. These reviews resulted in the lowest NO_x emission limit achieved in practice as 42.2 ppmv @ 7% O₂, dry, or 0.0667 lb/MMBtu, associated with the recently issued PSD permit for the SRU TGTU at the ConocoPhillips Ferndale Refinery. This level, for a unit currently in operation, is similar to the 0.06 lb/MMBtu level proposed by the ADEQ for the Arizona Clean Fuels Yuma LLC (ADEQ 2005), a facility not yet in operation.

5. Select BACT/ Document the Selection is BACT

Based on this review, NO_x BACT is proposed as combustion control with low-NO_x burners at 42.2 ppmv at 7% O₂, dry, or 0.0667 lb/MMBtu.

4.3.2 PM₁₀ BACT – SRU Tail Gas Incinerator

1. Identify All Available Control Technologies

The available technologies are the same as listed in Table 5 of Section 4.1.2.

2. Eliminate Technically Infeasible Options

All options in Table 5 are technically feasible.

3. Rank Remaining Technologies

See next (Step 4) discussion.

4. Evaluate Remaining Technologies

While the listed control technologies are all technically feasible, only good combustion practice is used for controlling PM₁₀ emissions from the combustion of gaseous fuels, as described in Section 4.1.2.

A review of the USEPA RLBC and CARB BACT Clearinghouse was conducted for currently achieved control levels. No applicable PM₁₀ BACT emission levels were found. It is proposed that reasonable PM₁₀ emission limit would be the amount produced by natural gas alone, or 0.0075 lb/MMBtu.

5. Select BACT/ Document the Selection is BACT

Based on this review, PM₁₀ BACT is proposed as good combustion practice at 0.0075 lb/MMBtu. The proposed PM₁₀ emissions level is consistent with the lowest level achieved in practice.

4.4 New Flaring

The proposed project includes a new Hydrogen Plant flare that would operate during planned and unplanned events. The shutdown and startup of the new Unit 240/246 would also cause new flaring emissions from the existing Main Flare, but this is estimated to occur only once every three years.

Flares operate primarily as air pollution control devices, but are nonetheless emission sources subject to BACT analyses. The technically feasible control options for emissions of all pollutants from flares are equipment design specifications and work practices: minimizing exit velocity, ensuring adequate heat value of combusted gases, and minimizing the quantity of gases combusted. Each of these control options is technically feasible and is required for the operation of emergency flares at the refinery.

The equipment design criteria for emergency flares are based largely on the parallel requirements set forth in the NSPS regulations (40 CFR 60.18) and the National Emission Standards for Hazardous Air Pollutants (NESHAP) regulations (40 CFR 63.11). These include a maximum allowable exit velocity, a requirement for smokeless operation, and a minimum allowable net heating value for gases combusted in the flares. ConocoPhillips is not aware of any more stringent requirements imposed on flares at any other petroleum refinery, nor any other technically feasible control options for emissions of any pollutants from flares.

Appendix C

CEQA FINDINGS

**CONOCOPHILLIPS – SAN FRANCISCO REFINERY
PROPOSED CLEAN FUELS EXPANSION PROJECT**

**FINDINGS AND SUPPORTING FACTS REGARDING THE
ENVIRONMENTAL IMPACT REPORT**

ConocoPhillips - San Francisco Refinery (The Refinery) has proposed to construct the Clean Fuels Expansion Project (CFEP) at its Rodeo Refinery. The CFEP includes new equipment and modifications to existing equipment that would enable the Refinery to process heavy gas oil (HGO), which is a by-product that is currently produced onsite and exported. Implementation of the CFEP would allow overall Refinery production to increase by up to 1,000,000 gallons per day (30 percent over current levels).

The CFEP includes the following: (1) construction of a new Hydrogen Plant to be built by Air Liquide with a capacity of 120 million standard cubic feet per day; (2) construction of a new Sulfur Recovery Unit with a capacity increase of 200 long tons per day; (3) conversion of a retired lube oil rail car loading rack into a butane rail car loading rack; (4) expansion of the Unicracker to allow for HGO hydrocracking and resulting in an increase in capacity of 23,000 barrels per day (bbl/day); (5) Reformer (Unit 244) modifications resulting in a capacity increase from 16,087 bbl/day to 18,500 bbl/day; (6) UNISAR (Unit 248) modifications resulting in a capacity increase from 8,812 bbl/day to 16,740 bbl/day; (7) Product Blending Unit (Unit 76) modifications resulting in a capacity increase from 90,411 bbl/day to 113,150 bbl/day; (8) Deisobutanizer (Unit 215 DIB) modifications resulting in a capacity increase from 7,600 bbl/day to 10,200 bbl/day; (9) Sulfur Recovery Plant (Units 234, 236, 238) modifications that would include a new sulfur degassing system, a new sulfur loading rack, a modified or replaced amine regenerator and an increase in sulfur storage capacity; and (10) modifications to ancillary facilities such as pumps, heat exchangers, instrumentation, utilities and piping.

Contra Costa County Community Development Department (CDD) acted as Lead Agency under the California Environmental Quality Act (CEQA) for this project. As a responsible agency under CEQA, the Bay Area Air Quality Management District (BAAQMD) participated in the EIR process, including reviewing and commenting on the Draft EIR. The following timeline illustrates the land use permit application's progress from approval by County Planning Commission (CPC) to present:

- April 24, 2007 – Public hearing held before the CDD in Martinez to consider certification of the Final EIR and approval of the CFEP.
- May 8, 2007 – Second CPC hearing held in Martinez. Final EIR was certified and project was approved with new and modified Conditions of Approval.
- May 17, 2007 – Appeal received from Communities for a Better Environment and Center for Biological Diversity (CBE/CBD), joint appellants.
- May 18, 2007 – Appeal received from ConocoPhillips Company and appeal received from the California State Attorney General.

- September 10, 2007 – California Attorney General withdrew his May 18, 2007 appeal and submits a copy of Settlement Agreement with ConocoPhillips Company. Concurrently, ConocoPhillips requests that the County include language from the Settlement Agreement in the County’s action on its appeal.
- September 25, 2007 – Board of Supervisors hearing held in Martinez. Final EIR was certified and project was approved. Board accepted the September 10, 2007 letter from the California Attorney General withdrawing their May 18, 2007 appeal. The Board denied the appeals of Communities for a Better Environment (CBE) and Center for Biological Diversity (CBD). The Board also granted the appeal of ConocoPhillips Company based on their revised proposed condition of approval addressing the storage of rail cars.

The EIR identified certain potentially significant environmental impacts that could occur as a result of the CFEP. The following discussion summarizes the air quality related effects identified in the EIR and during the District’s review of the ConocoPhillips and Air Liquide permit applications, makes one or more of the findings required under Section 15091 of the State CEQA Guidelines, and presents facts to support the findings. All of these effects have been mitigated to a level of insignificance.

Impact 1 – Construction activities associated with CFEP would generate short-term emissions of criteria pollutants, including suspended and respirable particulate matter and equipment exhaust emissions, which would contribute to existing air quality violations.

Mitigated to insignificance. Particulate emissions will be mitigated by implementation of comprehensive dust control measures including watering all active construction areas at least twice daily; covering of haul trucks or requiring all trucks to maintain at least two feet of freeboard; paving or otherwise stabilizing haul roads, parking and staging areas; and sweeping daily with water sweepers all paved access roads, parking areas and staging areas at construction sites. The following “enhanced” control measures will also be implemented: Hydroseeding or application of non-toxic soil stabilizers to inactive construction areas; enclosing, covering, watering twice daily or application of non-toxic soil binders to exposed stockpiles; installation of sandbags or other erosion control measures to prevent silt runoff to public roadways; suspension of excavation and grading activity when winds exceed 25 mph; installation of wheel washers for all exiting trucks, or washing off the tires or tracks of all trucks and equipment leaving the site.

Equipment emissions will be mitigated by regular equipment maintenance and limits to unnecessary idling. Other equipment mitigation measures include the following: use of alternative fuels and/or alternatively fueled equipment; use of post-1996 model diesel trucks only at the site or for on-road hauling of construction material; requirement for all construction diesel engines with a rating of 100 hp or more to meet at a minimum the Tier 2 California Emission Standards for Off-Road Compression –Ignition Engines unless certified by the onsite Construction Air Quality Mitigation Manager (CAQMM) that such an engine is not available for a particular item of equipment; offering incentives to encourage construction workers to carpool or employ other means of transportation; scheduling construction activities to allow at least 33% of the construction workforce to avoid the morning and afternoon peak traffic periods; and use of on-site power to minimize reliance on portable generators.

Impact 2 – Operational activities associated with the implementation of the CFEP would increase air pollutant emissions, contributing to existing air quality violations.

Mitigated to insignificance. As required by BAAQMD Rules and Regulations, project emissions will be mitigated by application of Best Available Control Technology (BACT) and by obtaining emission offsets. Specifically, following mitigation measures will be implemented:

- The four Dissolved Air Flotation (DAF) vents associated with the onsite wastewater treatment plant will be routed to a Thermal Oxidizer with a destruction efficiency of no less than 98 percent. The DAF outlet channel and downstream sumps will be sealed by a solid cover with gaskets. Any vents installed on the covered channel will be routed to the thermal oxidizer. Installation of these controls will reduce organic emissions by at least 242 pounds per day and 44.1 tons per year.
- The Refinery Steam Power Plant uses three gas turbines to generate electricity, and uses gas turbine waste heat to generate steam. Each gas turbine has a nitrogen oxide (NO_x) catalyst system located at the base of the exhaust stack. The Refinery will take a new permit limit to achieve a reduction of NO_x concentration in each stack by 1 ppm from its current operating baseline. This 1 ppm of NO_x equates to a reduction of 81 pounds per day and 14.7 tons per year.
- Operations at the ConocoPhillips' Carbon Plant will be modified to result in a decrease in SO₂ emissions of at least 230 pounds per day and 42 tons per year. The refinery will take a new permit limit to reflect this reduction.
- The baghouse at the Carbon Plant will use improved bag technology to capture particulate matter (PM₁₀) from the calcined coke operation. Installation of the improved bag-technology will reduce PM₁₀ emissions by at least 43.8 pounds per day and 8.0 tons per year. The refinery will take a new permit limit to reflect this reduction.
- Net reductions in ROG emissions associated with the mitigated CFEP will be used to offset 36 pounds per day and 7.6 tons per year of NO_x associated with the CFEP.

Impact 3 – The CFEP would contribute to cumulative regional air emissions; however, it would not be cumulatively considerable and it would not conflict with or obstruct implementation of the applicable air quality plan.

Mitigated to insignificance. As discussed in Impact 2, with the proposed mitigation measures, the CFEP would have a less-than-significant impact on air quality. Furthermore, as discussed in Section 4.10, Land Use, in Final EIR, the CFEP is consistent with the Contra Costa County General Plan which in turn is consistent with the BAAQMD's current air quality plan (2005 Ozone Strategy).

Impact 4 – Operational activities associated with the implementation of the CFEP could lead to increases in odorous emissions. This would be a less-than-significant impact.

No mitigation required. The CFEP will not result in increased odors because the hydrocracking process that would be used to process heavy gas oil produces clean intermediate feedstocks and blendstocks. Storing these products in existing tanks will not increase odors. Also, CFEP contains numerous design features that will reduce odor emissions from existing equipment and minimize the likelihood of odor emissions from the project's new equipment. CFEP-related design features include the following:

- A fourth compressor will be added to the odor abatement system. This will increase the robustness of the odor control system. The new compressor will be sized at approximately 3.3 MMSCFD and is slated to commence operation in March 2009.
- The new compressor will primarily be loaded with odor abatement gases but will be operated so that during most periods, it can pick up the swings that occur during brief peak loading on the existing G-503, Flare Gas Recovery (FGR) compressor. This new compressor will also be used to mitigate flaring when the G-503 FGR compressor is down for planned or emergency maintenance. This additional flare gas recovery capacity will further reduce odor-causing flaring.
- The vapor recovery will be installed on existing fixed-roof tanks that will change service to store heavy gas oil and sour water.
- The Odor abatement system will be subject to new and more stringent permit conditions by the BAAQMD to eliminate and/or minimize odor complaints.
- A new sulfur recovery unit will increase system redundancy and improve the refinery's ability to react to upset conditions for processing sulfur gases. This will reduce the number of refinery upsets and shutdowns.
- Molten sulfur loaded into trucks will be degassed prior to loading, which will reduce the H₂S emissions.
- The Dissolved Air Flotation unit at the wastewater treatment plant will be vented to a thermal oxidizer.
- After startup of the CFEP, less heavy gas oil will be loaded onto barges, which vent to the atmosphere.

As required by the State CEQA Guidelines, the BAAQMD, as a Responsible Agency for the ConocoPhillips CFEP, hereby finds that, for each of the impacts identified in the final EIR and discussed above, changes or alterations have been required in, or incorporated into, the project which avoid or substantially lessen the significant environmental effect as identified in the final EIR. In addition, for those mitigation measures that are identified in the final EIR to lessen impacts associated with construction activities and vehicle emissions and that are within the responsibility or jurisdiction of another public agency, the BAAQMD hereby finds that such measures either have been or can and should be adopted by such other agency.

In accordance with BAAQMD Rules and Regulations, the BAAQMD has fully considered the EIR prepared and certified by the Contra Costa County and has incorporated the EIR's analysis into its decision-making process. The BAAQMD granted an Authority to Construct for the proposed project on October 5, 2007.

The documents and other materials that constitute the record of proceedings upon which this decision is based are located at the BAAQMD office at 939 Ellis Street, San Francisco, California, and the custodian of the materials is Rochelle Henderson.

Jack P. Broadbent
Executive Officer/Air Pollution Control Officer
Bay Area Air Quality Management District

APPENDIX C

Engineering Evaluation Application 13424

FINAL: October 5, 2007

Evaluation Report, Application 13424, ConocoPhillips Refinery, Facility A0016, Rodeo CA

**FINAL
BAY AREA AIR QUALITY MANAGEMENT DISTRICT
ENGINEERING EVALUATION
CONOCOPHILLIPS SAN FRANCISCO REFINERY; PLANT 16
APPLICATION NO. 13424**

October 5, 2007

Table of Contents

| | |
|---|-----|
| 1. BACKGROUND | 102 |
| 2. EMISSION CALCULATIONS | 105 |
| 3. BACT and ract REVIEW AND DETERMINATION | 114 |
| 4. CUMULATIVE INCREASE AND OFFSETS | 124 |
| 5. STATEMENT OF COMPLIANCE..... | 129 |
| 6. RECOMMENDATIONS..... | 146 |
| 7. PERMIT CONDITIONS..... | 148 |
| APPENDIX A | 198 |
| APPENDIX B | 225 |
| APPENDIX C | 229 |
| APPENDIX D | 230 |
| APPENDIX E | 245 |
| APPENDIX F..... | 246 |
| APPENDIX G..... | 247 |

1. BACKGROUND

ConocoPhillips has submitted an application entitled "Clean Fuel Expansion Project " (CFEP). The purpose of the CFEP is to process heavy gas oil (HGO) that is produced at the coker crude unit, coker, and pre-fractionator, and that is received from the Santa Maria refinery via pipeline into gasoline and diesel. In order to do this, ConocoPhillips will add a high-pressure reactor train to S307, Unicracker. The new train will be integrated into S307, but will have a new source number, S434. ConocoPhillips will also increase the permitted capacity of S307, Unicracker; S309, Unisar; S432, Deisobutanizer; and S308, Reforming Unit. S1004, a new 200 long ton/day sulfur recovery unit (SRU), will be built. The new SRU will be designed without oxygen enrichment. A new 85 MMBtu/hr heater, S45, will be added for S434. The service will change on the following tanks: S98, S123, and S124. Tanks S118, S122, S128, S139, S140, and S182 will have throughput changes. S98 will switch from exempt diesel service to petroleum fluids with a vapor pressure up to 10 psia. The allowable vapor pressures at S123 and S124 will increase to 3.0 psia and 11.0 psia, respectively.

ConocoPhillips needs more hydrogen than it can currently produce to process the heavy gas oil. Air Liquide will build a new hydrogen plant on site and will retain ownership of the plant and operate it. However, ConocoPhillips will use all of the facility's output. BAAQMD Regulation 2-1-213 defines facility as:

"Any property, building, structure or installation (or any aggregation of facilities) located on one or more contiguous or adjacent properties and under common ownership or control of the same person..."

The hydrogen plant will be on ConocoPhillips property, so it meets the conditions of "contiguous or adjacent." In addition, the hydrogen plant will take its feed from the refinery. ConocoPhillips will direct the hydrogen plant to produce the amount of hydrogen that it needs at any time, so the hydrogen plant is considered to be under ConocoPhillips' control. Therefore, the hydrogen plant will be considered to be part of the refinery. The hydrogen plant will also supply steam and electricity to ConocoPhillips.

Since it is part of the refinery, the two projects (CFEP and hydrogen plant) will be considered as one project for the purposes of NSR, PSD, Major Facility Review (Title V), offsets, NSPS, NESHAPS, and any other applicable requirements.

The Title V regulations in 40 CFR 70 allow agencies to issue more than one Title V permit to a facility. Because the hydrogen plant will be owned and operated by Air Liquide, it will have a separate plant number, B7419, and a separate application, No. 13678.

The ConocoPhillips Carbon Plant, Plant A0022, is owned and operated by ConocoPhillips. It is contiguous to the refinery. Although it has a separate plant number and Title V permit, it is also considered part of the ConocoPhillips facility. The applicant will reduce emissions at the carbon plant to obtain reductions in actual emissions of PM10 for the purposes of CEQA and contemporaneous offsets of SO₂.

The facility will also generate contemporaneous offsets at the refinery by permanently reducing emissions of POC at S1007, Dissolved Air Flotation Unit; permanently reducing emissions of combustion contaminants by shutting down S8, Boiler; and permanently reducing NO_x emissions at the Steam Power Plant, S352-S357.

The list of equipment that is affected at ConocoPhillips, Facility A0016, is shown below:

- S45, Heater (U246), 85 MMbtu/hr
- S98, Tank 101, EFRT, 170k barrels
- S118, Tank No. 163, fixed roof, 5.3k barrels
- S122, Tank No. 167, EFRT, 3.1 MMgals
- S123, Tank No. 168, EFRT, 75k barrels
- S124, Tank No. 169, EFRT, 75k barrels
- S128, Tank No. 174, EFRT, 76k barrels
- S139, Tank No. 204, fixed roof, 81k barrels, abated by A7, Vapor Recovery System
- S140, Tank No. 205, fixed roof, 54k barrels, abated by A7, Vapor Recovery System
- S168, Tank No. 269, fixed roof, 39k barrels, abated by A7, Vapor Recovery System
- S173, Tank No. 280 fixed roof, 134k barrels, abated by A7, Vapor Recovery System
- S174, (Tank No. 281), fixed roof, 134k barrels, abated by A7, Vapor Recovery System
- S182, Tank No. 294, fixed roof, 40k barrels, abated by A7, Vapor Recovery System
- S465, Sulfur Pit 235 abated by S1004, U235 Sulfur Recovery Unit
- S307, U240 Unicracking Unit (increase of 23,000 bbl/day)
- S308, U244 Reforming Unit (increase of 2,413 bbl/day)
- S309, U248 UNISAR Unit (increase of 7,830 bbl/day)
- S318, U76 Gasoline Blending (increase of 8,300,000 bbl/yr)
- S339, U80 Gasoline/Mid Barrel Blending
- S352, Combustion Turbine
- S353, Combustion Turbine
- S354, Combustion Turbine
- S355, Duct Burner
- S356, Duct Burner

S357, Duct Burner
S432, U215 Deisobutanizer (increase of 2,600 bbl/day)
S434, U246 High Pressure Reactor Train (Cracking) (23,000 bbl/day)
S464, Hydrogen Plant (not new source, was originally permitted as part of S307, U240 Unicracking Unit)
S503, Sulfur Storage Tank abated by S1004, U235 Sulfur Recovery Unit
S504, Sulfur Degassing Unit abated by S1004, U235 Sulfur Recovery Unit
S505, Sulfur Truck Loading Rack abated by S1004, U235 Sulfur Recovery Unit
S1004, U235 Sulfur Recovery Unit (200 long tons/day)
S1007, Dissolved Air Flotation Unit (DAF)
A7, Odor Abatement System
A47, SCR abating S45, Heater
A48, SRU Tail Gas Treatment Unit abating S1004, Sulfur Recovery Unit
A49, DAF Thermal Oxidizer (440,000 btu/hr) abating S1007, Dissolved Air Flotation
A51, DAF Carbon Bed
A424, Tail Gas Incinerator abating A48, SRU Tail Gas Treatment Unit and S1004, Sulfur Recovery Unit

Demolitions

S8, Boiler, U240 B-1 Boiler, 256 MMbtu/hr

Sources S45, S465, S434, and S1004, and abatement devices A47, A48, A49, and A424 will be new.

The list of equipment that is affected at ConocoPhillips, Plant A0022, is shown below:

S2, K-2, Kiln Burner

The list of new equipment for Air Liquide, Plant B7419, is shown below:

S1, Hydrogen Plant including HRSG and steam turbine generator (10.5 MW)
S2, Hydrogen Plant Furnace, 1,072 MMbtu/hr abated by A1, SCR
S3, Hydrogen Plant Flare, 2200 MMbtu/hr
S4, Cooling Tower, 3,700 gpm
S5, Ammonia Tank, 10,000 gal

The application states that emissions from ships and barges will decrease because the most of the HGO that will be processed in the new unicracker, S434, will not be shipped through the marine loading source. Some is being produced at the refinery now and some will be shipped up from the Santa Maria refinery via the pipeline. Currently, an average of 249,000 barrels per year of HGO destined for S305, Prefractionator, is shipped to the refinery via marine

vessels. This HGO will be sent to the new Hydrocracker, S434, after being processed at S305.

The emissions increase in vessels carrying gasoline will be smaller than the decrease caused by processing the HGO that is in-house. ConocoPhillips has a firm limit on the amount of gasoline that can be shipped via ship or barge. The increase in heavy gas oil that is received from the Santa Maria refinery will be received by pipeline, not ship or barge, per the applicant. Also, a permit condition will be imposed on the marine loading source to restrict the amount of HGO received for this purpose via the marine loading source to 249,000 barrels per year.

2. EMISSION CALCULATIONS

The emissions are calculated in different ways to determine applicability of various requirements. The emission calculations will be presented in this order:

- Actual and CEQA emissions
- Emission calculations for the purposes of offsets
- PSD emissions

2.1 Actual and CEQA emissions

The detailed emission calculations of criteria pollutants (NOx, SO2, PM10, POC, and CO) are in Appendix A. Following is a summary of the proposed emissions in tons per year from the changes to the ConocoPhillips plant.

After the public comment period, the facility agreed to lower the NOx and CO emissions at S45, Heater, and the SO2 emissions at S1004, Sulfur Recovery Unit. The facility also agreed to lower the overall emission limit for PM10 by 0.2 ton/yr.

| Source | Tons per Year | | | | |
|--|---------------|-------|------|------|-------|
| | NOx | SO2 | PM10 | POC | CO |
| S45, New Unit 246 HGO Feed Heater ^{1,4} | 2.3 | 4.7 | 1.9 | 1.5 | 2.8 |
| S434, New Unit 246 Startup/Shutdown ² | <0.01 | <0.01 | - | 0.03 | 0.02 |
| S1004, New SRU (Unit 235) | 11.2 | 29.7 | 0.59 | 0.4 | 37.9 |
| Tanks 101, 168 & 169 Permit Cond. Change | | | | 8.1 | |
| Existing Tanks | | | | 4.8 | |
| Fugitives | | | | 6.1 | |
| Paved Roads | | | 1.1 | | |
| S8, Unit 240 Boiler B-1 Reductions ¹ | -22.4 | | -2.9 | -2.1 | -43.4 |
| Increased Heater Utilization ² | 7.2 | 1.2 | 3.1 | 2.3 | 2.8 |

| Source | Tons per Year | | | | |
|--|---------------|-----------|------------|--------------|------------|
| | NOx | SO2 | PM10 | POC | CO |
| Increased Tank Utilization ² | | | | 1.0 | |
| Refinery Steam Power Plant Reductions | -22.1 | | | | |
| Locomotive Emissions | 2.2 | 0.2 | 0.08 | 0.1 | 0.3 |
| Truck and Commuter Auto Trips ³ | 2.2 | <0.1 | 0.1 | 0.2 | 2.7 |
| S1007, Dissolved Air Flotation (DAF) Unit | 0.2 | 1.2 | 0.01 | -44.1 | 0.2 |
| Butane Loading Rack ³ | | | | 0.2 | |
| Total | -19.2 | 37 | 4.0 | -21.5 | 3.3 |

¹ CEQA does not require emissions to be RACT-adjusted.

² Increases within permitted limits

³ Exempt source

⁴ S45 and S1004 together will emit less than 2.5 tpy PM10. Reduction shown here at S45 for convenience.

Following is a summary of the original proposed emissions in tons per year from the proposed Air Liquide hydrogen plant. The annual emissions were calculated for the average operating rate of 975 MMBtu/hr. The maximum daily emissions were calculated for the maximum operating rate of 1,072 MMBtu/hr.

Summary of Hydrogen Plant Emissions

| Source | Tons per Year | | | | |
|-----------------------|---------------|------------|-------------|-------------|-------------|
| | NOx | SO2 | PM10 | POC | CO |
| New SMR Furnace | 28.1 | 5.0 | 15.8 | 11.5 | 34.2 |
| Deaerator Vent | -- | -- | -- | 0.8 | -- |
| Flare Pilots/NG Purge | 0.12 | 0.004 | -- | -- | 1.1 |
| Startup/Shutdown | 2.7 | 0 | 0 | 0.1 | 11 |
| Cooling Tower | | | 0.5 | 1.5 | |
| Fugitives | -- | -- | -- | 1.5 | -- |
| Total | 30.9 | 5.0 | 16.3 | 15.4 | 46.2 |

(975 MMBtu/hr, annual average)

| Source | Lb per Day | | | | |
|-----------------------|------------|-------|------|-----|-----|
| | NOx | SO2 | PM10 | POC | CO |
| New SMR Furnace | 169 | 30 | 95 | 69 | 206 |
| Deaerator Vent | -- | -- | -- | 4.4 | -- |
| Flare Pilots/NG Purge | 0.68 | 0.022 | -- | -- | 5.9 |
| Cooling Tower | | | 2.5 | 8.2 | |
| Fugitives | -- | -- | -- | 7.9 | -- |

(1072 MMBtu/hr, hourly maximum)

| Source | Lb per Day | | | | |
|--------|------------|-----|------|------|-----|
| | NOx | SO2 | PM10 | POC | CO |
| Total | 170 | 30 | 97.5 | 90.2 | 212 |

Air Liquide's final proposal is to reduce the particulate emissions from the new SMR furnace to 13.8 tons per year. Air Liquide may comply by showing that the particulate emission factor is less than 0.0037 lb/MMbtu or by curtailing operations. The resulting annual emissions are:

Summary of Hydrogen Plant Annual Emissions

| Source | Tons per Year | | | | |
|-----------------------|---------------|-------|------|------|------|
| | NOx | SO2 | PM10 | POC | CO |
| New SMR Furnace | 28.1 | 5.0 | 13.8 | 11.5 | 34.2 |
| Deaerator Vent | -- | -- | -- | 0.8 | -- |
| Flare Pilots/NG Purge | 0.12 | 0.004 | -- | -- | 1.1 |
| Startup/Shutdown | 2.7 | 0 | 0 | 0.1 | 11 |
| Cooling Tower | | | 0.5 | 1.5 | |
| Fugitives | -- | -- | -- | 1.5 | -- |
| Total | 30.9 | 5.0 | 14.3 | 15.4 | 46.2 |

Following is a summary of the proposed emission reductions in tons per year from the ConocoPhillips carbon plant, Plant A0022. The SO2 reductions are considered ERCs that comply with BAAQMD Regulation 2-2-201. The PM10 reductions do not comply and will be accepted for the purposes of CEQA only, which does not require RACT reductions for ERCs.

SO2: 42 tons per year

PM10: 8 tons per year

(Note: The PM10 reduction was increased from 7.5 to 8 tons per year.)

The total actual and CEQA emissions increases from the project are:

| | Tons per Year | | | | |
|-----------------------------|---------------|-------|------|-------|------|
| | NOx | SO2 | PM10 | POC | CO |
| ConocoPhillips Refinery | -19.2 | 37 | 4.0 | -21.5 | 3.3 |
| Hydrogen Plant | 30.9 | 5.0 | 14.3 | 15.5 | 46.2 |
| ConocoPhillips Carbon Plant | | -42.0 | -8 | | |
| Total | 11.7 | 0 | 10.3 | -6.0 | 49.5 |

2.2 Emissions for the purposes of cumulative increase and offsets

The PM10 emission reductions at the Carbon Plant are not considered ERCs for the purposes of BAAQMD Regulation 2-2-201 because these reductions are not "in excess of the reductions achieved by, or achievable by, the source using Reasonably Available Control Technology." The last three source tests show that the emission rate is approximately 0.04 gr/dscf. RACT has not been determined, but is estimated to be 0.01 or 0.02 gr/dscf.

For the refinery, the following adjustments are made to the sum of actual emissions in the first table in Section 2.1. The NOx reduction for S8 has been RACT-adjusted to 16.7 based on the RACT level of 0.033 lb/MMbtu in BAAQMD Regulation 9, Rule 10. The increased heater and tank utilization were not included since they are within permitted limits. The truck and commuter trips and the butane loading rack increases are not included since they do not require permits.

After public notice, the emissions estimates for NOx and CO at S45, Heater, have been reduced due to a new BACT determination and the facility has agreed to lower the annual SO2 emissions at S1004, Sulfur Recovery Unit, in response to a public comment.

| Source | Tons per Year | | | | |
|--|---------------|-------------|-------------|--------------|-------------|
| | NOx | SO2 | PM10 | POC | CO |
| S45, New Unit 246 HGO Feed Heater ^{1,4} | 2.3 | 4.7 | 1.9 | 1.5 | 2.8 |
| S434, New Unit 246 Startup/Shutdown ² | <0.01 | <0.01 | - | 0.03 | 0.02 |
| S1004, New SRU (Unit 235) | 11.2 | 26.7 | 0.59 | 0.4 | 37.9 |
| Tanks 101, 168 & 169 Permit Cond. Change | | | | 8.1 | |
| Existing Tanks | | | | 4.8 | |
| Fugitives | | | | 6.1 | |
| Paved Roads | | | 1.1 | | |
| S8, Unit 240 Boiler B-1 Reductions | -16.7 | | -2.9 | -2.1 | -43.4 |
| Refinery Steam Power Plant Reductions | -22.1 | | | | |
| Locomotive Emissions | 2.2 | 0.2 | 0.08 | 0.1 | 0.3 |
| S1007, Dissolved Air Flotation (DAF) Unit | 0.2 | 1.2 | 0.01 | -44.1 | 0.2 |
| Total | -22.9 | 32.8 | 0.78 | -25.1 | -2.2 |

(Note: The sum of particulate emissions in the original proposal was in error. The correct sum was 0.98 tons per year.)

The emission reductions are acceptable for the purposes of CEQA without the "RACT" adjustment. The emissions for the purposes of cumulative increase and offsets are:

| | Tons per Year | | | | |
|-----------------------------|---------------|-------|------|-------|------|
| | NOx | SO2 | PM10 | POC | CO |
| ConocoPhillips Refinery | -22.9 | 32.8 | 0.8 | -25.1 | -2.2 |
| Hydrogen Plant | 30.9 | 5.0 | 13.8 | 13.9 | 46.2 |
| ConocoPhillips Carbon Plant | | -42.0 | | | |
| Total | 8.0 | -4.2 | 14.6 | -11.2 | 44 |

In accordance with BAAQMD Regulation 2-2-215, emissions from cargo carriers are included in the total emissions that are subject to offsets. The total above includes the emissions increase from locomotives.

2.3 Emissions for the purposes of Prevention of Significant Deterioration (PSD)

As originally proposed, this project was subject to PSD because:

- The facility is a major facility.
- The project was a major modification because the applicants were proposing an increase of 16.9 tons PM10/year.

However, ConocoPhillips and Air Liquide have decided to limit the particulate emissions from S45, Heater; S1004, Sulfur Recovery Unit; and S2, Hydrogen Plant Furnace so that the emissions for the purposes of PSD are 14.5 tons per year.

The original emission estimates for the purposes of PSD were:

| | Tons per Year | | | | |
|--------------------------------------|---------------|-------|-------|-------|------|
| | NOx | SO2 | PM10 | POC | CO |
| ConocoPhillips Refinery ¹ | -24.2 | 42.6 | 1.02 | -25 | 2.5 |
| Hydrogen Plant | 30.9 | 5.0 | 15.8 | 13.9 | 46.2 |
| ConocoPhillips Carbon Plant | | -42.0 | | | |
| Total | 6.7 | 5.6 | 16.82 | -11.1 | 48.7 |

¹Locomotives are not included in the PSD total.

The final emission limits are:

| | Tons per Year | | | | |
|--------------------------------------|---------------|-------|------|-------|------|
| | NOx | SO2 | PM10 | POC | CO |
| ConocoPhillips Refinery ¹ | -25.1 | 35.6 | 0.7 | -25 | -2.5 |
| Hydrogen Plant | 30.9 | 5.0 | 13.8 | 13.9 | 46.2 |
| ConocoPhillips Carbon Plant | | -42.0 | | | |
| Total | 5.8 | -1.4 | 14.5 | -11.1 | 43.7 |

¹Locomotives are not included in the PSD total.

This project is not a major modification because the emission increase of PM10 is less than 15 ton per year, the emissions increases for NOx, SO2, and POC are less than 40 tons per year, and the emissions increase for CO is less than 100 tons per year. So, this project is not subject to PSD for NOx, SO2, CO, PM10, and POC. Nonetheless, modeling has been submitted for both NOx and PM10.

Following is a summary of the emissions of non-criteria pollutants found in BAAQMD Regulation 2-2-306 and 40 CFR 51.166 and the thresholds that require PSD analysis.

The ConocoPhillips refinery is a major facility for all of the following pollutants: NOx, POC, SO2, CO, PM10. Therefore, the emission increase from this project may not exceed the following limits, since no PSD air quality analysis has been performed for these pollutants:

| POLLUTANT | ANNUAL AVERAGE LIMIT (TON/YR) | EMISSION (TON/YR) | DAILY LIMIT (LB/DAY) | EMISSION (LB/DAY) |
|---|-------------------------------|-------------------|----------------------|-------------------|
| Lead | 0.6 | 0.026 | 3.2 | 0.141 |
| Asbestos | 0.007 | 0 | 0.04 | 0 |
| Beryllium | 0.0004 | 0 | 0.002 | 0 |
| Mercury | 0.1 | 0.00009 | 0.5 | 0.0052 |
| Fluorides | 3 | 0 | 16 | 0 |
| Sulfuric acid mist | 7 | 6.64 | 38 | 36.4 |
| Hydrogen sulfide | 10 | 1.1 | 55 | 5.34 |
| Total reduced sulfur including hydrogen sulfide | 10 | 1.1 (note 1) | 55 | 5.34 (note 1) |
| Reduced sulfur compounds including hydrogen sulfide | 10 | 1.1 (note 1) | 55 | 5.34 (note 1) |

Note 1. Reduced sulfur compounds emitted from refinery sources are emitted to the atmosphere as SO2 when they are collected and used as fuel gas. There is no emission increase for untreated or unreacted reduced sulfur compounds at combustion sources. However, the facility will be required to test for reduced sulfur compounds at the sulfur recovery unit to confirm that all reduced sulfur compounds are incinerated.

The estimates for sulfuric acid mist are close to the PSD thresholds, but they have been estimated conservatively. The estimate for the acid mist at the new SRU is based on source tests for acid mist at the 3 existing SRUs. The estimate for increased acid mist at the combustion sources is based on 5% conversion of SO₂ to SO₃, and all SO₃ converted to H₂SO₄.

The facility will have an annual limit on sulfuric acid mist at the SRU, which is estimated to emit a maximum of 5.65 tpy, and will be required to perform an annual source test to show compliance.

The facility has agreed to a reduction in SO₂ emissions at the SRU from 36.7 tons to 29.7 tons per year. Although the sulfuric acid mist limit has not been lowered, it is expected that the amount of sulfuric acid mist produced will decrease, because sulfuric acid mist is proportional to SO₂.

The acid mist calculations are shown in Appendix B.

No PSD analysis has been performed for the specified non-criteria pollutants, but a Health Risk Screening Analysis has been completed to comply with BAAQMD Regulation 2, Rule 5, New Source Review for Toxic Air Contaminants.

2.4 Increases in toxic air contaminants

Following is a summary of the increases in toxic air contaminants at the refinery:

| Substance | Emissions, lb/yr | BAAQMD Trigger Level, lb/yr |
|----------------------|------------------|-----------------------------|
| Acenaphthene | 2.12E-03 | |
| Acenaphthylene | 1.39E-03 | |
| Acetaldehyde | 1.38E+01 | 6.40E+01 |
| Acrolein | 0.00E+00 | 2.30E+00 |
| Ammonia | 1.27+04 | 7.70E+03 |
| Antimony | 4.65E-01 | 7.70E+00 |
| Arsenic | 7.64E-01 | 1.20E-02 |
| Benzene | 3.83E+02 | 6.40E+00 |
| Benzo(a)anthracene | 2.89E-02 | 0.011* |
| Benzo(a)pyrene | 8.06E-02 | 0.011* |
| Benzo(b)fluoranthene | 3.63E-02 | 0.011* |
| Benzo(k)fluoranthene | 2.17E-02 | 0.011* |
| Cadmium | 8.88E-01 | 4.50E-02 |

| Substance | Emissions, lb/yr | BAAQMD Trigger Level, lb/yr |
|------------------------|------------------|-----------------------------|
| Chromium (Total) | 9.62E-01 | 1.30E-03 |
| Chrysene | 1.47E-03 | |
| Copper | 3.79E+00 | 9.30E+01 |
| Cyclohexane | 1.59E+02 | |
| Ethylbenzene | 1.45E+02 | 7.70E+04 |
| Fluoranthene | 2.75E-03 | |
| Fluorene | 9.71E-03 | |
| Formaldehyde | 9.98E+01 | 3.00E+01 |
| n-Hexane | 1.74E+03 | 2.70E+05 |
| 1,2,3,4,7,8 -HxCDD | 1.11E-06 | |
| 1,2,3,6,7,8- HxCDD | 2.72E-06 | |
| 1,2,3,7,8,9- HxCDD | 1.79E-06 | |
| 1,2,3,4,7,8 -HxCDF | 1.52E-05 | |
| 1,2,3,6,7,8- HxCDF | 1.15E-05 | |
| 2,3,4,6,7,8- HxCDF | 1.00E-05 | |
| 1,2,3,7,8,9- HxCDF | 1.40E-06 | |
| 1,2,3,4,6,7,8- HpCDD | 9.73E-06 | |
| 1,2,3,4,6,7,8- HpCDF | 5.14E-05 | |
| 1,2,3,4,7,8,9- HpCDF | 4.66E-06 | |
| Hydrogen sulfide | 2.06+03 | 3.9E+02 |
| Indeno(1,2,3-cd)pyrene | 9.26E-02 | 0.011* |
| Lead | 4.40E+00 | 5.40E+00 |
| Manganese | 6.12E+00 | 7.70E+00 |
| Mercury | 1.62E-01 | 5.60E-01 |
| Naphthalene | 1.18E+01 | 5.30E+00 |
| Nickel | 8.47E+00 | 7.30E-01 |
| OCDD | 4.90E-06 | |
| OCDF | 1.21E-05 | |
| PCBs (Total) | 4.44E-03 | |
| 1,2,3,7,8 -PeCDD | 9.19E-07 | |
| 1,2,3,7,8 -PeCDF | 5.51E-06 | |
| 2,3,4,7,8 -PeCDF | 7.51E-06 | |
| Phenanthrene | 1.31E-02 | |
| Phenol | 5.08E+00 | 7.70E+03 |
| Propylene | 1.95E+00 | 1.20E+05 |
| Pyrene | 2.23E-03 | |
| Selenium | 1.76E-02 | 7.70E+02 |
| Silver | 1.45E+00 | |
| Sulfuric Acid Mist | 1.13+04 | 3.9E+01 |

| Substance | Emissions, lb/yr | BAAQMD Trigger Level, lb/yr |
|------------------------|------------------|-----------------------------|
| 2,3,7,8-TCDD | 5.12E-08 | |
| 2,3,7,8-TCDF | 1.95E-06 | |
| Toluene | 8.98E+02 | 1.20E+04 |
| 1,2,4-Trimethylbenzene | 1.82E+02 | |
| Xylene (Total) | 6.20E+02 | 2.70E+04 |
| Zinc | 1.87E+01 | 1.40E+03 |

Following is a summary of the increases in toxic air contaminants at the hydrogen plant:

| Substance | Emissions, lb/yr | BAAQMD Trigger Level, lb/yr |
|----------------------|------------------|-----------------------------|
| Acenaphthene | 2.27E-02 | |
| Acenaphthylene | 1.49E-02 | |
| Acetaldehyde | 1.48E+02 | 6.40E+01 |
| Acrolein | 4.69E-02 | 2.30E+00 |
| Ammonia | 5.38E+04 | 7.70E+03 |
| Antimony | 4.98E+00 | 7.70E+00 |
| Arsenic | 8.19E+00 | 1.20E-02 |
| Benzene | 6.24E+02 | 6.40E+00 |
| Benzo(a)anthracene | 3.09E-01 | 0.011b |
| Benzo(a)pyrene | 8.63E-01 | 0.011b |
| Benzo(b)fluoranthene | 3.89E-01 | 0.011b |
| Benzo(k)fluoranthene | 2.32E-01 | 0.011b |
| 1,3-Butadiene | 4.84E+00 | 1.10E+00 |
| Cadmium | 9.52E+00 | 4.50E-02 |
| Chlorine | 3.95E-02 | 7.70E+00 |
| Chloroform | 9.94E+00 | 3.40E+01 |
| Chromium (Total) | 1.03E+01 | 1.30E-03 |
| Chrysene | 1.57E-02 | |
| Copper | 4.06E+01 | 9.30E+01 |
| Ethylbenzene | 2.98E+02 | 7.70E+04 |
| Fluoranthene | 2.95E-02 | |
| Fluorene | 1.04E-01 | |
| Formaldehyde | 1.08E+03 | 3.00E+01 |

| Substance | Emissions, lb/yr | BAAQMD Trigger Level, lb/yr |
|------------------------|------------------|-----------------------------|
| n-Hexane | 7.63E+00 | 2.70E+05 |
| Indeno(1,2,3-cd)pyrene | 9.93E-01 | 0.011* |
| Lead | 4.71E+01 | 5.40E+00 |
| Manganese | 6.56E+01 | 7.70E+00 |
| Mercury | 1.73E+00 | 5.60E-01 |
| Methanol | 1.75E+04 | 1.50E+05 |
| Naphthalene | 3.08E+00 | 5.30E+00 |
| Nickel | 9.08E+01 | 7.30E-01 |
| Phenanthrene | 1.41E-01 | |
| Phenol | 5.43E+01 | 7.70E+03 |
| Propylene | 3.24E+01 | 1.20E+05 |
| Pyrene | 2.39E-02 | |
| Selenium | 1.89E-01 | 7.70E+02 |
| Silver | 1.55E+01 | |
| Sulfuric Acid Mist | 8.60+2 | 3.9E+01 |
| Toluene | 1.03E+03 | 1.20E+04 |
| 1,2,4-Trimethylbenzene | 4.98-01 | |
| Xylene (Total) | 3.60E+02 | 2.70E+04 |
| Zinc | 2.00E+02 | 1.40E+03 |

2.5 Mobile sources

Details of the emissions of mobile sources can be found in the Draft Environmental Impact Report that has been prepared by Contra Costa County. The District requires offsets only for emissions from cargo carriers that are not motor vehicles.

3. BACT and ract REVIEW AND DETERMINATION

In accordance with BAAQMD Regulation 2-2-301, the following sources will be subject to BACT because they are new sources that will emit more than 10 lb/highest day of POC, NO_x, SO₂, PM₁₀, and/or CO.

- S45, Heater (U246), 85 MMbtu/hr
- S434, U246 High Pressure Reactor Train (Cracking) (23,000 bbl/day)
- S1004, U235 Sulfur Recovery Unit (200 long tons/day)

In accordance with BAAQMD Regulation 2-2-301, the following sources will be subject to BACT because they are existing sources that emit more than 10

lb/highest day of POC, NOx, SO₂, PM₁₀, and/or CO, and the project will cause an emissions increase at the source.

- S98, Tank 101, EFRT, 170k barrels
- S122, Tank No. 167, EFRT, 3.1 MMgal
- S123, Tank No. 168, EFRT, 75k barrels
- S124, Tank No. 169, EFRT, 75k barrels
- S128, Tank No. 174, EFRT, 76k barrels
- S307, U240 Unicracking Unit
- S308, U244 Reforming Unit
- S309, U248 UNISAR Unit
- S318, U76 Gasoline Blending
- S339, U80 Gasoline/Mid Barrel Blending
- S432, U215 Deisobutanizer

The following sources are not subject to BACT because the emissions from each of POC, NOx, SO₂, PM₁₀, and/or CO will be below 10 lb/highest day.

- S118, Tank No. 163, fixed roof, 5.3k barrels
- S465, Sulfur Pit U235 abated by S1003 or S1004, Sulfur Recovery Units
- S503, Sulfur Storage Tank abated by S1003 or S1004, Sulfur Recovery Units
- S504, Sulfur Degassing Unit abated by S1003 or S1004, Sulfur Recovery Units
- S505, Sulfur Truck Loading Rack abated by S1004, U235 Sulfur Recovery Unit

The following sources are not subject to BACT because there will be no emissions increase at the sources.

- S139, Tank No. 204, fixed roof, 81k barrels, abated by A7, Vapor Recovery System
- S140, Tank No. 205, fixed roof, 54k barrels, abated by A7, Vapor Recovery System
- S168, Tank No. 269, fixed roof, 39k barrels, abated by A7, Vapor Recovery System
- S173, Tank No. 280 fixed roof, 134k barrels, abated by A7, Vapor Recovery System
- S174, (Tank No. 281), fixed roof, 134k barrels, abated by A7, Vapor Recovery System
- S182, Tank No. 294, fixed roof, 40k barrels, abated by A7, Vapor Recovery System
- S464, Hydrogen Plant (not new source, was originally permitted as part of S307, U240 Unicracking Unit)

The following source will not be subject to BACT for POC because there will be a decrease in POC emissions increase at the source.

S1007, Dissolved Air Flotation Unit (DAF) abated by A49, DAF Thermal Oxidizer.

There will be an emissions increase of NO_x, CO, PM, and SO₂ at A49, DAF Thermal Oxidizer. However, A49 will not be subject to BACT for these pollutants because the emissions of each will be less than 10 lb/highest day.

Cargo carriers, and therefore locomotives, are not subject to BACT pursuant to BAAQMD Regulation 2-2-206.

Abatement devices

Secondary emissions from abatement devices are not subject to BACT, but are subject to RACT (reasonably available control technology) if the device complies with BACT for the primary pollutant, per the exemption in BAAQMD Regulation 2-2-112, which states:

"The BACT requirements of Section 2-2-301 shall not apply to emissions of secondary pollutants which are the direct result of the use of an abatement device or emission reduction technique which complies with the BACT or BARCT requirements for control of another pollutant. However, the APCO shall require the use of Reasonably Available Control Technology (RACT) for control of these secondary pollutants. The Air Pollution Control Officer shall determine which pollutants are primary and which are secondary for the equipment being evaluated."

The following abatement devices are sources of secondary air pollutants:

A47, SCR abating S45, Heater

A49, DAF Thermal Oxidizer (440,000 btu/hr) abating S1007, Dissolved Air Flotation

A424, Tail Gas Incinerator abating A48, SRU Tail Gas Treatment Unit and S1004, Sulfur Recovery Unit

Following is the discussion of the BACT determinations for the sources that are subject to BACT in order of the magnitude of the emissions.

S1004, U235 Sulfur Recovery Unit (200 long tons/day)

S45, Heater (U246), 85 MMbtu/hr

Tanks: S98, S122, S123, S124, S128

Sources of fugitive emissions: S307, S308, S309, S318, S339, S432, S434

The abatement devices are discussed after the discussion of the BACT determinations.

3.1. S1004, U235 Sulfur Recovery Unit (200 long tons/day)

ConocoPhillips has proposed the following emission levels for the new Sulfur Recovery Unit:

| Pollutant ₁ | Emission Factor | | Reference for BACT determination |
|------------------------|-------------------------------|--------|---|
| NO _x | 42.2 ppmv @ 7% O ₂ | 0.0669 | BACT Determination for ConocoPhillips Ferndale Refinery |
| SO ₂ | 50 ppmv @ 0% O ₂ | NA | BACT Determination for Shell Martinez Refinery |
| PM10 | 7.6 lb/MMcf | 0.0075 | AP42 Section 1.4, Natural Gas Combustion |
| POC | 5.5 lb/MMcf | 0.0054 | AP42 Section 1.4, Natural Gas Combustion |
| CO | 75 ppmvd @ 7% O ₂ | 0.0965 | New BACT Determination |

The proposed emissions are:

| | Lb/hr | Lb/day | Ton/yr |
|-----------------|-------|--------|--------|
| NO _x | 2.56 | 61.3 | 11.2 |
| SO ₂ | 8.45 | 201 | 29.7 |
| PM10 | 0.14 | 3.2 | 0.59 |
| POC | 0.1 | 2.3 | 0.43 |
| CO | 8.65 | 201 | 37.9 |

Based on this proposal, the sulfur recovery unit (SRU) is not subject to BACT for PM10 or POC. An initial source test will be required to confirm the low emissions of PM10 and POC.

SO₂

The last BACT determination for an SRU made by the District was in Application 8407 for the Shell Refinery in 1993. At that time, BACT was only determined for SO₂ and CO. The BACT determination for SO₂ was:

- control by a SCOT unit and a tailgas incinerator
- 100 ppm total reduced sulfur @ 0% O₂ on the feed to the tailgas incinerator
- 50 ppm SO₂ @ 0% O₂
- 2.5 ppm H₂S @ 0% O₂
- requirement to strip 95% by weight of the H₂S and NH₃ from the sour water stream

This unit will be controlled by an amine stripper and tailgas incinerator. The same concentration limit on SO₂ will be imposed. The SO₂ emissions compare favorably to the emissions from the Shell Refinery SRU, because the emissions will be similar—35 tons per year for Shell versus 36.7 tons per year for ConocoPhillips—but the capacity of the Shell SRU is 30% smaller—140 tons sulfur make per day for Shell versus 200 tons sulfur make per day for ConocoPhillips.

The BACT proposal also compares favorably to the BACT determination made for the proposed Arizona Clean Fuel Yuma facility. That SRU would have the following specifications:

- 33.6 lb SO₂/hr or 806 lb SO₂/day
- maximum capacity: 800 long tons/day
- nominal capacity: 608 long tons/day
- 99.97% recovery of sulfur

The ConocoPhillips SRU will have a capacity of 200 long tons per day and SO₂ emissions of 201 lb/day. Therefore, about 1 lb SO₂/long ton sulfur will be emitted. At maximum capacity, the proposed Arizona SRU will emit about 1 lb SO₂/long ton sulfur. At nominal capacity, it will emit about 1.3 lb SO₂/long ton sulfur.

After public comment, the refinery agreed to lower the annual SO₂ emissions by an additional 7 tons per year at the SRU as an additional mitigation for CEQA. The final emission limit is 29.7 tons SO₂ per year. At nominal capacity, this is equivalent to 0.8 lb SO₂/long ton sulfur.

The facility has calculated emissions of H₂S in the outlet and has accepted a limit of 2.5 ppmvd @ 0% O₂. However, the facility has not provided an estimate for total reduced sulfur or reduced sulfur compounds at the outlet. The facility will be required to perform annual source tests for total reduced sulfur and reduced sulfur compounds to ensure that the trigger of 10 tons per year in BAAQMD Regulation 2-2-306 is not exceeded.

CO

The ConocoPhillips SRU is proposed to have CO emissions of 207 lb/day. Therefore, about 1.1 lb CO/long ton sulfur would be emitted.

Mass emissions of CO were not calculated for the SRU at the Shell refinery. The limit is 100 ppmv, dry, @ 0% O₂. ConocoPhillips is proposing 75 ppmv, dry, @ 7% O₂, which is equivalent to 8.65 lb/hr. The facility's original proposal was 57.1 ppmv, dry, @ 7% O₂, which is equivalent to 6.58 lb/hr, but was found by the designers not to be feasible.

The Arizona SRU is permitted to emit 36.8 tons CO/yr or 0.25 lb CO/long ton S at maximum capacity and 0.33 lb CO/long ton at nominal capacity. However, this is not achieved in practice, since the unit has not been built. The CO emissions are based purely on the thermal oxidizer heat input, using AP42 factors and may be overly optimistic. There are no emission limits for CO in the permit, according to the Statement of Basis.

The CO limits at the ConocoPhillips refinery in Ferndale, Washington, are 8.3 tons CO/yr and 42.2 ppmv, dry. Its capacity is 65 tons/day. Therefore, the rate of CO emissions is 0.7 lb CO/long ton sulfur.

NO_x

The ConocoPhillips SRU is proposed to have NO_x emissions of 61 lb/day. Therefore, about 0.3 lb NO_x/long ton sulfur would be emitted.

Mass emissions of NO_x were not calculated for the SRU at the Shell refinery.

The Arizona SRU is permitted to emit 26.3 tons NO_x/yr or 0.18 lb NO_x/long ton S at maximum capacity and 0.23 lb NO_x/long ton at nominal capacity. The emissions are based solely on NO_x formation in the thermal oxidizer. The BACT determination is 0.06 lb NO_x/MMbtu. The capacity of the thermal oxidizer is 100 MMbtu/hr. Again, this is not achieved in practice, since the unit has not been built.

The NO_x limits at the ConocoPhillips refinery in Ferndale, Washington, are 9.88 tons NO_x/yr and 42.2 ppmv, dry. Its capacity is 65 tons/day. Therefore, the rate of NO_x emissions is 0.7 lb NO_x/long ton sulfur.

Conclusion: The SRU meets BACT for SO₂, NO_x, and CO. The proposed NO_x emissions are lower, and the proposed CO emissions are higher, than those for the Ferndale refinery. This tradeoff is appropriate because the Bay Area is in attainment with all ambient air quality standards for CO.

ConocoPhillips has asked for a short-term limit of 8.0 lb NO_x/hr, the effects of which will be included in the annual limit. As of March 9, 2007, this short term limit has not been included in the PSD modeling, but it is not expected to have an important impact. (This modeling is not required, as explained in Section 2.3.)

3.2. S45, Heater (U246), 85 MMbtu/hr

ConocoPhillips has proposed the following BACT levels for the new heater:

| Pollutant | BACT | Technology | Reference |
|------------------|---|------------------------------------|---|
| NO _x | 7 ppmvd @ 3% O ₂ | Low-NO _x burner and SCR | BAAQMD BACT Determination for U-110 (Application 11293) |
| CO | 28 ppmvd @ 3% O ₂ | Good combustion practice | BAAQMD BACT Determination for ULSD (Application 5814) |
| SO ₂ | Use of natural gas and/or RFG; 100 ppmv total sulfur in RFG | Fuel selection | BAAQMD BACT Determination for ULSD Project and Guideline 94.3.1 |

| | | | |
|------|-------------------------------|---|------------------------------|
| | Use of natural gas and/or RFG | Fuel selection and good combustion practice | BAAQMD BACT Guideline 94.3.1 |
| POC | 5.5 lb/MMcf | | |
| | Use of natural gas and/or RFG | Fuel selection | BAAQMD BACT Guideline 94.3.1 |
| PM10 | 7.6 lb/MMcf | | |

Based on the proposed emissions below, the heater is subject to BACT for NOx, CO, SO2, and PM10.

| | lb/hr | lb/day | ton/yr |
|-----------------|-------|--------|--------|
| NOx | 0.73 | 18 | 3.2 |
| SO ₂ | 1.07 | 26 | 4.7 |
| PM10 | 0.48 | 12 | 2.1 |
| POC | 0.35 | 8.4 | 1.5 |
| CO | 1.79 | 43 | 7.8 |

The NOx, CO, and SO2 levels that ConocoPhillips has proposed are lower than the District's current BACT handbook.

The 100 ppmv total sulfur limit is lower than the 100 ppmv TRS limit in the BACT handbook, which only includes hydrogen sulfide, methyl mercaptan, methyl sulfide, and dimethyl disulfide. Recent permits have had limits of 45 ppmv TRS as defined here. However, analyses of gas treated in the Merichem (type of caustic scrubber) unit show that H2S is generally below detectable levels and that the largest sulfur components are carbonyl sulfide (COS) and thiophenes. Placing a limit on total sulfur ensures that the SO2 emissions are not overstated. Moreover, ConocoPhillips is capable of testing for H2S and total sulfur. Analyzing for a myriad of sulfur compounds adds to the cost and difficulty of monitoring and is unnecessary.

ConocoPhillips has requested an annual average for flexibility with the total sulfur limit. The District agrees with the need for flexibility but considers that the period is too long to easily determine compliance and considers a rolling 365-day period too cumbersome. Instead, the limit will have a calendar month average.

BACT for particulate matter is not an emission level but rather use of natural gas or treated refinery fuel gas. The facility will comply with this requirement because the refinery fuel gas will be treated in a Merichem unit that will reduce the total sulfur to less than 100 ppmv on a monthly average.

ConocoPhillips has performed a top-down analysis of BACT for NOx and PM10 at S45, which is required as part of the PSD analysis. The analysis is attached in Appendix D.

After the permit was proposed, the District determined that the South Coast Air Quality Management District had made some BACT determinations that had not been published for heaters burning refinery fuel gas. The concentrations that have been achieved in practice are 5 ppmv NOx and 10 ppmv CO at 3% O2, dry, 3-hour average.

The facility will conform to this BACT determination except when operating at a third of its maximum capacity or less. The facility explained that the cracking process generates a great deal of heat, so full capacity is not required at all times. The NOx limit is achievable at lower capacity, but the CO limit is not. The CO limit will be 28 ppmv at 3% O2, dry, 3-hour average, when the heater is operating at 30 MMbtu/hr or less. The mass emission rate will be roughly equivalent to the mass emission rate at maximum capacity. The averaging time will be reduced to 3 hours.

Following are the amended emission factors:

| Pollutant | BACT | Emission Factors (lb/MMbtu) |
|-----------|--|-----------------------------|
| NOx | 5 ppmvd @3% O2 | 0.0061 |
| CO | 10 ppmvd @3% O2 | 0.0075 |
| SO2 | 100 ppmv total sulfur in RFG; Use of natural gas and/or RFG | 0.0126 |
| POC | 5.5 lb/MMcf Use of natural gas and/or RFG | 0.0041 |
| PM10 | 7.6 lb/MMcf | 0.0057 |

Following are the amended hourly, daily, and annual mass emission rates:

| | lb/hr | lb/day | ton/yr |
|------|-------|--------|--------|
| NOx | 0.52 | 12.4 | 2.3 |
| SO2 | 1.07 | 26 | 4.7 |
| PM10 | 0.48 | 12 | 2.1 |
| POC | 0.35 | 8.4 | 1.5 |
| CO | 0.64 | 15.3 | 2.8 |

3.3. S98, S122, S123, S124, S128, External Floating Roof Tanks

The following BACT condition will be imposed on S98, S122, and S128 in BAAQMD Condition 22963, part 4:

The owner/operator shall equip S98, S122, S123, and S128 with a BAAQMD approved roof with mechanical shoe primary seal and zero gap secondary seal

meeting the design criteria of BAAQMD Regulation 8, Rule 5. The owner/operator shall ensure that there are no ungasketed roof penetrations, no slotted pipe guide poles unless equipped with float and wiper seals, and no adjustable roof legs unless fitted with vapor seal boots or equivalent. [BACT, cumulative increase]

BAAQMD Condition 22478, part 7, already subjects S123 and S124 to BACT. The wording is identical to the condition for S98, S122, and S128.

3.4. S307, S308, S309, S318, S339, S432, S434

These process units will have some new components (valves, flanges, pumps, compressors, etc.). These new components will be subject to BACT for petroleum refinery fugitive emissions in accordance with the Section 3 of the District's BACT handbook, which is:

- Graphitic gaskets for flanges
- Live loaded packing systems and polished stems, or equivalent, for valves
- "Wet" dual mechanical seals with a heavy liquid barrier fluid, or dual dry gas mechanical seals buffered with inert gas for hydrocarbon centrifugal compressors
- Seal-less design or dual mechanical seals with a heavy liquid barrier fluid, or equivalent, for pumps
- Fugitive equipment monitoring and repair program for all components

In the draft permit, the components were subject to Condition 21099 for fugitive components, which was written for the ULSD project in 2002. The components will now be subject to Condition 23725 because a new BACT determination has been made. The new condition contains explicit emission limits, a maximum annual emission rate for the new components as a group, and specifications for the types of components used. The leak rate for pumps and compressors has been lowered to 100 ppm. All pumps will be inspected, even those pumps that handle heavy liquids.

The new units, S434 and S1004, are subject to BAAQMD Regulation 8-28-302, which requires the installation of BACT on any pressure relief device. The BACT for new sources that is listed in the District's BACT Workbook is installation of a rupture disk and venting the pressure relief device to a fuel gas recovery system, furnace, or flare with a recovery/destruction efficiency of 98%. After discussions with the refinery, the District has determined that the rupture disks are unnecessary and may not be feasible where there are a high number of pressure cycles and high temperatures. The perceived advantage of the rupture disks is that they indicate whether there has been flow to the fuel gas recovery system. If this event is associated with flaring, knowing that the vessel was vented to the flare would aid in causal analysis. Refinery staff has stated that they will be able to determine whether venting of the vessel caused flaring by looking at the pressure data that they have for all vessels.

The modified units are also subject to this requirement. Therefore, a permit condition has been added for Sources S307, S308, S309, S318, S339, and S432, requiring the installation of BACT for the pressure relief devices. BACT for modified sources is venting the pressure relief device to a fuel gas recovery system, furnace, or flare with a recovery/destruction efficiency of 98%.

S309 and S339 are not subject to the standard in BAAQMD Regulation 8-28-302 because they are not considered to be modified. Although the units will have a throughput increase and are no longer considered to be "grandfathered" units, no new components will be installed. Since the emissions from these sources are fugitive emissions, if there are no new components, there is no increase in emissions from these sources, the sources are not considered to be modified, and they are not subject to BACT.

Following is the discussion of the RACT or BACT determinations for the abatement devices that are subject to RACT or BACT in order of the magnitude of the emissions.

A47, SCR abating S45, Heater

A49, DAF Thermal Oxidizer abating S1007, Dissolved Air Flotation

A424, Tail Gas Incinerator abating A48, SRU Tail Gas Treatment Unit and S1004, Sulfur Recovery Unit

3.5 A47, SCR abating S45, Heater

The secondary pollutant that is emitted by the SCR is ammonia. Ammonia is not subject to BACT, because the only pollutants mentioned in BAAQMD Regulation 2-2-301 are NO_x, CO, POC, PM₁₀, SO₂, and NPOC. However, the facility has agreed to a 15-ppm ammonia slip. The ammonia slip was 10 ppm before a new BACT determination was made lowering the NO_x concentration at the heater to 5 ppm. A higher ammonia slip is required to meet this lower limit.

3.6 A49, DAF Thermal Oxidizer (440,000 btu/hr) abating S1007, Dissolved Air Flotation (DAF) Unit

This abatement device is a thermal oxidizer that will burn vapors containing POC and H₂S that are emitted by the atmospheric vents at the DAF. As stated in BAAQMD Regulation 2-2-112, shown above, emissions of secondary pollutants are subject to RACT if the required level of control for the primary pollutant complies with BACT. In this case, POC is the primary pollutant. NO_x, CO, SO₂, and PM₁₀ are the secondary pollutants. Since POC levels from the DAF will be reduced, BACT is not triggered for POC and RACT is not triggered for the secondary pollutants.

Following are the emissions of secondary pollutants:

| Source | Lb/day | | | |
|---|--------|-----|------|------|
| | NOx | SO2 | PM10 | CO |
| S1007, Dissolved Air Flotation (DAF) Unit | 1.2 | 6.6 | 0.01 | 0.87 |

3.7 A424, Tail Gas Incinerator abating A48, SRU Tail Gas Treatment Unit and S1004, Sulfur Recovery Unit

RACT for this abatement device has not been considered. Instead, the entire sulfur recovery system including the Claus unit, the tail gas treatment unit, and the tail gas incinerator has been reviewed as a unit for BACT. This approach makes it possible to compare this sulfur recovery unit with others that have been built in the United States.

ConocoPhillips has performed a top-down analysis of BACT for NOx and PM10 at the hydrogen plant furnace, which is required as part of the PSD analysis. The analysis is attached in Appendix D.

4. CUMULATIVE INCREASE AND OFFSETS

The cumulative increase for the project is shown below.

| | Tons per Year | | | | |
|-----------------------------|---------------|-------|-------|-------|------|
| | NOx | SO2 | PM10 | POC | CO |
| ConocoPhillips Refinery | -22.9 | 35.8 | 0.8 | -25.1 | -2.2 |
| Hydrogen Plant | 30.9 | 5.0 | 13.8* | 13.9* | 46.2 |
| ConocoPhillips Carbon Plant | | -42.0 | | | |
| Total | 8.0 | -1.2 | 14.6 | -11.2 | 44 |

*The emissions from the exempt cooling tower at the hydrogen plant and the exempt butane loading rack at the refinery are not considered to be part of the cumulative increase and are not subject to offsets.

Offsets are required by BAAQMD Regulation 2-2-302 for NOx and POC because the emissions of the facility, which includes the ConocoPhillips refinery (BAAQMD Facility A0016), the ConocoPhillips carbon plant (BAAQMD Facility A0022), and the hydrogen plant (BAAQMD Facility B7419), are greater than 35 tons per year. In 2005, the refinery emitted approximately 335 tons NOx and 283 tons POC and the carbon plant emitted approximately 532 tons NOx in 2005 according to District estimates.

Offsets are required by BAAQMD Regulation 2-2-303 for SO₂ and PM₁₀ at major facilities. Major facilities, for the purpose of this requirement, are those that emit more than 100 tons per year of NO_x, CO, SO₂, PM₁₀, or POC. ConocoPhillips is a major facility for PM₁₀ because in 2005 the refinery emitted approximately 126 tons PM₁₀ and the carbon plant emitted approximately 63 tons PM₁₀ in 2005 according to District estimates. It is a major facility for SO₂ because in 2005 the refinery emitted approximately 424 tons SO₂ and the carbon plant emitted approximately 1212 tons SO₂ in 2005, according to District estimates.

Offsets are not required for CO, but 43.4 tons/yr are being provided through the shutdown of S8, Heater. The reduction is included in the emission totals for the refinery.

Contemporaneous offsets and banked offsets of SO₂ and PM₁₀ can be used at a 1.0:1.0 ratio. Banked offsets of NO_x or POC must be used at a 1.15:1.0 ratio. ConocoPhillips will provide contemporaneous offsets from the following sources:

- S8, Heater: shutdown
- S352-S357, Steam turbine plant: voluntary overcontrolling of NO_x emissions
- S1007, Dissolved Air Flotation Unit: voluntary overcontrolling of POC emissions
- BAAQMD Plant A0022, S2, Kiln: voluntary SO₂ reductions (Application 15328)

In accordance with BAAQMD Regulation 2-2-302.2, POC credits shall be used to offset part of the NO_x increases.

In previous applications, the District had not considered the carbon plant when processing permits for the refinery. Therefore, offsets were not required for PM₁₀. In this application, all increases in PM₁₀ at Facility A0016 since April 5, 1991, will require offsets. Following is a list of relevant applications and PM₁₀ increases:

| | |
|-------------------|-------------------|
| Application 5814 | 4.670 tons |
| Application 11293 | 0.300 tons |
| Application 12412 | <u>7.670 tons</u> |
| Total | 12.640 tons |

Also, 0.120 tons of SO₂ associated with Application 11293 will be offset at the refinery. These offsets had previously not been provided.

Following are details of the contemporaneous offsets:

S8, Heater: Shutdown of S8 will provide 16.7 tons NOx/yr, 2.9 tons PM10/yr, 2.1 tons POC/yr, and 43.4 tons CO/yr.

S352-S354, Turbines, and S355-S357, Duct Burners (Steam Power Plant): Permit condition 12122, part 9, currently allows annual NOx emissions from the Steam Power Plant of 167 tons/year. The actual emissions, as shown by CEM data, averaged 101.9 tons per year. The facility has proposed a new annual limit of 79.8 tons per year to provide 22.1 tons/yr of NOx offsets.

S1007, Dissolved Air Flotation Unit: The facility has proposed to control 44.1 tons per year of POC emissions at the DAF unit for the purpose of generating contemporaneous offsets. These emissions do not require a RACT adjustment because they were considered for control during the 2004 revisions of the BAAQMD Regulation 8, Rule 8, Wastewater Collection and Separation Systems, and were not regulated at that time. The facility has concluded that control of 44.1 tons per year is feasible, based on their measurements of flow at the atmospheric vents, the District's analysis of grab samples, and modeling of the wastewater system. Permit conditions will require the facility to demonstrate that they are collecting and oxidizing or abating the entire amount of POC. Otherwise, the facility will have to provide offsets from another source.

Facility A0022, S2, Kiln: This source is at the ConocoPhillips Carbon Plant, which is part of this facility. The kiln is used to drive sulfur from coke that is produced at the refinery. The purified coke is a saleable product. The kiln has an SO2 CEM that measures compliance with the 400 ppm or 250 lb/hr standard in BAAQMD Regulation 9-1-310.2, therefore the facility has good records of the SO2 emissions.

The facility submitted Application 15328 with a proposal for generating contemporaneous SO2 emission reduction credits (ERCs) from the kiln. The 3-year baseline annual average SO2 emissions were determined to be 791.32 tons/yr. The new SO2 limit will be 749.32 tons per year as verified by the SO2 CEM. This will provide 42 tons per year of SO2 ERCs.

In determining creditable ERCs under Section 2-2-605, the proposed additional SO2 reductions from the kiln were not reduced by a RACT-adjustment due to considerations of the cost-effectiveness of further controls required by Section 2-2-243.

A measure of cost effectiveness for new and modified sources is represented by EPA in their recent proposal for 40 CFR 60, Subpart J, Standards of Performance for Refineries. Following are the costs for control of SO2 emissions from various categories that were judged by EPA to be reasonable:

| | | |
|------------------------------|----------|-------------|
| New Fluid Catalytic Crackers | Option 4 | \$1,000/ton |
|------------------------------|----------|-------------|

| | | |
|-----------------------------------|----------|-----------|
| Modified Fluid Catalytic Crackers | Option 4 | 1,400/ton |
| Fluid Cokers | Option 2 | 210/ton |
| Sulfur Recovery Plants | Option 2 | 1,200/ton |
| Process Heaters/Other Combustion | Option 2 | 2,200/ton |

The ConocoPhillips proposal would use the existing sodium bicarbonate system at the Carbon Plant to achieve the proposed SO₂ emission reductions. Since the facility has already installed the system to ensure compliance with the limits in BAAQMD Regulation 9-1-310.2, the additional capital cost of increasing the level of control of SO₂ as proposed would be minimal. The operating costs, including disposal of hazardous waste, have been determined to be \$2700/ton SO₂. This cost of control exceeds all of the cost-effectiveness figures judged by EPA to be reasonable in their recent proposed NSPS.

The District is also aware that the South Coast AQMD has a rule requiring 80% control of SO₂ from coke calciners. This level of control has been achieved by the use of a wet scrubber. ConocoPhillips performed an analysis for a similar coke calciner at their Santa Maria refinery in San Luis Obispo County. The capital costs, operating costs, and \$/ton removed are shown below:

| Process | Capital Cost | Operating Cost | Removal Efficiency | \$/ton removed |
|--------------|--------------|----------------|--------------------|----------------|
| Wet Scrubber | \$8.5 MM | \$6.7 MM/yr | 95% | \$15,000 |
| Dry Scrubber | \$2.3 MM | \$4.5 MM/yr | 90% | \$9,000 |

However, the South Coast is a non-attainment area for SO₂. The South Coast rule represents a higher level of control that is well beyond RACT.

Based on the considerations of cost-effectiveness summarized above, no RACT adjustments were applied in determining creditable SO₂ ERCs from the Carbon Plant kiln control proposal.

For the purposes of cumulative increase and offsets, any increase from cargo carriers that are not motor vehicles are included in the definition of facility in BAAQMD Regulation 2-2-215. In this case, cargo carriers would include marine vessels and locomotives.

It is expected that there will be a decrease in emissions from marine loading because the heavy gas oil that was formerly shipped out in ships and barges will be processed at the facility, but the decrease has not been quantified. The resulting gasoline and diesel may be shipped out via pipeline or ships. ConocoPhillips has no truck rack at the facility to distribute its products.

An increase in the emissions from locomotives due to this project has been included in the emission total.

Following is a summary of all emissions increases, decreases, and offsets required.

| | NOx | SO2 | PM10 | POC | CO |
|---|------------|-------------|-------------|--------------|-------------|
| Increases | | | | | |
| S45, New Unit 246 HGO Feed Heater | 2.3 | 4.7 | 1.9 | 1.5 | 2.8 |
| S434, New Unit 246 Startup/Shutdown | <0.01 | <0.01 | - | 0.03 | 0.02 |
| S1004, New SRU (Unit 235) | 11.2 | 29.7 | 0.59 | 0.4 | 37.9 |
| Tanks 101, 168 & 169 Permit Cond. Change | | | | 8.1 | |
| Existing Tanks | | | | 4.8 | |
| Fugitives | | | | 6.1 | |
| Paved Roads | | | 1.1 | | |
| Locomotive Emissions | 2.2 | 0.2 | 0.08 | 0.1 | 0.3 |
| S1007, Dissolved Air Flotation (DAF) Unit | 0.2 | 1.2 | 0.01 | | 0.2 |
| Hydrogen Plant | 30.9 | 5 | 13.8 | 13.9 | 46.2 |
| Decreases | | | | | |
| S8, Unit 240 Boiler B-1 Reductions | -16.7 | | -2.9 | -2.1 | -43.4 |
| Refinery Steam Power Plant Reductions | -22.1 | | | | |
| S1007, Dissolved Air Flotation (DAF) Unit | | | | -44.1 | |
| A0022, S2, Kiln | | -42 | | | |
| Total decreases | -38.8 | -42 | -2.9 | -46.2 | -43.4 |
| Total | 8.0 | -1.2 | 14.6 | -11.3 | 44.0 |
| Offset of NOx with POC | 0 | -1.2 | 14.6 | 3.3 | 44.02 |
| Previous projects | | | | | |
| Application 5814 | | | 4.67 | | |
| Application 11293 | | 0.12 | 0.3 | | |
| Application 12412 | | | 7.67 | | |
| Emissions requiring offsets | | | 27.23 | | |
| Offsets required (1.0:1.0 ratio) | | | 27.23 | | |

The PM10 offsets will come from the following certificates:

| Certificate Number | Owner of Record | Amount tpy |
|--------------------|-----------------|--------------|
| 920 | ConocoPhillips | 6.650 |
| 979 | Air Liquide | 18.600 |
| 1032 | Air Liquide | <u>4.200</u> |
| Total | | 29.45 |

5. STATEMENT OF COMPLIANCE

BAAQMD Regulation 1, General Provisions

S1004, Sulfur Recovery Unit, will be permitted to emit an average of 200 lb SO₂/day, and therefore will be subject to the continuous emission monitoring requirements in Sections 1-520.4 and 1-522.

S1001-S1003 are smaller SRUs and are not subject to the requirement above because they do not emit more than 100 lb SO₂/day. Compliance has been confirmed by source testing.

S45, Heater, and S1004, Sulfur Recovery Unit, will be subject to flow monitoring and therefore will be subject to the parametric monitoring requirements in Section 1-523.

A47, SCR, abating S45, Heater, will be subject to temperature monitoring and therefore will be subject to the parametric monitoring requirements in Section 1-523.

S49, DAF Thermal Oxidizer, will be subject to temperature monitoring and therefore will be subject to the parametric monitoring requirements in Section 1-523.

BAAQMD Regulation 2, Rule 5, New Source Review Of Toxic Air Contaminants

In accordance with BAAQMD Regulation 2, Rule 5, a health risk screening analysis was prepared by the facility and reviewed by District Staff. The project risk including Facility A0016, ConocoPhillips refinery, meets the requirements as follows:

- Project cancer risk is less than 10.0 in a million;
- Project chronic hazard index is less than 1.0; and
- Project acute hazard index is less than 1.0.

The cancer risk for S2, Heater, at Facility B7459, is greater than 1.0 in a million. Therefore, the source is subject to TBACT in accordance with Section 2-5-301 of the rule. TBACT is the use of extremely clean gaseous fuels. 85% of the fuel that will be burned in the Heater will be PSA gas, which is extremely clean and has very little sulfur.

Also, the risk assessment for S2 is conservative, because it was based on an average heat input rate of 1,100 MMbtu/hr, but the final average heat input rate will be 975 MMbtu/hr, which is 12.8% less.

The maximum chronic hazard index was less than 0.2 for the entire project.

BAAQMD Regulation 6, Particulate Matter and Visible Emissions

The following sources will not be sources of particulate matter because their emissions are routed back to the Claus unit at S1004, Sulfur Recovery Unit:

- S465, Sulfur Pit
- S503, Sulfur Storage Tank
- S504, Sulfur Degassing Unit
- S505, Sulfur Truck Loading Rack

The following sources are the new sources of particulate matter in this application:

- S45, Heater
- S1004, Sulfur Recovery Unit
- A47, SCR abating S45, Heater
- A49, DAF Thermal Oxidizer abating S1007, Dissolved Air Flotation Unit
- A424, Tail Gas Incinerator, abating S1004, Sulfur Recovery Unit

S352-S354, Turbines, are existing sources of particulate matter that are expected to continue to comply with BAAQMD Regulation 6.

S45, Heater, and A47, SCR, are subject to Sections 6-301, 6-305, and 6-310.3. Section 6-301 is a requirement that visible emissions may not exceed 1.0 Ringelmann for more than 3 min/hr. Section 6-305 is a requirement that a unit may not emit visible particles that fall outside of the facility's property. Section 6-310.3 is the grain-loading limit for heat transfer operations of 0.15 gr filterable particulate/dscf @ 6% O₂. (The "gr" used in this section means "grains," which are equal to 1/7000 of a pound.) S45 burns gaseous fuels and is expected to comply with these requirements.

Sources that burn refinery fuel gas and that use ammonia in SCR control systems have special source testing requirements because ammonium sulfate is produced as an artifact of the test in these circumstances. EPA has approved alternate test methods for this situation: Methods 201 and 202 with the back-half ammonium sulfate subtracted. The facility will use these methods to test this heater and SCR.

S1004, Sulfur Recovery Unit, and A424, Tail Gas Incinerator are subject to Sections 6-301, 6-305, 6-310, 6-311, 6-330, and 6-501 of the regulation. Sections 6-301 and 6-305 were described in the paragraph above. Section 6-310 is the general grain-loading limit of 0.15 gr filterable particulate/dscf. Section 6-311 is the process weight limit. Section 6-330 has a limit of 0.08 gr/dscf of SO₃ or H₂SO₄, or both, expressed as 100% H₂SO₄, exceeding 0.08 gr/dscf of exhaust gas volume. "Filterable particulate" means particulate as measured by District Source Test Method ST-15, Particulate.

Based on experience with the 3 existing units, S1004 is expected to comply with Sections 6-301, 6-305, and 6-330. They are not generally sources of visible emissions and testing for the sulfuric acid mist standard in Section 6-330 is feasible and is being performed on an annual basis. It is not feasible to test the existing units for the filterable particulate standards in Sections 6-310 and 6-311 at this time because they do not have the required ports for source testing. The new unit will have the ports and will be tested on an annual basis.

The magnitude of the limit in Section 6-311 is determined by the process weight rate of the unit. Since the capacity of the unit is 200 long tons/day, the maximum process weight is 18,667 lb/hr, and the maximum limit is 18.3 lb filterable particulate/hr. If the process weight is less than 18,667 lb/hr, the limit is pro-rated using the equation in the section.

The facility has estimated that the S1004 will emit about 0.14 lb PM₁₀/hr and about 1.29 lb sulfuric acid mist/hr. The facility has not estimated filterable particulate matter. The tests for sulfuric acid mist on the facility's 3 existing units have results of 0.015 gr/dscf or less. The facility estimates that the flowrate at the incinerator stack will be 2,623 lbmol/hr, excluding water and oxygen. This is equivalent to 996,000 dscf, using the ideal gas law. At this rate, the acid mist emission rate is expected to be approximately 0.009 gr/dscf.

The facility will be required to perform an initial and annual source test to assure compliance with Sections 6-310, 6-311, and 6-330. At this time, the filterable particulate concentration and mass emissions will be determined. They are expected to comply with Sections 6-310 and 6-311, especially because controlled sulfur recovery units generally do not have visible emissions, which are indicators of high particulate emissions.

As described above, S1004, Sulfur Recovery Unit, is expected to comply with all of the Regulation 6 standards.

A49, DAF Thermal Oxidizer, will be a small source of particulate. It is rated for 440,000 btu/hr, which includes approximately 10 lb/hr of organic vapors. The facility has estimated 0.0033 lb PM10/hr, using the factor for natural gas combustion in AP-42. Since this unit will burn natural gas and abate organic compound vapors, the source is expected to easily comply with the Regulation 6 standards, and a source test for particulate matter will not be required.

BAAQMD Regulation 7, Odorous Emissions

The purpose of Regulation 7 is the general control of odorous compounds. Most are discussed generally. A few are mentioned by name. One of these is ammonia.

S45, Heater, and S1004, Sulfur Recovery Unit, are sources of ammonia. Ammonia is used at S45 in the SCR for abatement of NOx. S1004 burns ammonia that is concentrated in the sour gas. Section 7-303 limits the concentration of ammonia from Type A emission points to 5000 ppm. A Type A emission point is defined in BAAQMD Regulation 1-230 as: " An emission point, having sufficiently regular geometry so that both flow volume and contaminant concentrations can be measured and where the nature and extent of air contaminants do not change substantially between a sampling point and the emission point." There is no correction for oxygen concentration. The heater will comply because it has a limit of 10 ppmv ammonia @ 3% oxygen. It is expected that the SRU will comply because tests for ammonia at the other SRUs have measured concentrations less than 10 ppm @ 15% O2 and the facility has proposed a limit at the SRU of 12.5 ppmv @ 7% O2. The concentration of ammonia in the stacks of both sources will be measured by source test after construction.

Hydrogen sulfide is very odorous and is one of the compounds generated by various pieces of equipment in the refinery. Most of the H2S in the refinery is concentrated in sour gas streams that are sent to the sulfur recovery units, where H2S is converted to elemental sulfur. The SRU, S1004, is not expected to be a source of H2S because any residual H2S that exits the SRU and A48, SRU Tail Gas Treatment Unit, should be burned in A424, Tail Gas Incinerator. Nonetheless, the facility has requested a limit of 2.5 ppmv H2S @ 0% O2, which is the same limit placed on S4180, Sulfur Recovery Unit, at the Shell Martinez refinery. Considering the 65-meter stack height of the SRU, H2S emissions at this concentration would not be expected to cause odor complaints. The source is expected to comply with BAAQMD Regulation 7. An initial source test will be required to confirm that the H2S concentration is below 2.5 ppmv @ 0% O2.

S465, Sulfur Pit, will not be a source of H₂S because it will be abated by A1004, Sulfur Recovery Unit.

S504, Sulfur Degassing Unit, will remove H₂S from molten sulfur. The facility estimates that the molten sulfur contains up to 800 ppmv H₂S before degassing. After degassing, the sulfur will contain less than 10 ppmv H₂S. The sulfur degassing unit will be abated by A1004, Sulfur Recovery Unit.

S503, Sulfur Storage Tank, and S505, Sulfur Truck Rack, will handle molten sulfur that contains less than 10 ppmw H₂S. In addition, the tank and truck rack will also be controlled by A1004, Sulfur Recovery Unit.

S1007, DAF, will be less odorous after it is controlled pursuant to this application because it currently emits a small amount of H₂S. It is currently in compliance with the odor regulation.

In addition to the requirements of this rule, BAAQMD Regulation 9, Rule 2; Hydrogen Sulfide, has limits on the ground level concentration for H₂S and requires area monitoring for the refinery.

BAAQMD Regulation 8, Rule 5, Storage of Organic Liquids

The tanks affected by this project are:

S98, Tank 101, EFRT, 170k barrels

S118, Tank No. 163, fixed roof, 5.3k barrels

S122, Tank No. 167, EFRT, 3.1 MMgals

S123, Tank No. 168, EFRT, 75k barrels

S124, Tank No. 169, EFRT, 75k barrels

S128, Tank No. 174, EFRT, 76k barrels

S139, Tank No. 204, fixed roof, 81k barrels, abated by A7, Vapor Recovery System

S140, Tank No. 205, fixed roof, 54k barrels, abated by A7, Vapor Recovery System

S182, Tank No. 294, fixed roof, 40k barrels, abated by A7, Vapor Recovery System

The service for S98, Tank 101, EFRT, 170k barrels, will change from exempt diesel service to petroleum fluids with a vapor pressure up to 10 psia. Section 8-5-301 requires control by an internal floating roof, an external floating roof, or an approved emission control system. The tank has an external floating roof. The tank will be subject to Sections 8-5-111, 8-5-112, 8-5-301, 8-5-304, 8-5-320, 8-5-321, 8-5-322, 8-5-328, 8-5-331, 8-5-332, 8-5-401, and 8-5-501. The tank is expected to comply after retrofits.

FINAL: October 5, 2007

Evaluation Report, Application 13424, ConocoPhillips Refinery, Facility A0016, Rodeo CA

S118 will continue to be exempt from Regulation 8, Rule 5 due to low vapor pressure.

S122, S123, S124, and S128 are already subject to the requirements for external floating roof tanks in Regulation 8, Rule 5.

S139, S140, and S182 are already subject to the requirements for pressure vacuum valves and approved emission control systems in Regulation 8, Rule 5.

None of the tanks except S98 are changing service, although the throughput will change. The tanks are in compliance with the relevant standards and are expected to continue to comply.

BAAQMD Regulation 8, Rule 10, Process Vessel Depressurization

The new Unicracker vessel, S434, and the new SRU, S1004, will be subject to this rule. All of the other process vessels mentioned are already subject. Section 301 of the rule requires that the emissions during depressurizing be controlled by an abatement device or the fuel gas system until the vessel is as close to atmospheric pressure as possible, but at least until the partial pressure of organic compounds in that vessel is less than 4.6 psig.

Section 302 requires that no process vessel may be opened to the atmosphere unless the internal concentration of total organic compounds has been reduced prior to release to atmosphere to less than 10,000 parts per million (ppm), with the following exception: vessels may be opened when the concentration of total organic compounds is 10,000 ppm or greater provided that the total number of such vessels opened with such concentration during any consecutive five year period does not exceed 10% of the total process vessel population, the organic compound emissions from the opening of these vessels does not exceed 15 pounds per day and the vessels are not opened on any day on which the APCO predicts an exceedance of a National Ambient Air Quality Standard for ozone or declares a Spare the Air Day.

The facility is expected to comply with these standards.

BAAQMD Regulation 8, Rule 18, Equipment Leaks

Components such as valves, flanges, pumps, compressors, pressure relief devices, are subject to BAAQMD Regulation 8, Rule 18. The rule has total organic leak limits of 100 ppm for valves and flanges and 500 ppm for pumps, compressors, and pressure relief devices. This is a "work-practice" standard. The facility is obligated to test the components for leaks on a periodic basis and repair the leaks. A small percentage of non-repairable leaks are allowed until the next turnaround or five years, whichever is sooner.

The facility has an inspection program for this regulation and is expected to comply with these standards for the new sources because the components will meet BACT, which was defined in Section 3.4 of this evaluation.

BAAQMD Regulation 8, Rule 28, Episodic Releases from Pressure Relief Devices at Petroleum Refineries and Chemical Plants

BAAQMD Regulation 8, Rule 28 applies to pressure relief devices (PRD) installed on refinery equipment. Section 8-28-302 applies to PRDs on new or modified equipment. It requires that these PRDs comply with all requirements of BAAQMD Regulation 2, Rule 2, including BACT. BACT1 at this time is a rupture disk with a vent to a fuel gas recovery system, furnace, or flare with a recovery/destruction efficiency of 98%. All new PRDs installed pursuant to this project are subject to this standard.

Existing PRDs associated with the following units are also subject to the standard: S307, S308, S318, S432, S434, S1004. These PRDs will be subject to BACT2, which is a vent to a fuel gas recovery system, furnace, or flare with a recovery/destruction efficiency of 98%.

S309 and S339 are not subject to the standard in BAAQMD Regulation 8-28-302 because they are not considered to be modified. Although the units will have a throughput increase and are no longer considered to be "grandfathered" units, no new components will be installed. Since the emissions from these sources are fugitive emissions, if there are no new components, there is no increase in emissions from these sources, the sources are not considered to be modified, and they are not subject to Section 8-28-302. S309 and S339 will continue to comply with Section 8-28-303, Existing Pressure Relief Devices at Petroleum Refineries.

The sulfur pits, S301-S303 and S465 are not subject to Regulation 8, Rule 28, because Section 8-28-101 states that the rule applies to equipment handling gaseous organic compounds at petroleum refineries. The sulfur pits do not handle gaseous organic compounds. However, the SRUs at ConocoPhillips do handle gaseous organic compounds and are subject to the standard.

Permit conditions with the BACT requirement will be added to these units. The facility is expected to comply with this requirement.

BAAQMD Regulation 9, Rule 1, Sulfur Dioxide

S45, Heater, and S1004, SRU, are sources of SO₂. The heater is not subject to the 300-ppm limit in Section 9-1-301 of the rule because the refinery complies with the exemption in Section 9-1-110. The exemption requires ground level monitoring and compliance with the ground level concentration limit.

S1004 is subject to the limit of 250 ppmv SO₂, dry, at zero percent O₂, in Section 9-1-307. The source will be subject to continuous monitoring by BAAQMD Regulations 1-520, 1-522, and 9-1-502, which will ensure compliance.

BAAQMD Regulation 9, Rule 2, Hydrogen Sulfide

The facility is subject to the requirements of this rule. Many pieces of equipment that are being considered in this application can be sources of fugitive hydrogen sulfide: The facility has ground level monitoring of H₂S to ensure compliance with the ground level concentration limits of 0.06 ppm averaged over three consecutive minutes or 0.03 ppm averaged over any 60 consecutive minutes. These requirements have been incorporated into the Title V permit and apply to the facility as a whole. Therefore, the facility complies with the requirement.

Also, see the discussion of H₂S containing sources in the discussion for BAAQMD Regulation 7, Odorous Emissions.

BAAQMD Regulation 9, Rule 3, Nitrogen Oxides from Heat Transfer Operations

S45, Heater, is not subject to the rule because it applies to new heat transfer operations with a maximum heat input greater than 250 MMbtu/hr, per Section 9-3-303.

BAAQMD Regulation 9, Rule 10, Nitrogen Oxides and Carbon Monoxide from Boilers, Steam Generators and Process Heaters in Petroleum Refineries

S45, Heater, is not subject to BAAQMD Regulation 9, Rule 10, because it applies to affected units. Units are defined by Section 9-10-220 as "any petroleum refinery boiler, steam generator, or process heater... having an Authority to Construct or a Permit to Operate prior to January 5, 1994." This heater will be subject to current BACT limits for NO_x and CO, which are more stringent, instead of the Regulation 9, Rule 10, limits.

CEQA

The California Environmental Quality Act (CEQA) calls for a review of potential significant environmental impacts from proposed projects. This project has been

determined to be subject to CEQA by the Contra Costa County Community Development Department (CDD). The CDD is the Lead Agency for CEQA for this project. In accordance with Regulation 2-1-310.3, the District may not issue an Authority to Construct for this project until final action has been taken by the Lead Agency. A draft Environmental Impact Report (EIR) was prepared by the CDD in November 2006. This EIR includes all sources and activities that are the subject of this application. The District is a responsible agency under CEQA and has provided comments to the CDD on the draft EIR. These comments, as well as others received by CDD have been addressed in a revised EIR.

On September 25, 2007, the final EIR was certified by the Contra Costa County Board of Supervisors. The District must act on the application within 30 days of the certification.

As a responsible agency, the District has prepared findings for the purposes of CEQA. They are attached in Appendix G.

Prevention of Significant Deterioration

Emissions increases over 40 tpy NO_x, POC, or SO₂, over 100 tpy CO, and over 15 tpy PM₁₀ are defined as major modifications by BAAQMD Regulation 2-2-221 if they occur at a major facility. BAAQMD Regulation 2-1-204 defines ConocoPhillips as a major facility. Originally, ConocoPhillips estimated that the project would increase PM₁₀ emissions by 16.5 tons per year, 1.5 tons per year over the PSD threshold of 15 tons per year. Therefore, the original project was subject to PSD for PM₁₀ as required by BAAQMD Regulations 2-2-304.2 and 2-2-304.3.

A PSD analysis was submitted by the facility and reviewed by District staff. It was submitted for NO_x as well as PM₁₀. The NO_x emissions are lower than were originally proposed. The results of the analysis indicate that the proposed Clean Fuels Expansion and Hydrogen Plant Project would not interfere with the attainment or maintenance of the applicable Ambient Air Quality Standards for NO_x and PM₁₀ and would not cause an exceedance of any applicable PSD increment. The analysis was based on EPA approved models and calculation procedures and was performed in accordance with BAAQMD Regulation 2-2-414. The report is attached in Appendix C.

The PSD analysis was based on a NO_x emissions increase of 41.4 tons per year and a PM₁₀ emissions increase of 23.8 tons per year.

Pursuant to BAAQMD Regulation 2-2-414.1, the applicant has submitted a modeling analysis that adequately demonstrates the air quality impacts of the CFEP project. The applicant's analysis was based on EPA-approved models and was performed in accordance with District Regulation 2-2-414.

Pursuant to Regulation 2-2-414.2, the District has found that the modeling analysis has demonstrated that the allowable emission increases from the CFEP project, in conjunction with all other applicable emissions, will not cause or contribute to a violation of applicable ambient air quality standards for NO₂ and PM₁₀ or an exceedance of any applicable PSD increment.

Pursuant to Regulation 2-2-417, the applicant has submitted an analysis of the impact of the proposed source and source-related growth on visibility, soils, and vegetation.

Please see Appendix C for further detail of the analysis.

The final proposed emissions of PM₁₀ that is subject to PSD, including contemporaneous offsets, were dropped to 13.8 tons per year for Air Liquide and 0.7 for ConocoPhillips. Therefore, the project is no longer subject to PSD.

BAAQMD Regulation 2-2-306, Non-Criteria Pollutant Analysis, PSD, requires PSD air quality analysis if the daily or annual triggers are exceeded for lead, asbestos, beryllium, mercury, fluorides, sulfuric acid mist, hydrogen sulfide, total reduced sulfur, and/or reduced sulfur compounds. Only the sulfur compounds are expected to be emitted at this project. Following is an accounting of the expected emissions and the triggers:

| POLLUTANT | ANNUAL AVERAGE LIMIT (TON/YR) | EMISSION (TON/YR) | DAILY LIMIT (LB/DAY) | EMISSION (LB/DAY) |
|---|-------------------------------|-------------------|----------------------|-------------------|
| Sulfuric acid mist | 7 | 6.64 | 38 | 36.4 |
| Hydrogen sulfide | 10 | 1.1 | 55 | 5.34 |
| Total reduced sulfur including hydrogen sulfide | 10 | 1.1 | 55 | 5.34 |
| Reduced sulfur compounds including hydrogen sulfide | 10 | 1.1 | 55 | 5.34 |

Air quality analysis has not been performed for these pollutants for this project. Limits have been placed on sulfuric acid mist and hydrogen sulfide emissions, which are calculated at 6.64 and 1.1 tons per year, respectively. A limit has not been placed on total reduced sulfur or total reduced sulfur compounds. Instead, the facility will determine the rate of emissions of total reduced sulfur compounds at the SRU, the largest source of SO₂, SO₃, and sulfuric acid mist, on an annual basis. If the rate exceeds 2.2 lb/hr during the source test, the District will require

PSD modeling or an increase in the SRU incinerator temperature to control total reduced sulfur compounds.

The District does not have general delegation for the PSD program. The delegation was withdrawn on March 3, 2003 because EPA had revised its program. However, EPA has granted PSD delegation for certain projects on a case-by-case basis, because the federal regulations for new sources were not significantly changed, according to EPA Region 9. On January 24, 2006, EPA did delegate this project to the District. A copy of the letter granting delegation is attached in Appendix F.

NSPS, EQUIPMENT LEAKS

The following sources will become subject to NSPS fugitive emission requirements due to this project: S307, S308, S309, S339, S432, S434, and S464. The new standards are 40 CFR 60, Subpart VV, Standards of Performance for Equipment Leaks of VOC in the Synthetic Organic Chemicals Manufacturing Industry, and Subpart GGG, Standards of Performance for Equipment Leaks of VOC in Petroleum Refineries.

NSPS, Subpart J

S45, Heater, S465, Sulfur Pit, and S1004, U235 Sulfur Recovery Unit, will be subject to 40 CFR 60, Subpart J, Standards of Performance for Petroleum Refineries.

S45, Heater, is subject to the H₂S limit for fuel in Section 60.104(a)(1) of 0.10 gr/dscf or approximately 160 ppm. S45 will comply because it will burn either refinery fuel gas that has been processed by the Merichem Unit or natural gas. The outlet of the Merichem Unit is tested for H₂S three times per day by an H₂S analyzer. The Merichem Unit is subject to an alternative monitoring plan in place of the continuous monitoring required by Section 60.105(a)(4).

S465, Sulfur Pit, and S1004, U235 Sulfur Recovery Unit, are subject to the SO₂ limit in Section 60.104(a)(2)(i) of 250 ppm SO₂ at zero percent excess air. Compliance will be assured by the continuous SO₂ monitoring required by Section 60.105(a)(5).

A49, Thermal Oxidizer, is subject to the standard because it will burn fuel gas as defined by the NSPS: "any gas which is generated at a petroleum refinery and which is combusted." ConocoPhillips will be subject to the H₂S standard in Section 60.104(a)(1) and to the continuous monitoring requirement in Section 60.105(a)(5).

EPA intends to propose changes to Subpart J in April 2007, and finalize changes by April 2008. If these changes allow refineries to use periodic monitoring for small sources instead of continuous monitoring, or exempts small sources from the standard or monitoring, the permit condition will allow ConocoPhillips to take advantage of changes in the standard when they are finalized.

NSPS, Subpart GG

S352-S354, Turbines, are subject to 40 CFR 60, Subpart GG, Standards of Performance for Stationary Gas Turbines, because they were built after October 3, 1977. The limit in the standard for NO_x is 110 ppm_{dv} @ 15% O₂, and the limit for SO₂ is 0.8% S in fuel by weight. The sources are in compliance with both limits. The NO_x CEM that is required by BAAQMD Regulation 9, Rule 9, Nitrogen Oxides from Stationary Gas Turbines, ensures compliance with the NO_x limit, and the requirement to perform TRS analysis on the refinery fuel gas three times per day ensures compliance with the sulfur limit.

On July 8, 2004, EPA promulgated changes to the required monitoring for the NSPS. In Section 60.334(c), EPA allowed use of CEMs to determine compliance with the NO_x limit.

NSPS, Subpart K

The current Title V permit states that S139 is exempt from 40 CFR 60, Subpart K, Standards of Performance for Storage Vessels for Volatile Organic Liquid Storage Vessels for Which Construction, Reconstruction, or Modification Commenced After June 11, 1973, and Prior to May 19, 1978, because it does not contain petroleum fluids. For the purposes of this NSPS, distillate oil, which it may contain, is not a petroleum fluid. The tank also handles sour water. An increase in sour water or distillate oil will not cause an increase in emissions and is not considered a modification for the purposes of the NSPS.

NSPS, Subpart Kb

The following tanks are not currently subject to Subpart Kb: S98, S118, S122, S123, S124, S128, S140, and S182.

Although the emissions will increase at S98, S123, and S124 due to changes in the petroleum fluids that they will hold, it is not considered an increase for the purposes of Subpart Kb because EPA has determined in the May 17, 1999 letter from Gerald Potamis of EPA Region 1 to Paul Flaherty of Arthur D. Little (attached in Appendix E) that switching from one petroleum fluid to another is not a modification pursuant to 40 CFR 60.14. Therefore, these tanks will not be subject to Subpart Kb.

Increases in throughput at S118, S122, S128, S140 and S182 are not considered modifications for the purposes of NSPS.

NSPS, Subpart GGG/VV, Standards of Performance for Equipment Leaks of VOC in Petroleum Refineries

S433, U246 High Pressure Reactor Train, will be subject to Subpart GGG/VV. In addition, process streams containing >5% OHAP will be subject to 40 CFR 63 Subpart CC (MACT) requirements for equipment leaks. The components subject to these regulations will be required to be added to the refinery's current LDAR programs, and comply along with other process units at the facility that are already subject to these standards.

S1004, Sulfur Recovery Unit, is not subject to the standard because it is not a process unit as defined by Section 60.591, which states:

"Process unit means components assembled to produce intermediate or final products from petroleum, unfinished petroleum derivatives, or other intermediates; a process unit can operate independently if supplied with sufficient feed or raw materials and sufficient storage facilities for the product.

The sulfur recovery units are not assembled to produce intermediate or final products, and the feed to the sulfur recovery unit is not petroleum, unfinished petroleum derivatives, or an intermediate. It is true that sulfur is produced at the SRUs, but that is the unintended consequence of operating these control devices.

NESHAPS
Subpart CC
Tanks

Tanks S139, S140, and S182 are not subject to Subpart CC because they are routed to the fuel gas recovery system as allowed by Section 63.640(d)(5).

The requirements in Subpart CC for Tanks S118, S122, S123, S124, and S128 will not change.

Tank S98 will be subject to the requirements for Group 1 storage vessels because it is larger than 46,750 gallons (177 cubic meters), the vapor pressure will be greater than 1.5 psia (10.4 kilopascal), and it will be presumed to contain more than 4 percent by weight total organic HAP.

Miscellaneous process vents

The sulfur plant vents at S1004 are not subject to Subpart CC in accordance with Section 60.640(d)(4) and the vents are not considered miscellaneous process vents according to Section 60.641. This includes the vents for the sulfur pits,

FINAL: October 5, 2007

Evaluation Report, Application 13424, ConocoPhillips Refinery, Facility A0016, Rodeo CA

S301-S303, and S465. Also, vents from the control devices for the sulfur plant are not considered miscellaneous process vents.

The deaerator vents at the hydrogen plants are not considered miscellaneous process vents according to Section 60.641.

Relief valve discharges are not considered miscellaneous process vents.

Equipment Leaks

S434, U236 High Pressure Reactor Train, will be a new unit. Section 63.648 subjects new units to Subpart H.

The remaining units are considered existing and subject to 40 CFR 60, Subpart VV.

NESHAPS, Subpart UUU

S1004, U235 Sulfur Recovery Unit, is subject to 40 CFR 63, Subpart UUU. This standard is essentially equivalent to the SO₂ standard in 40 CFR 60, Subpart J. The unit will comply with the SO₂ standard and with the requirement for continuous SO₂ monitoring.

NESHAPS, Subpart DDDDD

S45, Process Heater, is subject to 40 CFR 63, Subpart DDDDD, National Emission Standards for Hazardous Air Pollutants for Industrial, Commercial, and Institutional Boilers and Process Heaters. The DC Circuit Court vacated the standard on June 8, 2007. Where there is no MACT for a new source and the deadline for promulgation of a standard by EPA is past, local agencies must determine case-by-case MACT for the new source, in accordance with 40 CFR 63.52(a). The emission limit for S45 in the standard was 400 ppm CO. There were no other limits for gaseous-fueled boilers. A CO CEM was not required for units under 100 MMbtu/hr.

The reason that the court gave for vacating the MACT was that EPA had inappropriately classified solid waste incineration units that were subject to Section 129 of the Clean Air Act as solid fuel units that were subject to the MACT. This classification greatly increased the number of units subject to the MACT and therefore skewed the determination of the MACT floor. The court stated that the "universe of units ... will be far smaller and more homogenous [sic]" after the solid waste units were taken out of the group of units affected. The court expects that the rule will change substantially when EPA considers the smaller pool of units.

One possible outcome is that the standards may become more stringent because the HAP emissions from the solid waste incineration units are expected to be higher. The MACT "floor" is based on the performance of the top 12 percent of the units in a category.

EPA had determined that CO was an appropriate surrogate for organic HAPs. The argument was that high CO was indicative of poor combustion and therefore, poor destruction of organic HAPs. This is a reasonable assumption.

Following are the CO limits proposed by EPA:

- New, large and limited use solid fuel units: 400 PPM @ 7% O₂
- Small solid fuel units: None
- New, large and limited use liquid fuel units: 400 PPM @ 3% O₂
- Small liquid fuel units: None
- New, large and limited use gaseous fuel units: 400 PPM @ 3% O₂
- Small gaseous fuel units: None
- Existing units: None

Small units are defined as units with a capacity less than 10 MMbtu/hr.

Gaseous-fueled units are not expected to be sources of metallic or inorganic HAP.

The MACT limit for S45, therefore, was 400 PPM @ 3% O₂, which is equivalent to the BAAQMD Regulation 9, Rule 7, Nitrogen Oxides and Carbon Monoxide from Industrial, Institutional, and Commercial Boilers, Steam Generators, and Process Heaters, which was adopted in 1992.

The District does not have the resources to survey all industrial, commercial, and institutional boilers and process heaters in the United States and determine the MACT "floor." However, the District notes that the CO BACT limit in the District's BACT workbook for boilers over 50 MMbtu/hr has been 50 ppmv since 2005. For refinery process heaters over 50 MMbtu/hr, the BACT limit has been 50 ppmv since 1994. The South Coast AQMD has had BACT limits for CO of 50 ppm for boilers since 2000.

On page 1680, column 3, second paragraph, of the MACT proposal published on January 13, 2003, EPA states:

"The approach that we use to calculate the MACT floors for new sources is somewhat different from the approach that we use to calculate the MACT floors for existing sources. While the MACT floors for existing units are intended to reflect the average performance achieved by a representative group of sources, the MACT floors for new units are meant to reflect the emission control that is achieved in practice by the best controlled source. Thus, for existing units, we are concerned about

estimating the central tendency of a set of multiple units, while for new units, we are concerned about estimating the level of control that is representative of that achieved by a single best controlled source."

If we agree with EPA that low CO levels indicate low levels of organic HAPs, then lower CO levels are better than higher CO levels. Considering that the "best controlled sources" have CO levels that are 50 ppm or lower, 400 ppm cannot be considered to be the proper MACT limit for a new gaseous-fueled source. The source is subject to the following BACT CO limits: 10 ppm CO when operating above 30 MMbtu/hr and 28 ppm CO when operating below 30 MMbtu/hr. These levels will be considered to be presumptive MACT levels for this source until EPA re-proposes and re-promulgates MACT. Since it is not expected that EPA will propose limits that are lower than these limits, the source incurs no risk from this determination.

40 CFR 70, Title V

The facility is subject to the Title V program because it is a major facility as defined by BAAQMD Regulation 2-6-206. The date of Initial issuance of the Title V permit was December 1, 2003. The permit has been modified several times after initial issuance.

The changes proposed in this application require a significant revision of the Title V permit because the project contains:

- 2-6-226.2: The incorporation of a change considered a modification under 40 CFR Parts 60 (NSPS) and 63 (MACT)
- 2-6-226.4: The establishment of or change to a permit term or condition allowing a facility to avoid an applicable requirement
- 2-6-226.5: The establishment of or change to a case-by-case determination of any emission limit or other standard
- 2-6-226.6: The establishment of or change to a facility-specific determination for ambient impacts, visibility analysis, or increment analysis on portable sources

The revisions will be proposed in the Title V permit after the District has received public comment on and finalized the conditions.

40 CFR 72-78, ACID RAIN

Electricity will be generated using excess heat at the hydrogen plant. The hydrogen plant will not be subject to 40 CFR 72-78 because it will not sell electricity. The hydrogen plant or ConocoPhillips will consume all electricity that is produced. The standards apply only to "utilities," which are defined in 40 CFR 72.2 as "any person who sells electricity."

The Steam Power Plant at the refinery consists of three 16.6 MW turbines and 3 Heat Recovery Steam Generators with 3 duct burners. There are no steam turbines, so the power plant is a simple cycle power plant. The steam power plant is not subject to Acid Rain because Section 72.6(b)(2) exempts:

"Any unit that commenced commercial operation before November 15, 1990 and that did not, as of November 15, 1990, and does not currently, serve a generator with a nameplate capacity of greater than 25 MWe."

MONITORING ANALYSIS

S45, Heater, 85 MMbtu/hr, has limits on hourly and annual heat input, concentration limits on NO_x, CO, and NH₃, lb/MMbtu limits on POC and PM₁₀, annual mass emission limits on NO_x, CO, POC, PM₁₀, and SO₂, and sulfur and H₂S limits on the fuel. The heater will have a fuel meter to ensure compliance with the heat input limits. Since the heater is abated by an SCR, it will have a NO_x CEM to ensure that the abatement device is in compliance. The refinery fuel gas is supplied from the Merichem unit and will be monitored for H₂S with the alternative monitoring plan approved in Application 11626. In addition, total sulfur will be monitored 3 times/day. The owner/operator will perform a one-time test for compliance with the NO_x, CO, POC, PM₁₀, and ammonia limits. Non-compliance with the POC and PM₁₀ are not expected at this source. The owner/operator will perform tests for CO twice per year. If the source is not in compliance with the CO limit more than once in every 3 year period, the owner/operator will have to install a CO CEM.

Tanks: BAAQMD Regulation 8, Rule 5, requires adequate monitoring. The seals and fittings on external floating roof tanks are now required to be inspected twice per year. Pressure relief devices on tanks must also be inspected twice per year.

S352-S357, Steam Power Plant: The NO_x CEMs on the steam power plant will ensure compliance with the new annual limit.

S1004, U235 Sulfur Recovery Unit (SRU): The SRU will be equipped with SO₂ and CO CEMs to ensure compliance with all SO₂ and CO limits. Initial compliance with the SO₂, NH₃, CO, NO_x, POC, filterable particulate, PM₁₀, sulfuric acid mist, and H₂S limits will be demonstrated by source test. The source test will be used to establish a temperature limit that will ensure that the H₂S concentration after control is less than 2.5 ppm_{dv} @ 0% O₂. An annual source test will be performed to ensure compliance with the limits in BAAQMD Regulation 6, and the NO_x, ammonia, H₂S, and sulfuric acid mist limits.

S1007, Dissolved Air Flotation Unit (DAF): Compliance with the H₂S limit in 40 CFR 60.104(a)(1) will be ensured by continuous monitoring of the H₂S content of the vapors sent to the thermal oxidizer. Initial compliance with the POC

collection and destruction limit will be demonstrated by source test or tests. The source test or tests will be used to establish a temperature limit that will ensure that the destruction efficiency will be maintained.

S465, Sulfur Pit, S503, Sulfur Storage Tank, S504, Sulfur Degassing Unit, and S505, Sulfur Truck Loading Rack will not be monitored because their vents are routed to the sulfur recovery units.

Fugitive emissions: S307, S308, S309, S318, S339, S432, S434: BAAQMD Regulation 8, Rule 18, requires adequate monitoring.

Facility A0022: Source 2, Kiln: The pre-existing SO₂ CEM is adequate and appropriate monitoring for the new SO₂ limit and the pre-existing annual source tests for particulate are adequate and appropriate monitoring for the new PM₁₀ limit.

Overall annual emission limits have been imposed in Condition 22970, parts A.1-A.3, to ensure that the emissions of the project are less than the emissions proposed by the applicant. The reasons that this condition has been imposed is to allow the facility to exceed certain limits during startup and shutdown and still comply with the annual limits. Part A.4 contains the monitoring and reporting for these limits.

6. RECOMMENDATIONS

Issue an authority to construct for the following sources:

- S45, Heater (U246), 85 MMbtu/hr abated by A47, SCR
- S98, Tank 101, EFRT, 170k barrels
- S118, Tank No. 163, fixed roof, 5.3k barrels
- S122, Tank No. 167, EFRT, 3.1 MMgals
- S123, Tank No. 168, EFRT, 75k barrels
- S124, Tank No. 169, EFRT, 75k barrels
- S128, Tank No. 174, EFRT, 76k barrels
- S168, Tank No. 269, fixed roof, 39k barrels, abated by A7, Vapor Recovery System
- S173, Tank No. 280 fixed roof, 134k barrels, abated by A7, Vapor Recovery System
- S174, (Tank No. 281), fixed roof, 134k barrels, abated by A7, Vapor Recovery System
- S465, Sulfur Pit U235 abated by S1004, Sulfur Recovery Unit
- S307, U240 Unicracking Unit (increase of 23,000 bbl/day)
- S308, U244 Reforming Unit (increase of 2,413 bbl/day)
- S309, U248 UNISAR Unit (increase of 7,830 bbl/day)
- S318, U76 Gasoline Blending (increase of 8,300,000 bbl/yr)
- S339, U80 Gasoline/Mid Barrel Blending

FINAL: October 5, 2007

Evaluation Report, Application 13424, ConocoPhillips Refinery, Facility A0016, Rodeo CA

S432, U215 Deisobutanizer (increase of 2,600 bbl/day)
S434, U246 High Pressure Reactor Train (Cracking) (23,000 bbl/day)
S503, Sulfur Storage Tank abated by S1004, Sulfur Recovery Unit
S504, Sulfur Degassing Unit abated by S1004, Sulfur Recovery Unit
S505, Sulfur Truck Loading Rack abated by S1004, Sulfur Recovery Unit
S1004, U235 Sulfur Recovery Unit (200 long tons/day)
S1007, Dissolved Air Flotation Unit (DAF) abated by A49, DAF Thermal Oxidizer
A7, Odor Abatement System
A47, SCR abating S45, Heater
A48, SRU Tail Gas Treatment Unit
A49, DAF Thermal Oxidizer abating S1007, Dissolved Air Flotation
A51, DAF Carbon Bed
A424, Tail Gas Incinerator abating S1004, Sulfur Recovery Unit

Modify BAAQMD conditions as shown below.

Issue a change of conditions for the following sources: S139, Tank No. 204, fixed roof, 81k barrels, abated by A7, Vapor Recovery System
S140, Tank No. 205, fixed roof, 54k barrels, abated by A7, Vapor Recovery System
S464, Hydrogen Plant
S352, Combustion Turbine
S353, Combustion Turbine
S354, Combustion Turbine
S355, Duct Burner
S356, Duct Burner
S357, Duct Burner

Issue a permit to operate for the following sources:

S139, Tank No. 204, fixed roof, 81k barrels, abated by A7, Vapor Recovery System
S140, Tank No. 205, fixed roof, 54k barrels, abated by A7, Vapor Recovery System
S182, Tank No. 294, fixed roof, 40k barrels, abated by A7, Vapor Recovery System
S464, Hydrogen Plant (not new source, was originally permitted as part of S307, U240 Unicracking Unit)

7. PERMIT CONDITIONS

ConocoPhillips will provide 44 tons per year of contemporaneous POC offsets by controlling emissions at S1007, Dissolved Air Flotation Unit (DAF). These emissions are surplus, because they are not otherwise controlled by District regulations or permit, or other federal, State or local requirements.

Part 7 of Condition 1440 was amended after public comment to make clear that control of emissions at S1007 are required when VOC emissions must be reduced to provide offsets for Application 13424.

Using a thermal oxidizer to control the DAF is also expected to reduce odors because the emissions of the DAF contain H₂S. The conditions allow control with carbon when the thermal oxidizer is not working. Because carbon will not control H₂S, a provision has been added requiring control with a thermal oxidizer or other equivalent control of H₂S at least 90% of the time.

The conditions regarding the control of emissions have been reorganized and made clearer.

"BAAQMD Regulation 2, Rule 5" replaces the following basis for permit conditions: "Toxics Risk Management."

CONDITION 1440

CONDITIONS FOR S324, S381, S382, S383, S384, S385, S386, S387, S390, S392, S400, S401 S1007, S1008, S1009

1. S324 API Separator shall be operated such that the liquid in the main separator basin is in full contact with the fixed concrete roof. This condition shall not apply during separator shutdown for maintenance.
[Cumulative Increase]
2. Diversions of refinery wastewater around the Water Effluent Treating Facility to the open Storm Water Basins (S1008, S1009) shall be minimized. These diversions shall not cause a nuisance as defined in District Regulation 7 or Regulation 1-301. [Cumulative Increase]
3. Records shall be maintained of each incident in which refinery wastewater is diverted to the open storm water basins. These records shall include the reason for the diversion, the total quantity of wastewater diverted to the basins, and the approximate hydrocarbon content of the water.
[Cumulative Increase]
4. The following sources shall be vapor-tight as defined in Regulation 8, Rule 8:

- a. Doors, hatches, covers, and other openings on the S324 API Separator, forebay, outlet basin, and channel to the S1007 DAF Unit.
- ~~b. Doors, hatches, covers, and other openings on the S1007 DAF Unit and the S400 Wet and S401 Dry Weather Sumps, except for the vent opening on these units.~~
- c. Any open process vessel, distribution box, tank, or other equipment downstream of the S1007 DAF Unit (S381, S382, S383, S384, S385, S386, S387, S390, S392).

[Cumulative Increase]

- 5. Compliance with the VOC emission criteria of Part 4 shall be determined semi-annually and records kept of each inspection. These records shall be made available to District personnel upon request.

[Cumulative Increase]

- 6. The maximum wastewater throughput at the S324 API Separator and S1007 DAF Unit shall not exceed 7,500 gpm during media filter backwash and 7,000 gpm during all other times for each unit. Any modifications to equipment at this facility that increase the annual average waste water throughput at S324 and S1007 shall first be submitted to the BAAQMD in the form of a permit application.

[Cumulative Increase]

- 7. This part will apply after VOC emissions at S1007 must be reduced to provide offsets for Application 13424 per Condition 22970, Part B. The owner/operator shall ensure that S1007, DAF, is controlled by A49, DAF Thermal Oxidizer or A51, DAF Carbon Bed, at all times of operation of S1007, except for up to 175 hours per any consecutive 12-month period for startup, shutdown, or maintenance. The owner/operator must control with a thermal oxidizer at least 90% of the time on a consecutive 12-month basis, unless owner/operator controls H2S with an equivalent control device as determined by the APCO.

[Offsets, CEQA]

- a. Through source testing as described in Part 7(b) and 7(c), the owner/operator must demonstrate that the total reduction of emissions through use of A49, DAF Thermal Oxidizer and/or A51, DAF Carbon Bed will result in a total reduction of 44 tons POC per year, considering that abatement will not occur with either abatement device up to 175 hours per year. If initial testing does not demonstrate total reduction of 44 tons POC per year, the owner/operator may choose to:
 - i. In the case of A49, DAF Thermal Oxidizer, perform 4 tests in one year and average the results. In this case, the tests will be performed no less than 2 months apart and no more than 4 months apart.

- ii. In the case of A51, DAF Carbon Bed, average the results of one year's worth of monitoring.

If, after further testing, a total of 44 tons worth of POC reduction is not demonstrated, the owner/operator will supply offsets necessary to ensure a total reduction of 44 tons per year POC pursuant to BAAQMD Regulation 2-2-302.

[Offsets, CEQA]

- b. The following conditions apply to operation of A49, DAF Thermal Oxidizer:
 - i. Within 90 days of the startup date of A49, DAF Thermal Oxidizer, the owner/operator shall perform a source test to determine the following:
 1. Mass emissions rate for POC that is collected and sent to A49.
 2. Mass emissions rate for POC after abatement by A49.
 3. Mass emissions rate for H₂S that is collected and sent to A49.
 4. Mass emissions rate for H₂S after abatement by A49.
 5. Mass emissions rate for SO₂

During the source test, the owner/operator shall determine the temperature required to achieve 98.0% destruction by weight of POC or a concentration of 10 ppmv POC at the outlet. The temperature shall become an enforceable limit.

For the purposes of determining the amount of POC controlled, the owner/operator shall use District Method ST-7, Organic Compounds. The owner/operator shall submit the source test results to the District Source Test Manager, the District Permit Evaluation Manager, and the District Director of Compliance and Enforcement no later than 60 days after any source test.

[Offsets, CEQA]

- ii. After the initial source test required in Part 8 of this condition, the minimum temperature determined shall become the minimum temperature limit for A49. A49 shall not be operated below the minimum temperature except during an "Allowable Temperature Excursion" as defined below:
 1. Operation of A49 within 20°F below the minimum temperature
 2. Operation of A49 more than 20°F below the minimum temperature for a period or periods which, when combined are less than or equal to 15 minutes in any hour; or
 3. Operation of A49 more than 20°F below the minimum temperature for a period or periods which when combined are more than 15 minutes in any hour, provided that all three of the following criteria are met:

- a. The excursion does not exceed 50°F below the minimum temperature;
- b. The duration of the excursion does not exceed 24 hours; and
- c. The total number of such excursions does not exceed 12 per calendar year (or any consecutive 12 month period).
Two or more excursions greater than 15 minutes in duration occurring during the same 24-hour period shall be counted as one excursion toward the 12 excursion limit.
For each such excursion, sufficient records shall be kept to demonstrate that they meet the qualifying criteria described above. Records shall include at least the following information:
 1. Temperature controller setpoint;
 2. Starting date and time, and duration of each Allowable Temperature Excursion;
 3. Measured temperature during each allowable Temperature Excursion;
 4. Number of Allowable Temperature Excursions per month, and total number for the current calendar year; and
 5. All strip charts or other temperature records.

[Offsets, CEQA]

- iii. To determine compliance with the temperature limit in Part 9, A49, Thermal Oxidizer shall be equipped with a temperature measuring device capable of continuously measuring and recording the temperature in A49. The temperature device shall be installed and maintained in accordance with the manufacturer's recommendations, shall be ranged appropriately to measure the temperature limit determined, and shall have a minimum accuracy over the range of 1.0 percent of full-scale.

[Offsets, CEQA]

- iv. Unless amendments to 40 CFR 60, Subpart J, remove applicability of the DAF vapors from that subpart, the owner or operator shall:
 1. Ensure that the H₂S content of the gas burned at A49 does not exceed 0.10 gr/dscf. (This condition will be deleted when the citation is added to the Title V Permit)
 2. Install, calibrate, maintain, and operate a District-approved Continuous Emissions Monitoring System and recorder for H₂S in the gas that is sent to A49. The owner/operator is not required to operate the CEMS when A49 is not being operated.

[40 CFR 60, Subpart J]

- v. If 40 CFR 60, Subpart J is amended such that a continuous monitoring system is not required for A49, and the owner/operator does not install a Continuous Emissions Monitoring System, the owner/operator shall perform a source test to determine emissions of SO₂ from A49, DAF Thermal Oxidizer using District Method ST-19A, Sulfur Dioxide, Continuous Sampling. The owner/operator shall submit the source test results to the District Source Test Manager, the District Permit Evaluation Manager and the District Director of Compliance and Enforcement no later than 60 days after any source test.

[Offsets, CEQA]

- vi. If the continuous monitoring data per Part 7.b.iv or the Source Test Data per Part 7.b.v shows that the annual SO₂ emissions are greater than 1.2 tons per year, the owner/operator shall provide additional SO₂ offsets in accordance with BAAQMD Regulation 2-2-303.

[Offsets, CEQA]

- c. The following conditions apply to A51, DAF Carbon Bed

- i. A51 shall consist of two or more activated carbon vessels arranged in series, with at least one carbon vessel in service except for up to 175 hours per any consecutive 12-month period for startup, shutdown, or maintenance.

[Offsets, CEQA]

- ii. Total emission reduction of A51 shall be demonstrated through use of an in-line flowmeter, and the results of monitoring per the conditions below.

[Offsets]

- iii. The owner/operator of A51 shall monitor with a photo-ionization detector (PID), flame-ionization detector (FID), or other method approved in writing by the Air Pollution Control Officer at the following locations:
 1. The stream prior to any carbon vessels
 2. At the inlet to the last carbon vessel in series
 3. At the outlet of the carbon vessel that is last in series prior to venting to atmosphere

[Offsets]

- iv. When using an FID to monitor breakthrough, readings may be taken with or without a carbon filter tip fitted on the FID probe. Concentrations measured with the carbon filter tip in place shall be considered methane for the purpose of these permit conditions.

[Offsets]

- v. All breakthrough monitoring readings shall be recorded in a monitoring log each time they are taken. Readings shall be conducted on a daily basis initially, but after two months of daily collection, the owner/operator may propose for District review, based on actual measurements taken at the site during operation of the source, that the monitoring schedule be changed to weekly based on the demonstrated breakthrough rates of the carbon vessels. If the District Engineering Division does not disapprove of the proposed monitoring changes within 30 days, the owner/operator shall commence weekly monitoring.

[Offsets]

- vi. The owner/operator shall utilize the activated carbon vessels in such a manner to ensure that the outlet stream to atmosphere contains below 10 ppm VOC or 98% reduction of VOC, whichever is greater.

[Offsets]

- vii. The owner/operator of this source shall maintain the following records for each month of operation of A51:
 - 1. The hours and times of operation
 - 2. Each monitor reading or analysis result for the day of operation they are taken.
 - 3. The number of spent carbon beds removed from service.

[Offsets]

- 8. **This part will apply after VOC emissions at S1007 must be reduced to provide offsets for Application 13424 per Condition 22970, Part B.** Any exceedance of any limit in part 7 shall be reported to the Compliance and Enforcement Division within 10 days of discovery of the occurrence. **(This condition will be deleted when the condition is added to the Title V Permit.)** [basis: Offsets; CEQA; 40 CFR 60, Subpart J]
- 9. This part will apply after VOC emissions at S1007 must be reduced to provide offsets for Application 13424 per Condition 22970, Part B. The owner/operator shall seal the DAF outlet channel and downstream sumps by a solid cover with gaskets. Any vents installed on the covered channel shall be routed to the thermal oxidizer or an equivalent control as determined by the APCO. [Offsets, CEQA]

The title of Condition 1694 has been changed to show that the emissions from engines are not included in the SO₂ cap. When this condition was written, the

engines were exempt and the emissions from engines were not considered. Also, the new heater, S45, will not be included in the SO2 cap.

S336 and S337 have been moved from part A.1a to A.1b because they are not grandfathered sources. They were modified in 1999 pursuant to Application 18696 to retrofit the burners for compliance with BAAQMD Regulation 9, Rule 10.

S8 will be removed from part A.1b because it will be removed from service. The SO2 cap in part A.4 will not change because the refinery fuel gas will be burned in other sources.

The overall fuel firing for Sources S2, S3, S4, S5, S7, S9, S10, S11, S12, S13, and S14, Heaters, in part F.1b will be reduced by 115.7 MMbtu/hr when S8 is removed from service, based on the baseline for S8.

CONDITION 1694

CONDITIONS FOR COMBUSTION SOURCES AND SO2 CAP, EXCEPT FOR GAS TURBINES, DUCT BURNERS, ENGINES, AND S45, HEATER (U246 B801/B802)

A. Heater Firing Rate Limits and General Requirements

1a. Each heater listed below shall not exceed the indicated daily firing rate limit (based on higher heating value of fuel), which are considered maximum sustainable firing rates. The indicated hourly firing rate is the daily limit divided by 24 hours and is the basis for permit fees and is the rate listed in the District database.

| <u>District Source Number</u> (MMbtu/hr) | <u>Refinery ID Number</u> | <u>Daily Firing Limit</u> (MMbtu/day) | <u>Hourly Firing Rate</u> |
|---|---------------------------|--|---------------------------|
| S3 | U230/B201 | 1,488 | 62 |
| S7 | U231/B103 | 1,536 | 64 |
| S21 | U244/B507 | 194.4 | 8.1 |
| [Regulation 2-1-234.3] | | | |

1b. Each heater listed below shall not exceed the indicated daily firing rate limit (based on higher heating value of fuel), which are considered maximum sustainable firing rates. The indicated hourly firing rate is the daily limit divided by 24 hours and is the basis for permit fees and is the rate listed in the District database.

| <u>District Hourly Firing Source Number</u> | <u>Refinery ID Number</u> | <u>Daily Firing Limit</u> (MM BTU/day) | <u>Rate</u> (MM BTU/hr) |
|---|---------------------------|---|----------------------------|
|---|---------------------------|---|----------------------------|

| | | | |
|----|-----------|-------|-----|
| S2 | U229/B301 | 528 | 22 |
| S4 | U231/B101 | 2,304 | 96 |
| S5 | U231/B102 | 2,496 | 104 |
| S8 | U240/B1 | 6,144 | 256 |

S8 will be removed from service within 90 days of the date that the NOx offsets pursuant to Application 13424 must be supplied pursuant to BAAQMD Regulation 2-2-410.

| | | | |
|--------------|---------------------|--------|--------|
| S9 | U240/B2 | 1,464 | 61 |
| S10 | U240/B101 | 5,352 | 223 |
| S11 | U240/B201 | 2,592 | 108 |
| S12 | U240/B202 | 1,008 | 42 |
| S13 | U240/B301 | 4,656 | 194 |
| S14 | U240/B401 | 13,344 | 556 |
| S15 thru S19 | U244/B501 thru B505 | 5,754 | 239.75 |
| S20 | U244/B506 | 552 | 23 |
| S22 | U248/B606 | 744 | 31 |
| S29 | U200/B5 | 2,472 | 103 |
| S30 | U200/B101 | 1,200 | 50 |
| S31 | U200/B501 | 480 | 20 |
| S43 | U200/B202 | 5,520 | 230 |
| S44 | U200/B201 | 1,104 | 46 |
| S351 | U267 | 2,280 | 95 |
| S336 | U231/B104 | 2,664 | 111 |
| S337 | U231/B105 | 816 | 34 |
| S371/372 | U228/B520 and B521 | 1,392 | 58 |

[Regulation 2-1-301]

1c. Each heater listed below shall not exceed the indicated daily firing rate limit (based on higher heating value of fuel), which are considered maximum sustainable firing rates. The indicated hourly firing rate is the daily limit divided by 24 hours and is the basis for permit fees and is the rate listed in the District database.

| District Source Number | Refinery ID Number | Daily Firing Limit (MMbtu/day) | Hourly Firing Rate (MMbtu/hr) |
|------------------------|--------------------|--------------------------------|-------------------------------|
| S438 | U110 | 6,000 | 250 |

[Cumulative Increase]

2a. All sources shall use only refinery fuel gas and natural gas as fuel, EXCEPT for S438 which may also use pressure swing adsorption (PSA) off gas as fuel, and EXCEPT for S3 and S7 which may also use naphtha fuel.

[Regulation 9-1-304 (sulfur content), Regulation 2, Rule 1]

[Note: Part 2a will be amended by Application 12931, which will prohibit the use of liquid fuel at S3 and S7 except during periods of natural gas curtailment, test runs, or for operator training.]

- 2b. Sources S3 and S7 are permitted to use naphtha fuel. These sources shall be monitored for visible emissions during tube cleaning. If any visible emissions are detected when the operation commences, corrective action shall be taken within one day, and monitoring shall be performed after the corrective action is taken. If no visible emissions are detected, monitoring shall be performed on an hourly basis. [Regulation 2-6-409.2]
[Note: Part 2b will be amended by Application 12931, which will prohibit the use of liquid fuel at S3 and S7 except during periods of natural gas curtailment, test runs, or for operator training.]
- 2c. Sources S3 and S7 are permitted to use naphtha fuel. These sources shall be monitored for visible emissions before each 1 million gallons of liquid fuel is combusted at each source. If an inspection documents visible emissions, a Method 9 evaluation shall be completed within 3 working days, or during the next scheduled operating period if the specific unit ceases firing on liquid fuel within the 3 working day time frame. [Regulation 2-6-409.2].
[Note: Part 2c will be amended by Application 12931, which will prohibit the use of liquid fuel at S3 and S7 except during periods of natural gas curtailment, test runs, or for operator training.]
- 3a. The refinery fuel gas shall be tested for total reduced sulfur (TRS) concentration by GC analysis at least once per 8 hour shift (3 times per calendar day). At least 90% of these samples shall be taken each calendar month. No readable samples or sample results shall be omitted. TRS shall include hydrogen sulfide, methyl mercaptan, methyl sulfide, dimethyl disulfide. As an alternative to GC TRS analysis, the fuel gas total sulfur content may be measured with a dedicated total sulfur analyzer (Houston Atlas or equivalent), and TRS concentration estimated based on the total sulfur/TRS ratio, with the TRS estimate increased by a 5% margin for conservatism. The total sulfur/TRS ratio shall be determined at least on a monthly basis through GC analyses of total sulfur and TRS values, and the most recent ratio shall be used to estimate TRS concentration.
[SO2 Bubble]
- 3b. The average of the 3 daily refinery fuel gas TRS sample results shall be reported to the District in a table format each calendar month, with a separate entry for each daily average. Sample reports shall be submitted to the District within 30 days of the end of each calendar month. Any omitted sample results shall be explained in this report. [SO2 Bubble]
4. Emissions of SO2 shall not exceed 1,612 lb/day on a monthly average basis from non-cogeneration sources burning fuel gas or liquid fuel. This limit shall not include S45, Heater (U240) and shall not include any engine. [SO2 Bubble]
5. The following records shall be maintained in a District-approved log for at least 5 years and shall be made available to the District upon request:

- a. Daily and monthly records of the type and amount of fuel combusted at each source listed in Part A.1. [Regulation 2, Rule 1]
- b. TRS sample results as required by Part A.3 [SO2 Bubble]
- c. SO2 emissions as required by Part A.4 [SO2 Bubble]
- d. The operator shall keep records of all visible emission monitoring required by Part 2b, shall identify the person performing the monitoring and shall describe all corrective actions taken [Regulation 2-6-409.2]
- e. The operator shall keep records of all visible emission monitoring required by Part 2c, of the results of required visual monitoring and Method 9 evaluations on these sources, shall identify the person performing the monitoring and shall describe all corrective actions taken. [Regulation 2-6-409.2]

F. S2, S3, S4, S5, S7, S8, S9, S10, S11, S12, S13, S14, Heaters
[S8 will be deleted from this part when the source is removed from service pursuant to Application 13424.]

- 1a. Total fuel firing at Unit 240 (S8, S9, S10, S11, S12, S13, S14) shall not exceed 993 MMBtu/hr averaged over any consecutive 12 month period. [Cumulative Increase]
[Part 1a will be effective until S8 is removed from service pursuant to Application 13424.]
- 1b. Total fuel firing at Unit 240 (S9, S10, S11, S12, S13, S14) shall not exceed 877.3 MMBtu/hr (based on higher heating value) averaged over any consecutive 12 month period. [Cumulative Increase]
[Part 1b will be effective after S8 is removed from service pursuant to Application 13424.]
- 2. Total fuel fired at the MP-30 Complex, including Unit 229 (S2), Unit 230 (S3) and Unit 231 (S4, S5, S7) shall not exceed 346.5 MMBtu/hr (based on higher heating value) averaged over any consecutive 12 month period. [Cumulative Increase]
- 3. Monthly records of the fuel fired at sources in Parts 1 and 2 shall be kept in a District-approved log for at least 5 years and shall be made available the District upon request. [Cumulative Increase]

G. Regulation 9-10 Startup / Shutdown Provisions [Basis: 9-10-301]

For determining compliance with Regulation 9-10-301, the contribution of each affected unit that is in a startup or shutdown condition shall be based on the methods described in 9-10-301.1, and the contribution of each affected unit that is in an out of service condition shall be based on the methods described in 9-10-301.2. Low-firing conditions (no higher than 20% of a unit's rated capacity), including refractory dryout periods, shall be considered out of service conditions

subject to the 30-day averaging procedure in Regulation 9-10-301.2, including the 60-day annual limit for this procedure.

1. Heaters S8 (Unit 240, B-1), S14 (Unit 240, B-401) and S44 (Unit 200, B-201) shall be considered to be in normal operation whenever they have detectable fuel flow, and shall be considered to be out of service for the purpose of Regulation 9-10-301 whenever they have undetectable fuel flow. [S8 will be deleted from this part when the source is removed from service pursuant to Application 13424.]

2. For heaters S43 (Unit 200, B-202), S351 (Unit 267, B-601/602) and S371/372 (Unit 228, B-520/521), the durations of startups, shutdowns and refractory dryout periods are defined in Condition 1694, Part D.2 (S43), Part B.2 (S351) and Part C.2 (S371, S372).

3. For heaters S10 (Unit 240, B-101) and S15 through S19 (Unit 244, B-501 through B-505), the duration of startups, shutdowns and low-firing periods are defined as follows:

- a. startup and shutdown periods are not to exceed 24 hours
- b. low-firing periods are not to exceed 72 hours

4. For heater S13 (Unit 240, B-301), the duration of startups, shutdowns and low-firing periods are defined as follows:

- a. startup and shutdown periods are not to exceed 72 hours
- b. low-firing periods are not to exceed 72 hours

5. For heaters with no CEMS:

- S2 (Unit 229, B-301)
- S3 (Unit 230, B-201)
- S4 (Unit 231, B-101)
- S5 (Unit 231, B-102)
- S7 (Unit 231, B-103)
- S9 (Unit 240, B-2)
- S11 (Unit 240, B-201)
- S12 (Unit 240, B-202)
- S20 (Unit 244, B-506)
- S22 (Unit 248, B-606)
- S29 (Unit 200, B-5)
- S30 (Unit 200, B-101)
- S31 (Unit 200, B-501)
- S336 (Unit 231, B-104)
- S337 (Unit 231, B-105)

startups, shutdowns, and out of service conditions shall each not exceed 5 days in succession at each source.

Since ConocoPhillips has stated that the any additional HGO that they receive from their Santa Maria refinery will be transported by pipeline, a condition has been added to limit

receipts of HGO destined for the hydrocracker through the wharf based on the average of the following 3 years: 8/1/02 to 8/1/05. The purpose of the condition is to ensure that emissions from marine vessels do not increase due to the CFEP project, as they have stated. If at a later date, ConocoPhillips wishes to receive more Santa Maria HGO by ship or purchase it from another source and receive it at the wharf, the facility may apply for this change and provide the emissions offsets.

CONDITION 4336

CONDITIONS FOR S425, S426, Marine Loading Berths

1. For each loading event of "regulated organic liquid", A420 shall be operated with a temperature of at least 1300 degrees F during the first 15 minutes of the loading operation. After the initial 15 minutes of loading, the A420 temperature shall be at least 1400 degrees F.
[Cumulative Increase]
2. Instruments shall be installed and maintained to monitor and record the following:
 - a. Static pressure developed in the marine tank vessel
 - b. A420 temperature.
 - c. Hydrocarbons and flow to determine mass emissions or a concentration measurement alone if it is demonstrated to the satisfaction of the APCO that concentration alone allows verification of compliance, or
 - d. Any other device that verifies compliance, with prior approval from the APCO.[Cumulative Increase]
3. A "regulated organic liquid" shall not be loaded from this facility into a marine tank vessel within the District whenever A420 is not fully operational. A420 must be maintained to be leak free, gas tight, and in good working order. For the purposes of this condition, "operational" shall mean the system is achieving the reductions required by Regulation 8, Rule 44; "regulated organic liquids" include gasoline, gasoline blendstocks, aviation gasoline and JP-4 aviation fuel and crude oil.
[Cumulative Increase]
4. A leak test shall be conducted on all vessels loading under positive pressure prior to loading more than 20% of the cargo. The leak test shall include all vessel relief valves, hatch cover, butterworth plates, gauging connections, and any other potential leak points.
[Cumulative Increase]
5. Loading pressure shall not exceed 80% of the lowest relief valve set pressure of the vessel being loaded. [Cumulative Increase]

- 6a. No more than 25,000 barrels per day of gasoline, naphtha and C5/C6 shall be shipped across the wharf on an annual average basis.
[Cumulative Increase]
1. Deleted Application 13690
 - ~~2. When barges are used to lighter crude oil, the volume of oil lightered during any reporting period shall be multiplied by a factor of 0.42 and included in the shipping totals to determine compliance with the throughput limits. The vessel Exxon Galveston is considered a ship for the purposes of this condition.~~
- 6b. The maximum loading rate at any time at both S425 and S426 shall not exceed 20,000 barrels per hour to prevent overloading the A420 oxidizer.
[Cumulative Increase]
- 7a. The owner/operator shall not receive more than 30,000 bbl per day crude oil delivered by tanker or ship on a 12 month rolling average basis.
(Cumulative increase, 2-1-403)
- 7b. The owner/operator shall receive no more than 249,000 barrels per year of gas oil feed at the Marine Terminal (S425, S426) to the U-240 (S305) Prefractionator. [Offsets]
- ~~8. All throughput records required to verify compliance with Parts 6 and 7, including hourly loading rate records (total for S425, S426), monthly crude oil receipt records, and maintenance records required for A420, which are subject to Regulation 8, Rule 44, shall be kept on site for at least 5 years and made available to the District upon request. [Cumulative Increase]~~
- ~~9. The destruction efficiency of the A420 control system shall be at least 98.5% by weight over each loading event for gasoline, gasoline blending stocks, aviation gas, aviation fuel (JP-4 type), and crude oil. [BACT]~~
10. The purpose of part 10 is to implement an alternative monitoring plan to assure compliance with the H₂S limit in 40 CFR 60.104(a)(1) at A420, Thermal Oxidizer. This part will apply whenever A420 is used to comply with BAAQMD Regulation 8, Rule 44, and whenever A420 is used to burn fuel gas as defined by 40 CFR 60.101(d). To ensure that the thermal oxidizer is not used to burn fuel gas that is high in H₂S, the following activities are not allowed at the terminal: ballasting, cleaning, inerting, purging, and gas freeing. The owner/operator shall perform the following monitoring: One detection tube sampling shall be conducted on the vapors collected during the event for each marine vessel tank that is affected. The detector tube ranges shall be 0-10/0-100 ppm (N=10/1) unless the H₂S level is above 100 ppm. If the H₂S level is above 100 ppm, the owner/operator shall use a detection tube with a 0-500 ppm range. The owner/operator shall use ASTM Method 4913-00, Standard Practice for Determining Concentration of Hydrogen Sulfide by Reading Length of

Stain, Visual Chemical Detectors. The owner/operator shall maintain records of the H₂S detection tube test data for five years from the date of the record. In addition, the owner/operator shall monitor at least once every calendar day that the thermal oxidizer is used. Within 8 months of approval of this part pursuant to Application 13691, the owner/operator shall submit the first six months of results of the H₂S analysis to the District's Engineering and Enforcement and Compliance Departments for review. [40 CFR 60.13(i), BAAQMD Regulation 2-6-501]

The purpose of Condition 6671 is to control emissions of POC from the dearator vent of a hydrogen plant that serves S307, Unicracker. Since hydrogen plants are normally permitted separately, a new source designation has been created for the hydrogen plant, and the condition has been assigned to it.

CONDITION 6671

CONDITIONS FOR S464, HYDROGEN PLANT, U-240 PLANT 4

1. The vapor vent on the E-421 condenser (overhead condenser on D-406 condensate stripper in U-240 Unicracker Complex hydrogen plant) shall be vented to the A50 (D-410 Vent Scrubber) condenser whenever the vent operates. [Regulation 8-2-301]
2. A50 shall reduce total organic carbon emissions from the E-421 vent as necessary to a level that complies with Regulation 8-2-301. [Regulation 8-2-301]
3. All blowdown and other liquid effluent from A50 shall be piped to the plant wastewater treatment system. [Cumulative Increase]
4. Whenever the U-240 hydrogen plant operates, normal flow of scrubbing liquid through the E-421 scrubber pumparound pump and normal flow of cooling water through the pumparound cooler shall be verified on a daily basis. [Cumulative Increase]
5. Daily records (on days when the U-240 hydrogen plant operates) of normal scrubbing liquid flow and normal cooling water flow shall be kept in a District-approved log for at least five years and shall be made available to the District upon request. [Cumulative Increase]
6. Effective 1/1/05, an annual source test shall be performed on the vapor vent on the E-421 condenser to verify compliance with Regulation 8-2-301 in accordance with District source test methods or other methods approved in advance by the District. A copy of the test report shall be provided to the District Director of Compliance and Enforcement within 45 days of completion of the test. [Regulation 2-6-409.2]

CONDITION 6725

CONDITIONS FOR S432, DEISOBUTANIZER

1. All new flanges in hydrocarbon service associated with the S432 Deisobutanizer project shall utilize graphitic gaskets. All new valves in hydrocarbon service associated with the project shall be either live-loaded valves, bellows-sealed valves, diaphragm valves, or other District approved equivalent valve designs. [BACT, Cumulative Increase]
2. All new pressure relief valves in hydrocarbon service associated with the S432 project shall be vented to the refinery flare gas recovery system. [BACT, Cumulative Increase]
3. All new pumps and compressors in hydrocarbon service associated with the S432 project shall utilize either a double mechanical shaft seal design with barrier fluid, a magnetically coupled shaft, or other District approved equivalent design. If a barrier fluid is used, either the fluid reservoir shall be vented to a 95% efficient control device, or the barrier fluid shall be operated at a pressure higher than the process stream pressure. [BACT, Cumulative Increase]
4. The owner/operator shall ensure that the throughput of S432 does not exceed 10,200 barrels/day. [Cumulative Increase]
5. All pressure relief devices on the process unit shall be vented to a fuel gas recovery system, furnace, or flare with a recovery/destruction efficiency of 98%. [8-28-302, BACT]

Parts 6, 15, and 9 of Condition 12122 imply the presence of fuel meters for these sources. Part 9d was added to make this clear.

Part 9b of Condition 12122 was amended after public comment to make clear that control of emissions at the turbines and duct burners are required when NOx emissions must be reduced to provide offsets for Application 13424 in accordance with offset condition 22970, part B.

CONDITION 12122

CONDITIONS FOR S352, S353, S354, S355, S356, S357: TURBINES AND DUCT BURNERS

1. The gas turbines (S352, S353 and S354) and the heat recovery steam generator (HRSG) duct burners (S355, S356 and S357) shall be fired on refinery fuel gas or natural gas. [Cumulative Increase]
2. A HRSG duct burner shall be operated only when the associated gas turbine is operated. [Cumulative Increase]

3. The exhaust from S352 and S355 shall be abated at all times by SCR unit A13, except that S352 and S355 may operate without SCR abatement on a temporary basis for periods of planned or emergency maintenance. A District-approved NOx CEM shall monitor and record the S352 and S355 NOx emission rate whenever S352 and S355 operate without abatement. All emission limits applicable to S352 and S355 shall remain in effect whether or not they are operated with SCR abatement.
[BACT, Cumulative Increase]
4. The exhaust from S353 and S356 shall be abated at all times by SCR unit A14, except that S353 and S356 may operate without SCR abatement on a temporary basis for periods of planned or emergency maintenance. A District-approved NOx CEM shall monitor and record the S353 and S356 NOx emission rate whenever S353 and S356 operate without abatement. All emission limits applicable to S353 and S356 shall remain in effect whether or not they are operated with SCR abatement.
[BACT, Cumulative Increase]
5. The exhaust from S354 and S357 shall be abated at all times by SCR unit A15, except that S354 and S357 may operate without SCR abatement on a temporary basis for periods of planned or emergency maintenance. A District-approved NOx CEM shall monitor and record the S354 and S357 NOx emission rate whenever S354 and S357 operate without abatement. All emission limits applicable to S354 and S357 shall remain in effect whether or not they are operated with SCR abatement.
[BACT, Cumulative Increase]
6. Total fuel fired in S355, S356, and S357 shall not exceed 2.42 E 12 btu in any consecutive 365 day period. [Cumulative Increase]
7. CO emissions from each turbine/duct burner set shall not exceed 39 ppmv at 15% oxygen, averaged over any consecutive 30 day period. Emissions during startup periods, which shall not exceed four hours, and shutdown periods, which shall not exceed two hours, may be excluded when averaging emissions. [BACT, Cumulative Increase]
8. POC emissions from each turbine/duct burner set shall not exceed 6 ppmv at 15% oxygen, averaged over any consecutive 30 day period. Emissions during startup periods, which shall not exceed four hours, and shutdown periods, which shall not exceed two hours, may be excluded when averaging emissions. [BACT, Cumulative Increase]
- 9a. The combined NOx emissions from S352, S353, S354, S355, S356 and S357 shall not exceed 66 lb/hr (averaged over any 3 hour period), nor 167 tons in any consecutive 365 day period. NOx emissions from each turbine/duct burner set shall not exceed 528 lb/day. (This condition will be invalid when the NOx emissions at these sources must be reduced to provide offsets for Application 13424.) [BACT, Cumulative Increase]

- 9b. This part will apply after NO_x emissions at S352, S353, S354, S355, S356 and S357 must be reduced to provide offsets for Application 13424 per Condition 22970, Part B. The combined NO_x emissions from S352, S353, S354, S355, S356 and S357 shall not exceed 66 lb/hr (averaged over any 3 hour period), and shall not exceed 79.8 tons in any consecutive 365 day period. NO_x emissions from each turbine/duct burner set shall not exceed 528 lb/day. [BACT, Cumulative Increase]
- 9c. NO_x emissions from S 352, S353, S354, S355, S356 and S357 shall be monitored with a District-approved continuous emission monitor. [BACT, Cumulative Increase]
- 9d. The owner/operator shall use a fuel meter to determine the heat input to each unit. This data shall be used to determine compliance with all throughput limits and the NO_x, CO, and SO₂ mass emission limits. [Cumulative Increase, 2-6-503]
- 10a. The combined CO emissions from S352, S353, S354, S 355, S356 and S357 shall not exceed 200 tons in any consecutive 365 day period. [BACT, Cumulative Increase]
- 10b. CO emissions from S 352, S353, S354, S355, S356 and S357 shall be monitored with a District-approved continuous emission monitor. [BACT, Cumulative Increase]
11. The combined POC emissions S352, S353, S354, S355, S356 and S357 shall not exceed 8.3 lb/hr and shall not exceed 30.5 tons in any consecutive 365 day period. [BACT, Cumulative Increase]
12. The refinery fuel gas shall be tested for total reduced sulfur (TRS) concentration at least once per 8 hour shift (3 times per calendar day). At least 90% of these samples shall be taken each calendar month. No readable samples or sample results shall be omitted. TRS shall include hydrogen sulfide, methyl mercaptan, methyl sulfide, dimethyl disulfide. [Cumulative Increase]
13. The average of the 3 daily refinery fuel gas TRS sample results shall be reported to the District in a table format each calendar month, with a separate entry for each daily average. Sample reports shall be submitted to the District within 30 days of the end of each calendar month. Any omitted sample results shall be explained in this report. [Cumulative Increase]
14. A source test to verify compliance with Parts 8 and 11 shall be performed each calendar year in accordance with District source test methods or other methods approved in advance by the District. A copy of the test report shall

be provided to the District Director of Compliance and Enforcement within 45 days of completion of the test. [Regulation 2-6-409.2]

15. Records shall be maintained to allow verification of compliance with all permit conditions. Records shall be retained for at least five years and shall be made available to the District upon request. [BACT, Cumulative Increase]

CONDITION 13184

For Source S182

1. The POC emissions from the S182 fixed roof storage tank shall be collected and vented at all times to the fuel gas collection system. [Cumulative Increase]

Condition 18629 is a PSD condition that was originally imposed by EPA. It also applies to the turbines. The existence of a fuel meter is implied in parts XI.G.1.b and XI.G.3.a(2).

CONDITION 18629

Conditions for S352, S353, S354, S355, S356, S357

May 30, 1989 PSD Permit Amendments (first issued March 3, 1986)
Permit NSR 4-4-3 SFB 85-03

- I. [Obsolete – Approval to Construct executed in a timely manner]
- II. [Obsolete – Approval to Construct executed in a timely manner]
- III. Facilities Operation

All equipment, facilities and systems installed or used to achieve compliance with the terms and conditions of this Approval to Construct/Modify shall at all times be maintained in good working order and be operated as efficiently as possible so as to minimize air pollutant emissions.

- IV. Malfunction

The Regional Administrator shall be notified by telephone within two working days following any failure of air pollution control equipment, process equipment, or of any process to operate in a normal manner which results in an increase in emissions above any allowable emissions limit stated in Section IX of these conditions. In addition, the Regional Administrator shall be notified in writing within 15 days of any such failure. This notification shall include a description of the malfunctioning equipment or abnormal operation, the date of the initial failure, the period of time over which emissions were increased due to the failure, the cause of the failure,

the estimated resultant emissions in excess of those allowed under Section IX of these conditions, and the methods utilized to restore normal operations. Compliance with this malfunction notification provision shall not excuse or otherwise constitute a defense to any violations of this permit or of any law or regulations that such malfunction may cause.

V. Right to Entry

The Regional Administrator, the head of the State Air Pollution Control Agency, the head of the responsible local air pollution control agency, and/or their authorized representatives, upon presentation of credentials, shall be permitted:

A. to enter upon the premises where the source is located or in which any records are required to be kept under the terms and conditions of this Approval to Construct/Modify; and

B. at reasonable times to have access to and copy any records required to be kept under the terms and conditions of this Approval to Construct/Modify; and

C. to inspect any equipment, operation, or method required in this Approval to Construct/Modify; and

D. to sample emissions from this source.

VI. Transfer of Ownership

In the event of any changes in control or ownership of facilities to be constructed or modified, this Approval to Construct/Modify shall be binding on all subsequent owners and operators. The applicant shall notify the succeeding owner and operator of the existence of this Approval to Construct/Modify and its conditions by letter, a copy of which shall be forwarded to the Regional Administrator and the State and local Air Pollution Control Agency.

VII. Severability

The provisions of this Approval to Construct/Modify are severable, and, if any provisions of this Approval to Construct/Modify are held invalid, the remainder of this Approval to Construct/Modify shall not be affected thereby.

VIII. Other Applicable Regulations

The owner and operator of the proposed project shall construct and operate the proposed stationary source in compliance with all other applicable provisions of Parts 52, 60 and 61 and all other applicable Federal, State and local air quality regulations.

IX. Special Conditions

A. [Obsolete – Approval to Construct executed in a timely manner]

B. Air Pollution Control Equipment

The owner/operator shall install, continuously operate, and maintain the following air pollution controls to minimize emissions. Controls listed shall be fully operational upon startup of the proposed equipment.

1. Each gas turbine shall be equipped with steam injection for the control of NO_x emissions.
2. Each gas turbine shall be equipped with a Selective Catalytic Reduction (SCR) system for the control of NO_x emissions.

D. Operating Limitations

1. The gas turbines and Heat Recovery Steam Generator (HRG) burners shall be fired only on refinery fuel gas and natural gas
2. The firing rate of each gas turbine/HRG burner set shall not exceed 466 MMbtu/hr.
3. The total fuel firing rate of the Steam/Power Plant shall not exceed 1048 MMbtu/hr.
4. The owner/operator shall maintain records of the amount of fuel used in the gas turbines and the HRG Burners, hours of operation, sulfur content of the fuel, and the ratio of steam injected to fuel fired in each gas turbine, in a permanent form suitable for inspection. The record shall be retained for at least two years following the date of record and shall be made available to EPA upon request.

E. Emission Limits for NO_x

On or after the date of startup, the owner/operator shall not discharge from the gas turbine/HRG Burner sets NO_x in excess of the more stringent of 83 lb/hr total or 25 ppmv at 15% O₂ (3-hour average), or 664 lb/day per set. The concentration limit shall not apply for 4 hours during startup or 2 hours during shutdown.

F. Emission Limits for SO₂

On or after the date of startup, the owner/operator shall not discharge from the gas turbine/HRG Burner sets SO₂ in excess of 15.6 lb/hr per set or 44 lb/hr total (3-hour average). Additionally, total SO₂ emissions shall not exceed 34 lb/hr (3 hour average) for more than 36 days per year, and shall not exceed a total of 153 tons per year (365 days)

G. Continuous Emission Monitoring

1. Prior to the date of startup and thereafter, the owner/operator shall install, maintain and operate the following continuous monitoring systems downstream of each of the gas turbine/HRG Burner units:

a. Continuous monitoring systems to measure stack gas NO_x and SO₂ concentrations. The systems shall meet EPA monitoring performance specifications (60.13 and 60, Appendix B, Performance Specifications). Alternatively, the SO₂ continuous monitor may be substituted for by a continuous monitoring system measuring H₂S in the refinery fuel gas system and daily sampling for total sulfur in the fuel gas.

b. A system to calculate the stack gas volumetric flow rates continuously from actual process variables.

2. The owner/operator shall maintain a file of all measurements, including continuous monitoring system performance evaluations, all continuous monitoring system monitoring device calibration checks, adjustments and maintenance performed on these systems or devices, and all other information required by 60 recorded in a permanent form suitable for inspection. The file shall be retained for at least two years following the date of such measurements, maintenance, reports and records.

3. The owner/operator shall submit a written report of SO₂ emission status and all excess emissions to EPA (Attn: A3-3) for every calendar quarter. The report shall include the following:

a. If fuel gas samples are used to determine SO₂ emissions:

(1) The total measured sulfur concentration in each fuel gas sample for the calendar quarter.

(2) The daily average sulfur content in the fuel gas, daily average SO₂ mass emission rate (lb/hr), and total tons per year of SO₂ emitted for the last 365 consecutive days. Total SO₂ emissions exceeding 34 lb/hr must be identified.

b. The magnitude of excess emissions computed in accordance with 60.13(h), any conversion factors used, and the date and time of commencement and completion of each time period of excess emissions.

c. Specific identification of each period of excess emissions that occurs during startups, shutdowns and malfunctions of the cogeneration gas turbine system. The nature and cause of any malfunction (if known) and the corrective action taken or preventative measures adopted shall also be reported.

d. The date and time identifying each period during which the continuous monitoring system was inoperative except for zero and span checks, and the nature of the system repairs or adjustments.

e. When no excess emissions have occurred or the continuous monitoring system has not been inoperative, repaired, or adjusted, such information shall be stated in the report.

f. Excess emissions shall be defined as any three-hour period during which the average emissions of NO_x and/or SO₂ as measured by the continuous monitoring system and/or calculated from the daily average of the total sulfur in the fuel gas, exceeds the NO_x and/or SO₂ maximum emission limits set for each of the pollutants in Conditions IX.E and IX.F. above

g. Excess emissions indicated by the CEM system shall be considered violations of the applicable emission limits for the purpose of this permit.

H. New Source Performance Standards

The proposed cogeneration facility is subject to the Federal regulations entitled Standards of Performance for New Stationary Sources (60). The owner/operator shall meet all applicable requirements of Subparts A and GG of this regulation.

X. Agency Notifications

All correspondence as required by this Approval to Construct/Modify shall be forwarded to:

A. Director, Air Management Division (Attn: A3-3)

EPA Region 9
215 Fremont Street
San Francisco, CA 94105 (415/974-8034)

B. Chief, Stationary Source Division

California Air Resources Board
P O Box 2815
Sacramento, CA 95812

C. Air Pollution Control Officer

Bay Area Air Quality Management District
939 Ellis Street
San Francisco, CA 94109

The throughput limits for S1001-S1003 were established in Application 5814, but were not added to the permit condition.

CONDITION 19278

Conditions for S1001, S1002, S1003

1. Deleted Application 12433
2. Deleted Application 12433
3. An annual District-approved source test shall be performed to verify compliance with the requirements of Regulation 6-330. A copy of the source test results shall be provided to the District Director of Compliance and Enforcement within 45 days of the test.
[Regulation 6-330]
4. The Owner/Operator shall perform a visible emissions check on Sources S1001, S1002, and S1003 on a monthly basis. The visible emissions check shall take place while the equipment is operating and during daylight hours. If any visible emissions are detected, the owner/operator shall have a CARB-certified smoke reader determine compliance with the opacity standard, using EPA Method 9 or the procedures outlined in the CARB manual, "Visible Emissions Evaluation" for six (6) minutes within three (3) days and record the results of the reading. If the reading is in compliance with the Ringelmann 1.0 limit in BAAQMD Regulation 6-301, the reading shall be recorded and the owner/operator shall continue to perform a visible emissions check on a monthly basis. If the reading is not in compliance with the Ringelmann 1.0 limit in BAAQMD Regulation 6-301, the owner/operator shall take corrective action and report the violation in accordance with Standard Condition 1.F of this permit. The certified smoke-reader shall continue to conduct the Method 9 or CARB Visible Emission Evaluation on a daily basis until the daily reading shows compliance with the applicable limit or until the equipment is shut down. Records of visible emissions checks and opacity readings made by a CARB-certified smoke reader shall be kept for a period of at least 5 years from date of entry and shall be made available to District staff upon request.
[Basis: Regulations 6-301, 2-6-501, 2-6-503]
5. The owner/operator shall ensure that the throughput of molten sulfur at S1001, S1002, and S1003 combined does not exceed 98,915 long tons/yr.
[Cumulative Increase]

CONDITION 20773

This condition applies to tanks that are exempt from Regulation 8, Rule 5, Storage of Organic Liquids, due to the exemption in Regulation 8-5-117 for storage of organic liquids with a true vapor pressure of less than or equal to 25.8 mm Hg (0.5 psia).

1. Whenever the type of organic liquid in the tank is changed, the owner/operator shall verify that the true vapor pressure at the storage temperature is less than or equal to 25.8 mm Hg (0.5 psia). The

owner/operator shall use Lab Method 28 from Volume III of the District's Manual of Procedures, Determination of the Vapor Pressure of Organic Liquids from Storage Tanks. For materials listed in Table 1 of Regulation 8 Rule 5, the owner/operator may use Table 1 to determine vapor pressure, rather than Lab Method 28. If the results are above 25.8 mm Hg (0.5 psia), the owner/operator shall report non-compliance in accordance with Standard Condition I.F and shall submit an application to the District for a new permit to operate for the tank as quickly as possible. [Basis: 8-5-117 and 2-6-409.2]

2. The results of the testing shall be maintained in a District-approved log for at least five years from the date of the record, and shall be made available to District staff upon request.

[Basis: 2-6-409.2]

Following is an excerpt of Condition 20989, which contains nominal throughputs for grandfathered sources. Several sources, which will have new limits, will be deleted from this condition. The new limits will appear in new conditions.

The limits for S301-S303, Sulfur Pits, and S1001-S1003, Sulfur Recovery Units, are not grandfathered limits, since these limits were increased in Application 5814. The limits for S301-S303 have been moved to Condition 22964 and the conditions for S1001-S1003 have been moved to Condition 19278.

FACILITY-WIDE REQUIREMENTS CONDITION 20989

A. THROUGHPUT LIMITS

The following limits are imposed through this permit in accordance with Regulation 2-1-234.3. Sources require BOTH hourly/daily and annual throughput limits (except for tanks and similar liquid storage sources, and small manually operated sources such as cold cleaners which require only annual limits). Sources with previously imposed hourly/daily AND annual throughput limits are not listed below; the applicable limits are given in the specific permit conditions listed above in this section of the permit. Also, where hourly/daily capacities are listed in Table II-A, these are considered enforceable limits for sources that have a New Source Review permit. Throughput limits imposed in this section and hourly/daily capacities listed in Table II-A are not federally enforceable for grandfathered sources. Grandfathered sources are indicated with an asterisk in the source number column in the following table. Refer to Title V Standard Condition J for clarification of these limits.

In the absence of specific recordkeeping requirements imposed as permit conditions, monthly throughput records shall be maintained for each source.

| source number | hourly / daily throughput limit | annual throughput limit (any consecutive 12-month period unless otherwise specified) |
|---------------|---------------------------------|--|
| *118 | NA for tank | 15,000 bbl |
| *122 | NA for tank | 4.38 E 6 bbl |
| *128 | NA for tank | 5.1 E 6 bbl |
| *139 | NA for tank | 2.74 E 6 bbl |
| *140 | NA for tank | 2.74 E 6 bbl |
| 304 | Table II-A | 98,915 long ton for S301, S302, S303 |
| 302 | Table II-A | 98,915 long ton for S301, S302, S303 |
| 303 | Table II-A | 98,915 long ton for S301, S302, S303 |
| 307 | Table II-A | 1.533 E 7 bbl |
| *308 | Table II-A | 5.87 E 6 bbl |
| *309 | Table II-A | 6.11 E 6 bbl |
| *318 | Table II-A | 3.3 E 7 bbl |
| *339 | Table II-A | 5.26 E 7 bbl |
| 432 | Table II-A | 2.8 E6 bbl |
| 1001 | Table II-A | 98,915 long ton for S1001, S1002, S1003 |
| 1002 | Table II-A | 98,915 long ton for S1001, S1002, S1003 |
| 1003 | Table II-A | 98,915 long ton for S1001, S1002, S1003 |

In the original proposal, the conditions for new fugitive components were included with the condition for fugitive components for the ULSD project in 2002. A new BACT determination was made after public notice. Condition 21099 will no longer apply to the new components. Condition 23725 replaces this condition for those components.

CONDITION 21099

CONDITIONS FOR ULSD PROJECT FUGITIVE COMPONENTS

1. The owner/operator shall equip all light hydrocarbon control valves installed as part of the USLD Project with live loaded packing systems and polished stems, or equivalent.
[BACT]
2. The owner/operator shall equip all flanges/connectors installed in the light hydrocarbon piping systems as part of the USLD Project with graphitic-based gaskets unless the service requirements prevent this material.
[BACT]

3. The owner/operator shall equip all new hydrocarbon centrifugal compressors installed as part of the USLD Project with "wet" dual mechanical seals with a heavy liquid barrier fluid, or dual dry gas mechanical seals buffered with inert gas. [BACT]
4. The owner/operator shall equip all new light hydrocarbon centrifugal pumps installed as part of the USLD Project with a seal-less design or with dual mechanical seals with a heavy liquid barrier fluid, or equivalent. [BACT]
5. The owner/operator shall integrate all new fugitive equipment installed as part of the USLD Project, in organic service, into the facility fugitive equipment monitoring and repair program. [BACT]
6. The Owner/Operator shall submit a count of installed pumps, compressors, valves, and flanges/connectors every 180 days until completion of the project. For flanges/connectors, the owner/operator shall also provide a count of the number of graphitic-based and non-graphitic gaskets used. The owner/operator has been permitted to install fugitive components (5,410 valves, 2,376 flanges, 3,564 connectors, 26 pumps, 14 compressors) with a total POC emission rate of 8.62 ton/yr. If there is an increase in the total fugitive component emissions, the plant's cumulative emissions for the project shall be adjusted to reflect the difference between emissions based on predicted versus actual component counts. The owner/operator shall provide to the District all additional required offsets at an offset ratio of 1.15:1 no later than 14 days after the submittal of the final POC fugitive equipment count. If the actual component count is less than the predicted, at the completion of the project, the total will be adjusted accordingly and all emission offsets applied by the owner/operator in excess of the actual total fugitive emissions will be credited back to owner/operator prior to issuance of the permits. [BACT, Cumulative Increase; Regulation 2, Rule 5]

An excerpt of Condition 21235 (NOx box condition) is shown below.

CONDITION 21235

REGULATION 9-10 COMPLIANCE

CONDITIONS FOR SOURCES S2, S3, S4, S5, S7, S8, S9, S10, S11, S12, S13, S14, S15, S16, S17, S18, S19, S20, S22, S29, S30, S31, S43, S44, S336, S337, S351, S371, S372

1. The following sources are subject to the refinery-wide NOx emission rate and CO concentration limits in Regulation 9-10: [Regulation 9-10-301 and 305]

| S# | Description | NOx CEM |
|----|--------------------|---------|
| 2 | U229, B-301 Heater | No |
| 3 | U230, B-201 Heater | No |
| 4 | U231, B-101 Heater | No |
| 5 | U231, B-102 Heater | No |
| 7 | U231, B-103 Heater | No |
| 8 | U240, B-1 Boiler | Yes |

S8 will be removed from service within 90 days of the date that the NOx offsets pursuant to Application 13424 must be supplied pursuant to BAAQMD Regulation 2-2-410.

| | | |
|-----|-------------------------------------|-----|
| 9 | U240, B-2 Boiler | No |
| 10 | U240, B-101 Heater | Yes |
| 11 | U240, B-201 Heater | No |
| 12 | U240, B-202 Heater | No |
| 13 | U240, B-301 Heater | Yes |
| 14 | U240, B-401 Heater | Yes |
| 15 | U244, B-501 Heater | Yes |
| 16 | U244, B-502 Heater | Yes |
| 17 | U244, B-503 Heater | Yes |
| 18 | U244, B-504 Heater | Yes |
| 19 | U244, B-505 Heater | Yes |
| 20 | U244, B-506 Heater | No |
| 22 | U248, B-606 Heater | No |
| 29 | U200, B-5 Heater | No |
| 30 | U200, B-101 Heater | No |
| 31 | U200, B-501 Heater | No |
| 43 | U200, B-202 Heater | Yes |
| 44 | U200, B-201 PCT Reboil Furnace | Yes |
| 336 | U231 B-104 Heater | No |
| 337 | U231 B-105 Heater | No |
| 351 | U267 B-601/602 Tower Pre-Heaters | Yes |
| 371 | U228 B-520 (Adsorber Feed) Furnace | Yes |
| 372 | U228 B-521 (Hydrogen Plant) Furnace | Yes |

CONDITION 22478

For Sources S123 (Tank 168), S124 (Tank 169), S186 (Tank 298), and S334 (Tank 107)

1. The owner/operator shall ensure that S123 contains only water and petroleum liquid with a true vapor pressure less than or equal to 3.0 psia. [Cumulative Increase]
2. The owner/operator shall ensure that S124 contains only water and petroleum liquid with a true vapor pressure less than or equal to 11.0 psia [Cumulative Increase]

3. The owner/operator shall ensure that the emissions of S186 do not exceed 2,231 lb VOC in any consecutive 12-month period. S186 shall only contain petroleum liquids. [Cumulative Increase]
4. The owner/operator shall ensure that S334 contains only crude oil or a less volatile petroleum liquid with a true vapor pressure less than or equal to 6.75 psia. [Cumulative Increase]
5. The owner/operator shall ensure that the throughput of petroleum liquids at S123 does not exceed 3,000,000 barrels/yr. [Cumulative Increase]
6. The owner/operator shall ensure that the throughput of petroleum liquids at S124 does not exceed 3,000,000 barrels/yr. [Cumulative Increase]
7. The owner/operator shall ensure that the throughput of crude oil or other petroleum liquids at S334 does not exceed 5,000,000 barrels/yr. [Cumulative Increase]
8. The owner/operator shall equip S123, S124, S186, and S334 with a BAAQMD approved roof with mechanical shoe primary seal and zero gap secondary seal meeting the design criteria of BAAQMD Regulation 8, Rule 5. The owner/operator shall ensure that there are no ungasketed roof penetrations, no slotted pipe guide poles unless equipped with float and wiper seals, and no adjustable roof legs unless fitted with vapor seal boots or equivalent. [BACT, cumulative increase]
9. The owner/operator shall calculate the emissions of S186 on a calendar month basis using the AP-42 equations. The owner/operator shall use actual throughputs, actual vapor pressures, and actual temperature data for each month. The owner/operator shall calculate the emissions for the last 12-month period on a monthly basis. The calculations shall be complete within a calendar month after the end of each monthly period. [Cumulative increase]

Condition 22549 has been amended so that the throughput limit excludes diesel because the diesel flow is an insignificant source of emissions at the tanks. The previous throughput limit of 33 MMbbl for all fluids has been deleted from Condition 20989, part A. The facility applied for this modification in Application 10115. It was not granted at that time because it results in an increase of gasoline flow to the tanks. In this application, the facility is applying for the increase in emissions at the tanks.

CONDITION 22549

Source 318, U76 Gasoline/Mid Barrel Blending Unit

1. The owner/operator shall ensure that the daily throughput of petroleum liquids, excluding diesel, at S318, U76 Gasoline/Mid Barrel Blending Unit, does not exceed 113,150 barrels/day. No daily limit is placed on diesel. [Cumulative Increase]

2. The owner/operator shall ensure that the throughput of petroleum liquids excluding diesel at S318 does not exceed 41,300,000 barrels/yr.
3. The owner/operator shall keep daily records of throughput of all petroleum fluids at S318, U76 Gasoline/Mid Barrel Blending Unit, in a District-approved log. These records shall be kept for at least five years and shall be made available to the District upon request. [Cumulative Increase]
4. All pressure relief devices on the process unit shall be vented to a fuel gas recovery system, furnace, or flare with a recovery/destruction efficiency of 98%. [8-28-302, BACT]

The NO_x and CO limits is BAAQMD Condition 22962, parts 4a, b, and e, have been amended in response to new BACT determinations made at SCAQMD. The NO_x limit has been reduced to 5 ppmv @ 3% O₂, dry, 3-hour limit. The CO limit has been reduced to 10 ppmv @ 3% O₂, dry, 3-hour limit, and 28 ppm @ 3% O₂, 3-hour limit when operating under 30 MMbtu/hr. This heater will be operated as a trim heater for long periods of time. The lower CO limit is not feasible when operating under 30 MMbtu/hr. The hourly mass emissions will not increase. The ammonia limit in part 5 will increase to make it possible to achieve the 5 ppm NO_x limit.

A basis of 40 CFR 63.52(a) has been added to the CO limits in parts 4b and 4e because, as explained in Section 5, Statement of Compliance, S45 is subject to a case-by-case MACT determination as a substitute for the standards in 40 CFR 63, Subpart DDDDD, which has been vacated. Also, part 18, which required compliance with the requirements of Subpart DDDDD, has been deleted.

The asterisk before part 5 is an indication that the condition is not federally enforceable. The reason that it is not federally enforceable is that it was imposed pursuant to BAAQMD Regulation 2, Rule 5, New Source Review for Toxic Air Contaminants, which is not a federally enforceable rule.

Part 9 of BAAQMD Condition 22962 was reorganized after public comment. The wording was also amended to make clear that the facility is not required to submit results of source tests if the District performed the tests.

CONDITION 22962

Source 45, U246 B-801/B-802 Heater

1. The owner/operator of the S45 heater shall fire only refinery fuel gas and/or natural gas at this unit. [BACT, Cumulative Increase]
2. Based on refinery gas HHV, the owner/operator of S45 shall not exceed the following firing rates:
 - a. 85 MMbtu/hr
 - b. 744,600 MMbtu in any consecutive 12-month period. [Cumulative Increase]

3. The owner/operator of S45 shall abate emissions from S45 at the A47 SCR system whenever S45 is operated, except that S45 may operate without SCR abatement on a temporary basis for periods of planned or emergency maintenance. A District-approved NO_x CEM shall monitor and record the S45 NO_x emission rate whenever S45 operates without abatement. All emission limits applicable to S45 shall remain in effect even if it is operated without SCR abatement. [BACT, Cumulative Increase]
4. The owner/operator of S45 shall not exceed the following emission concentrations or rates from S45/A47 except during startups and shutdowns. Startups and shutdowns shall not exceed 48 consecutive hours. The 48 consecutive-hour startup period is in addition to heater dryout/warmup periods, which shall not exceed 24 consecutive hours.
 - a. NO_x: 5 ppmv @ 3% oxygen (3 hr average) [BACT, Cumulative Increase]
 - b. CO: 28 ppmv @ 3% oxygen (3 hr average) when operating under 30 MMbtu/hr [BACT, Cumulative Increase, 40 CFR 63.52(a)]
 - c. POC: 5.5 lb/MM ft³ [Cumulative Increase]
 - d. PM₁₀: 7.6 lb/MM ft³ [BACT, Cumulative Increase]
 - e. CO: 10 ppmv @ 3% oxygen (3 hr average) when operating over 30 MMbtu/hr [BACT, Cumulative Increase, 40 CFR 63.52(a)]

If the heater operates at rates below and above 30 MMbtu/hr in any 3-hour period, the CO limit shall be a weighted average.

5. *The owner/operator of S45 shall not exceed the following emission rate from S45/A47 except during startups and shutdowns. Startups and shutdowns shall not exceed 48 consecutive hours. The 48 consecutive-hour startup period is in addition to heater dryout/warmup periods, which shall not exceed 24 consecutive hours.

Ammonia: 15 ppmv @ 3% oxygen (8 hr average) [Regulation 2, Rule 5]
6. The owner/operator of S45 shall not exceed the following annual emission rates from S45/A47 including startups, shutdowns, and malfunctions.

NO_x: 2.3 tons/yr [BACT, Cumulative Increase]
CO: 2.8 tons/yr [BACT, Cumulative Increase]
POC: 1.5 tons/yr [Cumulative Increase]
PM₁₀: 2.1 tons/yr [BACT, Cumulative Increase]
SO₂: 4.7 tons/yr [BACT, Cumulative Increase]

Year is defined as every consecutive 12-month period. Month is defined as calendar month.
7. The owner/operator shall equip S45 with a District-approved continuous fuel flow monitor and recorder in order to determine fuel consumption. A parametric monitor as defined in Regulation 1-238 is not acceptable. The owner/operator shall keep continuous fuel flow records for at least five years

and shall make these records available to the District upon request.
[Cumulative Increase]

8. The owner/operator shall install, calibrate, maintain, and operate District-approved continuous emission monitors and recorders for NO_x and O₂. The owner/operator shall keep NO_x and O₂ data for at least five years and shall make these records available to the District upon request. [BACT, Cumulative Increase]
9. The owner/operator shall conduct District-approved source tests two times per year to determine compliance with the CO limit. The tests shall be no less than 4 months apart and no more than 8 months apart. The source tests shall be performed on the heater in an as-found condition. CO source tests performed by the District may be substituted for semi-annual CO source tests. If the heater exceeds the limits in parts 4b or 4e more than once in any 3-year period, the owner/operator shall install, calibrate, maintain, and operate a District-approved continuous emission monitor and recorder for CO within the time period specified in the District Manual of Procedures after the second exceedance of the limits in parts 4b or 4e. The owner/operator shall keep CO data for at least five years and shall make these records available to the District upon request.

For tests conducted by the owner/operator, the owner/operator shall conduct the source tests in accordance with Part 17. The owner/operator shall submit the source test results to the Director of Compliance and Enforcement, the Source Test Manager, and the Manager of Permit Evaluation at the District no later than 60 days after the source test.
[BACT, Cumulative Increase]

10. The owner/operator shall use only refinery fuel gas and/or natural gas at S45 that does not exceed 100 ppmv total sulfur, averaged over a calendar month. [BACT, Cumulative Increase]
11. The owner/operator shall test refinery fuel gas prior to combustion at S45 to determine total sulfur concentration by GC analysis or with a total sulfur analyzer (Houston Atlas or equivalent) at least once per 8-hour shift (3 times per calendar day). At least 90% of these samples shall be taken each calendar month. No readable samples or sample results shall be omitted.
[BACT, Cumulative Increase]
12. To demonstrate compliance with Part 10, the owner/operator shall measure and record the daily average sulfur content. The owner/operator shall keep records of sulfur content in fuel gas for at least five years and shall make these records available to the District upon request. [BACT, Cumulative Increase]
13. For the purpose of demonstrating compliance with the H₂S limit in 40 CFR 60.104(a)(1), the owner/operator shall test refinery fuel gas prior to combustion at S45 to determine total H₂S concentration at least once per 8

hour shift (3 times per calendar day). At least 90% of these samples shall be taken each calendar month. No readable samples or sample results shall be omitted. Records of H₂S monitoring shall be kept for at least five years after the date the record was made. The owner/operator shall submit a semi-annual report regarding this monitoring to the District and to EPA. The reporting periods shall start on January 1st and July 1st of each year. The reports shall be submitted by January 31st and July 31st of each year. If the limit has not been exceeded during the reporting period, this information shall be stated in the report. If the limit has been exceeded, the owner/operator shall report the date and time that the exceedance began and the date and time that the exceedance ended. The owner/operator shall estimate and report the excess emissions during the exceedance. [40 CFR 60.13(i)]

14. The owner/operator shall record the duration of all startups, shutdowns, and heater dryout/warmup periods to determine compliance with parts 4 and 5. The owner/operator shall keep the records for at least five years and shall make these records available to the District upon request. [2-6-503]
15. Prior to the commencement of construction, the owner/operator shall submit plans to the District's Source Test Manager to obtain approval of the design and location of the source test ports. The sample ports shall be installed in accordance with Manual of Procedures, Volume 4, Section 1.2.4. (basis: Regulation 1-501)
16. No later than 90 days from the startup of S45, the owner/operator shall conduct District-approved source tests to determine initial compliance with the limits in Part 4 for NO_x, CO, POC, PM₁₀ and ammonia. For PM₁₀, USEPA Methods 201 and 202 with the back-half ammonium sulfate subtracted, shall be used. The owner/operator shall conduct the source tests in accordance with Part 17. The owner/operator shall submit the source test results to the District staff no later than 60 days after the source test. [BACT, Cumulative Increase, Regulation 2, Rule 5]
17. The owner/operator shall comply with all applicable requirements for source tests specified in Volume IV of the District's Manual of Procedures and all applicable testing requirements for continuous emissions monitors as specified in Volume V of the District's Manual of Procedures. The owner/operator shall notify the District's Source Test Manager, in writing, of the source test protocols and projected test dates at least 7 days prior to testing. [BACT, Cumulative Increase, Regulation 2, Rule 5]
18. The owner/operator will ensure that S45, Heater, complies with all applicable provisions of 40 CFR 60, Subpart J. (This part will be deleted when the applicable citations from this standard are incorporated into the Major Facility Review permit.) [40 CFR 60, Subpart J]

CONDITION 22963

For Sources S98 (Tank 101), S118 (Tank 163), S122 (Tank 167), S128 (Tank 174), S139 (Tank 204); S140 (Tank 205)

1. The owner/operator shall ensure that the following tanks contain only petroleum liquids with true vapor pressures less than or equal the vapor pressures below.
 - a. S98 10 psia
 - b. S118 0.5 psia
 - c. S122 11 psia
 - d. S128 4.4 psia[Cumulative Increase]

2. The owner/operator shall ensure that the throughput of petroleum liquids at the following tanks do not exceed the following throughput limits.
 - a. S98 7,446,000 barrels per consecutive 12-month period
 - b. S118 900 barrels per consecutive 12-month period
 - c. S122 2,000,000 barrels per consecutive 12-month period
 - d. S128 5,100,000 per consecutive 12-month period[Cumulative Increase]

3. The owner/operator shall ensure that S139 and S140 are abated by A7, Vapor Recovery System. [8-5-301, 40 CFR 61, Subpart FF]

4. The owner/operator shall equip S98, S122, and S128 with a BAAQMD approved roof with mechanical shoe primary seal and zero gap secondary seal meeting the design criteria of BAAQMD Regulation 8, Rule 5. The owner/operator shall ensure that there are no ungasketed roof penetrations, no slotted pipe guide poles unless equipped with float and wiper seals, and no adjustable roof legs unless fitted with vapor seal boots or equivalent. [BACT, cumulative increase]

The throughput limits for S301, S302, and S303 were established in Application 5814, but were not added to the permit conditions. In the original application, S505, Sulfur Loading Rack, was abated by A424, Tail Gas Incinerator, but the facility has decided to abate it with S1004, Sulfur Recovery Unit.

CONDITION 22964

Sources S301, S302, S303, Sulfur Pits, S465, Sulfur Pit abated by S1004, Sulfur Recovery Unit

1. The owner/operator shall ensure that the throughput of molten sulfur at S301, S302, and S303 combined does not exceed 98,915 long tons per consecutive 12-month period. [Cumulative Increase]

2. The owner/operator shall ensure that the throughput of molten sulfur at S465 does not exceed 73,000 long tons per consecutive 12-month period. [Cumulative Increase]

3. The owner/operator shall ensure that S465, Sulfur Pit, is controlled at all times by S1004, Sulfur Recovery Unit. [Cumulative increase, 40 CFR 60.104(b)]

CONDITION 22965

Source S307, U240 Unicracking Unit

1. The owner/operator shall ensure that the throughput of S307 does not exceed 65,000 barrels/day. [Cumulative Increase]
2. The owner/operator shall keep throughput records for this source on a daily basis. The records shall be kept on site for a period of at least 5 years and shall be made available for inspection by District staff upon request. [Cumulative Increase]
3. All pressure relief devices on the process unit shall be vented to a fuel gas recovery system, furnace, or flare with a recovery/destruction efficiency of 98% by weight. [8-28-302, BACT]

CONDITION 22966

Source S308, U244 Reforming Unit

1. The owner/operator shall ensure that the throughput of S308 does not exceed 18,500 barrels/day.
2. The owner/operator shall keep throughput records for this source on a daily basis. The records shall be kept on site for a period of at least 5 years and shall be made available for inspection by District staff upon request. [Cumulative Increase]
3. All pressure relief devices on the process unit shall be vented to a fuel gas recovery system, furnace, or flare with a recovery/destruction efficiency of 98% by weight. [8-28-302, BACT]

After public comment and at the request of the applicant, the frequency of the recordkeeping requirement in part 2 below was increased to daily.

CONDITION 22967

Source S309, U248 Unisar Unit

1. The owner/operator shall ensure that the throughput of S309 does not exceed 16,740 barrels/day.
2. The owner/operator shall keep throughput records for this source on a daily basis. The records shall be kept on site for a period of at least 5 years and shall be made available for inspection by District staff upon request. [Cumulative Increase]

CONDITION 22968

Source S339, U80 Gasoline/Mid Barrel Blending

1. The owner/operator shall ensure that the throughput of S339 does not exceed 52,600,000 barrels over any rolling 12-month period.
2. The owner/operator shall keep throughput records for this source on a daily basis. The records shall be kept on site for a period of at least 5 years and shall be made available for inspection by District staff upon request.
[Cumulative Increase]

CONDITION 22969

Source S434, U246 High Pressure Reactor Train (Cracking)

1. The owner/operator shall ensure that the throughput of S434 does not exceed 8,395,000 barrels over any rolling 12-month period.
2. The owner/operator shall keep throughput records for this source on a monthly basis. The records shall be kept on site for a period of at least 5 years and shall be made available for inspection by District staff upon request. [Cumulative Increase]
3. All pressure relief devices on the process unit shall be vented to a fuel gas recovery system, furnace, or flare with a recovery/destruction efficiency of 98% by weight. [8-28-302, BACT]

Condition 22970, Part A, has been imposed to ensure that the emissions increase allowed by Application 13424 is no more than the increase for which the facility has applied. The tanks are not included in the conditions because their applicable requirements will adequately limit the emissions. The following process units are not included because they are existing units and any startup, shutdown, upset, maintenance, or malfunction emissions are considered to be included in their current permits: S307, S308, S318, S432. The fugitive emissions from components are considered to be constant and are not included. S434 and S1004 are new and are included. Condition 1440 places sufficient limits on S1007 and so it is not included. Part A states the allowable emissions limits and includes sufficient monitoring and calculations to ensure that the limits are not exceeded.

Also, the calculated emissions for locomotives were not included.

After the public comment period, the following changes were made:

- Part A.4 was reorganized for clarity.
- The offset reporting requirement in Part B was amended to include banked credits.
- The sources of the contemporaneous offsets were added.
- The NO_x limit in part A.2.a was lowered from 14.4 tpy to 13.5 tpy.
- The SO₂ limit in part A.2.b was lowered from 2.7 tpy to 2.5 tpy.
- The PM₁₀ limit in part A.2.c was lowered from 2.7 tpy to 2.5 tpy.
- The CO limit in part A.2.e was lowered from 45.72 tpy to 40.72 tpy.

- The ammonia limit in part A.2.g was raised from 5.5 tpy to 6.35 tpy.
- An annual PM10 limit for sources in Facilities A0016 and B7419 was added to ensure that the CFEP project does not exceed PSD thresholds for PM10.

CONDITION 22970

A. CFEP Project Mass Emission Limits

1. Following are the sources that are subject to Condition 22970, part A:
S45, Heater (U246)
S434, U246 High Pressure Reactor Train (Cracking)
S1004, U235 Sulfur Recovery Unit
2. The owner/operator shall ensure that the annual emissions of the above sources do not exceed the following annual emission limits, including startup, shutdown, malfunction, and upset emissions.
 - a. NOx 13.5 tpy
 - b. SO2 34.4 tpy
 - c. PM10 2.5 tpy
 - d. POC 1.9 tpy
 - e. CO 40.72 tpy
 - f. Sulfuric acid mist 6.01 tpy
 - g. Ammonia 6.35 TPY
3. The owner/operator shall ensure that the daily emissions of the CFEP do not exceed the following daily emission limit, including startup, shutdown, malfunction, and upset emissions.
 - a. Sulfuric acid mist 38 lb/day [PSD]
4. The owner/operator shall determine whether the emissions are below the allowable emissions in Part A.2, as shown below. The owner/operator shall calculate and report the emissions of NOX, SO2, PM10, POC, CO, and sulfuric acid mist on an annual basis in the following manner.
 - a. For Source S45
 - i. Use the mass emissions data generated by the NOx CEM at S45.
 - ii. Use the emissions rates determined by semi-annual source tests for CO at S45.
 - iii. Use the emissions rates determined by initial source test for POC, PM10, ammonia, and sulfuric acid mist at S45.
 - iv. Use the sulfur analysis of fuel required by Condition 22862, part 11 at S45.
 - b. For Source S1004
 - i. Use the mass emissions data generated by the SO2 and CO CEMs at S1004.
 - ii. Use the emissions rates determined by annual source tests for NOx, sulfuric acid mist, and ammonia, at S1004.
 - c. For the refinery flare S296
 - i. Calculate any emissions caused by venting the contents of any part of the sulfur recovery unit including S1004, A48, and A424 to the refinery flare.

- ii. Calculate any emissions caused by venting the contents of any part of S434, to the refinery flare.
 - iii. The owner/operator shall calculate any emissions caused by venting the feed to Facility B7419, sources S1 or S2 to the refinery flare.
5. If the annual emissions, as determined in part 3, are above the allowable emissions in part A.1, the owner/operator shall supply additional offsets, where applicable, and perform additional analysis for PSD, if necessary. The results of the analysis shall be submitted to the Director of Compliance and Enforcement on an annual basis on the anniversary of the startup of S1004 or S434, whichever is earlier.
6. The annual emissions of the following sources shall not exceed 16.3 tons PM10/yr: S45, S434, and S1004 at Facility A0016, and S2 and S3 at Facility B7419. If the emissions exceed 16.3 tons in any consecutive 12-month period, the owners/operators of Facilities A0016 and B7419 shall provide contemporaneous offsets of PM10 that comply with BAAQMD Regulations 2-2-201 and 2-2-605. [1-104, 2-2-304]

B. Contemporaneous Offset Conditions

1. The owner/operator shall submit an offset report to the Director of Compliance and Enforcement and the Manager of Permit Evaluation at the end of every quarter after the initial date of startup of any of the new CFEP sources below. The report shall contain the detail of banked and contemporaneous offsets provided for each source to show compliance with the provision in BAAQMD Regulation 2-2-410 that offsets must commence no later than the initial operation of a new source or within 90 days after initial operation of a modified source. After all of the offsets required are provided, the owner/operator may submit the final report, even if all of the sources in the CFEP project are not built.

New CFEP Sources

Plant B7419, S1, Hydrogen Plant
Plant B7419, S2, Hydrogen Plant Furnace
Plant B7419, S3, Hydrogen Plant Flare
Plant A0016, S45, Heater
Plant A0016, S434, U246 High Pressure Reactor Train
Plant A0016, S1004, U235 Sulfur Recovery Unit

Contemporaneous Offset Sources

Plant A0016, S1007, Dissolved Air Flotation Unit (DAF)
Plant A0016, S8, Unit 240 B-1
Plant A0016, S352 – S357, Steam Power Plant Gas Turbines and HRSGs
Plant A0022, S2, Kiln K-2
[2-1-403, 2-2-410]

The facility has agreed to lower the annual SO₂ emission limit in part 11a to 29.7 tons per year. Compliance will be determined with the SO₂ CEM.

CONDITION 23125

Source S1004, U235 Sulfur Recovery Unit, S503, Sulfur Storage Tank, S504, Sulfur Degassing Unit, S505, Sulfur Truck Loading Rack

For the purposes of this condition, total reduced sulfur shall mean dimethyl disulfide, dimethyl sulfide, hydrogen sulfide, and methyl mercaptan; and reduced sulfur compounds shall mean hydrogen sulfide, carbonyl sulfide, and carbon disulfide.

1. The owner/operator shall ensure that the throughput of molten sulfur at S1004 does not exceed 200 long tons/day. [Cumulative Increase]
2. The owner/operator shall ensure that the throughput of molten sulfur at S503 does not exceed 471 long tons/day. [Cumulative Increase]
3. The owner/operator shall ensure that S1004 is abated at all times of operation by A48, SRU Tail Gas Treatment Unit, and A424, Incinerator. [Cumulative Increase]
4. The owner/operator shall ensure that S503, Sulfur Storage Tank, S504, Sulfur Degassing Unit, and S505, Sulfur Truck Loading Rack, are controlled at all times of operation by the Claus reaction furnace at S1004 or S1003, Sulfur Recovery Units. [Cumulative Increase, 2-1-305]
5. All pressure relief devices on S1004 shall be vented to a fuel gas recovery system, furnace, or flare with a recovery/destruction efficiency of 98%. [8-28-302, BACT]
6. The owner/operator shall ensure that the supplemental fuel used at A424, Tail Gas Incinerator, is PUC quality natural gas. [BACT]
7. The owner/operator shall not exceed the following emission concentrations from S1004/A48/A424:
 - a. SO₂ 50 ppmv @ 0% O₂, 24-hour basis. [BACT]
 - b. CO 75 ppmvd @ 7% O₂, 1-hour basis. [BACT]
 - c. NO_x 42.2 ppmv @ 7% O₂, 1-hour basis. [BACT]
8. The owner/operator shall not exceed the following emission concentrations from S1004/A48/A424:
 - a. NH₃ 12.5 ppmv @ 7% O₂, 24-hour basis [Regulation 2, Rule 5]
 - b. H₂S: 2.5 ppmv @ 0% O₂ [Regulation 2, Rule 5]
9. The owner/operator shall not exceed the following hourly limits from S1004/A48/A424:
 - a. NO_x: 8.0 lb/hr [2-1-305]
 - b. H₂S: 0.23 lb/hr [Regulation 2, Rule 5]
 - c. NH₃: 0.88 lb/hr [Regulation 2, Rule 5]

10. The owner/operator shall ensure that daily emissions, including startups, shutdowns, upsets, and malfunctions, from S1004/A48/A424 do not exceed the following limits:
 - a. Sulfuric acid mist: 31 lb/day [PSD]
 - b. PM10: 3.36 lb/day [2-1-301]

11. The owner/operator shall ensure that that annual emissions, including startups, shutdowns, upsets, and malfunctions, from S1004/A48/A424, do not exceed the following limits per any consecutive 12-month period:
 - a. SO₂: 29.7 tons [BACT, Cumulative Increase]
 - b. NH₃: 3.85 tons [Regulation 2, Rule 5]
 - c. CO: 37.9 tons [BACT, Cumulative Increase]
 - d. NO_x: 11.2 tons [BACT, Cumulative Increase]
 - e. POC: 0.43 tons [Cumulative Increase]
 - f. PM10: 0.59 tons [Cumulative Increase]
 - g. Sulfuric acid mist: 5.65 tons [2-1-301]
 - h. H₂S: 0.975 tons [Regulation 2, Rule 5]
 - i. Total Reduced Sulfur: 10 tons [PSD]
 - j. Reduced Sulfur Compounds 10 tons [PSD]

12. Prior to the commencement of construction, the owner/operator shall submit plans to the District's Source Test Division to obtain approval of the design and location of the source test ports. The sample ports shall be installed in accordance with Manual of Procedures, Volume 4, Section 1.2.4. Ports for particulate testing shall be installed. [basis: Regulation 1-501]

13. No later than 90 days from the startup of S1004, the owner/operator shall conduct District-approved source tests to determine (1) initial compliance with the limits in Parts 7, 8, 9, and 13 for NO_x, CO, POC, PM10, SO₂, sulfuric acid mist, H₂S, ammonia, (2) the BAAQMD Regulation 6 requirements below, and (3) the emission rates in lbs/dry standard cubic foot of NO_x, POC, PM10, sulfuric acid mist, NH₃, H₂S, and reduced sulfur compounds. The owner/operator shall conduct the source tests in accordance with Part 19. The owner/operator shall submit the source test results to the District staff no later than 60 days after the source test. During the source test, the owner/operator shall determine the temperature required to achieve an outlet concentration of 2.5 ppmv H₂S @ 0% O₂, while meeting all other limits. The temperature shall become an enforceable limit.
 - a. BAAQMD Regulation 6-310: 0.15 gr PM/dscf
 - b. BAAQMD Regulation 6-311: PM emissions based on Process Rate Weight
 - c. BAAQMD Regulation 6-330: SO₃ and H₂SO₄ limitIf the rate of reduced sulfur compounds, including H₂S, exceeds 2.2 lb/hr, or if the rate of total reduced sulfur, including H₂S, exceeds 2.2 lb/hr, the District reserves the right to require additional PSD analysis or to impose a higher temperature limit for S424, Incinerator, to control total reduced sulfur and reduced sulfur compounds.
[BACT, Cumulative Increase; Regulation 2, Rule 5; BAAQMD Regulation 6; PSD]

14. After the initial source test required in part 13 of this condition, the owner/operator shall ensure that the minimum temperature shall not be lower than the temperature determined in the initial source test. The temperature limit will be added to this part after the source test is performed. The owner/operator shall submit the source test results to District staff no later than 60 days after any source test. [Offsets]

15. To determine compliance with the temperature limit in part 14, A48, Thermal Oxidizer, shall be equipped with a temperature measuring device capable of continuously measuring and recording the temperature in A48. The owner/operator shall install, and maintain in accordance with manufacturer's recommendations, a temperature measuring device that meets the following criteria: the minimum and maximum measurable temperatures with the device are (TBD) degrees F and (TBD) degrees F, respectively, and the minimum accuracy of the device over this temperature range shall be 1.0 percent of full-scale. [Regulation 1-521]

16. The temperature limit in part 14 shall not apply during an "Allowable Temperature Excursion", provided that the temperature controller setpoint complies with the temperature limit. For the purposes of parts 16 and 17 of this condition, a temperature excursion refers only to temperatures below the limit. An Allowable Temperature Excursion is one of the following:
 - a. A temperature excursion not exceeding 20 degrees F; or
 - b. A temperature excursion for a period or periods which when combined are less than or equal to 15 minutes in any hour; or
 - c. A temperature excursion for a period or periods which when combined are more than 15 minutes in any hour, provided that all three of the following criteria are met.
 - i. the excursion does not exceed 50 degrees F;
 - ii. the duration of the excursion does not exceed 24 hours; and
 - iii. the total number of such excursions does not exceed 12 per calendar year (or any consecutive 12 month period).

Two or more excursions greater than 15 minutes in duration occurring during the same 24-hour period shall be counted as one excursion toward the 12 excursion limit. [Regulation 2-1-403]

17. For each Allowable Temperature Excursion that exceeds 20 degrees F and 15 minutes in duration, the Permit Holder shall keep sufficient records to demonstrate that they meet the qualifying criteria described above. Records shall be retained for a minimum of five years from the date of entry, and shall be made available to the District upon request. Records shall include at least the following information:
 - a. Temperature controller setpoint;
 - b. Starting date and time, and duration of each Allowable Temperature Excursion;
 - c. Measured temperature during each Allowable Temperature Excursion;
 - d. Number of Allowable Temperature Excursions per month, and total number for the current calendar year; and
 - e. All strip charts or other temperature records.[Regulation 2-1-403]

18. For the purposes of parts 16 and 17 of this condition, a temperature excursion refers only to temperatures below the limit. (Basis: Regulation 2-1-403)

19. The owner/operator shall submit protocols for all source test procedures to the District's Source Test Section at least three weeks prior to conducting any tests. The owner/operator shall comply with all applicable testing requirements for continuous emissions monitors as specified in Volume V of the District's Manual of Procedures. The owner/operator shall notify the District's Source Test Section, in writing, of the projected test dates at least 7 days prior to testing.
[BACT, Cumulative Increase; Regulation 2, Rule 5]

20. The owner/operator shall perform an annual District-approved source test to verify compliance with the following requirements. A copy of the source test results shall be provided to the District Director of Compliance and Enforcement within 60 days of the test.
 - a. BAAQMD Regulation 6-310: 0.15 gr PM/dscf
 - b. BAAQMD Regulation 6-311: PM emissions based on Process Rate Weight
 - c. BAAQMD Regulation 6-330: SO₃ and H₂SO₄ limit
 - d. Emission rates in parts 7c, 8a, 8b, 9a, 9b, and 9c of this condition.
 - e. Emission rates of sulfuric acid mist, total reduced sulfur, and reduced sulfur compounds[BACT, Regulation 6, PSD; Regulation 2, Rule 5; Cumulative increase]

21. The owner/operator shall install, calibrate, maintain, and operate a District-approved continuous emission monitor and recorder for exhaust gas flowrate, SO₂ and O₂. The owner/operator shall keep exhaust gas flow, SO₂ and O₂ data for at least five years and shall make these records available to the District upon request. The owner/operator shall measure SO₂ concentration and mass emissions on a clock-hour basis. The monitors shall comply the requirements of 40 CFR 60.105, 40 CFR 63.1572, and the District's Manual of Procedures, Volume 5. [BACT, Cumulative Increase, 40 CFR 63.1568(a)(1)(i)]
22. The owner/operator shall install, calibrate, maintain, and operate a District-approved continuous emission monitor and recorder for exhaust gas flow and CO. The owner/operator shall keep flow and CO data for at least five years and shall make these records available to the District upon request. The owner/operator shall measure CO concentration and mass emissions on a clock-hour basis. The monitors shall comply the requirements of the District's Manual of Procedures, Volume 5. [BACT, Cumulative Increase]
23. The owner/operator will ensure that S1004, SRU, complies with all applicable provisions of 40 CFR 60, Subpart J, and 40 CFR 63, Subpart UUU. This provision will be deleted when the applicable citations from these standards are incorporated into the Major Facility Review permit. [40 CFR 60, Subpart J; 40 CFR 63, Subpart UUU]
24. The owner/operator shall keep throughput records for sources S1004 and S503 on a daily basis. The records shall be kept on site for a period of at least 5 years and shall be made available for inspection by District staff upon request. [Cumulative Increase]
25. The owner/operator shall use the source tests required in parts 13 and 20 to determine compliance with the daily limit in part 10 and the annual limits in parts 11b, 11d, 11e, 11f, 11h, and 11i. At the end of every month, the owner/operator shall summarize the exhaust gas flow in dry standard cubic feet for the month and shall calculate the estimated emissions of each pollutant for the previous consecutive 12-month period and for H₂S for each day of the month using the emission rate determined in the last source test. The summaries and calculations shall be completed within 60 days of the end of each month. Alternately, the owner/operator may establish a daily and monthly exhaust gas flow level after each source test that will ensure compliance with the daily and annual limits. In this case, the owner/operator will log the daily and monthly exhaust gas flows from S1004/A48/A424. [Cumulative increase; Regulation 2, Rule 5; Cumulative Increase, PSD]
26. The Owner/Operator shall perform a visible emissions check on Source S1004 on a monthly basis. The visible emissions check shall take place while the equipment is operating and during daylight hours. If any visible emissions are detected, the owner/operator shall have a CARB-certified smoke reader determine compliance with the opacity standard, using EPA

Method 9 or the procedures outlined in the CARB manual, "Visible Emissions Evaluation" for six (6) minutes within three (3) days and record the results of the reading. If the reading is in compliance with the Ringelmann 1.0 limit in BAAQMD Regulation 6-301, the reading shall be recorded and the owner/operator shall continue to perform a visible emissions check on a monthly basis. If the reading is not in compliance with the Ringelmann 1.0 limit in BAAQMD Regulation 6-301, the owner/operator shall take corrective action and report the violation in accordance with Standard Condition 1.F of the Title V permit. The certified smoke-reader shall continue to conduct the Method 9 or CARB Visible Emission Evaluation on a daily basis until the daily reading shows compliance with the applicable limit or until the equipment is shut down. Records of visible emissions checks and opacity readings made by a CARB-certified smoke reader shall be kept for a period of at least 5 years from date of entry and shall be made available to District staff upon request. [Basis: Regulations 6-301, 2-1-403]

Members of the public commented on odors originating at the ConocoPhillips refinery. In response to those comments, the CEQA documents state that a fourth odor abatement compressor will be installed. To ensure that A7, Odor Abatement System, is properly operated, and that the new compressor is installed, the District has imposed the following permit condition. The condition requires pressure monitoring at the tanks that are controlled by the odor abatement system so that the tanks operate below the set pressure of the pressure/vacuum valves that can relieve to atmosphere.

CONDITION 23724

For Sources S135 (Tank 200), S137 (Tank 202), S139 (Tank 204), S140 (Tank 205), S158 (Tank 258), S168 (Tank 269), S173 (Tank 280), S174 (Tank 281), S175 (Tank 284), S182 (Tank 294), S360 (Tank 223), S445 (Tank 271), S449 (Tank 285), Tank 235, and Tank 236.

- 1a. The owner/operator shall ensure that all sources subject to this permit condition are abated by A7, Vapor Recovery System except for S168, S173, S174, which shall be abated prior to startup of S434. [Basis: Regulation 2-1-403]
- 1b. The owner/operator shall ensure that a fourth compressor is added to A7, Odor Abatement System, before the following sources are controlled by A7: S168, S173, S174. [Basis: Regulation 2-1-301, 2-1-305, 2-1-403, CEQA]
- 1c. The new odor abatement compressor, or a dedicated compressor, shall be designed and installed to supplement G-503, Flare Gas Recovery Compressor. [CEQA]

- ~~2. The owner/operator shall ensure that all tanks subject to this permit condition are blanketed by utility-grade natural gas. [Basis: Regulation 2-1-403]~~
- ~~3. Within 21 months of issuance of the Authority to Construct, the owner/operator shall equip all tanks subject to this permit condition with District-approved pressure monitoring devices. Within 3 months of issuance of the Authority to Construct, the owner/operator shall equip the following tanks with District-approved pressure monitoring devices: S139, S140, S182, S360, S445, and S449. [Basis: Regulation 2-1-403]~~
- ~~4. After the pressure monitoring devices are installed, the owner/operator shall ensure that tanks listed below operate at all times below their respective minimum set pressures, as shown in 4a and 4b of this condition. Any recorded pressure in excess of the minimum pressure shall be reported to the District's Enforcement and Engineering Divisions within 10 days of the pressure excess. The owner/operator must conduct an investigation of the incident to determine if the pressure excess resulted in the pressure/vacuum (PV) valve lifting to atmosphere and if so, why there was a pressure excess that resulted in the PV valve lifting to atmosphere. Results of the investigation must be reported to the District's Enforcement and Engineering Division within 30 days of the initial report. Any recorded pressure in excess of the minimum set pressure shall be considered an indication of a valve lift to atmosphere unless a District approved tell-tale indicator on the PV valve shows that the valve did not lift, or the owner/operator demonstrates to the satisfaction of the APCO that the recorded pressure excess was the result of a monitoring, recording or other malfunction.~~

~~The minimum set pressure for each storage tank must be submitted in a report to the District's Enforcement and Engineering Divisions within 21 months of issuance of the Authority to Construct and within 3 months of issuance of the Authority to Construct for the following tanks: S139, S140, S182, S360, S445, S449.~~

| a. | Source Number | Minimum Set Pressure (inches H₂O) |
|---------------|--------------------------|---|
| | 135 | TBD |
| | 137 | TBD |
| | 139 | TBD |
| | 140 | TBD |
| | 168 | TBD |
| | 182 | TBD |
| | 360 | TBD |
| | 445 | TBD |
| | 449 | TBD |

~~The owner/operator shall submit an accelerated permit application to include any change to any of the pressures above. Any amendment to the Title V permit to~~

include the pressures above shall be submitted as a minor revision to the Title V permit.

[Basis: Regulation 8, Rule 5]

| <u>b. Source Number</u> | <u>Minimum Set Pressure (inches H2O)</u> |
|-------------------------|--|
| 158 | TBD |
| 173 | TBD |
| 174 | TBD |
| 175 | TBD |
| Tank 235 | TBD |
| Tank 236 | TBD |

The owner/operator shall submit an accelerated permit application to include any change to any of the pressures above. Any amendment to the Title V permit to include the pressures above shall be submitted as a minor revision to the Title V permit.

[Basis: Regulation 2-1-403]

~~5. The owner/operator shall ensure that each pressure relief valve for each tank must be set at or above its nominal set pressure listed in Part 4 of this permit condition. [Basis: Regulation 2-1-403]~~

6. Corrective Plan

The corrective plan is a means for ConocoPhillips to correct occasional exceedances, to stay within the working pressure limits and thus to remain in compliance with District Regulations. If a PV valve has been determined to have lifted three times in a 12 month period, ConocoPhillips shall implement abatement measures to prevent the recurrence of the type of incident which caused the valve to lift. This plan is intended to provide a mechanism for bringing ConocoPhillips back into compliance should a temporary exceedance occur. This plan does not constitute an alternative means of compliance. [Basis: Regulation 2-1-403]

a. If, during any consecutive 12-month period, more than three instances of a PV valve release to atmosphere attributed to a storage tank subject to this permit condition are reported, ConocoPhillips shall propose a method to correct the exceedance and to ensure compliance with District regulations and permit conditions. The proposed method is subject to approval by the Air Pollution Control Officer. Potential methods include but are not limited to increasing the nominal set pressure of the pressure/vacuum valve, bladder tank(s) for additional short-term vapor storage capacity, dedicated vapor recovery flare, pilot control on pressure relief valves, flow meters on vapor recovery tanks to monitor blanket gas flows, replacement of tanks, and naphtha degassers. [Basis: Regulation 2-1-403]

7. To determine compliance with the above conditions, the owner/operator shall maintain the following records and provide all of

the data necessary to evaluate compliance with the above parts, including, but not necessarily limited to the following information:

- a. Pressure measurements from tanks listed in part 4 of this condition. Pressure shall be recorded at least for one-minute interval for each tank.

All records shall be retained on site for five years, from the date of entry and made available for inspection by the District staff upon request. These recordkeeping requirements shall not replace the recordkeeping requirements contained in any applicable District regulation. [Basis: Regulation 2-1-403]

8. The requirement to report pressures in excess of the minimum pressure as described in part 4 of this permit condition, shall start after 21 months of issuance of the Authority to Construct and 3 months after issuance of the Authority to Construct for the following tanks: S139, S140, S182, S360, S445, S449. [Basis: 2-1-403]
9. The permit to operate is contingent upon compliance with Regulation 1-301, Standard for Public Nuisance, and Regulation 7, Odorous Substances. Upon receipt of a violation for either of these regulations, the Air Pollution Control Officer may require the owner/operator to install additional emission control measures as stated in Part 6 of this permit condition. [Basis: Regulations 1-301, 7-301, 7-302]

Condition 23725 replaces Condition 21099 for fugitive components because the BACT determination has been updated. The leak standard is explicit in addition to the required technology. A requirement for leak detection for pumps in heavy liquid service has been added. An annual limit of 6.1 tons per year of POC, which is equivalent to the calculated emissions assuming a leak rate of 100 ppm, has been added. This annual rate is 0.2 tons per year less than rate that was in the final application.

The facility estimates that there will be up to 100 valves in high pressure high temperature gaseous service that will not be any of the types listed in part 1a of the condition because the valves are not available for this service. The District expects the facility to demonstrate that the leak rates of the valves that are installed are equivalent to the valves specified before installation. A manufacturers guarantee may be used to demonstrate equivalency.

CONDITION 23725

CONDITIONS FOR CLEAN FUELS EXPANSION PROJECT (CFEP) FUGITIVE COMPONENTS

1. Fugitive Equipment

- a. The owner/operator shall as part of the CFEP install only the following types of valves in light hydrocarbon service where the hydrocarbon has an initial boiling point less than or equal to 302 degree F: (1) bellows sealed, (2) live loaded, (3) graphite packed, (4) quarter-turn (e.g., ball valves or plug valves), or equivalent as determined by the APCO. [Basis: BACT]
- b. The owner/operator shall comply with a leak standard of 100 ppm of TOC (measured as C1) at any valve installed as part of the CFEP in hydrocarbon service. The owner/operator shall not be considered in violation of the leak standard if the owner/operator complies with the applicable minimization and repair provisions contained in Regulation 8, Rule 18. Valves that are not of a type listed in part 1 (a) and for which a leak greater than 100 ppm (measured as C1) has been determined, shall become subject to the inspection provisions contained in Regulation 8-18. If the leak remains greater than 100 ppm (measured as C1) after repair, or if the valve is determined to have a leak greater than 100 ppm (measured as C1) a second time within a 5-year period, the owner/operator shall replace the valve with a type listed in part 1 (a) within 5 years or at the next scheduled turnaround, whichever is sooner. [Basis: BACT, Regulation 8, Rule 18]
- c. The owner/operator shall install graphitic-based gaskets on all flanges or connectors (gasketed) installed as part of the CFEP in light hydrocarbon service unless the owner/operator demonstrates to the satisfaction of the APCO that the service requirements prevent this gasket material from being used. [Basis: BACT]
- d. The owner/operator shall install double mechanical seals with barrier fluid; or gas seal system vented to a thermal oxidizer or other District approved equivalent control device or technology as determined by the APCO on all compressors installed as part of the CFEP. [Basis: BACT]
- e. The owner/operator shall comply with a leak standard of 100 ppm of TOC (measured as C1) at any pumps and/or compressors installed as part of the CFEP in hydrocarbon service. The owner/operator shall not be considered in violation of the leak standard if the owner/operator complies with the applicable minimization and repair provisions contained in Regulation 8-18. All pumps and/or compressors subject to the leak standard of 100 ppm TOC shall be included in the total number of pumps and compressors used in Regulation 8-18-306.2 to determine the total number of non-repairable pumps and compressors allowed. [Basis: BACT]

- f. The owner/operator shall install double mechanical seals with barrier fluid; dual nitrogen gas purge seals; magnetically coupled pumps; canned pumps; magnetic fluid sealing technology; gas seal system vented to thermal oxidizer, or other BAAQMD approved equivalent control device; or District approved control technology as determined by the APCO on all pumps installed as part of the CFEP in light hydrocarbon service where the hydrocarbon has an initial boiling point less than or equal to 302 degree F. The owner/operator shall install double mechanical seals or District approved equivalent technology on all pumps in heavy hydrocarbon service where the hydrocarbon has an initial boiling point greater than 302 degree F and flash point less than 250 degree F. [Basis: BACT]
 - g. Unless the equipment exclusively handles material(s) with a flash point greater than or equal to 250 degree F, the owner/operator shall identify all new pumps and compressors installed as part of the CFEP in hydrocarbon service with a unique permanent identification code and shall include all new and replaced fugitive equipment in the Regulation 8, Rule 18 fugitive equipment monitoring and repair program. The owner/operator shall monitor all repaired equipment within 24 hours of the repair. [Basis: Cumulative Increase, BACT]
2. The Owner/Operator shall submit a count of installed pumps, compressors, valves, pressure relief devices, and flanges/connectors every 180 days after startup of the first unit until completion of the CFEP project. The owner/operator has been permitted to install the following number of fugitive components for the Clean Fuels Expansion Project:
- Pumps: 16 [As identified in part 1 (g)]
 - Compressors: 3
 - Valves: 1,730
 - Connectors (No Flanges): 1,961
 - Flanges: 3,450
 - Pressure Relief Devices: 118 non-atmospheric

~~The owner/operator shall not exceed 6.1 tons per year of POC emissions measured as C1 from the total fugitive component count installed in TOC services as part of the CFEP. Compliance with this provision shall be verified quarterly using methods described in Part 3. The results shall be submitted to the District on a quarterly basis for two years commencing with start-up. Documentation of results shall be kept on-site for five years.~~

~~If there is an increase in the total fugitive component counts, the plant's cumulative emissions for the project shall be adjusted, subject to APCO approval, to reflect the difference between emissions based on predicted component~~

~~counts versus actual component counts. The owner/operator may have enough remaining contemporaneous emissions reduction credits (ERCs) to cover any increase in POC fugitive emissions beyond the original projection. If not, the owner/operator shall provide to the District all additional required offsets at an offset ratio of 1.15:1 no later than 21 days after the submittal of the final POC fugitive equipment count. If the actual component count is less than the predicted count, at the completion of the project, the total will be adjusted accordingly. Any ERCs applied by the facility in excess of the actual total fugitive emissions estimate based on actual counts as opposed to estimated will be credited back to the owner/operator. [Basis: Cumulative Increase, Offsets, Regulation 2, Rule 5]~~

3. ~~_____ The owner/operator shall calculate fugitive emissions from CFEP fugitive components utilizing District approved methods. [Basis: Cumulative Increase, BACT, Offsets]~~

4. ~~_____ Inspections~~

a. ~~_____ The owner/operator shall conduct inspections of CFEP fugitive components in light hydrocarbon service with an initial boiling point less than or equal to 302 degree F in accordance with the frequency listed below:~~

~~Pumps: _____ Quarterly~~

~~Compressors: Quarterly~~

~~Valves: _____ Quarterly~~

~~Connectors (Not Flanges): _____ Annual~~

~~Flanges: _____ Annual~~

~~[Basis: BACT, Regulation 8, Rule 18]~~

b. ~~The owner/operator shall conduct quarterly inspections of all CFEP pumps in hydrocarbon service with a flash point less than 250 degree F. [Basis: BACT]~~

By: _____ October 5, 2007

FINAL: October 5, 2007

Evaluation Report, Application 13424, ConocoPhillips Refinery, Facility A0016, Rodeo CA

Brenda Cabral
Supervising Air Quality Engineer

Date

FINAL: October 5, 2007

Evaluation Report, Application 13424, ConocoPhillips Refinery, Facility A0016, Rodeo CA

APPENDIX A

Emission Calculations

S45, Heater (U246), 85 MMbtu/hr

ConocoPhillips proposed the following BACT levels for the new heater:

| Pollutant | BACT | Emission Factors (lb/MMbtu) |
|-----------|--|-----------------------------|
| NOx | 7 ppmvd @3% O2 | 0.0086 |
| CO | 28 ppmvd @3% O2 | 0.0210 |
| SO2 | Use of natural gas and/or RFG; 100 ppmv total sulfur in RFG | 0.0126 |
| POC | Use of natural gas and/or RFG; 5.5 lb/MMcf | 0.0041 |
| PM10 | Use of natural gas and/or RFG; 7.6 lb/MMcf | 0.0057 |

Hourly mass emission rates for the process heater were determined by multiplying the “pounds per MMBtu” emission factor by the rated maximum heat input of the heater.

Daily and annual mass emissions were calculated based on 24-hour-per-day and 365-day per-year operation, respectively. Daily and annual process heater emission rates for the new Heater, S45, were shown below.

| | lb/hr | lb/day | ton/yr |
|-----------------|-------|--------|--------|
| NOx | 0.73 | 18 | 3.2 |
| SO ₂ | 1.07 | 26 | 4.7 |
| PM10 | 0.48 | 12 | 2.1 |
| POC | 0.35 | 8.4 | 1.5 |
| CO | 1.79 | 43 | 7.8 |

After public notice, the District determined that lower concentrations of NOx and CO were achieved in practice by heaters burning refinery fuel in the SCAQMD. The lower levels were 5 ppmv NOx @ 3% O2, dry, and 10 ppmv CO @ 3% O2, dry. As explained in Section 3 of this evaluation, the heater will operate at low levels for much of the time, where the 10 ppm CO limit is not achievable. The facility has proposed, and the District has concurred with, a limit of 28 ppm CO below 30 MMbtu/hr. Therefore, the hourly mass emission rate for CO will remain approximately the same at high and low levels of operation. The lower NOx limit is achievable at high and low levels of operation.

Following are the amended emission factors:

| Pollutant | BACT | Emission Factors (lb/MMbtu) |
|-----------|--|-----------------------------|
| NOx | 5 ppmvd @3% O2 | 0.0061 |
| CO | 10 ppmvd @3% O2 | 0.0075 |
| SO2 | Use of natural gas and/or RFG; 100 ppmv total sulfur in RFG | 0.0126 |
| POC | Use of natural gas and/or RFG 5.5 lb/MMcf | 0.0041 |
| PM10 | Use of natural gas and/or RFG 7.6 lb/MMcf | 0.0057 |

Following are the amended hourly, daily, and annual mass emission rates:

| | lb/hr | lb/day | ton/yr |
|-----------------|-------|--------|--------|
| NOx | 0.52 | 12.4 | 2.3 |
| SO ₂ | 1.07 | 26 | 4.7 |
| PM10 | 0.48 | 12 | 2.1 |
| POC | 0.35 | 8.4 | 1.5 |
| CO | 0.64 | 15.3 | 2.8 |

The estimated emissions of toxic air contaminants are shown below. Emission factors from WSPA/API's [Air Toxic Emission Factors for Combustion Sources Using Petroleum-Based Fuels](#), final report, Volume 2, Appendix B, April 14, 1998 have been used for the calculations, except that the ammonia emission rate is based on the 15 ppmv limit.

| Pollutant | Emissions lb/yr | Emissions lb/hr |
|----------------------|--------------------|--------------------|
| Acenaphthene | 1.76E-03 | 2.01E-07 |
| Acenaphthylene | 1.15E-03 | 1.32E-07 |
| Acetaldehyde | 1.14E+01 | 4.75E-01 |
| Ammonia | 5.96+03 | 5.79-01 |
| Antimony | 3.85E-01 | 4.39E-05 |
| Arsenic | 6.33E-01 | 7.23E-05 |
| Benzene | 4.82E+01 | 5.50E-03 |
| Benzo(a)anthracene | 2.39E-02 | 2.73E-06 |
| Benzo(a)pyrene | 6.67E-02 | 7.62E-06 |
| Benzo(b)fluoranthene | 3.01E-02 | 3.43E-06 |
| Benzo(k)fluoranthene | 1.79E-02 | 2.05E-06 |
| Cadmium | 7.36E-01 | 8.40E-05 |
| Chromium (Total) | 7.97E-01 | 9.10E-05 |

FINAL: October 5, 2007

Evaluation Report, Application 13424, ConocoPhillips Refinery, Facility A0016, Rodeo CA

| Pollutant | Emissions lb/yr | Emissions lb/hr |
|------------------------|--------------------|--------------------|
| Chrysene | 1.21E-03 | 1.39E-07 |
| Copper | 3.13E+00 | 3.58E-04 |
| Ethylbenzene | 2.25E+01 | 2.57E-03 |
| Fluoranthene | 2.28E-03 | 2.60E-07 |
| Fluorene | 8.04E-03 | 9.18E-07 |
| Formaldehyde | 8.27E+01 | 9.44E-03 |
| Indeno(1,2,3-cd)pyrene | 7.67E-02 | 8.76E-06 |
| Lead | 3.64E+00 | 4.16E-04 |
| Manganese | 5.07E+00 | 5.79E-04 |
| Mercury | 1.34E-01 | 1.53E-05 |
| Naphthalene | 2.33E-01 | 2.66E-05 |
| Nickel | 7.01E+00 | 8.01E-04 |
| Phenanthrene | 1.09E-02 | 1.24E-06 |
| Phenol | 4.19E+00 | 4.79E-04 |
| Propylene | 1.62E+00 | 1.84E-04 |
| Pyrene | 1.85E-03 | 2.11E-07 |
| Selenium | 1.46E-02 | 1.67E-06 |
| Silver | 1.20E+00 | 1.37E-04 |
| Toluene | 7.97E+01 | 9.10E-03 |
| Xylene (Total) | 2.78E+01 | 3.17E-03 |
| Zinc | 1.55E+01 | 1.77E-03 |

Tanks
 S98, S122, S123, S124, S128, Tanks, EFRT
 S118, Tank No. 163, fixed roof, 5.3k barrels
 S139, S140, and S182, Fixed Roof Tanks, abated by A7, Vapor recovery System

Tanks S139, S140, and S182 are abated by vapor recovery and will not have an increase in emissions.

The emissions from S98, S123, and S124, which will have a change in service, are shown below.

Emission Increase from S98, S123, and S124

| Tank Emissions | | | | | | |
|------------------------------------|-----------|---------|----------------|---------|----------------|---------|
| Tank Number | S98 | | S123 | | S124 | |
| Material | Gasoline | | Gasoline (MUK) | | Gasoline (LUK) | |
| Throughput (bbl) | 7,446,000 | | 3,000,000 | | 3,000,000 | |
| Total POC Emissions (lb/yr) | 12,373 | | 993 | | 2,826 | |
| Toxic Emission | (lb/hr) | (lb/yr) | (lb/hr) | (lb/yr) | (lb/hr) | (lb/yr) |
| Benzene | 4.58E-03 | 40.08 | 3.17E-04 | 2.78 | 2.28E-03 | 20 |
| Cyclohexane | 6.73E-03 | 58.96 | 4.37E-04 | 3.83 | 1.04E-03 | 9.1 |
| Ethylbenzene | 7.63E-04 | 6.68 | 5.38E-04 | 4.71 | 2.20E-06 | 0.019 |
| Hexane | 2.75E-02 | 240.47 | 7.25E-04 | 6.36 | 5.28E-03 | 46 |
| Naphthalene | 7.63E-05 | 0.67 | 0.00E+00 | 0.00 | 2.20E-07 | 0.0019 |
| Toluene | 1.30E-02 | 113.55 | 5.16E-03 | 45.24 | 1.22E-04 | 1.1 |
| Xylene (Total) | 8.39E-03 | 73.48 | 2.78E-03 | 24.36 | 7.33E-06 | 0.064 |
| 1,2,4-Trimethylbenzene | 1.33E-03 | 11.69 | 5.38E-04 | 4.71 | 0.00E+00 | 0 |

* Baseline period is 2002, 2003 and 2004.

Emissions estimated by ConocoPhillips using EPA AP-42 methodology with option for zero-gap seals

Emission Increase from S98, S123, and S124

| Tank Emissions | | | |
|-----------------------|------------|-------------|-------------|
| Tank Number | S98 | S123 | S124 |

| Substance | Speciations | | |
|------------------------|-------------------------------------|-------------------------------------|-------------------------------------|
| | Gasoline | MUK | LUK, LTWXY |
| | Vapor Weight Fraction of ROG | Vapor Weight Fraction of ROG | Vapor Weight Fraction of ROG |
| Benzene | 0.0032 | 0.0028 | 0.0071 |
| Cyclohexane | 0.0048 | 0.0039 | 0.0032 |
| Ethylbenzene | 0.0005 | 0.0047 | 0.0000 |
| Hexane | 0.0194 | 0.0064 | 0.0164 |
| Naphthalene | 0.0001 | 0.0000 | 0.0000 |
| Toluene | 0.0092 | 0.0456 | 0.0004 |
| Xylene (Total) | 0.0059 | 0.0245 | 0.0000 |
| 1,2,4-Trimethylbenzene | 0.0009 | 0.0047 | 0.0000 |

| Source Number | Tank Number | Annual Proposed Limit (bbl) | Emissions lb/yr | | | Emissions lb/hr Increase | Emissions TPY Increase |
|---------------|-------------|-----------------------------|-----------------|----------|----------|--------------------------|------------------------|
| | | | Proposed | Baseline | Increase | | |
| S118 | 163 | 900 | 6 | 4 | 2 | 2.63E-04 | 0.00115 |
| S122 | 167 | 2,000,000 | 9,574 | 2,312 | 7,262 | 8.29E-01 | 3.631 |
| S128 | 174 | 5,100,000 | 3,094 | 721 | 2,373 | 2.71E-01 | 1.1865 |
| TOTAL | | | 9,637 | 1.10E+00 | 4.81865 | | |

Change in Emissions from Existing Tanks

| Source Number | Product Stored | Emissions lb/yr | | | | | | | | | | | | | |
|---------------|----------------|-----------------|-------------|--------------|----------|-------------|---------|----------------|------------------------|-------------------------|------------------------|-------------------------|--------|---------|--------|
| | | Benzene | Cyclohexane | Ethylbenzene | Hexane | Naphthalene | Toluene | Xylene (Total) | 1,2,4-Trimethylbenzene | 2,4-di-tert-butylphenol | Ortho-tert-butylphenol | Mixed butylated phenols | Phenol | Toluene | |
| S118 | Additive | | | | | | | | | | 0.0391 | 0.1840 | 0.2760 | 0.0184 | 0.4600 |
| S122 | Gasoline (LUK) | 51.2466 | 23.3110 | 0.0495 | 118.8327 | 0.0050 | 2.7356 | 0.1650 | 0.0000 | | | | | | |
| S128 | Gasoline | 7.6864 | 11.3087 | 1.2811 | 46.1186 | 0.1281 | 21.7782 | 14.0918 | 2.2419 | | | | | | |

| Source Number | Product Stored | Emissions lb/hr | | | | | | | | | | | | |
|---------------|----------------|-----------------|-------------|--------------|----------|-------------|----------|----------------|------------------------|-------------------------|------------------------|-------------------------|----------|----------|
| | | Benzene | Cyclohexane | Ethylbenzene | Hexane | Naphthalene | Toluene | Xylene (Total) | 1,2,4-Trimethylbenzene | 2,4-di-tert-butylphenol | Ortho-tert-butylphenol | Mixed butylated phenols | Phenol | Toluene |
| S118 | Gasoline | | | | | | | | | 4.46E-06 | 2.10E-05 | 3.15E-05 | 2.10E-06 | 5.25E-05 |
| S122 | Gasoline (LUK) | 5.85E-03 | 2.66E-03 | 5.65E-06 | 1.36E-02 | 5.65E-07 | 3.12E-04 | 1.88E-05 | 0.00E+00 | | | | | |
| S128 | Gasoline | 8.77E-04 | 1.29E-03 | 1.46E-04 | 5.26E-03 | 1.46E-05 | 2.49E-03 | 1.61E-03 | 2.56E-04 | | | | | |

The emissions were calculated using EPA's AP-42 methodology.

FINAL: October 5, 2007


Evaluation Report, Application 13424, ConocoPhillips Refinery, Facility A0016, Rodeo CA

S1004, U235 Sulfur Recovery Unit (200 long tons/day)
S301-S303, S465, Sulfur Pits
S503, Sulfur Storage Tank
S504, Sulfur Degassing Unit
S505, Sulfur Truck Loading Rack abated by A424, Tail Gas Incinerator

S1004, U235 Sulfur Recovery Unit (200 long tons/day)

Following is the estimate of SO₂ emissions based on a flow rate of 77,000 lb/hr through the SRU, which is provided by the SRU designers, and a limit of 50 ppm_{dv} SO₂ at 0% O₂.

SRU SO₂ Emissions



Assume sample is mostly air at 1 atm and 298 K (vol is approx. 0.856 m³/kg)

| | | |
|--|---------------------------------|---|
| P=101000 | Pa | |
| T=298 | K | |
| R=8.3 | (m ³ * Pa)/(K * mol) | |
| Ppm _{vd} =50 | mL/m ³ | based on Shell Martinez Refinery's Title V Permit Condition 12271 Part 68 |
| density of air=1.168 | kg/m ³ | at 1 atm and 298K |
| M _w sample=28.36 | g/gmol | |
| M _w SO ₂ =64 | g/gmol | |
| M _w N ₂ =28 | g/gmol | |
| M _w O ₂ =32 | g/gmol | |
| mole fraction of N ₂ in air =0.78 | | |

stack flow rate from SRU TGTU stack= 77700 lbs/hour at 0% O₂ and water
(also equal to 1.04 mmscfh with MW=28.36)

= 1.24E+06 gmol/hr
= 1.09E+10 gmol/yr

stack flow rate from incinerator stack= 1.19E+06 gmol/hr
= 1.04E+10 gmol/yr

SO₂=5.95E+01 gmol/hr
=5.21E+05 gmol/yr

= 36.7 TPY

= 201 lb/day

= 8.4 lb/hr

Following is the estimate of the maximum H2S emissions from the SRU assuming a flow of 77,000 lb/hr through the SRU and a concentration of 2.5 ppmvd @ 0% O2.

SRU H2S Emissions

Assume sample is mostly air at 1 atm and 298 K (vol is approx. 0.856 m³/kg)

P= 101000 Pa
 T= 298 K
 R= 8.3 (m³ * Pa)/(K * mol)
 Ppmvd= 2.5 mL/m³

based on Shell Martinez Refinery's Title V Permit Condition 12271 Part 68 at 1 atm and 298K

density of air= 1.168 kg/m³
 Mwsample= 28.36 g/gmol
 MWH2S= 34 g/gmol
 MWN2= 28 g/gmol
 MWO2= 32 g/gmol

mole fraction of N2 in air = 0.78

stack flow rate from SRU TGTU stack= 77700 lbs/hour at 0% O2 and water (also equal to 1.04 mmscfh with MW=28.36)

= 1.24E+06 gmol/hr
 = 1.09E+10 gmol/yr

stack flow rate from incinerator stack= 1.19E+06 gmol/hr
 = 1.04E+10 gmol/yr

H2S= 2.97E+00 gmol/hr
 = 2.6E+04 gmol/yr
 = 0.975 TPY
 = 5.3 lb/day
 = 0.23 lb/hr

FINAL: October 5, 2007

Evaluation Report, Application 13424, ConocoPhillips Refinery, Facility A0016, Rodeo CA

The NO_x, CO, and ammonia (NH₃) emissions are calculated in the same manner except that the correction for oxygen is 7%.

SRU Incinerator CO, NO_x and NH₃ Emission Calculations

| | | |
|-------------------------|----------------|--------------------|
| SRU Thermal Incinerator | | (@ 0% |
| stack flow= | 77700 lbs/hour | O ₂ and |
| MWsample= | 28.36 g/gmol | water) |

CO emissions at 75 ppm @ 7% O₂¹

| | |
|-----------------|-----------------------------|
| density of air= | 379 ft ³ /lbmole |
| CO Conc = | 75 ppmvd |
| MWCO= | 28 lb/lbmole |

| | |
|---------------|------------|
| CO emissions= | 8.65 lb/hr |
| CO emissions= | 208 lb/day |
| CO emissions= | 37.9 TPY |

NO_x emissions at 13.5 ppm @ 7% O₂¹

| | |
|------------------------|-----------------------------|
| density of air= | 379 ft ³ /lbmole |
| NO _x Conc = | 13.5 ppmvd |
| MW NO _x = | 46 lb/lbmole |

| | |
|----------------------------|------------|
| NO _x emissions= | 2.56 lb/hr |
| NO _x emissions= | 61 lb/day |
| NO _x emissions= | 11.21 TPY |

NH3 emissions at 12.5 ppm @ 7% O2

density of air= 379 ft³/lbmole
 ppmvd (@7%
 NH3 Conc = 12.5 O2)
 MWNH3 = 17 lb/lbmole

NH3 emissions= 0.88 lb/hr
 NH3 emissions= 21 lb/day
 NH3 emissions= 3.83 TPY

The facility has based the emissions of PM10 and POC, for the SRU complex on the heat input of the incinerator as follows:

SRU Incinerator

| Pollutant | Emission Factor | EF (lb/MMBtu) | Reference |
|-----------|-----------------|---------------|--|
| PM10 | 7.6 lb/MMcf | 0.0075 | AP42 Section 1.4, Natural Gas Combustion |
| POC | 5.5 lb/MMcf | 0.0054 | AP42 Section 1.4, Natural Gas Combustion |

(1) Assumed firing rate: 18 MMBtu/hr
 1,546,756 Therms/yr

Daily emissions assume 24 hr/day operation.
 Annual emissions assume 365 day/yr operation.

Assumptions for emissions factor table above:

(1) NOx and CO "ppm" emission factors converted to "lb/MMBtu" as follows:
 $(x \text{ [lb/MMBtu]}) = (y \text{ ppm @ 7\% O}_2) * (21\% - 0\%) / (21\% - 7\%) * (\text{EPA Fd Factor [ft}^3\text{/MMBtu]}) / (\text{Molar Volume [ft}^3\text{/lbmol]}) * (\text{Molecular weight [lb/lbmol]})$

PM10 and POC "lb/MMcf" emission factors converted to "lb/MMBtu" as follows:
 $(x \text{ [lb/MMBtu]}) = (\text{Emission factor [lb/MMcf]}) / (\text{Refinery gas heat content [Btu/scf]})$

EPA Fd Factor: 8710 ft³/MMBtu - based on EPA Method 19 (40 CFR 60)
 Molar volume: 379 ft³/lbmol (at STP: 25 C, 1 atm)
 NOx MW: 46 lb/lbmol

FINAL: October 5, 2007

Evaluation Report, Application 13424, ConocoPhillips Refinery, Facility A0016, Rodeo CA

CO MW: 28lb/lbmol
SO2 MW: 64lb/lbmol
Natural gas: 1020Btu/scf (AP42)

Based on the emission factors above, the facility has estimated hourly, daily, and annual emissions.

Hourly, Daily and Annual SRU Emissions

| Pollutant | Emissions ¹ | | |
|-----------|------------------------|--------|--------|
| | lb/hr | lb/day | ton/yr |
| PM10 | 0.14 | 3.24 | 0.59 |
| POC | 0.10 | 2.33 | 0.43 |

Notes:

(1) Assumed heater rating: 18MMBtu/hr
Daily emissions assume 24 hr/day operation.
Annual emissions assume 365 day/yr operation.

Based on the representations by the facility, the unit will be limited to the above amounts of SO2, H2S, NH3, NOX, PM10, POC, and CO.

Fugitive Sources
 S307, U240 Unicracking Unit
 S308, U244 Reforming Unit
 S309, U248 UNISAR Unit
 S318, U76 Gasoline Blending
 S339, U80 Gasoline/Mid Barrel Blending
 S432, U215 Deisobutanizer
 S434, U246 High Pressure Reactor Train (Cracking)
 S1004, U235 Sulfur Recovery Unit (200 long tons/day)

The following emission estimates were provided by ConocoPhillips and the District has found them to be acceptable.

New process equipment associated with the CFEP will emit fugitive POC emissions from various components including valves, flanges, connectors, pumps, and compressors. The proposed upgrades to the Unit 240 Unicracker will include new sources of fugitive POC emissions; however, there will be no more than a negligible change in fugitive POC emissions from other existing units. Replacement equipment at existing units is expected to have approximately the same number of fugitive components. Additionally, piping changes within and between existing units are not expected to significantly affect the fugitive component count.

The number of new fugitive components for the CFEP is estimated based on pre-design drawing hand-count, comparison to existing units, ConocoPhillips experience in construction of similar units, and other estimation techniques. The estimated count of new fugitive components is divided into three service categories including gas, light liquid, and heavy liquid. **Table 3-6** provides an estimated fugitive component count for the modified Unicracker Process Unit, modified new Sulfur Plant, Deisobutanizer Unit, Reformer Unit, Product Blending, and Storage Tank No. 101.

Table 3-6 Fugitive Component Count

| Unit | Stream | Component Counts | | | | |
|--|--------|------------------|-------|------------|---------|--------------------|
| | | Valves | Pumps | Connectors | Flanges | Other ¹ |
| Unit 240 Unicracker (S-307)(Unit 246) | Gas | 295 | 0 | 295 | 590 | 1 |
| | LL | 419 | 2 | 419 | 838 | 1 |
| | HL | 547 | 3 | 547 | 1094 | 1 |
| New Sulfur Plant Modifications (S1004 (Unit 235) | Gas | 125 | 0 | 125 | 250 | 0 |
| | LL | 0 | 0 | 0 | 0 | 0 |
| | HL | 0 | 0 | 2 | 0 | 0 |
| Unit 215 DIB Deisobutanizer | Gas | 0 | 0 | 0 | 0 | 0 |
| | LL | 20 | 0 | 160 | 40 | 0 |

| Unit (S-432) | Component Counts | | | | | |
|--|------------------|--------|-------|------------|---------|--------------------|
| | Stream | Valves | Pumps | Connectors | Flanges | Other ¹ |
| Unit 244 Reformer (S-308) | HL | 0 | 0 | 0 | 0 | 0 |
| | Gas | 0 | 0 | 0 | 0 | 0 |
| | LL | 100 | 2 | 200 | 200 | 0 |
| | HL | 0 | 0 | 0 | 0 | 0 |
| Unit 76 Product Blending (S-318) | Gas | 0 | 0 | 0 | 0 | 0 |
| | LL | 100 | 4 | 100 | 200 | 0 |
| | HL | 100 | 4 | 100 | 200 | 0 |
| New Tank No. 101 | Gas | 0 | 0 | 0 | 0 | 0 |
| | LL | 24 | 1 | 13 | 38 | 0 |
| | HL | 0 | 0 | 0 | 0 | 0 |

1. The "other" component type includes instruments, pressure relief valves, vents, compressors, dump lever arms, diaphragms, drains, hatches, meters, and polished rods stuffing boxes. This "others" component type should be applied for any component type other than connectors, flanges, open-ended lines, pumps, or valves.

LL – Light Liquid Stream

HL – Heavy Liquid Stream

These component counts were used to estimate fugitive POC and toxic air contaminant emission increases from the proposed CFEP. Pressure relief valves (PRVs) are not included in the fugitive component count because any new PRVs for the proposed CFEP will be connected to the refinery's blowdown system to control both fugitive leak and process upset emissions. There will not be any new open-ended lines for sampling or other purposes.

Fugitive POC emission estimates were calculated based on U.S. EPA Correlation Equations as presented in Table IV-3a of the February 1999 California Air Resources Board/California Air Pollution Control Officers Association (CARB/CAPCOA) document entitled California Implementation Guidelines for Estimating Mass Emissions of Fugitive Hydrocarbon Leaks at Petroleum Facilities. This document is the accepted BAAQMD standard for estimating fugitive emissions.

For the purposes of this application, the maximum leak rate allowed by the BAAQMD (100 ppmv for valves, 500 ppmv for pumps, etc.) was used as the screening value (SV) in each Correlation Equation. Use of BAAQMD maximum leak rates results in a conservative emissions estimate because most fugitive components in the ConocoPhillips' leak detection and repair (LDAR) program have actual leak rates well below BAAQMD maximum leak rates.

The screening values used for valves, flanges, connectors, pump, and compressors and the corresponding correlation equations are shown in **Table 3-7**. This table also displays resulting emission factors in lbs/hr per source. Using the Correlation Equation approach, with the BAAQMD maximum leak rates, the resulting emission factors for each component type are the same for each type of service (gas, light liquid, and heavy liquid).

Table 3-7 Fugitive Component Emission Factors

| Component Type/Service | Correlation Equation ¹ | Screening Value, SV ² (ppmv) | Resulting Emission Factor (kg/hr/source) | Resulting Emission Factor (lb/hr/source) |
|-------------------------|-----------------------------------|---|--|--|
| Valves/All | $2.27E-6*(SV)^{0.747}$ | 100 | 7.1E-05 | 1.6E-04 |
| Connectors/All | $1.53E-6*(SV)^{0.736}$ | 100 | 4.5E-05 | 1.0E-04 |
| Flanges/All | $4.53E-6*(SV)^{0.706}$ | 100 | 1.2E-04 | 2.6E-04 |
| Pump Seals/All | $5.07E-5*(SV)^{0.622}$ | 500 | 2.4E-03 | 5.3E-03 |
| Other ³ /All | $8.69E-6(SV)^{0.642}$ | 500 | 4.7E-04 | 1.0E-03 |

1. California Implementation Guidelines for Estimating Mass Emissions of Fugitive Hydrocarbon Leaks at Petroleum Facilities, February 1999.
2. Screening values assumed to be maximum leak rate allowed by BAAQMD, Regulation 8-18.
3. The "other" component type includes instruments, pressure relief valves, vents, compressors, dump lever arms, diaphragms, drains, hatches, meters, and polished rods stuffing boxes. This "others" component type should be applied for any component type other than connectors, flanges, open-ended lines, pumps, or valves.

Table 3-8 summarizes the total fugitive component emissions for all of the process units that are being modified.

Table 3-8 Total Fugitive Component Emissions

| | Emissions | | |
|-------------------------------|-----------|--------|--------|
| | lb/hr | lb/day | ton/yr |
| Unicracker (Unit 240)246) | 1.0 | 24 | 4.4 |
| Sulfur Plant Modifications | 0.096 | 2.32 | 0.42 |
| Deisobutanizer (Unit 215 DIB) | 0.029 | 0.71 | 0.13 |
| Reformer (Unit 244) | 0.10 | 2.3 | 0.43 |
| Product Blending (Unit 76) | 0.20 | 4.7 | 0.86 |
| New Tank No. 101 | 0.020 | 0.48 | 0.089 |
| Total | 1.4 | 35 | 6.3 |

After construction of the new and modified units associated with the CFEP, an actual count of fugitive components will be conducted when the new components are added to the ConocoPhillips' LDAR program. This information will be provided to the BAAQMD to determine if any adjustments are needed for compliance with applicable requirements (i.e., a possible change in the quantity of required emission reduction credits).

The emission factors used to estimate TAC emissions from process unit fugitive components are based on service-weighted speciation data provided by ConocoPhillips. **Table 4-5** summarizes the profiles that are used in this application.

Table 4-5 Speciation Profiles for Fugitive Components

| Unit | Weight Fraction of TACs in Process Unit Streams | | | | | | | |
|--|---|----------|---------|--------------|-----------------|-------------|------------------------|-------------|
| | Benzene | n-Hexane | Toluene | Total Xylene | EB ² | Naphthalene | 1,2,4-TMB ² | Cyclohexane |
| Unicracker (Unit 246) ¹ | 0.003 | 0.0069 | 0.0041 | 0.0044 | 0.0014 | 0.00001 | 0 | 0 |
| New Sulfur Plant (Unit 235) ¹ | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Deisobutanizer (Unit 215) ¹ | 0.011 | 0.12 | 0.015 | 0.001 | 0.01 | 0 | 0.001 | 0.02 |
| Reformer (Unit 244) ¹ | 0.02 | 0.01 | 0.13 | 0.11 | 0.03 | 0.003 | 0.05 | 0.001 |
| Product Blending (Unit 76) ¹ | 0.008 | 0.03 | 0.09 | 0.11 | 0.02 | 0.003 | 0.04 | 0.01 |
| Tank No. 101 ¹ | 0.0080 | 0.030 | 0.080 | 0.11 | 0.020 | 0.020 | 0.035 | 0.011 |

1. Based on service-weighted speciation provided by ConocoPhillips.
2. Compound abbreviations - EB: Ethylbenzene, TMB: Trimethylbenzene

Each speciation profile provides a weight percent breakdown of each chemical component that comprises total POC emissions. Therefore, fugitive TAC emissions for each component and service type are individually estimated by multiplying the weight percent of each toxic air contaminant (from the speciation profile) times the total fugitive POC emissions. **Table 4-6** presents a summary of TAC fugitive mass emissions.

Table 4-6 TAC Emissions from Fugitive Components

| Unit | POC | Benzene | n-Hexane | Toluene | Total Xylene | EB ¹ | Naphthalene | 1,2,4-TMB ¹ | Cyclohexane |
|-----------------------------|-------|---------|----------|---------|--------------|-----------------|-------------|------------------------|-------------|
| | lb/hr | | | | | | | | |
| Unicracker (Unit 246) | 1.0 | 0.0030 | 0.0069 | 0.0041 | 0.0044 | 0.0014 | 0.000010 | 0.00 | 0.00 |
| New Sulfur Plant (Unit 235) | 0.096 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |
| Deisobutanizer (Unit 215) | 0.029 | 0.00032 | 0.0035 | 0.00044 | 0.00002 | 0.0003 | 0.00 | 0.00003 | 0.00059 |
| Reformer (Unit 244) | 0.10 | 0.0020 | 0.00098 | 0.013 | 0.011 | 0.0029 | 0.00029 | 0.0049 | 0.000098 |
| Product Blending (Unit 76) | 0.20 | 0.0016 | 0.0059 | 0.018 | 0.022 | 0.0039 | 0.00059 | 0.0079 | 0.0020 |

FINAL: October 5, 2007

Evaluation Report, Application 13424, ConocoPhillips Refinery, Facility A0016, Rodeo CA

| | | | | | | | | | |
|-----------------------------|---------|---------|---------|--------|--------|--------|---------|---------|---------|
| Tank No. 101 | 0.020 | 0.00016 | 0.00060 | 0.0016 | 0.0022 | 0.0004 | 0.00040 | 0.00070 | 0.00022 |
| Total | 1.4 | 0.0070 | 0.018 | 0.0365 | 0.039 | 0.0090 | 0.0013 | 0.0135 | 0.0029 |
| | lb/year | | | | | | | | |
| Unicracker (Unit 246) | 8770 | 26 | 61 | 36 | 38.6 | 12.3 | 0.1 | 0.0 | 0.0 |
| New Sulfur Plant (Unit 235) | 845 | 0.0 | 0.0 | 0.0 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |
| Deisobutanizer (Unit 215) | 257 | 2.83 | 30.9 | 3.9 | 0.26 | 2.57 | 0.00 | 0.26 | 5.15 |
| Reformer (Unit 244) | 855 | 17.11 | 8.6 | 111.2 | 94.1 | 25.7 | 2.6 | 42.8 | 0.9 |
| Product Blending (Unit 76) | 1720 | 13.78 | 52 | 155.0 | 189.5 | 34.5 | 5.2 | 68.9 | 17.2 |
| Tank No. 101 | 176 | 1.41 | 5.3 | 14.11 | 19.41 | 3.53 | 3.53 | 6.17 | 1.94 |
| Total | 12600 | 61 | 157 | 320 | 342 | 78 | 11 | 118 | 25 |

1. Compound abbreviations - EB: Ethylbenzene, TMB: Trimethylbenzene
2. Benzene and naphthalene emissions exceed the risk screening trigger level of 6.4 and 5.3 lb/year, respectively.

FINAL: October 5, 2007

Evaluation Report, Application 13424, ConocoPhillips Refinery, Facility A0016, Rodeo CA

Turbines and HRSG
S352-S354, Combustion Turbines, S355-S357, HRSGs

The turbines/HRSGs will be a source of contemporaneous offsets for NO_x for the CFEP project. The current annual limit for all six sources combined is 167 tons NO_x in any consecutive 365-day period. The sources have CEMs that measure the concentration of NO_x, CO, and O₂. The flow is calculated using fuel flow monitors at each source and the F-factor method in 40 CFR 60, Appendix A, Method 19. On October 2, 2006, ConocoPhillips submitted data showing that the actual annual average NO_x emissions for the combined equipment were 101.9 tons per year. ConocoPhillips has proposed to decrease the NO_x emissions by 22.1 tons per year to 79.8 tons per year. The reduction will be confirmed by CEM monitoring.

Dissolved Air Flotation
S1007, Dissolved Air Flotation Unit (DAF)

An air flotation unit, is defined by BAAQMD Regulation 8-8-209 as:

Any device, equipment, or apparatus in which wastewater is saturated with air or gas under pressure and removes floating oil, floating emulsified oil, or other floating liquid precursor organic compounds by skimming.

Also included in this definition are: induced air flotation units and pre-air flotation unit flocculant sumps, tanks, or basins.

S1007, Dissolved Air Flotation Unit, accepts wastewater from the oil-water separator and separates remaining oil by bubbling air through the unit, adding a flocculant to aid separation, and skimming the oil and flocculant from the unit. The wastewater is then ready for processing by the biological treatment units.

BAAQMD Regulation 8-8-307 requires control of air flotation units with covers or organic compound recovery systems with a combined collection and destruction efficiency of at least 70 percent by weight. Section 307.1 allows the units to have atmospheric vents.

Based on samples gathered by BAAQMD in August 2005 and June 2006, and on flow testing that ConocoPhillips performed in June 2006, the facility has concluded that the DAF atmospheric vents emit up to 37 tons POC per year. The District has concluded using the model TOXCHEM during the 2004 rulemaking for BAAQMD Regulation 8, Rule 8, that the emissions from the channel and weir are about 8 tons per year.

The facility has proposed to control the source with a 440,000 btu/hr thermal oxidizer, A49, to obtain 44.1 tons of contemporaneous PCO offsets. The facility will be required to show by source test that they will capture and destroy 44.1 tons per year or they will be required to supply the offsets from another source. If the offsets are obtained from a banking certificate, ConocoPhillips will have to provide them at a 1:1.15 ratio.

Following are calculations of the DAFs secondary emissions.

DAF Vent Emissions

| Pollutant | Pre-Controlled Emissions (tons/yr) | % of Year that Thermal Oxidizer is in Operation (shutdown 1 wk per year) | Post Controlled Emissions (ton/yr) | Difference |
|-----------|------------------------------------|--|------------------------------------|------------|
| VOC | 45 | 0.98 | 0.92 | -44.08 |
| NOX | 0 | 0.98 | 0.21 | 0.21 |
| H2S | 0.63 | 0.98 | 0.01 | -0.62 |
| SO2 | 0 | 0.98 | 1.2 | 1.2 |

CO Emissions

| | | |
|-----------------------|---------------|---|
| Thermal Oxidizer duty | 440000 | |
| NG Heat Value | 1020 Btu/scf | |
| NG Flow= | 7.19 scfm | |
| NG Heat Content= | 0.44 MMBtu/hr | (A small boiler per AP 42 Table 1.4-1) |
| CO EF= | 84 lb/MMscf | (per AP 42 Table 1.4-1 for small boilers) |

CO Emissions (lb/hr)=(NG Flow)*(CO EF)/1000000*60*(% year in operation)

| | |
|----------------|-------------|
| CO Emissions = | 0.036 lb/hr |
| CO Emissions = | 0.85 lb/day |
| CO Emissions = | 0.16 TPY |

PM10 Emissions

| | |
|----------|--------------------------------------|
| NG Flow= | 7.19 scfm |
| PM10 EF= | 7.6 lb/MMscf (per AP 42 Table 1.4-2) |

PM10 Emissions (lb/hr)=(NG Flow)*(PM10 EF)/1000000*60*(% year in operation)

| | |
|------------------|--------------|
| PM10 Emissions = | 0.0032 lb/hr |
| PM10 Emissions = | 0.077 lb/day |
| PM10 Emissions = | 0.014 TPY |

DAF SO₂ Emissions

| | Current H ₂ S Emissions (lb/d) | SO ₂ emissions (if combusted) (lb/d) | |
|-------------------|--|---|-------|
| Flow rate Vent #6 | 2.21 | 4.2 | |
| Flow rate Vent #7 | 0.34 | 0.6 | |
| Flow rate Vent #8 | 0.61 | 1.1 | |
| Flow rate Vent #9 | 0.29 | 0.5 | |
| | | 6.5 | lb/d |
| | | 2364 | lb/yr |

Paved Roads

ConocoPhillips provided the following emission estimates and the District has found them to be acceptable.

Paved Road Emissions

| | Estimated Project Change | Estimated Daily Project Change |
|-------------------------------|-----------------------------|--------------------------------|
| Commodity | Trips/time period | Trips/day |
| Raw Material Delivery: | | |
| Sodium hydroxide | +1 trip/month | 0.033 |
| Aqueous ammonia | +2 trip/month | 0.067 |
| Amine | +2 trips/year | 0.0055 |
| Feedstock additives | +2 trips/month | 0.067 |
| Stretford solution | 0 trips/year | 0 |
| Feed crude oil | no change | 0 |
| Product shipping: | | |
| Molten sulfur | +9 trips/day | 9 |
| Waste Shipping | | |
| Sulfur/vanadium | | |
| Stretford waste | 0 trip/day | 0 |
| Spent catalyst | +12 trips/year ¹ | 0.033 |
| Total | | 9.2 |

Emissions are estimated with Equation 2 (with precipitation correction factor) from Chapter 13.2.1 ("Paved Roads") of U.S. EPA's AP-42:

$$E \text{ (lb/VMT)} = k (sL/2)0.65(W/3)1.5(1-P/4N)$$

E = emission rate

$$\text{VMT} = \text{"vehicle miles traveled"} = (4 \text{ mile/trip}) * 9.2 \\ 36.8 \text{ miles/day}$$

k = particle size multiplier from Table 13.2.1-1
= 0.016 lb/VMT for PM10

sL = road surface silt loading from Table 13.2.1-2
= 0.4 g/m² (default value for normal conditions on roads with less than 5,000 vehicles/day)

W = average weight (tons) of vehicles
= 30 tons based on the most common reduced trip (liquid oxygen transport), where a shipment is approximately 23 tons and a truck is assumed to weigh approximately 7 tons

FINAL: October 5, 2007

Evaluation Report, Application 13424, ConocoPhillips Refinery, Facility A0016, Rodeo CA

P = number of "wet days" from Figure 13.2.1-2

= 60 days for the San Francisco Bay Area

N = number of days in the P averaging period

= 365 days

$$E (\text{lb/VMT}) = [(0.016)(0.4/2)^{0.65}(30/3)^{1.5}(1-60/4(365))]$$

$$= 0.17 \text{ lb/mile}$$

$$E (\text{lb/day}) = (0.17 \text{ lb/mile}) * 36.8$$

$$= 1.1 \text{ ton/yr}$$

$$6.3 \text{ lbs/day}$$

FINAL: October 5, 2007

Evaluation Report, Application 13424, ConocoPhillips Refinery, Facility A0016, Rodeo CA

Locomotive Emissions

ConocoPhillips provided the following emission estimates and the District has found them to be acceptable.

Locomotive Emission Calculations

Emission Factors (g/gal)

| HC | CO | NOx | SOx | PM |
|------|------|-------|------|-----|
| 10.1 | 27.4 | 185.6 | 13.6 | 6.4 |

Rail cars

3

Distance Traveled (miles)

42

Weight Per Railcar (pounds)

100000

Combined Weight of Railcars and Butane (pounds)

263000

Conversion Factors

0.001296 gal/ton mile

0.0005 ton / pound

Emissions (g) (Empty Railcars)

| HC | CO | NOx | SOx | PM |
|----------|----------|----------|----------|----------|
| 82.46448 | 223.7155 | 1515.387 | 111.0413 | 52.25472 |

Emissions (lb) (Empty Railcars)

| HC | CO | NOx | SOx | PM |
|-------------|----------|----------|----------|---------|
| 0.181421856 | 0.492174 | 3.333851 | 0.244291 | 0.11496 |

Emissions (g) (Full Railcars)

| HC | CO | NOx | SOx | PM |
|----------|----------|----------|----------|----------|
| 216.8816 | 588.3718 | 3985.467 | 292.0386 | 137.4299 |

Emissions (lb) (Full Railcars)

| HC | CO | NOx | SOx | PM |
|-------------|----------|----------|----------|----------|
| 0.477139481 | 1.294418 | 8.768028 | 0.642485 | 0.302346 |

| Emissions (lb/day) | | | | | | |
|--------------------|------|-------|------|------|-------------|--------------|
| HC | CO | NOx | SOx | PM | Benzen e | Formaldehyde |
| 0.66 | 1.79 | 12.10 | 0.89 | 0.42 | 0.013 | 0.097 |

| Emissions (lb/year) | | | | | | |
|---------------------|-------|--------|-------|-------|-------------|--------------|
| HC | CO | NOx | SOx | PM | Benzen e | Formaldehyde |
| 240.4 | 652.1 | 4417.2 | 323.7 | 152.3 | 4.8 | 35.4 |

| Emissions (TPY) | | | | | | |
|-----------------|------|------|------|-------|-------------|--------------|
| HC | CO | NOx | SOx | PM | Benzen e | Formaldehyde |
| 0.12 | 0.33 | 2.21 | 0.16 | 0.076 | 0.0024 | 0.018 |

FINAL: October 5, 2007

Evaluation Report, Application 13424, ConocoPhillips Refinery, Facility A0016, Rodeo CA

Truck Emissions

The truck emissions can be found in the Draft Environmental Impact Report that was prepared by Contra Costa County.

Facility A0022, ConocoPhillips Carbon Plant
S2, Kiln

S2 will be a source of contemporaneous offsets for SO₂ for the CFEP project. There is currently no annual limit for SO₂ for the source. The source is subject to the limits in BAAQMD Regulation 9-310.2, which are a concentration limit of 400 ppm by volume and 250 lb/hr, whichever is more restrictive. The source is also subject to a throughput limit of 262,800 tons coke per year and natural gas limits of 5 million therms at the kiln and 2.6 million therms at A1, Pyroscrubber.

The source has a CEM that measures the concentration of SO₂ and flow. On October 17, 2006, ConocoPhillips submitted data showing that the actual annual average SO₂ emissions were 791 tons per year. ConocoPhillips has proposed to decrease the SO₂ emissions by 42 tons per year to 749 tons per year. The reduction will be confirmed by CEM monitoring.

ConocoPhillips will lower the SO₂ emissions by injecting sodium bicarbonate into the stream of combustion products prior to the baghouse. The sodium bicarbonate absorbs some of the SO₂. This system is in place and is currently being used to ensure that the limits in BAAQMD Regulation 9-310.2 are met. ConocoPhillips will simply inject a higher amount of sodium bicarbonate than is currently being used.

S2 will also be a source of actual reductions for PM₁₀ for the CFEP project. For the purposes of CEQA, Contra Costa County did not agree to emission reduction credits were acceptable and requested that ConocoPhillips make "real-time" reductions in PM₁₀. ConocoPhillips will reduce the emissions of PM₁₀ by upgrading the bags in the kiln baghouse. The new bags will improve control without increasing the pressure drop beyond the baghouse specifications. The facility has 3 annual source tests for particulate that establish the current emission levels. The facility will demonstrate the reduction using annual source tests.

The reduction is not eligible for contemporaneous offsets because it is not in excess of the reductions achieved by the source using Reasonably Available Control Technology (RACT) as required by BAAQMD Regulation 2-1-201. RACT has not been established for this source, but the District estimates that it may be about 0.01 or 0.02 gr/dscf. The source is currently at about 0.04 gr/dscf. The source is in compliance with the BAAQMD Regulation 6-310 level of 0.15 gr/dscf. The facility may apply for emission reduction credits for a portion of this reduction if the RACT level is established.

FINAL: October 5, 2007

Evaluation Report, Application 13424, ConocoPhillips Refinery, Facility A0016, Rodeo CA

APPENDIX B

Sulfuric Acid Mist Calculations

| Summary of Emission Increases | |
|---|---------------------------------|
| Non SRU Total Emission Increases | |
| New Unit 246 HGO Heater | 0.36 TPY |
| New SMR Furnace in Hydrogen Plant | 0.43 TPY |
| Increased Heater Utilization | 0.20 TPY |
| | |
| Total Non SRU Emission Increases | 0.99 TPY |
| Max Possible New SRU U235 Emissions | 5.65 TPY |
| Max Possible New SRU U235 Emissions rate | 0.0087 gr/dscf (@ 0% O2) |

based on SO3/SO2 conversion in heaters/boilers of 5%

max possible derived such that CFEP project emissions are <7 TPY

Estimated New SRU U235 Emission Rate 4.89 TPY

based on average of emission rates from existing SRUs

4. New SMR Furnace in Hydrogen Plant

1) Ratio of SO₃/SO₂ conversion is represented as 0.05 based upon guidance developed originally in EPA AP40 and used as industry standard for boilers and heaters

$$\text{H}_2\text{SO}_4(\text{mass}) = (\text{mass SO}_2) * (\text{SO}_2 \text{ fraction converted to H}_2\text{SO}_4) * (\text{MW}_{\text{H}_2\text{SO}_4}) / (\text{MW}_{\text{SO}_2})$$

MW_SO2 64.06 g/mole

MW_H2SO4 98.08 g/mole

SO2 Total = 5.6 TPY

H2SO4 Total= 0.43 TPY

5. Increased Heater Utilization

1) Ratio of SO₃/SO₂ conversion is represented as 0.05 based upon guidance developed originally in EPA AP40 and used as industry standard for boilers and heaters

$$\text{H}_2\text{SO}_4(\text{mass}) = (\text{mass SO}_2) * (\text{SO}_2 \text{ fraction converted to H}_2\text{SO}_4) * (\text{MW}_{\text{H}_2\text{SO}_4}) / (\text{MW}_{\text{SO}_2})$$

MW_SO2 64.06 g/mole

MW_H2SO4 98.08 g/mole

SO2 Total = 2.6 TPY

H2SO4 Total= 0.20 TPY

FINAL: October 5, 2007

Evaluation Report, Application 13424, ConocoPhillips Refinery, Facility A0016, Rodeo CA

APPENDIX C

PSD AIR QUALITY IMPACT ANALYSIS

FINAL: October 5, 2007

Evaluation Report, Application 13424, ConocoPhillips Refinery, Facility A0016, Rodeo CA

APPENDIX d

FINAL: October 5, 2007

Evaluation Report, Application 13424, ConocoPhillips Refinery, Facility A0016, Rodeo CA

ConocoPhillips Analysis of BACT for NOx and PM10

Following is ConocoPhillips' review of Best Available Control Technology for S45, Heater, S1004, Sulfur Recovery Unit, and Facility B7149, S2, Heater from Prevention of Significant Deterioration Application submitted on June 2, 2006

4.0 BEST AVAILABLE CONTROL TECHNOLOGY

This section addresses BACT requirements for the proposed ConocoPhillips CFEP, as well as the related new Hydrogen Plant on the Refinery site to be owned and operated by Air Liquide Large Industries U.S. LP.

BAAQMD Rule 2-2-301 requires BACT to be applied to:

“...any new or modified source which results in an emission from a new source, or an increase in emissions from a modified source, and which has the potential to emit 10.0 pounds or more per highest day of precursor organic compounds (POC), non-precursor organic compounds (NPOC), nitrogen oxides (NO_x), sulfur dioxide (SO₂), PM₁₀, or carbon monoxide (CO).”

Proposed controlled emission levels to meet BAAQMD BACT requirements, from recent BAAQMD BACT determinations and the BAAQMD BACT Guidelines (BAAQMD 2005) can be found in the *Clean Fuels Project Application for Authority to Construct and Significant Revision to Major Facility* (ConocoPhillips 2006) and the *Hydrogen Plant Project Application for Authority to Construct and Major Facility Review Permit* (Air Liquide 2005).

Included in BAAQMD Regulation 2, Rule 2, are provisions that implement federal PSD requirements. USEPA policy includes a “top-down” BACT analysis for all pollutants emitted in PSD-significant quantities from new and modified emissions. As described in Section 3.0, PSD requirements apply to NO_x and PM₁₀ in this proposed action. To supplement the BACT analysis presented in the above-referenced BAAQMD Authority to Construct (ATC) Applications, the remainder of this section presents “top-down” BACT analyses for the proposed new and modified sources of NO_x and PM₁₀, based on the USEPA RACT/BACT/LAER Clearinghouse (RBLC), California Air Resources Board (CARB) BACT Clearinghouse, and available information on other recently issued permits. USEPA guidance for a “top-down” BACT analysis requires reviewing all possible control options starting at the top level of control efficiency. In the course of the BACT analysis, one or more options may be eliminated from consideration because they are demonstrated to be technically infeasible or have unacceptable energy, economic, or environmental impacts on a case-by-case (site-specific) basis. The steps required for a “top-down” BACT review are:

6. Identify All Available Control Technologies
7. Eliminate Technically Infeasible Options
8. Rank Remaining Technologies
9. Evaluate Remaining Technologies (in terms of economic, energy, and environmental impacts)

10. Select BACT (the most efficient technology that cannot be rejected for economic, energy, or environmental impact reasons is BACT)

4.1 U246 HEAVY GAS OIL (HGO) FEED HEATER

The proposed new U246 HGO Feed Heater supporting the modified Unit 240/246 Unicracker is proposed to be fired on refinery fuel gas (RFG), with natural gas as a backup fuel. The new HGO Feed Heater would be a natural draft process heater rated at 85 million British thermal units per hour (MMBtu/hr).

4.1.1 NO_x BACT – U246 HGO Feed Heater

1. Identify All Available Control Technologies

Table 3 lists the technologies identified for controlling NO_x emissions from process heaters fired on RFG or natural gas.

Table 3 **NO_x Control Technologies**

| Control Technology |
|---|
| No Controls (Base Case) |
| Water/Steam Injection |
| Selective Non-Catalytic Reduction (SNCR) |
| Combustion Controls (Low-NO _x Burners) |
| Selective Catalytic Reduction (SCR) |
| Low-NO _x Burners and SNCR |
| Low-NO _x Burners and SCR |
| SCONOX |




2. Eliminate Technically Infeasible Options

All the control methods identified in Table 3 are considered technically feasible for a process heater fired on RFG, except SCONOx™, SNCR, and water/steam injection.

SCONOx. SCONOx™ uses a potassium carbonate (K₂CO₃) coated catalyst to reduce NO_x emissions. The catalyst oxidizes carbon monoxide (CO) to carbon dioxide (CO₂), and nitric oxide (NO) to NO₂. The CO₂ is exhausted while the NO₂ absorbs onto the catalyst to form potassium nitrite (KNO₂) and potassium nitrate (KNO₃). Dilute hydrogen gas is passed periodically across the surface of the catalyst to convert the KNO₂ and KNO₃ to K₂CO₃, water (H₂O), and elemental nitrogen (N₂), thereby regenerating the K₂CO₃ coating for further absorption. The H₂O and N₂ are exhausted.

SCONOx has not been demonstrated on RFG-fired process heaters (Arizona Department of Environmental Quality [ADEQ] 2005). It has only been demonstrated on combustion sources burning exclusively natural gas. The performance of SCONOx is sensitive to sulfur in the exhaust stream. In addition, the heat ratings on natural gas burners demonstrated with SCONOx are lower than the proposed HGO Feed Heater. Thus, there are significant technical differences between the proposed source and those few sources where SCONOx has been demonstrated in practice. These preclude a finding that SCONOx has been demonstrated to function efficiently on sources identical or similar to the proposed process heater.

Selective Non-Catalytic Reduction (SNCR). SNCR is a post-combustion NO_x control technology based on the reaction of urea or ammonia (NH₃) and NO_x. SNCR involves injecting urea/NH₃ into the combustion gas path to reduce the NO_x to nitrogen and water. This is described by the following chemical equations:



Temperatures ranging from 1,200°F to 2,000°F are required for optimum SNCR performance. Operation at temperatures below this range results in NH₃ slip, while operation above this temperature range results in oxidation of NH₃, forming additional NO_x. Exhaust temperatures of process heaters are typically below the optimum temperature range. In addition, the urea/ammonia must have sufficient residence time, approximately 3 to 5 seconds, at the optimum operating temperatures for efficient NO_x reduction.

SNCR can only be used in induced draft process heaters because of the need to recirculate the flue gas. The HGO Feed Heater will be a natural draft process heater. In addition, existing information on SCNR systems indicate they achieve NO_x reductions ranging from 30 to 75 percent (USEPA 2001), thus SNCR is an

inferior control technology to either SCR or modern combustion controls for an RFG-fired process heater. Therefore, SNCR is considered infeasible for this review.

Water/Steam Injection. The injection of steam or water into the combustion zone can decrease peak flame temperatures, thus reducing thermal NO_x formation. Steam injection is predominantly used with gas turbines. There is little data available to document the effectiveness of water/steam injection for process heaters and no application of this type could be found. Steam injection has been specified as a control method for boilers on a very limited basis. Only one was listed in the USEPA RBL database during the ADEQ's recent review of the Arizona Clean Fuels Yuma, LLC project (ADEQ 2005). This review showed a controlled emission rate higher than low NO_x burners produced today. Additionally, there are operating issues concerning flame stability using low NO_x burners with steam injection. Therefore, water/steam injection is considered infeasible for this review.

3. Rank Remaining Technologies

Technically feasible NO_x control technologies are listed in Table 4 with typical emission levels, ranked from most efficient to least efficient.

Combustion Controls. Combustion controls reduce NO_x emissions by controlling the combustion temperature or the availability of oxygen (O₂). These are referred to as "low NO_x burners" or "ultra-low NO_x burners." There are several designs of low/ultra-low NO_x burners currently available. These burners combine two NO_x reduction steps into one burner, typically staged air with internal flue gas recirculation (IFGR) or staged fuel with IFGR, without any external equipment.

In staged air burners with IFGR, fuel is mixed with part of the combustion air to create a fuel-rich zone. High-pressure atomization of the fuel creates the recirculation. Secondary air is routed by means of pipes or ports in the burner block to optimize the flame and complete combustion. This design is predominantly used with liquid fuels.

Table 4 *NO_x Control Hierarchy for Process Heaters Fired on Refinery Fuel Gas*

| Technology | Typical Emission Level | |
|--|------------------------|-----------------------|
| | ppmv ¹ | lb/MMBtu ² |
| Combustion Controls and SCR ³ | 7 | 0.0085 |
| Selective Catalytic Reduction (SCR) | 18 | 0.022 |

| | | |
|--------------------------|----|-------|
| Combustion Controls | 29 | 0.035 |
| No Controls ⁴ | 89 | 0.11 |

Source: *Petroleum Refinery Tier 2 BACT Analysis Report, Final Report* (EPA, 2001).

¹ Parts per million by volume (ppmv), dry basis, corrected to 3% oxygen.

² Pounds (lbs) of NO_x produced per MMBtu of fuel heat input.

³ Recent data show a range of values, with 7 ppmv representing the low end of current permitted levels on RFG-fired refinery heaters. See discussion of current BACT determinations in text for more details.



⁴ Emission level shown is for a natural draft heater; an induced draft heater would typically have higher uncontrolled NO_x levels, on the order of 179 ppmv at 3% O₂, dry (USEPA 2001).

In staged fuel burners with IFGR, fuel pressure induces the IFGR, which creates a fuel lean zone and a reduction in oxygen partial pressure. This design is predominantly used for gas fuel applications.

The range of performance achieved in practice for the best combustion controls is 25 to 29 ppmv at 3% O₂, dry (0.03 to 0.035 lb/MMBtu), with the upper end of range representing heaters firing gas with high hydrogen content (USEPA 2001). Burners that could achieve 10 ppmv or lower are under development, but are not currently available for process heaters.

RFG is high in hydrogen content, so for heaters burning RFG or a mixture of RFG and natural gas, the upper end of the demonstrated range (29 ppmv at 3% O₂, dry, or 0.035 lb/MMBtu) would be appropriate as the achievable performance level for combustion controls on RFG-fired process heaters.

Selective Catalytic Reduction (SCR). SCR is a process that involves post-combustion removal of NO_x from flue gas with a catalytic reactor. In the SCR process, ammonia injected into the exhaust gas reacts with nitrogen oxides and oxygen to form nitrogen and water. SCR converts nitrogen oxides to nitrogen and water by the following reactions:



The reactions take place on the surface of a catalyst. The function of the catalyst is to effectively lower the activation energy of the NO_x decomposition reaction. Technical factors related to this technology include the catalyst reactor design, optimum operating temperature, sulfur content of the fuel, catalyst deactivation due to aging, ammonia slip emissions, and design of the NH₃ injection system. The most common catalysts are composed of vanadium, titanium, molybdenum, and zeolite. Sulfur dioxide and sulfur trioxide are generated in the flue gas when sulfur-containing compounds in fuel are combusted. Catalyst systems promote

partial oxidation of sulfur dioxide (from sulfur and mercaptans in the fuel) to sulfur trioxide, which combines with water to form sulfuric acid, causing corrosion over time. In addition, sulfur trioxide and sulfuric acid reacts with excess ammonia to form ammonium salts. These ammonium salts may condense as the flue gases are cooled, which over time can accumulate on the catalyst causing "plugging" and catalyst deterioration, often referred to as "fouling." These effects can be minimized by proper operation, including:

Controlling the amount of sulfur in the fuel.

Using a properly designed ammonia injection system to maximize the efficient mixing of ammonia and flue gas without colder surfaces present on which ammonium salts can condense.

Operating with the lowest amount of ammonia needed to achieve the desired performance. To achieve high NO_x reduction rates, SCR vendors suggest a higher ammonia injection rate than stoichiometrically required, which necessarily results in ammonia slip. Thus, an emissions tradeoff between NO_x and ammonia occurs in high NO_x reduction applications.

Operating at temperatures above the dew point of ammonium salts and sulfuric acid.

Optimal operating temperatures vary by catalyst but generally range from 500 to 800°F. Operating above the maximum temperature results in oxidation of NH₃ to either nitrogen oxides (thereby adding NO_x emissions) or ammonium nitrate. Operating below the optimal temperature increases ammonia slip and catalyst fouling. Refinery process heaters typically operate in the range of 450 to 700°F, thus would be expected to operate above the dew point of ammonium salts and sulfuric acid to minimize fouling and corrosion. SCR systems have been used on process heaters burning mixtures of RFG and natural gas.

SCR systems achieve 80 to 90 percent reductions in NO_x emissions (USEPA 2001). The 90 percent reduction is relative to an uncontrolled induced draft heater since the higher NO_x emissions (approximately 179 ppmv at 3% O₂, dry, or 0.22 lb/MMBtu) versus a natural draft heater (approximately 89 ppmv at 3% O₂, dry, 0.11 lb/MMBtu) provides a greater driving force for increased mass transfer and also enhances the SCR's mechanical draft requirements. This yields an outlet NO_x emission level of approximately 18 ppmv at 3% O₂, dry, or 0.011 lb/MMBtu. For a natural draft heater, maximum SCR control efficiency is on the order of 80 percent due to lower uncontrolled emission rates, yielding approximately the same controlled NO_x emission rate. Thus, a typical achievable performance level for SCR systems on RFG-fired process heaters is 18 ppmv at 3% O₂, dry, or 0.011 lb/MMBtu.

SCR and Combustion Controls. This control option uses SCR downstream of combustion controls to reduce NO_x emissions. With this combination, the inlet NO_x level to the SCR is lower, so lower outlet NO_x can be achieved. However, the SCR may not achieve the same percent reduction performance compared to

no upstream combustion controls because of the lower NO_x inlet levels. As is discussed further below, a review of the USEPA RBLC and CARB BACT Clearinghouse showed permit limits of 7 ppmv NO_x at 3% O₂, dry, as the lowest level achieved in practice on refinery process heaters with SCR and combustion controls fired on a combination of RFG and natural gas. Therefore, the achievable performance level for SCR and combustion controls on RFG-fired process heaters is 7 ppmv at 3% O₂, dry, or about 0.0085 lb/MMBtu.

4. Evaluate Remaining Technologies

Technically feasible technologies are reviewed on a case-by-case basis taking into consideration energy, environmental, and economic impacts beginning with the top option. If the top option is not selected as BACT, the next most effective control is evaluated until it cannot be ruled out for energy, environmental, or economic reasons.

In this case, the top technically feasible control option, SCR with combustion controls, is the proposed control technology. Therefore, the selection of BACT consists of establishing the lowest controlled NO_x emission level achievable with this control technology, taking into consideration the lowest controlled NO_x emissions currently achieved in practice, and if necessary, energy, environmental and economic impacts between different potential controlled emission levels using this technology.

A review of the USEPA RLBC and CARB BACT Clearinghouse was conducted. These reviews resulted in the lowest NO_x emission limits for refinery heaters fired on RFG/natural gas found in the South Coast Air Quality Management District (SCAQMD). A review of the BACT Determinations published by the SCAQMD provided further details.

There were three SCAQMD BACT Determinations for 7 ppmv NO_x at 3% O₂, dry, documented in the USEPA *Petroleum Refinery Tier 2 BACT Analysis Report* (USEPA 2001) for process heaters burning natural gas or a combination of RFG and natural gas. These were for: (1) Chevron El Segundo Refinery (Permit No. D64697, D62860, D64621); (2) TOSCO Refinery, Wilmington (Application 326118);⁴ and (3) CENCO Refinery, Santa Fe Springs (Application 352869).

The ADEQ (2005) recently issued a permit for a similar project, Arizona Clean Fuels Yuma, LLC (ADEQ Permit Number 1001205). In their top-down BACT finding issued on 3 February 2005, the ADEQ summarized the following findings for the highest efficiencies achievable with SCR and combustion controls on RFG-fired process heaters (all 3-hour averages):

High-Efficiency SCR:

NO_x: 0.0085 lb/MMBtu (7 ppmv at 3% O₂, dry)⁵

⁴ Noted in the SCAQMD BACT Determinations to be for a 460-MMBtu/hr Hydrogen Reforming Furnace also combusting Pressure Swing Absorption (PSA) off gas.

⁵ Although the NO_x permit limit for Arizona Clean Fuels Yuma LLC is presented as ppm corrected to 3% O₂, dry, the ADEQ Technical Report presents results in ppm corrected to

Moderate-Efficiency SCR:

NO_x: 0.0125 lb/MMBtu (10 ppmv at 3%O₂, dry)

The ADEQ concluded for Arizona Clean Fuels Yuma LLC that the beneficial environmental impacts of increased NO_x control for the high-efficiency SCR was outweighed by adverse environmental impacts of increased ammonia slip. Therefore, the NO_x emissions level found to be BACT was 10 ppmv at 3% O₂, dry.

The proposed NO_x emission limit for the ConocoPhillips HGO Feed Heater is 7 ppmv at 3% O₂, dry. This is equivalent to the high-efficiency SCR option that was ruled out by ADEQ, and matches the lowest NO_x emission limit achieved in practice. No further energy, environmental, or economic impact assessment is needed.

5. Select BACT/ Document the Selection is BACT

Based on this review, NO_x BACT is proposed as SCR with combustion controls (low NO_x burners) at 7 ppmv at 3% O₂, dry, or 0.0086 lb/MMBtu.⁶

4.1.2 PM₁₀ BACT – U246 HGO Feed Heater

1. Identify All Available Control Technologies

Table 5 lists the control technologies identified for controlling PM₁₀ emissions from process heaters fired on natural gas or RFG.

Table 5 PM₁₀ Control Technologies

| Control Technology |
|---|
| Good Combustion Practice |
| Cyclone |
| Wet Gas Scrubber |
| Electrostatic Precipitator |
| Baghouse/Fabric Filters |
| <u>Good Combustion Practice.</u> By maintaining heaters in good working order and limiting the sulfur in the feed fuels, PM ₁₀ emissions are controlled. |
| <u>Cyclone.</u> A cyclone operates on the principle of centrifugal force. Exhaust gas enters tangentially at the top of the cyclone and spirals towards the bottom. As the gas spins, heavier particles hit the outside wall and are collected at the bottom. Cleaned gas escapes through an inner tube. |

0% O₂, dry. These have been converted to 3% O₂, dry, for the purposes of the ConocoPhillips analysis.

⁶ Slight difference from the previous conversions from 7 ppmv at 3% O₂, dry, due to fuel heat value assumptions and/or rounding.

Wet Gas Scrubber. A wet gas scrubber uses gas/liquid contacting to remove particles primarily by inertial impaction on liquid droplets, followed by collection of the larger liquid droplets as liquid waste.

Electrostatic Precipitator (ESP). An ESP uses an electric field to charge and collect particles in a gas stream, followed by collection of the particles on oppositely charged plates.

Baghouse/Fabric Filter. A baghouse is a metal housing containing many fabric bags. A partial vacuum pulls the dirty air through the fabric bags, filtering the particles from the exhaust stream.

2. Eliminate Technically Infeasible Options

All options in Table 5 are technically feasible.

3. Rank Remaining Technologies

See next (Step 4) discussion.

4. Evaluate Remaining Technologies

While the listed control technologies are all technically feasible, only good combustion practice is used for controlling PM₁₀ emissions from gas-fired heaters. The other technologies are not used because of inherently low PM₁₀ emissions from gaseous fuel combustion. A cyclone would be ineffective in capturing the extremely small particles generated from gaseous fuel combustion, and costs associated with designing the other add-on systems to capture minute particles in low concentrations would be economically infeasible. This is a well-accepted finding of all past BACT determinations for the control of PM₁₀ from combustion of gaseous fuels.

A review of the USEPA RLBC and CARB BACT Clearinghouse was conducted for currently achieved control levels. Findings were the same as summarized by the ADEQ for the Arizona Clean Fuels Yuma LLC (ADEQ 2005). ADEQ proposed a PM₁₀ emission limit of 0.0075 lb/MMBtu as representative of good combustion practice with gas-fired process heaters, based on the AP-42 emission factor (USEPA 1995a et seq.) for natural gas combustion and typical natural gas heat content. This is consistent with the lowest level achieved in practice.

5. Select BACT/ Document the Selection is BACT

Based on this review, PM₁₀ BACT is proposed as good combustion practice. The USEPA AP-42 natural gas combustion factor was adjusted with the estimated fuel heat content of the proposed RFG/natural gas mixture to calculate a proposed PM₁₀ BACT emission level of 0.0057 lb/MMBtu.

4.2 HYDROGEN PLANT REFORMER Furnace

The proposed new Hydrogen Plant Steam Methane Reformer (SMR) Furnace is proposed to be fired on a mix of approximately 85 percent Pressure Swing Absorption (PSA) off gas and 15 percent RFG/natural gas.

4.2.1 NO_x BACT – Hydrogen Plant Reformer Furnace

1. Identify All Available Control Technologies

The available technologies are the same as listed in Table 3 of Section 4.1.1.

2. Eliminate Technically Infeasible Options

All the control methods identified in Table 3 are considered technically feasible for a Hydrogen Plant Reformer fired on the proposed mix of fuels, except SCONO_x, SNCR, and water/steam injection, for the same reasons provided for a refinery process heater in Section 4.1.1.

3. Rank Remaining Technologies

Technically feasible NO_x control technologies are the same as listed in Table 4 of Section 4.1.1. Since the proposed mix of fuels includes natural and RFG, the emission levels presented in Table 4 can still be considered typical for this application. Inclusion of PSA off gas, however, affects combustion characteristics, and hence, can impact the actual achievable emission levels. Consideration of PSA off gas is included in the following BACT evaluation discussion.

4. Evaluate Remaining Technologies

Technically feasible technologies are reviewed on a case-by-case basis taking into consideration energy, environmental, and economic impacts beginning with the top option. If the top option is not selected as BACT, the next most effective control is evaluated until it cannot be ruled out for energy, environmental, or economic reasons.

In this case, the top technically feasible control option, SCR with combustion controls, is the proposed control technology. Therefore, the selection of BACT consists of establishing the lowest controlled NO_x emission level achievable with this control technology, taking into consideration the lowest controlled NO_x emissions currently achieved in practice, and if necessary, energy, environmental and economic impacts between different potential controlled emission levels using this technology.

A review of the USEPA RLBC and CARB BACT Clearinghouse was conducted. These reviews resulted in the lowest NO_x emission limits for hydrogen reformer furnaces fired on PSA off gas and RFG/natural gas found in the SCAQMD. A review of the SCAQMD BACT Determinations provided further details.

PSA off gas is high in hydrogen content, and therefore has the potential to form less NO_x and PM₁₀. There were five SCAQMD BACT Determinations for hydrogen reformer furnaces. In reverse chronological order, these NO_x emission limits were: (1) Chevron El Segundo Refinery (Application 411357, 5/19/2004, 5 ppmv at 3% O₂, dry); (2) Praxair, Ontario (Application 389926, 7/17/2002, 5 ppmv at 3% O₂, dry); (3) TOSCO Refinery, Wilmington (Application 326118, 9/9/1999, 7 ppmv at 3% O₂, dry); (4) Chevron El Segundo Refinery (Application 341340, 7/14/1999, 5 ppmv at 3% O₂, dry) and (5) Air Products and Chemicals, Inc. (Application 337979, 6/16/1999, 5 ppmv at 3% O₂, dry).

The proposed NO_x emission limit for the Air Liquide Hydrogen Reformer is 5 ppmv at 3% O₂, dry. Since this is the lowest NO_x emission limit achieved in practice, no further energy, environmental, or economic impact assessment is needed.

5. Select BACT/ Document the Selection is BACT

Based on this review, NO_x BACT is proposed as SCR with combustion controls (low NO_x burners) at 5 ppmv at 3% O₂, dry, or 0.0058 lb/MMBtu.

4.2.2 PM₁₀ BACT – Hydrogen Plant Reformer Furnace

1. Identify All Available Control Technologies

The available technologies are the same as listed in Table 5 of Section 4.1.2.

2. Eliminate Technically Infeasible Options

All options in Table 5 are technically feasible.

3. Rank Remaining Technologies

See next (Step 4) discussion.

4. Evaluate Remaining Technologies

While the listed control technologies are all technically feasible, only good combustion practice is used for controlling PM₁₀ emissions from gas-fired heaters, as described in Section 4.1.2.

A review of the USEPA RLBC and CARB BACT Clearinghouse was conducted for currently achieved control levels. No applicable PM₁₀ BACT emission levels were found. The five SCAQMD BACT Determinations for hydrogen reformer furnaces did not include PM₁₀, thus, from Section 4.1.2, a PM₁₀ emission limit of 0.0075 lb/MMBtu is representative of good combustion practice with gas-fired process heaters. In this case, the proposed Hydrogen Reformer will fire up to 85 percent PSA off gas, which produces less PM₁₀ emissions due to high hydrogen content. It is proposed that with the inclusion of PSA off gas, a reasonable PM₁₀ emission limit would be half the amount produced by natural gas alone, or 0.0037 lb/MMBtu.

5. Select BACT/ Document the Selection is BACT

Based on this review, PM₁₀ BACT is proposed as good combustion practice at 0.0037 lb/MMBtu. The proposed PM₁₀ emissions level is consistent with the lowest level achieved in practice, with further consideration given for the PSA off gas in the fuel mixture.

4.3 SULFUR RECOVERY UNIT (SRU)

The proposed new Unit 235 SRU will be a closed Claus process supported by an amine-based TGTU to convert unreacted hydrogen sulfide (H₂S) from the Claus process. The TGTU is also a closed process. Any unreacted H₂S in the tail gas passing through the TGTU will be oxidized in a new tail gas incinerator, which is the emission point for the process. Vents from the new sulfur loading rack will also be routed to the tail gas incinerator for oxidation of H₂S. Therefore, BACT for the SRU was assessed for NO_x and PM₁₀ from the tail gas incinerator.

4.3.1 NO_x BACT – SRU Tail Gas Incinerator

1. Identify All Available Control Technologies

The available technologies are the same as listed in Table 3 of Section 4.1.1.

2. Eliminate Technically Infeasible Options

The only option listed in Table 3 that is technically feasible for an SRU tail gas incinerator is combustion control with low-NO_x burners. The other technologies are either based on lowering flame temperature, which is not compatible with the primary function of the incinerator (i.e., efficient oxidation of reduced sulfur compounds), or add-on controls that have not been demonstrated technically feasible for a thermal oxidizer. There are significant technical differences between thermal oxidizers and the combustion sources for which these technologies have been demonstrated in practice.

3. Rank Remaining Technologies

The only technically feasible NO_x control technology is combustion control with low-NO_x burners.

4. Evaluate Remaining Technologies

Technically feasible technologies are reviewed on a case-by-case basis taking into consideration energy, environmental, and economic impacts beginning with the top option. If the top option is not selected as BACT, the next most effective control is evaluated until it cannot be ruled out for energy, environmental, or economic reasons.

In this case, a review of the USEPA RLBC and CARB BACT Clearinghouse was conducted for the most efficient low-NO_x burners achieved in practice for tail gas thermal oxidizers for SRU TGTUs. These reviews resulted in the lowest NO_x emission limit achieved in practice as 42.2 ppmv @ 7% O₂, dry, or 0.0667 lb/MMBtu, associated with the recently issued PSD permit for the SRU TGTU at the ConocoPhillips Ferndale Refinery. This level, for a unit currently in operation, is similar to the 0.06 lb/MMBtu level proposed by the ADEQ for the Arizona Clean Fuels Yuma LLC (ADEQ 2005), a facility not yet in operation.

5. Select BACT/ Document the Selection is BACT

Based on this review, NO_x BACT is proposed as combustion control with low-NO_x burners at 42.2 ppmv at 7% O₂, dry, or 0.0667 lb/MMBtu.

4.3.2 PM₁₀ BACT – SRU Tail Gas Incinerator

1. Identify All Available Control Technologies

The available technologies are the same as listed in Table 5 of Section 4.1.2.

2. Eliminate Technically Infeasible Options

All options in Table 5 are technically feasible.

3. Rank Remaining Technologies

See next (Step 4) discussion.

4. Evaluate Remaining Technologies

While the listed control technologies are all technically feasible, only good combustion practice is used for controlling PM₁₀ emissions from the combustion of gaseous fuels, as described in Section 4.1.2.

A review of the USEPA RLBC and CARB BACT Clearinghouse was conducted for currently achieved control levels. No applicable PM₁₀ BACT emission levels were found. It is proposed that reasonable PM₁₀ emission limit would be the amount produced by natural gas alone, or 0.0075 lb/MMBtu.

5. Select BACT/ Document the Selection is BACT

Based on this review, PM₁₀ BACT is proposed as good combustion practice at 0.0075 lb/MMBtu. The proposed PM₁₀ emissions level is consistent with the lowest level achieved in practice.

4.4 New Flaring

The proposed project includes a new Hydrogen Plant flare that would operate during planned and unplanned events. The shutdown and startup of the new Unit 240/246 would also cause new flaring emissions from the existing Main Flare, but this is estimated to occur only once every three years.

Flares operate primarily as air pollution control devices, but are nonetheless emission sources subject to BACT analyses. The technically feasible control options for emissions of all pollutants from flares are equipment design specifications and work practices: minimizing exit velocity, ensuring adequate heat value of combusted gases, and minimizing the quantity of gases combusted. Each of these control options is technically feasible and is required for the operation of emergency flares at the refinery.

The equipment design criteria for emergency flares are based largely on the parallel requirements set forth in the NSPS regulations (40 CFR 60.18) and the National Emission Standards for Hazardous Air Pollutants (NESHAP) regulations (40 CFR 63.11). These include a maximum allowable exit velocity, a requirement for smokeless operation, and a minimum allowable net heating value for gases combusted in the flares. ConocoPhillips is not aware of any more stringent requirements imposed on flares at any other petroleum refinery, nor any other technically feasible control options for emissions of any pollutants from flares.

FINAL: October 5, 2007

Evaluation Report, Application 13424, ConocoPhillips Refinery, Facility A0016, Rodeo CA

APPENDIX E
Kb letter

FINAL: October 5, 2007

Evaluation Report, Application 13424, ConocoPhillips Refinery, Facility A0016, Rodeo CA

Appendix F

PSD Re-delegation Agreement.

FINAL: October 5, 2007

Evaluation Report, Application 13424, ConocoPhillips Refinery, Facility A0016, Rodeo CA

Appendix g

CEQA Findings

**CONOCOPHILLIPS – SAN FRANCISCO REFINERY
PROPOSED CLEAN FUELS EXPANSION PROJECT**

**FINDINGS AND SUPPORTING FACTS REGARDING THE
ENVIRONMENTAL IMPACT REPORT**

ConocoPhillips - San Francisco Refinery (The Refinery) has proposed to construct the Clean Fuels Expansion Project (CFEP) at its Rodeo Refinery. The CFEP includes new equipment and modifications to existing equipment that would enable the Refinery to process heavy gas oil (HGO), which is a by-product that is currently produced onsite and exported. Implementation of the CFEP would allow overall Refinery production to increase by up to 1,000,000 gallons per day (30 percent over current levels).

The CFEP includes the following: (1) construction of a new Hydrogen Plant to be built by Air Liquide with a capacity of 120 million standard cubic feet per day; (2) construction of a new Sulfur Recovery Unit with a capacity increase of 200 long tons per day; (3) conversion of a retired lube oil rail car loading rack into a butane rail car loading rack; (4) expansion of the Unicracker to allow for HGO hydrocracking and resulting in an increase in capacity of 23,000 barrels per day (bbl/day); (5) Reformer (Unit 244) modifications resulting in a capacity increase from 16,087 bbl/day to 18,500 bbl/day; (6) UNISAR (Unit 248) modifications resulting in a capacity increase from 8,812 bbl/day to 16,740 bbl/day; (7) Product Blending Unit (Unit 76) modifications resulting in a capacity increase from 90,411 bbl/day to 113,150 bbl/day; (8) Deisobutanizer (Unit 215 DIB) modifications resulting in a capacity increase from 7,600 bbl/day to 10,200 bbl/day; (9) Sulfur Recovery Plant (Units 234, 236, 238) modifications that would include a new sulfur degassing system, a new sulfur loading rack, a modified or replaced amine regenerator and an increase in sulfur storage capacity; and (10) modifications to ancillary facilities such as pumps, heat exchangers, instrumentation, utilities and piping.

Contra Costa County Community Development Department (CDD) acted as Lead Agency under the California Environmental Quality Act (CEQA) for this project. As a responsible agency under CEQA, the Bay Area Air Quality Management District (BAAQMD) participated in the EIR process, including reviewing and commenting on the Draft EIR. The following timeline illustrates the land use permit application's progress from approval by County Planning Commission (CPC) to present:

- April 24, 2007 – Public hearing held before the CDD in Martinez to consider certification of the Final EIR and approval of the CFEP.
- May 8, 2007 – Second CPC hearing held in Martinez. Final EIR was certified and project was approved with new and modified Conditions of Approval.
- May 17, 2007 – Appeal received from Communities for a Better Environment and Center for Biological Diversity (CBE/CBD), joint appellants.
- May 18, 2007 – Appeal received from ConocoPhillips Company and appeal received from the California State Attorney General.

- September 10, 2007 – California Attorney General withdrew his May 18, 2007 appeal and submits a copy of Settlement Agreement with ConocoPhillips Company. Concurrently, ConocoPhillips requests that the County include language from the Settlement Agreement in the County’s action on its appeal.
- September 25, 2007 – Board of Supervisors hearing held in Martinez. Final EIR was certified and project was approved. Board accepted the September 10, 2007 letter from the California Attorney General withdrawing their May 18, 2007 appeal. The Board denied the appeals of Communities for a Better Environment (CBE) and Center for Biological Diversity (CBD). The Board also granted the appeal of ConocoPhillips Company based on their revised proposed condition of approval addressing the storage of rail cars.

The EIR identified certain potentially significant environmental impacts that could occur as a result of the CFEP. The following discussion summarizes the air quality related effects identified in the EIR and during the District’s review of the ConocoPhillips and Air Liquide permit applications, makes one or more of the findings required under Section 15091 of the State CEQA Guidelines, and presents facts to support the findings. All of these effects have been mitigated to a level of insignificance.

Impact 1 – Construction activities associated with CFEP would generate short-term emissions of criteria pollutants, including suspended and respirable particulate matter and equipment exhaust emissions, which would contribute to existing air quality violations.

Mitigated to insignificance. Particulate emissions will be mitigated by implementation of comprehensive dust control measures including watering all active construction areas at least twice daily; covering of haul trucks or requiring all trucks to maintain at least two feet of freeboard; paving or otherwise stabilizing haul roads, parking and staging areas; and sweeping daily with water sweepers all paved access roads, parking areas and staging areas at construction sites. The following “enhanced” control measures will also be implemented: Hydroseeding or application of non-toxic soil stabilizers to inactive construction areas; enclosing, covering, watering twice daily or application of non-toxic soil binders to exposed stockpiles; installation of sandbags or other erosion control measures to prevent silt runoff to public roadways; suspension of excavation and grading activity when winds exceed 25 mph; installation of wheel washers for all exiting trucks, or washing off the tires or tracks of all trucks and equipment leaving the site.

Equipment emissions will be mitigated by regular equipment maintenance and limits to unnecessary idling. Other equipment mitigation measures include the following: use of alternative fuels and/or alternatively fueled equipment; use of post-1996 model diesel trucks only at the site or for on-road hauling of construction material; requirement for all construction diesel engines with a rating of 100 hp or more to meet at a minimum the Tier 2 California Emission Standards for Off-Road Compression –Ignition Engines unless certified by the onsite Construction Air Quality Mitigation Manager (CAQMM) that such an engine is not available for a particular item of equipment; offering incentives to encourage construction workers to carpool

or employ other means of transportation; scheduling construction activities to allow at least 33% of the construction workforce to avoid the morning and afternoon peak traffic periods; and use of on-site power to minimize reliance on portable generators.

Impact 2 – Operational activities associated with the implementation of the CFEP would increase air pollutant emissions, contributing to existing air quality violations.

Mitigated to insignificance. As required by BAAQMD Rules and Regulations, project emissions will be mitigated by application of Best Available Control Technology (BACT) and by obtaining emission offsets. Specifically, following mitigation measures will be implemented:

- The four Dissolved Air Flotation (DAF) vents associated with the onsite wastewater treatment plant will be routed to a Thermal Oxidizer with a destruction efficiency of no less than 98 percent. The DAF outlet channel and downstream sumps will be sealed by a solid cover with gaskets. Any vents installed on the covered channel will be routed to the thermal oxidizer. Installation of these controls will reduce organic emissions by at least 242 pounds per day and 44.1 tons per year.
- The Refinery Steam Power Plant uses three gas turbines to generate electricity, and uses gas turbine waste heat to generate steam. Each gas turbine has a nitrogen oxide (NO_x) catalyst system located at the base of the exhaust stack. The Refinery will take a new permit limit to achieve a reduction of NO_x concentration in each stack by 1 ppm from its current operating baseline. This 1 ppm of NO_x equates to a reduction of 81 pounds per day and 14.7 tons per year.
- Operations at the ConocoPhillips' Carbon Plant will be modified to result in a decrease in SO₂ emissions of at least 230 pounds per day and 42 tons per year. The refinery will take a new permit limit to reflect this reduction.
- The baghouse at the Carbon Plant will use improved bag technology to capture particulate matter (PM₁₀) from the calcined coke operation. Installation of the improved bag-technology will reduce PM₁₀ emissions by at least 43.8 pounds per day and 8.0 tons per year. The refinery will take a new permit limit to reflect this reduction.
- Net reductions in ROG emissions associated with the mitigated CFEP will be used to offset 36 pounds per day and 7.6 tons per year of NO_x associated with the CFEP.

Impact 3 – The CFEP would contribute to cumulative regional air emissions; however, it would not be cumulatively considerable and it would not conflict with or obstruct implementation of the applicable air quality plan.

Mitigated to insignificance. As discussed in Impact 2, with the proposed mitigation measures, the CFEP would have a less-than-significant impact on air quality. Furthermore, as discussed in Section 4.10, Land Use, in Final EIR, the CFEP is consistent with the Contra Costa County

General Plan which in turn is consistent with the BAAQMD's current air quality plan (2005 Ozone Strategy).

Impact 4 – Operational activities associated with the implementation of the CFEP could lead to increases in odorous emissions. This would be a less-than-significant impact.

No mitigation required. The CFEP will not result in increased odors because the hydrocracking process that would be used to process heavy gas oil produces clean intermediate feedstocks and blendstocks. Storing these products in existing tanks will not increase odors. Also, CFEP contains numerous design features that will reduce odor emissions from existing equipment and minimize the likelihood of odor emissions from the project's new equipment. CFEP-related design features include the following:

- A fourth compressor will be added to the odor abatement system. This will increase the robustness of the odor control system. The new compressor will be sized at approximately 3.3 MMSCFD and is slated to commence operation in March 2009.
- The new compressor will primarily be loaded with odor abatement gases but will be operated so that during most periods, it can pick up the swings that occur during brief peak loading on the existing G-503, Flare Gas Recovery (FGR) compressor. This new compressor will also be used to mitigate flaring when the G-503 FGR compressor is down for planned or emergency maintenance. This additional flare gas recovery capacity will further reduce odor-causing flaring.
- The vapor recovery will be installed on existing fixed-roof tanks that will change service to store heavy gas oil and sour water.
- The Odor abatement system will be subject to new and more stringent permit conditions by the BAAQMD to eliminate and/or minimize odor complaints.
- A new sulfur recovery unit will increase system redundancy and improve the refinery's ability to react to upset conditions for processing sulfur gases. This will reduce the number of refinery upsets and shutdowns.
- Molten sulfur loaded into trucks will be degassed prior to loading, which will reduce the H₂S emissions.
- The Dissolved Air Flotation unit at the wastewater treatment plant will be vented to a thermal oxidizer.
- After startup of the CFEP, less heavy gas oil will be loaded onto barges, which vent to the atmosphere.

As required by the State CEQA Guidelines, the BAAQMD, as a Responsible Agency for the ConocoPhillips CFEP, hereby finds that, for each of the impacts identified in the final EIR and

FINAL: October 5, 2007

Evaluation Report, Application 13424, ConocoPhillips Refinery, Facility A0016, Rodeo CA

discussed above, changes or alterations have been required in, or incorporated into, the project which avoid or substantially lessen the significant environmental effect as identified in the final EIR. In addition, for those mitigation measures that are identified in the final EIR to lessen impacts associated with construction activities and vehicle emissions and that are within the responsibility or jurisdiction of another public agency, the BAAQMD hereby finds that such measures either have been or can and should be adopted by such other agency.

In accordance with BAAQMD Rules and Regulations, the BAAQMD has fully considered the EIR prepared and certified by the Contra Costa County and has incorporated the EIR's analysis into its decision-making process. The BAAQMD granted an Authority to Construct for the proposed project on October 5, 2007.

The documents and other materials that constitute the record of proceedings upon which this decision is based are located at the BAAQMD office at 939 Ellis Street, San Francisco, California, and the custodian of the materials is Rochelle Henderson.

Jack P. Broadbent
Executive Officer/Air Pollution Control Officer
Bay Area Air Quality Management District