

**REGULATION 9
INORGANIC GASEOUS POLLUTANTS
RULE 4
NITROGEN OXIDES FROM NATURAL GAS-FIRED ~~FAN-TYPE RESIDENTIAL~~
~~CENTRAL~~ FURNACES**

INDEX

9-4-100 GENERAL

9-4-101 Description

9-4-200 DEFINITIONS

~~9-4-201 Fan Type Central Furnace~~

9-4-201~~2~~ Annual Fuel Utilization Efficiency ([AFUE](#))

[9-4-202 BTU](#)

[9-4-203 Heat Input](#)

[9-4-204 Natural Gas](#)

[9-4-205 Natural Gas-Fired Fan Type Central Furnace](#)

[9-4-206 Natural Gas-Fired Furnace](#)

[9-4-207 Nitrogen Oxides \(NO_x\)](#)

9-4-208~~3~~ Useful Heat Delivered to the Heated Space

9-4-300 STANDARDS

9-4-301 ~~Residential-Central~~ [Natural Gas-Fired Ffurnace Emission Standards](#)

9-4-302 Certified Furnaces

9-4-400 ADMINISTRATIVE REQUIREMENTS

9-4-401 Certification

9-4-402 Compliance Statement

9-4-403 Identification

9-4-404 Enforcement

[9-4-405 Interim Report](#)

9-4-500 MONITORING AND RECORDS (NOT INCLUDED)

9-4-600 MANUAL OF PROCEDURES (~~NOT INCLUDED~~)

[9-4-601 Determination of Emissions](#)

REGULATION 9
INORGANIC GASEOUS POLLUTANTS
RULE 4
NITROGEN OXIDES FROM NATURAL GAS-FIRED ~~FAN-TYPE RESIDENTIAL~~
~~CENTRAL~~ FURNACES

9-4-100 GENERAL

9-4-101 Description: This Rule limits emissions of nitrogen oxides from natural gas-fired ~~fan type residential-central~~ furnaces.

(Amended December 7, 1983)

9-4-200 DEFINITIONS

~~**9-4-201 Fan Type Central Furnace:** A self-contained space heater providing for circulation of heated air at pressures other than atmospheric through ducts more than 25 cm (10 in) in length with an input rate of less than 175,000 BTU/hr, excluding heating/cooling units utilizing three phase electric current.~~

~~*(Amended December 7, 1983)*~~

9-4-201² Annual Fuel Utilization Efficiency (AFUE): The efficiency as defined by Section 4.2.35 of the Code of Federal Regulations, Title 10, Part 430, Subpart B, Appendix N.

(Amended December 7, 1983)

9-4-202 BTU: British thermal unit or units.

9-4-203 Heat Input: The heat of combustion based on the gross (higher) heating value of the fuel, excluding the enthalpy of incoming combustion air.

9-4-204 Natural Gas: A mixture of gaseous hydrocarbons containing at least 80% methane by volume as determined by ASTM Standard D1945, 2003.

9-4-205 Natural Gas-Fired Fan Type Central Furnace: A self-contained space heater providing for circulation of heated air at pressures other than atmospheric through ducts more than 25 cm (10 in) in length with a heat input rate of less than 175,000 BTU/hr. This includes combination heating/cooling units with natural gas heating and also an electric cooling rate less than 65,000 BTU/hr.

9-4-206 Natural Gas-Fired Furnace: A product with a heat input rate less than 175,000 BTU/hr which utilizes single-phase, three-phase or DC current in conjunction with natural gas, which is designed to be a source of interior space heating.

9-4-207 Nitrogen Oxides (NO_x): The sum of nitrogen oxide (NO) and nitrogen dioxide (NO₂), collectively expressed as nitrogen dioxide.

9-4-208³ Useful Heat Delivered to the Heated Space: The Annual Fuel utilization efficiency (expressed as a fraction) multiplied by the heat input.

(Amended December 7, 1983)

9-4-300 STANDARDS

9-4-301 ~~Residential Central Natural Gas-Fired~~ Furnace Emission Standards: ~~A person shall not sell, install or offer for sale within the District any stationary residential natural gas-fired fan type central furnace manufactured after January 1, 1984 that emits more than 40 nanograms of oxides of nitrogen expressed as NO₂ per joule of useful heat delivered to the heated space.~~ A person shall not sell, install or offer for sale within the District:

301.1 Any stationary residential natural gas-fired fan type central furnace manufactured after January 1, 1984, that emits more than 40 nanograms of nitrogen oxides expressed as NO₂ per joule of useful heat delivered to the heated space.

301.2 Any natural gas-fired fan type central furnace manufactured after July 1, 2023, that emits more than 14 nanograms of nitrogen oxides expressed as NO₂ per joule of useful heat delivered to the heated space.

301.3 Any natural gas-fired furnace manufactured after January 1, 2029, that emits more than 0 nanograms of nitrogen oxides expressed as NO₂ per joule of useful heat delivered to the heated space. This includes non-central installations such as wall furnaces as well as units installed in non-residential applications. This section does not apply to furnaces used for mobile homes.

(Amended December 7, 1983)

9-4-302 Certified Furnaces: A person shall not sell, install or offer for sale within the District furnaces subject to the requirements of Section 9-4-301 unless such furnaces are certified in accordance with Sections 9-4-401, 402, 403, and 404.

(Amended and Renumbered December 7, 1983)

9-4-400 ADMINISTRATIVE REQUIREMENTS

9-4-401 Certification: The manufacturer shall have each appliance model tested in accordance with the following:

401.1 Nitrogen oxides, carbon dioxide and oxygen measurements, test equipment, and other required test procedures shall be in accordance with ~~Oxides of nitrogen measurements, test equipment, and other required test procedures shall be in accordance with methods and standards or equivalent procedures approved by the APCO. Section 9-4-601.~~

401.2 Operation of the furnace shall be in accordance with the procedures specified in Section 3.1 of the Code of Federal Regulations, Title 10, Part 430, Subpart B, Appendix N.

401.3 ~~The following calculation~~ One of the two formulas shown below shall be used to determine the nanograms emissions of NO_x in units of nanograms per joule of useful heat delivered to heated space:

$$N = \frac{3.655 \times 10^{10} \times P}{20.9 \times Y \times Z \times E}$$

or

$$N = \frac{4.566 \times 10^4 \times PU}{H \times C \times E}$$

Where:

N = ~~Nanograms~~ Calculated emissions of NO_x (~~nanograms emitted~~ per joule of useful heat delivered to the heated space).

P = Measure concentration of NO_x in flue gas (parts per million by volume)

Y = Measured concentration ~~Percentage~~ of O₂ in flue gas (percentage by volume).

Z = Gross heating value of fuel (joules per cubic meter at 0.0 degrees Celcius, 1 atm).

E = AFUE (percentage), as defined in Section 9-4-201

- U = Concentration of CO₂ in water-free flue gas for stoichiometric combustion (percentage by volume), as determined by South Coast AQMD protocol.
- H = Gross heating value of the fuel (BTU per cubic foot, 60°F, 30-in Hg.)
- C = Measured concentration of CO₂ in flue gas (percentage by volume).
(Amended December 7, 1983)

9-4-402 Compliance Statement: The manufacturer shall submit to the APCO a statement that the model is in compliance with this Rule. The statement shall be signed and dated, and shall attest to the accuracy of all information. The statement shall include the brand name and model number as it appears on the furnace rating plate. ~~and be on forms provided by the APCO.~~ In lieu of a compliance statement, the manufacturer may submit to the APCO a valid South Coast Air Quality Management District (SCAQMD) certification for SCAQMD Rule 1111 for units demonstrating compliance with Section 9-4-301.2.

(Amended December 7, 1983)

9-4-403 Identification: The manufacturer shall display the model number of the furnace complying with this rule on the shipping carton and rating plate.

9-4-404 Enforcement: The APCO may require the emission test results to be provided when deemed necessary to verify compliance and may periodically conduct such tests as are deemed necessary to ensure compliance.

9-4-405 Interim Report: No later than two years prior to the compliance date listed in Section 301.3 of this Rule, the APCO shall present to the Air District Board of Directors for consideration at a public meeting a report that includes the technology options currently (and projected to be) available to comply with the standard in Section 301.3 of this Rule; the market availability of such technology; the projected costs of purchase and installation of such technology, including electrical panel upgrades, as applicable; and any incentive programs available to reduce these costs.

9-4-600 MANUAL OF PROCEDURES

9-4-601 Determination of Emissions: Furnaces subject to Sections 9-4-301 and 302 shall be tested in accordance with the following provisions:

601.1 Certification shall be based on emission tests of a randomly selected unit of each furnace model.

601.2 The measurement of nitrogen oxides emissions shall be conducted in accordance with the Manual of Procedures, Volume IV, Method ST-13A or US EPA Reference Method RM-7 (40 CFR Part 60, Appendix A, Test Method 7E.

601.3 The measurement of carbon dioxide shall be conducted in accordance with the Manual of Procedures, Volume IV, Method ST-5 or US EPA Method 3A.

601.4 The measurement of oxygen shall be conducted in accordance with the Manual of Procedures, Volume IV, Method ST-14 or US EPA Method 3A.