

4114 Lakeside Drive
Richmond, CA 94806



909 Montgomery St., Suite 260
San Francisco, California 94133
T 415 546 1212 breton.com

Stamp



Consultant

AWA
Amit Wadhwa & Associates
Engineers
870 Market Street
19th Floor, Suite 400
San Francisco, CA 94102
415.786.5593 fax
415.617.2076 text
19098

Issue/Revision:

No.	Date	Description
1	3/22/24	32249.01 ISSUE FOR REVIEW 29F1AR19
2	3/22/24	32249.01 ISSUE FOR PERMIT 22AFR19

Copyright Statement:
All drawings and written material appearing herein constitute original and unpublished original work of the architect and may not be duplicated, used, or disclosed without prior written consent of the architect.
Approval Signature:

Co./ Title: Date:

GENERAL NOTES, LEGEND & DRAWING INDEX

Scale: NONE Issue Date: 1/7/24
Drawn By: PT Reviewed By: AM
Sheet: 1 of 15

1M0.0.1

LEGEND		
SYMBOL	ABBR	DESCRIPTION
		EQUIPMENT IDENTIFICATION EQUIPMENT NUMBER (FLOOR NUMBER – UNIT SEQUENCE)
	CSD1	CEILING SUPPLY AIR DIFFUSER
	CRG1	CEILING RETURN AIR GRILLE
	CEG1	CEILING EXHAUST AIR GRILLE
		CEILING ACCESS PANEL
$\frac{\text{CODE}}{X}$ CFM		AIR OUTLET DESIGNATION CODE AND CFM INLET NECK SIZE
$\frac{\text{CODE}}{\text{CFM}}$		EXHAUST AIR OUTLET DESIGNATION CODE CFM
		(E) DUCTWORK, PIPING OR EQUIPMENT TO REMAIN
		(E) DUCTWORK, PIPING OR EQUIPMENT TO BE REMOVED
		(N) OR (R) DUCTWORK, PIPING OR EQUIPMENT
	AL	ACOUSTICAL LINING (1" FIBER FREE, UON)
		SQUARE TO ROUND DUCT
		REDUCING TRANSITION
	VD	VOLUME DAMPER
		VOLUME DAMPER WITH REMOTE REGULATOR
		FLEX CONNECTION
	FD, FSD	FIRE DAMPER, COMBINATION FIRE/SMOKE DAMPER
	R, D	DUCT RISE, DUCT DROP
		FLEXIBLE DUCT
	CFF	CAPPED FOR FUTURE
		DUCT DOWN
		DIRECTION OF AIRFLOW
		THERMOSTAT
		SWITCH
		DUCT SMOKE DETECTOR
	CTE	CONNECT TO EXISTING
	(E)	EXISTING
	(N)	NEW
	(R)	RELOCATED
	OSA	OUTSIDE AIR
	RA	RETURN AIR
	EA	EXHAUST AIR
	ACV	AUTOMATIC CONTROL VALVE
	BMS	BUILDING MANAGEMENT SYSTEM
	BDD	BACKDRAFT DAMPER
	UON	UNLESS OTHERWISE NOTED
	AFF	ABOVE FINISHED FLOOR
	CD	CONDENSATE DRAIN
	N/A	NOT APPLICABLE
	EF	EXHAUST FAN
	SAD	SEE ARCHITECTURAL DRAWINGS

GENERAL NOTES

- CONTRACTOR SHALL CONFIRM ALL EXISTING CONDITIONS SHOWN ON THE DRAWINGS BEFORE START OF THIS WORK. DISCREPANCIES, IF ANY, MUST BE BROUGHT TO THE ATTENTION OF THE ARCHITECT IMMEDIATELY.
- CONTRACTOR SHALL FOLLOW LATEST VERSION BUILDING TENANT CONSTRUCTION STANDARDS.
- ALL BRANCH DUCTS CONNECTING TO DIFFUSERS TO BE OF SAME SIZE AS DIFFUSER NECK. (EXAMPLE: FOR DIFFUSER NECK SIZE 10" X 10". USE 10" ROUND DUCT).
- USE ROUND TO SQUARE TRANSITION AT THE DIFFUSER NECK.
- ALL BRANCH DUCTS CONNECTING TO VAV BOXES TO BE OF SAME SIZE AS VAV BOX INLET, UON. SEE VAV BOX SCHEDULE FOR VAV BOX INLET SIZE.
- PROVIDE CONICAL TAKE-OFF FOR ALL NEW VAV BRANCH DUCTS CONNECTING TO EXISTING MAIN SUPPLY AIR LOOP.
- SEAL ALL PIPE AND DUCT OPENINGS THROUGH FIRE RATED PARTITIONS USING FIRE SAFING FOAM.
- RELOCATE EXISTING PIPES, DUCTWORK, ELECTRICAL CONDUITS, ETC. TO ACCOMMODATE NEW WORK.
- PROVIDE AIR/WATER BALANCING FOR ALL SYSTEMS SHOWN ON THE DRAWING. (AIR OUTLETS, VRF, FAN COIL UNITS, AC UNITS, EF, ETC.) BALANCING SHALL BE PERFORMED BY AABC CERTIFIED INDEPENDENT FIRM AS PER BUILDING STANDARDS. MEASURE AND DOCUMENT SUPPLY AIR TEMPERATURE AT FULL HEATING AND FULL COOLING MODES.
- MAINTAIN MINIMUM 2 FEET CLEARANCE IN FRONT OF THE VAV BOX CONTROLLER.
- INSTALL EQUIPMENT AS HIGH AS POSSIBLE.
- LOCATE THERMOSTATS SERVING FAN COILS/AC UNIT PER MECHANICAL FLOOR PLANS. COORDINATE EXACT LOCATION IN THE FIELD WITH ARCHITECT AND FURNITURE. FURNITURE SHALL NOT OBSTRUCT THERMOSTAT. TOP OF THE THERMOSTAT SHALL BE INSTALLED 48" AFF.
- CEILING AND PLENUM SPACE FOR THIS PROJECT IS VERY LIMITED. VERY CLOSE COORDINATION BETWEEN THIS CONTRACTOR, ELECTRICAL, FIRE PROTECTION CONTRACTOR, PLUMBING CONTRACTOR, DATA AND SECURITY CONTRACTORS IS MANDATORY. MECHANICAL CONTRACTOR SHALL NOT START DUCTWORK FABRICATION UNTIL ALL AREAS OF THE PLENUM SPACE ARE FULLY COORDINATED AT ALL LOCATIONS. ADJUST AND PROVIDE DUCT SLICE FITTINGS, DUCT SIZES, SEAM SPACING, ETC. AS REQUIRED. PRODUCE SHOP DRAWINGS AND COORDINATE LAYOUT WITH ALL TRADES.
- ALL PIPING, DUCTWORK, CONDUITS, WIRING, ETC. SHALL BE INSTALLED PARALLEL AND PERPENDICULAR TO BUILDING LINES.
- LIFE SAFETY WORK/ INTERFACE (INCLUDING DUCT SMOKE DETECTORS) SHALL BE PROVIDED BY THE BUILDING'S LIFE SAFETY CONTRACTOR.
- PROVIDE BUILDING STANDARD DUCT SMOKE DETECTOR AT NEW FC/AC UNITS AND WHERE SHOWN. DUCT DETECTOR SHALL BE FURNISHED AND INSTALLED BY DIV. 15. ELECTRICAL WIRING SHALL BE BY DIV. 16. LIFE SAFETY WIRING AND INTERFACING WITH BUILDING'S LIFE SAFETY SYSTEM SHALL BE BY THE BUILDING'S LIFE SAFETY SYSTEM PROVIDER. UPON SMOKE DETECTION ASSOCIATED FAN COIL/AC UNIT SHALL STOP OPERATION.

CONTROLS

- PROVIDE STANDALONE CONTROLS BY VRV SYSTEM MANUFACTURER.
- SET THERMOSTATS TO THE FOLLOWING, UON.:
 - FAN COIL UNITS (FC 1–1, 1–3, FC 1–4) – 74°F(COOLING), 70°F(HEATING) – ADJUSTABLE
 - FAN COIL UNIT (FC 1–2, –5) – 70°F(COOLING) – ADJUSTABLE
 - ROOF TOP UNIT (E)AC–1 74°F(COOLING), 70°F(HEATING) – ADJUSTABLE
- ALL CONTROL WIRING SHALL BE NEATLY TIED TO THE BUILDING STRUCTURE.

SCOPE OF WORK

- NEW AIR DISTRIBUTION DUCTWORK AND AIR OUTLETS ARE BEING PROVIDED.
- (5) NEW FAN COIL UNITS (VRV SYSTEM) ARE BEING ADDED.
- (1) NEW CONDENSING UNIT (VRV SYSTEM) IS BEING ADDED.
- (1) NEW ROOF MOUNTED EXHAUST FAN IS BEING ADDED.
- NO NEW FSD IS BEING ADDED.

CALGREEN COMPLIANCE REQUIREMENTS

COMPLY WITH THE REQUIREMENTS OF THE LATEST EDITION OF THE CALIFORNIA GREEN CODE REQUIREMENTS WITH LOCAL AMENDMENTS INCLUDING BUT NOT LIMITED TO THE FOLLOWING:

- PROVIDE EQUIPMENTS AND CONTROLS TO COMPLY WITH THE T–24 ENERGY EFFICIENCY REQUIREMENTS.
- PLUMBING TRADE WORK TO PROVIDE WATER-EFFICIENT PLUMBING FIXTURES AND FAUCETS TO COMPLY WITH THE WATER EFFICIENCY REQUIREMENTS.
- PROVIDE EQUIPMENTS THAT DO NOT USE ENVIRONMENTALLY HARMFUL REFRIGERANTS SUCH AS CFCs, HCFCs, AND HALONS. NO NEW REFRIGERANT USING HVAC EQUIPMENT SPECIFIED FOR THE REMODELED SPACE.
- WHEN INSTALLING DUCTWORK, PIPING AND EQUIPMENTS, KEEP THE OPENINGS COVERED WITH SHEETMETAL CAPS TO ENSURE THAT CONSTRUCTION DUST AND POLLUTANTS DO NOT ENTER THE SYSTEM. PROTECT THE RETURN AIR SYSTEM DUCT OPENINGS WITH MERV 8 CONSTRUCTION FILTERS. REMOVE THE FILTERS AFTER THE CONSTRUCTION WORK IS COMPLETED.
- COMPLY WITH THE T–24 MANDATED TESTING, START–UP, COMMISSIONING, CERTIFICATION REQUIREMENTS INCLUDING HERS TESTING. PROVIDE OUTSIDE AIR CERTIFICATION EACH ZONES.
- PROVIDE THERMAL AND ACOUSTICAL INSULATION FOR THE HVAC AND PLUMBING SYSTEM TO SATISFY T–24 ENERGY EFFICIENCY REQUIREMENTS.
- COMPLY WITH ALL OTHER REQUIREMENTS LISTED IN THE CAL–GREEN CODE (CGC) CHECKLIST AND THE LOCAL CITY REQUIREMENTS FOR THE PROJECT.
- HVAC WORK SHALL BE PERFORMED BY A LICENSED MECHANICAL CONTRACTOR WHO IS TRAINED AND CERTIFIED IN THE PROPER INSTALLATION OF THE HVAC SYSTEMS, EQUIPMENTS, CONTROLS AND HAS AT LEAST 10 YEARS OF EXPERIENCE IN UNDERTAKING AND COMPLETING WORK SIMILAR TO THIS PROJECT IN SIZE, TYPE AND COMPLEXITY. PLUMBING CONTRACTOR SHALL BE QUALIFIED WITH MIN 7 YEARS OF EXPERIENCE IN PROJECTS OF SIMILAR TYPE AND COMPLEXITY.
- PREPARE AND SUBMIT OPERATING AND MAINTENANCE MANUALS FOR EACH SYSTEM OR EQUIPMENT (MECHANICAL, PLUMBING, ELECTRICAL AND CONTROL SYSTEMS) INSTALLED OR MODIFIED UNDER THIS CONTRACT, ALONG WITH SERVICE AND MAINTENANCE INSTRUCTIONS, AS–BUILT PLANS, GAURANTY/WARRANTY INFORMATION PRIOR TO FINAL INSPECTION IN ACCORDANCE WITH CBC5.410.5. SUBMIT COPIES OF ALL INSPECTION VERIFICATIONS AND REPORTS, T–24 FORMS REQUIRED BY THE ENFORCING AGENCY.
- ALL ADHESIVES, SEALANTS AND CAULKS USED ON THE PROJECT SHALL MEET THE REQUIREMENTS OF THE CGC 5.504.4.1 STANDARDS.
- PLUMBING FIXTURES AND FITTINGS SHALL MEET THE APPLICABLE STANDARDS REFERENCED IN TABLE 1401.1 OF 2016 CALIFORNIA PLUMBING CODE AND IN CHAPTER 6 OF CGC.
- GREEN BUILDING CHECKLIST IS IN THE ARCHITECTURAL SET.


ALL WORK SHALL BE PERFORMED IN COMPLIANCE WITH APPLICABLE CODES FOR CITY OF RICHMOND

2016 CALIFORNIA BUILDING CODE
2016 CALIFORNIA MECHANICAL CODE
2016 CALIFORNIA ELECTRICAL CODE
2016 CALIFORNIA PLUMBING CODE
2016 CALIFORNIA FIRE CODE
2016 CALIFORNIA ENERGY COMMISSION BUILDING ENERGY EFFICIENCY STANDARDS
2016 CALIFORNIA GREEN BUILDING STANDARDS CODE (CAL–GREEN)
(ALL APPLICABLE CODES WITH ALL RICHMOND AMENDMENTS)

DRAWING INDEX

DWG. No.	DESCRIPTION
1M0.0.1	GENERAL NOTES, LEGEND AND DRAWING INDEX
1M0.0.2	MECHANICAL SCHEDULES
1M0.0.3	MECHANICAL SCHEDULES
1M0.0.4	MECHANICAL SPECIFICATIONS
1MD1.0.1	1ST FLOOR – MECHANICAL DEMOLITION PLAN
1M2.0.1	1ST FLOOR – MECHANICAL FLOOR PLAN
1M2.0.2	1ST FLOOR – MECHANICAL PIPING PLAN
1M2.1.1	MECHANICAL ROOF PLAN
1M3.0.1	MECHANICAL DETAILS
1M3.0.2	MECHANICAL DETAILS
1TM4.0.1	MECHANICAL TITLE 24
1TM4.0.2	MECHANICAL TITLE 24
1TM4.0.3	MECHANICAL TITLE 24
1TM4.0.4	MECHANICAL TITLE 24
1TM4.0.5	MECHANICAL TITLE 24

VRV SYSTEM SCHEDULE																										MFR: DAIKIN			
FAN COIL UNIT														BRANCH SELECTOR										REMARKS					
CODE	MODEL	SYSTEM COOLING CAPACITY (NOMINAL)	SEER	FAN		O.A. CFM	2-PIPE REFRIGERANT PIPE CONNECTION	WEIGHT	ELECTRICAL						CODE	PORT CONFIGURATION	MODEL NO.	3-PIPE REFRIGERANT PIPE CONNECTION	WEIGHT	ELECTRICAL									
				CFM	ESP				VOLT	PH	Hz	MCA	MOCP	VOLT						PH	Hz	MCA	MOCP						
FC 1-1	FXMQ96MVJU	8.0 TONS	—	2540	0.4	275	PER MANUFACTURER'S RECOMMENDATIONS	305 LBS.	230	1	60	10.7	15	BS 1-A1	MULTI-PORT	BS8Q54TVJ	PER MANUFACTURER'S RECOMMENDATIONS	75 LBS	208	1	60	0.8	15	1. PROVIDE PROGRAMMABLE ROOM THERMOSTAT. THERMOSTAT SHALL MEET TITLE 24 REQUIREMENTS. 2. ALL REFRIGERANT PIPE SIZES SHALL BE PER MANUFACTURER'S RECOMMENDATIONS. 3. PROVIDE WRITTEN DOCUMENTATION FROM THE MANUFACTURER INDICATING THE REQUIRED PIPE SIZES FOR EACH UNIT AND THE MAIN/ BRANCH LINES. 4. ALL REFRIGERANT PIPE SHALL BE INSULATED. 5. CONTRACTOR TO RUN LOW/ HIGH VOLTAGE CONTROL WIRING IN CONDUIT BETWEEN CONDENSING UNIT, FAN COIL UNIT AND BRANCH SELECTOR AS REQUIRED. 6. PROVIDE NECESSARY WIRING PER MANUFACTURER'S RECOMMENDATION BETWEEN BETWEEN CONDENSING UNIT, FAN COIL UNIT AND BRANCH SELECTOR AS REQUIRED. 7. PROVIDE ALL REQUIRED ACCESSORIES FOR LONG REFRIGERANT LINE APPLICATION. 8. PROVIDE NECESSARY LOW VOLTAGE TRANSFORMER AS REQUIRED. 9. IF REQUIRED, PROVIDE ADDITIONAL REFRIGERANT CHARGE PER MANUFACTURER'S RECOMMENDATIONS. 10. ALL FAN COIL UNITS ARE HEATING/ COOLING UNITS. FC 1-2 & -5 SHALL BE COOLING ONLY. 11. PROVIDE OPTIONAL IN-BUILT CONDENSATE PUMP. 12. REFRIGERANT SHALL BE R-410A. 13. PROVIDE LONG LIFE FILTER. MERV 13. 14. PROVIDE DAIKIN VRV I TOUCH SYSTEM CONTROLLER. 15. PROVIDE FACTORY SHOP DRAWINGS SHOWING THE ENTIRE VRV SYSTEM LAYOUT (FCUs, BRANCH SELECTOR, CU, PIPING, ETC.) DRAWN TO ACTUAL SCALE. 16. PROVIDE SPEED CONTROLLER FOR FC. 17. EXTERIOR AIR COOLED CONDENSER UNITS SHALL SHALL BE INSTALLED ON THE ROOF. 18. REFRIGERANT GAS QUANTITY IS 50.8 LBS. 19. EER: NON-DUCTED=11.6, DUCTED=11.2 20. IEER: NON-DUCTED=22.0, DUCTED=20.7 21. HEATING COP: DUCTED=3.2 22. PROVIDE MINIMUM 8 PORT BRANCH SELECTOR. ALL PORTS (INCLUDING SPARE) SHALL BE PROVIDED WITH MUELLER CYCLEMASTER BALL VALVES AND REFPNET JOINT OUTLET CONNECTION. 23. MFR: DAIKIN OR APPROVED EQUAL.					
FC 1-2	FXAQ24PVJU	2.0 TONS	—	635	0.4	—	PER MANUFACTURER'S RECOMMENDATIONS	35 LBS.	230	1	60	0.6	15																
FC 1-3	FXMQ36PBVJU	3.0 TONS	—	1090	0.4	100	PER MANUFACTURER'S RECOMMENDATIONS	105 LBS.	230	1	60	2.9	15																
FC 1-4	FXMQ24PBVJU	2.0 TONS	—	685	0.4	100	PER MANUFACTURER'S RECOMMENDATIONS	80 LBS.	230	1	60	1.8	15																
FC 1-5	FXAQ24PVJU	2.0 TONS	—	635	0.4	—	PER MANUFACTURER'S RECOMMENDATIONS	35 LBS.	230	1	60	0.6	15																
REFRIGERANT LINES NOTES														CONDENSER UNIT															
1. THIS PROJECT ENTAILS LONG REFRIGERANT LINES. PROVIDE ALL ACCESSORIES REQUIRED FOR LONG REFRIGERANT LINE APPLICATION. THESE SHOULD INCLUDE, BUT NOT LIMITED TO: a. ADDITIONAL REFRIGERANT CHARGE AS NEEDED b. ADDITIONAL OIL AS NEEDED c. PROVIDE VIBRATION ELIMINATING DEVICES COORDINATE WITH THE MANUFACTURER AND PROVIDE ALL THE REQUIRED ACCESSORIES. 3. STRICTLY FOLLOW MANUFACTURER'S INSTALLATION GUIDELINES. 4. USE CONTINUOUS COPPER TUBING WITHOUT BREAKS AND LONG-RADIUS ELBOWS. DO NOT USE SHORT PIPE SECTIONS WITH BRAZED JOINTS. LIMIT ELBOWS, TURNS AND FITTINGS TO ABSOLUTE MINIMUM. RUN IN STRAIGHT LINE. 5. PITCH ALL HORIZONTAL RUNS ½" PER 10 FEET IN THE DIRECTION OF FLOW. 6. REFRIGERANT LINE SIZES SHALL BE STRICTLY PER MANUFACTURERS RECOMMENDATIONS.														CODE	MODEL NO.	UNIT TYPE	SYSTEM TONAGE	SYSTEM (COOLING BTU)	WEIGHT (EACH MODULE)	ELECTRICAL									
														CU 1-1	REYQ168TAYDU	EXTERIOR AIR COOLED	14 TONS	144,000	800 LBS	460	3	60	36.1	40					

COMPLIANCE WITH CMC TABLE 1102.2 REFRIGERANT ALLOWABLE QUANTITIES CALCULATION										
1ST FLOOR VRV SYSTEM										
ROOM/AREA	AREA (sq.ft)	HEIGHT (ft.)	VOLUME (cu.ft)	MAXIMUM ALLOWABLE QUANTITY (lbs.)	ACTUAL REFRIGERANT AMOUNT (lbs.)	REQUIRED ROOM OPEN FOR CALCULATION COMPLIANCE	TOTAL VOLUME (cu.ft.) WITH OPENING	MAXIMUM ALLOWABLE QUANTITY (lbs.) IN COMBINED SPACE	ROOM VOLUME COMPLIES	REMARKS
IDF ROOM 106	140	17	2380	62	50.8	N/A	N/A	N/A	YES	62 >50.8
STORAGE ROOM 116	155	17	2635	69	50.8	N/A	N/A	N/A	YES	69 >50.8
ELECTRICAL ROOM 117	295	17	5015	130	50.8	N/A	N/A	N/A	YES	130 > 50.8
OPEN OFFICE	6730	17	114410	2975	50.8	N/A	N/A	N/A	YES	2975 > 50.8
<u>GENERAL NOTES:</u> 1. ROOMS AND AREA INDICATE THE LOCATION OF FCU LOCATIONS AND THE AREA WHERE THE REFRIGERANT PIPING IS ROUTED. 2. VOLUME IS CALCULATED USING FLOOR-TO-CEILING HEIGHT PER 2016 CMC 1104.2.3.2 PLENUM DUE TO EXISTING WOOD STRUCTURE. PLENUMS ARE NOT PART OF THE AIR SUPPLY OR RETURN SYSTEM. 3. MAXIMUM ALLOWABLE QUANTITY CALCULATIONS HAVE BEEN DONE FOR COMMON AREA AND EACH ENCLOSED ROOM WHERE A FAN COIL UNIT IS LOCATED. ROOM NUMBERS INDICATED IN TABLE. 4. HALLWAY/Common Area Square Footage Noted in Table Indicates the summation of all adjacent contiguous open common areas' square footage. The common areas' volume shall be used to dissipate refrigerant gas if a leak occurs.										<u>DETAIL:</u> 
<u>TABLE NOTES:</u> A. PROVIDE 1" UNDERCUT FOR ENTRY DOOR OF ALL ENCLOSED ROOMS THAT HAS FAN COIL UNITS, BRANCH CONTROLLER AND REFRIGERANT PIPING TO ALLOW ANY REFRIGERANT WITHIN ROOM TO SPILL OUT AND DILUTE INTO THE COMMON AREAS. SEE MECHANICAL PIPING PLAN DRAWING 1M2.0.2.										

ECONOMIZER EXCEPTION CALCULATIONS	
A. ECONOMIZER EXCEPTION 4 TO SECTION 140.4(e)1.	
B. PER TABLE 110.2-H: ELECTRICALLY OPERATED VRF AIR CONDITIONERS MINIMUM EFFICIENCY REQUIREMENTS.	
C. PER TABLE 140.4-A ECONOMIZER TRADE-OFF TABLE FOR COOLING SYSTEMS.	
1. FOR CLIMATE ZONE 3: EFFICIENCY IMPROVEMENT IS 65%.	
2. 65% EFFICIENCY IMPROVEMENT OF 11.6 IEER IS 17.8 IEER.	
D. IEER FOR DUCTED FCUs IS 20.7, NON-DUCTED FCUs IS 22.0.	
1. IEER FOR DESIGNED SYSTEM IS 22.05 IEER.	
2. 20.0 IEER IS GREATER THAN REQUIRED 17.8 IEER. FAN COIL UNITS LARGER THAN 54,000 BTU/H ARE EXEMPTED FROM ECONOMIZER REQUIREMENTS.	

4114 Lakeside Drive
Richmond, CA 94806



909 Montgomery St., Suite 260
San Francisco, California 94133
T 415 546 1212 brereton.com

Stamp



Consultant

Amit Wadhwa & Associates
Engineers
870 Market Street
P.O. Box 380
San Francisco, CA 94102
415.786.5599
415.617.2076 fax 19098

Issue/Revision:		
No.	Date	Description
1	3/22/24	01 ISSUE FOR REVIEW
2	3/22/24	01 ISSUE FOR PERMIT

Copyright Statement:
All drawings and written material appearing herein constitute original and unpublished original work of the architect and may not be duplicated, used, or disclosed without prior written consent of the architect.
Approved Signature:

Co./ Title: Date:

MECHANICAL
SCHEDULES

Scale: NONE Issue Date: 1/7/24
Drawn By: PT Reviewed By: AM
Sheet: 2 of 15

1M0.0.2

4114 Lakeside Drive
Richmond, CA 94806



909 Montgomery St., Suite 260
San Francisco, California 94133
T 415 546 1212 brereton.com

Stamp



Consultant



AIR OUTLET SCHEDULE			MFR: TITUS OR APPROVED EQUAL
CODE	MODEL	DESCRIPTION	
CSD1	PMC	PERFORATED FACE CEILING SUPPLY DIFFUSER WITH 24" x 24" FACE. MODULAR CORE WITH ADJUSTABLE DISCHARGE PATTERNS. SEE PLAN FOR ROUND NECK SIZE AND THROW PATTERN.	
CRG1	PAR	PERFORATED FACE CEILING RETURN GRILLE WITH 24" x 24" FACE AND 22" x 22" NECK. (ALL RETURN AIR GRILLES)	
CEG1	PAR	PERFORATED FACE CEILING RETURN GRILLE WITH 24 x 24" FACE AND 22" x 22" NECK. (ALL RETURN AIR GRILLES)	
CEG2	355ZFL	CEILING MOUNTED GRILLE. 1/2" FIXED BLADE, 0° DEFLECTION. ALUMINUM CONSTRUCTION. SEE PLAN FOR SIZE. PROVIDE SHEET METAL TRANSITION TO CONNECT TO DUCTWORK.	
NOTE: 1. COORDINATE BORDER/FACE TYPE WITH THE ARCHITECT AND CEILING TYPE. UON. 2. PROVIDE ALL HARDWARE AS REQUIRED FOR MOUNTING AIR-OUTLETS ON VARIOUS CEILING TYPES. COORDINATE WITH CEILING PROVIDER. 3. VARIOUS CEILING TYPES ARE BEING USED ON THE FLOOR. IT IS MANDATORY TO CHECK COMPATIBILITY OF AIR OUTLET BORDER WITH CEILING TYPE PRIOR TO PLACING ORDER.			

VIBRATION ISOLATOR SCHEDULE					MFR: MASON OR APPROVED EQUAL
EQUIPMENT	ISOLATOR		SEISMIC RESTRAINT	REMARKS	
	TYPE	S.D.			
FAN COIL UNITS(FC 1-1, -3, -4)	30N	1"	SEISMIC BRACE CABLE	①②	
BRANCH SELECTOR	30N	1"	SEISMIC BRACE CABLE	①②	
CU1-1	SLR	1"	IN-BUILT IN SLR	①②	
NOTES: ① FOR NUMBER OF MOUNTS, DIMENSION, ETC. COORDINATE WITH EQUIPMENT MANUFACTURER. ② PROVIDE HEIGHT SAVING BRACKETS.					

EXHAUST FAN SCHEDULE								MFR: GREENHECK OR APPROVED EQUAL
CODE	TYPE AND SIZE	CFM	ESP "W.G.	MTR. WATTS	VOLTS PHASE	SERVICE	LOCATION	REMARKS
EF 1-1	ROOF CENTRIFUGAL, G-123-VG	950	0.6	¾HP	120V/1Ø	RESTROOMS/COPY/PANTRY	ROOF	
NOTES: 1. INSTALL EXHAUST FAN ON FACTORY ROOF CURB. 2. PROVIDE BACKDRAFT DAMPER. 3. FAN SHALL BE UL LISTED. PROVIDE VARI-GREEN EC MOTOR WITH POTENTIOMETER DIAL. POTENTIOMETER DIAL SHALL BE ACCESSIBLE. 4. MECHANICAL CONTRACTOR TO PROVIDE 7-DAY TIME CLOCK FOR START/ STOP. WIRING BY ELECTRICAL CONTRACTOR.								

EXISTING PACKAGED ROOFTOP AIR CONDITIONING UNIT SCHEDULE																						
CODE	SERVICE	LOCATION	MANUFACTURER	MODEL	CFM	ESP (IN.WC)	COOLING CAPACITY			HEATING CAPACITY					UNIT ELECTRICAL			MOTOR (BHP)	SEER (EER)	MINIMUM OUTSIDE AIR (CFM)	OPER. WEIGHT LBS.	REMARKS
							TONS	SENS MBH	TOTAL MBH	INPUT MBH	OUTPUT MBH	FUEL	EAT (°F)	LAT (°F)	MCA	MOCP	V/ø/Hz					
(E)AC-1	FIRST FLOOR	ROOF	TRANE	YCD180B4L0EA	5415	(E)	15	(E)	(E)	(E)	(E)	NATURAL GAS	(E)	(E)	(E)	(E)	(E)	(E)	(E)	750	(E)	SEE NOTE 3
NOTES: 1. BALANCE AIR FLOW TO CFM QUANTITIES INDICATED. RECOMMISSION THE UNIT. 2. PROVIDE NEW MERV 13 FILTERS. 3. PROVIDE CERTIFIED STARTUP REPORT VALIDATING THE PERFORMANCE OF THE UNIT. PROVIDE POINT-BYPOINT INSPECTION BY A FACTORY AUTHORIZED TECHNICIAN. 4. THE UNIT SHALL BE TESTED THROUGH THEIR ENTIRE RANGE OF OPERATION FROM FULL COOLING TO FULL HEATING. DOCUMENT SUPPLY, RETURN AND OA TEMPERATURES AT FULL COOLING AND FULL HEATING. 5. ENTIRE ELECTRIC/GAS UNIT SECTIONS BE RECOMMISSIONED, REFURBISHED AND RECHARGED IN ORDER TO ACHIEVE TO THEIR ORIGINAL FACTORY PERFORMANCE. ALL WORK SHALL BE DONE BY FACTORY AUTHORIZED TECHNICIAN. PROVIDE ALL LABOR AND MATERIAL REQUIRED TO BRING THE UNITS TO PERFORM AT THEIR INTENDED DESIGN. 6. RE-CALIBRATE CONTROLS AND SETTINGS. 7. PROVIDE NEW THERMOSTAT.																						

Copyright Statement:
All drawings and written material appearing herein constitute original and unpublished original work of the architect and may not be duplicated, used, or disclosed without prior written consent of the architect.
Approval Signature:

Co./ Title: Date:

MECHANICAL
SCHEDULES

Scale: NONE Issue Date: 17APR19
Drawn By: PT Reviewed By: AM
Sheet: 3 of 15

1M0.0.3

SPECIFICATIONS - DIVISION 15

1 - GENERAL

- 1.1 Provide all labor, equipment and materials that are required, to provide a complete, properly operating and safe mechanical installation. The extent of the work is indicated on the drawings and as described in these specifications, shall include all that may be reasonably inferred to be required for proper execution of installation work and/or systems' operation.
- 1.2 Provide cutting and patching as required for execution of work performed under this Section unless specifically provided for, under other Sections.
- 1.3 Repair or replace, to the satisfaction of the Owner, any damage to work of this Section, damage caused by leaks or breaks in systems of this Section, and damage caused by work of this Section.
- 1.4 Coordinate with work performed by other Sections, in order to accommodate the requirements of this Section, and to assure adequate space and proper location for all necessary work of this project whether or not work is under this Section.
- 1.5 Provide all necessary rigging equipment and manpower to set new equipment and materials in place.
- 1.6 Provide all seismic restraints required by code, or this specification, for all equipment, duct, pipe, and materials furnished under this Section. This Contractor is responsible for the design of the restraints and for proof of adequacy of the restraints. Equipment, ductwork, and piping shall be restrained in all directions.
- 1.7 Provide all labor and material required to set and adjust the installation so that it performs in accordance with the design intent included in the drawings and these specifications.
- 1.8 The work installed under this Section shall conform to all applicable federal, state and local codes, regulations, and standards.
- 1.9 Reasonable effort has been made to coordinate the location of equipment and materials with the structure and other trades, it is the responsibility of this Contractor to coordinate exact requirements and locations as governed by actual job conditions, manufacturer's recommendations etc.. Check all information and report any discrepancies to the Architect before fabrication or purchasing any equipment and in time to avoid unnecessary work.
- 1.10 Provide, procure, and pay for all permits, services, meters, licenses, fees, etc., required for performance of work of this Section.
- 1.11 Install equipment and materials with all working parts readily accessible for inspection, repair, and renewal.
- 1.12 Confer with the Owner/Architect to establish exact locations, mounting heights, and arrangements of all the finish work prior to roughing in.
- 1.13 Workmanship shall be first class throughout and performed only by competent and experienced workmen in a manner satisfactory to the Owner. Constant supervision of the work, either by the Contractor or his competent representative, shall be maintained.
- 1.14 Include all cutting and repairing necessary and required for this installation that is not covered by other trades. Structural members shall not be cut except with the written approval of the Architect. Repairing shall be performed by workmen skilled in the trades involved in a manner satisfactory to the Architect.
- 1.15 Submit for approval shop drawings/and Equipment submittals (including controls).
- 1.16 Refer to and follow Building Tenant Construction Standards. If discrepancies are found, follow the more stringent requirement.
- 1.17 All equipment piping, ductwork, etc. shall be braced and anchored to resist horizontal forces acting in any direction in accordance with the latest California/ City of Richmond Codes.
- 1.18 Install all piping and ductwork to best suit field conditions and coordinate with the installation work of other trades. The drawings are diagrammatic and shall not be scaled to determine exact locations of piping or ductwork.
- 1.19 Coordinate ductwork, piping with structural drawings, electrical including lighting, audio visual and sprinkler system. Provide transitions as required.
- 1.20 Contractor shall coordinate with architect ceiling access panels for all required fire, smoke, volume dampers and Mechanical equipment in inaccessible ceiling as required.
- 1.21 Provide all miscellaneous steel, special supports and anchoring for all Mechanical equipment requiring such.
- 1.22 Seal all fire rated penetrations with fire retardant material as required per NFPA and CBC.
- 1.23 Ducts stored on the construction site shall be protected and isolated from dust contamination.
- 1.24 Not all existing pipes, conduits, ducts, etc. are shown on these drawings. Where existing pipes, conduits and/or ducts which are to remain prevent installation of new work, relocate, or arrange for relocation of existing pipes, conduits and/or ducts, to facilitate new work.
- 1.25 All materials and workmanship are subject to review and approval by the architect. Any portion of the work found to be defective shall be replaced by the contractor as part of this contract at no additional cost to the owner.
- 1.26 Not all duct and piping transitions and/or offsets are shown. Provide transitions and/or offsets at no additional cost to owner.
- 1.27 Provide all required miscellaneous steel for complete installation of systems and for support of ductwork, piping, etc.
- 1.28 Drawing are diagrammatic in nature and all conditions shall be contractor coordinated and verified for exact location and sizes. The contractor is responsible to thoroughly verify all existing field conditions before submitting his/her bid.
- 1.29 Contractor shall provide dust covers as required to contain dust and debris within construction area and keep dust to a minimum.
- 1.30 Absolute accuracy of the drawings can not be guaranteed. While every effort has been made to coordinate the location of existing equipment, piping, etc., it is the responsibility of the contractor to coordinate the exact requirements governed by actual job conditions.
- 1.31 The submission of bid proposal shall be considered as conclusive evidence that the contractor is thoroughly familiar with the intent of the contract documents and scope of work. The contractor, prior to bidding, shall visit the job site, check existing installations and systems related to his/her work and shall, in the bid proposal, include all labor and material required to complete the system.
- 1.32 Contractor shall complete the work with minimum interference with existing systems. Any shutdown of the existing system shall be coordinated with the general contractor and the owner's representative three weeks in advance.
- 1.33 All work shall be in compliance with all applicable federal, state and local codes, regulations and standards.
- 1.34 Contractor shall protect the equipment, duct openings, pipes, etc. to prevent dust & debris from entering during construction. The existing air handling system return air openings shall be protected with minimum MERV 8 rated construction filters until, the construction activity is completed and ready for balancing in accordance with CAL-Green requirements.

2 - MATERIALS

- 2.1 Fabricate ductwork of galvanized sheet metal in accordance with latest edition of the SMACNA duct manual and ASHRAE guide. Seal and tape all duct joints airtight.
- 2.2 Acoustical Lining: Acoustical lining shall be 1" thick, fiber-free duct liner and shall meet UL-181 requirements. Install per manufacturer's recommendations.
- 2.3 Flexible Round Ducts: UL Class I air ducts with helical support wire, scrim cloth inner liner, R-4 insulation and outer plastic liner. Cody/West or equal. Use only to make final connections to the air-outlets. Maximum length allowed is 5 feet.
- 2.4 Fan Coil Units Supply/ Return ductwork for 2" pressure rating, seal Class A.
- 2.5 Transfer/ Return/Outside Air Ducts: 2" static pressure rating; 2,000 FPM maximum, seal Class A.
- 2.6 Insulate all condensate drain lines with ½ " thick jacketed Owens Corning fiberglass SSL-II insulation. Provide vapor barrier.
- 2.7 All ductwork shall be spiral round as shown with no flanged joints. Ductwork shall be neatly supported and braced seismically.
- 2.8 All insulation material shall meet flame spread rating of 25 and smoke developed rating of 50.
- 2.9 Refrigerant lines shall be copper Type K (Domestically manufactured in the USA) and silver brazed. Working pressure rating for the entire refrigerant assembly shall be 1.5X the system pressure.
- 2.10 All drain lines shall be copper Type M, 95/ 5 solder. Domestically manufactured in the USA.
- 2.11 Insulate entire length of refrigerant lines. Provide hard aluminum jacket to protect piping and insulation routed outside. Interior piping insulation shall incorporate soft jacket to protect insulation. Provide vapor barrier. Insulation thickness and density shall meet Title 24 requirements.
- 2.12 Insulate all condensate drain lines with ½ " thick jacketed Owens Corning fiberglass SSL-II insulation.
- 2.13 All insulation material shall meet flame spread rating of 25 and smoke developed rating of 50.
- 2.14 Duct insulation shall be by Owens Corning. 1½" thick and minimum density of 1 PCF. Insulation shall incorporate protective aluminum foil jacket.
- 2.15 All material in the ceiling plenum shall be plenum rated.
- 2.16 Provide dielectric union when connecting dissimilar metals.

3 - EXECUTION

- 3.1 Supports and Hangers: Use Super Strut, Unistrut, B-Line, Elcen or Grinnell hangers and structural attachments to properly support equipment, ductwork, and piping systems according to good standard practice and according to the manufacturer's recommendations. Minimum safety factor of 5.0. Support system shall meet all local codes.
- 3.2 No piping shall have direct contact with the hanging and support system or the structure. On pipes that are insulated, run the insulation continuous through the hanger and provide sheet metal shields of proper length and gages under the insulation to prevent crushing. On uninsulated copper piping, use Stoneman "trisolator" or similar Unistrut or Super-Strut device at each hanger or support point.
- 3.3 Design seismic restraints per SMACNA/PPIC "Guidelines for Seismic Restraints of Mechanical Systems and Piping Systems", for equipment, ducts, and piping.
- 3.4 Provide Access door and panels whenever a piece of equipment or valve and operator is inaccessible and requires access for maintenance, repair or adjustment.
- 3.5 Provide equipment (FC, etc.) and piping identification labeling. ¾" lettering on pipes and 1-1/2" lettering on equipment. Include directional arrows on piping. Coordinate style/ color with the Chief Building Engineer.
- 3.6 Fire/Smoke dampers shall be installed according to state and local codes and exactly as tested by UL to develop fire ratings.
- 3.7 Provide 18" x 12" minimum access doors in ductwork and furring to provide easy access to each fire damper. Use insulated access doors in insulated ducts.
- 3.8 The installation of all ductwork, louvers, dampers, etc., shall be according to the SMACNA standards.
- 3.9 Ducts shall be hung with galvanized 1" x 18 gauge duct straps with spacing as recommended by SMACNA or as required by local codes, whichever is most stringent. Provide sway bracing on all ductwork in accordance with the local codes.
- 3.10 Throughout the progress of the work, protect all pipe, conduit, ducts, fixtures, and equipment from intrusion by rain, dirt, and foreign matter, and from damage of any kind. Thoroughly clean all metallic, plastic, and painted surfaces of equipment prior to final inspection.
- 3.11 Flush pipes and ducts free from foreign substances before installing valves, stops, or making final connections.
- 3.12 After all other work has been accomplished, clean all air outlet faces. Remove all debris of work of this Section from site.
- 3.13 All materials, parts, equipment, modifications made, and workmanship shall be guaranteed for a period of one year from date of acceptance of the work. This guarantee is contingent upon the system being properly maintained by a qualified mechanic familiar with this equipment and that the equipment is not abused. Excluded is normal wear and tear, replacement of filters and belts, and acts of God. If the manufacturer provides for a longer guarantee period, it shall also be submitted.
- 3.14 Develop and provide final as-built, reproducible drawings and all O&M manuals prior to final acceptance.
- 3.15 Start, operate and commission all systems. Provide the services of factory trained technicians for start-up of major equipment and all systems including but not limited to temperature controls, VRV system.
- 3.16 Air balancing shall be performed by AABC certified independent balancing contractor per AABC format.
- 3.17 Insulate all unexposed Supply and Return air ductwork.
- 3.18 All new filters shall be minimum MERV 13.
- 3.19 All equipment, ductwork and piping shall be supported using drilled anchors. Do not use powder driven inserts.
- 3.20 No CFC equipment shall be added.
- 3.21 Contractor to provide all labor and material required to complete and perform all acceptance tests as required by 2016 Title 24. Acceptance tests forms are included under Title 24 sheets. Contractor to provide additional forms as required. Review all forms and provide cost for all acceptance tests in the base bid.

4114 Lakeside Drive
Richmond, CA 94806



909 Montgomery St., Suite 260
San Francisco, California 94133
T 415 546 1212 breton.com

Stamp



Consultant



Issue/Revision:

No.	Date	Description
1	32243.01 29MAR19	ISSUE FOR REVIEW
2	32243.01 22APR19	ISSUE FOR PERMIT


Copyright Statement:
All drawings and written material appearing herein constitute original and unpublished original work of the architect and may not be duplicated, used, or disclosed without prior written consent of the architect.
Approval Signature:

Co./ Title: Date:

MECHANICAL
SPECIFICATIOIS

Scale: NONE Issue Date: 17APR19
Drawn By: PT Reviewed By: AM
Sheet: 4 of 15

1MO.0.4



Wadhwa & Associates
Engineers

870 Market Street
(Food Bldg) Suite 846
San Francisco, CA 94102
415.788.9999 tel
415.617.0076 fax

19036

Issue/Revision:		
No.	Proj. No. Date:	Description
1	32243.01 29MARI9	ISSUE FOR REVIEW
2	32243.01 22APRI9	ISSUE FOR PERMIT

o/ Title: _____ Date: _____

FIRST FLOOR - MECHANICAL DEMOLITION PLAN

Scale: 1/8=1'-0" Issue Date: 17APR19
Drawn By: PT Reviewed By: AW
Sheet: 5 of 15

1MD1.0.1



- GENERAL NOTES:**
1. OFFSET FULL HEIGHT WALL(S) ABOVE CEILING TO AVOID CONFLICT WITH THE DUCTWORK/ PIPING.
 2. COORDINATE THERMOSTAT LOCATION/HEIGHT WITH THE ARCHITECT AND FURNITURE LAYOUT. FURNITURE SHALL NOT OBSTRUCT THERMOSTAT. CENTER THERMOSTAT ON COLUMNS IN OPEN OFFICE AREAS. TOP OF THERMOSTATS SHALL BE INSTALLED AT 48" ABOVE FINISHED FLOOR.
 3. INSTALL ALL PIPING AS HIGH AS POSSIBLE TO THE STRUCTURE TO AVOID CONFLICT WITH DUCTWORK AND HVAC EQUIPMENT. PROVIDE TRANSITIONS AS REQUIRED TO CROSS ABOVE DUCTWORK AND HVAC EQUIPMENT. ALLOW ROOM FOR ONLY FIRE PROOFING AND PIPE INSULATION. COORDINATE WITH CHIEF BUILDING ENGINEER.
 4. VERIFY ALL NEW DUCT ROUTING WITH EXISTING BEAMS, DUCTWORK, PIPING, CONDUITS, ETC. PRIOR TO DUCT FABRICATION.
 5. PRIOR TO FABRICATION AND INSTALLATION COORDINATE DUCT/ PIPE ROUTING AND EQUIPMENT PLACEMENT WITH ALL OTHER CEILING ELEMENTS SUCH AS BEAMS, SPRINKLER LINES, LIGHT FIXTURES, PLUMBING LINES, CONDUITS, ETC. MARK AND DRAFT ON THE FLOOR ENTIRE LAYOUT SHOWING THE COMPLETE SYSTEM (MAIN LOOP, FAN COIL UNITS, DUCT DISTRIBUTION, AIR OUTLETS, ETC.), INCLUDING HEIGHTS/ ELEVATIONS, FOR ARCHITECT'S REVIEW AND APPROVAL. PROVIDE TRANSITIONAL FITTINGS, ADJUSTMENTS AS PER ARCHITECT'S DIRECTION. DO NOT FABRICATE/ INSTALL WITHOUT THIS EXERCISE AND ARCHITECT'S APPROVAL.
 6. PROVIDE CONDUIT FOR CONTROL WIRING FOR THERMOSTATS LOCATED ON NON-FURRED COLUMN AND WALLS.
 7. PROVIDE DUCT/ PIPE TRANSITIONS AS REQUIRED TO CLEAR FLOATING CEILING, BEAMS, SPRINKLER LINES, ETC.
 8. ROUTE CONDUIT ALONG SIDE REFRIGERANT LINES FOR CONTROL WIRING.
 9. PROVIDE TURNING VANES FOR ALL RECTANGULAR DUCT ELBOW FITTINGS.
 10. DRAWINGS ARE ONLY DIAGRAMMATIC. PROVIDE DUCT/ PIPE TRANSITIONS, OFFSETS, FITTINGS AS REQUIRED TO CLEAR BEAMS, HIGH CEILINGS AND OTHER CEILING CONSTRAINTS. ALL TRANSITIONS, FITTINGS, ETC. NEEDED ARE NOT SHOWN. EXTREMELY TIGHT FIT IN CEILING PLENUM DUE TO HIGH CEILING HEIGHT. REFER TO ARCHITECTURAL DRAWINGS (CEILING HEIGHT, ELEVATION SECTIONS, ETC.) TO UNDERSTAND AND TAKE INTO ACCOUNT THE UNIQUE NATURE OF THIS PROJECT AND THE NEED FOR ADDITIONAL OFFSETS, TRANSITIONS, ETC. PRIOR TO BIDDING.
 11. CEILING ACCESS PANEL SHALL BE 24"x24". CEILING ACCESS PANEL SHALL BE LOCATED TO ALLOW FULL ACCESS FOR MAINTENANCE OF HVAC EQUIPMENT (FIRE/SMOKE DAMPER(S), SHUT-OFF VALVE(S), ETC.).

- SHEET NOTES:**
1. RELOCATE EXISTING SPRINKLER LINES, J-BOXES, CONDUITS, PIPING, ETC. TO ACCOMMODATE NEW EQUIPMENT, DUCTWORK AND PIPING. PROVIDE CLEARANCES AND ADEQUATE MAINTENANCE ACCESS.
 2. SECONDARY DRAIN PAN UNDER THE UNIT. DRAIN PAN SHALL HAVE GROSS-SECTIONAL AREA BIG ENOUGH TO COVER THE ENTIRE UNIT AS WELL AS PIPE CONNECTIONS AT THE UNIT. CONDENSATE LINE FROM THE PAN SHALL DISCHARGE THROUGH THE CEILING TILE 1/2" BELOW THE CEILING. COORDINATE EXACT LOCATION WITH THE ARCHITECT.
 3. PROVIDE DUCT SMOKE DETECTOR AT UNIT DISCHARGE.(TYP.)
 4. PROVIDE ACOUSTICALLY LINED RETURN AIR PLENUM. PLENUM SHALL BE FULL SIZE OF UNIT'S RETURN AIR OPENING x 48" LONG. CONNECT OA DUCT TO THE PLENUM AS SHOWN. BALANCE OUTSIDE AIR TO THE CFM SHOWN ON THE FC UNIT SCHEDULE.
 5. REMOTE VOLUME DAMPER. PROVIDE ADDITIONAL HARDWARE AS REQUIRED.
 6. FLEX DUCT CONNECTED TO CRG1. 5 FT MAXIMUM LENGTH.(TYP.)
 7. OUTSIDE AIR DUCT UP THRU ROOF.
 8. 7-DAY TIME CLOCK FOR EF 1-1.
 9. VRV SYSTEM CONTROLLER.
 10. 12x12 UP TO EF-1 ON ROOF.
 11. PROVIDE NEW DUCT SMOKE DETECTOR FOR (E)AC-1 ID NONE EXIST. DUCT DETECTOR TO SHUT UNIT OFF UPON SMOKE DETECTION. PROVIDE SEPARATE COST FOR THIS LINE ITEM.
 12. PROVIDE CONICAL CONNECTION.(TYP.)
 13. SEAL ALL OPENINGS IN THE WALL AIRTIGHT.
 14. PROVIDE NEW PROGRAMMABLE THERMOSTAT FOR (E)AC-1 BEING REUSED.
 15. BALANCE OSA TO CFM NOTED IN THE VRV SCHEDULE.


RICHMOND LAKESIDE
TENANT IMPROVEMENT

4114 Lakeside Drive
Richmond, CA 94806



909 Montgomery St., Suite 260
San Francisco, California 94133
T 415 546 1212 brereton.com

Stamp



Consultant

AWA
Amit Wadhwa & Associates
Engineers
870 Market Street
P.O. Box 3300
San Francisco, CA 94102
415.786.3990
415.617.2076 fax 19098

Issue/Revision:

No.	Date	Description
1	32243.01	ISSUE FOR REVIEW
2	22AFR19	
1	32243.01	ISSUE FOR PERMIT
2	22AFR19	

Copyright Statement:
All drawings and written material appearing herein constitute original and unpublished original work of the architect and may not be duplicated, used, or disclosed without prior written consent of the architect.

Approval Signature:

Co./ Title:

Date:

**1ST FLOOR -
MECHANICAL
FLOOR PLAN**

Scale: 1/8"=1'-0"
Drawn By: PT
Sheet: 6 of 15
Issue Date: 17APR19
Reviewed By: AM

1M2.0.1


GENERAL NOTES:

1. INSTALL ALL PIPING AS HIGH AS POSSIBLE TO THE STRUCTURE TO AVOID CONFLICT WITH DUCTWORK AND HVAC EQUIPMENT. PROVIDE OFFSETS AS REQUIRED TO CROSS ABOVE DUCTWORK AND HVAC EQUIPMENT.
2. PRIOR TO FABRICATION AND INSTALLATION COORDINATE DUCT/ PIPE ROUTING AND EQUIPMENT PLACEMENT WITH ALL OTHER CEILING ELEMENTS SUCH AS BEAMS, SPRINKLER LINES, LIGHT FIXTURES, PLUMBING LINES, CONDUITS, ETC. MARK AND DRAFT ON THE FLOOR ENTIRE LAYOUT SHOWING THE COMPLETE SYSTEM (MAIN LOOP, FAN COIL UNITS, DUCT DISTRIBUTION, AIR OUTLETS, ETC.), INCLUDING HEIGHTS/ ELEVATIONS, FOR ARCHITECT'S REVIEW AND APPROVAL. PROVIDE TRANSITIONAL FITTINGS, ADJUSTMENTS AS PER ARCHITECT'S DIRECTION. DO NOT FABRICATE/ INSTALL WITHOUT THIS EXERCISE AND ARCHITECT'S APPROVAL.
3. ALL CONTROL WIRING SHALL BE ROUTED WITHIN METAL CONDUIT OR SECURED ON TOP OF DUCTWORK. ALL CONTROL WIRING SHALL BE UN-SEEN AND SECURED.
4. PROVIDE DUCT/ PIPE TRANSITIONS AS REQUIRED TO CLEAR CEILING, BEAMS, SPRINKLER LINES, ETC.
5. ROUTE CONDUIT ALONG SIDE REFRIGERANT LINES FOR CONTROL WIRING.
6. DRAWINGS ARE ONLY DIAGRAMMATIC. PROVIDE DUCT/ PIPE TRANSITIONS, OFFSETS, FITTINGS AS REQUIRED TO CLEAR BEAMS, HIGH CEILINGS AND OTHER CEILING CONSTRAINTS. ALL TRANSITIONS, FITTINGS, ETC. NEEDED ARE NOT SHOWN. EXTREMELY TIGHT FIT IN CEILING PLENUM DUE TO HIGH CEILING HEIGHT. REFER TO ARCHITECTURAL DRAWINGS (CEILING HEIGHT, ELEVATION SECTIONS, ETC.) TO UNDERSTAND AND TAKE INTO ACCOUNT THE UNIQUE NATURE OF THIS PROJECT AND THE NEED FOR ADDITIONAL OFFSETS, TRANSITIONS, ETC. PRIOR TO BIDDING.
7. SYSTEM DESIGNED USING VRF MANUFACTURED BY DAIKIN. IF CONTRACTOR CHOOSES TO USE A DIFFERENT APPROVED EQUAL, THE SYSTEM DESIGN CHANGE FOR BRANCH SELECTOR, PIPING, FCUS, ETC. SHALL BE PROVIDED BY THE CONTRACTOR. CONTRACTOR SHALL PROVIDE NEW DESIGN DRAWINGS SHOWING ALL THE COMPONENTS OF THE NEW SYSTEM INCLUDING PIPE SIZES FOR REVIEW AND APPROVAL.

SHEET NOTES:

- ① 3/4" CONDENSATE DRAIN. SEE PLUMBING DRAWINGS FOR CONDENSATE DRAIN LINE TERMINATION.
- ② PROVIDE PENETRATION WITH WALL PENETRATION SLEEVE. SEAL PENETRATION WATER-TIGHT.
- ③ PROVIDE OVERHEAD UNISTRUT /FRAME TO SUPPORT THE REFRIGERANT LINES AND CONTROL WIRING.
- ④ REFRIGERANT LINES & CONTROL WIRING UP TO CONDENSER ON ROOF.
- ⑤ 1" CONDENSATE DRAIN. SEE PLUMBING DRAWINGS FOR CONDENSATE DRAIN LINE TERMINATION.
- ⑥ MULTI-PORT TWINNING KIT.
- ⑦ EXACT SIZING SHALL BE BY VRF MANUFACTURER GUILDLINE AND INSTRUCTIONS.(TYP.)

1 1ST FLOOR - MECHANICAL PIPING PLAN
SCALE: 1/8" = 1'-0"



CONTROLLER WIRING SCHEMATICS
NTS

Issue/Revision:

No.	Date	Description
①	32249.01	ISSUE FOR REVIEW
291AR19		
②	32249.01	ISSUE FOR PERMIT
22AFR19		

Copyright Statement:
All drawings and written material appearing herein constitute original and unpublished original work of the architect and may not be duplicated, used, or disclosed without prior written consent of the architect.
Approved Signature:

Co./ Title: Date:

1ST FLOOR -
MECHANICAL
PIPING PLAN

Scale: 1/8"=1'-0"
Drawn By: PT
Sheet: 7 of 15
Issue Date: 17APR19
Reviewed By: AK

1M2.0.2



Stamp



Consultant



Issue/Revision:

No.	Date	Description
1	29*1AR19	ISSUE FOR REVIEW
2	22*AFR19	ISSUE FOR PERMIT

Copyright Statement:
All drawings and written material appearing herein constitute original and unpublished original work of the architect and may not be duplicated, used, or disclosed without prior written consent of the architect.

Approval Signature:

Co./ Title:


Date:

MECHANICAL ROOF PLAN

Scale: 1/8"=1'-0"
Drawn By: PT
Sheet: 8 of X



Issue Date: 17APR19
Reviewed By: AM

1M2.1.1




1 MECHANICAL ROOF PLAN


SCALE: 1/8" = 1'-0"



2 MECHANICAL DEMOLITION PLAN

SCALE: 1/8" = 1'-0"






NOTES:

- ① SINGLE-LINE ILLUSTRATIONS ARE SYMBOLS USED ON DRAWINGS.
- ② FOR LOW PRESSURE SYSTEM ONLY.

1 ROUND DUCT DETAILS

SCALE: NONE




NOTES:

- ① SINGLE-LINE ILLUSTRATIONS ARE SYMBOLS USED ON DRAWINGS.
- ② SIZE A & B DIMENSIONS IN PROPORTION TO AIR QUANTITIES IN EACH LEG SPLIT.
- ③
- ④ FOR LOW PRESSURE SYSTEM ONLY. CONICAL CONNECTION SHALL INCORPORATE SIDE FLARE THAT IS 3" LARGER THAN THE DUCT WIDTH/ DIAMETER ON EITHER SIDE.


2 RECTANGULAR DUCT DETAILS

SCALE: NONE




3 DUCT SLICE FITTING DETAIL

SCALE: NONE



4 CEILING SUPPLY AIR DIFFUSER DETAIL

SCALE: NONE



5 CEILING RETURN AIR GRILLE DETAIL

SCALE: NONE



Stamp



Consultant


Issue/Revision:

No.	Date:	Description
①	32249.01 29MAR19	ISSUE FOR REVIEW
②	32249.01 22APR19	ISSUE FOR PERMIT

Copyright Statement:
All drawings and written material appearing herein constitute original and unpublished original work of the architect and may not be duplicated, used, or disclosed without prior written consent of the architect.
Approval Signature:

Co./ Title: Date:

**MECHANICAL
DETAILS**




- NOTE:**
1. ALL SUPPORT COMPONENT SIZES AND MINIMUM BOLT EMBEDMENT SHALL BE BY MANUFACTURE'S INSTRUCTIONS OR CALCULATED BY A REGISTERED STRUCTURAL ENGINEER BASED ON UNIT WEIGHT.
 2. INSTALL BRANCH SELECTOR AND FAN COIL UNIT PER MANUFACTURE'S INSTRUCTION.
 3. FAN COIL UNIT MAINTENANCE ACCESS IS AT THE BOTTOM OF THE UNIT. FOR UNITS INSTALL ABOVE CEILING STRUCTURE PROVIDE SHUT-OFF VALVES AND UNION FITTINGS TO DISCONNECT REFRIGERANT LINES TO LIFT UP UNIT. ALSO PROVIDE DUCT CONNECTION AT FLEXIBLE DUCT TO ALLOW FOR DISCONNECTION.

DETAIL NOTES:


- | | |
|---|--|
| <ol style="list-style-type: none"> ① STRUCTURAL ENGINEER HIRED BY THE CONTRACTOR TO ESTABLISH CONNECTION TYPE. ② UNISTRUT OR "L" ANGLE IRON ③ MASON VIBRATION ISOLATORS ④ "Z" SHAPED BRACKET ⑤ SEISMIC BRACE CABLE (TENSION CABLE ONLY TO REMOVE SLACK)(TYPICAL OF 4) ⑥ U-BOLT CLIPS ⑦ THREADED ROD (TYPICAL OF 4) ⑧ CONDENSATE PUMP(LIMITED HEAD, ONLY TO RAISE DRAIN LINE TO MEET SLOPE) | <ol style="list-style-type: none"> ② 2-PIPE (LIQUID, GAS) BETWEEN BRANCH SELECTOR AND FAN COIL UNIT. PIPE SIZE AND REQUIRED ACCESSORIES PER MANUFACTURER'S RECOMMENDATIONS. ③ 3-PIPE (LIQUID, SUCTION GAS, DISCHARGE GAS) BETWEEN CONDENSING UNIT AND BRANCH SELECTOR. PIPE SIZE AND REQUIRED ACCESSORIES PER MANUFACTURER'S RECOMMENDATIONS. ⑩ PROVIDE SHUT-OFF VALVES FOR EACH FAN COIL UNITS LOCATED ABOVE AND SUPPORTED BY CEILING STRUCTURE. ⑪ PROVIDE UNION FITTINGS FOR EACH FAN COIL UNITS LOCATED ABOVE AND SUPPORTED BY CEILING STRUCTURE. |
|---|--|

1 FAN COIL UNIT (FC) AND BRANCH SELECTOR INSTALLATION DETAIL
SCALE: NONE




- NOTES:**
1. ROOF SLOPES. PROVIDE ADDITIONAL HARDWARE AS REQUIRED FOR FULLY HORIZONTAL INSTALLATION.
 2. INTERFACING WITH EXISTING ROOFING SHALL BE FIELD COORDINATED. HIRE ROOFING CONTRACTOR FOR ASSOCIATED ROOFING WORK. ASSEMBLY SHALL BE TOTALLY WATER PROOF.
 3. INTENT ONLY IS DEPICTED HERE. ACTUAL ROOF / ROOFING CONDITION MAY VARY. COORDINATE IN FIELD AND PROVIDE COMPATIBLE ASSEMBLY.

3 WOODEN SLEEPER MOUNTING DETAIL
SCALE: N.T.S.




- NOTES:**
1. FOR NUMBER AND PLACEMENT OF UNIT'S MOUNTING LUGS COORDINATE WITH UNIT MANUFACTURER.
 2. ROOF SLOPES. PROVIDE ADDITIONAL HARDWARE AS REQUIRED FOR FULLY HORIZONTAL INSTALLATION.
 3. INTERFACING WITH EXISTING ROOFING SHALL BE FIELD COORDINATED. HIRE ROOFING CONTRACTOR FOR ASSOCIATED ROOFING WORK. ASSEMBLY SHALL BE TOTALLY WATER PROOF.
 4. INTENT ONLY IS DEPICTED HERE. ACTUAL ROOF / ROOFING CONDITION MAY VARY. COORDINATE IN FIELD AND PROVIDE COMPATIBLE ASSEMBLY.

4 CONDENSER UNIT MOUNTING DETAIL
SCALE: NONE



- NOTES:**
1. INTENT ONLY IS DEPICTED HERE. ACTUAL ROOF/ ROOFING CONDITION MAY VARY. COORDINATE IN FIELD AND PROVIDE COMPATIBLE ASSEMBLY.

2 ROOF EXHAUST FAN INSTALLATION DETAIL
SCALE: NONE




- NOTES:**
1. ROOF SLOPES. PROVIDE ADDITIONAL HARDWARE AS REQUIRED FOR FULLY HORIZONTAL INSTALLATION.

5 PIPE ROOF PENERATION
SCALE: NONE



Stamp



Consultant

Issue/Revision:		
No.	Date	Description
①	32243.01 29MAR19	ISSUE FOR REVIEW
②	32243.01 22APR19	ISSUE FOR PERMIT

Copyright Statement:
All drawings and written material appearing herein constitute original and unpublished original work of the architect and may not be duplicated, used, or disclosed without prior written consent of the architect.
Approval Signature:

Co./ Title: Date:

**MECHANICAL
DETAILS**

4114 Lakeside Drive
Richmond, CA 94806



909 Montgomery St., Suite 260
San Francisco, California 94133
T 415 546 1212 b rereton.com

Stamp



Consultant



Issue/Revision:

No.	Date:	Description
1	3/22/24	ISSUE FOR REVIEW
2	2/24/24	ISSUE FOR PERMIT

Copyright Statement:
All drawings and written material appearing herein constitute original and unpublished original work of the architect and may not be duplicated, used, or disclosed without prior written consent of the architect.

Approval Signature:

Co./ Title: Date:

MECHANICAL TITLE 24

Scale: NONE Issue Date: 1/24/24
Drawn By: PT Reviewed By: AM
Sheet: 11 of 15

1TM4.0.1

STATE OF CALIFORNIA
MECHANICAL SYSTEMS
CEC-NRCC-MCH-01-E (Revised 01/16)
CALIFORNIA ENERGY COMMISSION
CERTIFICATE OF COMPLIANCE
Mechanical Systems
Project Name: RICHMOND LAKESIDE TENANT IMPROVEMENT Date Prepared: 4/15/19 Page 1 of 4

A. MECHANICAL COMPLIANCE DOCUMENTS & WORKSHEETS (check box if worksheet is included)

For detailed instructions on the use of this and all Energy Efficiency Standards compliance forms, refer to the 2016 Nonresidential Manual Note: The Enforcement Agency may require all forms to be incorporated onto the building plans.

YES	NO	Comp. Doc./Worksheet #	Title
<input checked="" type="checkbox"/>	<input type="checkbox"/>	NRCC-MCH-01-E (Part 1 of 3)	Certificate of Compliance, Declaration. Required on plans for all submittals.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	NRCC-MCH-01-E (Part 2 of 3)	Certificate of Compliance, Required Acceptance Tests (MCH-02-A to 11-A). Required on plans for all submittals.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	NRCC-MCH-01-E (Part 3 of 3)	Certificate of Compliance, Required Acceptance Tests (MCH-12-A to 18-A). Required on plans where applicable.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	NRCC-MCH-02-E (Part 1 of 2)	Mechanical Dry Equipment Summary is required for all submittals with Central Air Systems. It is optional on plans.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	NRCC-MCH-02-E (Part 2 of 2)	Mechanical Wet Equipment Summary is required for all submittals with chilled water, hot water or condenser water systems. It is optional on plans.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	NRCC-MCH-03-E	Mechanical Ventilation and Reheat is required for all submittals with multiple zone heating and cooling systems. It is optional on plans.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	NRCC-MCH-07-E (Part 1 of 2)	Power Consumption of Fans. Required on plans where applicable.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	NRCC-MCH-07-E (Part 2 of 2)	Power Consumption of Fans, Declaration. Required on plans where applicable.

CA Building Energy Efficiency Standards - 2016 Nonresidential Compliance January 2016

STATE OF CALIFORNIA
MECHANICAL SYSTEMS
CEC-NRCC-MCH-01-E (Revised 01/16)
CALIFORNIA ENERGY COMMISSION
CERTIFICATE OF COMPLIANCE
Mechanical Systems
Project Name: RICHMOND LAKESIDE TENANT IMPROVEMENT Date Prepared: 4/15/19 Page 4 of 4

DOCUMENTATION AUTHOR'S DECLARATION STATEMENT

I, certify that this Certificate of Compliance documentation is accurate and complete.

Documentation Author Name: AMIT WADHWHA Documentation Author Signature: _____
Company: AMIT WADHWHA & ASSOCIATES Signature Date: _____
Address: 870 MARKET STREET, SUITE 846 CEA/RES Certification Identification (if applicable): _____
City/State/Zip: SAN FRANCISCO, CA 94102 Phone: (415) 788-9999

RESPONSIBLE PERSON'S DECLARATION STATEMENT

I certify the following under penalty of perjury, under the laws of the State of California:

- The information provided on this Certificate of Compliance is true and correct.
- I am eligible under Division 3 of the Business and Professions Code to accept responsibility for the building design or system design identified on this Certificate of Compliance (responsible designer).
- The energy features and performance specifications, materials, components, and manufactured devices for the building design or system design identified on this Certificate of Compliance conform to the requirements of Title 24, Part 1 and Part 6 of the California Code of Regulations.
- The building design features or system design features identified on this Certificate of Compliance are consistent with the information provided on other applicable compliance documents, worksheets, calculations, plans and specifications submitted to the enforcement agency for approval with this building permit application.
- I will ensure that a completed signed copy of this Certificate of Compliance shall be made available with the building permit(s) issued for the building, and made available to the enforcement agency for all applicable inspections. I understand that a completed signed copy of this Certificate of Compliance is required to be included with the documentation the builder provides to the building owner at occupancy.

Responsible Designer Name: AMIT WADHWHA Responsible Designer Signature: _____
Company: AMIT WADHWHA & ASSOCIATES Date Signed: _____
Address: 870 MARKET STREET, SUITE 846 License: M30894
City/State/Zip: SAN FRANCISCO, CA 94102 Phone: (415) 788-9999

CA Building Energy Efficiency Standards - 2016 Nonresidential Compliance January 2016

STATE OF CALIFORNIA
HVAC DRY & WET SYSTEM REQUIREMENTS
CEC-NRCC-MCH-02-E (Revised 01/16)
CALIFORNIA ENERGY COMMISSION
CERTIFICATE OF COMPLIANCE
HVAC Dry System Requirements
Project Name: RICHMOND LAKESIDE TENANT IMPROVEMENT Date Prepared: 4/15/19 Page 1 of 3

A. Equipment Tags and System Description¹- Dry Systems

	FC 1.1	FC 1.2	FC 1.3
MANDATORY MEASURES	T-24 Sections	Reference to the Requirements in the Contract Documents²	
Heating Equipment Efficiency ³	110.1 or 110.2(a)	1M0.0.2	N/A
Cooling Equipment Efficiency ³	110.1 or 110.2(a)	1M0.0.2	1M0.0.2
HVAC or Heat Pump Thermostats	110.2(b), 110.2(c)	PROGRAMMABLE	PROGRAMMABLE
Furnace Standby Loss Control	110.2(d)	N/A	N/A
Low Leakage AHUs	110.2(f)	N/A	N/A
Ventilation ⁴	120.1(b)	1M0.0.2	1M0.0.2
Demand Control Ventilation ⁵	120.1(c)(4)	N/A	N/A
Occupant Sensor Ventilation Control ⁶	120.1(c)(5), 120.2(e)(3)	N/A	N/A
Shutoff and Reset Controls ⁷	120.2(a)	N/A	N/A
Outdoor Air and Exhaust Damper Control	120.2(f)	1M2.0.1	1M2.0.1
Isolation Zones	120.2(g)	N/A	N/A
Automatic Demand Shed Controls	120.2(h)	N/A	N/A
Economizer FDD	120.2(i)	N/A	N/A
Duct Insulation	120.4	1M0.0.4	1M0.0.4

PRESCRIPTIVE MEASURES

Equipment is sized in conformance with 140.4 (a & b)

140.4(a & b)	Yes	No	Yes	No	Yes	No
Supply Fan Pressure Control	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Simultaneous Heat/Cool ⁸	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Economizer	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Heat and Cool Air Supply Reset	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Electric Resistance Heating ⁹	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Duct Leakage Sealing and Testing ¹⁰	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Notes:

- Provide equipment tags (e.g. AHU 1 to 10) and system description (e.g. Single Duct VAV reheat) as appropriate. Multiple units with common requirements can be grouped together.
- Provide references to plans (i.e. Drawing Sheet Numbers) and/or specifications (including Section name/number and relevant paragraphs) where each requirement is specified. Enter "N/A" if the requirement is not applicable to this system.
- The referenced plans and specifications must include all of the following information: equipment tag, equipment nominal capacity, Title 24 minimum efficiency requirements, and actual rated equipment efficiencies. Where multiple efficiency requirements are applicable (e.g. full- and part-load) include all. Where appliance standards apply (110.1), identify where equipment is required to be listed per Title 20 1601 et seq.
- Identify where the ventilation requirements are documented for each central HVAC system. Include references to both central unit schedules and sequences of operation. If one or more spaces is naturally ventilated identify where this is documented in the plans and specifications. Multiple zone central air systems must also provide a MCH-03-E compliance document.
- If one or more spaces has demand controlled ventilation identify where it is specified including the sensor specifications and the sequence of operation.
- If one or more space has occupant sensor ventilation control identify where it is specified including the sensor specifications and the sequence of operation.
- If the system is DX: identify the sequences for the system start/stop, optimal start, setback (if required) and setup (if required). For all systems identify the specification for the thermostats and time clocks (if applicable).
- Identify where the heating, cooling and deadband airflowers are scheduled for this system. Include a reference to the specification of the zone controls. Provide a MCH-03-E compliance document.
- Enter N/A if there is no electric heating. If the system has electric heating indicate which exception to 140.4(a) applies.
- If duct leakage sealing and testing is required, a MCH-04-A compliance document must be submitted.

CA Building Energy Efficiency Standards - 2016 Nonresidential Compliance January 2016

STATE OF CALIFORNIA
HVAC DRY & WET SYSTEM REQUIREMENTS
CEC-NRCC-MCH-02-E (Revised 01/16)
CALIFORNIA ENERGY COMMISSION
CERTIFICATE OF COMPLIANCE
HVAC Dry System Requirements
Project Name: RICHMOND LAKESIDE TENANT IMPROVEMENT Date Prepared: 4/15/19 Page 1 of 3

A. Equipment Tags and System Description¹- Dry Systems

	FC 1.4	FC 1.5	(T)AC1
MANDATORY MEASURES	T-24 Sections	Reference to the Requirements in the Contract Documents²	
Heating Equipment Efficiency ³	110.1 or 110.2(a)	1M0.0.2	N/A
Cooling Equipment Efficiency ³	110.1 or 110.2(a)	1M0.0.2	N/A
HVAC or Heat Pump Thermostats	110.2(b), 110.2(c)	PROGRAMMABLE	PROGRAMMABLE
Furnace Standby Loss Control	110.2(d)	N/A	N/A
Low Leakage AHUs	110.2(f)	N/A	N/A
Ventilation ⁴	120.1(b)	1M0.0.2	1M0.0.2
Demand Control Ventilation ⁵	120.1(c)(4)	N/A	N/A
Occupant Sensor Ventilation Control ⁶	120.1(c)(5), 120.2(e)(3)	N/A	N/A
Shutoff and Reset Controls ⁷	120.2(a)	N/A	N/A
Outdoor Air and Exhaust Damper Control	120.2(f)	1M2.0.1	N/A
Isolation Zones	120.2(g)	N/A	N/A
Automatic Demand Shed Controls	120.2(h)	N/A	N/A
Economizer FDD	120.2(i)	N/A	N/A
Duct Insulation	120.4	1M0.0.4	1M0.0.4

PRESCRIPTIVE MEASURES

Equipment is sized in conformance with 140.4 (a & b)

140.4(a & b)	Yes	No	Yes	No	Yes	No
Supply Fan Pressure Control	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Simultaneous Heat/Cool ⁸	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Economizer	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Heat and Cool Air Supply Reset	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Electric Resistance Heating ⁹	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Duct Leakage Sealing and Testing ¹⁰	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Notes:

- Provide equipment tags (e.g. AHU 1 to 10) and system description (e.g. Single Duct VAV reheat) as appropriate. Multiple units with common requirements can be grouped together.
- Provide references to plans (i.e. Drawing Sheet Numbers) and/or specifications (including Section name/number and relevant paragraphs) where each requirement is specified. Enter "N/A" if the requirement is not applicable to this system.
- The referenced plans and specifications must include all of the following information: equipment tag, equipment nominal capacity, Title 24 minimum efficiency requirements, and actual rated equipment efficiencies. Where multiple efficiency requirements are applicable (e.g. full- and part-load) include all. Where appliance standards apply (110.1), identify where equipment is required to be listed per Title 20 1601 et seq.
- Identify where the ventilation requirements are documented for each central HVAC system. Include references to both central unit schedules and sequences of operation. If one or more spaces is naturally ventilated identify where this is documented in the plans and specifications. Multiple zone central air systems must also provide a MCH-03-E compliance document.
- If one or more spaces has demand controlled ventilation identify where it is specified including the sensor specifications and the sequence of operation.
- If one or more space has occupant sensor ventilation control identify where it is specified including the sensor specifications and the sequence of operation.
- If the system is DX: identify the sequences for the system start/stop, optimal start, setback (if required) and setup (if required). For all systems identify the specification for the thermostats and time clocks (if applicable).
- Identify where the heating, cooling and deadband airflowers are scheduled for this system. Include a reference to the specification of the zone controls. Provide a MCH-03-E compliance document.
- Enter N/A if there is no electric heating. If the system has electric heating indicate which exception to 140.4(a) applies.
- If duct leakage sealing and testing is required, a MCH-04-A compliance document must be submitted.

CA Building Energy Efficiency Standards - 2016 Nonresidential Compliance January 2016

STATE OF CALIFORNIA
HVAC DRY & WET SYSTEM REQUIREMENTS
CEC-NRCC-MCH-02-E (Revised 01/16)
CALIFORNIA ENERGY COMMISSION
CERTIFICATE OF COMPLIANCE
HVAC Dry & Wet System Requirements
Project Name: RICHMOND LAKESIDE TENANT IMPROVEMENT Date Prepared: 4/15/19 Page 2 of 3

B. Equipment Tags and System Description¹- Wet Systems

	N/A			
MANDATORY MEASURES	T-24 Sections	Reference to the Requirements in the Contract Documents²		
Heating Hot Water Equipment Efficiency ³	110.1			
Cooling Chilled and Condenser Water Equipment Efficiency ³	110.1, 140.4(i)			
Open and Closed Circuit Cooling Towers conductivity or flow-based controls	110.2(e) 1			
Open and Closed Circuit Cooling Towers Maximum Achievable Cycles of Concentration (LSI) ⁴	110.2(e) 2			
Open and Closed Circuit Cooling Towers Flow Meter with analog output	110.2(e) 3			
Open and Closed Circuit Cooling Towers Overflow Alarm	110.2(e) 4			
Open and Closed Circuit Cooling Towers Efficient Drift Eliminators	110.2(e) 5			
Pipe Insulation	120.3			

PRESCRIPTIVE MEASURES

140.4(h)2, 140.4(h)5	Yes	No	Yes	No	Yes	No
Cooling Tower Fan Controls	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Cooling Tower Flow Controls	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Centrifugal Fan Cooling Towers ⁵	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Air-Cooled Chiller Limitation ⁶	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Variable Flow System Design	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Chiller and Boiler Isolation	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
CHW and H-W Reset Controls	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
WHP Isolation Valves	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
VSD on CHW, CW & WHP Pumps >5HP	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
DP Sensor Location	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Notes:

- Provide equipment tags (e.g. CH 1 to 3) or system description (e.g. CHW loop) as appropriate. Multiple units with common requirements can be grouped together.
- Provide references to plans (i.e. Drawing Sheet Numbers) and/or specifications (including Section name/number and relevant paragraphs) where each requirement is specified. Enter "N/A" if the requirement is not applicable to this system.
- The referenced plans and specifications must include all of the following information: equipment tag, equipment nominal capacity, Title 24 minimum efficiency requirements, and actual rated equipment efficiencies. Where multiple efficiency requirements are applicable (e.g. full- and part-load) include all. For chillers operating at non-standard efficiencies provide the K_{adj} values. For chillers also note whether the efficiencies are Path A or Path B.
- Identify if cooling towers have propeller fans. If towers use centrifugal fans document which exception is used.
- If air-cooled chillers are used, document which exceptions have been used to comply with 140.4(i) and the total installed design capacity of the air-cooled chillers in the chilled water plant.
- Identify the existence of a completed MCH-06-E when open or closed circuit cooling towers are specified to be installed, otherwise enter "N/A".

CA Building Energy Efficiency Standards - 2016 Nonresidential Compliance January 2016

STATE OF CALIFORNIA
HVAC SYSTEM REQUIREMENTS
CEC-NRCC-MCH-02-E (Revised 01/16)
CALIFORNIA ENERGY COMMISSION
CERTIFICATE OF COMPLIANCE
HVAC Wet System Requirements
Project Name: RICHMOND LAKESIDE TENANT IMPROVEMENT Date Prepared: 4/15/19 Page 3 of 3

DOCUMENTATION AUTHOR'S DECLARATION STATEMENT

I, certify that this Certificate of Compliance documentation is accurate and complete.

Documentation Author Name: AMIT WADHWHA Documentation Author Signature: _____
Company: AMIT WADHWHA & ASSOCIATES Signature Date: _____
Address: 870 MARKET STREET, SUITE 846 CEA/RES Certification Identification (if applicable): _____
City/State/Zip: SAN FRANCISCO, CA 94102 Phone: (415) 788-9999

RESPONSIBLE PERSON'S DECLARATION STATEMENT

I certify the following under penalty of perjury, under the laws of the State of California:

- The information provided on this Certificate of Compliance is true and correct.
- I am eligible under Division 3 of the Business and Professions Code to accept responsibility for the building design or system design identified on this Certificate of Compliance (responsible designer).
- The energy features and performance specifications, materials, components, and manufactured devices for the building design or system design identified on this Certificate of Compliance conform to the requirements of Title 24, Part 1 and Part 6 of the California Code of Regulations.
- The building design features or system design features identified on this Certificate of Compliance are consistent with the information provided on other applicable compliance documents, worksheets, calculations, plans and specifications submitted to the enforcement agency for approval with this building permit application.
- I will ensure that a completed signed copy of this Certificate of Compliance shall be made available with the building permit(s) issued for the building, and made available to the enforcement agency for all applicable inspections. I understand that a completed signed copy of this Certificate of Compliance is required to be included with the documentation the builder provides to the building owner at occupancy.

Responsible Designer Name: AMIT WADHWHA Responsible Designer Signature: _____
Company: AMIT WADHWHA & ASSOCIATES Date Signed: _____
Address: 870 MARKET STREET, SUITE 846 License: M30894
City/State/Zip: SAN FRANCISCO, CA 94102 Phone: (415) 788-9999

CA Building Energy Efficiency Standards - 2016 Nonresidential Compliance January 2016

4114 Lakeside Drive
Richmond, CA 94806



909 Montgomery St., Suite 260
San Francisco, California 94133
T 415 546 1212 brereton.com

Stamp



Consultant

AWA
Amit Wadhwa & Associates
Engineers
870 Market Street
Floor 800, Suite 800
San Francisco, CA 94102
415.788.9999
415.617.2076 fax

STATE OF CALIFORNIA

MECHANICAL VENTILATION AND REHEAT

CEC-NRCC-MCH-03-E (Revised 05/16)

CALIFORNIA ENERGY COMMISSION

NRCC-MCH-03-E

Page 1 of 2

CERTIFICATE OF COMPLIANCE

MECHANICAL VENTILATION AND REHEAT

PROJECT NAME: RICHMOND LAKESIDE TENANT IMPROVEMENT

DATE PREPARED: 4/15/19

A MECHANICAL VENTILATION AND REHEAT

In lieu of this compliance document the required outdoor ventilation rates and airflow s may be shown n on the plans or the calculations can be presented in a spreadsheet Mechanical Ventilation and Reheat worksheet available on the Energy Commission's website at: <http://www.energy.ca.gov/9624/2016standards/>.

Note: In all of the calculations that compare a supply quantity to the REQUIRED V.A. quantity the actual percentage of outdoor air in the supply is ignored. Areas in buildings for which natural ventilation is used should be clearly designated. Specifications must require that building operating instructions include explanations of the natural ventilation system.

ACTUAL DESIGN INFO (FROM EQUIPMENT SCHEDULES, ETC.)				AREA BASIS		OCCUPANCY BASIS		ROOM BASIS		MINIMUM		VAV Reheated Primary Air CFM		VAV Deadband Primary Air CFM						
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21
ZONE/SYSTEM/VAV BOX TAG	DESIGN PRIMARY COOLING AIRFLOW (CFM)	DESIGN PRIMARY DEADBAND AIRFLOW (CFM)	DESIGN PRIMARY HEATING AIRFLOW (CFM)	CONTROL TYPE DDC (Y/N)	TRANSFER AIRFLOW (CFM)	CONDITIONED AREA (SF)	MIN CFM PER AREA (CFM/SF)	MIN CFM BY AREA (CFM)	NUM. OF PEOPLE	CFM PER PERSON	MIN CFM BY OCCUPANT (CFM)	MIN CFM BY ROOM (CFM)	REQD VENTILATION AIRFLOW (CFM)	COMPLIES?	BASED DESIGN PRIMARY COOLING AIR	MAXIMUM REHEAT (CFM)	COMPLIES?	PRIMARY COOLING AIR	AIRFLOW	COMPLIES?
FC 1-1	2,540	2,540	2,540	DDC	0	1,715	0.15	257	10	15	150	N/A	257	Y	1,270	1,270	N	508	508	Y
FC 1-2	635	635	635	DDC	0	295	0.15	44	1	15	15	N/A	44	Y	318	318	N	127	127	Y
FC 1-3	1,080	1,080	1,080	DDC	0	654	0.15	98	6	15	90	N/A	98	Y	540	540	N	216	216	Y
FC 1-4	685	685	685	DDC	0	495	0.15	74	10	15	150	N/A	150	Y	343	343	N	137	150	Y
FC 1-5	635	635	635	DDC	0	140	0.15	21	1	15	15	N/A	21	Y	318	318	N	127	127	Y
AC-1	5,415	5,415	5,415	DDC	0	3,185	0.15	478	28	15	420	N/A	478	Y	2,708	2,708	N	1,083	1,083	Y

CA Building Energy Efficiency Standards - 2016 Nonresidential Compliance

May 2016

NOTE:

1. EXISTING AC-1 & NEW FC 1-1 THRU -5 ARE A CONSTANT VOLUME SYSTEM.

2. CALCULATIONS ARE FOR VENTILATION AIR ONLY. REHEAT CALCULATIONS DOES NOT APPLY.

STATE OF CALIFORNIA

MECHANICAL VENTILATION AND REHEAT

CEC-NRCC-MCH-03-E (Revised 05/16)

CALIFORNIA ENERGY COMMISSION

NRCC-MCH-03-E

Page 2 of 2

CERTIFICATE OF COMPLIANCE

MECHANICAL VENTILATION & Reheat

PROJECT NAME: RICHMOND LAKESIDE TENANT IMPROVEMENT

DATE PREPARED: 4/15/19

DOCUMENTATION AUTHOR'S DECLARATION STATEMENT

I certify that this Certificate of Compliance documentation is accurate and complete.

Documentation Author Name: AMIT WADHWHA	Documentation Author Signature:
Company: AMIT WADHWHA & ASSOCIATES	Signature Date:
Address: 870 MARKET STREET, SUITE 846	ATT Certification Identification (If applicable):
City/State/Zip: SAN FRANCISCO, CA 94102	Phone: (415) 788-9999

RESPONSIBLE PERSON'S DECLARATION STATEMENT

I certify the following under penalty of perjury, under the laws of the State of California:

1. The information provided on this Certificate of Compliance is true and correct.

2. I am eligible under Division 3 of the Business and Professions Code to accept responsibility for the building design or system design identified on this Certificate of Compliance (responsible designer).

3. The energy features and performance specifications, materials, components, and manufactured devices for the building design or system design identified on this Certificate of Compliance conform to the requirements of Title 24, Part 1 and Part 6 of the California Code of Regulations.

4. The building design features or system design features identified on this Certificate of Compliance are consistent with the information provided on other applicable compliance documents, worksheets, calculations, plans and specifications submitted to the enforcement agency for approval with this building permit application.

5. I will ensure that a completed signed copy of this Certificate of Compliance shall be made available with the building permit(s) issued for the building, and made available to the enforcement agency for all applicable inspections. I understand that a completed signed copy of this Certificate of Compliance is required to be included with the documentation the builder provides to the building owner at occupancy.

Responsible Designer Name: AMIT WADHWHA	Responsible Designer Signature:
Company: AMIT WADHWHA & ASSOCIATES	Date Signed:
Address: 870 MARKET STREET, SUITE 846	License No: M30894
City/State/Zip: SAN FRANCISCO, CA 94102	Phone: (415) 788-9999

CA Building Energy Efficiency Standards - 2016 Nonresidential Compliance

May 2016

STATE OF CALIFORNIA

OUTDOOR AIR ACCEPTANCE

CEC-NRCA-MCH-02-A (Revised 07/16)

CALIFORNIA ENERGY COMMISSION

NRCA-MCH-02-A

Page 1 of 3

CERTIFICATE OF ACCEPTANCE

Outdoor Air Acceptance

Project Name: RICHMOND LAKESIDE TENANT IMPROVEMENT

Permit Number: 94806

Project Address: 4114 LAKESIDE DRIVE

City: RICHMOND

System Name or Identification Tag: FC

System Location or Area Served: 1ST FLOOR

Note: Submit one Certificate of Acceptance for each system that must demonstrate compliance.

Enforcement Agency Use: Checked by/Date:

Intert:

Verify measured outside airflow reading is within 10% of the total required outside airflow. Required for all newly installed HVAC units. Reference MCH-03 (Columns 14) or Mechanical Equipment Schedules.

A. Construction Inspection

Note: MCH-02-A can be performed in conjunction with MCH-07-A Supply Fan VFD Acceptance (if applicable) since testing activities overlap.

- Supporting documentation needed to perform test includes:
 - As-built and/or design documents (for example, Mechanical Equipment Schedules, Equipment Start-Up Sheets or Balancing Reports).
 - 2016 Building Energy Efficiency Standards Nonresidential Compliance Manual (NA7.5.1.1 Ventilation Systems: Variable Air Systems At-A-Glance and NA7.5.1.2 Constant Volume Systems Outdoor Air Acceptance At-A-Glance).
 - 2016 Building Energy Efficiency Standards.
- Instrumentation needed to perform test includes:
 - Watch
 - Calibrated means to measure airflow (i.e. hot-wire anemometer, velocity pressure probe, etc.).
 - Method and equipment used: _____
 - Equipment calibration date (must be within one year): _____
- System type (check either VAV or CAV): ☐ VAV ☐ CAV
 - Check if Variable Air Volume (VAV) and complete the following:
 - Outside airflow is either factory calibrated or field calibrated.
 - Check if factory calibrated and attach calibration certificate.
 - Check if field calibrated and attach calibration results.
 - Damper Control (must be checked):
 - Dynamic damper control is being used to control outside air. (This is NOT a fixed minimum position).
 - One of the following dynamic controls is being utilized to control outside air (check method used):
 - Outdoor Air CFM Compensation
 - Energy Balance Method
 - Demand Control Ventilation
 - Return Fan Tracking
 - Ejection Fan Method
 - Dedicated Minimum Ventilation Damper with Pressure Control
 - Other Active Control, Describe: _____
 - Check if Constant Air Volume (CAV) and verify the following:
 - System is designed to provide a fixed minimum OSA when the unit is on.
 - Method of delivering outside air to the unit (check one of the following):
 - Outside air is ducted to the return air plenum. Confirm that outside air is ducted to within (check one of the following):
 - 6 ft. of the unit.
 - 15 ft. of the unit, with the air directed substantially toward the unit.
 - Return air plenum is NOT used to distribute outside air to the unit. (i.e. outside air is ducted directly to the unit, outside air is provided independent of the unit, or economizer)
 - Pre-occupancy purge has been programmed for the 1-hour period immediately before the building is normally occupied to provide (one of the following methods must be verified and checked):
 - The conditioned floor area times the ventilation rate from the 2016 Building Energy Efficiency Standards TABLE 120.1.A, or 15 cfm per person time; the expected number of occupants, whichever is greater.
 - Complete air changes to the zone served by the air handler.

CA Building Energy Efficiency Standards - 2016 Nonresidential Compliance

July 2016

STATE OF CALIFORNIA

OUTDOOR AIR ACCEPTANCE

CEC-NRCA-MCH-02-A (Revised 07/16)

CALIFORNIA ENERGY COMMISSION

NRCA-MCH-02-A

Page 2 of 3

CERTIFICATE OF ACCEPTANCE

Outdoor Air Acceptance

Project Name: RICHMOND LAKESIDE TENANT IMPROVEMENT

Permit Number: 94806

Project Address: 4114 LAKESIDE DRIVE

City: RICHMOND

System Name or Identification Tag: FC

System Location or Area Served: 1ST FLOOR

B. NA7.5.1.1 Outdoor Air Acceptance Functional Testing

	CAV	VAV
Step 1: Disable demand control ventilation (if applicable)	<input type="checkbox"/>	<input type="checkbox"/>
Step 2: Verify unit is not in economizer mode during test (economizer disabled)	<input type="checkbox"/>	<input type="checkbox"/>

Note: Shaded boxes do not apply for CAV systems

Step 3: CAV and VAV testing at full supply airflow

Adjust supply air to achieve design airflow or maximum airflow at full cooling. Record VFD speed (Hz).

	CAV	VAV
a. Measured outdoor airflow reading (cfm)	cfm	cfm
b. Required outdoor airflow (cfm) (from MCH-03, Column 14, or Mechanical Equipment Schedules)	cfm	cfm
c. Time for outside air damper to stabilize after full supply airflow is achieved (minutes)	min	min

Step 4: VAV testing at reduced supply airflow

Adjust supply airflow to either the sum of the minimum zone airflows, full heating, or 30% of the total design airflow. Record VFD speed (Hz).

	CAV	VAV
a. Measured outdoor airflow reading (cfm)	cfm	cfm
b. Required outdoor airflow (cfm) (from MCH-03, Column 14, or Mechanical Equipment Schedules)	cfm	cfm
c. Time for outside air damper to stabilize after reduced supply airflow is achieved (minutes)	min	min

Step 5: Return to initial conditions (check)

☐

☐

C. Testing Calculations & Results

Determine Percent Outside Air at full supply airflow (%OA_{full}) for Step 3.

a. %OA _{full} = Measured outdoor airflow reading / Required outdoor airflow. (Step3b/Step3c)	%	%
b. %OA _{full} is within 10% of design Outside Air. (90% ≤ %OA _{full} ≤ 110%)	Yes <input type="checkbox"/> No <input type="checkbox"/>	Yes <input type="checkbox"/> No <input type="checkbox"/>
c. Outside air damper position stabilizes within 5 minutes. (Step 3d < 5 minutes)	Yes <input type="checkbox"/> No <input type="checkbox"/>	Yes <input type="checkbox"/> No <input type="checkbox"/>

Determine Percent Outside Air at reduced supply airflow (%OA_{red}) for Step 4. (VAV only)

a. %OA _{red} = Measured outdoor airflow reading / Required outdoor airflow reading. (Step4b/Step4c)	%	%
b. %OA _{red} is within 10% of design Outside Air. (90% ≤ %OA _{red} ≤ 110%)	Yes <input type="checkbox"/> No <input type="checkbox"/>	Yes <input type="checkbox"/> No <input type="checkbox"/>
c. Outside air damper position stabilizes within 5 minutes. (Step 4d < 5 minutes)	Yes <input type="checkbox"/> No <input type="checkbox"/>	Yes <input type="checkbox"/> No <input type="checkbox"/>

Note: The intent of this test is to ensure that 1) all air handlers provide the minimum amount of OSA and 2) VAV air handlers use dynamic controls to avoid over ventilation.

D. Evaluation

☐ PASS: All Construction Inspection responses are complete and Testing Calculations & Results responses are positive.

CA Building Energy Efficiency Standards - 2016 Nonresidential Compliance

July 2016

STATE OF CALIFORNIA

OUTDOOR AIR ACCEPTANCE

CEC-NRCA-MCH-02-A (Revised 07/16)

CALIFORNIA ENERGY COMMISSION

NRCA-MCH-02-A

Page 3 of 3

CERTIFICATE OF ACCEPTANCE

Outdoor Air Acceptance

Project Name: RICHMOND LAKESIDE TENANT IMPROVEMENT

Permit Number: 94806

Project Address: 4114 LAKESIDE DRIVE

City: RICHMOND

System Name or Identification Tag: FC

System Location or Area Served: 1ST FLOOR

DOCUMENTATION AUTHOR'S DECLARATION STATEMENT

I certify that this Certificate of Acceptance documentation is accurate and complete.

Documentation Author Name: AMIT WADHWHA	Documentation Author Signature:
Company: AMIT WADHWHA & ASSOCIATES	Date Signed:
Address: 870 MARKET STREET, SUITE 846	ATT Certification Identification (If applicable):
City/State/Zip: SAN FRANCISCO, CA 94102	Phone: (415) 788-9999

FIELD TECHNICIAN'S DECLARATION STATEMENT

I certify the following under penalty of perjury, under the laws of the State of California:

1. The information provided on this Certificate of Acceptance is true and correct.

2. I am the person who performed the acceptance verification reported on this Certificate of Acceptance (Field Technician).

3. The construction or installation identified on this Certificate of Acceptance complies with the applicable acceptance requirements indicated in the plans and specifications approved by the enforcement agency, and conforms to the applicable acceptance requirements and procedures specified in Reference Nonresidential Appendix NA7.

4. I have confirmed that the Certificate(s) of Installation for the construction or installation identified on this Certificate of Acceptance has been completed and signed by the responsible builder/installer and has been posted or made available with the building permit(s) issued for the building.

Field Technician Name:	Field Technician Signature:
Field Technician Company Name:	Position with Company (Title):
Address:	ATT Certification Identification (If applicable):
City/State/Zip:	Phone:
	Date Signed:

RESPONSIBLE PERSON'S DECLARATION STATEMENT

I certify the following under penalty of perjury, under the laws of the State of California:

1. I am the Field Technician, or the Field Technician is acting on my behalf as my employee or my agent and I have reviewed the information provided on this Certificate of Acceptance.

2. I am eligible under Division 3 of the Business and Professions Code in the applicable classification to accept responsibility for the system design, construction or installation of features, materials, components, or manufactured devices for the scope of work identified on this Certificate of Acceptance and attest to the declarations in this statement (responsible acceptance person).

3. The information provided on this Certificate of Acceptance substantiates that the construction or installation identified on this Certificate of Acceptance complies with the acceptance requirements indicated in the plans and specifications approved by the enforcement agency, and conforms to the applicable acceptance requirements and procedures specified in Reference Nonresidential Appendix NA7.

4. I have confirmed that the Certificate(s) of Installation for the construction or installation identified on this Certificate of Acceptance has been completed and is posted or made available with the building permit(s) issued for the building.

5. I will ensure that a completed, signed copy of this Certificate of Acceptance shall be posted, or made available with the building permit(s) issued for the building, and made available to the enforcement agency for all applicable inspections. I understand that a signed copy of this Certificate of Acceptance is required to be included with the documentation the builder provides to the building owner at occupancy.

Responsible Acceptance Person Name:	Responsible Acceptance Person Signature:
Responsible Acceptance Person Company Name:	Position with Company (Title):
Address:	DOB License:
City/State/Zip:	Phone:
	Date Signed:

CA Building Energy Efficiency Standards - 2016 Nonresidential Compliance

July 2016

Issue/Revision:

Proj. No. Description
No. Date:

1 32249.01 ISSUE FOR REVIEW
29*1AR19
2 32249.01 ISSUE FOR PERMIT
22*1AR19

Copyright Statement:
All drawings and written material appearing herein constitute original and unpublished original work of the architect and may not be duplicated, used, or disclosed without prior written consent of the architect.
Approval Signature:

Cd/ Title: Date:

MECHANICAL
TITLE 24

Scale: NONE Issue Date: 17APR19
Drawn By: PT Reviewed By: AM
Sheet: 12 of 15

1TM4.0.2

4114 Lakeside Drive
Richmond, CA 94806



909 Montgomery St., Suite 260
San Francisco, California 94133
T 415 546 1212 brereton.com

Stamp



Consultant

AWA
Amit Wadhwa & Associates
Engineers
870 Market Street
14th Floor, Suite 400
San Francisco, CA 94102
415.788.9999
415.617.2076 fax

Issue/Revision:

No. Date: Description

1 32249.01 ISSUE FOR REVIEW
22AFR19

2 32249.01 ISSUE FOR PERMIT
22AFR19

Copyright Statement:
All drawings and written material appearing herein constitute original and unpublished original work of the architect and may not be duplicated, used, or disclosed without prior written consent of the architect.
Approval Signature:

Co./ Title: Date:

**MECHANICAL
TITLE 24**

Scale: NONE Issue Date: 17APR19
Drawn By: PT Reviewed By: AM
Sheet: 13 of 15

1TM4.0.3

STATE OF CALIFORNIA
**CONSTANT VOLUME, SINGLE ZONE, UNITARY (PACKAGED AND SPLIT)
AIR CONDITIONER AND HEAT PUMP SYSTEMS**
CEC-NRCA-MCH-03-A (Revised 01/18) CALIFORNIA ENERGY COMMISSION

CERTIFICATE OF ACCEPTANCE NRCA-MCH-03-A
Constant Volume, Single Zone, Unitary (Packaged and Split) Air-Conditioner and Heat Pump Systems Page 1 of 3

Project Name: RICHMOND LAKESIDE TENANT IMPROVEMENT Enforcement Agency: Permit Number:
Project Address: 4114 LAKESIDE DRIVE City: RICHMOND State Code: 94806
System Name or Identification No.: VAV SYSTEM System Location or Area Served: 1ST FLOOR

Note: Submit one Certificate of Acceptance for each system that must demonstrate compliance. Enforcement Agency Use: Checked by/Date:

A. Construction Inspection

1. Supporting documentation needed to perform test includes, but not limited to:
a. 2016 Building Energy Efficiency Standards Nonresidential Compliance Manual (NA/2.2 Constant Volume, Single-zone, Unitary Air Conditioner and Heat Pumps Systems Acceptance At-A-Glance).
b. 2016 Building Energy Efficiency Standards Manual.
2. Instrumentation to perform test may include:
a. Temperature Meter
b. Amp Meter
3. Installation (check if applies):
☐ Thermostat is located within the space conditioning zone that is served by the HVAC system.
4. Programming (check all those that apply):
☐ Thermostat meets the temperature adjustment and dead band requirements of 2016 Building Energy Efficiency Standards Manual Section 120.1(2).
Minimum heating setpoint: _____°F. Maximum cooling setpoint: _____°F. Deadband: _____°F.
☐ Occupied, unoccupied, and holiday schedules have been programmed per the schedule provided.
☐ Pre-occupancy purge has been programmed to meet the requirements of 2016 Building Energy Efficiency Standards Manual Section 120.1(2).
1. Check method used to determine pre-occupancy purge:
☐ Lesser of: conditioned floor area times ventilation rate from 2016 Building Energy Efficiency Standards TABLE 120.1.A or 15cfm per person times the expected number of occupants.
☐ 3 complete air changes.

Notes:

CA Building Energy Efficiency Standards - 2016 Nonresidential Compliance July 2016

STATE OF CALIFORNIA
**CONSTANT VOLUME, SINGLE ZONE, UNITARY (PACKAGED AND SPLIT)
AIR CONDITIONER AND HEAT PUMP SYSTEMS**
CEC-NRCA-MCH-03-A (Revised 01/18) CALIFORNIA ENERGY COMMISSION

CERTIFICATE OF ACCEPTANCE NRCA-MCH-03-A
Constant Volume, Single Zone, Unitary (Packaged and Split) Air-Conditioner and Heat Pump Systems Page 2 of 3

Project Name: RICHMOND LAKESIDE TENANT IMPROVEMENT Enforcement Agency: Permit Number:
Project Address: 4114 LAKESIDE DRIVE City: RICHMOND State Code: 94806
System Name or Identification No.: VAV SYSTEM System Location or Area Served: 1ST FLOOR

B. Functional Testing Requirements

Step 1: Disable economizer control and demand-controlled ventilation (if applicable) to prevent unexpected interactions.

Occupied Mode

Step 2: Heating load during occupied condition

Step 3: No load during occupied condition

Step 4: Cooling load during occupied condition

Unoccupied Mode

Step 5: No load during unoccupied condition

Step 6: Heating load during unoccupied condition

Step 7: Cooling load during unoccupied condition

Step 8: Manual override

Step 2 - 8: Check and verify the following for each simulation mode required

a. Supply fan operates continuously

b. Supply fan turns off

c. Supply fan cycles on and off

d. System reverts to "occupied" mode to satisfy any condition

e. System turns off when manual override time period expires

f. Gas-fired furnace, heat pump, or electric heater stages on

g. No heating is provided by the unit

h. No cooling is provided by the unit

i. Compressor stages on

j. Outside air damper is open to minimum position

k. Outside air damper closes completely

Step 9: System returned to initial operating conditions after all tests have been completed: Yes ☐ No ☐

C. Testing Results

Indicate if Passed (P), Failed (F), or N/A/DL fill in appropriate letter

D. Evaluation

☐ PASS: All Construction Inspection responses are complete and all applicable Testing Results responses are "Pass" (P).

CA Building Energy Efficiency Standards - 2016 Nonresidential Compliance July 2016

STATE OF CALIFORNIA
**CONSTANT VOLUME, SINGLE ZONE, UNITARY (PACKAGED AND SPLIT)
AIR CONDITIONER AND HEAT PUMP SYSTEMS**
CEC-NRCA-MCH-03-A (Revised 01/18) CALIFORNIA ENERGY COMMISSION

CERTIFICATE OF ACCEPTANCE NRCA-MCH-03-A
Constant Volume, Single Zone, Unitary (Packaged and Split) Air-Conditioner and Heat Pump Systems Page 3 of 3

Project Name: RICHMOND LAKESIDE TENANT IMPROVEMENT Enforcement Agency: Permit Number:
Project Address: 4114 LAKESIDE DRIVE City: RICHMOND State Code: 94806
System Name or Identification No.: VAV SYSTEM System Location or Area Served: 1ST FLOOR

DOCUMENTATION AUTHOR'S DECLARATION STATEMENT

1. I certify that this Certificate of Acceptance documentation is accurate and complete.

Documentation Author Name: AMIT WADHWA Documentation Author Signature: _____
Date Signed: _____
Documentation Author Company Name: AMIT WADHWA & ASSOCIATES Date Signed: _____
Address: 870 MARKET STREET, SUITE 846 CEA Certification Identification (if applicable): _____
City/State/Zip: SAN FRANCISCO, CA 94102 Phone: (415) 788-9999

FIELD TECHNICIAN'S DECLARATION STATEMENT

I certify the following under penalty of perjury, under the laws of the State of California:

1. The information provided on this Certificate of Acceptance is true and correct.

2. I am the person who performed the acceptance verification reported on this Certificate of Acceptance (Field Technician).

3. The construction or installation identified on this Certificate of Acceptance complies with the applicable acceptance requirements indicated in the plans and specifications approved by the enforcement agency, and conforms to the applicable acceptance requirements and procedures specified in Reference Nonresidential Appendix A67.

4. I have confirmed that the Certificate(s) of Installation for the construction or installation identified on this Certificate of Acceptance has been completed and is posted or made available to the enforcement agency for all applicable inspections. I understand that a signed copy of this Certificate of Acceptance is required to be included with the documentation the builder provides to the building owner at occupancy.

Field Technician Name: _____ Field Technician Signature: _____
Field Technician Company Name: _____ Position with Company (Title): _____
Address: _____ CEA Certification Identification (if applicable): _____
City/State/Zip: _____ Phone: _____ Date Signed: _____

RESPONSIBLE PERSON'S DECLARATION STATEMENT

I certify the following under penalty of perjury, under the laws of the State of California:

1. I am the Field Technician, or the Field Technician is acting on my behalf as my employee or my agent and I have reviewed the information provided on this Certificate of Acceptance.

2. I am eligible under Division 3 of the Business and Professions Code in the applicable classification to accept responsibility for the system design, construction or installation of features, materials, components, or manufactured devices for the scope of work identified on this Certificate of Acceptance and attest to the declarations in this statement (responsible acceptance person).

3. The information provided on this Certificate of Acceptance substantiates that the construction or installation identified on this Certificate of Acceptance complies with the acceptance requirements indicated in the plans and specifications approved by the enforcement agency, and conforms to the applicable acceptance requirements and procedures specified in Reference Nonresidential Appendix A67.

4. I have confirmed that the Certificate(s) of Installation for the construction or installation identified on this Certificate of Acceptance has been completed and is posted or made available with the building permit(s) issued for the building.

5. I will ensure that a completed signed copy of this Certificate of Acceptance shall be posted, or made available with the building permit(s) issued for the building, and made available to the enforcement agency for all applicable inspections. I understand that a signed copy of this Certificate of Acceptance is required to be included with the documentation the builder provides to the building owner at occupancy.

Responsible Acceptance Person Name: _____ Responsible Acceptance Person Signature: _____
Responsible Acceptance Person Company Name: _____ Position with Company (Title): _____
Address: _____ CEA License: _____
City/State/Zip: _____ Phone: _____ Date Signed: _____

CA Building Energy Efficiency Standards - 2016 Nonresidential Compliance July 2016

STATE OF CALIFORNIA
MECHANICAL
CEC-NRCA-MCH-01-E (Revised 01/18) CALIFORNIA ENERGY COMMISSION

CERTIFICATE OF INSTALLATION NRCA-MCH-01-E
Mechanical Page 1 of 2

Project Name: RICHMOND LAKESIDE TENANT IMPROVEMENT Enforcement Agency: Permit Number:
Project Address: 4114 LAKESIDE DRIVE City: RICHMOND State Code: 94806

A. GENERAL INFORMATION

DATE OF PERMIT: _____

BUILDING TYPE: ☒ Nonresidential ☐ High-Rise Residential ☐ Hotel/Motel

PHASE OF CONSTRUCTION: ☐ New Construction ☐ Addition ☒ Alteration

B. SCOPE OF RESPONSIBILITY

Enter the date of approval by enforcement agency of the Certificate of Compliance that provides the specifications for the energy efficiency measures for the scope of responsibility for this Installation Certificate. Date: _____

In the table below identify all applicable construction documents that specify the features, materials, components, manufactured devices, or system performance diagnostic results required for the scope of responsibility for this Installation Certificate (continued).

Document Title or Description	Applicable Sheets or Pages, Tables, Schedules, etc.	Date Approved by Enforcement Agency

Add Row Remove Last

CA Building Energy Efficiency Standards - 2016 Nonresidential Compliance January 2016

STATE OF CALIFORNIA
MECHANICAL
CEC-NRCA-MCH-01-E (Revised 01/18) CALIFORNIA ENERGY COMMISSION

CERTIFICATE OF INSTALLATION NRCA-MCH-01-E
Mechanical Page 2 of 2

Project Name: RICHMOND LAKESIDE TENANT IMPROVEMENT Enforcement Agency: Permit Number:
Project Address: 4114 LAKESIDE DRIVE City: RICHMOND State Code: 94806

DOCUMENTATION AUTHOR'S DECLARATION STATEMENT

1. I certify that this Certificate of Installation documentation is accurate and complete.

Documentation Author Name: AMIT WADHWA Documentation Author Signature: _____
Date Signed: _____
Documentation Author Company Name: AMIT WADHWA & ASSOCIATES Date Signed: _____
Address: 870 MARKET STREET, SUITE 846 CEA Certification Identification (if applicable): _____
City/State/Zip: SAN FRANCISCO, CA 94102 Phone: (415) 788-9999

RESPONSIBLE PERSON'S DECLARATION STATEMENT

I certify the following under penalty of perjury, under the laws of the State of California:

1. The information provided on this Certificate of Installation is true and correct.

2. I am eligible under Division 3 of the Business and Professions Code in the applicable classification to accept responsibility for the system design, construction, or installation of features, materials, components, or manufactured devices for the scope of work identified on this Certificate of Installation and attest to the declarations in this statement (responsible builder/installer), otherwise I am an authorized representative of the responsible builder/installer.

3. The constructed or installed features, materials, components or manufactured devices (the installation) identified on this Certificate of Installation conforms to all applicable codes and regulations, and the installation conforms to the requirements given on the plans and specifications approved by the enforcement agency.

4. I reviewed a copy of the Certificate of Compliance approved by the enforcement agency that identifies the specific requirements for the scope of construction or installation identified on this Certificate of Installation, and I have ensured that the requirements that apply to the construction or installation have been met.

5. I will ensure that a completed signed copy of this Certificate of Installation shall be posted, or made available with the building permit(s) issued for the building, and made available to the enforcement agency for all applicable inspections. I understand that a completed signed copy of this Certificate of Installation is required to be included with the documentation the builder provides to the building owner at occupancy.

Responsible Builder/Installer Name: _____ Responsible Builder/Installer Signature: _____
Company Name: (Installing Subcontractor or General Contractor or Builder/Owner) Position With Company (Title): _____
Address: _____ CEA License: _____
City/State/Zip: _____ Phone: _____ Date Signed: _____

CA Building Energy Efficiency Standards - 2016 Nonresidential Compliance January 2016

4114 Lakeside Drive
Richmond, CA 94806



brereton

909 Montgomery St., Suite 260
San Francisco, California 94133
T 415 546 1212 brereton.com

Stamp



Consultant



Amit Wadhwa & Associates
Engineers

870 Market Street
Floor 800, Suite 800
San Francisco, CA 94102
415.768.9999
415.617.2076 fax

Issue/Revision:

No. Date Description

- 1

32249.01
22AFR19

ISSUE FOR REVIEW
- 2

32249.01
22AFR19

ISSUE FOR PERMIT

Copyright Statement:
All drawings and written material appearing herein constitute original and unpublished original work of the architect and may not be duplicated, used, or disclosed without prior written consent of the architect.
Approved Signature:

Co./ Title: Date:

MECHANICAL TITLE 24

Scale: NONE Issue Date: 17APR19
Drawn By: PT Reviewed By: AM
Sheet: 14 of 15

1TM4.0.4

STATE OF CALIFORNIA

PROCESS COMPLIANCE FORMS AND WORKSHEETS

CEC/NRCC-PRC-01-E (Revised 04/19)

CALIFORNIA ENERGY COMMISSION

CERTIFICATE OF COMPLIANCE

NRCC-PRC-01-E

(Page 1 of 3)

CERTIFICATE OF COMPLIANCE

Process Compliance Forms & Checklists

Project Name: RICHMOND LAKESIDE TENANT IMPROVEMENT

Date Prepared: 4/15/19

A. PROCESS COMPLIANCE DOCUMENTS & WORKSHEETS

Check box if worksheet is included.

For detailed instructions on the use of this and all Energy Standards compliance documents, refer to the 2016 Nonresidential Manual.

Note: The Enforcement Agency may require all forms to be incorporated onto the building plans.

YES	NO	Doc/Worksheet #	Title
<input checked="" type="checkbox"/>	<input type="checkbox"/>	PRC-01-E (1 of 2)	Covered Process Certificate of Compliance. Required on plans for all submittals with covered processes.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	PRC-01-E (2 of 2)	Certificate of Compliance, Required Acceptance Tests (PRC-02-A to PRC-08-A). Required on plans for all submittals.
<input type="checkbox"/>	<input checked="" type="checkbox"/>	PRC-02-E	Certificate of Compliance for Enclosed Parking Garage Exhaust Fans
<input type="checkbox"/>	<input checked="" type="checkbox"/>	PRC-03-E	Certificate of Compliance for Commercial Kitchens
<input checked="" type="checkbox"/>	<input type="checkbox"/>	PRC-04-E	Certificate of Compliance for Computer Rooms
<input type="checkbox"/>	<input checked="" type="checkbox"/>	PRC-05-E	Certificate of Compliance for Commercial Refrigeration
<input type="checkbox"/>	<input checked="" type="checkbox"/>	PRC-06-E	Certificate of Compliance for ALL Refrigerated Warehouses
<input type="checkbox"/>	<input checked="" type="checkbox"/>	PRC-07-E	Certificate of Compliance for Refrigerated Warehouse > 3,000 ft ³
<input type="checkbox"/>	<input checked="" type="checkbox"/>	PRC-08-E	Certificate of Compliance for Refrigerated Warehouse Where Multiple Spaces that (i) comprise a total of 3,000ft ³ or more; and (ii) are collectively served by the same refrigeration system (compressor(s) and condenser(s) (central systems).
<input type="checkbox"/>	<input checked="" type="checkbox"/>	PRC-09-E	Certificate of Compliance for Laboratory Exhaust
<input type="checkbox"/>	<input checked="" type="checkbox"/>	PRC-10-E	Certificate of Compliance for Compressed Air Systems
<input type="checkbox"/>	<input checked="" type="checkbox"/>	PRC-11-E	Certificate of Compliance for Process Boilers
<input type="checkbox"/>	<input checked="" type="checkbox"/>	PRC-12-E	Certificate of Compliance for Elevator Lighting and Ventilation Controls
<input type="checkbox"/>	<input checked="" type="checkbox"/>	PRC-13-E	Certificate of Compliance for Escalators and Moving Walkways Speed Controls

CA Building Energy Efficiency Standards - 2016 Nonresidential Compliance April 2016

STATE OF CALIFORNIA

PROCESS COMPLIANCE FORMS AND WORKSHEETS

CEC/NRCC-PRC-01-E (Revised 04/19)

CALIFORNIA ENERGY COMMISSION

CERTIFICATE OF COMPLIANCE

NRCC-PRC-01-E

(Page 2 of 3)

CERTIFICATE OF COMPLIANCE

Process Compliance Forms & Checklists

Project Name: RICHMOND LAKESIDE TENANT IMPROVEMENT

Date Prepared: 4/15/19

B. PROCESS ACCEPTANCE DOCUMENTS

Check box for required compliance documents.

Designer:
This compliance document is to be used by the designer and attached to the plans. Listed below are all the acceptance tests for process systems. The designer is required to check the applicable boxes for all acceptance tests that apply and list all equipment that requires an acceptance test. If all equipment of the same type requires a test, list the equipment description and the number of systems.

Installing Contractor:
The contractor who installed the equipment is responsible to either conduct the acceptance test themselves or have a qualified entity run the test for them. If more than one person has responsibility for the acceptance testing, each person shall sign and submit the Certificate of Acceptance applicable to the portion of the construction or installation for which they are responsible.

Enforcement Agency:
Planchick - The NRCC-PRC-01-E compliance document is not considered a completed document and is not to be accepted by the building department unless the correct boxes are checked.
Inspector - Before occupancy permit is granted all newly installed process systems must be tested to ensure proper operation.

Test Description	PRC-01-A	PRC-02-A	PRC-03-A	PRC-04-A	PRC-05-A	PRC-06-A	PRC-07-A	PRC-08-A	PRC-12-A	PRC-13-A	
Equipment Requiring Testing or Verification	# of Units	Compressed Air Systems	Garage Exhaust	Kitchen Exhaust	R/W Evap Fan Motor Controls	R/W Evap Condenser Controls	R/W Air-Cooled Condenser Controls	R/W Variable Speed Compressors	R/W Elect. Underlab Heating	Elevator Lighting and Ventilation Controls	Escalators and Moving Walkways Speed Controls
FC 1-2	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
FC 1-5	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

CA Building Energy Efficiency Standards - 2016 Nonresidential Compliance April 2016

STATE OF CALIFORNIA

PROCESS COMPLIANCE FORMS AND WORKSHEETS

CEC/NRCC-PRC-01-E (Revised 04/19)

CALIFORNIA ENERGY COMMISSION

CERTIFICATE OF COMPLIANCE

NRCC-PRC-01-E

(Page 3 of 3)

CERTIFICATE OF COMPLIANCE

Process Compliance Forms & Checklists

Project Name: RICHMOND LAKESIDE TENANT IMPROVEMENT

Date Prepared: 4/15/19

DOCUMENTATION AUTHOR'S DECLARATION STATEMENT

I certify that this Certificate of Compliance documentation is accurate and complete.

Documentation Author Name: AMIT WADHWHA

Documentation Author Signature:

Company: AMIT WADHWHA & ASSOCIATES

Signature Date:

Address: 870 MARKET STREET, SUITE 846

CAL/NECS Certification Identification (if applicable):

City/State/Zip: SAN FRANCISCO, CA 94102

Phone: (415) 788-9999

RESPONSIBLE PERSON'S DECLARATION STATEMENT

I certify the following under penalty of perjury, under the laws of the State of California:

1. The information provided on this Certificate of Compliance is true and correct.

2. I am eligible under Division 3 of the Business and Professions Code to accept responsibility for the building design or system design identified on this Certificate of Compliance (responsible designer).

3. The energy features and performance specifications, materials, components, and manufactured devices for the building design or system design identified on this Certificate of Compliance conform to the requirements of Title 24, Part 1 and Part 6 of the California Code of Regulations.

4. The building design features or system design features identified on this Certificate of Compliance are consistent with the information provided on other applicable compliance documents, worksheets, calculations, plans and specifications submitted to the enforcement agency for approval with this building permit application.

5. I will ensure that a completed signed copy of this Certificate of Compliance shall be made available with the building permit(s) issued for the building, and made available to the enforcement agency for all applicable inspections. I understand that a completed signed copy of this Certificate of Compliance is required to be included with the documentation the builder provides to the building owner at occupancy.

Responsible Designer Name: AMIT WADHWHA

Responsible Designer Signature:

Company: AMIT WADHWHA & ASSOCIATES

Date Signed:

Address: 870 MARKET STREET, SUITE 846

License: M30894

City/State/Zip: SAN FRANCISCO, CA 94102

Phone: (415) 788-9999

CA Building Energy Efficiency Standards - 2016 Nonresidential Compliance April 2016

STATE OF CALIFORNIA

COMPUTER ROOM REQUIREMENTS

CEC/NRCC-PRC-04-E (Revised 01/19)

CALIFORNIA ENERGY COMMISSION

CERTIFICATE OF COMPLIANCE

NRCC-PRC-04-E

(Page 1 of 2)

CERTIFICATE OF COMPLIANCE

Computer Room Requirements

Project Name: RICHMOND LAKESIDE TENANT IMPROVEMENT

Date Prepared: 4/15/2019

TOTAL INSTALLED COOLING CAPACITY (TONS)¹: 21.01N

Equipment Tags and System Description ²	FC 1.1		
PRESCRIPTIVE MEASURES	T-24 Sections	Reference to the Requirements in the Contract Documents⁴	
Economizers	140.9(a)1	N/A, SEE EXCEPTION 1.	
Reheat	140.9(a)2	COOLING ONLY UNIT	
Humidification	140.9(a)3	N/A	
Fan Power	140.9(a)4	UNDER 27W/10BTU	
Fan Control	140.9(a)5	N/A, UNDER 60000BTU/H	
Containment	140.9(a)6	N/A, SEE EXCEPTION 2.	

Notes:
1. Enter the total installed cooling capacity for all computer rooms under this permit.
2. Provide equipment tags (e.g. CRAU-1 to 10, AHU 1 to 5 and CH 1 to 3) for all cooling systems that are covered by these requirements. Groups of equipment that are similar can be combined into one column.
3. Provide references to plans (i.e. Drawing Sheet Numbers) and/or specifications (including Section name/number and relevant paragraphs) where each requirement is specified. Enter "N/A" if the requirement is not applicable to this system. Explicitly list any exceptions used to avoid a requirement.

CA Building Energy Efficiency Standards - 2016 Nonresidential Compliance January 2016

STATE OF CALIFORNIA

COMPUTER ROOM REQUIREMENTS

CEC/NRCC-PRC-04-E (Revised 01/19)

CALIFORNIA ENERGY COMMISSION

CERTIFICATE OF COMPLIANCE

NRCC-PRC-04-E

(Page 2 of 2)

CERTIFICATE OF COMPLIANCE

Computer Room Requirements

Project Name: RICHMOND LAKESIDE TENANT IMPROVEMENT

Date Prepared: 4/15/2019

DOCUMENTATION AUTHOR'S DECLARATION STATEMENT

I certify that this Certificate of Compliance documentation is accurate and complete.

Documentation Author Name: AMIT WADHWHA

Documentation Author Signature:

Company: AMIT WADHWHA

Signature Date:

Address: 870 MARKET STREET, SUITE 846

CAL/NECS Certification Identification (if applicable):

City/State/Zip: SAN FRANCISCO, CA 94102

Phone: (415) 738-9829

RESPONSIBLE PERSON'S DECLARATION STATEMENT

I certify the following under penalty of perjury, under the laws of the State of California:

1. The information provided on this Certificate of Compliance is true and correct.

2. I am eligible under Division 3 of the Business and Professions Code to accept responsibility for the building design or system design identified on this Certificate of Compliance (responsible designer).

3. The energy features and performance specifications, materials, components, and manufactured devices for the building design or system design identified on this Certificate of Compliance conform to the requirements of Title 24, Part 1 and Part 6 of the California Code of Regulations.

4. The building design features or system design features identified on this Certificate of Compliance are consistent with the information provided on other applicable compliance documents, worksheets, calculations, plans and specifications submitted to the enforcement agency for approval with this building permit application.

5. I will ensure that a completed signed copy of this Certificate of Compliance shall be made available with the building permit(s) issued for the building, and made available to the enforcement agency for all applicable inspections. I understand that a completed signed copy of this Certificate of Compliance is required to be included with the documentation the builder provides to the building owner at occupancy.

Responsible Designer Name: AMIT WADHWHA

Responsible Designer Signature:

Company: AMIT WADHWHA

Date Signed:

Address: 870 MARKET STREET, SUITE 846

License: M30894

City/State/Zip: SAN FRANCISCO, CA 94102

Phone: (415) 738-9829

CA Building Energy Efficiency Standards - 2016 Nonresidential Compliance January 2016

4114 Lakeside Drive
Richmond, CA 94806



909 Montgomery St., Suite 260
San Francisco, California 94133
T 415 546 1212 b. breton.com

Stamp



Consultant

AWA
Amit Wadhwa & Associates
Engineers

870 Market Street
Phon: 415.546.1212
San Francisco, CA 94102
415.788.9999
415.617.2076 fax

Issue/Revision:

Proj. No. Description

1 32249.01 ISSUE FOR REVIEW

2 32249.01 ISSUE FOR PERMIT

22AFR19

Copyright Statement:
All drawings and written material appearing herein
constitute original and unpublished original work of the
architect and may not be duplicated, used, or disclosed
without prior written consent of the architect.
Approved Signature:

Cd/ Title: Date:

MECHANICAL
TITLE 24

Scale: NONE Issue Date: 17APR19
Drawn By: PT Reviewed By: AM
Sheet: 15 of 15

1TM4.0.5

STATE OF CALIFORNIA
WATER HEATING SYSTEM GENERAL INFORMATION
CEC/NRCC-PLB-01-E (Revised 01/16) CALIFORNIA ENERGY COMMISSION

CERTIFICATE OF COMPLIANCE NRCC-PLB-01-E
Water Heating System General Information (Page 1 of 2)
Project Name: RICHMOND LAKESIDE TENANT IMPROVEMENT Date Prepared: 4/15/19

A. GENERAL INFORMATION/SYSTEM INFORMATION

01	Water Heater System Name:	IWH 1-1
02	Water Heater System Configuration:	Single Dwelling Unit
03	Water Heater System Type:	Domestic Hot Water
04	Building Type:	Nonresidential
05	Total Number of Water Heaters in Systems:	1
06	Central DHW Distribution Type:	N/A
07	Dwelling Unit DHW Distribution Type:	Standard Distribution System (STD)

B. WATER HEATER INFORMATION
Each water heater type requires a separate compliance document.

01	Water Heater Type:	Instantaneous Small - Electric
02	Fuel Type:	Electricity
03	Manufacturer Name:	CHRONOMITE
04	Model Number:	E-40LPL
05	Number of Identical Water Heaters:	1
06	Installed Water Heater System Efficiency:	99%
07	Required Minimum Efficiency:	-
08	Standby Loss Percent or Standby Loss Total:	N/A
09	Rated Input:	4.6 KW
10	Pilot Energy:	N/A
11	Water Heater Tank Storage Volume:	N/A
12	Exterior Insulation on Water Heater:	N/A
13	Volume of Supplemental Storage:	N/A
14	Internal Insulation on Supplemental Storage:	N/A
15	Exterior Insulation on Supplemental Storage:	N/A

C. PLUMBING COMPLIANCE FORMS & WORKSHEETS
Check box if worksheet is included.

For detailed instructions on the use of this and all Energy Standards compliance documents, refer to the 2016 Nonresidential Manual.
Note: The Enforcement Agency may require all compliance documents to be incorporated onto the building plans.

YES	NO	Doc/Worksheet #	Title
<input checked="" type="checkbox"/>	<input type="checkbox"/>	NRCC-PLB-01-E	Certificate of Compliance, Declaration. Required on plans for all submittals.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	NRCL-PLB-01-E	Certificate of Installation. Required on plans for all submittals.
<input type="checkbox"/>	<input type="checkbox"/>	NRCL-PLB-02-E	Certificate of Installation, required on central systems in high-rise residential, hotel/motel application.
<input type="checkbox"/>	<input type="checkbox"/>	NRCL-PLB-03-E	Certificate of Installation, required on single dwelling unit systems in high-rise residential, hotel/motel application.
<input type="checkbox"/>	<input type="checkbox"/>	NRCL-PLB-21-H	Certificate of Installation, required on HERS verified central systems in high-rise residential, hotel/motel application.
<input type="checkbox"/>	<input type="checkbox"/>	NRCL-PLB-22-H	Certificate of Installation, required on HERS verified single dwelling unit systems in high-rise residential, hotel/motel application.
<input type="checkbox"/>	<input type="checkbox"/>	NRCL-STH-01-E	Certificate of Installation, required on any solar water heating.

CA Building Energy Efficiency Standards - 2016 Nonresidential Compliance January 2016

STATE OF CALIFORNIA
WATER HEATING SYSTEM GENERAL INFORMATION
CEC/NRCC-PLB-01-E (Revised 01/16) CALIFORNIA ENERGY COMMISSION

CERTIFICATE OF COMPLIANCE NRCC-PLB-01-E
Water Heating System General Information (Page 1 of 2)
Project Name: RICHMOND LAKESIDE TENANT IMPROVEMENT Date Prepared: 4/15/19

A. GENERAL INFORMATION/SYSTEM INFORMATION

01	Water Heater System Name:	IWH 1-2
02	Water Heater System Configuration:	Single Dwelling Unit
03	Water Heater System Type:	Domestic Hot Water
04	Building Type:	Nonresidential
05	Total Number of Water Heaters in Systems:	1
06	Central DHW Distribution Type:	N/A
07	Dwelling Unit DHW Distribution Type:	Standard Distribution System (STD)

B. WATER HEATER INFORMATION
Each water heater type requires a separate compliance document.

01	Water Heater Type:	Instantaneous Small - Electric
02	Fuel Type:	Electricity
03	Manufacturer Name:	CHRONOMITE
04	Model Number:	E-70LPL
05	Number of Identical Water Heaters:	1
06	Installed Water Heater System Efficiency:	99%
07	Required Minimum Efficiency:	-
08	Standby Loss Percent or Standby Loss Total:	N/A
09	Rated Input:	7.0 KW
10	Pilot Energy:	N/A
11	Water Heater Tank Storage Volume:	N/A
12	Exterior Insulation on Water Heater:	N/A
13	Volume of Supplemental Storage:	N/A
14	Internal Insulation on Supplemental Storage:	N/A
15	Exterior Insulation on Supplemental Storage:	N/A

C. PLUMBING COMPLIANCE FORMS & WORKSHEETS
Check box if worksheet is included.

For detailed instructions on the use of this and all Energy Standards compliance documents, refer to the 2016 Nonresidential Manual.
Note: The Enforcement Agency may require all compliance documents to be incorporated onto the building plans.

YES	NO	Doc/Worksheet #	Title
<input checked="" type="checkbox"/>	<input type="checkbox"/>	NRCC-PLB-01-E	Certificate of Compliance, Declaration. Required on plans for all submittals.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	NRCL-PLB-01-E	Certificate of Installation. Required on plans for all submittals.
<input type="checkbox"/>	<input type="checkbox"/>	NRCL-PLB-02-E	Certificate of Installation, required on central systems in high-rise residential, hotel/motel application.
<input type="checkbox"/>	<input type="checkbox"/>	NRCL-PLB-03-E	Certificate of Installation, required on single dwelling unit systems in high-rise residential, hotel/motel application.
<input type="checkbox"/>	<input type="checkbox"/>	NRCL-PLB-21-H	Certificate of Installation, required on HERS verified central systems in high-rise residential, hotel/motel application.
<input type="checkbox"/>	<input type="checkbox"/>	NRCL-PLB-22-H	Certificate of Installation, required on HERS verified single dwelling unit systems in high-rise residential, hotel/motel application.
<input type="checkbox"/>	<input type="checkbox"/>	NRCL-STH-01-E	Certificate of Installation, required on any solar water heating.

CA Building Energy Efficiency Standards - 2016 Nonresidential Compliance January 2016

STATE OF CALIFORNIA
WATER HEATING SYSTEM GENERAL INFORMATION
CEC/NRCC-PLB-01-E (Revised 01/16) CALIFORNIA ENERGY COMMISSION

CERTIFICATE OF COMPLIANCE NRCC-PLB-01-E
Water Heating System General Information (Page 2 of 2)
Project Name: RICHMOND LAKESIDE TENANT IMPROVEMENT Date Prepared: 4/15/19

DOCUMENTATION AUTHOR'S DECLARATION STATEMENT

I certify that this Certificate of Compliance documentation is accurate and complete.

Documentation Author Name: AMIT WADHWHA
Signature Date: _____
Signature: _____
Address: 870 MARKET STREET, SUITE 846
City/State/Zip: SAN FRANCISCO, CA 94102
Phone: (415) 788-9999

RESPONSIBLE PERSON'S DECLARATION STATEMENT

I certify the following under penalty of perjury, under the laws of the State of California:

- The information provided on this Certificate of Compliance is true and correct.
- I am eligible under Division 3 of the Business and Professions Code to accept responsibility for the building design or system design identified on this Certificate of Compliance (responsible designer).
- The energy features and performance specifications, materials, components, and manufactured devices for the building design or system design identified on this Certificate of Compliance conform to the requirements of Title 24, Part 1 and Part 6 of the California Code of Regulations.
- The building design features or system design features identified on this Certificate of Compliance are consistent with the information provided on other applicable compliance documents, worksheets, calculations, plans and specifications submitted to the enforcement agency for approval with this building permit application.
- I will ensure that a completed signed copy of this Certificate of Compliance shall be made available with the building permit(s) issued for the building, and made available to the enforcement agency for all applicable inspections. I understand that a completed signed copy of this Certificate of Compliance is required to be included with the documentation the builder provides to the building owner at occupancy.

Responsible Designer Name: AMIT WADHWHA
Company: AMIT WADHWHA & ASSOCIATES
Address: 870 MARKET STREET, SUITE 846
City/State/Zip: SAN FRANCISCO, CA 94102
Date Signed: _____
License: M30894
Phone: (415) 788-9999

CA Building Energy Efficiency Standards - 2016 Nonresidential Compliance January 2016

STATE OF CALIFORNIA
PLUMBING
CEC/NRCL-PLB-01-E (Revised 01/16) CALIFORNIA ENERGY COMMISSION

CERTIFICATE OF INSTALLATION NRCL-PLB-01-E
Plumbing (Page 1 of 4)
Project Name: RICHMOND LAKESIDE TENANT IMPROVEMENT Enforcement Agency: Richmond Permit Number: 94806
Project Address: 4114 LAKESIDE DRIVE

A. GENERAL INFORMATION

DATE OF PERMIT: _____

BUILDING TYPE: ☒ Nonresidential ☐ High-Rise Residential ☐ Hotel/Motel

PHASE OF CONSTRUCTION: ☐ New Construction ☐ Addition ☒ Alteration

If more than one person has responsibility for building construction, each person shall prepare and sign an Installation Certificate document applicable to the portion of construction for which they are responsible; alternatively, the person with chief responsibility for construction shall prepare and sign the Installation Certificate document(s) for the entire construction.

B. SCOPE OF RESPONSIBILITY

Enter the date of approval by enforcement agency of the Certificate of Compliance that provides the specifications for the energy efficiency measures for the scope of responsibility for this Installation Certificate.

In the table below identify all applicable construction documents that specify the features, materials, components, manufactured devices, or system performance diagnostic results required for the scope of responsibility for this Installation Certificate (continued).

Document Title or Description	Applicable Sheets or Pages, Tables, Schedules, etc.	Date Approved by Enforcement Agency

Add Row Remove Last

CA Building Energy Efficiency Standards - 2016 Nonresidential Compliance January 2016

STATE OF CALIFORNIA
PLUMBING
CEC/NRCL-PLB-01-E (Revised 01/16) CALIFORNIA ENERGY COMMISSION

CERTIFICATE OF INSTALLATION NRCL-PLB-01-E
Plumbing (Page 2 of 4)
Project Name: RICHMOND LAKESIDE TENANT IMPROVEMENT Enforcement Agency: Richmond Permit Number: 94806
Project Address: 4114 LAKESIDE DRIVE

C. MANDATORY REQUIREMENTS FOR ALL CENTRAL DOMESTIC HOT WATER RECIRCULATION SYSTEMS

On systems that have a total capacity greater than 167,000 Btu/hr, outlets that require higher than service water temperatures as listed in the ASHRAE Handbook have separate remote heaters, heat exchangers, or boosters to supply the outlet with the higher temperature. (Section 110.3(c)(1))

01 Systems with circulating pumps or with electrical heat trace systems shall be capable of automatically turning off the system. (Section 110.3(c)(2))

02 For public lavatories, the control system shall limit the outlet temperature to 110°F. (Section 110.3(c)(3))

03 Unfired storage tanks are insulated with an external R-13 or combination of R-16 internal and external insulation. Alternatively, the heat loss of the tank surface based on an 80°F water-air temperature difference shall be less than 6.5 Btu per hour per square foot. (Section 110.3(c)(4))

04 All sections of the recirculation loop, and the first 5 feet of all branches off the loop are insulated, to the thicknesses required by Table 120.3A, except for the following: (RA4.4.1)

- Piping installed in interior or exterior walls that is surrounded on all sides by at least 1 inch of insulation.
- Piping installed in attics with a minimum of 4 inches (10 cm) of attic insulation on top
- Piping that penetrates framing members shall not be required to have pipe insulation for the distance of the framing penetration. Metal piping that penetrates metal framing shall use grommets, plugs, wrapping or other insulating material to assure that no contact is made with the metal framing. Insulation shall butt securely against all framing members.
- Insulation is not required on the cold water line when it is used as the return

05 Hot water pipes that are buried below grade are installed in a water proof and non-crushable casing or sleeve that allows for installation, removal, and replacement of the enclosed pipe and insulation. (RA4.4.1)

06 Insulation outside conditioned space is protected from damage, including that due to sunlight, moisture, equipment maintenance, and wind. (RA4.4.1)

07 Pipe insulation fits tightly to the pipe. (RA4.4.1)

08 On insulated sections of pipe, no piping is visible due to insulation voids, and all elbows and tees are fully insulated. (RA4.4.1)

09 The recirculation pump is mounted on a vertical section of the return line, OR an automatic air release valve is installed on a riser at least 12 inches in length, on the inlet side of the recirculation pump, no more than 4 feet from the pump. (Section 110.3(c)(5A))

10 A check valve is located between the recirculation pump and the water heater. (Section 110.3(c)(5B))

11 A hose bibb is installed between the pump and the water heating equipment with an isolation valve between the hose bibb and the water heating equipment. (Section 110.3(c)(5C))

12 Isolation valves are installed on both sides of the pump. One of the isolation valves may be the same isolation valve as in Item 12 above. (Section 110.3(c)(5D))

13 The cold water supply piping and the recirculation loop piping is not connected to the hot water storage tank drain port. (Section 110.3(c)(5E))

14 A check valve is installed on the cold water supply line between the hot water system and the next closest tee on the cold water supply. (Section 110.3(c)(5F))

15 The hot water distribution system piping from the water heater(s) to the fixtures and appliances takes the most direct path. (RA 4.4.7.1)

16 Installation and operation instructions that provide details of the operation of the pump and controls are available at the jobsite for inspection. (RA 4.4.7.1)

17 More than one circulation loop may be installed. Each loop shall have its own pump and controls. (RA4.4.8, RA 4.4.9, RA 4.4.10)

The responsible person's signature on this compliance document affirms that all applicable requirements in this table have been met.

STATE OF CALIFORNIA
PLUMBING
CEC/NRCL-PLB-01-E (Revised 01/16) CALIFORNIA ENERGY COMMISSION

CERTIFICATE OF INSTALLATION NRCL-PLB-01-E
Plumbing (Page 3 of 4)
Project Name: RICHMOND LAKESIDE TENANT IMPROVEMENT Enforcement Agency: Richmond Permit Number: 94806
Project Address: 4114 LAKESIDE DRIVE

D. MANDATORY MEASURES FOR ALL SINGLE DWELLING HOT WATER DISTRIBUTION SYSTEMS

01 Equipment shall meet the applicable requirements of the Appliance Efficiency Regulations (Section 110.3(b)(1)).

02 Unfired Storage Tanks are insulated with an external R-12 or combination of R-16 internal and external insulation. (Section 110.3(c)(4))

The following pipes are insulated, to the thicknesses required by Table 120.3A, except for those sections of pipe that are subject to one of the exceptions below: (RA4.4.1)

- The first 5 feet (1.5 meters) of hot and cold water pipes from the storage tank.
- All piping with a nominal diameter of 3/4 inch (19 millimeter) or larger.
- All piping associated with a domestic hot water recirculation system regardless of the pipe diameter, except when cold water return is used in a demand system.
- Piping from the heating source to storage tank or between tanks.
- Piping buried below grade.
- All hot water pipes from the heating source to the kitchen fixtures.
- All piping sections of pipe do not have to be insulated: (RA4.4.1)
- Piping installed in interior or exterior walls that is surrounded on all sides by at least 1 inch of insulation.
- Piping installed in attics with a minimum of 4 inches (10 cm) of attic insulation on top
- Piping that penetrates framing members shall not be required to have pipe insulation for the distance of the framing penetration. Metal piping that penetrates metal framing shall use grommets, plugs, wrapping or other insulating material to assure that no contact is made with the metal framing. Insulation shall butt securely against all framing members.

03 Piping buried below grade must be installed in a water proof and non-crushable casing or sleeve that allows for installation, removal, and replacement of the enclosed pipe and insulation. (Section 150.0(i))

04 All elbows and tees shall be fully insulated. (RA4.4.1)

05 Where insulation is required, no piping shall be visible due to insulation voids, and all insulation shall fit tightly to the pipe. (RA4.4.1)

06 For Gas or Propane Water Heaters: Ensure the following are installed (Section 150.0(n))

- A 120W electrical receptacle is within 3 feet from the water heater and accessible with no obstructions
- A Category III or IV vent, or a Type B vent with straight pipe between outside and water heater
- A condensate drain no more than 2 inches higher than the base on water heater for natural draining
- A gas supply line with capacity of at least 200,000 Btu/hr

The responsible person's signature on this compliance document affirms that all applicable requirements in this table have been met.

STATE OF CALIFORNIA
PLUMBING
CEC/NRCL-PLB-01-E (Revised 01/16) CALIFORNIA ENERGY COMMISSION

CERTIFICATE OF INSTALLATION NRCL-PLB-01-E
Plumbing (Page 4 of 4)
Project Name: RICHMOND LAKESIDE TENANT IMPROVEMENT Enforcement Agency: Richmond Permit Number: 94806
Project Address: 4114 LAKESIDE DRIVE

DOCUMENTATION AUTHOR'S DECLARATION STATEMENT

I certify that this Certificate of Installation documentation is accurate and complete.

Documentation Author Name: AMIT WADHWHA
Signature Date: _____
Signature: _____
Address: 870 MARKET STREET, SUITE 846
City/State/Zip: SAN FRANCISCO, CA 94102
Phone: (415) 788-9999

RESPONSIBLE PERSON'S DECLARATION STATEMENT

I certify the following under penalty of perjury, under the laws of the State of California:

- The information provided on this Certificate of Installation is true and correct.
- I am eligible under Division 3 of the Business and Professions Code in the applicable classification to accept responsibility for the system design, construction, or installation of features, materials, components, or manufactured devices for the scope of work identified on this Certificate of Installation and attest to the declarations in this statement (responsible builder/installer), otherwise I am an authorized representative of the responsible builder/installer.
- The constructed or installed features, materials, components or manufactured devices (the installation) identified on this Certificate of Installation conforms to all applicable codes and regulations, and the installation conforms to the requirements given on the plans and specifications approved by the enforcement agency.
- I reviewed a copy of the Certificate of Compliance approved by the enforcement agency that identifies the specific requirements for the scope of construction or installation identified on this Certificate of Installation, and I have ensured that the requirements that apply to the construction or installation have been met.
- I will ensure that a completed signed copy of this Certificate of Installation shall be posted, or made available with the building permit(s) issued for the building, and made available to the enforcement agency for all applicable inspections. I understand that a completed signed copy of this Certificate of Installation is required to be included with the documentation the builder provides to the building owner at occupancy.

Responsible Builder/Installer Name: _____ Responsible Builder/Installer Signature: _____
Company Name: (Including Subcontractor or General Contractor or Builder/Owner) Position With Company (Title): _____
Address: _____ CCB License: _____
City/State/Zip: _____ Phone: _____ Date Signed: _____