

**BAY AREA AIR QUALITY MANAGEMENT DISTRICT
Best Available Control Technology (BACT) Guideline**

Source Category

Source:	Gas Turbine	Revision:	1
		Document #:	89.1.5
Class:	Combined Cycle (> = 2.0 MW and < 40 MW)	Date:	07/18/03

Determination

POLLUTANT	BACT 1. Technologically Feasible/ Cost Effective 2. Achieved in Practice	TYPICAL TECHNOLOGY
POC	1. n/d 2. 2.0 ppmv, Dry @ 15%O ₂ ^{a,b}	1. n/d 2. Oxidation Catalyst ^{a,b}
NO _x	1. 2.5 ppmv, Dry @ 15%O ₂ ^a (achieved in practice for >12 MW) ^a 2. 5.0 ppmv, Dry @ 15%O ₂ ^{a,b}	1. SCR + Water or Steam Injection; or SCONO _x ^a 2. SCR + Water or Steam Injection ^{a,b}
SO ₂	1. Natural Gas Fuel ^a 2. Natural Gas Fuel ^a	1. Fuel Selection ^a 2. Fuel Selection ^a
CO	1. n/d 2. 6.0 ppmv, Dry @15% O ₂ ^{a,b}	1. n/d 2. Oxidation Catalyst ^{a,b}
PM ₁₀	1. Natural Gas Fuel ^a 2. Natural Gas Fuel ^{a,b}	1. Fuel Selection ^a 2. Fuel Selection ^{a,b}
NPOC	1. n/a 2. n/a	1. n/a 2. n/a

References

- a. *Guidance for the Permitting of Electrical Generation Technologies*, CalEPA Air Resources Board, Stationary Source Division, July 2002
b. Application #10962, UCSF Cogeneration Plant