

**BAY AREA AIR QUALITY MANAGEMENT DISTRICT
Best Available Control Technology (BACT) Guideline**

Source Category

Source:	IC Engine-Compression Ignition: Stationary Emergency, non- Agricultural, non-direct drive fire pump	Revision:	0
		Document #:	96.1.5
Class:	≥ 1000 BHP Output	Date:	12/22/2020*

Determination

Pollutant	BACT 1. Technologically Feasible/ Cost Effective 2. Achieved in Practice 3. TBACT	TYPICAL TECHNOLOGY
POC (NMHC)	1. n/s ^a 2. 0.14 g/bhp-hr ^b	1. n/s ^a 2. Any engine certified or verified to achieve the applicable standard
NOx	1. n/s ^a 2. 0.5 g/bhp-hr ^b	1. n/s ^a 2. Any engine certified or verified to achieve the applicable standard
SO₂	1. n/s ^a 2. Fuel sulfur content not to exceed 0.0015% (wt) or 15 ppm (wt)	1. n/s ^a 2. CARB Diesel Fuel (Ultra Low Sulfur Diesel)
CO	1. n/s ^a 2. 2.6 g/bhp-hr ^b	1. n/s ^a 2. Any engine certified or verified to achieve the applicable standard
PM₁₀	1. n/s ^a 2. 0.02 g/bhp-hr ^b 3. 0.02 g/bhp-hr	1. n/s ^a 2. Any engine or technology demonstrated, certified or verified to achieve the applicable standard 3. Any engine or technology demonstrated, certified or verified to achieve the applicable standard
NPOC	1. n/s 2. n/s	1. n/s 2. n/s

* Applies to open permit applications with a complete date on or after 1/1/2020.

References

- a. Cost effectiveness analysis must be based on lesser of 50 hr/yr or non-emergency operation as limited by District health risk screen analysis.
- b.
 1. BAAQMD Application 27020 San Jose/Santa Clara Water Pollution Control
 2. BAAQMD Application 25115 Sutro Tower, Inc.
 3. Microsoft MWH Data Center, Quincy, Washington
Tier 4-Compliant (Tier 2 engines abated by catalyzed diesel particulate filter and selective catalytic reduction)
<https://ecology.wa.gov/Air-Climate/Air-quality/Data-Centers>
 4. Comments by the California Air Resources Board on the California Energy Commission's Proposed Decision for the Proposed Sequoia Data Center project (19-SPPE-03), Attachment 2: Tier 4 Diesel Emergency Generator Engines