

## ENGINEERING EVALUATION

Facility ID No. 201802  
Facebook MPK 62 & 63  
125 & 135 Constitution Drive, Menlo Park, CA 94025  
Application No. 492585

### Background

On behalf of Facebook, Cupertino Electric, Inc. is applying for an Authority to Construct/Permit to Operate for the following equipment:

- S-1 Emergency Standby Diesel Generator Set (for MPK 63)**  
**Make: Cummins, Model: QSX15-G9, Model Year: 2019**  
**755 bhp, 4.12 MMBtu/hr**  
**Permit Condition Nos. 100072 and 100073**
- S-2 Emergency Standby Diesel Generator Set (for MPK 62)**  
**Make: Cummins, Model: QSX15-G9, Model Year: 2019**  
**755 bhp, 4.12 MMBtu/hr**  
**Permit Condition Nos. 100072 and 100073**

The criteria pollutants are nitrogen oxides (NO<sub>x</sub>), carbon monoxide (CO), precursor organic compounds (POC) from unburned diesel fuel, sulfur dioxide (SO<sub>2</sub>) and particulate matter (PM<sub>10</sub>). All of these pollutants are briefly discussed on the District's web site at [www.baaqmd.gov](http://www.baaqmd.gov).

S-1 and S-2 meets the Environmental Protection Agency and California Air Resources Board (EPA/CARB) Tier 2 Off-road standard. The engine will burn commercially available California low sulfur diesel fuel. The sulfur content of the diesel fuel will not exceed 0.0015% by weight.

This evaluation report will discuss compliance of the proposed project with all applicable rules and regulations.

### Emissions

**Table 1. Annual and Daily Emissions from EPA Emissions Data for S-1 & S-2**

<b>Pollutant</b>	<b>Emission Factor (g/bhp-hr)</b>	<b>Max Daily Emissions (lb/day)</b>	<b>Annual Emissions (lb/yr)</b>	<b>Annual Emissions (tons/yr)</b>
NO <sub>x</sub>	4.21	167.86	349.71	0.175
POC	0.07	2.98	6.20	0.003
CO	0.45	17.86	37.20	0.019
PM <sub>10</sub> /PM <sub>2.5</sub> <sup>1</sup>	0.10	3.87	8.06	0.004
SO <sub>2</sub>	N/A <sup>2</sup>	0.22	0.46	0.000

Basis:

- Annual emissions: Reliability-related activity 50 hours for S-1 and S-2
- Max daily emissions: 24-hour operation
- Emission factors from EPA Engine Family KCEXL015.AAJ for S-1 and S-2
- <sup>1</sup> Conservative Assumption: All PM emissions are PM<sub>2.5</sub>.
- <sup>2</sup>SO<sub>2</sub> emission factor from AP-42 Table 3.4-1, SO<sub>2</sub> (15 ppm) = 0.00809\*0.0015 lb SO<sub>2</sub>/bhp-hr

### **Cumulative Increase**

Table 2 summarizes the cumulative increase in criteria pollutant emissions that will result from this application.

**Table 2. Cumulative Emissions Increase, Post 4/5/91**

<b>Pollutant</b>	<b>Existing Emissions Post 4/5/91 (tons/yr)</b>	<b>Application Emissions (tons/yr)</b>	<b>Cumulative Emissions (tons/yr)</b>
NO <sub>x</sub>	0.000	0.350	0.350
POC	0.000	0.006	0.006
CO	0.000	0.037	0.037
PM <sub>10</sub> /PM <sub>2.5</sub>	0.000	0.008	0.008
SO <sub>2</sub>	0.000	0.000	0.000

### **Health Risk Assessment (HRA)**

At a maximum rate of 8.06 lbs/year per engine, the diesel particulate emissions from the project are greater than the toxic trigger level of 0.26 lbs/year. All PM<sub>10</sub> emissions are considered diesel particulate emissions. There were no other related projects permitted in the last three years.

Based on 50 hours/year of operation, this project passed the HRA conducted on 1/6/2020 by the District's Permitting, Title V & Toxics Section. Results from the HRA indicate that the maximum project cancer risk is estimated at 1.7 in a million, and the maximum project chronic hazard index is estimated at 0.0013. In accordance with the District's Regulation 2, Rule 5, these sources are in compliance with the TBACT and project risk requirements.

### **Best Available Control Technology (BACT)**

In accordance with Regulation 2-2-301, BACT is triggered for any new or modified source with the potential to emit 10 pounds or more per highest day of POC, NPOC, NO<sub>x</sub>, CO, SO<sub>2</sub>, or PM<sub>10</sub>.

BACT for this source is presented in the current BAAQMD BACT/TBACT Workbook for IC Engine – Compression Ignition: Stationary Emergency, non-Agricultural, non-direct drive fire pump, Document #96.1.3, Revision 7. dated 12/22/2010. For NO<sub>x</sub>, CO, POC and PM<sub>10</sub>, BACT(2) is the CARB ATCM standard for the respective pollutant at the applicable horsepower rating. For SO<sub>2</sub>, BACT(2) is using fuel with sulfur content not to exceed 0.0015%, or 15 ppm. The more restrictive BACT(1) standards are not applicable to this engine because it will be limited to operation as an emergency standby engine.

S-1 and S-2 satisfy the current BACT(2) standards for the following pollutants which exceed 10 lb/day in Table 1:

<b>Pollutant</b>	<b>Emission Factor</b>	<b>BACT(2) Standard</b>
NO <sub>x</sub>	4.21 g/bhp-hr	4.56 g/bhp-hr
CO	0.45 g/bhp-hr	2.60 g/bhp-hr

**Offsets**

Offset must be provided for any new or modified source at a facility that will have the potential to emit more than 10 tons per year of NO<sub>x</sub> or POC, as specified in Regulation 2-2-302; and more than 100 tons per year of PM<sub>2.5</sub>, PM<sub>10</sub> or sulfur dioxide, as specified in Regulation 2-2-303.

**Table 3. Potential to Emit for Facility #201802**

<b>Pollutant</b>	<b>Existing Emissions (TPY)</b>	<b>Application Annual Emissions* (TPY)</b>	<b>Facility Annual Emissions (TPY)</b>	<b>Offset Requirement (TPY)</b>	<b>Offset Required?</b>
NO <sub>x</sub>	0.000	1.049	1.049	10	N
POC	0.000	0.019	0.019	10	N
CO	0.000	0.112	0.112	-	N
PM <sub>10</sub> /PM <sub>2.5</sub>	0.000	0.024	0.024	100	N
SO <sub>2</sub>	0.000	0.001	0.001	100	N

*\*Annual emissions: Reliability-related activity of 50 hours and emergency operation of 100 hours for S-1 and S-2*

Based on the emission calculations in Table 3, offsets are not required for this application.

**Statement of Compliance**

The owner/operator is expected to comply with all applicable requirements. Key requirements are listed below:

**Airborne Toxic Control Measure for Stationary Compression Ignition Engines**  
 ATCM, 5/19/2011, section 93115, title 17, CA Code of Regulations

### **District Rules**

Regulation 6-1-303 (*Ringelmann No. 2 Limitation*)

Regulation 9-1-301 (*Limitations on Ground Level Concentrations of SO<sub>2</sub>*)

Regulation 9-8 (*NO<sub>x</sub> and CO from Stationary Internal Combustion Engines*)

Section 9-8-110.5 – Limited exemption for emergency standby engines

Section 9-8-330 – Hours of operation for emergency standby engines

Section 9-8-502 – Recordkeeping

### **California Environmental Quality Act (CEQA)**

This project is ministerial under the District Regulation 2-1-311 (Permit Handbook Chapter 2.3), and is therefore not subject to CEQA review.

### **New Source Performance Standards (NSPS)**

40 CFR 60, Subpart IIII (*Stationary Compression Ignition Internal Combustion Engines*)

### **National Emissions Standards for Hazardous Air Pollutants (NESHAP)**

40 CFR 63, Subpart ZZZZ (*Stationary Reciprocating Internal Combustion Engines (RICE)*)

### **Prevention of Significant Deterioration (PSD)**

This application is not part of a PSD project as defined in Regulation 2-2.

### **School Notification (Regulation 2-1-412)**

This project is located within 1,000 feet from the nearest K-12 school, and is therefore subject to the public notification requirements of Regulation 2-1-412.

### **Permit Conditions**

#### **Permit Condition #100072 for S-1 and S-2**

1. The owner or operator shall operate each emergency standby engine only for the following purposes: to mitigate emergency conditions, for emission testing to demonstrate compliance with a District, state or Federal emission limit, or for reliability-related activities (maintenance and other testing, but excluding emission testing). Operating while mitigating emergency conditions or while emission testing to show compliance with District, state or Federal emission limits is not limited.

[Basis: Title 17, California Code of Regulations, section 93115, ATCM for Stationary CI Engines]

2. The owner/operator shall operate each emergency standby engine only when a non-resettable totalizing meter (with a minimum display capability of 9,999 hours) that measures the hours of operation for the engine is installed, operated and properly maintained.

[Basis: Title 17, California Code of Regulations, section 93115, ATCM for Stationary CI Engines]

3. Records: The owner/operator shall maintain the following monthly records in a District-approved log for at least 36 months from the date of entry (60 months if the facility has been issued a Title V Major Facility Review Permit or a Synthetic Minor Operating Permit). Log entries shall be retained on-site, either at a central location or at the engine's location, and made immediately available to the District staff upon request.
  - a. Hours of operation for reliability-related activities (maintenance and testing).
  - b. Hours of operation for emission testing to show compliance with emission limits.
  - c. Hours of operation (emergency).
  - d. For each emergency, the nature of the emergency condition.
  - e. Fuel usage for each engine(s).

[Basis: Title 17, California Code of Regulations, section 93115, ATCM for Stationary CI Engines]

4. At School and Near-School Operation: If the emergency standby engine is located on school grounds or within 500 feet of any school grounds, the following requirements shall apply: The owner or operator shall not operate each stationary emergency standby diesel-fueled engine for non-emergency use, including maintenance and testing, during the following periods:
  - a. Whenever there is a school sponsored activity (if the engine is located on school grounds)
  - b. Between 7:30 a.m. and 3:30 p.m. on days when school is in session.  
"School" or "School Grounds" means any public or private school used for the purposes of the education of more than 12 children in kindergarten or any of grades 1 to 12, inclusive, but does not include any private school in which education is primarily conducted in a private home(s). "School" or "School Grounds" includes any building or structure, playground, athletic field, or other areas of school property but does not include unimproved school property.

[Basis: Title 17, California Code of Regulations, section 93115, ATCM for Stationary CI Engines]

**Permit Condition #100073 for S-1 and S-2**

The owner/operator shall not exceed the following limits per year per engine for reliability-related activities:

- 50 Hours of Diesel fuel (Diesel fuel)

[Basis: Cumulative Increase; Regulation 2-5; Title 17, California Code of Regulations, section 93115, ATCM for Stationary CI Engines].

*End of Conditions*


**Recommendation**

The District has reviewed the material contained in the permit application for the proposed project and has made a preliminary determination that the project is expected to comply with all applicable requirements of District, state and federal air quality-related regulations. The preliminary recommendation is to issue an Authority to Construct for the equipment listed below. However, the proposed source will be located within 1,000 feet of a school, which triggers the public notification requirements of District Regulation 2-1-412. After the comments are received and reviewed, the District will make a final determination on the permit.

I recommend that the District initiate a public notice and consider any comments received prior to taking any final action on issuance of an Authority to Construct/Permit to Operate for the following source:

**S-1 Emergency Standby Diesel Generator Set**  
**Make: Cummins, Model: QSX15-G9, Model Year: 2019**  
**755 bhp, 4.12 MMBtu/hr**  
**Permit Condition Nos. 100072 and 100073**

**S-2 Emergency Standby Diesel Generator Set**  
**Make: Cummins, Model: QSX15-G9, Model Year: 2019**  
**755 bhp, 4.12 MMBtu/hr**  
**Permit Condition Nos. 100072 and 100073**

Prepared by: 

Date: 1/7/2019

Huiting Gao  
Air Quality Engineer I