

DRAFT ENGINEERING EVALUATION
Facility ID No. 202292
South Loop, Bldg "C"
1410 Harbor Bay Parkway, Alameda, CA 94502
Application No. 640580

Background

South Loop, Bldg "C" is applying for an Authority to Construct for the following equipment:

- S-1 Emergency Standby Diesel Fire Pump**
Make: JOHN DEERE, Model: 4045HFG82A, Model Year: 2020
157 bhp, 1.37 MMBtu/hr
Permit Condition Nos. 100072, 100073 and 100076

The criteria pollutants are nitrogen oxides (NO_x), carbon monoxide (CO), precursor organic compounds (POC) from unburned diesel fuel, sulfur dioxide (SO₂) and particulate matter (PM₁₀). The pollutants are briefly discussed on the District's web site at www.baaqmd.gov.

S-1 meets the Environmental Protection Agency and California Air Resources Board (EPA/CARB) Tier 3 Off-road standard. The engine will burn commercially available California low sulfur diesel fuel. The sulfur content of the diesel fuel will not exceed 0.0015% by weight.

This evaluation report will discuss compliance of the proposed project with all applicable rules and regulations.

Emissions

Table 1. Annual and Daily Emissions from EPA/CARB Certified Data from S-1

Pollutant	Emission Factor (g/bhp-hr)	Max Daily Emissions (lb/day)	Annual Emissions (lb/yr)	Annual Emissions (tons/yr)
NO _x	2.58	21.39	30.30	0.015
POC	0.13	1.11	1.57	0.001
CO	0.82	6.79	9.62	0.005
PM ₁₀ /PM _{2.5} ¹	0.10	0.86	1.22	0.001
SO ₂	N/A ²	0.05	0.06	0.000

Basis:

- Annual emissions: Reliability-related activity 34 hours for S-1
- Max daily emissions: 24-hour operation
- Emissions from EPA Engine Family LJDXL04.5119 for S-1
- ¹ Conservative Assumption: All PM emissions are PM_{2.5}
- ² SO₂ emission factor from AP-42 Table 3.4-1, SO₂ (15 ppm) = 0.00809*0.0015 lb SO₂/bhp-hr

Plant Cumulative Increase

Table 2 summarizes the cumulative increase in criteria pollutant emissions that will result from this application.

Table 2. Plant Cumulative Emissions Increase, Post 4/5/91

Pollutant	Existing Emissions Post 4/5/91 (tons/yr)	Application Emissions (tons/yr)	Cumulative Emissions (tons/yr)
NO _x	0.000	0.015	0.015
POC	0.000	0.001	0.001
CO	0.000	0.005	0.005
PM ₁₀ /PM _{2.5}	0.000	0.001	0.001
SO ₂	0.000	0.000	0.000

Health Risk Assessment (HRA)

At a maximum rate of 1.22 lbs/year, the diesel particulate emissions from the project are greater than the toxic trigger level of 0.26 lb/year. All PM₁₀ emissions are considered diesel particulate emissions. There were no other related projects permitted in the last three years.

S-1 is subject to the District's HRA streamlining policy for stationary diesel-fueled combustion engines used for backup power or fire pumps. The included HRA streamlining policy checklist shows that a refined HRA is not required for this permit application. The project is presumed to be in compliance with project risk requirements as recommended, limiting reliability-related activity hours by permit condition.

Best Available Control Technology (BACT)

In accordance with Regulation 2-2-301, BACT is triggered for any new or modified source with the potential to emit 10 pounds or more per highest day of POC, NPOC, NO_x, CO, SO₂, or PM₁₀.

BACT for this source is presented in the current BAAQMD BACT/TBACT Workbook for IC Engine – Compression Ignition: Stationary Emergency, non-Agricultural, non-direct drive fire pump, 50-1000 bhp, Document #96.1.3, Revision 8, dated 12/22/2020. For NO_x, CO, POC and PM₁₀, BACT(2) is the CARB ATCM standard for the respective pollutant at

the applicable horsepower rating. For SO₂, BACT(2) is using fuel with sulfur content not to exceed 0.0015%, or 15 ppm. The more restrictive BACT(1) standards are not applicable to this engine because it will be limited to operation as an emergency standby engine.

S-1 satisfies the current BACT(2) standards for the following pollutants which exceed 10 lb/day in Table 1:

Pollutant	Emission Factor	BACT(2) Standard
NO _x	2.58 g/bhp-hr	2.85 g/bhp-hr

* The standard is expressed as 3.0 g/bhp of NMHC + NO_x. NO_x is estimated to be 95% of the combined standard (3.0*0.95 = 2.85 g/bhp-hr)

Offsets

Since the facility permitted levels are below the offset trigger levels specified in Regulation 2-2, offsets are not required.

Statement of Compliance

The owner/operator is expected to comply with all applicable requirements. Key requirements are listed below:

Airborne Toxic Control Measure for Stationary Compression Ignition Engines
ATCM, 5/19/2011, section 93115, title 17, CA Code of Regulations

District Rules

Regulation 6-1-303 (*Ringelmann No. 2 Limitation*)

Regulation 9-1-301 (*Limitations on Ground Level Concentrations of SO₂*)

Regulation 9-8 (*NO_x and CO from Stationary Internal Combustion Engines*)

Section 9-8-110.5 – Limited exemption for emergency standby engines

Section 9-8-330 – Hours of operation for emergency standby engines

Section 9-8-502 – Recordkeeping

California Environmental Quality Act (CEQA)

This project is ministerial under the District Regulation 2-1-311 (Permit Handbook Chapter 2.3) and is therefore not subject to CEQA review.

New Source Performance Standards (NSPS)

40 CFR 60, Subpart IIII (*Stationary Compression Ignition Internal Combustion Engines*)

National Emissions Standards for Hazardous Air Pollutants (NESHAP)

40 CFR 63, Subpart ZZZZ (*Stationary Reciprocating Internal Combustion Engines (RICE)*)

Prevention of Significant Deterioration (PSD)

This application is not part of a PSD project as defined in Regulation 2-2.

School Notification (Regulation 2-1-412)

Because this equipment will be located within 1,000 feet of Coastline Christian School, the project is subject to the public notification requirements of Regulation 2-1-412 due to the increase in emissions from the project.

A public notice will be sent to all parents of students of the above mentioned school(s) and all residents within 1,000 feet of the facility. There will be a 30-day public comment period.

Permit Conditions

Permit Condition #100072 for S-1

1. The owner or operator shall operate each emergency standby engine only for the following purposes: to mitigate emergency conditions, for emission testing to demonstrate compliance with a District, state or Federal emission limit, or for reliability-related activities (maintenance and other testing, but excluding emission testing). Operating while mitigating emergency conditions or while emission testing to show compliance with District, state or Federal emission limits is not limited.
[Basis: Title 17, California Code of Regulations, section 93115, ATCM for Stationary CI Engines]

2. The owner/operator shall operate each emergency standby engine only when a non-resettable totalizing meter (with a minimum display capability of 9,999 hours) that measures the hours of operation for the engine is installed, operated and properly maintained.
[Basis: Title 17, California Code of Regulations, section 93115, ATCM for Stationary CI Engines]

3. Records: The owner/operator shall maintain the following monthly records in a District-approved log for at least 36 months from the date of entry (60 months if the facility has been issued a Title V Major Facility Review Permit or a Synthetic Minor Operating Permit). Log entries shall be retained on-site, either at a central location or at the engine’s location, and made immediately available to the District staff upon request.
 - a. Hours of operation for reliability-related activities (maintenance and testing).
 - b. Hours of operation for emission testing to show compliance with emission limits.
 - c. Hours of operation (emergency).
 - d. For each emergency, the nature of the emergency condition.
 - e. Fuel usage for each engine(s).
[Basis: Title 17, California Code of Regulations, section 93115, ATCM for Stationary CI Engines]

4. At School and Near-School Operation: If the emergency standby engine is located on school grounds or within 500 feet of any school grounds, the following requirements shall apply: The owner or operator shall not operate each stationary emergency standby diesel-fueled engine for non-emergency use, including maintenance and testing, during the following periods:
- a. Whenever there is a school sponsored activity (if the engine is located on school grounds)
 - b. Between 7:30 a.m. and 3:30 p.m. on days when school is in session.
- 'School' or 'School Grounds' means any public or private school used for the purposes of the education of more than 12 children in kindergarten or any of grades 1 to 12, inclusive, but does not include any private school in which education is primarily conducted in a private home(s). 'School' or 'School Grounds' includes any building or structure, playground, athletic field, or other areas of school property but does not include unimproved school property.
[Basis: Title 17, California Code of Regulations, section 93115, ATCM for Stationary CI Engines]

Permit Condition #100073 for S-1

The owner/operator shall not exceed the following limits per year per engine for reliability-related activities:

- 34 Hours of Diesel fuel (Diesel fuel)
[Basis: Cumulative Increase; Regulation 2-5; Title 17, California Code of Regulations, section 93115, ATCM for Stationary CI Engines]

Permit Condition #100076 for S-1

The owner/operator shall operate this emergency standby engine only when directly coupled to pump(s) exclusively used in water-based fire protection system(s).

[Basis: Title 17, California Code of Regulations, section 93115, ATCM for Stationary CI Engines]

End of Conditions

Recommendation

The District has reviewed the material contained in the permit application for the proposed project and has made a preliminary determination that the project is expected to comply with all applicable requirements of District, State and federal air quality-related regulations. The preliminary recommendation is to issue an Authority to Construct for the equipment listed below. However, the proposed source will be located within 1000 feet of a school which triggers the public notification requirements of District Regulation

2-1-412. After the comments are received and reviewed, the District will make a final determination on the permit.

I recommend that the District initiate a public notice and consider any comments received prior to taking any final action on issuance of an Authority to Construct/Permit to Operate to change permit conditions for the following source:

S-1 Emergency Standby Diesel Fire Pump
Make: JOHN DEERE, Model: 4045HFG82A, Model Year: 2020
157 bhp, 1.37 MMBtu/hr
Permit Condition Nos. 100072, 100073 and 100076

Prepared By: Sheryl Wallace, Senior Air Quality Technician

Attachment 1

BAY AREA AIR QUALITY MANAGEMENT DISTRICT Best Available Control Technology (BACT) Guideline
--

Source Category

Source:	IC Engine-Compression Ignition: Stationary Emergency, non- Agricultural, non-direct drive fire pump	Revision:	8
		Document #:	96.1.3
Class:	> 50 BHP and < 1000 BHP Output	Date:	12/22/2020*

Determination

Pollutant	BACT 1. Technologically Feasible/ Cost Effective 2. Achieved in Practice 3. TBACT	TYPICAL TECHNOLOGY
POC (NMHC)	1. n/s ^c 2. CARB ATCM standard ^a for POC at applicable horsepower rating (see attached Table 1).	1. n/s ^c 2. Any engine certified or verified to achieve the applicable standard. ^a
NOx	1. n/s ^c 2. CARB ATCM standard ^a for NOx at applicable horsepower rating (see attached Table 1).	1. n/s ^c 2. Any engine certified or verified to achieve the applicable standard. ^a
SO₂	1. n/s ^c 2. Fuel sulfur content not to exceed 0.0015% (wt) or 15 ppm (wt).	1. n/s ^c 2. CARB Diesel Fuel (Ultra Low Sulfur Diesel)
CO	1. n/s ^c 2. CARB ATCM standard ^a for CO at the applicable horsepower rating (see attached Table 1).	1. n/s ^c 2. Any engine certified or verified to achieve the applicable standard. ^a
PM₁₀	1. n/s ^c 2. 0.15 g/bhp-hr 3. 0.15 g/bhp-hr	1. n/s ^c 2. Any engine or technology demonstrated, certified or verified to achieve the applicable standard. 3. Any engine or technology demonstrated, certified or verified to achieve the applicable standard.
NPOC	1. n/s 2. n/s	1. n/s 2. n/s

* Applies to open permit applications with a complete date on or after 1/1/2020.

References

- | | |
|----|---|
| a. | ATCM standard (listed below): Where NMHC + NOx is listed (with no individual standards for NOx or NMHC) as the standard, the portions may be considered 95% NOx and 5% NMHC. For the purposes of determining BACT NMHC = POC. Any engine which has been certified or demonstrated to meet the current year tier standard may be considered compliant with the certified emission standard for that pollutant. |
| b. | Deleted (no longer applies). |
| c. | Cost- effectiveness analysis must be based on lesser of 50 hr/yr or non-emergency operation as limited by District health risk screen analysis. |

Table 1: BACT 2 Emission Limits based on CARB ATCM

Emissions Standards for Stationary Emergency Standby Diesel-Fueled CI Engines ≥ 50 BHP g/Kw-hr (g/bhp-hr)			
Maximum Engine Power	PM	NMHC+NOx	CO
37 \leq KW < 56 (50 < HP < 75)	0.20 (0.15)	4.7 (3.5)	5.0 (3.7)
56 \leq KW < 75 (75 < HP < 100)	0.20 (0.15)	4.7 (3.5)	5.0 (3.7)
75 \leq KW < 130 (100 < HP < 175)	0.20 (0.15)	4.0 (3.0)	5.0 (3.7)
130 \leq KW < 225 (175 \leq HP < 300)	0.20 (0.15)	4.0 (3.0)	3.5 (2.6)
225 \leq KW < 450 (300 < HP < 600)	0.20 (0.15)	4.0 (3.0)	3.5 (2.6)
450 \leq KW \leq 560 (600 < HP \leq 750)	0.20 (0.15)	4.0 (3.0)	3.5 (2.6)
560 < KW < 750 (750 < HP < 1000)	0.20 (0.15)	6.4 (4.8)	3.5 (2.6)