

**BAAQMD Title V Permit
6 Month Monitoring Report**

From 7/1/2014 to 12/31/2014

A0011 Shell Oil Products US Martinez Refinery	
<u>Facility Address:</u> 3485 Pacheco Blvd	<u>Mailing Address:</u> PO Box 711
City: Martinez	City: Martinez
State: CA	State: CA
Zip Code: 94553-0071	Zip Code: 94553-0071
Contact: Liz Rosales	Title: Environmental Speciali Phone: (925) 313-3857

Inoperable monitors as defined by BAAQMD Regulations 1-522 and 1-523 for the reporting period are summarized below:

Started	Stopped	Source (S#)	Abatement Device (A#)	Emission Point (P#)	CEM	GLM	Fuel Gas	Parametri	NOx	SO2	CO	H2S	TRS	NH3	O2	CO2	H2O	Opacity/LTA	Lead	Steam Flow	Wind Dir.	Wind Speed	pH	Temp.	VOC.	Gauge Press.	
9/3/2014 8:40 AM	9/8/2014 4:00 PM							<input checked="" type="checkbox"/>																			
Event Description: The Parametric Cooling water tower Hydrocarbon analyzer 40A1708 out of service for over 24 hours. Analyzer membrane had plugging issues. Part was ordered and analyzer repaired.																											
9/24/2014 7:45 AM	9/25/2014 1:00 PM	4002	A4002		<input checked="" type="checkbox"/>				<input checked="" type="checkbox"/>																		
Event Description: 45A257 - DCU Heater Stack NOx analyzer was out of service for replacement. The replacement analyzer was RATA tested and certified by the BAAQMD as of 1:00 pm on 9/25/14.																											
12/17/2014 2:20 AM	12/20/2014 11:30 AM	1471						<input checked="" type="checkbox"/>													<input checked="" type="checkbox"/>						
Event Description: LOP Flare flow parametric meter 9F3126 A&B out of service for greater than 24 hours.																											

Certification Statement

I certify under penalty of law that based on the information and belief formed after reasonable inquiry, the statements and information in this document and in all attachments and other materials are true, accurate, and complete.

Signature of Responsible Official: *Paul Gabbard* Print Name: Paul Gabbard Title: General Manager Date: Jan 15, 2015