Bay Area Air Quality Management District

939 Ellis Street San Francisco, CA 94109 (415) 771-6000

Proposed

MAJOR FACILITY REVIEW PERMIT

Issued To:

City <u>o</u>←f Santa Clara, Electric Department Facility #A0621

Facility Address:

524 Robert Avenue Santa Clara, CA 95050

Mailing Address:

1500 Warburton Avenue Santa Clara, CA 95050

Responsible Official

Jennifer Sparacino, City Manager (408)_615-2210

Facility Contact

Ken D. SpeerOrville Plum (408) 423-6553615-6562

Type of Facility: Cogeneration Facility BAAQMD Permit Division Contact:

Primary SIC: 4911 Robert T. Hull Madhav Patil

Product: Electric Power and Process Steam

ISSUED BY THE BAY AREA AIR QUALITY MANAGEMENT DISTRICT

Jack P. Broadbent, Executive Officer/Air Pollution Control Officer

Date

TABLE OF CONTENTS

I.	STANDARD CONDITIONS	3
II.	EQUIPMENT	7
III.	GENERALLY APPLICABLE REQUIREMENTS	8
IV.	SOURCE-SPECIFIC APPLICABLE REQUIREMENTS	. 11
V.	SCHEDULE OF COMPLIANCE	. 16
VI.	PERMIT CONDITIONS	. 16
VII.	APPLICABLE LIMITS & COMPLIANCE MONITORING REQUIREMENTS	. 19
VIII.	TEST METHODS	. 24
IX.	PERMIT SHIELD	. 26
X.	REVISION HISTORY	. 27
XI.	GLOSSARY	. 28

I. STANDARD CONDITIONS

A.

B.

Adn	ninistrative Requirements
Th	e permit holder shall comply with all applicable requirements in the following
-	gulations:
\mathbf{B}^{A}	AAQMD Regulation 1 - General Provisions and Definitions
	(as amended by the District Board on $\frac{5/2/017/9/085/4/11}{7}$);
SI	P Regulation 1 - General Provisions and Definitions
	(as approved by EPA through 6/28/99);
\mathbf{B}^{A}	AAQMD Regulation 2, Rule 1 - Permits, General Requirements
	(as amended by the District Board on $\frac{6}{15}$ /05 $\frac{3}{4}$ /09);
SI	P Regulation 2, Rule 1 - Permits, General Requirements
	(as approved by EPA through 1/26/99);
\mathbf{B}^{A}	AAQMD Regulation 2, Rule 2 - Permits, New Source Review
	(as amended by the District Board on 6/15/05);
SI	P Regulation 2, Rule 2 - Permits, New Source Review and Prevention of Significant
	terioration
200	(as approved by EPA through 1/26/99);
R/	AAQMD Regulation 2, Rule 4 - Permits, Emissions Banking
Di	(as amended by the District Board on12/21/04); and
ÇTI	P Regulation 2, Rule 4 - Permits, Emissions Banking
SII	(as approved by EPA through 1/26/99)-,.
D /	· 11 · ·
<u>B</u> F	AAQMD Regulation 2, Rule 5 – New Source Review of Toxic Air Contaminants
D /	(as amended by the District Board on 01/06/10);
BA	AAQMD Regulation 2, Rule 6 - Permits, Major Facility Review
	(as amended by the District Board on 4/16/03)-, and
<u>S1</u>	P Regulation 2, Rule 6 – Permits, Major Facility Review
	(as approved by EPA through 6/23/95).
Con	ditions to Implement Regulation 2, Rule 6, Major Facility Review
1.	This Major Facility Review Permit expires on The permit holder shall
	submit a complete application for renewal of this Major Facility Review Permit no
	later than and no earlier than If a complete application for
	renewal has not been submitted in accordance with these deadlines, the facility
	may not operate after If the permit renewal has not been issued by
	, but a complete application for renewal has been submitted in
	accordance with the above deadlines, the existing permit will continue in force until
	the District takes final action on the renewal application. (Regulation 2-6-307, 404.2,
	407, & 409.6; MOP Volume II, Part 3, §4.2) (Regulation 2-6-307, 404.2, & 409.6;
2	MOP Volume II, Part 3, §4.2)
2.	The permit holder shall comply with all conditions of this permit. The permit
	consists of this document and all appendices. Any non-compliance with the terms
	and conditions of this permit will constitute a violation of the law and will be grounds
	for enforcement action; permit termination, revocation and re-issuance, or
	modification; or denial of a permit renewal application. (Regulation 2-6-307; MOP
	Volume II, Part 3, §4.11)

I. Standard Conditions

- 3. In the event any enforcement action is brought as a result of a violation of any term or condition of this permit, the fact that it would have been necessary for the permittee to halt or reduce the permitted activity in order to maintain compliance with such term or condition shall not be a defense to such enforcement action. (MOP Volume II, Part 3, §4.11)
- 4. This permit may be modified, revoked, reopened and reissued, or terminated for cause. (Regulation 2-6-307, 409.8, 415; MOP Volume II, Part 3, §4.11)
- 5. The filing of a request by the facility for a permit modification, revocation and reissuance, or termination, or the filing of a notification of planned changes or anticipated non-compliance does not stay the applicability of any permit condition. (Regulation 2-6-409.7; MOP Volume II, Part 3, §4.11)
- 6. This permit does not convey any property rights of any sort, nor any exclusive privilege. (Regulation 2-6-409.7; MOP Volume II, Part 3, §4.11)
- 7. The permit holder shall supply within 30 days any information that the District requests in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. (Regulation 1-441, Regulation 2-6-409.4 & 501; MOP Volume II, Part 3, §4.11)
- 8. Any records required to be maintained pursuant to this permit that the permittee considers to contain proprietary or trade secret information shall be prominently designated as such. Copies of any such proprietary or trade secret information which are provided to the District shall be maintained by the District in a locked confidential file, provided, however, that requests from the public for the review of any such information shall be handled in accordance with the District's procedures set forth in Section 11 of the District Administrative Code. (Regulation 2-6-419; MOP Volume II, Part 3, §4.11)
- 9. Proprietary or trade secret information provided to EPA will be subject to the requirements of 40 CFR Part 2, Subpart B Public Information, Confidentiality of Business Information. (40 CFR Part 2)
- 10. The emissions inventory submitted with the application for this Major Facility Review Permit is an estimate of actual emissions or the potential to emit for the time period stated and is included only as one means of determining applicable requirements for emission sources. It does not establish, or constitute a basis for establishing, any new emission limitations. (MOP Volume II, Part 3, §4.11)
- 11. The responsible official shall certify all documents submitted by the facility pursuant to the major facility review permit. The certification shall state that based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete. The certifications shall be signed by a responsible official for the facility. (Regulation 2-6-409.20, MOP Volume II, Part 3, §4.11)
- 12. The permit holder is responsible for compliance, and certification of compliance, with all conditions of the permit, regardless whether it acts through employees, agents, contractors, or subcontractors. (Regulation 2-6-307)

Renewal Date:

I. Standard Conditions

C. Requirement to Pay Fees

The permit holder shall pay annual fees in accordance with District Regulation 3, including Schedule P. (Regulation 2-6-402 & 409.13, Regulation 3; MOP Volume II, Part 3, §4.12)

D. Inspection and Entry

Access to Facility: The permit holder shall provide reasonable access to the facility and equipment which is subject to this permit to the APCO and/or to his or her designee. (Regulation 1-440, Regulation 2-6-409.3; MOP Volume II, Part 3, §4.14)

E. Records

- 1. The permit holder must provide any information, records, and reports requested or specified by the APCO. (Regulation 1-441, Regulation 2-6-409.4)
- 2. Notwithstanding the specific wording in any requirement, all records for federally enforceable requirements shall be maintained for at least five years from the date of entry. (Regulation 2-6-501, Regulation 3; MOP Volume II, Part 3, §4.7)

F. Monitoring Reports

Reports of all required monitoring must be submitted to the District at least once every six months, except where an applicable requirement specifies more frequent reporting. The reporting periods for this permit shall be March 1st through August 31st and September 1st through February 28th or 29th. Each report is due on the last day of the month after the end of the reporting period. All instances of non-compliance shall be clearly identified in these reports. The reports shall be certified by the responsible official as true, accurate, and complete. In addition, all instances of non-compliance with the permit shall be reported in writing to the District's Compliance and Enforcement Division within 10 calendar days of the discovery of the incident. Within 30 calendar days of the discovery of any incident of non-compliance, the facility shall submit a written report including the probable cause of non-compliance and any corrective or preventative actions. The reports shall be sent to the following address:

Director of Compliance and Enforcement Bay Area Air Quality Management District 939 Ellis Street San Francisco, CA 94109 Attn: Title V Reports

(Regulation 2-6-502, Regulation 3; MOP Volume II, Part 3, §4.7)

G. Compliance Certification

Compliance certifications shall be submitted annually by the responsible official of this facility to the Bay Area Air Quality Management District and to the Environmental Protection Agency. The certification period will be March 1st to February 28th or 29th of the following year. The certification shall be submitted by March 31st of each year. The certification must list each applicable requirement, the compliance status, whether

Renewal Date:	
---------------	--

I. Standard Conditions

compliance was continuous or intermittent, the method used to determine compliance, and any other specific information required by the permit. The permit holder may satisfy this requirement through submittal of District-generated Compliance Certification forms. The certification should be directed to the District's Compliance and Enforcement Division at the address above, and a copy of the certification should be sent to the Environmental Protection Agency at the following address:

Director of the Air Division USEPA, Region IX 75 Hawthorne Street San Francisco, CA 94105 Attention: Air-3

(MOP Volume II, Part 3, §4.5 and 4.15)

H. Emergency Provisions

- 1. The permit holder may seek relief from enforcement action in the event of a breakdown, as defined by Regulation 1-208 of the District's Rules and Regulations, by following the procedures contained in Regulations 1-431 and 1-432. The District will thereafter determine whether breakdown relief will be granted in accordance with Regulation 1-433. (MOP Volume II, Part 3, §4.8)
- 2. The permit holder may seek relief from enforcement action for a violation of any of the terms and conditions of this permit by applying to the District's Hearing Board for a variance pursuant to Health and Safety Code Section 42350. The Hearing Board will determine after notice and hearing whether variance relief should be granted in accordance with the procedures and standards set forth in Health and Safety Code Section 42350 et seq. (MOP Volume II, Part 3, §4.8)
- 3. The granting by the District of breakdown relief or the issuance by the Hearing Board of a variance will not provide relief from federal enforcement. (MOP Volume II, Part 3, §4.8)

I. Severability

In the event that any provision of this permit is invalidated by a court or tribunal of competent jurisdiction, or by the Administrator of the EPA, all remaining portions of the permit shall remain in full force and effect. (Regulation 2-6-409.5; MOP Volume II, Part 3, §4.10)

J. Miscellaneous Conditions

The maximum capacity for each source as shown in Table II-A is the maximum allowable capacity. Exceedance of the maximum allowable capacity for any source is a violation of Regulation 2, Rule 1, Section 301. (Regulation 2-1-301

Renewal D	Date:
-----------	-------

II. EQUIPMENT

Table II A - Permitted Sources

Each of the following sources has been issued a permit to operate pursuant to the requirements of BAAQMD Regulation 2, Permits. The capacities in this table are the maximum allowable capacities for each source, pursuant to Standard Condition I.J and Regulation 2-1-301.

S-#	Description	Make or Type	Model	Capacity
1	Gas Turbine w/Water Injection,	Allison	501 KB	3,800 KW; 55.1
	Natural Gas Fired			MMBTU/hr
2	Gas Turbine w/Water Injection,	Allison	501 KB	3,800 KW, 55.1
	Natural Gas Fired			MMBTU/hr
3	Supplemental Duct Burner,	Coen	GDB-20	20 MMBTU/hr
	Natural Gas Fired			
4	Supplemental Duct Burner,	Coen	GDB-20	20 MMBTU/hr
	Natural Gas Fired			

III. GENERALLY APPLICABLE REQUIREMENTS

The permit holder shall comply with all applicable requirements, including those specified in the BAAQMD and SIP Rules and Regulations and other federal requirements cited below. These requirements apply in a general manner to the facility and/or to sources exempt from the requirement to obtain a District Permit to Operate. The District has determined that these requirements would not be violated under normal, routine operations, and that no additional periodic monitoring or reporting to demonstrate compliance is warranted. In cases where a requirement, in addition to being generally applicable, is also specifically applicable to one or more sources, the requirement and the source are also included in Section IV, Source-Specific Applicable Requirements, of this permit. This section also contains provisions that may apply to temporary sources.

The dates in parentheses in the Title column identify the versions of the regulations being cited and are, as applicable:

- 1. BAAQMD regulation(s): The date(s) of adoption or most recent amendment of the regulation by the District Board of Directors.
- 2. Any federal requirement, including a version of a District regulation that has been approved into the SIP: The most recent date of EPA approval of any portion of the rule, encompassing all actions on the rule through that date

The full language of SIP requirements is on EPA Region 9's website. The address is: http://yosemite.epa.gov/r9/r9sips.nsf/Agency?ReadForm&count=500&state=California&cat=Bay+Area+Air+Quality+Management+District-Agency-Wide+Provisions

NOTE:

There are differences between the current BAAQMD rule and the version of the rule in the SIP. All sources must comply with <u>both</u> versions of the rule until US EPA has reviewed and approved the District's revision of the regulation.

Table III
Generally Applicable Requirements

		Federally
Applicable	Regulation Title or	Enforceable
Requirement	Description of Requirement	(Y/N)
BAAQMD Regulation 1	General Provisions and Definitions (5/2/015/4/11)	Y
SIP Regulation 1	General Provisions and Definitions (6/28/99)	Y
BAAQMD Regulation 2, Rule 1	General Requirements (12/21/043/4/09)	N
BAAQMD 2-1-429	Federal Emissions Statement (12/21/04)	<u>¥N</u>
SIP Regulation 2, Rule 1	General Requirements (1/26/99)	\mathbf{Y}^{1}
SIP Regulation 2-1-429	Federal Emissions Statement (4/3/95)	<u>Y</u>
BAAQMD Regulation 2, Rule 5	New Source Review of Toxic Air Contaminants	<u>N</u>
	(01/06/10)	

8

III. Generally Applicable Requirements

Table III Generally Applicable Requirements

		Federally
Applicable	Regulation Title or	Enforceable
Requirement	Description of Requirement	(Y/N)
BAAQMD Regulation 4	Air Pollution Episode Plan (3/20/91)	N
SIP Regulation 4	Air Pollution Episode Plan (8/06/90)	\mathbf{Y}^{1}
BAAQMD Regulation 5	Open Burning (<u>7/09/08</u> <u>3/6/02</u>)	Y
SIP Regulation 5	Open Burning (9/4/98)	Y ¹
BAAQMD Regulation 6	Particulate Matter and Visible Emissions (12/19/90)	¥
BAAQMD Regulation 6, Rule 1	Particulate Matter, General Requirements (12/5/07)	<u>N</u>
SIP Regulation 6	Particulate Matter and Visible Emissions (9/4/98)	<u>Y</u>
BAAQMD Regulation 7	Odorous Substances (3/17/82)	N
BAAQMD Regulation 8, Rule 1	Organic Compounds - General Provisions (6/15/94)	Y
BAAQMD Regulation 8, Rule 2	Organic Compounds – Miscellaneous Operations (7/20/056/15/94)	¥ <u>N</u>
SIP Regulation 8, Rule 2	Organic Compounds – Miscellaneous Operations (3/22/95)	<u>Y</u>
BAAQMD Regulation 8, Rule 3	Organic Compounds - Architectural Coatings (11/21/017/1/09)	N
SIP Regulation 8, Rule 3	Organic Compounds - Architectural Coatings (1/2/04)	<u>Y</u>
BAAQMD Regulation 8, Rule 4	Organic compounds - General Solvent and Surface Coating Operations (10/16/02)	Y
BAAOMD Regulation 8, Rule 15	Organic Compounds – Emulsified and Liquid Asphalts (6/1/94)	<u>Y</u>
BAAQMD Regulation 8, Rule 16	Organic Compounds - Solvent Cleaning Operations (10/16/02)	Y
BAAQMD Regulation 8, Rule 40	Organic Compounds – Aeration of Contaminated Soil and Removal of Underground Storage Tanks (12/15/996/15/05)	Y
SIP Regulation 8, Rule 40	Organic Compounds - Aeration of Contaminated Soil and Removal of Underground Storage Tanks (4/19/01)	<u>Y</u>
BAAQMD Regulation 8, Rule 47	Organic Compounds – Air Stripping and Soil Vapor Extraction Operations (6/15/056/15/94)	<u>¥N</u>
SIP Regulation 8, Rule 47	Organic Compounds - Air Stripping and Soil Vapor Extraction Operations (4/26/95)	<u>Y</u>
BAAQMD Regulation 8, Rule 49	Organic Compounds - Aerosol Paint Products (12/20/95)	N
SIP Regulation 8, Rule 49	Organic Compounds - Aerosol Paint Products (3/22/95)	\mathbf{Y}^1
BAAQMD Regulation 8, Rule 51	Organic Compounds - Adhesive and Sealant Products (7/17/02)	N

III. Generally Applicable Requirements

Table III
Generally Applicable Requirements

		Federally
Applicable	Regulation Title or	Enforceable
Requirement	Description of Requirement	(Y/N)
SIP Regulation 8, Rule 51	Organic Compounds - Adhesive and Sealant Products (2/26/02)	Y^1
BAAQMD Regulation 9, Rule 1	<u>Inorganic Gaseous Pollutants - Sulfur Dioxide (3/15/95)</u>	<u>N</u>
SIP Regulation 9, Rule 1	Inorganic Gaseous Pollutants - Sulfur Dioxide (6/8/99)	<u>Y</u>
BAAQMD Regulation 11, Rule 1	Hazardous Pollutants - Lead (3/17/82)	N
SIP Regulation 11, Rule 1	Hazardous Pollutants – Lead (9/2/81)	Y^1
BAAQMD Regulation 11, Rule 2	Hazardous Pollutants - Asbestos Demolition, Renovation and Manufacturing (10/7/98)	<u>¥N</u>
BAAQMD Regulation 12, Rule 4	Miscellaneous Standards of Performance - Sandblasting (7/11/90)	N
SIP Regulation 12, Rule 4	Miscellaneous Standards of Performance - Sandblasting (9/2/81)	Y^1
California Health and Safety Code Section 41750 et seq.	Portable Equipment	N
California Health and Safety Code Section 44300 et seq.	Air Toxics "Hot Spots" Information and Assessment Act of 1987	N
California Health and Safety Code Title 17, Section 93116	Airborne Toxic Control Measure for Diesel Particulate Matter from Portable Engines Rated at 50 Horsepower and Greater	<u>N</u>
40 CFR Part 61, Subpart M	National Emission Standards for Hazardous Air Pollutants – National Emission Standard for Asbestos (7/20/04)	Y
40 CFR Part 61, Subpart A	National Emission Standards for Hazardous Air Pollutants – General Provisions (5/28/03)	Y

This section has been removed from BAAQMD Regulations because it has been superseded. Nevertheless, the source must comply with this regulation until US EPA has reviewed and approved (or disapproved) the District's revision of the regulation

Renewal Date:

IV. SOURCE-SPECIFIC APPLICABLE REQUIREMENTS

The permit holder shall comply with all applicable requirements, including those specified in the BAAQMD and SIP Rules and Regulations and other federal requirements cited below. The requirements cited in the following tables apply in a specific manner to the indicated source(s).

The dates in parentheses in the Title column identify the versions of the regulations being cited and are, as applicable:

- 1. BAAQMD regulation(s): The date(s) of adoption or most recent amendment of the regulation by the District Board of Directors.
- 2. Any federal requirement, including a version of a District regulation that has been approved into the SIP: The most recent date of EPA approval of any portion of the rule, encompassing all actions on the rule through that date

The full text of each permit condition cited is included in Section VI, Permit Conditions, of this permit. The full language of SIP requirements is on EPA Region 9's website.

The address is:

 $\frac{http://yosemite.epa.gov/r9/r9sips.nsf/Agency?ReadForm\&count=500\&state=California\&cat=Bay+Area+Air+Quality+Management+District-Agency-Wide+Provisions}$

All other text may be found in the regulations themselves.

Table IV - A Source-specific Applicable Requirements S1, S2 – GAS TURBINES W/WATER INJECTION S3, S4: DUCT BURNERS

Applicable Requirement	Regulation Title or Description of Requirement	Federally Enforceable (Y/N)	Future Effective Date
BAAQMD			
Regulation 1	General Provisions and Definitions (5/2/01)		
1-107	Combination of Emissions	Y	
1-523	Parametric Monitoring and Recordkeeping Procedures	N	
1-523.1	Reporting requirement for periods of inoperation > 24 hours	Y	
1-523.2	Limit on duration of inoperation	Y	
1-523.3	Reporting requirement for violations of any applicable limits	N	
1-523.4	Records of inoperation, tests, calibrations, adjustments, & maintenance	Y	
1-523.5	Maintenance and calibration	N	
SIP	General Provisions and Definitions (6/28/99)		
Regulation 1			
1-523	Parametric Monitoring and Recordkeeping Procedures	Y^1	

11

IV. Source-Specific Applicable Requirements

Table IV - A Source-specific Applicable Requirements S1, S2 – GAS TURBINES W/WATER INJECTION S3, S4: DUCT BURNERS

		Federally	Future
Applicable	Regulation Title or	Enforceable	Effective
Requirement	Description of Requirement	(Y/N)	Date
1-523.3	Reports of Violations	\mathbf{Y}^{1}	
BAAQMD	Particulate Matter, General Requirements Particulate Matter and		
Regulation 6	Visible Emissions (12/19/9012/5/07)		
6- <u>1-</u> 301	Ringelmann #1 Limitation	<u>¥N</u>	
6- <u>1-</u> 305	Visible Particles	<u>¥N</u>	
6- <u>1-</u> 310	Particulate Weight Limitation	<u>¥N</u>	
6- <u>1-</u> 310.3	Heat Transfer Operations	<u>¥N</u>	
SIP	Particulate Matter and Visible Emissions (9/4/98)		
Regulation 6			
<u>6-301</u>	Ringelmann #1 Limitation	<u>Y</u>	
<u>6-305</u>	<u>Visible Particles</u>	<u>Y</u>	
<u>6-310</u>	Particulate Weight Limitation	<u>Y</u>	
<u>6-310.3</u>	Heat Transfer Operations	<u>Y</u>	
BAAQMD	Inorganic Gaseous Pollutants – Sulfur Dioxide (3/15/95)		
Regulation 9,			
Rule 1			
9-1-301	Limitations on Ground Level Concentrations	N	
9-1-302	General Emissions Limitation	Y	
BAAQMD	Inorganic Gaseous Pollutants - Nitrogen Oxides from Stationary Gas		
Regulation 9,	Turbines (9/21/94 <u>12/6/06</u>)		
Rule 9			
9-9-113	Exemption – Inspection and Maintenance Periods	<u>¥N</u>	
9-9-114	Exemption – Start-up and Shutdown Periods	<u>¥N</u>	
<u>9-9-115</u>	Limited Exemption, Minor Inspection and Maintenance Work	<u>N</u>	
9-9-301	General Emission Limits	<u>¥N</u>	
9-9-301.1 <u>.1</u>	Gas Turbines ≥ 0.3 MW and <10.0 MW	<u>¥N</u>	
9-9-301.2	NOx limits	<u>N</u>	
9-9-301.4	Alternative standards	<u>N</u>	

IV. Source-Specific Applicable Requirements

Table IV - A Source-specific Applicable Requirements S1, S2 – GAS TURBINES W/WATER INJECTION S3, S4: DUCT BURNERS

Applicable Requirement	Regulation Title or Description of Requirement	Federally Enforceable (Y/N)	Future Effective Date
9-9-404	Compliance Schedule for Future Commercial Availability of Retrofit	<u>N</u>	Upon APCO
	Technology	_	notification,
			<u>up to 60</u>
			months after
			availability
			<u>of</u>
			comercially
			<u>available</u>
			<u>technology</u>
9-9-504	Annual Demonstration of Compliance	<u>N</u>	
<u>9-9-601</u>	<u>Determination of Emissions</u>	<u>N</u>	
<u>9-9-602</u>	Determination of Stack Gas Oxygen	<u>N</u>	
SIP	<u>Inorganic Gaseous Pollutants – Nitrogen Oxides from Stationary Gas</u>		
Regulation 9,	<u>Turbines (12/15/97)</u>		
Rule 9			
9-9-113	Exemption – Inspection and Maintenance Periods	<u>Y</u>	
<u>9-9-114</u>	Exemption – Start-up and Shutdown Periods	<u>Y</u>	
<u>9-9-301</u>	General Emission Limits	<u>Y</u>	
<u>9-9-301.1</u>	Gas Turbines > 0.3 MW and <10.0 MW	<u>Y</u>	
40 CFR Part 60	Standards of Performance for New Stationary Sources (12/23/71)		
Subpart A	General Provisions		
Subpart A	Notification and Recordkeeping	Y	
60.7			
60.8	Performance Tests	Y	
60.9	Availability of Information	Y	
60.11	Compliance with Standards and Maintenance Requirements	Y	
60.12	Circumvention	Y	
60.13	Monitoring Requirements	Y	
60.13(a)	Continuous monitoring systems	Y	
60.13(b)	Installation deadline	Y	
60.13(e)	Continuous operation	Y	

IV. Source-Specific Applicable Requirements

Table IV - A Source-specific Applicable Requirements S1, S2 – GAS TURBINES W/WATER INJECTION S3, S4: DUCT BURNERS

		Federally	Future
Applicable	Regulation Title or	Enforceable	Effective
Requirement	Description of Requirement	(Y/N)	Date
60.13(f)	Representative measurements	Y	
40 CFR 60	Standards of Performance for Stationary Gas Turbines		
Subpart GG	(7/8/0 4 <u>2/24/06</u>)		
60.332	Standard for Nitrogen Oxides	Y	
60.332(a)(2)	NOx Emission Standard – Turbines > 10 MMBTU/hr and <100	Y	
	MMBTU/hr		
60.333	Standard for Sulfur Dioxide	Y	
60.333(a)	Sulfur Dioxide Emission Standard	Y	
60.333(b)	Fuel Sulfur Limit	Y	
60.334	Monitoring Requirements	Y	
60.334(a)	Fuel/Water Ratio	Y	
60.334(g)	Parameter Monitoring During Performance Testing	Y	
60.334(h)(3)	Fire Only Natural Gas in lieu of Fuel Sulfur Monitoring	Y	
60.334(j)	Excess Emissions Reports	Y	
60.334	Requirements for Turbines Using Water or Steam to Fuel Ratio	Y	
(j)(1)(i)	Monitoring		
60.334(j)(5)	Report Due Dates	Y	
BAAQMD			
Cond #14194			
part 1	Fuel Requirement (basis: BACT, 40 CFR 60.333)	Y	
part 2	Heat Input Limit – Turbines (basis: Cumulative Increase)	Y	
part 3	Heat Input Limit – Duct Burners (basis: Cumulative Increase)	Y	
part 4	NOx Emissions Limit – Turbines (Basis: BAAQMD Regulations 9-9-	Y	
	301.1.1, 9-9-301.2, SIP Regulation 9-9-301.1)		
part 5	NOx Emissions Limit – Combined Turbine/Duct Burner (Basis:	Y	
	BAAQMD Regulations 1-107, 9-9-301.1.1, 9-9-301.2, SIP Regulation 9-		
	9-301.1)		
part 6	Water Injection System Requirements (Basis: BACT)	Y	
part 7	Fuel Monitoring Requirement (basis: Cumulative Increase)	Y	
part 8	Continuous Monitoring System Requirement (basis: 40 CFR 60.334)	Y	
part 9	Annual Source Test Requirement for Turbines (basis: BAAQMD	Y	
	Regulations 9-9-301.1.1, 9-9-301.2; SIP Regulation 9-9-301.1)		

IV. Source-Specific Applicable Requirements

Table IV - A Source-specific Applicable Requirements S1, S2 – GAS TURBINES W/WATER INJECTION S3, S4: DUCT BURNERS

		Federally	Future
Applicable	Regulation Title or	Enforceable	Effective
Requirement	Description of Requirement	(Y/N)	Date
<u>Part 10</u>	Annual Source Test Requirement for Turbines/Duct Burnes (basis:	<u>Y</u>	
	BAAQMD Regulations 9-9-301.1.1, 9-9-301.2; SIP Regulation 9-9-		
	<u>301.1)</u>		
part 10	Recordkeeping. (Basis: BAAQMD Regulations 1-107, 2-6-503, 9-9-	Y	
	<u>301.1.1, SIP 9-9-301.1)</u>		
part 11	Reporting (basis: Cumulative Increase, 40 CFR 60.334)	Y	

This section has been removed from BAAQMD Regulations because it has been superseded. Nevertheless, the source must comply with this regulation until US EPA has reviewed and approved (or disapproved) the District's revision of the regulation.

Renewal Date: _____

15

V. SCHEDULE OF COMPLIANCE

The permit holder shall comply with all applicable requirements cited in this permit. The permit holder shall also comply with applicable requirements that become effective during the term of this permit on a timely basis.

VI. PERMIT CONDITIONS

Any condition that is preceded by an asterisk is not federally enforceable.

Condition #14194 for:

- S1, Gas Turbine with water injection
- S2, Gas Turbine with water injection
- S3, Supplemental Duct Burner
- S4, Supplemental Duct Burner

Conditions:

- 1. All combustion sources at this facility shall be fired exclusively with California Public Utilities Commission (PUC) quality natural gas. (basis: BACT, 40 CFR 60.333)
- 2. Heat input for each turbine, S1 and S2, is limited to 55.1 MMBTU/hr. (Basis: Cumulative Increase)
- 3. Heat input for each supplemental duct burner, S3 and S4, is limited to 13.5 MMBTU/hr. (Basis: Cumulative Increase)
- 4. NOx emissions from each turbine, S1 or S2, shall not exceed 42 ppm, by volume in the exhaust, measured at 15% oxygen (dry basis), except during startup and shutdown. (Basis: <u>BAAQMD</u> Regulations 9-9-301.1.)
- 5. NOx emissions from each turbine-supplemental duct burner combination, S1/S3 or S2/S4, shall not exceed 42 ppm by volume in the exhaust, measured at 15% oxygen (dry basis). The supplemental burners shall not operate during startup or shutdown. (Basis: <u>BAAQMD</u> Regulations 1-107, 9-9-301.1.1, 9-9-301.2, SIP Regulation 9-9-301.1)
- 6. NOx emissions from each turbine shall be controlled at all times by water injection except during startup and shutdown. Water-to-fuel ratio shall be maintained in the range of 57% to 62% (weight basis) during all periods of operation. (Basis: BACT)

Renewal Date:

VI. Permit Conditions

7. In order to demonstrate compliance with parts #2 and #3, the owner/operator of the Gas Turbines and Supplemental Duct Burners shall install and operate approved continuous fuel meters to monitor and record the amount of fuel heat input to each turbine and duct burner. (basis: Cumulative Increase)

- 8. In order to demonstrate compliance with part #6, the owner/operator of the Gas Turbines shall install and operate an approved continuous monitoring system to monitor and record the ratio of water-to-fuel being fired in each turbine. (basis: 40 CFR 60.334)
- 9. In order to demonstrate compliance with NOx limits of parts #4 and #5, the owner/operator of the Gas Turbines S1 and S2 and the Supplemental Duct Burners S3 and S4 shall conduct annual source testing of each turbine (S1, S2) and each turbine supplemental duct burner combination (S1/S3, S2/S4). (basis: BAAQMD Regulations 9-9-301.1.1, 9-9-301.2; SIP Regulation 9-9-301.1)

All source testing shall be performed in accordance with the District's Manual of Procedures. The facility shall obtain prior approval from the District's Source Test Manager for the location of sampling ports and source testing procedures. All source test results shall be delivered to the District within 30 days of the date of the test. The time interval between source testing shall not exceed 15 months.

Note: The revision to part 9 is not applicable until the Major Facility Review permit is issued pursuant to Application 23709. [This note will be deleted upon issuance.]

10. In order to demonstrate compliance with NOx limits of Part #5, the owner/operator of the Gas Turbines, S1 and S2, and duct burners S3 and S4 shall conduct annual source testing of each turbine-supplemental duct burners combination (S1/S3, S3/S4). This requirement shall be waived if the duct burners have not been fired since the last source test. (Basis: BAAQMD Regulations 1-107, 2-6-503, 9-9-301.1.1, SIP Regulation 9-9-301.1)

All source testing shall be performed in accordance with the District's Manual of Procedures. The facility shall obtain prior approval from the District's Source Test Manager for the location of sampling ports and source testing procedures. All source test results shall be delivered to the District within 30 days of the date of the test. The time interval between source testing shall not exceed 15 months.

Renewal Date:

VI. Permit Conditions

Note: Part 10 is not applicable until the Major Facility Review permit is issued pursuant to Application 23709. [This note will be deleted upon issuance.]

- 101. The owner/operator of the Gas Turbines S1 and S2 and the Supplemental Duct Burners S3 and S4 shall keep records of the operation of this equipment as follows: (basis: Cumulative Increase, 40 CFR 60.334)
 - a. hours of operation of each turbine and supplemental burner
 - b. monthly summary of fuel usage at each turbine and supplemental burner
 - c. average fuel to water ratio at each turbine for each 24 hour period that the turbines are in operation
- 142. The owner/operator of the Gas Turbines S1 and S2 shall submit an excess emissions and monitoring systems performance report to the District and the U.S. Environmental Protection Agency on a semiannual basis. These reports shall be submitted as stipulated in Standard Condition I.F and shall include the following: (basis: 40 CFR 60.7(c))
 - a. the hours of operation of each turbine during the reporting period
 - b. each one-hour period during which the average water-to-fuel ratio falls out of the range specified in part #6
 - c. the date and time identifying each period during which the continuous monitoring system was inoperative and the nature of the system repairs or adjustments
 - d. the average fuel consumption and turbine load conditions for each period when the water-to-fuel ratio was out of the specified range or the continuous monitoring system was inoperative

Respective reports to the District and the EPA shall be addressed as follows:

Director of Compliance and Enforcement Bay Area Air Quality Management District 939 Ellis Street San Francisco, CA 94109 Attn: Title V Reports

Director of the Air Division USEPA, Region IX 75 Hawthorne Street San Francisco, CA 94105

Attn: Air-3

Renewal Date:	
---------------	--

VII. APPLICABLE LIMITS & COMPLIANCE MONITORING REQUIREMENTS

This section has been included only to summarize the applicable emission limits contained in Section IV, Source-Specific Applicable Requirements, of this permit. The following tables show the relationship between each emission limit and the associated compliance monitoring provisions, if any. The monitoring frequency indicates whether periodic (P) or continuous (C) monitoring is required. For periodic monitoring, the frequency of the monitoring has also been shown, using the following codes: annual (A), quarterly (Q), monthly (M), weekly (W), daily (D), or on an event basis (E). No monitoring (N) has been required if the current applicable rule or regulation does not require monitoring, and the operation is unlikely to deviate from the applicable emission limit based upon the nature of the operation.

This section is only a summary of the limits and monitoring requirements. In the case of a conflict with any requirement in Sections I-VI, the preceding sections take precedence over Section VII.

Table VII – A
Applicable Limits and Compliance Monitoring Requirements
S1, S2 – GAS TURBINES W/WATER INJECTION
S3, S4: DUCT BURNERS

	Emission		Future		Monitoring	Monitoring	
Type of	Limit	FE	Effective		Requirement	Frequency	Monitoring
limit	Citation	Y/N	Date	Emission Limit	Citation	(P/C/N)	Type
PM	BAAQMD	<u>¥N</u>		Ringelmann 1.0		N	
	Regulation						
	6- <u>1-</u> 301						
<u>PM</u>	SIP	<u>Y</u>		Ringelmann 1.0		<u>N</u>	
	Regulation						
	<u>6-301</u>						
FP	BAAQMD	<u>¥N</u>		0.15 gr/dscf @ 6% O2		N	
	Regulation						
	6- <u>1-</u> 310.3						
<u>FP</u>	SIP	<u>N</u>		0.15 gr/dscf @ 6% O2		<u>N</u>	
	Regulation						
	6-1-310.3						
NOx	BAAQMD	<u>¥N</u>		42 ppmv	Condition	P/A	Source test
	9-9-301.1 <u>.1</u>			@_15% O ₂ (dry)	#14194,		
					parts 9 and 10,		
					BAAQMD		
					<u>9-9-504</u>		

19

VII. Applicable Limits and Compliance Monitoring Requirements

Table VII – A Applicable Limits and Compliance Monitoring Requirements S1, S2 – GAS TURBINES W/WATER INJECTION S3, S4: DUCT BURNERS

Type of	Emission Limit Citation	FE Y/N	Future Effective Date	Emission Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type
NOx	BAAQMD 9-9-301.1.1	<u>N</u>	Date	42 ppmv @ 15% O ₂ (dry)	Condition #14194,	<u>C</u>	Water-to-fuel monitoring
	<u> </u>			<u></u>	part 8		<u></u>
<u>NOx</u>	BAAQMD	<u>N</u>		42 ppmv	Condition	<u>P/A</u>	Source test
	9-9-301.2			<u>@ 15% O₂ (dry)</u>	#14194, parts 9 and 10,		
					BAAQMD		
					<u>9-9-504</u>		
<u>NOx</u>	BAAQMD	<u>N</u>		<u>42 ppmv</u>	<u>Condition</u>	<u>C</u>	Water-to-fuel
	9-9-301.2			<u>@ 15% O₂ (dry)</u>	#14194 <u>,</u>		monitoring
NOx	BAAQMD	<u>N</u>	Up to 60	35 ppmv	<u>part 8</u> <u>Condition</u>	P/A	Source test
11011	9-9-301.2		months	@15% O ₂ (dry)	#14194 <u>,</u>	2712	<u> </u>
			<u>after</u>		parts 9 and 10,		
			<u>availa-</u>		<u>BAAQMD</u>		
			bility of		<u>9-9-504</u>		
			comer-				
			<u>cially</u>				
			available techno-				
			logy				
NOx	BAAQMD	<u>N</u>	<u>Up to 60</u>	<u>35 ppmv</u>	Condition	<u>C</u>	Water-to-fuel
	9-9-301.2		months	<u>@15% O₂ (dry)</u>	<u>#14194,</u>		monitoring
			<u>after</u>		part 8		
			<u>availa-</u>				
			bility of				
			comer-				
			<u>cially</u> available				
			techno-				
			logy				

VII. Applicable Limits and Compliance Monitoring Requirements

Table VII – A Applicable Limits and Compliance Monitoring Requirements S1, S2 – GAS TURBINES W/WATER INJECTION S3, S4: DUCT BURNERS

	Emission		Future		Monitoring	Monitoring	
Type of	Limit	FE	Effective		Requirement	Frequency	Monitoring
limit	Citation	Y/N	Date	Emission Limit	Citation	(P/C/N)	Туре
<u>NOx</u>	SIP	<u>Y</u>		<u>42 ppmv</u>	<u>Condition</u>	<u>P/A</u>	Source test
	<u>9-9-301.1.1</u>			<u>@15% O₂ (dry)</u>	<u>#14194,</u>		
					parts 9 and 10		
<u>NOx</u>	<u>SIP</u>	<u>Y</u>		<u>42 ppmv</u>	<u>Condition</u>	<u>C</u>	Water-to-fuel
	<u>9-9-301.1.1</u>			<u>@15% O₂ (dry)</u>	<u>#14194,</u>		monitoring
					part 8		
	NSPS	Y		150 ppmv	NSPS	С	Water-to-fuel
	Subpart			@15% O ₂ (dry)	Subpart GG		ratio
	GG				60.334(a)		monitoring
	60.332						
	(a)(2)						
NOx	Condition	Y		42 ppmv	Condition	P/A	Source test
	#14194,			@_15% O ₂ (dry), each	#14194,		
	part 4			turbine	part <u>s</u> 9 and 10		
				(except during startup			
				and shutdown)			
<u>NOx</u>	Condition	<u>Y</u>		<u>42 ppmv</u>	<u>Condition</u>	<u>C</u>	Water-to-fuel
	<u>#14194,</u>			<u>@ 15% O₂ (dry), each</u>	<u>#14194,</u>		monitoring
	part 4			<u>turbine</u>	<u>part 8</u>		
				(except during startup			
				and shutdown)			
NOX	Condition	Y		42 ppmv	Condition	P/A	Source test
	#14194,			@_15% O ₂ (dry), each	#14194,		
	part 5			turbine/supplemental	parts 9 and 10		
				burner combination			

Renewal Date: _____

21

VII. Applicable Limits and Compliance Monitoring Requirements

Table VII – A Applicable Limits and Compliance Monitoring Requirements S1, S2 – GAS TURBINES W/WATER INJECTION S3, S4: DUCT BURNERS

TD 6	Emission	EE	Future		Monitoring	Monitoring	36 4
Type of limit	Limit Citation	FE Y/N	Effective Date	Emission Limit	Requirement Citation	Frequency	Monitoring
			Date		Citation	(P/C/N)	Туре
SO2	BAAQMD	Y		Ground level		N	
	9-1-301			concentrations:			
				0.5 ppm for 3			
				consecutive minutes,			
				0.25 ppm averaged			
				over 60 consecutive			
				minutes, 0.05 ppm			
				averaged over 24			
				hours			
	BAAQMD	Y		300 ppm (dry)		N	
	9-1-302			general emission			
				limitation			
	40 CFR 60	Y		0.8% (wt)	40 CFR 60	P/ENone	Specification
	Subpart			fuel sulfur content	Subpart GG		from Natural
	GG				60.334 (h)(3)		Gas
	60.333 (b)						Supplier None
Fuel	BAAQMD	Y		55.1 MMBTU/hr	BAAQMD	С	Continuous
Usage	Condition			heat input	Condition		Fuel Usage
	#14194			(each turbine)	#14194		Monitors
	part 2				part 7		
	BAAQMD	Y		13.5 MMBTU/hr	BAAQMD	С	Continuous
	Condition			heat input	Condition		Fuel Usage
	#14194			(each duct burner)	#14194		Monitors
	part 3				part 7		
Water-to-	BAAQMD	Y		Water-to-Fuel Ratio:	BAAQMD	С	Continuous
Fuel	Condition			57% to 62% (wt)	Condition		Water-to-Fuel
Ratio	#14194				#14194		Ratio
	part 6				part 7		Monitoring

VII. Applicable Limits and Compliance Monitoring Requirements

Table VII – A Applicable Limits and Compliance Monitoring Requirements S1, S2 – GAS TURBINES W/WATER INJECTION S3, S4: DUCT BURNERS

	Emission		Future		Monitoring	Monitoring	
Type of	Limit	FE	Effective		Requirement	Frequency	Monitoring
limit	Citation	Y/N	Date	Emission Limit	Citation	(P/C/N)	Type
Periods of	BAAQMD	Y		15 consecutive	BAAQMD	P/D	Operating
Inopera-	1-523.2			days/incident and	1-523.4		Records for All
tion for				30 calendar days/12			Parametric
Para-				month period			Monitors
metric							
Monitors							

VIII. TEST METHODS

The test methods associated with the emission limit of a District regulation are generally referenced in Section 600 et seq. of the regulation. The following table indicates only the test methods associated with the emission limits referenced in Section VII, Applicable Emission Limits & Compliance Monitoring Requirements, of this permit.

Table VIII Test Methods

Applicable		
Requirement	Description of Requirement	Acceptable Test Methods
BAAQMD	Ringelmann No. 1 Limitation	Manual of Procedures, Volume I, Evaluation of Visible Emissions
6-301		
SIP	Ringelmann No. 1 Limitation	Manual of Procedures, Volume I, Evaluation of Visible Emissions
<u>6-301</u>		
BAAQMD	Particulate Weight Limitation	Manual of Procedures, Volume IV, ST-15, Particulates Sampling;
6-310		or
		USEPA Method 5, Determination of Particulate Matter Emissions
		from Stationary Sources
BAAQMD	Particulate Weight Limitation at	Manual of Procedures, Volume IV, ST-15, Particulates Sampling:
<u>6-310.3</u>	<u>6% O2</u>	<u>or</u>
		USEPA Method 5, Determination of Particulate Matter Emissions
		<u>from Stationary Sources</u>
SIP	Particulate Weight Limitation at	Manual of Procedures, Volume IV, ST-15, Particulates Sampling;
<u>6-310.3</u>	<u>6% O2</u>	<u>or</u>
		USEPA Method 5, Determination of Particulate Matter Emissions
		from Stationary Sources
BAAQMD	General Emission Limitation	Manual of Procedures, Volume IV, ST-19A, Sulfur Dioxide,
9-1-302		Continuous Sampling
BAAQMD	Emission Limit, NOx, Turbines	Manual of Procedures, Volume IV, ST-13A, Oxides of Nitrogen,
9-9-301.1	Rated <u>></u> 0.3 MW to <10 MW	Continuous Sampling and ST-14, Oxygen, Continuous Sampling
BAAQMD	Emission Limit, NOx,	Manual of Procedures, Volume IV, ST-13A, Oxides of Nitrogen,
Cond. #14194,	Gas Turbines, Gas Turbines	Continuous Sampling and ST-14, Oxygen, Continuous Sampling
part 4, part 5	w/Duct Burners	

VIII. Test Methods

Table VIII Test Methods

Applicable		
Requirement	Description of Requirement	Acceptable Test Methods
40 CFR 60	Performance Standard, NOx	EPA Method 20, Determination of Nitrogen Oxides, Sulfur
Subpart GG		Dioxide, and Diluent Emissions from Stationary Gas Turbines, or
60.332(a)(2)		ASTM D6522-00, Test Method for Determination of Nitrogen
		Oxides, Carbon Monoxide, and Oxygen Concentrations in
		Emissions from Natural Gas-Fired Reciprocating Engines,
		Combustion Turbines, Boilers, and Process Heaters Using
		Portable Analyzers, or
		EPA Method 7E, Determination of Nitrogen Oxides Emissions
		from Stationary Sources (Instrumental Analyzer Procedure)
40 CFR 60	SO2 Volumetric Emission Limit	EPA Method 20, Determination of Nitrogen Oxides, Sulfur
Subpart GG		Dioxide, and Diluent Emissions from Stationary Gas Turbines
60.333(a)		
40 CFR 60	Fuel Sulfur Limit (gaseous fuel)	ASTM D 1072-80, Standard Method for Total Sulfur in Fuel
Subpart GG		Gases; and/or
60.333(b)		ASTM D 3031-81, Standard Test Method for Total Sulfur in
		Natural Gas by Hydrogenation

IX. PERMIT SHIELD

A. Non-applicable Requirements None.

B. Subsumed Requirements

None.

X. REVISION HISTORY

Final Title V Permit (Application 18321): March 22, 2000 Administrative Amendment (no application): September 17, 2002 Changes to Condition #14194, part 11, to conform to Standard Condition I.F Change of facility name from "City of Santa Clara" to "Silicon Valley Power" Administrative Amendment (no application): October 17, 2002 Change of facility name from "Silicon Valley Power" to "City of Santa Clara, Electric Department" Change telephone number for William J. Reichmann (facility contact) Title V Renewal (Application #10664): August 30, 2005 Title V Renewal (Application #21654): Insert Renewal date

XI. GLOSSARY

ACT

Federal Clean Air Act

APCO

Air Pollution Control Officer

API

American Petroleum Institute

ARB

Air Resources Board

BAAQMD

Bay Area Air Quality Management District

RACT

Best Available Control Technology

BARCT

Best Available Retrofit Control Technology

C5

An Organic chemical compound with five carbon atoms

C

An Organic chemical compound with six carbon atoms

CAA

The federal Clean Air Act

CAAOS

California Ambient Air Quality Standards

CAPCOA

California Air Pollution Control Officers Association

CEC

California Energy Commission

CEOA

California Environmental Quality Act

CEM

A "continuous emission monitor" is a monitoring device that provides a continuous direct measurement of some pollutant (e.g. NOx concentration) in an exhaust stream.

CFR

The Code of Federal Regulations. 40 CFR contains the implementing regulations for federal environmental statutes such as the Clean Air Act. Parts 50-99 of 40 CFR contain the requirements for air pollution programs.

CO

Carbon Monoxide

CO₂

Carbon Dioxide

XI. Glossary

Cumulative Increase

The sum of permitted emissions from each new or modified source since a specified date. Used to determine whether threshold-based requirements are triggered.

District

The Bay Area Air Quality Management District

dscf

Dry Standard Cubic Feet

dscm

Dry Standard Cubic Meter

E 6, E 9, E 12

Very large or very small number values are commonly expressed in a form called scientific notation, which consists of a decimal part multiplied by 10 raised to some power. For example, $4.53 ext{ E 6 equals } (4.53) ext{ x } (10^6) = (4.53) ext{ x } (10 ext{ x } 10 ext{ multiplied by 10 raised to some power.}$ Scientific notation is used to express large or small numbers without writing out long strings of zeros.

EGT

Exhaust Gas Temperature

EPA

The federal Environmental Protection Agency.

Excluded

Not subject to any District Regulations.

FE, Federally Enforceable

All limitations and conditions which are enforceable by the Administrator of the EPA including those requirements developed pursuant to 40 CFR Part 51, subpart I (NSR), Part 52.21 (PSD), Part 60, (NSPS), Part 61, (NESHAPS), Part 63 (HAP), and Part 72 (Permits Regulation, Acid Rain), and also including limitations and conditions contained in operating permits issued under an EPA-approved program that has been incorporated into the SIP.

FP

Filterable Particulate as measured by BAAQMD Method ST-15, Particulate.

FR

Federal Register

GLC

Ground level concentration.

GLM

Ground Level Monitor

grains

1/7000 of a pound

HAP

Hazardous Air Pollutant. Any pollutant listed pursuant to Section 112(b) of the Act. Also refers to the program mandated by Title I, Section 112, of the Act and implemented by both 40 CFR Part 63, and District Regulation 2, Rule 5.

H2S

Hydrogen Sulfide

Renewal Date:	
---------------	--

XI. Glossary

HHV

Higher Heating Value. The quantity of heat evolved as determined by a calorimeter where the combustion products are cooled to 60F and all water vapor is condensed to liquid.

LHV

Lower Heating Value. Similar to the higher heating value (see HHV) except that the water produced by the combustion is not condensed but retained as vapor at 60F.

Major Facility

A facility with potential emissions of regulated air pollutants greater than or equal to 100 tons per year, greater than or equal to 10 tons per year of any single hazardous air pollutant, and/or greater than or equal to 25 tons per year of any combination of hazardous air pollutants, or such lesser quantity as determined by the EPA administrator.

MFR

Major Facility Review. The District's term for the federal operating permit program mandated by Title V of the Act and implemented by District Regulation 2, Rule 6.

MOP

The District's Manual of Procedures.

MSDS

Material Safety Data Sheet

MW

Megawatts

NA

Not Applicable

NAAQS

National Ambient Air Quality Standards

NESHAPS

National Emission Standards for Hazardous Air Pollutants. Contained in 40 CFR Part 61.

NMHC

Non-methane Hydrocarbons

NMOO

Non-methane Organic Compounds (Same as NMHC)

NOx

Oxides of nitrogen.

NSPS

Standards of Performance for New Stationary Sources. Federal standards for emissions from new stationary sources. Mandated by Title I, Section 111 of the Act, and implemented by both 40 CFR Part 60 and District Regulation 10.

NSR

New Source Review. A federal program for pre-construction review and permitting of new and modified sources of air pollutants for which the District is classified "non-attainment". Mandated by Title I of the Clean Air Act and implemented by 40 CFR Parts 51 and 52 as well as District Regulation 2, Rule 2. (Note: There are additional NSR requirements mandated by the California Clean Air Act.)

Renewal Date:

XI. Glossary

02

The chemical name for oxygen gas.

Offset Requirement

A New Source Review requirement to provide federally enforceable emission offsets at a specified ratio for the emissions from a new or modified source and any pre-existing cumulative increase minus any onsite contemporaneous emission reduction credits. Applies to emissions of POC, NOx, PM10, and SO2.

Phase II Acid Rain Facility

A facility that generates electricity for sale through fossil-fuel combustion and by virtue of certain other characteristics (defined in Regulation 2, Rule 6) is subject to Titles IV and V of the Clean Air Act.

POC

Precursor Organic Compounds

PM

Total Particulate Matter

PM10

Particulate matter with aerodynamic equivalent diameter of less than or equal to 10 microns

PCD

Prevention of Significant Deterioration. A federal program for permitting new and modified sources of air pollutants for which the District is classified "attainment" of the National Air Ambient Quality Standards. Mandated by Title I of the Act and implemented by both 40 CFR Part 52 and District Regulation 2, Rule 2.

SCR

A "selective catalytic reduction" unit is an abatement device that reduces NOx concentrations in the exhaust stream of a combustion device. SCRs utilize a catalyst, which operates at a specific temperature range, and injected ammonia to promote the conversion of NOx compounds to nitrogen gas.

SIP

State Implementation Plan. State and District programs and regulations approved by EPA and developed in order to attain the National Air Ambient Quality Standards. Mandated by Title I of the Act.

SO₂

Sulfur dioxide

SO₃

Sulfur trioxide

THO

Total Hydrocarbons (NMHC + Methane)

therm

100,000 British Thermal Unit

Title V

Title V of the federal Clean Air Act. Requires a federally enforceable operating permit program for major and certain other facilities.

TOC

Total Organic Compounds (NMOC + Methane, Same as THC)

TRMP

Toxic Risk Management Plan

XI. Glossary

TSP

Total Suspended Particulate

TVP

True Vapor Pressure

VOC

Volatile Organic Compounds

Units of Measure:

oi ivieasur	e:	
bhp	=	brake-horsepower
Btu	=	British Thermal Unit
g	=	grams
gal	=	gallon
hp	=	horsepower
hr	=	hour
lb	=	pound
in	=	inches
max	=	maximum
m^2	=	square meter
min	=	minute
MM	=	million
ppmv	=	parts per million, by volume
ppmw	=	parts per million, by weight
psia	=	pounds per square inch, absolute
psig	=	pounds per square inch, gauge
scfm	=	standard cubic feet per minute
yr	=	year

Symbols:

<	=	less than
>	=	greater than
<u><</u>	=	less than or equal to
<u>></u>	=	greater than or equal to