

# Bay Area Air Quality Management District

375 Beale Street, Suite 600  
San Francisco, CA 94105  
(415) 771-6000

---

---

**Final**

## MAJOR FACILITY REVIEW PERMIT

Issued to:

**Graphic Packaging International, Inc.**

**Facility #A0732**

**Facility Address:**

2600 De La Cruz Blvd  
Santa Clara, CA 95050-2663

**Mailing Address:**

2600 De La Cruz Blvd  
Santa Clara, CA 95050-2663

**Responsible Official**

Jeff Mih, General Manager  
(408) 496-5118

**Facility Contact**

Rick Horne, Environmental Manager  
(408) 496-5080

---

---

<b>Type of Facility:</b>	Recycled Paperboard Mill and Cogeneration Plant	<b>BAAQMD Engineering Division Contact:</b> Carol Lee
<b>Primary SIC:</b>	2631	
<b>Product:</b>	Recycled Paperboard & Electricity	

**ISSUED BY THE BAY AREA AIR QUALITY MANAGEMENT DISTRICT**

Signed by Jack P. Broadbent  
Jack Broadbent, Executive Officer/Air Pollution Control Officer

February 6, 2017  
Date

## TABLE OF CONTENTS

I.	STANDARD CONDITIONS .....	3
II.	EQUIPMENT LIST .....	7
III.	GENERALLY APPLICABLE REQUIREMENTS .....	9
IV.	SOURCE-SPECIFIC APPLICABLE REQUIREMENTS .....	12
V.	SCHEDULE OF COMPLIANCE .....	27
VI.	PERMIT CONDITIONS .....	27
VII.	APPLICABLE LIMITS & COMPLIANCE MONITORING REQUIREMENTS .....	33
VIII.	TEST METHODS .....	44
IX.	PERMIT SHIELD .....	47
X.	REVISION HISTORY .....	49
XI.	GLOSSARY .....	50

## I. STANDARD CONDITIONS

### A. Administrative Requirements

The permit holder shall comply with all applicable requirements in the following regulations:

BAAQMD Regulation 1 - General Provisions and Definitions  
(as amended by the District Board on 5/4/11);

SIP Regulation 1 - General Provisions and Definitions  
(as approved by EPA through 6/28/99);

BAAQMD Regulation 2, Rule 1 - Permits, General Requirements  
(as amended by the District Board on 12/19/12, effective  
8/31/16);

BAAQMD Regulation 2, Rule 2 - Permits, New Source Review  
(as amended by the District Board on 12/19/12, effective  
8/31/16);

BAAQMD Regulation 2, Rule 4 - Permits, Emissions Banking  
(as amended by the District Board on 12/19/12);

SIP Regulation 2, Rule 4 - Permits, Emissions Banking  
(as approved by EPA through 1/26/99);

BAAQMD Regulation 2, Rule 5 – New Source Review of Toxic Air Contaminants  
(as amended by the District Board on 12/07/16);

BAAQMD Regulation 2, Rule 6 - Permits, Major Facility Review  
(as amended by the District Board on 4/16/03); and

SIP Regulation 2, Rule 6 – Permits, Major Facility Review  
(as approved by EPA through 6/23/95).

### B. Conditions to Implement Regulation 2, Rule 6, Major Facility Review

1. This Major Facility Review Permit was issued on February 6, 2017 and expires on February 5, 2022. The permit holder shall submit a complete application for renewal of this Major Facility Review Permit no later than August 5, 2021 and no earlier than February 5, 2022. **If a complete application for renewal has not been submitted in accordance with these deadlines, the facility may not operate after February 5, 2022.** If the permit renewal has not been issued by February 5, 2022, but a complete application for renewal has been submitted in accordance with the above deadlines, the existing permit will continue in force until the District takes final action on the renewal application. (Regulation 2-6-307, 404.2, 407, & 409.6; MOP Volume II, Part 3, §4.2)
2. The permit holder shall comply with all conditions of this permit. The permit consists of this document and all appendices. Any non-compliance with the terms and conditions of this permit will constitute a violation of the law and may be grounds for enforcement action; permit termination, revocation and reissuance, or modification; or denial of a permit renewal application. (Regulation 2-6-307; MOP Volume II, Part 3, §4.11)

## I. Standard Conditions

3. In the event any enforcement action is brought as a result of a violation of any term or condition of this permit, the fact that it would have been necessary for the permittee to halt or reduce the permitted activity in order to maintain compliance with such term or condition shall not be a defense to such enforcement action. (MOP Volume II, Part 3, §4.11)
4. This permit may be modified, revoked, reopened and reissued, or terminated for cause. (Regulation 2-6-307, 409.8, 415; MOP Volume II, Part 3, §4.11)
5. The filing of a request by the facility for a permit modification, revocation and reissuance, or termination, or the filing of a notification of planned changes or anticipated non-compliance does not stay the applicability of any permit condition. (Regulation 2-6-409.7; MOP Volume II, Part 3, §4.11)
6. This permit does not convey any property rights of any sort, or any exclusive privilege. (Regulation 2-6-409.7; MOP Volume II, Part 3, §4.11)
7. The permit holder shall supply within 30 days any information that the District requests in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. (Regulation 1-441, Regulation 2-6-409.4 & 501; MOP Volume II, Part 3, §4.11)
8. Any records required to be maintained pursuant to this permit that the permittee considers to contain proprietary or trade secret information shall be prominently designated as such. Copies of any such proprietary or trade secret information which are provided to the District shall be maintained by the District in a locked confidential file, provided, however, that requests from the public for the review of any such information shall be handled in accordance with the District's procedures set forth in Section 11 of the District Administrative Code. (Regulation 2-6-419; MOP Volume II, Part 3, §4.11)
9. Proprietary or trade secret information provided to EPA will be subject to the requirements of 40 CFR Part 2, Subpart B - Public Information, Confidentiality of Business Information. (40 CFR Part 2)
10. The emissions inventory submitted with the application for this Major Facility Review Permit is an estimate of actual emissions or the potential to emit for the time period stated and is included only as one means of determining applicable requirements for emission sources. It does not establish, or constitute a basis for establishing, any new emission limitations. (MOP Volume II, Part 3, §4.11)
11. The responsible official shall certify all documents submitted by the facility pursuant to the major facility review permit. The certification shall state that based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete. The certifications shall be signed by a responsible official for the facility. (Regulation 2-6-409.20, MOP Volume II, Part 3, §4.11)

## **I. Standard Conditions**

12. The permit holder is responsible for compliance, and certification of compliance, with all conditions of the permit, regardless whether it acts through employees, agents, contractors, or subcontractors. (Regulation 2-6-307)

### **C. Requirement to Pay Fees**

The permit holder shall pay annual fees in accordance with District Regulation 3, including Schedule P. (Regulation 2-6-402 & 409.13, Regulation 3; MOP Volume II, Part 3, §4.12)

### **D. Inspection and Entry**

**Access to Facility:** The permit holder shall provide reasonable access to the facility and equipment that is subject to this permit to the APCO and/or to his or her designee. (Regulation 1-440, Regulation 2-6-409.3; MOP Volume II, Part 3, §4.14)

### **E. Records**

1. The permit holder must provide any information, records, and reports requested or specified by the APCO. (Regulation 1-441, Regulation 2-6-409.4)
2. Notwithstanding the specific wording in any requirement, all records for federally enforceable requirements shall be maintained for at least five years from the date of entry. (Regulation 2-6-501; MOP Volume II, Part 3, §4.7)

### **F. Monitoring Reports**

Reports of all required monitoring must be submitted to the District at least once every six months, except where an applicable requirement specifies more frequent reporting. Monitoring reports shall be submitted for the following periods: January 1st through June 30th and July 1st through December 31st, and are due on the last day of the month after the end of the reporting period. All instances of non-compliance shall be clearly identified in these reports. The reports shall be certified by the responsible official as true, accurate, and complete. In addition, all instances of non-compliance with the permit shall be reported in writing to the District's Compliance and Enforcement Division within 10 calendar days of the discovery of the incident. Within 30 calendar days of the discovery of any incident of non-compliance, the facility shall submit a written report including the probable cause of non-compliance and any corrective or preventative actions. The reports shall be sent by e-mail to [compliance@baaqmd.gov](mailto:compliance@baaqmd.gov) or postal mail to the following address:

Director of Compliance and Enforcement  
Bay Area Air Quality Management District  
375 Beale Street, Suite 600  
San Francisco, CA 94105  
Attn: Title V Reports

(Regulation 2-6-502; MOP Volume II, Part 3, §4.7)

## **I. Standard Conditions**

### **G. Compliance Certification**

Compliance certifications shall be submitted annually by the responsible official of this facility to the Bay Area Air Quality Management District and to the Environmental Protection Agency. The certification period will be January 1st through December 31st. The certification shall be submitted by February 28th of each year. The certification must list each applicable requirement, the compliance status, whether compliance was continuous or intermittent, the method used to determine compliance, and any other specific information required by the permit. The certification should be directed to the District's Compliance and Enforcement Division at the address above, and a copy of the certification should be sent by e-mail to [r9.aeo@epa.gov](mailto:r9.aeo@epa.gov) or postal mail to the Environmental Protection Agency at the following address:

Director  
Enforcement Division, TRI & Air Section (ENF-2-1)  
USEPA Region 9  
75 Hawthorne Street  
San Francisco, CA 94105

(MOP Volume II, Part 3, §4.5 and 4.15)

### **H. Emergency Provisions**

1. The permit holder may seek relief from enforcement action in the event of a breakdown, as defined by Regulation 1-208 of the District's Rules and Regulations, by following the procedures contained in Regulations 1-431 and 1-432. The District will thereafter determine whether breakdown relief will be granted in accordance with Regulation 1-433. (MOP Volume II, Part 3, §4.8)
2. The permit holder may seek relief from enforcement action for a violation of any of the terms and conditions of this permit by applying to the District's Hearing Board for a variance pursuant to Health and Safety Code Section 42350. The Hearing Board will determine after notice and hearing whether variance relief should be granted in accordance with the procedures and standards set forth in Health and Safety Code Section 42350 et seq. (MOP Volume II, Part 3, §4.8)
3. The granting by the District of breakdown relief or the issuance by the Hearing Board of a variance will not provide relief from federal enforcement. (MOP Volume II, Part 3, §4.8)

### **I. Severability**

In the event that any provision of this permit is invalidated by a court or tribunal of competent jurisdiction, or by the Administrator of the EPA, all remaining portions of the permit shall remain in full force and effect. (Regulation 2-6-409.5; MOP Volume II, Part 3, §4.10)

### **J. Miscellaneous Conditions**

1. The maximum capacity for each source as shown in Table II-A is the maximum allowable capacity. Exceedance of the maximum allowable capacity for any source is a violation of Regulation 2, Rule 1, Section 301. (Regulation 2-1-301)

## II. EQUIPMENT LIST

**Table II-A - Permitted Sources**

Each of the following sources has been issued a permit to operate pursuant to the requirements of BAAQMD Regulation 2, Permits. The capacities in this table are the maximum allowable capacities for each source, pursuant to Standard Condition I.J and Regulation 2-1-301.

S#	Description	Make or Type	Model	Capacity
S6	Gas Turbine, natural gas only, with Steam Injection (26 MW nominal)	General Electric	LM2500	219 MMBtu/hr
S7	Duct Burner, natural gas	Coen	C-0700-248	75 MMbtu/hr, HHV (limited to 70.2 MMbtu/hr, HHV)
S9	Standby Boiler, with low NOx Burners and Flue Gas Recirculation, natural gas & distillate oil (cannot fire both simultaneously)	Cleaver-Brooks	W-3813	161 MMBtu/hr
S10	Papermaking including pulping, separation processes, web production, and drying	Kobayashi	Not Applicable	146,000 ton/12 month period
S11	Cold Cleaner	ZEP Dynaclean		30 gallons of volume
S13	Cold Cleaner	ZEP Dynaclean		30 gallons of volume
S14	Fire Pump Engine	1984 Fairbanks Morse		223 hp
S16	Felt Cleaning (Top Felt)	Custom		
S17	Felt Cleaning (Bottom Felt)	Custom		
S18	Felt Cleaning (1 <sup>st</sup> Main Press)	Custom		
S19	Felt Cleaning (2 <sup>nd</sup> Main Press)	Custom		
S20	Paperboard Sealing (Dry Stack Solution Box)	Custom	Custom	
S21	Paperboard Sealing (Wet Stack Top Solution Box)	Custom	Custom	
S22	Paperboard Sealing (Wet Stack Bottom Solution Box)	Custom	Custom	
S23	Paperboard Coating (#1 Coater)	Custom	Custom	
S24	Paperboard Coating (#2 Coater)	Custom	Custom	
S25	Paperboard Coating (#3 Coater)	Custom	Custom	

## II. Equipment List

**Table II-C – Significant Sources**

The following sources are exempt from the requirement to obtain an authority to construct and permit to operate, but are defined as significant sources pursuant to BAAQMD Regulation 2-6-239.

S#	Description	Make or Type	Model	Capacity
N/A	Cooling Tower			400 gpm 34,000 cfm



### III. GENERALLY APPLICABLE REQUIREMENTS

The permit holder shall comply with all applicable requirements, including those specified in the BAAQMD and SIP Rules and Regulations and other federal requirements cited below. These requirements apply in a general manner to the facility and/or to sources exempt from the requirement to obtain a District Permit to Operate. The District has determined that these requirements would not be violated under normal, routine operations, and that no additional periodic monitoring or reporting to demonstrate compliance is warranted. In cases where a requirement, in addition to being generally applicable, is also specifically applicable to one or more sources, the requirement and the source are also included in Section IV, Source-Specific Applicable Requirements, of this permit. This section also contains provisions that may apply to temporary sources.

The dates in parentheses in the Title column identify the versions of the regulations being cited and are, as applicable:

1. BAAQMD regulation(s):  
The date(s) of adoption or most recent amendment of the regulation by the District Board of Directors
2. Any federal requirement, including a version of a District regulation that has been approved into the SIP:  
The most recent date of EPA approval of any portion of the rule, encompassing all actions on the rule through that date

The full language of SIP requirements is on EPA Region 9's website. The address is:  
<http://yosemite.epa.gov/r9/r9sips.nsf/Agency?ReadForm&count=500&state=California&cat=Bay+Area+Air+Quality+Management+District-Agency-Wide+Provisions>.

**NOTE:**

There are differences between current BAAQMD rules and the versions of the rules in the SIP. All sources must comply with both versions of a rule until US EPA has reviewed and approved (or disapproved) the District's revision of the regulation.

### III. Generally Applicable Requirements

**Table III**  
**Generally Applicable Requirements**

<b>Applicable Requirement</b>	<b>Regulation Title or Description of Requirement</b>	<b>Federally Enforceable (Y/N)</b>
BAAQMD Regulation 1	General Provisions and Definitions (5/4/11)	N
SIP Regulation 1	General Provisions and Definitions (6/28/99)	Y
BAAQMD Regulation 2, Rule 1	General Requirements (12/19/12, effective 8/31/16)	Y
BAAQMD 2-1-429	Federal Emissions Statement (12/21/04)	Y
BAAQMD Regulation 4	Air Pollution Episode Plan (3/20/91)	N
SIP Regulation 4	Air Pollution Episode Plan (8/06/90)	Y
BAAQMD Regulation 5	Open Burning 6/19/13)	N
SIP Regulation 5	Open Burning (9/4/98)	Y
BAAQMD Regulation 6, Rule 1	Particulate Matter, General Requirements (12/5/07)	N
SIP Regulation 6	Particulate Matter and Visible Emissions (9/4/98)	Y
BAAQMD Regulation 7	Odorous Substances (3/17/82)	N
BAAQMD Regulation 8, Rule 1	Organic Compounds - General Provisions (6/15/94)	Y
BAAQMD Regulation 8, Rule 2	Organic Compounds – Miscellaneous Operations (7/20/05)	N
SIP Regulation 8, Rule 2	Organic Compounds – Miscellaneous Operations (3/22/95)	Y
BAAQMD Regulation 8, Rule 3	Organic Compounds - Architectural Coatings (7/01/09)	Y
SIP Regulation 8, Rule 3	Organic Compounds - Architectural Coatings (1/2/04)	Y
BAAQMD Regulation 8, Rule 4	Organic compounds - General Solvent and Surface Coating Operations (10/16/02)	Y
BAAQMD Regulation 8, Rule 15	Organic Compounds – Emulsified and Liquid Asphalts (6/1/94)	Y
BAAQMD Regulation 8, Rule 40	Organic Compounds - Aeration of Contaminated Soil and Removal of Underground Storage Tanks (6/15/05)	N
SIP Regulation 8, Rule 40	Organic Compounds - Aeration of Contaminated Soil and Removal of Underground Storage Tanks (4/19/01)	Y
BAAQMD Regulation 8, Rule 47	Organic Compounds - Air Stripping and Soil Vapor Extraction Operations (6/15/05)	N
SIP Regulation 8, Rule 47	Organic Compounds - Air Stripping and Soil Vapor Extraction Operations (4/26/95)	Y
BAAQMD Regulation 8, Rule 49	Organic Compounds - Aerosol Paint Products (12/20/95)	N
SIP Regulation 8, Rule 49	Organic Compounds - Aerosol Paint Products (3/22/95)	Y
BAAQMD Regulation 9, Rule 1	Inorganic Gaseous Pollutants - Sulfur Dioxide (3/15/95)	N
SIP Regulation 9, Rule 1	Inorganic Gaseous Pollutants - Sulfur Dioxide (6/8/99)	Y

### III. Generally Applicable Requirements

**Table III  
 Generally Applicable Requirements**

<b>Applicable Requirement</b>	<b>Regulation Title or Description of Requirement</b>	<b>Federally Enforceable (Y/N)</b>
BAAQMD Regulation 11, Rule 2	Hazardous Pollutants - Asbestos Demolition, Renovation and Manufacturing (10/7/98)	N
BAAQMD Regulation 12, Rule 4	Miscellaneous Standards of Performance - Sandblasting (7/11/90)	N
SIP Regulation 12, Rule 4	Miscellaneous Standards of Performance - Sandblasting (9/2/81)	Y
California Health and Safety Code Section 41750 et seq.	Portable Equipment	N
California Health and Safety Code Section 44300 et seq.	Air Toxics "Hot Spots" Information and Assessment Act of 1987	N
California Health and Safety Code Title 17, Section 93115	Airborne Toxic Control Measure for Stationary Compression Ignition Engines	N
California Health and Safety Code Title 17, Section 93116	Airborne Toxic Control Measure for Diesel Particulate Matter from Portable Engines Rated at 50 Horsepower and Greater	N
40 CFR Part 61, Subpart M	National Emission Standards for Hazardous Air Pollutants – National Emission Standard for Asbestos (6/19/95)	Y
EPA Regulation 40 CFR 82	Protection of Stratospheric Ozone (2/21/95)	
Subpart F, 40 CFR 82.156	Recycling and Emissions Reductions – Required Practices	Y
Subpart F, 40 CFR 82.161	Recycling and Emissions Reduction – Technician Certification	Y
Subpart F, 40 CFR 82.166	Recycling and Emissions Reductions – Reporting and Recordkeeping Requirements	Y

#### IV. SOURCE-SPECIFIC APPLICABLE REQUIREMENTS

The permit holder shall comply with all applicable requirements, including those specified in the BAAQMD and SIP Rules and Regulations and other federal requirements cited below. The requirements cited in the following tables apply in a specific manner to the indicated source(s).

The dates in parentheses in the Title column identify the versions of the regulations being cited and are, as applicable:

1. BAAQMD regulation(s): The date(s) of adoption or most recent amendment of the regulation by the District Board of Directors
2. Any federal requirement, including a version of a District regulation that has been approved into the SIP:  
 The most recent date of EPA approval of any portion of the rule, encompassing all actions on the rule through that date

The full text of each permit condition cited is included in Section VI, Permit Conditions, of this permit. The full language of SIP requirements is on EPA Region 9's website. The address is: <http://yosemite.epa.gov/r9/r9sips.nsf/Agency?ReadForm&count=500&state=California&cat=Bay+Area+Air+Quality+Management+District-Agency-Wide+Provisions>. All other text may be found in the regulations themselves.

**Table IV-A  
 Source-Specific Applicable Requirements  
 S6, Turbine; S7, Duct Burner**

Applicable Requirement	Regulation Title or Description of Requirement	Federally Enforceable (Y/N)	Future Effective Date
<b>BAAQMD Regulation 1</b>	<b>General Provisions and Definitions (5/4/11)</b>		
1-107	Combination of Emissions	Y	
1-520	Continuous Emission Monitoring	Y	
1-520.8	Monitors required per Reg. 2-1-403	Y	
1-522	Continuous Emission Monitoring and Recordkeeping Procedures	Y	
1-522.4	reporting of inoperative CEMs	Y	
1-522.5	CEM calibration requirements	Y	
1-522.6	CEM accuracy requirements	Y	
1-522.7	emission limit exceedance reporting requirements	N	
1-522.8	monitoring data submittal requirements	Y	
1-522.9	recordkeeping requirements	Y	
1-602	Area and Continuous Emission Monitoring Requirements	N	

#### IV. Source-Specific Applicable Requirements

**Table IV-A  
 Source-Specific Applicable Requirements  
 S6, Turbine; S7, Duct Burner**

<b>Applicable Requirement</b>	<b>Regulation Title or Description of Requirement</b>	<b>Federally Enforceable (Y/N)</b>	<b>Future Effective Date</b>
<b>SIP Regulation 1</b>	<b>General Provisions and Definitions (6/28/99)</b>		
1-522	Continuous Emission Monitoring and Recordkeeping Procedures	Y	
1-522.7	Monitor excesses	Y	
<b>BAAQMD Regulation 2, Rule 1</b>	<b>Regulation 2, Rule 1 - Permits, General Requirements (6/7/95)</b>		
2-1-501	Monitors	Y	
<b>BAAQMD Regulation 6, Rule 1</b>	<b>Particulate Matter, General Requirements (12/5/07)</b>		
6-1-301	Ringelmann #1 Limitation	N	
6-1-305	Visible Particles	N	
6-1-310	Particulate Weight Limitation	N	
6-1-310.3	Particulate Weight Limitation @ 6% O2	N	
6-1-401	Appearance of Emissions	N	
<b>SIP Regulation 6</b>	<b>Particulate Matter and Visible Emissions (9/4/98)</b>		
6-301	Ringelmann #1 Limitation	Y	
6-305	Visible Particles	Y	
6-310	Particulate Weight Limitation	Y	
6-310.3	Particulate Weight Limitation @ 6% O2	Y	
6-401	Appearance of Emissions	Y	
<b>BAAQMD Regulation 9, Rule 1</b>	<b>Inorganic Gaseous Pollutants - Sulfur Dioxide (3/15/95)</b>		
9-1-301	Limitations on Ground Level Concentrations	Y	
9-1-302	General Emission Limitations	Y	
<b>BAAQMD Regulation 9, Rule 9</b>	<b>Inorganic Gaseous Pollutants - Nitrogen Oxides from Stationary Gas Turbines (12/6/06)</b>		
9-9-113	Exemption - Inspection/Maintenance	N	
9-9-114	Exemption - Startup/Shutdown	N	
9-9-115	Limited Exemption, Minor Inspection and Maintenance Work	N	

## IV. Source-Specific Applicable Requirements

**Table IV-A**  
**Source-Specific Applicable Requirements**  
**S6, Turbine; S7, Duct Burner**

<b>Applicable Requirement</b>	<b>Regulation Title or Description of Requirement</b>	<b>Federally Enforceable (Y/N)</b>	<b>Future Effective Date</b>
9-9-120	Limited Exemption, Interchangeable Emission Reduction Credits	N	
9-9-301	Emission Limits – General	N	
9-9-301.1.2	Emission Limits - Turbines over 10.0 MW without SCR	Y	
9-9-301.2	Emission limits	N	
9-9-301.4	Rebuttable presumption	N	
9-9-501	Monitoring & Recordkeeping	N	
9-9-603	Continuous Emission Monitoring	N	
9-9-605	Compliance With Output Based NOx Emissions Standards	N	
<b>SIP Regulation 9, Rule 9</b>	<b>Inorganic Gaseous Pollutants - Nitrogen Oxides from Stationary Gas Turbines (12/15/97)</b>		
9-9-113	Exemption - Inspection/Maintenance	Y	
9-9-114	Exemption - Startup/Shutdown	Y	
9-9-301	Emission Limits – General	Y	
9-9-301.2	Emission Limits - Turbines over 10.0 MW without SCR	Y	
9-9-501	Monitoring & Recordkeeping	Y	
<b>BAAQMD Manual of Procedures, Volume V</b>	<b>Continuous Emission Monitoring Policy and Procedures (1/20/82)</b>	Y	
<b>40 CFR 60 Subpart A</b>	<b>Standards of Performance for New Stationary Sources – General Provisions (12/23/71)</b>	Y	
60.4(b)	Reports to EPA and District	Y	
60.7(a)(4)	Written notification of physical or operational changes	Y	
60.7(b)	Records	Y	
60.8	Performance Tests	Y	
60.9	Availability of Information	Y	
60.11(a)	Compliance with standards and maintenance requirements	Y	
60.11(d)	Minimizing emissions	Y	
60.12	Circumvention	Y	
60.13	Monitoring Requirements	Y	
<b>NSPS Subpart GG</b>	<b>Standards of Performance for Stationary Gas Turbines (10/17/00)</b>		
60.332 (a)(2)	Performance Standard, NOx	Y	

## IV. Source-Specific Applicable Requirements

**Table IV-A**  
**Source-Specific Applicable Requirements**  
**S6, Turbine; S7, Duct Burner**

<b>Applicable Requirement</b>	<b>Regulation Title or Description of Requirement</b>	<b>Federally Enforceable (Y/N)</b>	<b>Future Effective Date</b>
60.333(b)	Performance Standards, SO <sub>2</sub> : percentage of S in fuel (S6, Turbine only)	Y	
60.334(b)	Use of CEM to monitor NO <sub>x</sub>	Y	
60.334(h)(3)(i)	Valid purchase contract, tariff sheet, or transportation contract for natural gas	Y	
60.334(j)(iii)	4-hour average	Y	
60.335	Test Methods and Procedures	Y	
<b>40 CFR 60, Appendix B</b>	<b>Performance Specifications</b>		
Performance Specification 2	Specifications and Test Procedures for SO <sub>2</sub> and NO <sub>x</sub> Continuous Emission Monitoring Systems in Stationary Sources	Y	
Performance Specification 3	Specifications and Test Procedures for O <sub>2</sub> and CO <sub>2</sub> Continuous Emission Monitoring Systems in Stationary Sources	Y	
<b>40 CFR 60 Appendix F</b>	<b>Quality Assurance Procedures</b>		
Procedure 1	QA requirements for gas continuous emission monitoring systems	Y	
<b>BAAQMD Condition #14522</b>	<b>Permit to Operate Condition</b>	Y	
Part 1	Natural gas firing [BACT]	Y	
Part 4	Steam Injection to control NO <sub>x</sub> emissions during all periods of gas turbine operation except during times of start-up, shutdown, and inspection and maintenance [BAAQMD Regulation 9, Rule 9]	Y	
Part 5	Monitoring & recordkeeping [BACT, BAAQMD Regulation 9, Rule 9]	Y	
Part 6	Sulfur Limit (PUC quality gas) [BAAQMD Regulation 2-1-403]	Y	
Part 7	Heat input limit for turbine [Cumulative Increase, 2-1-305, 2-2-409]	Y	
Part 8	Hourly records of turbine heat input [2-6-503]	Y	
Part 9	Heat input limit for duct burner [Cumulative Increase, 2-1-305, 2-2-409]	Y	
Part 10	Hourly records of duct burner heat input [2-6-503]	Y	
Part 11	Records of fuel usage [2-6-501, 2-6-503]	Y	

## IV. Source-Specific Applicable Requirements

**Table IV-B  
 Source-Specific Applicable Requirements  
 S9, Standby Boiler**

<b>Applicable Requirement</b>	<b>Regulation Title or Description of Requirement</b>	<b>Federally Enforceable (Y/N)</b>	<b>Future Effective Date</b>
<b>BAAQMD Regulation 6, Rule 1</b>	<b>Particulate Matter, General Requirements (12/5/07)</b>		
6-1-301	Ringelmann #1 Limitation	N	
6-1-304	Tube Cleaning	N	
6-1-305	Visible Particles	N	
6-1-310	Particulate Weight Limitation	N	
6-1-310.3	Particulate Weight Limitation	N	
6-1-401	Appearance of Emissions	N	
<b>SIP Regulation 6</b>	<b>Particulate Matter and Visible Emissions (9/4/98)</b>		
6-301	Ringelmann #1 Limitation	Y	
6-304	Tube Cleaning	Y	
6-305	Visible Particles	Y	
6-310	Particulate Weight Limitation	N	
6-310.3	Particulate Weight Limitation	Y	
6-401	Appearance of Emissions	Y	
<b>BAAQMD Regulation 9, Rule 1</b>	<b>Inorganic Gaseous Pollutants - Sulfur Dioxide (3/15/95)</b>		
9-1-301	Limitations on Ground Level Concentrations	Y	
9-1-302	General Emission Limitations	Y	
9-1-304	Fuel Burning (Liquid and Solid Fuels)	Y	
<b>BAAQMD Regulation 9, Rule 7</b>	<b>Inorganic Gaseous Pollutants - Nitrogen Oxides and Carbon Monoxide from Industrial, Institutional, and Commercial Boilers, Steam Generators, and Process Heaters (5/4/11)</b>		
9-7-112	Limited Exemption, Low Fuel Usage	N	
9-7-112.2	Operation at 10% capacity	N	
9-7-114	Limited Exemption, Tune-Up	N	
9-7-115	Limited Exemption, Startup and Shutdown	N	
9-7-503	Records	N	



## IV. Source-Specific Applicable Requirements

**Table IV-B**  
**Source-Specific Applicable Requirements**  
**S9, Standby Boiler**

<b>Applicable Requirement</b>	<b>Regulation Title or Description of Requirement</b>	<b>Federally Enforceable (Y/N)</b>	<b>Future Effective Date</b>
9-7-503.2	Records of natural gas curtailment	N	
9-7-503.3	Records of equipment testing	N	
9-7-503.4	Source Test Records and Record Retention	N	
9-7-504	Low Fuel Usage - Monitoring and Records	N	
<b>SIP Regulation 9, Rule 7</b>	<b>Inorganic Gaseous Pollutants - Nitrogen Oxides and Carbon Monoxide from Industrial, Institutional, and Commercial Boilers, Steam Generators, and Process Heaters (12/15/97)</b>		
9-7-301	Emission Limits - Gaseous Fuels	Y	
9-7-301.1	Performance Standard, NOx, gaseous fuel	Y	
9-7-301.2	Performance Standard, CO, non-gaseous fuel	Y	
9-7-302	Emission Limits – Non-gaseous fuels	Y	
9-7-302.1	Performance Standard, NOx	Y	
9-7-302.2	Performance Standard, CO	Y	
9-7-303	Emission Limits - Gaseous and Non-Gaseous Fuel	Y	
9-7-305	Natural Gas Curtailment-Non-Gaseous Fuel	Y	
9-7-305.1	Natural Gas Curtailment-Non-Gaseous Fuel: NOx limit	Y	
9-7-305.2	Natural Gas Curtailment-Non-Gaseous Fuel: CO limit	Y	
9-7-306	Equipment Testing Non-Gaseous Fuel	Y	
9-7-503	Records	Y	
9-7-503.2	Records of natural gas curtailment	Y	
9-7-503.3	Records of equipment testing	Y	
9-7-503.4	Source Test Records and Record Retention	Y	
<b>40 CFR 60 Subpart A</b>	<b>Standards of Performance for New Stationary Sources – General Provisions (12/23/71)</b>		
60.4(b)	Reports to EPA and District	Y	
60.7(a)(4)	Written notification of physical or operational changes	Y	
60.7(b)	Records	Y	
60.8	Performance Tests	Y	
60.9	Availability of Information	Y	
60.11(a)	Compliance with standards and maintenance requirements	Y	
60.11(d)	Minimizing emissions	Y	
60.12	Circumvention	Y	
60.13	Monitoring Requirements	Y	

#### IV. Source-Specific Applicable Requirements

**Table IV-B**  
**Source-Specific Applicable Requirements**  
**S9, Standby Boiler**

<b>Applicable Requirement</b>	<b>Regulation Title or Description of Requirement</b>	<b>Federally Enforceable (Y/N)</b>	<b>Future Effective Date</b>
<b>NSPS Subpart Db</b>	<b>Standards of Performance for Industrial-Commercial-Institutional Steam Generating Units (12/16/87)</b>		
60.42b(j)	Requirement to burn only very low sulfur oil	Y	
60.43b(f)	Opacity limit	Y	
60.43b(g)	Opacity limit does not apply during startup, shutdown, or malfunction	Y	
60.44b(k)	10% capacity factor	Y	
60.45b(j)	Fuel receipts	Y	
60.46b(a)	Opacity limit does not apply during startup, shutdown, and malfunction	Y	
60.46b(d)(7)	Opacity test	Y	
60.47b(f)	Fuel receipts	Y	
60.48b(i)	Exemption from NOx CEM for sources subject to Section 60.44b(k)	Y	
60.48b(j)(2)	Exemption from COM monitor for use of low-sulfur liquid fuel	Y	
60.49b(d)	Records of fuels combusted	Y	
60.49b(f)	Records of opacity	Y	
60.49b(j)	Reports of sulfur dioxide emissions	Y	
60.49b(o)	Record retention requirement	Y	
60.49b(p)	Records of calendar date, number of hours of operation, hourly steam load	Y	
60.49b(q)	Annual report	Y	
60.49b(q)(1)	Annual capacity factor	Y	
60.49b(r)	Maintenance of fuel oil receipts; annual report to Administrator	Y	
60.49b(w)	Reporting period-every six months	Y	
<b>BAAQMD Cond #12231</b>	<b>Permit to Operate Condition</b>		
Part 1	Only burn natural gas or distillate oil , only use distillate oil in the event of natural gas curtailment or testing, only PUC quality gas shall be used [Cumulative Increase]	Y	
Part 2	Annual Heat Input limit (natural gas) [Cumulative Increase]	Y	
Part 3	Operating Hour Limit (distillate oil) [Cumulative Increase]	Y	
Part 4	Maximum Heat Input [Cumulative Increase]	Y	
Part 5	Natural Gas Flow Meter [Cumulative Increase]	Y	

#### IV. Source-Specific Applicable Requirements

**Table IV-B  
 Source-Specific Applicable Requirements  
 S9, Standby Boiler**

<b>Applicable Requirement</b>	<b>Regulation Title or Description of Requirement</b>	<b>Federally Enforceable (Y/N)</b>	<b>Future Effective Date</b>
Part 6	Flue Gas Recirculation Requirement [BACT]	Y	
Part 7	BACT NOx and CO Limit (natural gas) [BACT]	Y	
Part 8	NOx Limit (distillate oil) [BACT]	Y	
Part 9	Sulfur Limit in distillate oil [BACT]	Y	
Part 10	PM Limit [BACT]	Y	
Part 11	Recordkeeping [Cumulative Increase, Regulation 9-7-504]	Y	
Part 12	Annual Portable Analyzer Verification [BACT, Regulation 9-7-112.2, Regulation 2-6-503]	Y	

**Table IV-C  
 Source-Specific Applicable Requirements  
 S10, Papermaking including pulping, separation processes, web production, and drying**

<b>Applicable Requirement</b>	<b>Regulation Title or Description of Requirement</b>	<b>Federally Enforceable (Y/N)</b>	<b>Future Effective Date</b>
<b>BAAQMD Regulation 6, Rule 1</b>	<b>Particulate Matter, General Requirements (12/5/07)</b>		
6-1-301	Ringelmann #1 Limitation	N	
6-1-305	Visible Particles	N	
6-1-310	Particulate Weight Limitation	N	
6-1-310.3	Particulate Weight Limitation	N	
6-1-311	General Operations	N	
6-1-401	Appearance of Emissions	N	
<b>SIP Regulation 6</b>	<b>Particulate Matter and Visible Emissions (9/4/98)</b>		
6-301	Ringelmann #1 Limitation	Y	
6-305	Visible Particles	Y	
6-310.3	Particulate Weight Limitation	Y	
6-311	General Operations	Y	

#### IV. Source-Specific Applicable Requirements

**Table IV-C**  
**Source-Specific Applicable Requirements**  
**S10, Papermaking including pulping, separation processes, web production, and**  
**drying**

<b>Applicable Requirement</b>	<b>Regulation Title or Description of Requirement</b>	<b>Federally Enforceable (Y/N)</b>	<b>Future Effective Date</b>
6-401	Appearance of Emissions	Y	
<b>BAAQMD Regulation 8, Rule 2</b>	<b>Organic Compounds - Miscellaneous Operation (7/20/05)</b> <b>(Applies to pulping and drying operations only)</b>	Y	
8-2-301	Miscellaneous Operations (pulping and drying operations)	Y	
<b>BAAQMD Regulation 9, Rule 1</b>	<b>Inorganic Gaseous Pollutants - Sulfur Dioxide (3/15/95)</b>		
9-1-301	Limitations on Ground Level Concentrations	Y	
9-1-302	General Emission Limitations	Y	
<b>BAAQMD Cond #13344</b>	<b>Permit to Operate Condition</b>		
Part 1	Throughput Limit [2-1-301, 2-1-234.3.1.2]	Y	
Part 2	Recordkeeping [2-1-301, 2-1-234.3.1.2]	Y	

#### IV. Source-Specific Applicable Requirements

**Table IV - D**  
**Source-specific Applicable Requirements**  
**S11, S13, COLD CLEANERS**

Applicable Requirement	Regulation Title or Description of Requirement	Federally Enforceable (Y/N)	Future Effective Date
<b>BAAQMD Regulation 8, Rule 16</b>	<b>Solvent Cleaning Operations (10/16/02)</b>	<b>Y</b>	
8-16-303	Cold Cleaner Requirements	Y	
8-16-303.1	General Operating Requirements	Y	
8-16-303.2	Cold Cleaner Operating Requirements	Y	
8-16-303.3	Cold Cleaner General Equipment Requirements	Y	
8-16-303.5	Requirements for solvents	Y	
8-16-303.5.2	Use of cyclic methylated siloxanes	Y	
8-16-501	Solvent records	Y	
8-16-501.2	Monthly records	Y	
8-16-501.5	Record retention for 24 months	Y	
<b>BAAQMD Condition #16714</b>			
Part 1	Throughput limit (Cumulative Increase)	Y	
Part 2	Recordkeeping (Cumulative Increase)	Y	

**Table IV - E**  
**Source-specific Applicable Requirements**  
**S14, FIRE PUMP ENGINE**

Applicable Requirement	Regulation Title or Description of Requirement	Federally Enforceable (Y/N)	Future Effective Date
<b>BAAQMD Regulation 6, Rule 1</b>	<b>Particulate Matter, General Requirements (12/5/07)</b>		
6-1-303	Ringelmann Number 2 Limitation	N	
6-1-303.1	Ringelmann Number 2 Limitation	N	
6-1-305	Visible Particles	N	
6-1-310	Particulate Weight Limitation	N	

#### IV. Source-Specific Applicable Requirements

**Table IV - E**  
**Source-specific Applicable Requirements**  
**S14, FIRE PUMP ENGINE**

<b>Applicable Requirement</b>	<b>Regulation Title or Description of Requirement</b>	<b>Federally Enforceable (Y/N)</b>	<b>Future Effective Date</b>
6-1-401	Appearance of Emissions	N	
<b>SIP Regulation 6</b>	<b>Particulate Matter and Visible Emissions (9/4/98)</b>		
6-303	Ringelmann Number 2 Limitation	Y	
6-303.1	Ringelmann Number 2 Limitation	Y	
6-305	Visible Particles	Y	
6-310	Particulate Weight Limitation	Y	
6-401	Appearance of Emissions	Y	
<b>BAAQMD Regulation 9, Rule 1</b>	<b>Inorganic Gaseous Pollutants – Sulfur Dioxide (3/15/95)</b>		
9-1-301	Limitations on Ground Level Concentrations	Y	
9-1-304	Liquid and Solid Fuels	Y	
<b>BAAQMD Regulation 9, Rule 8</b>	<b>Inorganic Gaseous Pollutants - Nitrogen Oxides and Carbon Monoxide from Stationary Internal Combustion Engines (7/25/07)</b>		
9-8-110	Exemptions	N	
9-8-110.5	Emergency Standby Engines	N	
9-8-330	Emergency Standby Engines, Hours of Operation	N	
9-8-502	Recordkeeping	N	
9-8-502.1	Monthly records of usage	N	
9-8-530	Emergency Standby and Low Usage Engines, Monitoring and Recordkeeping	N	
9-8-110.1	Engines less than 250 bhp horsepower	Y	
9-8-110.2	Engines fired exclusively by liquid fuels	Y	
<b>40 CFR 63 Subpart A</b>	<b>National Emission Standards for Hazardous Air Pollutants for Source Categories (3/16/1994)</b>		
63.1	Applicability	Y	
63.2	Definitions	Y	
63.3	Units and abbreviations	Y	
63.4	Prohibited activities and circumvention	Y	
63.5	Construction and reconstruction	Y	
63.6	Compliance with standards and maintenance requirements	Y	
63.7	Performance testing requirements	Y	

## IV. Source-Specific Applicable Requirements

**Table IV - E**  
**Source-specific Applicable Requirements**  
**S14, FIRE PUMP ENGINE**

<b>Applicable Requirement</b>	<b>Regulation Title or Description of Requirement</b>	<b>Federally Enforceable (Y/N)</b>	<b>Future Effective Date</b>
63.8	Monitoring requirements	Y	
63.9	Notification requirements	Y	
63.10	Recordkeeping and reporting requirements	Y	
63.12	State authority and delegations	Y	
63.13	Addresses of EPA Regional Offices	Y	
63.14	Incorporation by Reference	Y	
63.15	Availability of Information and confidentiality	Y	
<b>40 CFR 63 Subpart ZZZZ</b>	<b>National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines</b>		
63.6585	Applicability	Y	
63.6585(a)	Applicable to stationary RICE	Y	
63.6585(c)	Applicable to area source of HAPs	Y	
63.6590	Subject to subpart ZZZZ	Y	
63.6590(a)(1)(iii)	Existing stationary RICE at an area source of HAPs	Y	
63.6595	Compliance Schedule to 40 CFR 63, Subpart ZZZZ	Y	
63.6595(a)(1)	Comply with the applicable emission limitation and operating limitations no later than May 3, 2013	Y	
63.6603	Emission Limitations and Operating Limitations for Existing Stationary RICE located at an area source of HAP emissions	Y	
63.6603(a), Table 2d, part 4	Change oil and filter every 500 hours of operation or annually, whichever comes first; Inspect air cleaner every 1,000 hours of operation or annually, whichever comes first; and Inspect all hoses and belts every 500 hours of operation or annually, whichever comes first, and replace as necessary.	Y	
63.6605	General Requirements	Y	
63.6605(a)	Comply with the emission limitations and operating limitations at all times	Y	
63.6605(b)	Safety and good air pollution control practices for minimizing emissions	Y	
63.6625	Monitoring, Installation, Operation, and Maintenance Requirements	Y	
63.6625(e)(3)	Operate and maintain engine and after-treatment control device (if any) in a manner consistent with good air pollution control practice for minimizing emissions	Y	

#### IV. Source-Specific Applicable Requirements

**Table IV - E**  
**Source-specific Applicable Requirements**  
**S14, FIRE PUMP ENGINE**

<b>Applicable Requirement</b>	<b>Regulation Title or Description of Requirement</b>	<b>Federally Enforceable (Y/N)</b>	<b>Future Effective Date</b>
63.6625(f)	Install a non-resettable hour meter if one is not already installed	Y	
63.6625(h)	Minimize the engine's time spent at idle during startup and minimize the engine's startup time to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes	Y	
63.6635	Monitor and Collect Data to Demonstrate Continuous Compliance	Y	
63.6640	Demonstrate Continuous Compliance with the Emission Limitations and Operating Limitations	Y	
63.6640(f)(1)	Requirements for an existing emergency stationary RICE located at an area source of HAP emissions.	Y	
63.6645	Notification, Reports, and Records	Y	
63.6645(a)(2)	Submit notification in §§63.7(b) and (c), 63.8(e), (f)(4) and (f)(6), 63.9(b) through (e), and (g) and (h) that apply	Y	
63.6655	Recordkeeping	Y	
63.6655(a)	Recordkeeping with the emission and operating limitations	Y	
63.6655(e)(2)	Keep records of the maintenance conducted on an existing emergency RICE	Y	
63.6660	Recordkeeping	Y	
<b>CCR, Title 17, Section 93115</b>	<b>ATCM for Stationary Compression Ignition Engines</b>		
93115.5	Fuel Requirements	N	
93115.6	ATCM for Stationary CI Engines – Emergency Standby Diesel-Fueled CI Engine (>50 bhp) Operating Requirements and Emission Standards	N	
93115.6(b)	In-Use Emergency Standby Diesel-Fueled CI Engine (> 50 bhp) Operating Requirements and Emission Standards	N	
93115.6(b)(2)	Operation near schools	N	
93115.10(e)(1)	Monitoring Equipment	N	
93115.10(g)	Reporting Requirements for Emergency Standby Engines	N	
93115.11	ATCM for Stationary CI Engines – Compliance Schedule for Owners or Operators of Three or Fewer Engines (>50 bhp) Located within a District	N	
93115.11(a)	Compliance by 1/1/06 for engines complying by reducing hours of operation	N	



#### IV. Source-Specific Applicable Requirements

**Table IV - E**  
**Source-specific Applicable Requirements**  
**S14, FIRE PUMP ENGINE**

Applicable Requirement	Regulation Title or Description of Requirement	Federally Enforceable (Y/N)	Future Effective Date
93115.15	Severability	N	
<b>BAAQMD Condition 22851</b>			
Part 1	Operation for reliability-related activities	N	
Part 2	Operation for emergencies	N	
Part 3	Non-resettable totalizing meter	N	
Part 4	Records	N	
Part 5	At School and Near-School Operation	N	

**Table IV-F**  
**Source-Specific Applicable Requirements**  
**S16, Felt Cleaning (Top Felt)**  
**S17, Felt Cleaning (Bottom Felt)**  
**S18, Felt Cleaning (1<sup>st</sup> Main Press)**  
**S19, Felt Cleaning (2<sup>nd</sup> Main Press)**

Applicable Requirement	Regulation Title or Description of Requirement	Federally Enforceable (Y/N)	Future Effective Date
<b>BAAQMD Regulation 8, Rule 4</b>	<b>Organic Compounds - General Solvent and Surface Coating Operations (10/16/02)</b> <b>(Applies to felt cleaning operation)</b>		
8-4-302	Solvents and Surface Coating Requirements	Y	
8-4-302.1	VOC less than 5 tons/yr (Note: Limit applies to each source separately)	Y	
8-4-312	Solvent Evaporative Loss Minimization	Y	
8-4-312.3	Closed containers of solvent	Y	
8-4-501	Recordkeeping Requirements	Y	
8-4-501.1	Current list of solvents in use	Y	
8-4-501.4	Monthly records of solvents	Y	
8-4-501.5	Record retention requirement	Y	

#### IV. Source-Specific Applicable Requirements

**Table IV-G**  
**Source-Specific Applicable Requirements**  
**S20, Paperboard Sealing (Dry Stack Solution Box)**  
**S21, Paperboard Sealing (Wet Stack Top Solution Box)**  
**S22, Paperboard Sealing (Wet Stack Bottom Solution Box)**  
**S23, Paperboard Coating (#1 Coater)**  
**S24, Paperboard Coating (#2 Coater)**  
**S25, Paperboard Coating (#3 Coater)**

<b>Applicable Requirement</b>	<b>Regulation Title or Description of Requirement</b>	<b>Federally Enforceable (Y/N)</b>	<b>Future Effective Date</b>
<b>BAAQMD Regulation 8, Rule 12</b>	<b>Organic Compounds - Paper, Fabric, and Film Coating (12/20/95)</b> <b>(Applies to paper coating operation)</b>		
8-12-301	Limitations, Coating Lines	Y	
8-12-301.1	Low Solvent Coating or Adhesive	Y	
8-12-302	Storage and Mixing Operations	Y	
8-12-305	Surface Preparation and Cleanup Solvent	Y	
8-12-501	Coating Records	Y	
8-12-501.1	List of Coatings and Adhesives	Y	
8-12-501.2	Daily Records	Y	
8-12-501.4	Record Retention Requirement	Y	

## V. SCHEDULE OF COMPLIANCE

The permit holder shall comply with all applicable requirements cited in this permit. The permit holder shall also comply with applicable requirements that become effective during the term of this permit on a timely basis.

## VI. PERMIT CONDITIONS

Any condition that is preceded by an asterisk is not federally enforceable.

### **Condition # 12231**

#### **Source: S9 Standby Boiler**

1. The owner/operator of S-9 shall operate this source on natural gas fuel exclusively, except that fuel oil may be used in the event of a natural gas curtailment or for periodic testing. (basis: Cumulative Increase)
2. The owner/operator of S-9 shall not exceed 140,875 MMBTU in any consecutive twelve-month period while firing on natural gas. (basis: Cumulative Increase)
3. The owner/operator of S-9 shall not operate more than 100 hours while firing on fuel oil in any consecutive twelve-month period and only during times of natural gas curtailment or for periodic testing. (basis: Cumulative Increase)
4. The owner/operator of S-9 shall not exceed a heat input of 161 MMBTU in any hour while operating S-9. (basis: Cumulative Increase)
5. The owner/operator of S-9 shall maintain a natural gas meter to monitor the flow of natural gas. (basis: Cumulative Increase)
6. The owner/operator of S-9 shall maintain and operate the fuel gas recirculation fan whenever S-9 is in operation. (basis: BACT)
7. The owner/operator of S-9 shall not exceed the following limits when using natural gas as a fuel:  
NO<sub>x</sub> = 25 ppm @ 3% O<sub>2</sub>  
CO = 50 ppm @ 3% O<sub>2</sub>  
(basis: BACT)

## VI. Permit Conditions

8. The owner/operator of S-9 shall not exceed the following limit when using fuel oil as a fuel:  
NO<sub>x</sub> = 60 ppm @ 3% O<sub>2</sub>  
(basis: BACT)
9. The owner/operator of S-9 shall not use any fuel oil with sulfur content exceeding 0.05wt%. (basis: Cumulative Increase)
10. The owner/operator of S-9 shall not exceed visible particulate emissions of Ringelmann No. 0.5. (basis: BACT)
11. To determine compliance with the above parts, the owner/operator of S-9 shall maintain the following monthly records in a District approved log:
  - a. Natural gas usage in cubic feet.
  - b. Fuel oil hourly usage and consumption in hours and gallons.
  - c. Natural gas heat content information from natural gas supplier (PG&E) in therms/cubic feet.
  - d. Monthly calculated natural gas heat input in MMBTU (Part 11a multiplied by Part 11c divided by 10).
  - e. Consecutive 12-month total of calculated natural gas heat input in MMBTU.
  - f. If fuel oil is fired, natural gas supplier verification of natural gas curtailment or record of fuel oil testing.
  - g. If fuel oil is fired, certification of fuel sulfur content.

These records and natural gas supplier provided data shall be kept for at least 5 years from the date of entry and shall be made available to the District upon request. (basis: Cumulative Increase; Regulation 9-7-504)

12. The owner/operator shall determine compliance with the following NO<sub>x</sub> and CO limits by using a portable analyzer and U.S. EPA Method CTM-030 on an annual basis. The owner/operator shall use the method during natural gas firing. Use of the method during fuel oil firing is not required. Source testing that is performed by the District's Source Test group, if available, may be used to fulfill this requirement. The owner/operator shall submit the NO<sub>x</sub> and CO compliance data to the Director of Enforcement and Compliance within 60 days of using the protocol.
  - a. NO<sub>x</sub> and CO limits in part 7 of this condition
  - b. NO<sub>x</sub> and CO limits in BAAQMD Regulation 9-7-112.  
[BACT, Regulation 9-7-112.2, BAAQMD Regulation 2-6-503]

## VI. Permit Conditions

### Condition # 13344

#### **S10: Papermaking including pulping, separation processes, web production, and drying**

1. The owner/operator shall ensure that the paperboard throughput at S-10 shall not exceed 146,000 tons of paperboard in any consecutive 12-month period. [basis: 2-1-301, 2-1-234.3.1.2]
2. The owner/operator shall ensure that records be maintained in a District approved logbook of the amount of paperboard throughput on a monthly basis. Records shall be maintained for a period of at least five years from the date of entry and made readily available to District staff upon request. [basis: 2-1-301, 2-1-234.3.1.2]

### Condition #14522

#### **Sources S6, S7 - Turbine & Duct Burner**

1. S6, Gas Turbine, and S7, Duct Burner, shall be fired only on natural gas. [basis: BACT]
2. Deleted 6/18/01
3. Deleted 7/2/01
4. The owner/operator shall not operate the turbine unless the steam injection system to control NOx emissions from S6 Turbine is in operation, except during times of start-up and shutdown pursuant to Regulation 9-9-114. The start-up period may be followed by a commissioning period of no more than 4 hours, during which the steam injection system is not required, if one or more of the following activities were conducted during the shutdown:
  - Replacement of more than 1/3 of the duct burners
  - Replacement of steam injection parts
  - Replacement of gas compressor parts
  - Computer control system upgrades
  - Gas turbine fuel nozzle replacementThe commissioning period shall end when the steam injection system is in operation and the turbine is in compliance with Regulation 9-9-305. The turbine shall be operated in low-fire mode during the commissioning period. The steam injection rate shall be controlled by the gas turbine control system at all times during the operation of the steam injection system. [basis: BAAQMD Regulation 9, Rule 9]
5. JSC shall install, calibrate and operate District-approved continuous monitors and recorders for oxides of nitrogen and either oxygen or carbon dioxide as required by District Regulation 10. These monitoring records shall be supplied to the Director of the Compliance and Enforcement Division upon request. [basis: BACT, Regulation 9, Rule 9]

## **VI. Permit Conditions**

6. All natural gas burned at S6, Gas Turbine, and S7, Duct Burner, shall be PUC quality gas. [basis: BAAQMD Regulation 2, Rule 1, Section 403]
7. The owner/operator shall ensure that the heat input to S6, Gas Turbine, does not exceed 2190 therms/hr. [Cumulative Increase, 2-1-305, 2-2-409]
8. The owner/operator shall maintain records of the heat input at S6 and make them available to District staff upon request. Records shall be maintained for a period of at least five years from the date of entry. [2-6-503]
9. The owner/operator shall ensure that the heat input to S7, Duct Burner, does not exceed 1684.8 MMbtu/day (HHV). [Cumulative Increase, 2-1-234, 2-1-305, 2-2-409]
10. The owner/operator shall maintain records of the daily heat input at S7 and make them available to District staff upon request. Records shall be maintained for a period of at least five years from the date of entry. [2-6-503]
11. Within 6 months of issuance of the renewed Major Facility Review permit, the owner/operator shall record fuel usage for S6 and S7 on an hourly basis. The owner/operator shall record S6 and S7 separately. The fuel usage data shall be made available to the District upon request. [basis: 2-6-501, 2-6-503]

## VI. Permit Conditions

### COND# 16714 -----

#### S11 and S13, Cold Cleaners

1. Net usage of methylated siloxane at S11 and S13 shall not exceed 20 gallons per source, in any consecutive 12-month period. (basis: Cumulative Increase)
2. To determine compliance with the above conditions, the Permit Holder shall maintain monthly usage records of methylated siloxane. All records shall be retained on-site for five years, from the date of entry, and made available for inspection by District staff upon request. These requirements shall not replace the recordkeeping requirements contained in any applicable District regulations. (basis: Cumulative Increase)

### Condition #22851

#### S14, Fire Pump Engine

1. Operating for reliability-related activities is limited to no more than 34 hours per year per engine which is the number of hours necessary to comply with the testing requirements of the National Fire Protection Association (NFPA) 25. This emergency fire pump is subject to the current National Fire Protection Association (NFPA) 25 - "Standard for the Inspection, Testing and Maintenance of Water-Based Fire Protection Systems."

[Basis: "Stationary Diesel Engine ATCM" section 93115, title 17, CA Code of Regulations]

2. The owner or operator shall operate each emergency standby engine only for the following purposes: to mitigate emergency conditions, for emission testing to demonstrate compliance with a District, state or Federal emission limit, or for reliability-related activities (maintenance and other testing, but excluding emission testing). Operating while mitigating emergency conditions or while emission testing to show compliance with District, state or Federal emission limits is not limited.

[Basis: "Stationary Diesel Engine ATCM" section 93115, title 17, CA Code of Regulations, subsection (e)(2)(B)(3)]

3. The owner/operator shall operate each emergency standby engine only when a non-resettable totalizing meter (with a minimum display capability of 9,999 hours) that measures the hours of operation for the engine is installed, operated and properly maintained.

[Basis: "Stationary Diesel Engine ATCM" section 93115, title 17, CA Code of Regulations, subsection(e)(4)(G)(1)]

## VI. Permit Conditions

4. Records: The owner/operator shall maintain the following monthly records in a District-approved log for at least 36 months from the date of entry (60 months if the facility has been issued a Title V Major Facility Review Permit or a Synthetic Minor Operating Permit). Log entries shall be retained on-site, either at a central location or at the engine's location, and made immediately available to the District staff upon request.
  - a. Hours of operation for reliability-related activities (maintenance and testing).
  - b. Hours of operation for emission testing to show compliance with emission limits.
  - c. Hours of operation (emergency).
  - d. For each emergency, the nature of the emergency condition.
  - e. Fuel usage for each engine(s).

[Basis: "Stationary Diesel Engine ATCM" section 93115, title 17, CA Code of Regulations, subsection (e)(4)(I), (or, Regulation 2-6-501)]

5. At School and Near-School Operation:  
If the emergency standby engine is located on school grounds or within 500 feet of any school grounds, the following requirements shall apply:  
The owner or operator shall not operate each stationary emergency standby diesel-fueled engine for non-emergency use, including maintenance and testing, during the following periods:
  - a. Whenever there is a school sponsored activity (if the engine is located on school grounds)
  - b. Between 7:30 a.m. and 3:30 p.m. on days when school is in session. "School" or "School Grounds" means any public or private school used for the purposes of the education of more than 12 children in kindergarten or any of grades 1 to 12, inclusive, but does not include any private school in which education is primarily conducted in a private home(s). "School" or "School Grounds" includes any building or structure, playground, athletic field, or other areas of school property but does not include unimproved school property.

[Basis: "Stationary Diesel Engine ATCM" section 93115, title 17, CA Code of Regulations, subsection (e)(2)(A)(1)] or (e)(2)(B)(2)]



## VII. APPLICABLE LIMITS & COMPLIANCE MONITORING REQUIREMENTS

This section has been included only to summarize the applicable emission limits contained in Section IV, Source-Specific Applicable Requirements, of this permit. The following tables show the relationship between each emission limit and the associated compliance monitoring provisions, if any. The monitoring frequency column indicates whether periodic (P) or continuous (C) monitoring is required. For periodic monitoring, the frequency of the monitoring has also been shown, using the following codes: annual (A), quarterly (Q), monthly (M), daily (D), or on an event basis (E). No monitoring (N) has been required if the current applicable rule or regulation does not require monitoring, and the operation is unlikely to deviate from the applicable emission limit based upon the nature of the operation.

This section is only a summary of the limits and monitoring requirements. In the case of a conflict with any requirement in Sections I-VI, the preceding sections take precedence over Section VII.

**Table VII-A  
 Applicable Limits and Compliance Monitoring Requirements  
 S6, Turbine, S7, Duct Burner**

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type
NOx	BAAQMD 9-9-301.1.2 and 9-9-401	N		17.2 ppmv @ 15% O <sub>2</sub> (dry), 3-hour average except during startup, not to exceed 3 hours, and shutdown, not to exceed 1 hour and inspection and maintenance periods as allowed by BAAQMD 9-9-113 and 9-9-115	BAAQMD 9-9-501	C	CEM

## VII. Applicable Limits & Compliance Monitoring Requirements

**Table VII-A**  
**Applicable Limits and Compliance Monitoring Requirements**  
**S6, Turbine, S7, Duct Burner**

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type
NOx	BAAQMD 9-9-301.2	N		15 ppmv or 0.7 lb/MWhr @15% O <sub>2</sub> (dry), 3-hour average except during startup, not to exceed 3 hours, and shutdown, not to exceed 1 hour and inspection and maintenance periods as allowed by BAAQMD 9-9-113 and 9-9-115	BAAQMD 9-9-501	C	CEM
NOx	SIP 9-9-301.2 and 9-9-401	Y		17 ppmv @15% O <sub>2</sub> (dry), 3-hour average except during startup, not to exceed 3 hours, and shutdown, not to exceed 1 hour and inspection and maintenance periods as allowed by BAAQMD 9-9-113	BAAQMD 9-9-501	C	CEM
	40 CFR 60.332(a)(2)	Y		122 ppmv @15% O <sub>2</sub> , dry, 4-hour average except during startup, shutdown, and malfunction	40 CFR 60.334(b);	C	CEM
SO <sub>2</sub>	BAAQMD 9-1-301	N		GLC <sup>1</sup> of 0.5 ppm for 3 min or 0.25 ppm for 60 min or 0.05 ppm for 24 hours		N	
SO <sub>2</sub>	BAAQMD 9-1-302	Y		300 ppm (dry)		N	

## VII. Applicable Limits & Compliance Monitoring Requirements

**Table VII-A**  
**Applicable Limits and Compliance Monitoring Requirements**  
**S6, Turbine, S7, Duct Burner**

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type
SO2	40 CFR 60.333(b)	Y		Fuel sulfur content of 0.8 percent by weight (applies to turbine only)	40 CFR 60.334(h)(3)	N	
Opacity	BAAQMD 6-1-301	N		Ringelmann No. 1 for less than 3 min/hr		N	
Opacity	SIP 6-301	Y		Ringelmann No. 1 for less than 3 min/hr		N	
FP	BAAQMD 6-1-310	N		0.15 grain/dscf	None	N	
FP	SIP 6-310	Y		0.15 grain/dscf	None	N	
FP	BAAQMD 6-1-310.3	N		0.15 grain/dscf @ 6% O2	None	N	
FP	SIP 6-310.3	Y		0.15 grain/dscf @ 6% O2	None	N	
Heat input	BAAQMD Cond #14522, part 7	Y		2190 therms/hr (applies to turbine only)	BAAQMD Cond #14522, part 7	P/H	
Heat input				1684.8 MMbtu/day (HHV) applies to duct burner only)	BAAQMD Cond #14522, part 7	P/D	

## VII. Applicable Limits & Compliance Monitoring Requirements

**Table VII-B**  
**Applicable Limits and Compliance Monitoring Requirements**  
**S9 Standby Boiler**

Type of Limit	Limit of Citation	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type
NOX	9-7-112.2	N		30 ppmv dry @ 3% O <sub>2</sub>	BAAQMD Cond #12231 Part 12	P/A	Portable analyzer
	SIP 9-7-301.1	Y		30 ppmv dry @ 3% O <sub>2</sub> when firing gaseous fuel	BAAQMD Cond #12231 Part 12	P/A	Portable analyzer
	SIP 9-7-302.1	Y		40 ppmv dry @ 3% O <sub>2</sub> when firing non-gaseous fuel		N	
NO <sub>x</sub>	SIP 9-7-305.1	Y		150 ppmv @3%O <sub>2</sub> , dry when firing non-gaseous fuel during natural gas curtailment		N	
	SIP 9-7-306.1	Y		150 ppmv @3%O <sub>2</sub> , dry when firing non-gaseous fuel during testing		N	
	BAAQMD Cond #12231 Part 7	Y		25 ppmv dry @ 3% O <sub>2</sub> during natural gas firing	BAAQMD Cond #12231 Part 12	P/A	Portable analyzer
NOX	BAAQMD Cond #12231 Part 8	Y		60 ppmv dry @ 3% O <sub>2</sub> when firing distillate oil		N	
CO	SIP 9-7-301.2	Y		400 ppmv dry @ 3% O <sub>2</sub> when firing gaseous fuel	BAAQMD Cond #12231 Part 12	P/A	Portable analyzer
CO	SIP 9-7-305.2	Y		400 ppmv @3% O <sub>2</sub> , dry when firing non-gaseous fuel during a natural gas curtailment		N	

## VII. Applicable Limits & Compliance Monitoring Requirements

**Table VII-B**  
**Applicable Limits and Compliance Monitoring Requirements**  
**S9 Standby Boiler**

Type of Limit	Limit of Citation	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type
	SIP 9-7-306.2	Y		400 ppmv @3% O <sub>2</sub> , dry, when testing with non-gaseous fuel		N	
	BAAQMD 9-7-112.2	N		400 ppmv dry @ 3% O <sub>2</sub>	BAAQMD Cond #12231 Part 12	P/A	Portable analyzer
	BAAQMD Cond #12231 Part 7	Y		50 ppmv dry @ 3% O <sub>2</sub> during natural gas firing	BAAQMD Cond #12231 Part 12	P/A	Portable analyzer
SO <sub>2</sub>	BAAQMD 9-1-301	Y		GLC <sup>1</sup> of 0.5 ppm for 3 min or 0.25 ppm for 60 min or 0.05 ppm for 24 hours		N	
	BAAQMD 9-1-302	Y		300 ppm (dry)		N	
SO <sub>2</sub>	BAAQMD 9-1-304	Y		Sulfur content of fuel <0.5% by weight	BAAQMD Cond #12231, Part 11g	P/E	Records of fuel receipts
	BAAQMD Cond #12231 Part 10	Y		Sulfur content of distillate <0.05% by weight	BAAQMD Cond #12231, Part 11g	P/E	Records of fuel receipts
	40 CFR 60.42b(d)	Y		S < 0.5 wt%, 24 hour average when burning oil; limit applies at all times when burning fuel oil	40 CFR 60.46b(d), 60.47b(f), & 60.®(r)	P/E	Records of fuel receipts
Opacity	BAAQMD 6-1-301	N		Ringelmann No. 1 for less than 3 min/hr		N	
Opacity	SIP 6-301	Y		Ringelmann No. 1 for less than 3 min/hr		N	

## VII. Applicable Limits & Compliance Monitoring Requirements

**Table VII-B**  
**Applicable Limits and Compliance Monitoring Requirements**  
**S9 Standby Boiler**

Type of Limit	Limit of Citation	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type
Opacity	BAAQMD 6-1-304	N		Ringelmann No. 2 for less than 3 min/hr during tube cleaning		N	
	SIP 6-1-304	Y		Ringelmann No. 2 for less than 3 min/hr during tube cleaning		N	
	BAAQMD Cond #12231 Part 11	Y		Ringelmann No. 0.5		N	
	40 CFR 60.43b(f)	Y		Opacity < 20%, 6-min average, except for one 6-min period/hr at < 27%; limit does not apply during startup, shutdown or malfunction		N	
FP	BAAQMD 6-1-310.3	N		0.15 grain/dscf @ 6% O2		N	
FP	SIP 6-1-310.3	Y		0.15 grain/dscf @ 6% O2		N	
Annual Heat Input	BAAQMD Cond #12231 Part 2	Y		140,875 MMBTU or less per consecutive twelve-month of operation with natural gas	BAAQMD Cond #12231, Part 11	P/M	records
Hours of operation	BAAQMD Cond #12231 Part 3	Y		100 hours or less per year of operation with distillate oil	BAAQMD Cond #12231, Part 11	P/E	records
Heat input	BAAQMD Cond #12231 Part 10	Y		Heat input less than 161 MMbtu/hr	BAAQMD Cond #12231, Part 11	C	gas meter

## VII. Applicable Limits & Compliance Monitoring Requirements

**Table VII-B  
 Applicable Limits and Compliance Monitoring Requirements  
 S9 Standby Boiler**

Type of Limit	Limit of Citation	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type
Heat input	BAAQMD 9-7-112.2	N		<10% of annual maximum heat capacity per consecutive 12-month period (eq. to 141,197 MMbtu/yr)	BAAQMD 9-7-504	C	Totalizing fuel meter, records
Heat input	40 CFR 60.44b(k)	Y		<10% of annual maximum heat capacity per consecutive 12-month period (eq. to 141,197 MMbtu/yr)	BAAQMD 9-7-504	P/M	fuel

<sup>1</sup> Ground Level Concentration

## VII. Applicable Limits & Compliance Monitoring Requirements

**Table VII-C**  
**Applicable Limits and Compliance Monitoring Requirements**  
**S10, Papermaking including pulping, separation processes, web production, and**  
**drying**

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type
Total Carbon Emissions	BAAQMD 8-2-301	Y		15 pounds/day or 300 ppm, dry basis		N	
Throughput	BAAQMD Cond #13344 Part 1	Y		throughput limit of 146,000 tons of paperboard in any consecutive 12 month period	BAAQMD Cond #13344 Part 2	P/M	Records
SO2	BAAQMD 9-1-301	N		GLC <sup>1</sup> of 0.5 ppm for 3 min or 0.25 ppm for 60 min or 0.05 ppm for 24 hours		N	
	BAAQMD 9-1-302	Y		300 ppm (dry)		N	
Opacity	BAAQMD 6-1-301	N		Ringelmann No. 1 for less than 3 min/hr		N	
	BAAQMD 6-1-310.3	Y		0.15 grain/dscf @ 6% O2		N	



## VII. Applicable Limits & Compliance Monitoring Requirements

**Table VII - D**  
**Applicable Limits and Compliance Monitoring Requirements**  
**S11, S13, COLD CLEANERS**

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type
VOC	BAAQMD Cond# 16714, part 1	Y		Usage < 20 gal/year at each source	BAAQMD Cond# 16714, part 3	P/M	Record-keeping

**Table VII – E**  
**Applicable Limits and Compliance Monitoring Requirements**  
**S14, FIRE PUMP ENGINE**

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type
Opacity	BAAQMD Regulation 6-1-303	N		Ringelmann 2.0 for less than 3 minutes in any hour		N	
	SIP Regulation 6-1-303	N		Ringelmann 2.0 for less than 3 minutes in any hour		N	
FP	BAAQMD Regulation 6-1-310	N		0.15 grain/dscf		N	
	SIP Regulation 6-310	Y		0.15 grain/dscf		N	

**VII. Applicable Limits & Compliance Monitoring Requirements**

**Table VII – E  
 Applicable Limits and Compliance Monitoring Requirements  
 S14, FIRE PUMP ENGINE**

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type
SO2	BAAQMD Regulation 9-1-301	N		ground level concentrations: 0.5 ppm for 3 consecutive minutes, 0.25 ppm averaged over 60 consecutive minutes, 0.05 ppm averaged over 24 hours		N	
SO2	BAAQMD Regulation 9-1-304	Y		0.5% sulfur limit for liquid fuel		N	
Hours of operation	BAAQMD Condition #22851, part 1	N		34 hours/yr for reliability and maintenance	BAAQMD Condition #22851, part 3	C	Non-resettable totalizing meter

**Table VII - F  
 Applicable Limits and Compliance Monitoring Requirements  
 S16, Felt Cleaning (Top Felt)  
 S17, Felt Cleaning (Bottom Felt)  
 S18, Felt Cleaning (1<sup>st</sup> Main Press)  
 S19, Felt Cleaning (2<sup>nd</sup> Main Press)**

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type
VOC	BAAQMD 8-4-302.1	Y		5 tons of VOC during any calendar year (Limit applies to each source)	BAAQMD 8-4-501.1 and 8-4-501.4	P/M	Records

## VII. Applicable Limits & Compliance Monitoring Requirements

**Table VII - G**  
**Applicable Limits and Compliance Monitoring Requirements**  
**S20, Paperboard Sealing (Dry Stack Solution Box)**  
**S21, Paperboard Sealing (Wet Stack Top Solution Box)**  
**S22, Paperboard Sealing (Wet Stack Bottom Solution Box)**  
**S23, Paperboard Coating (#1 Coater)**  
**S24, Paperboard Coating (#2 Coater)**  
**S25, Paperboard Coating (#3 Coater)**

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type
VOC	BAAQMD 8-12-301.1	Y		2.2 lb VOC/gal (applies to coatings)	BAAQMD 8-12-501.1 and 8-12-501.2	P/D	records

## VIII. TEST METHODS

The test methods associated with the emission limit of a District regulation are generally found in Section 600 et seq. of the regulation. The following table indicates only the test methods associated with the emission limits referenced in Section VII, Applicable Emission Limits & Compliance Monitoring Requirements, of this permit.

**Table VIII**

<b>Applicable Requirement</b>	<b>Description of Requirement</b>	<b>Acceptable Test Methods</b>
BAAQMD 6-1-301	Ringelmann No. 1 Limitation	Manual of Procedures, Volume I, Evaluation of Visible Emissions
BAAQMD 6-1-310	Particulate Weight Limitation	Manual of Procedures, Volume IV, ST-15, Particulates Sampling or USEPA Method 5, Determination of Particulate Matter Emissions from Stationary Sources
BAAQMD 6-1-310.3	Particulate Weight Limitation	Manual of Procedures, Volume IV, ST-15, Particulates Sampling or USEPA Method 5, Determination of Particulate Matter Emissions from Stationary Sources
BAAQMD 6-1-311	General Operations	Manual of Procedures, Volume IV, ST-15, Particulates Sampling or USEPA Method 5, Determination of Particulate Matter Emissions from Stationary Sources
BAAQMD 9-1-302	General Emission Limitation	Manual of Procedures, Volume IV, ST-19A, Sulfur Dioxide, Continuous Sampling, or ST-19B, Total Sulfur Oxides Integrated Sample
BAAQMD 9-1-304	Fuel Burning (Liquid and Solid Fuels)	Manual of Procedures, Volume III, Method 10, Determination of Sulfur in Fuel Oils.
BAAQMD 9-7-301.1	Performance Standard, NOx, Gaseous Fuel	Manual of Procedures, Volume IV, ST-13A, Oxides of Nitrogen, Continuous Sampling and ST-14, Oxygen, Continuous Sampling
BAAQMD 9-7-301.2	Performance Standard, CO, Gaseous Fuel	Manual of Procedures, Volume IV, ST-6, Carbon Monoxide, Continuous Sampling and ST-14, Oxygen, Continuous Sampling
BAAQMD 9-7-302.1	Performance Standard, NOx, Non-Gaseous Fuel	Manual of Procedures, Volume IV, ST-13A, Oxides of Nitrogen, Continuous Sampling and ST-14, Oxygen, Continuous Sampling

## VIII Test Methods

**Table VIII**

<b>Applicable Requirement</b>	<b>Description of Requirement</b>	<b>Acceptable Test Methods</b>
BAAQMD 9-7-302.2	Performance Standard, CO, Non-Gaseous Fuel	Manual of Procedures, Volume IV, ST-6, Carbon Monoxide, Continuous Sampling and ST-14, Oxygen, Continuous Sampling
BAAQMD 9-7-305.1	Natural Gas Curtailment Performance Standard, NOx	Manual of Procedures, Volume IV, ST-13A, Oxides of Nitrogen, Continuous Sampling and ST-14, Oxygen, Continuous Sampling
BAAQMD 9-7-305.2	Natural Gas Curtailment Performance Standard, CO	Manual of Procedures, Volume IV, ST-6, Carbon Monoxide, Continuous Sampling and ST-14, Oxygen, Continuous Sampling
BAAQMD 9-7-306.1	Equipment Testing - Non-Gaseous Fuel NOx Performance Standard	Manual of Procedures, Volume IV, ST-13A, Oxides of Nitrogen, Continuous Sampling and ST-14, Oxygen, Continuous Sampling
BAAQMD 9-7-306.2	Equipment Testing - Non-Gaseous Fuel CO Performance Standard	Manual of Procedures, Volume IV, ST-6, Carbon Monoxide, Continuous Sampling and ST-14, Oxygen, Continuous Sampling
BAAQMD 9-9-301.2	Emission Limits, Turbines over 10 mw w/o SCR (9/21/94)	Manual of Procedures, Volume IV, ST-13A, Oxides of Nitrogen, Continuous Sampling and ST-14, Oxygen, Continuous Sampling
<b>NSPS Subpart GG</b>	<b>Standards of Performance for Stationary Gas Turbines (1/27/82)</b>	
60.332 (a)(1)	Performance Standard, NOx	EPA Method 20, Determination of Nitrogen Oxides, Sulfur Dioxide, and Diluent Emissions from Stationary Gas Turbines
60.333 (a)	SO2 Volumetric Emission Limit	EPA Method 20, Determination of Nitrogen Oxides, Sulfur Dioxide, and Diluent Emissions from Stationary Gas Turbines
60.333 (b)	Fuel Sulfur Limit (gaseous fuel)	ASTM D 1072-80, Standard Method for Total Sulfur in Fuel Gases ASTM D 3031-81, Standard Test Method for Total Sulfur in Natural Gas by Hydrogenation ASTM D 4084-82, Standard Method for Analysis of Hydrogen Sulfide in Gaseous Fuels (Lead Acetate Reaction Rate Method), ASTM D 3246-81, Standard Method for Sulfur in Petroleum Gas by Oxidative Microcoulometry
Permit Condition 12231 part 7	NOx Limit	Manual of Procedures, Volume IV, ST-13A, Oxides of Nitrogen, Continuous Sampling and ST-14, Oxygen, Continuous Sampling

## VIII Test Methods

**Table VIII**

<b>Applicable Requirement</b>	<b>Description of Requirement</b>	<b>Acceptable Test Methods</b>
Permit Condition 12231 part 8	NOx Limit	Manual of Procedures, Volume IV, ST-13A, Oxides of Nitrogen, Continuous Sampling and ST-14, Oxygen, Continuous Sampling
Permit Condition 12231 part 9	CO Limit	Manual of Procedures, Volume IV, ST-6, Carbon Monoxide, Continuous Sampling and ST-14, Oxygen, Continuous Sampling
Permit Condition 12231 part 10	SO2 Limit in distillate oil	ASTM D 2880-71, Standard Specification for Gas Turbine Fuel Oils
Permit Condition 12231 part 11	Visible particulate emissions	Manual of Procedures, Volume IV, ST-15, Particulate
<b>NSPS Subpart Db</b>	<b>Standards of Performance for Industrial-Commercial-Institutional Steam Generating Units (12/16/87)</b>	
40 CFR 60.43b(f)	Opacity Standard	EPA Method 9

**IX. PERMIT SHIELD**

A. Non-Applicable Requirements

Pursuant to District Regulations 2-6-233 and 2-6-409.12, the federally enforceable regulations and/or standards cited in the following table[s] are not applicable to the source or group of sources identified at the top of the table[s]. Enforcement actions and litigation may not be initiated against the source or group of sources covered by this shield based on the regulatory and/or statutory provisions cited, as long as the reasons listed below remain valid for the source or group of sources covered by this shield.

**Table IX-A  
 S7, Duct Burner**

Citation	Title or Description NOx from boilers
BAAQMD Regulation 9, Rule 7	Nitrogen Oxides And Carbon Monoxide From Industrial, Institutional, and Commercial Boilers, Steam Generators, and Process Heaters  Waste heat recovery boilers are exempt per 9-7-110.5
NSPS, 40 CFR 60, Subpart D	Standards of Performance for Fossil-Fuel-Fired Steam Generators for Which Construction is Commenced After August 17, 1971  The capacity of S7 is less than 250 MMbtu/hr.
NSPS, 40 CFR 60, Subpart Da	Standards of Performance for Electric Utility Steam Generating Units for Which Construction is Commenced After September 18, 1978  The capacity of S7 is less than 250 MMbtu/hr.
NSPS, 40 CFR 60 Db	Standards of Performance for Industrial-Commercial-Institutional Steam Generating Units  S7 is less than 100 MMbtu/hr.
NSPS, 40 CFR 60 Subpart Dc	Standards of Performance for Small Industrial-Commercial-Institutional Steam Generating Units  S7 was built before 1989.

## IX. Permit Shield

**Table IX-B**  
**S10, Papermaking including pulping, separation processes, web production, drying, and coating**  
**All Recycle Paperboard Plant Sources, Felt Cleaning, Sealing & Coating**

Citation	Title or Description Standards of Performance
NSPS 40 CFR 60	No applicable subpart for recycle paperboard plants

**Table IX-C**  
**Facility Wide**

Citation	Title or Description
BAAQMD Regulation 6-1-302 and 6-1-502	Data, Records and Reporting The APCO has not required the owner/operator to install opacity monitors.
Regulation 8, Rule 5	Storage of Organic Liquids Organic chemicals have a vapor pressure below 25.8 mmHg
NESHAPS, 40 CFR 63	Major source MACT standards Facility is not a major source of hazardous air pollutants
40 CFR 68	Accidental Release Facility does not store large quantities of materials subject to this standard.
40 CFR 82.166(k)	Recordkeeping Regulation not applicable to refrigerant units containing 50 lbs or less refrigerant
Federal Clean Power Plan, 40 CFR 60, Subpart UUUU, Section 60.5850(d)	Federal regulation applies only to states.  Gas turbine and cogeneration plant, which has never sold 219,000 MWh electricity per year, determined by state as not affected unit under state Clean Power Plan.

### B. Subsumed Requirements

None



## **X. REVISION HISTORY**

Initial Issuance (Application 25822):	February 16, 1999
Administrative Amendment (no application): Changes in monitoring report dates	September 28, 2000
Administrative Amendments (no application): Change to the responsible official and title of contact Deletion of Permit Condition 14522, Parts 2 and 3 because the duct burner no longer burns fuel oil. Merger of Permit Condition 14522, Parts 1 and 7 because both of them require use of natural gas. Addition of standard condition I.11 to conform with Manual of Procedures, Volume 2, Part 3, as amended on May 2, 2001. Changes to standard conditions H.2 and H.3 to with Manual of Procedures, Volume 2, Part 3, as amended on May 2, 2001. Updates of District rule and SIP amendments Changes to the permit shield language in Section X.B to conform to Regulation 2, Rule 6, as amended on May 2, 2001 Deletion of out-dated SIP rules	July 6, 2001
Renewal (Application 8095):	September 30, 2011
Renewal (Application 28132):	February 6, 2017

## **XI. GLOSSARY**

**ACT**

Federal Clean Air Act

**APCO**

Air Pollution Control Officer

**API**

American Petroleum Institute

**ARB**

Air Resources Board

**BAAQMD**

Bay Area Air Quality Management District

**BACT**

Best Available Control Technology

**BARCT**

Best Available Retrofit Control Technology

**Basis**

The underlying authority that allows the District to impose requirements.

**C<sub>5</sub>**

An Organic chemical compound with five carbon atoms

**C<sub>6</sub>**

An Organic chemical compound with six carbon atoms

**CAA**

The federal Clean Air Act

**CAAQS**

California Ambient Air Quality Standards

**CAPCOA**

California Air Pollution Control Officers Association

**CEC**

California Energy Commission

**CEM**

Continuous Emission Monitor

**CEQA**

California Environmental Quality Act

## **XI. Glossary**

### **CFR**

The Code of Federal Regulations. 40 CFR contains the implementing regulations for federal environmental statutes such as the Clean Air Act. Parts 50-99 of 40 CFR contain the requirements for air pollution programs.

### **CO**

Carbon Monoxide

### **CO<sub>2</sub>**

Carbon Dioxide

### **COM**

Continuous Opacity Monitor

### **Cumulative Increase**

The sum of permitted emissions from each new or modified source since a specified date pursuant to BAAQMD Rule 2-1-403, Permit Conditions (as amended by the District Board on 7/17/91) and SIP Rule 2-1-403, Permit Conditions (as approved by EPA on 6/23/95). Used to determine whether threshold-based requirements are triggered.

### **District**

The Bay Area Air Quality Management District

### **dscf**

Dry Standard Cubic Feet

### **dscm**

Dry Standard Cubic Meter

### **E 6, E 9, E 12**

Very large or very small number values are commonly expressed in a form called scientific notation, which consists of a decimal part multiplied by 10 raised to some power. For example, 4.53 E 6 equals  $(4.53) \times (10^6) = (4.53) \times (10 \times 10 \times 10 \times 10 \times 10 \times 10) = 4,530,000$ . Scientific notation is used to express large or small numbers without writing out long strings of zeros.

### **EPA**

The federal Environmental Protection Agency.

### **Excluded**

Not subject to any District Regulations.

### **Federally Enforceable, FE**

All limitations and conditions which are enforceable by the Administrator of the EPA including those requirements developed pursuant to 40 CFR Part 51, subpart I (NSR), Part 52.21 (PSD), Part 60, (NSPS), Part 61, (NESHAPs), Part 63 (HAP), and Part 72 (Permits Regulation, Acid Rain), and also including limitations and conditions contained in operating permits issued under an EPA-approved program that has been incorporated into the SIP.

## **XI. Glossary**

### **FP**

Filterable Particulate as measured by BAAQMD Method ST-15, Particulate.

### **FR**

Federal Register

### **grain**

1/7000 of a pound

### **HAP**

Hazardous Air Pollutant. Any pollutant listed pursuant to Section 112(b) of the Act. Also refers to the program mandated by Title I, Section 112, of the Act and implemented by both 40 CFR Part 63, and District Regulation 2, Rule 5.

### **Major Facility**

A facility with potential emissions of: (1) at least 100 tons per year of any regulated air pollutant, (2) at least 10 tons per year of any single hazardous air pollutant, and/or (3) at least 25 tons per year of any combination of hazardous air pollutants, or such lesser quantity of hazardous air pollutants as determined by the EPA administrator.

### **MFR**

Major Facility Review. The District's term for the federal operating permit program mandated by Title V of the Act and implemented by District Regulation 2, Rule 6.

### **MOP**

The District's Manual of Procedures.

### **NAAQS**

National Ambient Air Quality Standards

### **NESHAP**

National Emission Standard for Hazardous Air Pollutants as codified in 40 CFR Parts 61 and 63.

### **NMHC**

Non-methane Hydrocarbons

### **NMOC**

Non-methane Organic Compounds (Same as NMHC)

### **NO<sub>x</sub>**

Oxides of nitrogen.

### **NSPS**

Standards of Performance for New Stationary Sources. Federal standards for emissions from new stationary sources. Mandated by Title I, Section 111 of the Act, and implemented by both 40 CFR Part 60 and District Regulation 10.

## **XI. Glossary**

### **NSR**

New Source Review. A federal program for preconstruction review and permitting of new and modified sources of air pollutants for which the District is classified "non-attainment". Mandated by Title I of the Clean Air Act and implemented by 40 CFR Parts 51 and 52 as well as District Regulation 2, Rule 2. (Note: There are additional NSR requirements mandated by the California Clean Air Act.)

### **O<sub>2</sub>**

The chemical name for naturally-occurring oxygen gas.

### **Offset Requirement**

A New Source Review requirement to provide federally enforceable emission offsets at a specified ratio for the emissions from a new or modified source and any pre-existing cumulative increase minus any onsite contemporaneous emission reduction credits. Applies to emissions of POC, NO<sub>x</sub>, PM<sub>10</sub>, and SO<sub>2</sub>.

### **POC**

Precursor Organic Compounds

### **PM**

Total Particulate Matter

### **PM<sub>10</sub>**

Particulate matter with aerodynamic equivalent diameter of less than or equal to 10 microns

### **PSD**

Prevention of Significant Deterioration. A federal program for permitting new and modified sources of air pollutants for which the District is classified "attainment" of the National Air Ambient Quality Standards. Mandated by Title I of the Act and implemented by both 40 CFR Part 52 and District Regulation 2, Rule 2.

### **SIP**

State Implementation Plan. State and District programs and regulations approved by EPA and developed in order to attain the National Air Ambient Quality Standards. Mandated by Title I of the Act.

### **SO<sub>2</sub>**

Sulfur dioxide

### **SO<sub>3</sub>**

Sulfur trioxide

### **THC**

Total Hydrocarbons (NMHC + Methane)

## **XI. Glossary**

### **therm**

100,000 British Thermal Units

### **Title V**

Title V of the federal Clean Air Act. Requires a federally enforceable operating permit program for major and certain other facilities.

### **TOC**

Total Organic Compounds (NMOC + Methane, Same as THC)

### **TSP**

Total Suspended Particulate

### **TVP**

True Vapor Pressure

### **VMS**

Branched, cyclic, or linear completely methylated siloxane

### **VOC**

Volatile Organic Compounds

### **Units of Measure:**

bhp	=	brake-horsepower
Btu	=	British Thermal Unit
C	=	degrees Celcius
F	=	degrees Fahrenheit
f <sup>3</sup>	=	cubic feet
g	=	gram
gal	=	gallon
GLC	=	ground level concentration
gpm	=	gallons per minute
gr	=	grain
Hr	=	hour
hp	=	horsepower
lb	=	pound
in	=	inches
m <sup>2</sup>	=	square meter
max	=	maximum
min	=	minute
M	=	thousand

## **XI. Glossary**

### **Units of Measure:**

Mg	=	mega-gram, one thousand grams
µg	=	micro-gram, one millionth of a gram
MM	=	million
mm	=	millimeter
MMbtu	=	million btu
mm Hg	=	millimeters of Mercury (pressure)
MW	=	megawatts
O <sub>2</sub>	=	diatomaceous oxygen
ppb	=	parts per billion
ppm	=	parts per million
ppmv	=	parts per million, by volume
ppmw	=	parts per million, by weight
psia	=	pounds per square inch, absolute
psig	=	pounds per square inch, gauge
S	=	sulfur
scfm	=	standard cubic feet per minute
std	=	standard
vol	=	volume
wt	=	weight
yr	=	year

### **Symbols:**

<	=	less than
>	=	greater than
≤	=	less than or equal to
≥	=	greater than or equal to