San Jose-Santa Clara Regional Wastewater Facility

Mr. Wayne Kino Director of Compliance and Enforcement Bay Area Air Quality Management District 375 Beale Street, Suite 600 San Francisco, CA 94105

Re: Title V Semi-Annual Report March 1st, 2018 to August 31st, 2018

San Jose/Santa Clara Regional Wastewater Facility 700 Los Esteros Road, San Jose, CA 95134

Facility No. A0778

Dear Mr. Kino:

This letter and the attached table comprise Title V Semi-annual report for the San Jose-Santa Clara Regional Wastewater Facility (RWF) covering the period from March 1st, 2018 through August 31st, 2018. Except as noted in the report, the RWF was in compliance with all applicable requirements during the reporting period.

A summary of compliance provisions is included in the attached table. The basis for the compliance determination is listed in the Results column. The monitoring data, source test reports, and records that validate the complete compliance record are available for inspection on site.

If there are any questions, or if additional information is required, please contact Jason Nettleton, Air Compliance Manager, at (408) 635-4036.

Based on information and belief formed after reasonable inquiry, I certify that the information presented in this Semi-Annual Report is true, accurate, and complete.

Sincerely,

Amit Mutsuddy Deputy Director

Al Mutsud

Regional Wastewater Facility

Enclosures:

1. Semi-Annual Report Table

annual (A), quarterly (Q), monthly (M), weekly (W), daily (D), or on an event basis (E), 8760 hrs of operation (8760 hrs) Table VII— A

**Applicable Limits and Compliance Monitoring Requirements** 

S-5, Stationary Internal Combustion Engine, Plt E2, Location P&E

S-7, Stationary Internal Combustion Engine, Plt E5, Location P&E

\*Note: E2 (S-5) Decommissioned on 2/23/2017; E5 (S-7) Decommissioned on 2/25/2017.

annual (A), quarterly (Q), monthly (M), weekly (W), daily (D), or on an event basis (E), 8760 hrs of operation (8760 hrs)

Table VII— B

**Applicable Limits and Compliance Monitoring Requirements** 

- S-9, Stationary Internal Combustion Engine, Plt A3, Location SBC
- S-10, Stationary Internal Combustion Engine, Plt A2, Location SBC
- S-11, Stationary Internal Combustion Engine, Plt A1, Location SBC
- S-12, Stationary Internal Combustion Engine, Plt B1, Location SBC
- S-13, Stationary Internal Combustion Engine, Plt B2, Location SBC
- S-14, Stationary Internal Combustion Engine, Plt B3, Location SBC

Type of Limit	Citation for Limit	FE Y/N	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)			RESU	JLTS		
NO <sub>x</sub>	BAAQMD Regulation 9-8-302.1	Y	70 ppmv @ 15% O <sub>2</sub> , dry (waste gas combustion)	BAAQMD Condition 17899, Part 9.b	P/ 8760 hrs	S-9 S-10 S-11 S-12 S-13 S-14	Date: 3/22/17 Date: 4/18/17 Date: 6/21/18 Date: 9/29/15 Date: 5/31/17 Date: 3/22/17	Result: Result: Result: Result: Result: Result:	26.3 ppm 18.1 ppm 19.0 ppm 54.0 ppm 19.7 ppm 18.5 ppm	Hours: Hours: Hours: Hours: Hours:	4258 4977 25 3089 3799 4382
NO <sub>x</sub>	BAAQMD Regulation 9-8-302.1	N	70 ppmv @ 15% O₂, dry (waste gas combustion)	BAAQMD Regulation 9-8-503	Quarterly portable analyzer	S-9 S-10 S-11 S-12 S-13 S-14	Date: 5/15/18  Date: 5/14/18  Date: 5/11/18  Date: 5/16/18  Date: 5/11/18  Date: 5/15/18	Result: Result: Result: Result: Result: Result:	38 ppm 49 ppm 38 ppm 42 ppm 35 ppm 55 ppm		
со	BAAQMD Condition 17899, Part 3	Y	1620 ppmv @ 15% O₂, dry (waste gas combustion)	BAAQMD Condition 17899, Part 9.b	P/ 8760 hrs	S-9 S-10 S-11 S-12 S-13 S-14	Date: 3/22/17 Date: 4/18/17 Date: 6/21/18 Date: 9/29/15 Date: 5/31/17 Date: 3/22/17	Result: Result: Result: Result:	54.0 ppm	Hours: Hours: Hours: Hours: Hours:	4258 4977 25 3089 3799 4382
со	BAAQMD Regulation 9-8-302.3	N	2000 ppmv @ 15% O <sub>2</sub> , dry (waste gas combustion)	BAAQMD Regulation 9-8-503	Quarterly portable analyzer	S-9 S-10 S-11 S-12 S-13 S-14	Date: 5/15/18 Date: 5/14/18 Date: 5/11/18 Date: 5/16/18 Date: 5/11/18 Date: 5/15/18	Result: Result: Result: Result: Result:	328 ppm 247 ppm 295 ppm 276 ppm 353 ppm 267 ppm	<del></del>	
мнс	BAAQMD Condition 17899, Part 4	Υ	225 ppmv for Digester gas @ 15% O₂, dry 108 ppm for Landfill gas @ 3% O2 dry	BAAQMD Condition 17899, Part 9.b&c	P/ 8760 hrs	S-9 S-10 S-11 S-12 S-13 S-14	Date: 3/22/17 Date: 4/18/17 Date: 6/21/18 Date: 9/29/15 Date: 5/31/17 Date: 3/22/17	Result: Result: Result: Result: Result: Result:	54.1 ppm 51.9 ppm 67.5 ppm 64.0 ppm 23.0 ppm 67.6 ppm	Hours: Hours: Hours: Hours: Hours:	4258 4977 25 3089 3799 4382
SO <sub>2</sub>	BAAQMD Regulation 9-1-302	Υ	300 ppmv outlet SO <sub>2</sub> 350 ppmv TRS digester gas	BAAQMD Condition 17741, Part 4	P/W	S210	Date: 8/19/18	Result:	289 ppm		
Key Parameter	BAAQMD Regulation 8-34-509	Ŷ	Cylinder Temperature >600 degrees F	BAAQMD Condition 17898, Part 8a	Continuous	S-9 S-10 S-11 S-12 S-13 S-14	Temp.: Temp.: Temp.: Temp.:	>600F >600F >600F >600F >600F >600F			
Gas Flow	BAAQMD Regulation 8-34-508	Y	Record Every 5 Minutes	BAAQMD Condition 17898, Part 7a	P/15 minutes	S-9 S-10 S-11 S-12 S-13 S-14	Recorded every 5 Recorded every 5 Recorded every 5 Recorded every 5 Recorded every 5 Recorded every 5	minutes minutes minutes minutes	; ; ;		:

annual (A), quarterly (Q), monthly (M), weekly (W), daily (D), or on an event basis (E), 8760 hrs of operation (8760 hrs) Table VII—B (cont.)

Applicable Limits and Compliance Monitoring Requirements

S-9, Stationary Internal Combustion Engine, Plt A3, Location SBC

S-10, Stationary Internal Combustion Engine, Plt A2, Location SBC

S-11, Stationary Internal Combustion Engine, Plt A1, Location SBC

S-12, Stationary Internal Combustion Engine, Plt B1, Location SBC S-13, Stationary Internal Combustion Engine, Plt B2, Location SBC

S-14, Stationary Internal Combustion Engine, Plt B3, Location SBC

Type of	Citation for Limit	FE Y/N	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)			RESULTS	
Heat Input	BAAQMD Condition 17899	Y	Not to exceed S9: 525.4 MM Btu/per day S10: 525.4 MM Btu/per day	BAAQMD Condition 17899,	P/M	S-9 S-10 S-11	Date: 3/19/18 Date: 3/25/18 Date: 4/16/18	Result: 504.3 MM Btu/day Result: 415.9 MM Btu/day Result: 421.2 MM Btu/day	(Max.) (Max.) (Max.)
	Part 5		\$11: 525.4 MM Btu/per day \$12: 415.5 MM Btu/per day \$13: 415.5 MM Btu/per day \$14: 415.5 MM Btu/per day	Part 5		S-12 S-13 S-14	Date: 8/31/18 Date: 3/4/18 Date: 3/18/18	Result: 266.1 MM Btu/day Result: 284.2 MM Btu/day Result: 325.3 MM Btu/day	(Max.) (Max.) (Max.)

### Table VII-C

**Applicable Limits and Compliance Monitoring Requirements** 

S-15, Paint Spray Booth

S-16, Paint Spray Booth

Type of Limit	Citation for Limit	FE Y/N	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	RESULTS		
Coating	BAAQMD	Y	Coatings	BAAQMD	P/D	S15<50 gals of coatings used in the last		
-	Condition	ľ	50 gal/12 months	Condition		12 months S-16<50 gals of coatings used in the last	Result:	0 Gal.
	Part 1			Part 3		12 months	Result:	7 Gal.
Primer Throughput	BAAQMD Condition 17737	Y	Primer 50 gal/12 months	BAAQMD Condition	P/D	S15<50 gals of primer used in the last 12 months: S16<50 gals of primer used in the last 12	Result:	0 Gal.
	Part 1			Part 3		months	Result:	4 Gal.
Solvent Throughput	BAAQMD Condition 17737 Part 2	Y	Methyl Ethyl Ketone 50 gal/12 months Mineral Spirits 50 gal/12 months	BAAQMD Condition 17737 Part 3	P/D	S15<50 gals of each solvent used in the last 12 months S16<50 gals of each solvent used in the last 12 months	Result:	32 Gal. 39 Gal.
voc	BAAQMD Regulation 8-19-301.1	Y	Baked Coating 2.3 lb/gal max VOC	BAAQMD Regulation 8-19-501	P/W	No baked coatings used.		
voc	BAAQMD Regulation 8-19-301.1	Y	Air Dried Coating 2.8 lb/gal max VOC	BAAQMD Regulation 8-19-501	P/W	VOC content of each coating used is less Shop has MSDS)	than 2.8 lb/g	al. (Paint

annual (A), quarterly (Q), monthly (M), weekly (W), daily (D), or on an event basis (E), 8760 hrs of operation (8760 hrs) Table VII--- D

Applicable Limits and Compliance Monitoring Requirements S-26, Gasoline Dispensing Island

Type of Limit	Citation for Limit	FE Y/N	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	RESULTS			
	BAAQMD Condition 17738 Part 1	N	50,000 gallons	BAAQMD Condition 17738, Part 2	P/D	S26	Date: 9/6/17 - 9/4/18	Volume: 13,695 Gal.	
Fugutive Emissions	BAAQMD Condition 24298 Part 3		< 3 drops/minute - liquids < 100 % of LEL - vapor	BAAQMD Condition 24298 Part 4	P/A	S26	Date: 8/3/18 Result:	Pass	
Dispensing Rates	BAAQMD Condition 24298 Part 7		Dispensing rate between 6 and 10 gpm	BAAQMD Condition 24298 Part 4	P/A	S26	Date: 8/3/18 Result:	Pass	

annual (A), quarterly (Q), monthly (M), weekly (W), daily (D), or on an event basis (E), 8760 hrs of operation (8760 hrs) Table VII— E

**Applicable Limits and Compliance Monitoring Requirements** 

S-36, Engine Generator 1 - Cogen Unit, Plt EG2 S-37, Engine Generator 2 - Cogen Unit, Plt EG3

Type of Limit	Citation for Limit	FE Y/N	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)			RESU	LTS		
NO <sub>x</sub>	BAAQMD Regulation	Y	70 ppmv @ 15% O <sub>2</sub> , dry	BAAQMD Condition	P/ 8760 hrs	S36	Date: 9/13/17	Result:	23.7 ppm	Hours:	405
	9-8-302.1		(waste gas combustion)	17900, Part 10	:	\$37	Date: 9/14/17	Result:	28.8 ppm	Hours:	7261
NO <sub>x</sub>	BAAQMD	N	70 ppmv	BAAQMD	Quarterly	S36	Date: 2/12/18	Result:	30.0 ppm		
	Regulation 9-8-302.1		@ 15% O₂, dry (waste gas combustion)	Regulation 9-8-503	portable analyzer	S37	Date: 5/11/18	Result:	61.5 ppm		
						Note: S	36 (EG2) has bee	en out of s	ervice for this las	t semeste.	r.
NO <sub>x</sub>	BAAQMD Condition 17900 Part 2	Y	1.6 gram/bhp-hr	BAAQMD Condition 17900 Part 10.b	P/ 8760 hrs	S36 S37	Date: 9/13/17 Date: 9/14/17	Result:	0.40 g/bhp-hr 0.49 g/bhp-hr		405 7261
NO <sub>x</sub>	BAAQMD Condition 17900 Part 16	Y	774 lb/24 hours combined emissions from S-36, S-37, S-38 and S-39	BAAQMD Condition 17900 Part 18	P/M	Result:	84.2 lb/day on	max. day	during compliand	e period	
со	BAAQMD Regulation	Y	2000 ppmv @ 15% O <sub>2</sub> , dry	BAAQMD Condition	P/ 8760 hrs	S36	Date: 9/13/17	Result:	221.4 ppm	Hours:	405
	9-8-302.3		(waste gas combustion)	17900, Part 10		S37	Date: 9/14/17	Result:	259.9 ppm	Hours:	7261
со	BAAQMD Regulation	N	2000 ppmv @ 15% O <sub>2</sub> , dry	BAAQMD Regulation	Quarterly portable	S36	Date: 2/12/18	Result:	592.0 ppm		
	9-8-302.3		(waste gas combustion)	9-8-503	analyzer	S37	Date: 5/11/18	Result:	217.5 ppm		
со	BAAQMD Condition	Y	546 lb/24 hr period/engine	BAAQMD Condition	P/ 8760 hrs	S36	Date: 9/13/17		399.5 lb/day	Hours:	405
	17900 Part 3			17900 Part 10.b		S37	Date: 9/14/17	Result:	476.2 lb/day	Hours:	7261
SO₂	BAAQMD Regulation 9-1-302	Y	300 ppmv outlet SO <sub>2</sub> 350 ppmv TRS digester gas	BAAQMD Condition 17741, Part 4	P/W	S210	Date: 8/19/18	Result:	289 ppm		
SO <sub>2</sub>	BAAQMD Condition 17900 Part 17	Y	150 lb/24 hours combined emissions from S-36, S-37, S-38 and S-39	BAAQMD Condition 17900 Part 18	P/M	Result:	21.9 lb/day on	max. day	during compliand	e period	
FP	BAAQMD Condition,	Y	36.4 lb/24 hr period	BAAQMD Condition	P/ 8760 hrs	S36	Date: 9/13/17	Result:	4.2 lb/day	Hours:	405
	17900 Part 4			17900 Part 10.b		S37	Date: 9/14/17	Result:	2.8 lb/day	Hours:	7261
NMHC	BAAQMD Condition	Y	87.8 lb/24 hr period	BAAQMD Condition	P/ 8760 hrs	S36	Date: 9/13/17	Result:	6.7 lb/day	Hours:	405
	17900 part 5a			17900 Part 10.c		S37	Date: 9/14/17	Result:	27.6 lb/day	Hours:	7261
NMHC	BAAQMD Condition	Υ-	108 ppm for Landfill gas @ 3% O₂ dry	BAAQMD Condition	P/ 8760 hrs	S36	Date:	Result:	•	Hours:	
	17900 Part 5b.			17900 Part 10.c	!	S37	Date:	Result:		Hours:	
		<u> </u>				Note: L	andfill gas was no	ot combust	ed during the rep	orting per	iod.

annual (A), quarterly (Q), monthly (M), weekly (W), daily (D), or on an event basis (E), 8760 hrs of operation (8760 hrs)

### Table VII- E (cont.)

Applicable Limits and Compliance Monitoring Requirements S-36, Engine Generator 1 - Cogen Unit, Plt EG2

S-37, Engine Generator 2 - Cogen Unit, Plt EG3

Type of Limit	Citation for Limit	FE Y/N	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)			RESUL	_TS	
Heat	BAAQMD	Y	Not to exceed	BAAQMD	P/M	S36	Date: 8/31/18	Result:	164 MMBtu/day	(Max.)
Input	Condition 17900 Part 6		S36: 792 MM Btu/per day S37: 792 MM Btu/per day	Condition 17900 Part 18		S37	Date: 4/3/18	Result:	674 MMBtu/day	(Max.)
Key Parameter	BAAQMD Regulation 8-34-509	Υ	Cylinder Temperature >600 degrees F	BAAQMD Condition 17900 Part 9a	Continuous	S36 S37 Note:	Temp.	: >600F : >600F t combusté	ed during the reporting	ı period
Gas Flow	BAAQMD Regulation 8-34-508	Y	Record Every 5 Minutes	BAAQMD Condition 17900 Part 8a	P/15 minutes	\$36 \$37	Recorded every s			

# Table VII— F Applicable Limits and Compliance Monitoring Requirements S-38, Commercial Boiler, 12.5 MM BTU/hr S-39, Commercial Boiler, 12.5 MM BTU/hr

Type of Limit	Citation for Limit	FE Y/N	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)			RESUL	_TS		
NO <sub>x</sub>	BAAQMD Regulation	Y	15 ppmv, dry @ 3% O <sub>2</sub>	BAAQMD Condition	P/A	S38	Date: 1/3/18	Result:	7.0 ppm	Hours:	1975
	9-7-307.3			17900 Part 19 & 20		S39	Date: 1/3/18	Result:	5.7 ppm	Hours:	2782
NO <sub>x</sub>	BAAQMD Condition 17900 Part16	Y	774lbs/24hr combined emissions from S-36-37-38,and 39	BAAQMD Condition 17900 Part 18	P/M	Result:	84.2 lb/day o	n max. day o	during compliar	nce period	
со	BAAQMD Regulation 9-7-301.3	Y	400 ppmv, dry @ 3% O₂	BAAQMD Condition 17900,	P/A	S38 S39	Date; 1/3/18 Date: 1/3/18	Result:	ppm	Hours:	1975 2782
SO₂	BAAQMD	Y	300 ppmv outlet SO <sub>2</sub>	Part 19 BAAQMD	P/W	S210	Date: 8/19/18	Result:	289 ppm		
-	Regulation 9-1-302		350 ppmv TRS digester gas	Condition 17741, Part 4							
SO <sub>2</sub>	BAAQMD Condition 17900, Part 17	Υ	150lb/24 hr combined emissions from S-36-37-38, and 39	BAAQMD Condition 17900 Part 18	P/M	Result:	21.9 lb/day o	n max. day o	during compliar	nce period	
Heat Input	BAAQMD Condition 17900, Part 15	Y	Not to exceed S38: 12.5 MM Btu/hr S39: 12.5 MM Btu/hr	BAAQMD Condition 17900 Part 18	P/M	S38 S39	Date: 3/7/18 Date: 3/10/18	Result:	11.7 MMBtu/		(Max.)

annual (A), quarterly (Q), monthly (M), weekly (W), daily (D), or on an event basis (E), 8760 hrs of operation (8760 hrs)

### Table VII— G

Applicable Limits and Compliance Monitoring Requirements S-52, Sand Blast Operations

Type of	Citation	FE			Monitoring Frequency			RESULTS	
Limit	for Limit	Y/N	Limit	Citation	(P/C/N)	]			
	BAAQMD Condition 9055 Part 1	Y		BAAQMD Condition 9055 Part 2	P/M	S-52	Date: 8/31/18	Result:	23 tons/yr

### Table VII--- H

**Applicable Limits and Compliance Monitoring Requirements** 

S-54, Engine Generator, 12 - Cylinder Turbocharged LSVB, Plt EG1

Type of Limit	Citation for Limit	FE Y/N	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)			RESU	LTS		
NO <sub>x</sub>	BAAQMD Regulation 9-8-302.1	Y	70 ppmv @ 15% O <sub>2</sub> , dry (waste gas combustion)	BAAQMD Condition 17901 Part 14.b	P/ 8760 hrs	S54	Date: 5/31/17	Result:	48.4 ppm	Hours:	6326
NO <sub>x</sub>	BAAQMD Regulation 9-8-302.1	N	70 ppmv @ 15% O <sub>2</sub> , dry (waste gas combustion)	BAAQMD Regulation 9-8-503	Quarterly portable analyzer	S54	Date: 5/24/18	Result:	48 ppm		
NO <sub>x</sub>	BAAQMD Condition 17901 Part 5	Y	0.9 gram/bhp-hr	BAAQMD Condition 17901 Part 14.b	P/ 8760 hrs	S54	Date: 5/31/17	Result:	0.88 g/bhp-hr	Hours:	6326
NO <sub>x</sub>	BAAQMD Condition 17901 Part 9	Y	36.2 tons/yr	BAAQMD Condition 17901 Part 15	P/D & P/M	S54	Date: 8/31/18	Result:	16.1 tons/yr		
со	BAAQMD Regulation 9-8-302.3	Y	2000 ppmv @ 15% O <sub>2</sub> , dry (waste gas combustion)	BAAQMD Condition 17900, Part 14	P/ 8760 hrs	S54	Date: 5/31/17	Result:	250.2 ppm	Hours:	6326
со	BAAQMD Regulation 9-8-302.3	N	2000 ppmv @ 15% O <sub>2</sub> , dry (waste gas combustion)	BAAQMD Regulation 9-8-503	Quarterly portable analyzer	S54 ,	Date: 5/24/18	Result:	293 ppm		
со	BAAQMD Condition 17901, Part 6	Y	2.97 grams/bhp-hr	BAAQMD Condition 17900 Part 14.b	P/ 8760 hrs	S54	Date: 5/31/17	Result:	2.53 g/bhp-hr	Hours:	6326
со	BAAQMD Condition 17901 Part 9	Y	119.4 tons/yr	BAAQMD Condition 17901 Part 15	P/D & P/M	S54	Date: 8/31/18	Result:	53.6 tons/yr	•	
NMHC	BAAQMD Condition 17901 Part 7a	Y	0.72 grams/bhp-hr	BAAQMD Condition 17901 Part 14c	P/ 8760 hrs	S54	Date: 5/31/17	Result:	0.06 g/bhp-hr		
NMHC	BAAQMD Condition 17901 Part 7b.	Y	108 ppm for Landfill gas @ 3% O2 dry	BAAQMD Condition 17901 Part 14c	P/ 8760 hrs	S54	Date: Landfill gas was no	Result:	ied during the rep	orting per	iod

annual (A), quarterly (Q), monthly (M), weekly (W), daily (D), or on an event basis (E), 8760 hrs of operation (8760 hrs) Table VII— H (cont.)

**Applicable Limits and Compliance Monitoring Requirements** 

S-54, Engine Generator, 12 - Cylinder Turbocharged LSVB, Plt EG1

NMHC	BAAQMD Condition 17901 Part 9	Y	28.9 tons/yr	BAAQMD Condition 17901 Part 15	P/D & P/M	S54 Date: 8/31/18 Result: 5.0 tons/yr
Heat Input	BAAQMD Condition 17901 Part 2	Y	Not to exceed S54: 763 MM Btu/per day	BAAQMD Condition 17901 Part 15	P/M	S54 Date: 3/10/18 Result: 616 MMBtu/day (Max.)
Key Parameter	BAAQMD Regulation 8-34-509	Y	Cylinder Temperature >600 degrees F	BAAQMD Condition 17901 Part 13a	Continuous	S54 Date: Result:  Note: Landfill gas was not combusted during the reporting period
Type of Limit	Citation for Limit	FE Y/N	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	RESULTS
Gas Flow	BAAQMD Regulation 8-34-508	Y	Record Every 5 Minutes	BAAQMD Condition 17901 Part 12a	P/15 minutes	S54 Recorded every 5 minutes
SO₂	BAAQMD Regulation 9-1-302	Y	300 ppmv outlet SO <sub>2</sub> 350 ppmv TRS digester gas	BAAQMD Condition 17741, Part 4	P/W	S210 Date: 8/19/18 Result: 289 ppm
SO <sub>2</sub>	BAAQMD Condition 17901 Part 9	Υ	7.2 tons/yr	BAAQMD Condition 17901 Part 15	P/D & P/M	S54 Date: 8/31/18 Result: 1.0 tons/yr
Diesel Sulfur Content	BAAQMD condition 17901 Part 4	Y	0.0015% by weight	BAAQMD Condition 17901 Part 4	P/E	CARB dyed 15ppm sulfur verified on delivery receipt
Heat Input	BAAQMD Regulation 9-8-306	N	Use of deisel for less than 5% of fuel input	BAAQMD Regulation 9-8-502.2	P/M	Result: Diesel fuel average 1.6% of heat input for compliance period
Heat Input	40 CFR 63.6675	Υ	Use of diesel for less than 2% of fuel input (to be considered spark ignition)	BAAQMD Regulation 9-8-502.2	P/M	Result: Diesel fuel average 1.6% of heat input for compliance period
Heat Input	BAAQMD Condition 17901, Part 1	Y	27,000 gal/yr diesel fuel	BAAQMD Condition 17901, Part 15	P/M	S54 Date: 8/31/18 Result: 14.5 thous. gal/yr
FP	BAAQMD Condition 17901 Part 8	Υ	0.068 grams/bhp-hr	BAAQMD Condition 17901, Part 14.b	P/A	S54 Date: 5/31/17 Result: 0.018 g/bhp-hr  Note:
FP	BAAQMD Condition 17901 Part 9	Y	3.1 tons/yr	BAAQMD Condition 17901, Part 15	P/D & P/M	S54 Date: 8/31/18 Result: 0.5 tons/yr

## SAN JOSE/SANTA CLARA WATER POLLUTION CONTROL PLANT SAN JOSE CA BAAOMD PERMIT #778

SEMI-ANNUAL MONITORING REPORT

**REPORTING PERIOD: 3/1/2018 - 8/31/2018** 

annual (A), quarterly (Q), monthly (M), weekly (W), daily (D), or on an event basis (E), 8760 hrs of operation (8760 hrs)

### Table VII— I

**Applicable Limits and Compliance Monitoring Requirements** 

S-55, IC Engine Bldg 40 500 KW

Power and Air

S-56, IC Engine Bldg CL 250 KW

Power and Air

S-57, 1C Engine P&E, 500 KW

Power and Air

Type of Limit	Citation for Limit	FE Y/N	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)		RESULTS		
Reliability- Related	BAAQMD Condition	N	20 hrs/yr	BAAQMD Condition	P/M	S55 S56	Date: 1/1/18 - 8/31/2018 Date: 1/1/18 - 8/31/2018	Result: Result:	0.0 hrs-yr 2.3 hrs-yr
Hours	22820 Part 1			22820 Parts 3 & 4		S57	Date: 1/1/18 - 8/31/2018 S57 went out of service starting of	Result: In January 2011	0.0 hrs-yr 7: S55 went
							service starting March 2017.		,, 626

### Table VII— J

**Applicable Limits and Compliance Monitoring Requirements** 

S-66, S-222, S-223, S-224, S-225 - Emergency IC Generators, Diesel

				Monitoring	Monitoring	[			
Type of	Citation	FE	į	Requirement	Frequency		RESULTS		
Limit	for Limit	Y/N	Limit	Citation	(P/C/N)				
Reliability-	BAAQMD	N	50 hrs/yr	BAAQMD	P/M	S66	Date: 1/1/18 - 8/31/2018	Result:	1.7 hrs-yr
Related	Condition	•	1	Condition		S222	Date: 1/1/18 - 8/31/2018	Result:	10.3 hrs-yr
Hours	22850			22850		S223	Date: 1/1/18 - 8/31/2018	Result:	8.7 hrs-yr
	Part 1			Parts 3 & 4		S224	Date: 1/1/18 - 8/31/2018	Result:	9.1 hrs-yr
	1			1		\$225	Date: 1/1/18 - 8/31/2018	Result:	13.6 hrs-yr
Į.	1				ł	l			

### Table VII-- K

**Applicable Limits and Compliance Monitoring Requirements** 

S-100, Municipal wastewater Treatment Plant

				Monitoring	Monitoring				
Type of	Citation	FE.		Requirement	Frequency			RESULTS	
Limit	for Limit	Y/N	Limit	Citation	(P/C/N)		•		
Wastewater	BAAQMD	Υ	167 MGD design	BAAQMD	P/W	S100	Date: 3/22/18	Max Flow:	124 MGD
Throughput	Condition	l	360 MGD peak wet	Condition					
	17740	-		17740		Note:			
	Part 1	l	i	Part 2					

### Table VII— L

Applicable Limits and Compliance Monitoring Requirements

S-210, Anaerobic Digesters

Type of Limit	Citation for Limit	FE Y/N	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	RESULTS				
Flare Throuphput	BAAQMD Condition 17741, Part 2.a.ii.3		74,200 Mscf/12-months	BAAQMD Condition 17741, Parts 6 & 20	P/M	A405 A406	Date: 8/31/18		Result:	13,083 kscf
Digester Gas Sulfur Content	BAAQMD Condition 17741, Part 3a	Y	350 ppm	BAAQMD Condition 17741 Part 5	P/W	S210	Date: 8/19/18	Result:	289 ppm	
SO <sub>2</sub>	BAAQMD Condition 17741, Part 4		12.722 tons/year SO <sub>2</sub> 742,000 mscf production	BAAQMD Condition 17741 Part 5	P/M	S-210  Note: n	Date: oot applicable until	Result:	up of thermophili	c digester

	Express
1	Package US Airbil

City Say, France, 5000 State C.A. 21P 94105 0120331705	A Year of A. Que 1:44 M	2 Your Internal Billing Reference Recipient's T. + (e)	CITY OF SAN JOSE WATER 700 LOS ESTEROS RD	Express US Airbill Tracking BUB5 3C1 / B160  1 From Date 9/2/18 Sender's Jasca North Club Phone
Third Party Credit Card No. bolow.  Sendor Sendor Recipient Third Party Credit Card Card Card Card Card Card Card Card	Indirect Signature in one a system at replace and response a septiment and response as engineering address may generate delivery For rescensive delivery For Response CB	FedEx Envelope*  FedEx Pak*  FedEx  Other  SATURDAY Delivery	between Friday estimaters with be askered on Monday unless SATURDAY between it selected.  FedEx Priority Overnight Next business morning, "Friday shipments will be dehvered on Monday unless SATURDAY Delivery is selected.  FedEx Standard Overnight Next business afternoon." Saturday Delivery NOT available.	4 Express Package Service • To most locations.  A DITE Service order has changed. Please select carefully.  Packages up to 150 lbs.  For packages up to 150 lbs.

# Peel-and-Stick FedEx Express Package US Airbili

- 1. Complete front page of the Airbill,
- 2. Retain "Sender's Copy" for your records.
  - 3. Remove label backing.
- 4. Adhere Airbill to front of package.

Please DO NOT remove "FedEx Copy."