

REDWOOD LANDFILL, INC.

P.O. Box 793 8950 Redwood Highway Novato, CA 94948 (415) 892-2851 (415) 898-1354 Fax

May 28, 2020

Director of Compliance and Enforcement Bay Area Air Quality Management District 375 Beale Street, Suite 600 San Francisco, CA 94105 Attn: Title V Reports compliance@baagmd.gov Director of the Air Division USEPA, Region IX 75 Hawthorne Street San Francisco, CA 94105 Attn: Air-3 r9.aeo@epa.gov

SUBJECT: Combined Title V Semi-Annual and Partial 8-34 Annual Report 40 CFR 63

Subpart AAAA Semi-Annual Report

Redwood Landfill, Inc.

8950 Redwood Highway, Novato, CA 94948

Facility Number A1179

#### Dear Sir or Madam:

The Redwood Landfill, Inc. (RLI) is submitting this Combined Title V Semi-Annual and Partial 8-34 Annual Report for the period of November 1, 2019 to April 30, 2020, to the Bay Area Air Quality Management District (BAAQMD) and the United States Environmental Protection Agency (USEPA), Region IX. The Semi-Annual Startup, Shutdown and Malfunction (SSM) Report is also enclosed, as required by 40 Code of Federal Regulations (CFR) Part 63 Subpart AAAA. The Combined Title V Semi-Annual and Partial 8-34 Annual Report satisfies the requirements of the Title V Permit listed in Condition Number 19867 Part 32 and Standard Condition I.F.

Based on information and belief formed after reasonable inquiry, I certify under penalty of law that the statements included in this report are true, accurate, and complete.

Sincerely,

Redwood Landfill, Inc.

Ramin Khany District Manager

Attachments:

Combined Title V Semi-Annual and Partial 8-34 Annual Report

Ramin S. 16 hany

# Combined Title V Semi-Annual and Partial 8-34 Annual Report

For the Redwood Landfill 8950 Redwood Highway Novato, California 94948 Facility Number A1179

November 1, 2019 to April 30, 2020

Prepared for Redwood Landfill, Inc. 8950 Redwood Highway Novato, CA

For Submittal to:
The Bay Area Air Quality Management District
375 Beale Street, Suite 600
San Francisco, CA 94105

The United States Environmental Protection Agency
Region IX
75 Hawthorne Street
San Francisco, CA 94105

Prepared by: Redwood Landfill, Inc. 8950 Redwood Highway Novato, CA

# **CONTENTS**

1	INTRODUCTION	1
	1.1 Purpose 1.2 Record Keeping and Reporting	1 1
2	SEMI-ANNUAL MONITORING REPORT	2
	2.1 Collection System Operation [BAAQMD 8-34-501.1& §60.757(f)(4)]	3
	2.2 Emission Control Device Downtime [BAAQMD 8-34-501.2 & §60.757(f)(3)	)] 4
	2.3 Temperature Monitoring Results [(BAAQMD 8-34-501.3, 8-34-507, & §60.757(f)(1)]	5
	2.4 Monthly Cover Integrity Monitoring [BAAQMD 8-34-501.3, 8-34-507, &	5
	§60.757(f)(1)]	6
	2.5 Less Than Continuous Operation (BAAQMD 8-34-501.5)	6
	2.6 Surface Emissions Monitoring [BAAQMD 8-34-501.6, 8-34-506, &	
	§60.757(f)(5)]	6
	2.7 Component Leak Testing [BAAQMD 8-34-501.6, 8-34-503)	7
	2.8 Solid Waste Placement Records (BAAQMD 8-34-501.7)	7
	2.9 Non-Degradable Waste Acceptance Records (BAAQMD 8-34-501.8)	7
	2.10 Wellhead Monitoring Data (BAAQMD 8-34-501.4 & 8-34-505)	8
	2.11 Gas Flow Monitoring Results [BAAQMD 8-34-501.10, 8-34-508 &	•
	§60.757(f)(1)]	8
	2.12 Compliance With §60.757(f)(6)	9
	2.13 Compliance With Title V Permit Condition 13123 (S-34 & S-39) 2.14 Compliance With Title V Permit Conditions 14098 and 16516 (S-55)	10
	2.14 Compliance With Title V Permit Conditions 14096 and 16516 (5-55)  2.15 Compliance With Title V Permit Conditions 22820 (S-49)	10 11
	2.16 Compliance With Title V Permit Conditions 22020 (3-49) 2.16 Compliance With Title V Permit Condition 19865 (S-41)	11
	2.17 Compliance With Title V Permit Condition 19866 (S-42)	11
	2.18 Compliance With Title V Permit Condition 19867, Parts 6-10	11
	2.19 Compliance With Title V Permit Condition 19867, Parts 14 and 15	12
	2.20 Compliance With Title V Permit Condition 19867, Parts 31 and 33	12
	2.21 Compliance With Title V Permit Condition 22940 (S-56)	15
	2.22 Compliance With Title V Permit Condition 22941 (S-57)	16
	2.23 Compliance With Title V Permit Condition 23052 (S-58)	16
	2.24 Compliance With Title V Permit Condition 24527 (S-61 and S-62)	17
	2.25 Compliance With Title V Permit Condition 25634	18
3	PERFORMANCE TEST REPORT	19
	3.1 Source Test Results (BAAQMD 8-34-412)	19
	3.3 Compliance With §60.757(g)(1)	21
	3.4 Compliance With §60.757(g)(2)	21
	3.6 Compliance With §60.757(g)(3)	22
	3.7 Compliance With §60.757(g)(4)	22
	3.8 Compliance With §60.757(g)(5)	22
	3.9 Compliance With §60.757(g)(6)	22

24

# 4 START-UP, SHUTDOWN, MALFUNCTION REPORT

# **List of Tables**

Table 2-1 Table 2-2 Table 2-3	Semi-Annual Report Requirements A-51 and A-60 Downtimes S-64 and S-65 Downtimes
Table 2-4	GCCS Downtime Summary
Table 2-5	Applicable Temperature Limits
Table 2-6	Solid Waste Placement
Table 2-7	Total LFG Flow
Table 2-8	Composting and Screening Operations Throughput
Table 2-9	Unleaded Gasoline Throughput
Table 2-10	Waste Processed at S-41
Table 2-11	Quarterly LFG Characterization
Table 2-12	Quarterly Engine Inlet (pre-treatment) Characterization
Table 2-13	Rolling 4-Quarter TRS Concentration
Table 2-14	Annual LFG Characterization
Table 2-15	Toxic Air Contaminants Sampling
Table 2-16	Waste Processed at S-56
Table 2-17	Fuel Usage at S-57
Table 2-18	Leachate Flow Information for S-58
Table 2-19	POC Concentrations for S-58
Table 2-20	S-61 and S-62 Portable Diesel Engines
Table 2-21	Rolling 4-Quarter LFG Input and CO and SO2 Emissions
Table 3-1	Performance Test Requirements
Table 3-2	A-51 Flare Source Test Results
Table 3-3	A-60 Zone A Flare Source Test Results
Table 3-4	A-60 Zone B Flare Source Test Results

### **List of Appendices**

Appendix A	Site Map
Appendix B	A-51 and A-60 Flare SSM Logs and GCCS Downtime Summary
Appendix C	Correspondence
Appendix D	Wellfield SSM Log
Appendix E	A-51 and A-60 Flare Temperature Reports
Appendix F	Missing A-51 and A-60 Flow and Temperature Records
Appendix G	Cover Integrity Forms
Appendix H	Surface Emissions and Component Leak Monitoring Reports
Appendix I	Wellfield Monitoring Logs
Appendix J	Wellfield Deviation Log
Appendix K	Monthly Landfill Gas Flow Rates

Appendix L VOC Soils Logs

Appendix M H2S Weekly and Quarterly Monitoring

Appendix N Source Test Report Summary

Appendix O S-55 Static Pressure Performance Test (Leak Test)
Appendix P Rolling Quarterly LFG Input and CO and SO<sub>2</sub> Emissions

#### 1 INTRODUCTION

### 1.1 Purpose

This document is a Title V Combined Semi-Annual Report and Partial 8-34 Annual Report for Redwood Landfill, Inc. (RLI) pursuant to Title V Permit Standard Condition I.F and Condition Number 19867, Part 32. This Combined Report satisfies the requirements of Bay Area Air Quality Management District's (BAAQMD) Regulation 8, Rule 34, Section 411 and Title 40 Code of Federal Regulations (CFR) Part 60 Subpart WWW (40 CFR §60.757[f]), New Source Performance Standards (NSPS) for municipal solid waste (MSW) landfills, and the RLI Title V Standard Condition I.F. This report covers compliance activities conducted from November 1, 2019 to April 30, 2020. This Combined Report also includes the Semi-Annual Start-up, Shutdown, and Malfunction (SSM) Plan Report activities pursuant to National Emission Standards for Hazardous Air Pollutants (NESHAP), 40 CFR Part 63, Subpart AAAA for Landfills.

Section 2 of this Report contains the elements required to satisfy both BAAQMD Regulation 8-34-411 and 40 CFR §60.757(f).

Section 3 of this Combined Report includes a discussion of the data from the most recent source tests, for the A-51 and A-60 Flares, in compliance with BAAQMD Regulation 8-34-412 and Title V Permit Condition Number 19867, Part 30.

Section 4 and Appendices B, D, and E of this Report contain the Semi-Annual Report of SSM Plan activities.

### 1.2 Record Keeping and Reporting

Records are maintained and available for inspection in accordance with BAAQMD Regulation 8-34-501.12 and 40 CFR §60.758. The primary location for records storage is Redwood Landfill. Records are maintained onsite at the Landfill for a minimum of five years.

#### 2 SEMI-ANNUAL MONITORING REPORT

In accordance with RLI Title V Permit Standard Conditions I.F and 19867, Part 32; BAAQMD Regulation 8-34-411; and 40 CFR §60.757(f) of the NSPS for landfills, this report is a Title V Combined Semi-Annual Report and Partial 8-34 Annual Report that is required to be submitted by RLI. This Report contains monitoring data for the operation of the gas collection and control system (GCCS). The operational records have been reviewed and summarized. The timeframe included in this Report is November 1, 2019 to April 30, 2020. The following table lists the rules and regulations that are required to be included in this Combined Report:

**Table 2-1 Semi-Annual Report Requirements** 

RULE	REQUIREMENT	LOCATION IN REPORT
	All collection system downtime, including individual well shutdown times and the reason for the shutdown.	Section 2.1, Appendices B & D
8-34-501.2, §60.757(f)(3)	All emission control system downtime and the reason for the shutdown.	Section 2.2, Appendix B
8-34-501.3, 8-34-507, §60.757(f)(1)	Continuous temperature for all operating flares and any enclosed combustor subject to Section 8-34-507.	Section 2.3, Appendices E & F
8-34-501.4, 8-34-505, 8-34-510	Testing performed to satisfy any of the requirements of this rule.	Sections 2.4 & 2.10, Appendices G & I
8-34-501.5	Monthly landfill gas (LFG) flow rates and well concentration readings for facilities subject to 8-34-404.	Sections 2.5 & 2.11, Appendix K
8-34-503, 8-34-506,	For operations subject to Section 8-34-503 and 8-34-506, records of all monitoring dates, leaks in excess of the limits in Section 8-34-301.2 or 8-34-303 that are discovered by the operator, including the location of the leak, leak concentration in parts per million by volume (ppm <sub>v</sub> ), date of discovery, the action taken to repair the leak, date of the repair, date of any required re-monitoring, and the re-monitored concentration in ppm <sub>v</sub> .	Sections 2.6 & 2.7, Appendix H
8-34-501.7	Annual waste acceptance rate and current amount of waste in-place.	Section 2.8
8-34-501.8	Records of the nature, location, amount, and date of deposition of non- degradable wastes, for any landfill areas excluded from the collection system requirement as documented in the GCCS Design Plan.	Section 2.9
8-34-505,	For operations subject to Section 8-34-505, records of all monitoring dates and any excesses of the limits stated in Section 8-34-305 that are discovered by the operator, including well identification number, the measured excess, the action taken to repair the excess, and the date of repair.	Section 2.10, Appendices I & J
8-34-501.10, 8-34-508, §60.757(f)(1)	Continuous gas flow rate records for any site subject to Section 8-34-508.	Section 2.11, Appendix K

RULE	REQUIREMENT	LOCATION IN REPORT		
	For operations subject to Section 8-34-509, records or key emission control system operating parameters.	Section 2.2.2		
	8-34-501.12 The records required above shall be made available and retained for a period of five years.			
§60.757(f)(2)	Description and duration of all periods when the gas stream is diverted from the control device through a bypass line or the indication of bypass flow as specified under §60.756.	Section 2.2.1		
§60.757(f)(6)	The date of installation and the location of each well or collection system expansion added pursuant to paragraphs (a)(3), (b), (c)(4) of §60.755.	Section 2.12		
§60.10 (d)(5)(i)	Start-up, Shutdown, Malfunction Events	Section 4, Appendices B, D, and E		

# 2.1 COLLECTION SYSTEM OPERATION [BAAQMD 8-34-501.1& §60.757(f)(4)]

Appendix A contains a map of the GCCS at RLI. Section 2.1.1 includes all collection system downtimes. The information contained in Appendix B, A-51 and A-60 Flares SSM Logs, GCCS Downtime Summary, S-64 and S-65 Landfill Gas Engine SSM logs, and S-71 Gas Treatment System Downtime Log, includes the individual well shutdown times and the reason for each shutdown.

#### 2.1.1 FLARE SYSTEM DOWNTIME

The A-51 Flare commenced operation in June 2005, and the A-60 Flare commenced operation on April 1, 2009. Table 2-2 summarizes the A-51 and A-60 Flares' downtimes for the reporting period.

Table 2-2 A-51 and A-60 Downtimes

Month	A-51 Downtime (Hours)	A-60 Downtime (Hours)
November 2019	720.20	2.00
December 2019	665.67	78.47
January 2020	730.20	14.10
February 2020	696.00	0.00
March 2020	743.00	0.00
April 2020	717.60	1.87
Total Hours:	4,272.67	96.43

During the period covered in this report, the GCCS was not shut down for more than five days on any one occasion. Appendix B contains the A-51 and A-60 Flare SSM

logs, and GCCS Downtime Summary which lists dates, times, and lengths of shutdowns for the reporting period and year-to-date.

#### 2.1.2 LANDFILL GAS ENGINE SYSTEM DOWNTIME

The S-64 and S-65 Landfill Gas Engines (with accompanying S-71 Landfill Gas Treatment System) commenced operation in April 27, 2017. Table 2-3 summarizes the S-64 and S-65 Engines' downtimes for the reporting period.

Table 2-3 S-64 and S-65 Downtimes

Month	S-64 Downtime (Hours)	S-65 Downtime (Hours)
November 2019	13.75	1.83
December 2019	245.08	318.17
January 2020	22.75	37.17
February 2020	43.50	20.92
March 2020	42.17	10.17
April 2020	159.50	26.50
Total Hours:	526.75	414.75

Appendix B contains the S-64 and S-65 Engine SSM logs, and S-71 Downtime Log which lists dates, times, and lengths of shutdowns for the reporting period.

#### 2.1.3 WELL DISCONNECTION LOG

A Wellfield SSM Log that lists dates, times, and lengths of disconnections for the reporting period is included in Appendix D. In addition, 1 well (out of a possible 5) remains disconnected at the end of the reporting period, pursuant to BAAQMD Regulation 8-32-116.2 (Limited Exemption, Well Raising).

# 2.2 EMISSION CONTROL DEVICE DOWNTIME [BAAQMD 8-34-501.2 & §60.757(f)(3)]

No bypassing of the control system or emissions of raw LFG occurred. The Flare SSM Logs that include all downtimes and reasons for each shutdown for the A-51 and A-60 Flares are contained in Appendix B. Device downtime is summarized in Table 2-4.

**Table 2-4 GCCS Downtime Summary** 

Total 2019 Downtime:	64.63
November 1, 2019 through April 30, 2020 Downtime:	2.00
January 1, 2020 through April 30, 2020 Total Downtime:	0.50
Total 2020 Downtime:	0.50

#### 2.2.1 LFG BYPASS OPERATIONS (§60.757(f)(2))

Title 40 CFR §60.757(f)(2) is not applicable at RLI because no bypass line is installed. LFG cannot be diverted around the control equipment.

# 2.2.2 KEY EMISSION CONTROL OPERATING PARAMETERS (BAAQMD 8-34-501.11 & 8-34-509)

The A-51 and A-60 Flares are subject to continuous temperature monitoring as required in BAAQMD Regulation 8-34-507 and 40 CFR §60.757(f)(1).

# 2.3 TEMPERATURE MONITORING RESULTS [(BAAQMD 8-34-501.3, 8-34-507, & §60.757(f)(1)]

The RLI has two flares used to destroy LFG collected by the GCCS (A-51 and A-60). Combustion zone temperatures of the flares are monitored with thermocouples and recorded with Yokogawa DX100 paperless chart recorders. There were no continuous recorder device SSM events during the reporting period. As shown in Appendix F, there were no periods of missing temperature data for the flares during the reporting period.

Title V Permit Condition Number 19867 Part 22 states that the minimum combustion zone temperature shall be equal to the average combustion zone temperature determined during the most recent complying source test minus 50°F, provided that the minimum combustion zone temperature is not less than 1,400°F. Pursuant to Part 22, the following temperature limits applied during the reporting period:

**Table 2-5 Applicable Temperature Limits** 

Device	Test Date	Report Submitted	Average Temperature During Test (°F)	3-hr Minimum Temperature (°F)
A-51	1/30/2019	3/28/2019	1,411	1,400
A-51	1/22/2020	3/16/2020	1,419	1,400
A-60 Zone A	7/25/2019	9/20/2019	1,585	1,535
A-60 Zone B	7/17/2018	9/14/2018	1,605	1,555

The three-hour minimum temperature applies upon submittal of the source test report. Operating records for the flares indicate all flares operated in compliance with the

applicable three-hour average minimum temperatures from November 1, 2019 to April 30, 2020.

Pursuant to Title V Permit Condition Number 19867, Part 30g, the annual source test at A-60 may be conducted while A-60 is operating in either zone, provided that each operating zone is tested at least once every five years. The most recent source test for Zone A was completed in July 2019. Zone B was tested in July 2018, meeting the obligation to test each zone every five years.

# 2.4 MONTHLY COVER INTEGRITY MONITORING [BAAQMD 8-34-501.3, 8-34-507, & §60.757(f)(1)]

The Monthly Cover Integrity Monitoring Reports are included in Appendix G. The cover integrity monitoring was performed on the following dates:

- November 26, 2019
- December 24, 2019
- January 29, 2020
- February 25, 2020
- March 24, 2020
- April 30, 2020

No breaches of cover integrity (e.g., cover cracks or exposed garbage) were found during the reporting period. If areas of concern were observed, repairs were documented as required.

### 2.5 LESS THAN CONTINUOUS OPERATION (BAAQMD 8-34-501.5)

The RLI does not operate under BAAQMD Regulation 8-34-404 (Less Than Continuous Operation) and therefore is not required to submit monthly LFG flow rates.

# 2.6 SURFACE EMISSIONS MONITORING [BAAQMD 8-34-501.6, 8-34-506, & §60.757(f)(5)]

Quarterly Surface Emissions Monitoring (SEM), pursuant to BAAQMD Regulation 8-34-506, was conducted during the reporting period. A flame ionization detector (FID) was used during the SEM events to monitor the path along the landfill surface according to the Landfill SEM Map. Any areas suspected of having emission problems by visible observations also were monitored. Immediately prior to both monitoring events, the FID was zeroed and calibrated using zero air and a 500-ppm<sub>v</sub> methane calibration gas.

The Fourth Quarter 2019 SEM event was conducted by Roberts Environmental Services (RES) personnel on November 5, 2019. Three exceedances were identified. Corrective action and re-monitoring are described below:

• 10-day re-monitoring was completed on November 14, 2019 with all locations cleared.

• 1-month remonitoring was completed on December 4, 2019. All locations cleared.

The First Quarter 2020 SEM was conducted by RES on January 30, 2020. Two exceedances were identified. Corrective action and re-monitoring are described below:

- 10-day re-monitoring was completed on February 7, 2020. All locations cleared.
- 1-month remonitoring was completed February 27, 2020. All locations cleared.

Per the Compliance Agreement between RLI and BAAQMD, the SEM frequency was increased to bi-monthly. In the First Quarter 2020, the bi-monthly Instantaneous SEM was performed on March 11 and 12, 2020. There were no exceedances of 500-ppm<sub>v</sub> methane detected. No re-monitoring was required.

SEM Reports are included in Appendix H.

### 2.7 COMPONENT LEAK TESTING [BAAQMD 8-34-501.6, 8-34-503)

Quarterly component leak testing, pursuant to BAAQMD Regulation 8-34-503, occurred during the reporting period on the following dates:

Fourth Quarter 2019 – November 5, 2019 First Quarter 2020 – January 30, 2020

No exceedances were identified during either monitoring event. The Component Leak Testing results are included with the SEM reports in Appendix H.

### 2.8 SOLID WASTE PLACEMENT RECORDS (BAAQMD 8-34-501.7)

The solid waste placement total was calculated for the period of November 1, 2019 to April 30, 2020. The current waste in place figure includes solid waste placed in the landfill through the end of the reporting period. Table 2-6 summarizes the RLI solid waste placement records for the reporting period.

**Table 2-6 Solid Waste Placement** 

Waste Placement (November 1, 2019 to April 30, 2020)	112,109 tons
Current Waste In Place as of May 1, 2020	14.42 million tons

# 2.9 NON-DEGRADABLE WASTE ACCEPTANCE RECORDS (BAAQMD 8-34-501.8)

RLI does not have non-degradable waste areas that are excluded from the collection system. Therefore, BAAQMD Regulation 8-34-501.8 is not applicable.

# 2.10 WELLHEAD MONITORING DATA (BAAQMD 8-34-501.4 & 8-34-505)

Wellhead monitoring was performed monthly pursuant to BAAQMD Regulation 8-34-505. The well data for November 1, 2019 to April 30, 2020 are included in Appendix I. Each well was monitored in accordance with the following requirements:

- 8-34-305.1 Each wellhead shall operate under a vacuum.
- 8-34-305.2 The LFG temperature in each wellhead shall be less than 55 degrees Celsius (131 °F).
- 8-34-305.4 The oxygen concentration in each wellhead shall be less than 5 percent by volume.

The wellhead monitoring was performed on the following dates:

- November 5, 6, 7, 11, 12, 15, and 27, 2019
- December 2, 3, 4, 5, 10, 16, 17, 19, 20, 23, and 30, 2019
- January 2, 6, 7, 8, and 14, 2020
- February 5, 6, 11, 12, 13, 14, and 17, 2020
- March 2, 3, 9, 10, 11, and 13, 2020
- April 1, 2, 3, 6, 7, 8, and 9, 2020

#### WELLHEAD DEVIATIONS [BAAQMD 8-34-501.9 & §60.757(f)(1)]

A total of four (4) deviations from the wellhead standards in 8-34-305 occurred during the reporting period. All exceedances were addressed prior to issuance of this report.

The Wellfield Deviation Log is included in Appendix J.

# 2.11 GAS FLOW MONITORING RESULTS [BAAQMD 8-34-501.10, 8-34-508 & §60.757(f)(1)]

The LFG flow rates from both the A-51 and A-60 flares are measured with Veris flow meters. The S-64 and S65 LFG engines are measured with ABB flow meters. The flow meters meet the requirements of BAAQMD Regulation 8-34-508 by recording fuel flow at least every 15 minutes.

Appendix K contains a summary of the daily and monthly LFG flow rates and heat input for the flares and engine plant. The A-51 flare is utilized as a backup for the A-60 flares. These flow rates are summarized in Table 2-7:

**Table 2-7 Total LFG Flow** 

Emission Control Device	Total Runtime (hours)	Average Flow Rate (scfm)	Average Methane (%) <sup>1</sup>	Total LFG Flow (scf)	12-Month Total LFG Flow (scf) Corrected to 500 BTU/scf	Max Daily Flow (scf) Corrected to 500 BTU/scf
A-51	95	1,902	50.6	10,879,622	34,287,730	2,961,989
A-60	4,272	1,581	47.3	405,327,784	823,054,029	3,243,391
S-64	3,841	615	47.7	141,688,188	294,968,466	944,944
S-65	3,953	612	47.8	145,133,827	308,309,993	925,070
Total	4,366	2,684	47.5	703,029,421	1,460,620,218	

<sup>&</sup>lt;sup>1</sup>Methane content was determined from the 7/17/18, 1/30/19, 7/25/29, and 1/22/20 Source Tests. Heating value of methane used in heat input calculations is 1,013 BTU/scf

MMBTU = million British thermal units

Pursuant to Title V Condition Number 19867, Part 20, the total LFG throughput to the either flare did not exceed 4,320,000 scf during any one day. The A-51 and A-60 Flares combined total LFG throughput did not exceed 2,207,520,000 scf during any consecutive 12-month period.

Appendix K contains a summary of the combined daily LFG flow rates for the A-51 and A-60 Flares and the consecutive 12-month summaries.

There were no periods of missing data or chart recorder non-operation for the A-51 and A-60 Flares or the landfill gas engine plant (S-64 and S-65 engines) during the reporting period. The Flare Missing Data Report Forms are included in Appendix F.

### 2.12 COMPLIANCE WITH §60.757(f)(6)

"The date of installation and the location of each well or collection system expansion added pursuant to (a)(3), (b), (c)(4) of  $\S60.755$ ."

Routine GCCS maintenance occurred during the reporting period. The Wellfield SSM Log is included in Appendix D, Wellfield SSM Log.

Zero (0) wells were added to and four (4) wells were removed from the collection system during the reporting period (November 1, 2019 to April 30, 2020).

As of the end of this reporting period, 115 total collectors (106 vertical wells and 9 horizontal collectors) were in service at RLI. A map of the LFG collection system showing the positioning of all vertical wells, horizontal collectors, and other LFG extraction devices is included in Appendix A.

scfm = standard cubic feet per minute

scf= standard cubic feet

# 2.13 COMPLIANCE WITH TITLE V PERMIT CONDITION 13123 (S-34 & S-39)

The S-34 Compost Facility Operations and S-39 Screening Operations were utilized during the reporting period. The total amount of material processed did not exceed 160,368 tons during any consecutive 12-month period during the reporting period of November 1, 2019 to April 30, 2020. Monthly and 12-month rolling throughputs are summarized in Table 2-8.

**Table 2-8 Composting and Screening Operations Throughput** 

Month	Total Throughput (tons)	Rolling 12-Month Throughput (tons)
November-2019	11,607	131,867
December-2019	12,019	132,265
January-2020	11,347	132,537
February-2020	9,866	133,918
March-2020	10,302	134,267
April-2020	12,167	134,412

Pursuant to Title V Permit Condition Number 13123 Part 7, all yard waste material was processed within 72 hours of receipt. In addition, pursuant to Title V Permit Condition Number 13123 Part 8, the plant received no public nuisance notices of violation during the reporting period of November 1, 2019 to April 30, 2020.

# 2.14 COMPLIANCE WITH TITLE V PERMIT CONDITIONS 14098 AND 16516 (S-55)

Pursuant to Title V Permit Condition Number 14098, the annual gasoline throughput for the S-55 Non-Retail Gasoline Dispensing Facility Number 8573 did not exceed 940,000 gallons in any consecutive 12-month period during the timeframe of this report. Monthly gasoline throughput totals for the reporting period are listed in Table 2-9:

**Table 2-9 Unleaded Gasoline Throughput** 

Month	Total Throughput (gallons)	Rolling 12-Month Fuel Usage (gallons)
November-2019	126	2,590
December-2019	136	2,474
January-2020	69	2,290
February-2020	182	2,219
March-2020	154	2,106
April-2020	100	1,994

Pursuant to Title V Permit Condition Number 16516, the Static Pressure Performance Test (Leak Test) for S-55 was performed on April 8, 2019. S-55 also passed the 2018 Leak Test. The Static Pressure Performance Test results are included in Appendix O.

### 2.15 COMPLIANCE WITH TITLE V PERMIT CONDITIONS 22820 (S-49)

The permit for S-49 was surrendered to BAAQMD on November 4, 2013. The equipment is on longer on site.

### 2.16 COMPLIANCE WITH TITLE V PERMIT CONDITION 19865 (S-41)

Pursuant to Title V Permit Condition 19865, the total of waste processed at the S-41 Yard and Green Waste Shredding Operation did not exceed 820 tons per day or 200,000 tons per year. Table 2-10 summarizes the amount of waste processed at S-41 during the reporting period:

Table 2-10 Waste Processed at S-41

Month	Total Throughput (tons)	Rolling 12-Month Throughput (tons)
November-2019	11,607	131,867
December-2019	12,019	132,265
January-2020	11,347	132,537
February-2020	9,866	133,918
March-2020	10,302	134,267
April-2020	12,167	134,412

#### 2.17 COMPLIANCE WITH TITLE V PERMIT CONDITION 19866 (S-42)

The total amount of material received at the S-42 Soil and Cover Stockpiles did not exceed 1,160 tons per day and 105,500 tons per year.

# 2.18 COMPLIANCE WITH TITLE V PERMIT CONDITION 19867, PARTS 6-10

The following is a summary of vehicle activity at the RLI:

- The mean vehicle fleet weight for all off-site vehicles traveling on paved roads was 13.93 tons, which is less than the permit limit of 15.31 tons.
- Mean vehicle fleet weight for all off-site vehicles traveling on gravel or dirt roads was 14.90 tons, which is less than the permit limit of 16.63 tons.
- The mean vehicle fleet weight for all on-site landfilling and construction related vehicles was 11.7 tons, which is below the permit limit of 28.37 tons.
- During the reporting period, the vehicle miles travelled (VMT) per day on gravel roads did not exceed the permit limit of 280 VMT per day. 2019 calendar year VMT on gravel roads was 25,447 VMT, below the limit of 87,080 VMT. 2020 partial calendar year VMT on gravel roads was 7,983 VMT, below the limit of 87,080 VMT.

- During the reporting period, the VMT per day on dirt roads did not exceed the permit limit of 639 VMT per day. 2019 calendar year VMT on dirt roads was 119,750 VMT, below the limit of 198,650 VMT. 2020 partial calendar year VMT on dirt roads was 37,568 VMT, below the limit of 198,650 VMT.
- During the reporting period, the VMT per day on paved roads did not exceed the permit limit of 622 VMT per day. 2019 calendar year VMT on paved roads was 80,479 VMT, below the limit of 205,880 VMT. 2020 partial calendar year VMT on paved roads was 23,480 VMT, below the limit of 205,880 VMT.
- During the reporting period, the VMT per day on dirt roads for the on-site vehicle fleet did not exceed the permit limit of 61 VMT per day. 2019 calendar year VMT on dirt roads is 15,905 VMT, below the limit of 19,080 VMT. 2020 partial calendar year VMT on dirt roads is 4,703 VMT, below the 19,080 VMT.

The records for VMT and average vehicle fleet weights are available for review at RLI.

# 2.19 COMPLIANCE WITH TITLE V PERMIT CONDITION 19867, PARTS 14 AND 15

No contaminated soil containing volatile organic compound (VOC) concentrations greater than 50 parts per million (ppm) was received during this reporting period. The total VOC emission rate for the reporting period (November 1, 2019 to April 30, 2020) is 0.00 lbs. The VOC soil log is included in Appendix L.

# 2.20 COMPLIANCE WITH TITLE V PERMIT CONDITION 19867, PARTS 31 AND 33

#### WEEKLY H2S MONITORING

Pursuant to Title V Permit Condition Number 19867, Part 31b, weekly hydrogen sulfide  $(H_2S)$  readings were taken using Draeger/RAE tubes. This sampling frequency was increased to twice weekly starting November 22, 2016 per the Compliance Agreement between RLI and BAAQMD. This agreement is in effect and all terms of the agreement have been complied with.

The twice weekly H<sub>2</sub>S readings and quarterly averages are summarized in Appendix M, H<sub>2</sub>S Twice Weekly and Quarterly Monitoring.

#### QUARTERLY H2S CHARACTERIZATION

Pursuant to Title V Permit Condition Number 19867, Part 31a, RLI collected the quarterly characterization of the LFG for analysis of sulfur compounds. The results are included in Tables 2-11 (LFG), 2-12 (Engine Inlet before pre-treatment), and Appendix M. As previously discussed, RLI has obtained a Compliance Agreement with BAAQMD covering the concentration limits of H<sub>2</sub>S in the landfill gas. This agreement is in effect and all terms of the agreement have been complied with.

**Table 2-11 LFG Characterization Results** 

Compound	Fourth Quarter 2019 Result (ppm <sub>v</sub> )	First Quarter 2020 Result (ppm <sub>v</sub> )
Hydrogen Sulfide	1,100	920
Carbonyl Sulfide	1.10	0.41
Methyl Mercaptan	1.50	0.67
Ethyl Mercaptan	0.39	ND
Dimethyl Sulfide	0.56	ND
Carbon Disulfide	0.13	ND
Total Reduced Sulfur	1,113	924

ND = not detected N/A = not applicable

Table 2-12 Engine Inlet (pre-treatment) Characterization Results

Compound	Fourth Quarter 2019 Result (ppm <sub>v</sub> )	First Quarter 2020 Result (ppm <sub>v</sub> )
Hydrogen Sulfide	2,000	1,800
Carbonyl Sulfide	1.10	0.74
Methyl Mercaptan	3.60	0.95
Ethyl Mercaptan	0.63	0.25
Dimethyl Sulfide	0.59	0.25
Carbon Disulfide	0.29	0.15
Total Reduced Sulfur	2,030	1,815

ND = not detected N/A = not applicable

#### **ROLLING 4-QUARTER TRS LIMIT**

The rolling 4-quarter average TRS concentration was calculated at the end of each quarter using data collected from twice weekly tube samples and quarterly analytical samples per Condition 19867, Part 31b. Results are shown in Table 2-13. As shown in the table, at the end of all the Quarters, the calculated TRS concentration was in excess of the 350 ppm<sub>V</sub> limit. The Compliance Agreement also covers this limit. Follow-up actions are discussed later in this section.

Table 2-13 Rolling 4-Quarter TRS Concentration

Quarter	Calculated TRS (ppmv)	Rolling Quarterly Average Annual TRS (ppmv)
2019 Q2	1,187	898
2019 Q3	936	946
2019 Q4	778	963
2020 Q1	753	914

#### **ANNUAL LFG CHARACTERIZATION**

LFG characterization sampling was conducted concurrently with the A-51 annual source test as required by Title V Permit Condition Number 19867, Part 31 on January 22, 2020. The LFG sample was collected from the main LFG header and analyzed for the organic and sulfur compounds listed in Part 31. The results were included in the Annual Source Test report submitted on March 16, 2020.

Results for Toxic Air Contaminants (TACs) are presented in Table 2-14 and indicate that the LFG collected by S-5 did not exceed the limits listed in Title V Permit Condition 19867, Part 18.b.

**Table 2-14 Annual LFG Characterization: Toxic Air Contaminants** 

Compound	Result (ppb <sub>v</sub> )	Concentration Limit* (ppb <sub>v</sub> )
Acrylonitrile	<srl< td=""><td>300</td></srl<>	300
Benzene	459	1,500
Benzyl Chloride	<srl< td=""><td>500</td></srl<>	500
Carbon Tetrachloride	<srl< td=""><td>200</td></srl<>	200
Chlorobenzene	<srl< td=""><td>200</td></srl<>	200
Chloroethane	92	500
Chloroform	<srl< td=""><td>200</td></srl<>	200
1,4-Dichlorobenzene	<srl< td=""><td>1,000</td></srl<>	1,000
Ethylbenzene	778	4,000
Ethylene Dibromide	<srl< td=""><td>200</td></srl<>	200
Ethylene Dichloride	89	200
Ethylidene Dichloride	10	500
Hexane	339	2,000
Isopropyl Alcohol	3,840	10,000
Methyl Alcohol	8,380	300,000
Methyl Ethyl Ketone	5,250	15,000
Methylene Chloride	32	1,000
Methyl tert-Butyl Ether	9	500
Perchloroethylene	46	1,000
Styrene	29	500
1,1,2,2-Tetrachloroethane	<srl< td=""><td>200</td></srl<>	200
Toluene	3,400	20,000
1,1,1-Trichloroethane	<srl< td=""><td>200</td></srl<>	200
Trichloroethylene	55	500
Vinyl Chloride	91	2,000
Vinylidene Chloride	<srl< td=""><td>500</td></srl<>	500
Xylenes	1,416	20,000

ppb<sub>v</sub> = parts per billion by volume

<SRL = less than the sample reporting limit

Per the Compliance Agreement, quarterly samples were collected and analyzed for ethylbenzene and 1,4-Dichlorobenzene on November 14, 2019 and February 18, 2020 at the Flare and the Engine Inlet (pre-treatment). Laboratory analyses were performed by ALS Environmental (ALS). Results from this sampling are presented in Table 2-15 below.

**Table 2-15 Toxic Air Contaminants Sampling** 

Species	4 <sup>th</sup> Quarter 2019 Flare (ppb <sub>v</sub> )	4 <sup>th</sup> Quarter 2019 Engine Inlet (ppb <sub>v</sub> )	1 <sup>st</sup> Quarter 2020 Flare (ppb <sub>v</sub> )	1 <sup>st</sup> Quarter 2020 Engine Inlet (ppb <sub>v</sub> )	Limit (ppb <sub>v</sub> )
Ethylbenzene	1,400	1,300	1,800	1,600	4,000
1,4-Dichlorobenzene	150	150	100	110	1,000

#### GROUND LEVEL H2S MONITORING

RLI began conducting fenceline monitoring for ground level H<sub>2</sub>S concentrations in accordance with the May 2011 Proposed Hydrogen Sulfide Monitoring Plan in November 2016. Monitoring was conducted on the following days:

- November 7, 2019
- December 10, 2019
- January 15, 2020
- February 13, 2020
- March 13, 2020
- April 14, 2020

There were no H<sub>2</sub>S concentrations observed above 30 ppb averaged over 60 minutes or 60 ppb averaged over 3 minutes.

### 2.21 COMPLIANCE WITH TITLE V PERMIT CONDITION 22940 (S-56)

Conditions from the California Air Resources Board (CARB) Permit Number 117378 for the S-56 Portable Horizontal Grinder have been incorporated by reference into the RLI Title V Permit. Therefore, the compliance records for this equipment have been included in this Combined Report. Pursuant to BAAQMD Condition Number 22940, the emissions of particulate matter less than 10 microns in diameter (PM<sub>10</sub>) did not exceed 10 tons per year. The maximum daily throughput for the portable horizontal grinder (S-56) did not exceed 820 tons per day or 200,000 tons per year. Monitoring is performed daily when operations are conducted, the recording of total throughput of all registered equipment units operating. Table 2-16 lists the PM<sub>10</sub> emissions and total throughput of waste processed at S-56 for the reporting period:

Table 2-16 Waste Processed at S-56

Month	PM <sub>10</sub> Emissions (tons)	Estimated Total Throughput (tons)
November-2019	0.00	0
December-2019	0.00	0
January-2020	0.00	0
February-2020	0.00	0
March-2020	0.00	0
April-2020	0.00	0

### 2.22 COMPLIANCE WITH TITLE V PERMIT CONDITION 22941 (S-57)

Conditions from the California Air Resources Board (CARB) Permit Number 117376 for the S-57 Portable Diesel Engine have been incorporated by reference into the RLI Title V Permit. Therefore, the compliance records for this equipment have been included in this Combined Report. Pursuant to BAAQMD Condition Number 22941, the diesel fuel usage has not exceeded 72,295 gallons during any consecutive 12-month period. The Daily fuel and operating records are maintained and summarized on a monthly basis. Table 2-17 lists the monthly and rolling 12-month fuel usage for the S-57 Portable Diesel Engine for the reporting period:

Table 2-17 Fuel Usage at S-57

Month	Diesel Fuel Usage (gallons)	Rolling 12-Month Fuel Usage (gallons)
November-2019	0	3
December-2019	0	2
January-2020	0	0
February-2020	0	0
March-2020	0	0
April-2020	0	0

### 2.23 COMPLIANCE WITH TITLE V PERMIT CONDITION 23052 (S-58)

Pursuant to Permit Condition 23052 Part 1, the total leachate influent rate to the Aerated Leachate Pond (S-58), excluding non-contact storm runoff, did not exceed 39.42 million gallons during any consecutive 12-month period. Table 2-18 displays the leachate flow information for S-58.

**Table 2-18 Leachate Flow Information for S-58** 

Month	Total Leachate Influent Rate to S-58 (gallons)	Total Rolling 12-Month Flow Rate to S-58 (millions of gallons)
November 2019	1,031,700	19,218,580
December 2019	2,707,760	20,319,060
January 2020	2,447,120	20,293,720
February 2020	2,070,640	17,108,120
March 2020	2,392,820	16,362,400
April 2020	1,480,580	16,742,500

As shown in Table 2-19, the average concentration of precursor organic compounds (POCs) in the leachate influent to S-58 did not exceed the limits specified by Title V Permit Condition Number 23052 Parts 2 and 3:

**Table 2-19 POC Concentrations for S-58** 

Sample Date	Benzen	e (ppb)	1,4 Dichlorol (pp	benzene	Vinyl Chlo	ride (ppb)	Total Concen (pp	tration
	GR-7R	GR-8R	GR-7R	GR-8R	GR-7R	GR-8R	GR-7R	GR-8R
6/5/2019	1.6	3.7	5.3	2.8	ND<0.50	ND<0.50	11	18
Average	2.	7	4.	1	ND<	<0.5	16	6
Limit	19	9	48	8	7	7	50	0

# 2.24 COMPLIANCE WITH TITLE V PERMIT CONDITION 24527 (S-61 AND S-62)

The S-61 Portable Diesel Engine for Waste Tipper and S-62 Portable Diesel Engine for Power Screens operated less than 4,992 hours combined during any 12-month period ending in the November 1, 2019 to April 30, 2020 reporting period. Table 2-20 displays runtime hours for S-61 and S-62 during the reporting period.

Table 2-20 S-61 and S-62 Portable Diesel Engines

1 day 1 = 10 0 0 1 day 0 0 1 1 0 1 day 0 2 1 0 0 0 1 1 1 1 1 1 1 1 1 1 1 1 1 1							
Month	S-61 Total Runtime (Hours)	S-62 Total Runtime (Hours)	Combined Rolling 12- Month Total (Hours)				
November 2019	0	0	145				
December 2019	0	0	127				
January 2020	0	0	109				
February 2020	0	0	100				
March 2020	0	0	81				
April 2020	0	0	50				

#### 2.25 COMPLIANCE WITH TITLE V PERMIT CONDITION 25634

Permit Condition 25634 requires the calculation of monthly LFG Input to all LFG-Fired Combustion Equipment and calculation of monthly emissions of CO and SO<sub>2</sub>. The calculations are summarized on a quarterly basis to show compliance with rolling 4-quarter limits. These calculations are summarized below. Complete calculations are presented in Appendix P.

Table 2-21 Rolling 4-Quarter LFG Input and CO and SO<sub>2</sub> Emissions

		Rolling 4-Quarter Totals								
Year	Quarter	LFG Input (MMscf)	CO Emissions (tons)	SO <sub>2</sub> Emissions (tons)						
2019	2	1,449	42.65	60.44						
2019	3	1,498	48.26	68.39						
2019	4	1,499	45.30	71.96						
2020 1		1,499	41.80	69.47						
Lin	nits	2,625	237.5	99						

#### 3 PERFORMANCE TEST REPORT

In accordance with BAAQMD Regulation 8-34-413 and 40 CFR §60.757(g) in NSPS, a Performance Test Report is required to be submitted from subject facilities containing performance and monitoring data for the operation of the GCCS. The operational records listed in Table 3-1 have been reviewed, summarized, and are included herein.

**Table 3-1 Performance Test Requirements** 

Rule	Requirement	Location in Report
8-34-412, §60.8, §60.752(b)(2)(iii)(B), §60.754(d)	Compliance Demonstration Test	Section 3.1,
§60.757(g)(1)	A diagram of the collection system showing collection system positioning including all wells, horizontal collectors, surface collectors, or other gas extraction devices, including the locations of any areas excluded from collection and the proposed sites for future collection system expansion.	Section 3.2, Appendix A
§60.757(g)(2)	The data upon which the sufficient density of wells, horizontal collectors, surface collectors, or other gas extraction devices and the gas mover equipment sizing are based.	Section 3.3
§60.757(g)(3)	The documentation of the presence of asbestos or non- degradable material for each area from which collection wells have been excluded based on the presence of asbestos or non-degradable material.	Section 3.4
§60.757(g)(4)	The sum of the gas generation flow rates for all areas from which collection wells have been excluded based on non-productivity and the calculations of gas generation flow rate for each excluded area.	Section 3.5
§60.757(g)(5)	The provisions for increasing gas mover equipment capacity with increased gas generation flow rate, if the present gas mover equipment is inadequate to move the maximum flow rate expected over the life of the landfill.	Section 3.6
§60.757(g)(6)	The provisions for the control of off-site migration.	Section 3.7

### 3.1 SOURCE TEST RESULTS (BAAQMD 8-34-412)

### 3.1.1 FLARE (A-51) SOURCE TEST RESULTS

The 2020 Annual Compliance Demonstration Test (Source Test) was conducted on January 22, 2020. The Test Report was submitted to BAAQMD on March 16, 2020. A summary of the source test report is presented in Appendix N.

The results for the A-51 Flare indicated that the flare is in compliance with BAAQMD Regulation 8-34-301.3 and Title V Condition Number 19867, Parts 23 and 26. Inlet LFG samples were collected from the discharge side of the blower during the test to show compliance with the NMOC limits from Title V Permit Condition Number 18.a. Table 3-2 below shows the results of the source test, averaged from three test runs.

**Table 3-2 A-51 Flare Source Test Results** 

Condition	Flare (A-51) Average Results	Permit Limit	8-34-301.3 limit	Compliance Status	
NO <sub>x</sub> (ppm <sub>v</sub> @ 15% O <sub>2</sub> )	14.2	15		In Compliance	
CO (ppm <sub>v</sub> @ 15% O <sub>2</sub> )	8.2	82		In Compliance	
NMOC Outlet (ppm <sub>v</sub> @ 3% O <sub>2</sub> )	3.3		30	In Compliance	
NMOC Inlet (ppm <sub>v</sub> )	243	360		In Compliance	

#### 3.1.2 FLARE (A-60) SOURCE TEST RESULTS

The A-60 Flare has two operating Zones (A and B). Title V Permit Condition 19867, Part 30 states that source testing can be conducted while the flare is operating in either zone, provided that each operating zone is tested at least once every five years.

The 2019 Source Test was performed on by Blue Sky Environmental, LLC on July 25, 2019 with the flare operating in Zone A. The Test Report was submitted to BAAQMD on September 20, 2019. A summary of the report is presented in Appendix N.

The results for Zone A of the A-60 Flare indicate that the flare is in compliance with BAAQMD Regulation 8-34-301.3 and Title V Condition Number 19867, Parts 23 and 26. Inlet LFG samples were collected from the discharge side of the blower during the test to show compliance with the NMOC limits from Title V Permit Condition Number 18.a. Table 3-3 below shows the results of the source test, averaged from three test runs.

Table 3-3 A-60 Zone A Flare Source Test Results

Condition	Flare (A-60 Zone A) Average Results	Permit Limit	8-34-301.3 limit	Compliance Status	
NO <sub>x</sub> (ppm <sub>v</sub> @ 15% O <sub>2</sub> )	11.8	15		In Compliance	
CO (ppm <sub>v</sub> @ 15% O <sub>2</sub> )	40.2	82		In Compliance	
NMOC Outlet (ppm <sub>v</sub> @ 3% O <sub>2</sub> )	11.9		30	In Compliance	
NMOC Inlet (ppm <sub>v</sub> )	191	360		In Compliance	

The 2018 Source Test was performed on by Blue Sky Environmental, LLC on July 17, 2018 with the flare operating in Zone B. The Test Report was submitted to BAAQMD on September 14, 2018 and was included in the November 2018 semi-annual report. The revised Test Report was submitted on March 15, 2019 and was included in the May 2019 semi-annual report.

The results for Zone B of the A-60 Flare indicate that the flare is in compliance with BAAQMD Regulation 8-34-301.3 and Title V Condition Number 19867, Parts 23 and 26. Inlet LFG samples were collected from the discharge side of the blower during the test to show compliance with the NMOC limits from Title V Permit Condition Number 18.a. Table 3-4 below shows the results of the source test.

Table 3-4 A-60 Zone B Flare Source Test Results

Condition	Flare (A-60 Zone B) Average Results	Permit Limit	8-34-301.3 limit	Compliance Status
NO <sub>x</sub> (ppm <sub>v</sub> @ 15% O <sub>2</sub> )	12.6	15		In Compliance
CO (ppm <sub>v</sub> @ 15% O <sub>2</sub> )	78.2	82		In Compliance
NMOC Outlet (ppm <sub>v</sub> @ 3% O <sub>2</sub> )	<9.1		30	In Compliance
NMOC Inlet (ppm <sub>v</sub> )	233	360		In Compliance

### 3.3 **COMPLIANCE WITH §60.757(G)(1)**

"A diagram of the collection system showing collection system positioning including wells, horizontal collectors..."

A map of the LFG collection system showing the positioning of all vertical wells, horizontal collectors, and other LFG extraction devices is included in Appendix A.

### 3.4 **COMPLIANCE WITH §60.757(g)(2)**

"The data upon which the sufficient density of wells, horizontal collectors, surface collectors, or other gas extraction devices and the gas mover equipment sizing are based."

RLI's GCCS has historically provided LFG wells and collectors spaced in accordance with standard industry practices. The A-51 and A-60 flares, LFG extraction wells, and piping are more than adequate to move the current LFG flow rate. RLI will continue to add additional LFG control capacity as necessary with the approval of the BAAQMD. The installed collector density appears more than adequate for controlling surface emissions, based on continuous compliance and operational experience.

The total capacity of the LFG mover equipment was designed and will be designed to meet the current United States Environmental Protection Agency (EPA) Model AP-42 projections of LFG generation and the historic LFG extraction rates determined to be continuously available from the facility.

#### **DEMONSTRATING COMPLIANCE WITH §60.757(g)(2)**

"The data upon which the sufficient density of wells, horizontal collectors, surface collectors, or other gas extraction devices and the gas mover equipment sizing are based."

Compliance with 40 CFR §60.757(g)(2) is maintained by performing quarterly SEM. Refer to Section 2.6, Surface Emissions Monitoring for information pertaining to the SEM results. These results show that the GCCS has sufficient coverage over the waste footprint. The current flaring system has the capacity to destroy more than twice the

actual recovery. Well monitoring data shows that adequate vacuum is available at all points in the wellfield, demonstrating that the piping network is sufficient to handle all extracted LFG.

### 3.6 COMPLIANCE WITH §60.757(g)(3)

"The documentation of the presence of asbestos or non-degradable material for each area from which collection wells have been excluded based on the presence of asbestos or non-degradable material."

No segregated areas or accumulations of asbestos material are documented for the site in the GCCS Design Plan. Therefore, 40 CFR §60.757(g)(3) is not applicable.

### 3.7 **COMPLIANCE WITH §60.757(g)(4)**

"The sum of the gas generation flow rates for all areas from which collection wells have been excluded based on non-productivity and the calculations of gas generation flow rate for each excluded area."

No non-productive areas have been excluded from the coverage of the GCCS. Therefore, 40 CFR §60.757(g)(4) is not applicable.

### 3.8 **COMPLIANCE WITH §60.757(g)(5)**

"The provisions for increasing gas mover equipment capacity with increased gas generation flow rate, if the present gas mover equipment is inadequate to move the maximum flow rate expected over the life of the landfill."

The present LFG mover equipment capacity is adequate to move the current LFG flow rate. RLI will continue to add additional LFG control capacity as necessary with the approval of the BAAQMD.

Zero (0) wells were added to and four (4) wells were removed to the collection system during the reporting period (November 1, 2019 to April 30, 2020).

As of the end of this reporting period, 115 total collectors (106 vertical wells and 9 horizontal collectors) were in service at RLI.

# 3.9 COMPLIANCE WITH §60.757(g)(6)

"The provisions for the control of off-site migration."

RLI is a diked area that is completely surrounded by permanent surface water features (San Antonio Creek, Hans Slough, West Slough, and South Slough) which present a barrier to gas migration. The waste footprint is also surrounded by an engineered leachate collection trench that provides a further barrier to LFG migration. Based on the location of RLI and on existing LFG monitoring data, the existing GCCS has been adequate in preventing subsurface lateral migration of LFG to off-site locations.

#### **DEMONSTRATING COMPLIANCE WITH §60.757(g)(6)**

"The provisions for the control of off-site migration."

The landfill operator will continue surface monitoring in accordance with the approved monitoring plans. If the GCCS at RLI does not meet the measures of performance set forth in the NSPS/Emissions Guidelines (EG), the GCCS will be adjusted or modified in accordance with the NSPS/EG requirements.

#### 3.10 COMPLIANCE AGREEMENT SUMMARY

In response to increased concentrations of H<sub>2</sub>S, 1,4-dichlorobenzene and ethylbenzene observed both during routine sampling events and the 2016 Source Test. RLI entered into a Compliance Agreement with BAAQMD on November 22, 2016. The agreement includes enhanced monitoring and reporting activities for RLI:

- The frequency for H<sub>2</sub>S monitoring using Draeger/RAE tubes was increased from weekly to twice per week.
- Monthly fenceline monitoring for ground-level H<sub>2</sub>S is now required.
- The frequency for TO-15 sampling for 1,4-dichlorobenzene and ethylbenzene was increased to quarterly.
- The frequency for instantaneous SEM was increased from quarterly to bimonthly.

Reports summarizing this monitoring are required to be submitted to BAAQMD by the 20<sup>th</sup> day of each month.

All terms of the Agreement were complied with during the reporting period. The monthly compliance reports were submitted to BAAQMD on the following days:

- December 6, 2019
- January 9, 2020
- February 10, 2020
- March 16, 2020
- April 10, 2020
- May 4, 2020

#### 4 START-UP, SHUTDOWN, MALFUNCTION REPORT

# Start-up, Shutdown, Malfunction (SSM) Report for the Collection and Control Systems at the Redwood Landfill

The NESHAP contained in 40 CFR Part 63, AAAA for MSW landfills to control hazardous air pollutants include the regulatory requirements for submittal of a semi-annual report (under 40 CFR §63.10(d)(5) of the general provisions) if an SSM event occurred during the reporting period. The reports required by 40 CFR §63.1980(a) of the NESHAP and §60.757(f) of the NSPS summarize the GCCS exceedances. These two semi-annual reports contain similar information and have been combined as allowed by 40 CFR §63.10(d)(5)(i) of the General Provisions.

NESHAP 40 CFR Part 63, AAAA became effective on January 16, 2004. SSM events that occurred during the semi-annual reporting period (November 1, 2019 to April 30, 2020) are noted in this section and included in Appendix B. The following information is included as required:


- During the reporting period, 13 A-51 Flare SSM events, 14 A-60 Flare Zone A SSM events, and 4 A-60 Flare Zone B SSM events occurred. The time, duration, and cause of each event are included in Appendix B, Flare and Engine SSM Logs.
- During the reporting period, 13 wellfield SSM events occurred. The time and duration of these events are included in Appendix D, Wellfield SSM Log.
- During the reporting period, 77 S-64 Engine (#1) SSM events, 70 S-65 Engine (#2) SSM events occurred. The time, duration, and cause of each event are included in Appendix B, Flare & Engine SSM Logs
- During the reporting period, 0 monitoring/recorder equipment SSM event occurred.
- In all 191 flare, wellfield, and engine SSM events, automatic systems and operator actions were consistent with the standard operating procedures contained in the SSM Plan.
- Revisions of the SSM Plan to correct deficiencies in the landfill operations or procedures were neither required nor prepared (§63.6(e)(3)(viii)).

#### I certify the following:

Based on information and belief formed after reasonable inquiry, information on the startup, shutdown, malfunction forms, all accompanying reports, and other required certifications are true, accurate, and complete.

Ramin S. Khang	<i>'</i>
Signature of Responsible Official	<u>May 28, 2020</u> Date
Ramin Khany	

# APPENDIX A SITE MAP



# **APPENDIX B**

FLARE (A-51 & A-60) SSM LOGS, ENGINE (S-64 & S65) SSM LOGS, AND GCCS DOWNTIME SUMMARY

# REDWOOD LANDFILL, INC. A-51 CONTROL DEVICE DOWNTIME LOG

Event No.	Check Applicable Event	Device	(1) Event Start Date/Time	(2) Event End Date/Time	(3) Duration (Hrs)	Downtime (Hrs)	(4) Cause or Reason	(5) Applicable Regulation	(6) Type of Event	(7) Procedures Used (a),(b)	(8) Did Steps Taken Vary From (7)	(9) Did Event Cause Any Emission Limit Exceedance?	(10) Describe Emission Standard(s) Exceeded (b)	Completed By	(11) Date Entry Completed
			10/30/19 4:30	10/30/19 4:32	0.03		Rental Generator shutdown.	x 113: Inspection/Maintenance	Manual (Go to 7)	Procedures	Yes (Go to 9)	Yes (Go to 10)			
1	x Shutdown	A-51 Flare	10,00,10 1100	10,00,10 1102	0.00	668.50	Remained Off due to A60 starting on PG&E power.	116: Well Raising	x Automatic (Go to 9)	1 to 3	No	x No		Mike Chan	11/27/2019
'	x Startup	A-31 Flate	44/07/40 4:00	44/07/40 4 00	0.00	000.50	Generator startup 11/27/19	117: Gas Collection	x Manual (Go to 7)	Procedures	Yes (Go to 9)	Yes (Go to 10)		WIIKE CHAIT	11/21/2019
	Malfunction		11/27/19 1:00	11/27/19 1:02	0.03		during facility power outage.	118: Construction Activities	Automatic (Go to 9)	1 to 4	x No	No			
			44/07/40 4 40	44/07/40 4 50	0.00		Generator shutdown when A60	x 113: Inspection/Maintenance	Manual (Go to 7)	Procedures	Yes (Go to 9)	Yes (Go to 10)			
2	x Shutdown	A-51 Flare	11/27/19 1:48	11/27/19 1:50	0.03	295.27	back on with PG&E power.	116: Well Raising	x Automatic (Go to 9)	1 to 3	No	x No		Mike Chan	12/0/2010
2	x Startup	A-51 Flare	12/9/19 9:04	12/9/19 9:06	0.03	295.27	Generator startup 12/9/19 A60	117: Gas Collection	x Manual (Go to 7)	Procedures	Yes (Go to 9)	Yes (Go to 10)		- Mike Chan	12/9/2019
	Malfunction		12/9/19 9:04	12/9/19 9:00	0.03		maintenance.	118: Construction Activities	Automatic (Go to 9)	1 to 4	x No	No			
			12/12/19 14:22	12/12/19 14:24	0.03			x 113: Inspection/Maintenance	x Manual (Go to 7)	Procedures	Yes (Go to 9)	Yes (Go to 10)			
3	x Shutdown	A-51 Flare				94.00	Generator shutdown when A60	116: Well Raising	Automatic (Go to 9)	1 to 3	x No	No		Mike Chan	12/16/2019
	x Startup		12/16/19 12:22	12/16/19 12:24	0.03		back on with PG&E power.	117: Gas Collection	x Manual (Go to 7)	Procedures	Yes (Go to 9)	Yes (Go to 10)			
	Malfunction							118: Construction Activities	Automatic (Go to 9)	1 to 4	x No	No (O ( 10)			
	. Chutalaus		12/16/19 12:50	12/16/19 12:52	0.03			x 113: Inspection/Maintenance	x Manual (Go to 7)	Procedures 1 to 3	Yes (Go to 9)	Yes (Go to 10)			12/17/2019
4	x Shutdown	A-51 Flare				20.07	Operate system with A60 only.	116: Well Raising 117: Gas Collection	Automatic (Go to 9)  x Manual (Go to 7)		x No Yes (Go to 9)	No Yes (Go to 10)		Mike Chan	
	x Startup  Malfunction		12/17/19 8:54	12/17/19 8:56	0.03			118: Construction Activities	Automatic (Go to 9)	Procedures 1 to 4	x No	No			
	Ivialiuriction							x 113: Inspection/Maintenance	x Manual (Go to 7)	Procedures	Yes (Go to 9)	Yes (Go to 10)			
	x Shutdown		12/17/19 9:28	12/17/19 9:30	0.03			116: Well Raising	Automatic (Go to 9)	1 to 3	x No	No No			
5	x Startup	A-51 Flare				406.97	Operate system with A60 only.	117: Gas Collection	x Manual (Go to 7)	Procedures			Mike Chan	1/3/2020	
	Malfunction		1/3/20 8:26	1/3/20 8:28	0.03				Automatic (Go to 9)	1 to 4	x No	No			
	, manancuen							x 113: Inspection/Maintenance	x Manual (Go to 7)	Procedures	Yes (Go to 9)	Yes (Go to 10)	<del>                                     </del>	+ +	
	x Shutdown		1/3/20 9:28	1/3/20 9:30	0.03			116: Well Raising	Automatic (Go to 9)	1 to 3 x No	⊢ <sub>No</sub> ` ′				
6	x Startup	A-51 Flare	4/45/00 44:00	4/45/00 44:00	0.00	289.87	Operate system with A60 only.	117: Gas Collection	x Manual (Go to 7)	Procedures	Yes (Go to 9)	Yes (Go to 10)		Mike Chan	1/15/2020
	Malfunction		1/15/20 11:20	1/15/20 11:22	0.03			118: Construction Activities	Automatic (Go to 9)	1 to 4	x No	No			
			1/15/20 12:18	1/15/20 12:20	0.03			x 113: Inspection/Maintenance	x Manual (Go to 7)	Procedures	Yes (Go to 9)	Yes (Go to 10)			
7	x Shutdown	A-51 Flare	1/13/20 12.10	1/13/20 12.20	0.03	116.03	Operate system with A60 only.	116: Well Raising	Automatic (Go to 9)	1 to 3	x No	No		Mike Chan	1/20/2020
,	x Startup	A-311 late	1/20/20 8:20	1/20/20 8:22	0.03	110.03	Operate system with A00 only.	117: Gas Collection	x Manual (Go to 7)	Procedures	Yes (Go to 9)	Yes (Go to 10)		Wilke Chan	1/20/2020
	Malfunction		1720720 0.20	1720720 0.22	0.00			118: Construction Activities	Automatic (Go to 9)	1 to 4	x No	No			
	<u> </u>		1/20/20 9:58	1/20/20 10:00	0.03			x 113: Inspection/Maintenance	x Manual (Go to 7)	Procedures	Yes (Go to 9)	Yes (Go to 10)			
8	x Shutdown	A-51 Flare				21.30	Operate system with A60 only.	116: Well Raising	Automatic (Go to 9)	1 to 3	x No	No		Mike Chan	1/21/2020
	x Startup		1/21/20 7:16	1/21/20 7:18	0.03			117: Gas Collection	x Manual (Go to 7)	Procedures	Yes (Go to 9)	Yes (Go to 10)			
	Malfunction							118: Construction Activities	Automatic (Go to 9)	1 to 4	x No	No			
	. Chutalaus		1/21/20 12:00	1/21/20 12:02	0.03		Operate system with A60 only.	x 113: Inspection/Maintenance	x Manual (Go to 7)	Procedures 1 to 3	Yes (Go to 9)	Yes (Go to 10)			
9	x Shutdown	A-51 Flare				18.67	A51 Source Testing on January	116: Well Raising 117: Gas Collection	Automatic (Go to 9)  x Manual (Go to 7)	<u> </u>	x No	No Yes (Go to 10)		Mike Chan	1/22/2020
	x Startup Malfunction		1/22/20 6:40	1/22/20 6:42	0.03		22, 2020	118: Construction Activities	Automatic (Go to 9)	Procedures 1 to 4	Yes (Go to 9)	No			
	Manunction							x 113: Inspection/Maintenance	x Manual (Go to 7)	Procedures	Yes (Go to 9)	Yes (Go to 10)			1
	x Shutdown		1/22/20 12:06	1/22/20 12:08	0.03		A51 Source Testing on January	116: Well Raising	Automatic (Go to 9)	1 to 3	x No	No			
10	x Startup	A-51 Flare				1987.87	22, 2020. After test, operate	117: Gas Collection	x Manual (Go to 7)	Procedures	Yes (Go to 9)	Yes (Go to 10)		Mike Chan	4/14/2020
	Malfunction		4/14/20 7:58	4/14/20 8:00	0.03		system with A60 only.	118: Construction Activities	Automatic (Go to 9)	1 to 4	x No	No No			
	andnouon							x 113: Inspection/Maintenance	x Manual (Go to 7)	Procedures	Yes (Go to 9)	Yes (Go to 10)			
	x Shutdown		4/14/20 8:36	4/14/20 8:38	0.03	405.55	After both engines come back	116: Well Raising	Automatic (Go to 9)	1 to 3	x No	No			
11	x Startup	A-51 Flare	4/04/02 2 22	4/04/02 2 2 :	0.00	165.93	online, operate system with A60 only.	117: Gas Collection	x Manual (Go to 7)	Procedures	Yes (Go to 9)	Yes (Go to 10)		Mike Chan	4/21/2020
	Malfunction		4/21/20 6:32	4/21/20 6:34	0.03		Offity.	118: Construction Activities	Automatic (Go to 9)	1 to 4	x No	No (1			1

5/26/2020 RLI 2020.05 SAR Appendix v1.xlsx

# REDWOOD LANDFILL, INC. A-51 CONTROL DEVICE DOWNTIME LOG

Event No.	Check Applicable Event	Device	(1) Event Start Date/Time	(2) Event End Date/Time	(3) Duration (Hrs)	Downtime (Hrs)	(4) Cause or Reason	(5) Applicable Regulation		(6) Type of Event	(7) Procedures Used (a),(b)	(8) Did Steps Taken Vary From (7)	E	Cause Any Emission Limit	(10) Describe Emission Standard(s) Exceeded (b)	Completed By	(11) Date Entry Completed		
			4/21/20 6:46	4/21/20 6:48	0.03			x 113: Inspection/Maintenance	Х	Manual (Go to 7)	Procedures	Yes (Go to 9)		Yes (Go to 10)					
12	x Shutdown	A-51 Flare	4/21/20 0:40	472 1720 0.40	0.00	217.40	After swapping blowers on A60,	116: Well Raising		Automatic (Go to 9)	1 to 3	x No		No		Mike Chan	4/30/2020		
12	x Startup	A-011 laic	A-311 late	A-31 Flate	4/30/20 8:10	4/30/20 8:12	0.03	217.40	operate system with A60 only.	117: Gas Collection	Х	Manual (Go to 7)	Procedures	Yes (Go to 9)		Yes (Go to 10)		WIRE CHAIT	4/30/2020
	Malfunction		4/30/20 6.10	4/30/20 6.12	0.03			118: Construction Activities		Automatic (Go to 9)	1 to 4	x No		No					
			4/30/20 9:42	4/30/20 9:44	0.03	14.30	After Yokogawa maintenance, operate system with A60 only.	x 113: Inspection/Maintenance	Х	Manual (Go to 7)	Procedures	Yes (Go to 9)		Yes (Go to 10)					
40	13 X Shutdown A-5 Startup	A 54 51ama		4/30/20 9:44	0.03			116: Well Raising		Automatic (Go to 9)	1 to 3	x No		No		Miles Obser	F /4 /0000		
13		A-51 Flare		down as of May 1	2020			117: Gas Collection		Manual (Go to 7)	Procedures	Yes (Go to 9)		Yes (Go to 10)		Mike Chan	5/1/2020		
	Malfunction		A-51 shut down as of May 1, 2020		, 2020			118: Construction Activities		Automatic (Go to 9)	1 to 4	No		No					

5/26/2020 RLI 2020.05 SAR Appendix v1.xlsx

# REDWOOD LANDFILL, INC. A-60 ZONE A CONTROL DEVICE DOWNTIME LOG

Event No.	Check Applicable Event	Device	(1) Event Start Date/Time	(2) Event End Date/Time	(3) Duration (Hrs)	Downtime (Hrs)	(4) Cause or Reason	(5) Applicable Regulation	(6) Type of Event	(7) Procedures Used (a),(b)	(8) Did Steps Taken Vary From (7)	(9) Did Event Cause Any Emission Limit Exceedance?	(10) Describe Emission Standard(s) Exceeded (b)	Completed By	(11) Date Entry Completed
			11/7/19 10:48	11/7/19 10:50	0.03		M 101 11 1 1 1	x 113: Inspection/Maintenance	x Manual (Go to 7)	Procedures	Yes (Go to 9)	Yes (Go to 10)			
1	x Shutdown x Startup	A-60 Zone A				0.63	Manual Shutdown to disconnect generator from compressor.	116: Well Raising 117: Gas Collection	Automatic (Go to 9)  x Manual (Go to 7)	1 to 3 Procedures	x No Yes (Go to 9)	No Yes (Go to 10)		Mike Chan	11/7/2019
	Malfunction		11/7/19 11:26	11/7/19 11:28	0.03			118: Construction Activities	Automatic (Go to 9)	1 to 4	x No	No			
	1		44/07/40 0.00	44/07/40 0.00	0.00		All control devices were	x 113: Inspection/Maintenance	Manual (Go to 7)	Procedures	Yes (Go to 9)	Yes (Go to 10)			
2	x Shutdown	A-60 Zone A	11/27/19 0:28	11/27/19 0:30	0.03	1.37	shutdown due to a site-wide power outage. Inspected upon	116: Well Raising	x Automatic (Go to 9)	1 to 3	No `	x No `	Miles Ob ser	11/27/2019	
2	x Startup	A-00 Zone A	11/27/19 1:50	11/27/19 1:52	0.03	1.37	restart of the control devices.	117: Gas Collection	x Manual (Go to 7)	Procedures	Yes (Go to 9)	Yes (Go to 10)		Mike Chan	11/2//2019
	Malfunction		11/21/10 1.00	11/2//10 1.02	0.00		Visual inspections and PLC	118: Construction Activities	Automatic (Go to 9)	1 to 4	x No	No			
	L		12/9/19 9:00	12/9/19 9:02	0.03			x 113: Inspection/Maintenance	x Manual (Go to 7)	Procedures	Yes (Go to 9)	Yes (Go to 10)			
3	x Shutdown	A-60 Zone A				77.27	Manual Shutdown for piping Willexa to A60A side.	116: Well Raising 117: Gas Collection	Automatic (Go to 9)  x Manual (Go to 7)	1 to 3	x No Yes (Go to 9)	No Yes (Go to 10)		Mike Chan	12/12/2019
	x Startup Malfunction		12/12/19 14:16	12/12/19 14:18	0.03		Willexa to AooA side.	118: Construction Activities	Automatic (Go to 9)	Procedures 1 to 4	x No	No			
	Ivialiunction							x 113: Inspection/Maintenance	x Manual (Go to 7)	Procedures	Yes (Go to 9)	Yes (Go to 10)			
	x Shutdown		12/16/19 12:20	12/16/19 12:22	0.03		Manual Shutdown for	116: Well Raising	Automatic (Go to 9)	1 to 3	x No	No No			
4	x Startup	A-60 Zone A	40/40/40 40:50	40/40/40 40-54	0.00	0.53	maintenance & programing.	117: Gas Collection	x Manual (Go to 7)	Procedures	Yes (Go to 9)	Yes (Go to 10)		Mike Chan	12/16/2019
	Malfunction	12/	12/16/19 12:52	12/16/19 12:54	0.03			118: Construction Activities	Automatic (Go to 9)	1 to 4	x No	No			
			12/17/19 8:50	12/17/19 8:52	0.03			x 113: Inspection/Maintenance	x Manual (Go to 7)	Procedures	Yes (Go to 9)	Yes (Go to 10)			
5	x Shutdown	A-60 Zone A	12/11/10 0.00	12/1//10 0.02	0.00	0.53	Manual Shutdown for	116: Well Raising	Automatic (Go to 9)	1 to 3	x No	No		Mike Chan	12/17/2019
Ü	x Startup	7. 00 _0	12/17/19 9:22	12/17/19 9:24	0.03	0.00	maintenance.	117: Gas Collection	x Manual (Go to 7)	Procedures	Yes (Go to 9)	Yes (Go to 10)		1	
	Malfunction							118: Construction Activities	Automatic (Go to 9)	1 to 4	x No	No (O ( 10)			
	Churtdauur		12/17/19 10:06	12/17/19 10:08	0.03		I	x 113: Inspection/Maintenance	Manual (Go to 7)	Procedures 1 to 3	Yes (Go to 9)	Yes (Go to 10)			
6	x Shutdown x Startup	A-60 Zone A				0.07	Flame alarm shutdown. System inspected after restart.	116: Well Raising 117: Gas Collection	x Automatic (Go to 9) x Manual (Go to 7)	Procedures	No Yes (Go to 9)	Yes (Go to 10)		Mike Chan	12/17/2019
	Malfunction		12/17/19 10:10	12/17/19 10:12	0.03		mopeoted after restart.	118: Construction Activities	Automatic (Go to 9)	1 to 4	x No	No			1
	Mananodon							x 113: Inspection/Maintenance	Manual (Go to 7)	Procedures	Yes (Go to 9)	Yes (Go to 10)			
7	x Shutdown	A 00 7 A	12/18/19 15:58	12/18/19 16:00	0.03	0.07	Flame alarm shutdown. System	116: Well Raising	x Automatic (Go to 9)	1 to 3	No	x No		Miles Observ	40/40/0046
1	x Startup	A-60 Zone A	12/18/19 16:02	12/18/19 16:04	0.03	0.07	inspected after restart.	117: Gas Collection	x Manual (Go to 7)	Procedures	Yes (Go to 9)	Yes (Go to 10)		Mike Chan	12/18/2019
	Malfunction		12/10/19 10.02	12/16/19 10:04	0.03			118: Construction Activities	Automatic (Go to 9)	1 to 4	x No	No			
			1/3/20 8:24	1/3/20 8:26	0.03			x 113: Inspection/Maintenance	x Manual (Go to 7)	Procedures	Yes (Go to 9)	Yes (Go to 10)			
8	x Shutdown	A-60 Zone A				1.10	Manual Shutdown for	116: Well Raising	Automatic (Go to 9)	1 to 3	x No	No		Mike Chan	1/3/2020
	x Startup		1/3/20 9:30	1/3/20 9:32	0.03		maintenance.	117: Gas Collection	x Manual (Go to 7)	Procedures	Yes (Go to 9)	Yes (Go to 10)			
	Malfunction							118: Construction Activities  x 113: Inspection/Maintenance	Automatic (Go to 9)  x Manual (Go to 7)	1 to 4 Procedures	x No Yes (Go to 9)	No Yes (Go to 10)			
	x Shutdown		1/15/20 11:12	1/15/20 11:14	0.03		Manual Shutdown for	116: Well Raising	Automatic (Go to 9)	1 to 3	x No	No			
9	x Startup	A-60 Zone A				1.13	maintenance.	117: Gas Collection	x Manual (Go to 7)	Procedures	Yes (Go to 9)	Yes (Go to 10)		Mike Chan	1/15/2020
	Malfunction		1/15/20 12:20	1/15/20 12:22	0.03			118: Construction Activities	Automatic (Go to 9)	1 to 4	x No	No			
			1/20/20 8:18	1/20/20 8:20	0.03			x 113: Inspection/Maintenance	x Manual (Go to 7)	Procedures	Yes (Go to 9)	Yes (Go to 10)			
10	x Shutdown	A-60 Zone A	1/20/20 0.10	1/20/20 6.20	0.03	1.57	Manual Shutdown for	116: Well Raising	Automatic (Go to 9)	1 to 3	x No	No		Mike Chan	1/20/2020
10	x Startup	71 00 2010 71	1/20/20 9:52	1/20/20 9:54	0.03	1.07	maintenance.	117: Gas Collection	x Manual (Go to 7)	Procedures	Yes (Go to 9)	Yes (Go to 10)		Wilke Grian	1/20/2020
	Malfunction		.,20,20 0.02	.,_0,_0 0.0 .	0.00			118: Construction Activities	Automatic (Go to 9)	1 to 4	x No	No			
			1/21/20 7:14	1/21/20 7:16	0.03		Manual Ob. 11	x 113: Inspection/Maintenance	x Manual (Go to 7)	Procedures	Yes (Go to 9)	Yes (Go to 10)			
11	x Shutdown x Startup	A-60 Zone A				4.80	Manual Shutdown for maintenance.	116: Well Raising	Automatic (Go to 9)	1 to 3	x No Yes (Go to 9)	No Yes (Go to 10)		Mike Chan	1/21/2020
	X Startup  Malfunction		1/21/20 12:02	1/21/20 12:04	0.03		mannenance.	117: Gas Collection 118: Construction Activities	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4	x No	No			
	Manufiction							x 113: Inspection/Maintenance	x Manual (Go to 7)	Procedures	Yes (Go to 9)	Yes (Go to 10)			
	x Shutdown		1/22/20 6:38	1/22/20 6:40	0.03		Manual Shutdown for A51	116: Well Raising	Automatic (Go to 9)	1 to 3	x No	No			
12	x Startup	A-60 Zone A	4/00/00 40:00	4/00/00 40 40	0.00	5.50		117: Gas Collection	x Manual (Go to 7)	Procedures	Yes (Go to 9)	Yes (Go to 10)	Mike Chan	1/22/2020	
		1	1/22/20 12:08	1/22/20 12:10	0.03	Ī	ı	118: Construction Activities	Automatic (Go to 9)		x No	No ( )			

No A-60 Zone A SSM events in February 2020

5/26/2020 RLI 2020.05 SAR Appendix v1.xlsx

## REDWOOD LANDFILL, INC.

#### A-60 ZONE A CONTROL DEVICE DOWNTIME LOG

Event No.	Check Applicable Event	Device	(1) Event Start Date/Time	(2) Event End Date/Time	(3) Duration (Hrs)	Downtime (Hrs)	(4) Cause or Reason	(5) Applicable Regulation	(6) Type of Event	(7) Procedures Used (a),(b)	(8) Did Steps Taken Vary From (7)	(9) Did Event Cause Any Emission Limit Exceedance?	(10) Describe Emission Standard(s) Exceeded (b)	Completed By	(11) Date Entry Completed
							No A-60 Zo	one A SSM events in Ma	rch 2020						
13	x Shutdown	A-60 Zone A	4/21/20 6:30	4/21/20 6:32	0.03	0.30	Manual Shutdown for swapping	x 113: Inspection/Maintenance 116: Well Raising	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 3	Yes (Go to 9) x No	Yes (Go to 10) No		Mike Chan	4/21/2020
13	x Startup Malfunction	A-00 Zone A	4/21/20 6:48	4/21/20 6:50	0.03	0.30	blowers on A60	117: Gas Collection 118: Construction Activities	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4	Yes (Go to 9) x No	Yes (Go to 10) No		WING CHAIT	4/21/2020
1.1	x Shutdown	A CO 7 A	4/30/20 8:10	4/30/20 8:12	0.03	4.57	Manual Shutdown for Yokogawa	x 113: Inspection/Maintenance 116: Well Raising	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 3	Yes (Go to 9)	Yes (Go to 10) No		Miles Chair	4/20/2020
14	x Startup Malfunction	A-60 Zone A	4/30/20 9:44	4/30/20 9:46	0.03	1.57	maintenance on A60	117: Gas Collection 118: Construction Activities	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4	Yes (Go to 9) x No	Yes (Go to 10) No		Mike Chan	4/30/2020

# REDWOOD LANDFILL, INC. A-60 ZONE B CONTROL DEVICE DOWNTIME LOG

Even	Check Applicable Event	Device	(1) Event Start Date/Time	(2) Event End Date/Time	(3) Duration (Hrs)	Downtime (Hrs)	(4) Cause or Reason	(5) Applicable Regulation	(6) Type of Event	(7) Procedures Used (a),(b)	(8) Did Steps Taken Vary From (7)	(9) Did Event Cause Any Emission Limit Exceedance?	(10) Describe Emission Standard(s) Exceeded (b)	Completed By	(11) Date Entry Completed
			11/7/19 10:48	11/7/19 10:50	0.03			x 113: Inspection/Maintenance	x Manual (Go to 7)	Procedures 1 to 3	Yes (Go to 9)	Yes (Go to 10)			
1	x Shutdown	A-60 Zone B				0.73	Manual Shutdown to disconnect generator from compressor.	116: Well Raising	Automatic (Go to 9)		x No	No		Mike Chan	11/7/2019
	x Startup Malfunction		11/7/19 11:32	11/7/19 11:34	0.03		generator from compressor.	117: Gas Collection 118: Construction Activities	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4	Yes (Go to 9)	Yes (Go to 10)			
	Mananoton		11/27/19 0:28	11/27/19 0:30	0.03		All control devices were	x 113: Inspection/Maintenance	Manual (Go to 7)	Procedures	Yes (Go to 9)	Yes (Go to 10)			
2	x Shutdown	A-60 Zone B	11/27/19 0.20	11/21/19 0.30	0.03	1.43	shutdown due to a site-wide power outage. Inspected upon	116: Well Raising	x Automatic (Go to 9)	1 to 3	No	x No		Mike Chan	11/27/2019
	x Startup	7. 00 Zone B	11/27/19 1:54	11/27/19 1:56	0.03	1.40	restart of the control devices.  Visual inspections and PLC	117: Gas Collection	x Manual (Go to 7)	Procedures	Yes (Go to 9)	Yes (Go to 10)		Will Contain	11/21/2010
	Malfunction		11/2//10 1.04	11/2//10 1.00	0.00		checks were conducted.	118: Construction Activities	Automatic (Go to 9)	1 to 4	x No	No			
			12/9/19 9:00	12/9/19 9:02	0.03		Manual Shutdown for piping	x 113: Inspection/Maintenance	x Manual (Go to 7)	Procedures 1 to 3	Yes (Go to 9)	Yes (Go to 10)			
3	x Shutdown	A-60 Zone B				218.80	Willexa to A60A side. Running	116: Well Raising	Automatic (Go to 9)		x No	No		Mike Chan	12/18/2019
	x Startup Malfunction		12/18/19 11:48	12/18/19 11:50	0.03		on A60A only.	117: Gas Collection 118: Construction Activities	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4	Yes (Go to 9) x No	Yes (Go to 10) No			
	Ľ		12/18/19 13:28	12/18/19 13:30	0.03			x 113: Inspection/Maintenance	x Manual (Go to 7)	Procedures	Yes (Go to 9)	Yes (Go to 10)	1		
4	x Shutdown	A-60 Zone B	12/10/10 10.20	12/10/10 10:00	0.00	3226.53	Manual shutdown. Running on	116: Well Raising	Automatic (Go to 9)	1 to 3	x No	No		Mike Chan	5/1/2020
	Startup Malfunction	→ IA-60 Zone B →	Zone B shut	t down as of May 1	, 2020	0220.00	A60A only.	117: Gas Collection 118: Construction Activities	Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4	Yes (Go to 9)	Yes (Go to 10)		Willio Offair	0, 1,2020

#### (a) STANDARD OPERATING PROCEDURES

#### Shutdown

Procedure No. Procedure

- Ensure that there is no unsafe conditions present, contact manager immediately Initiate shutdown sequence below by one or more of the following (Note date and time in Section 1 of form above) a. Press Emergency Stop if necessary b. Close On/Off switch(es) or Push On/Off button(s)

  - c. Close adjacent valves if necessary

    Observe that system achieves normal shutdown ranges for levels, pressures, and temperatures (Note date and time in Section 2 of form above)

#### 3. Startup

Procedure No. Procedure

- Ensure that there is no unsafe conditions present
  Ensure that the system is ready to start by one of the following:

  - a. Valves are in correct position
     b. Levels, pressures, and temperatures are within normal starting range

  - c. Alarms are cleared
    d. Power is on and available to control panel and ready to energized equipment.
- e. Emergency stop is de-energized
  Initiate start sequence (Note time and date in section 1 of form above)
  Observe that system achieves normal shutdown ranges for levels, pressures, and temperatures (Note time and date in Section 2 of form above)

#### Malfunction

EQUIPMENT	PURPOSE	MALFUNCTION	COMMON CAUSES	PROCEDURE NOTYPICAL RESPONSE ACTIONS
EQUI MENT	I CKI OSE	EVENT	OCHMINICIT GAGGES	TROOLEGIC NOTIT TOAL NEGI GNOL ACTIONS
LFG Collection and Control Sy	stem	EVENI		
Blower or Other Gas Mover	Applies vacuum to wellfield	Loss of LFG Flow/Blower	-Flame arrestor fouling/deterioration	Repair breakages in extraction piping
Equipment	to control device		-Automatic valve problems -Blower failure (e.g., belt, motor, impeller, coupling, seizing, etc.) -Loss of power -Extraction piping failure -Condensate knock-out problems -Extraction piping blockages	2. Clean flame arrestor 3. Repair blockages in extraction piping 4. Verify automatic valve operation, compressed air/nitrogen supply 5. Notify power utility, if appropriat 6. Provide/utilize auxiliary power source, if necessar 7. Repair Settlement in Collection Piping 8. Repair Blower 9. Activate back-up blower, if available 10. Clean knock-up pot/demister 11. Drain knock-out pot
Extraction Wells and Collection	Conduits for extractions and	Collection well and pipe	-Break/crack in header or lateral piping	12. Repair leaks or breaks in lines or wellheads
Piping	movement of LFG flow	failures	-Leaks at wellheads, valves, flanges, Test ports, seals, couplings, etcCollection piping blockages -Problems due to settlement (e.g. pipe separation, deformation, development of low points	Follow procedures for loss of LFG flow/blower malfunction     H4. Repair blockages in collection piping     Follow procedures the collection piping     Re-install, repair, or replace piping
Blower or Other Gas Mover	Collection and control of	Loss of electrical power	- Force majeure/Act of God (e.g., lightning, flood,	17. Check/reset breaker
Equipment And Control Device	LFG		earthquake, etc.) -Area-wide or local blackout or brown-ou -Interruption in service (e.g. blown service fuse -Electrical line failure -Breaker trip -Transformer failure -Motor starter failure/trip -Overdraw of power -Problems in electrical panel -Damage to electrical equipment from on-site operations	18. Check/repair electrical panel component: 19. Check/repair transformer 20. Check/repair motor starter 21. Check/repair electrical line 22. Test amperage to various equipment 23. Contact electricity supplies 24. Contact/contract electrician 25. Provide auxiliary power (if necessary
LFG Control Device	Combusts LFG	Low temperature conditions	-Problems with temperature -monitoring equipmen	26. Check/repair temperature monitoring equipment
		at control device	-Problems failure of -thermocouple and/or thermocouple wiring  -Change of LFG flow  -Change of LFG quality  -Problems with air louvers  -Problems with airfuel controls  -Change in atmospheric conditions	Check/repair thermocouple and/or wiring     Sellow procedures for loss of flow/blower malfunction     Check/adjust louvers     Check/adjust air/fuel controls
LFG Control Device	Combusts LFG	Loss of Flame	-Problems/failure of thermocouph -Loss/change of LFG flow -Loss/change of LFG quality	Check/repair temperature monitoring equipment     Check/repair thermocoupk     Sollow procedures for loss of flow/blower malfunction
		No. 10 and	-Problems with air/fuel controls -Problems/failure of flame sensor -Problems with temperature monitoring equipmen	34. Check/adjust air/fuel controls 35. Check/adjust/repair flame sensor 36. Check/adjust LFG collectors
Flow Monitoring/	Measures and records gas flow from collection system	Malfunctions of Flow Monitoring/Recording	-Problems with orifice plate, pitot tube, or other in-line flow measuring device	37. Check/adjust/repair flow measuring device and/or wiring
Recording Device	to control	Device Device	-Problems with device controls and/or wiring -Problems with chart recorder	38. Check/repair chart recorder 39. Replace paper in chart recorder
Temperature Monitoring/ Recording Device	Monitors and records combustion temperature of enclosed combustion device	Malfunctions of Temperature Monitoring/Recording Device	-Problems with thermocouple     -Problems with device controls and/or wiring     -Problems with chart recorder	40. Check/adjust/repair thermocouple 41. Check/adjust/repair controller and/or wiring 42. Check/adjust/repair electrical panel component 43. Check/repair chart recorder 44. Replace paper in chart recorder
Control Device	Combusts LFG	Other Control Device Malfunctions	-Control device smoking (i.e. visible emissions) -Problems with flare insulation -Problems with pilot light system -Problems with air louvers -Problems with airfled controllers -Problems with thermocouple -Problems with thermocouple -Problems with burners -Problems with burners -Problems with flame arrester -Alarmed malfunction conditions not covered abov -Unalarmed conditions discovered during inspection not covered abov	45. Site-specific diagnosis procedure: 46. Site-specific responses actions based on diagnosis 47. Open manual louvers 48. Clean pitot orifice 49. Clean/drain flame arrestor 50. Refill propane supply 51. Check/repair pilot sparking system

(b) For each permit limit exceedance complete an "SSM Plan Departure Form".

RLI 2020.05 SAR Appendix v1.xlsx Proc(2) 5/26/2020

Event No.	Check Applicable Event	Device	(1) Event Start Date/Time	(2) Event End Date/Time	(3) Duration (Hrs)	Downtime (Hrs)	(4) Cause or Reason		(5) Applicable Regulation	(6) Type of Event	(7) Procedures Used (a),(b)		(8) Did Steps aken Vary From (7)	E	(9) Did Event Cause Any Emission Limit Exceedance?	(10) Describe Emission Standard(s) Exceeded (b)	Completed By	(11) Date Entry Completed
1	x Shutdown	Engine #1	11/8/19 8:00	11/8/19 8:02	0.03	0.59	Oil Change	х	113: Inspection/Maintenance 116: Well Raising	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 3		Yes (Go to 9) No		Yes (Go to 10) No	, ,	P Madison	11/9/2010
ľ	x Startup Malfunction	(S-64)	11/8/19 8:35	11/8/19 8:37	0.03	0.58	Oil Change	$\vdash$	117: Gas Collection 118: Construction Activities	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4	_	Yes (Go to 9) No		Yes (Go to 10) No		Piviadison	11/8/2019
0	x Shutdown	Engine #1	11/10/19 18:35	11/10/19 18:37	0.03	0.50	O'll leave leave founds	Х	113: Inspection/Maintenance 116: Well Raising	Manual (Go to 7) x Automatic (Go to 9)	Procedures 1 to 3		Yes (Go to 9) No		Yes (Go to 10) No		D.M. die	44/40/0040
2	x Startup Malfunction	(S-64)	11/10/19 21:05	11/10/19 21:07	0.03	2.50	Oil leveler fault		117: Gas Collection 118: Construction Activities	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4		Yes (Go to 9) No		Yes (Go to 10) No		P Madison	11/10/2019
3	x Shutdown	Engine #1	11/12/19 1:00	11/12/19 1:02	0.03	1.40	oil loveler foult	Х	113: Inspection/Maintenance 116: Well Raising	Manual (Go to 7) x Automatic (Go to 9)	Procedures 1 to 3		Yes (Go to 9) No		Yes (Go to 10) No		D Madison	11/12/2019
3	x Startup Malfunction	(S-64)	11/12/19 2:25	11/12/19 2:27	0.03	1.42	oil leveler fault		117: Gas Collection 118: Construction Activities	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4		Yes (Go to 9) No		Yes (Go to 10) No		P Madison	11/12/2019
4	x Shutdown	Engine #1	11/18/19 3:00	11/18/19 3:02	0.03	7.22	Lowellloyel	Х	113: Inspection/Maintenance 116: Well Raising	Manual (Go to 7) x Automatic (Go to 9)	Procedures 1 to 3		Yes (Go to 9) No		Yes (Go to 10) No		P Madison	11/18/2019
4	x Startup Malfunction	(S-64)	11/18/19 10:20	11/18/19 10:22	0.03	7.33	Low oil level	$\vdash$	117: Gas Collection 118: Construction Activities	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4		Yes (Go to 9) No		Yes (Go to 10) No		Piviadison	11/10/2019
5	x Shutdown	Engine #1	11/18/19 14:10	11/18/19 14:12	0.03	0.92	Low Oil Level	Х	<ul><li>113: Inspection/Maintenance</li><li>116: Well Raising</li></ul>	Manual (Go to 7) x Automatic (Go to 9)	Procedures 1 to 3		Yes (Go to 9) No		Yes (Go to 10) No		P Madison	11/18/2019
J	x Startup Malfunction	(S-64)	11/18/19 15:05	11/18/19 15:07	0.03	0.92	Low Oil Level	$\vdash$	<ul><li>117: Gas Collection</li><li>118: Construction Activities</li></ul>	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4	_	Yes (Go to 9) No		Yes (Go to 10) No		i iviauisori	11/10/2019
6	x Shutdown	Engine #1	11/27/19 0:30	11/27/19 0:32	0.03	1.00	Loss of utlity	Х	<ul><li>113: Inspection/Maintenance</li><li>116: Well Raising</li></ul>	Manual (Go to 7) x Automatic (Go to 9)	Procedures 1 to 3		Yes (Go to 9) No	-	Yes (Go to 10) No		P Madison	11/27/2019
	x Startup Malfunction	(S-64)	11/27/19 1:30	11/27/19 1:32	0.03	1.00	2000 Of duity		117: Gas Collection 118: Construction Activities	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4	-	Yes (Go to 9) No	$\vdash$	Yes (Go to 10) No		1 Madioon	11/21/2010
7	x Shutdown	Engine #1	12/7/19 7:40	12/7/19 7:42	0.03	1.00	Detonation Cylinder #20	Х	113: Inspection/Maintenance 116: Well Raising	Manual (Go to 7) x Automatic (Go to 9)	Procedures 1 to 3		Yes (Go to 9) No	х	Yes (Go to 10) No		P Madison	12/7/2019
	x Startup Malfunction	(S-64)	12/7/19 8:40	12/7/19 8:42	0.03		200.10.07		117: Gas Collection 118: Construction Activities	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4	_	Yes (Go to 9) No	-	Yes (Go to 10) No			12,172010
8	x Shutdown	Engine #1	12/9/19 9:30	12/9/19 9:32	0.03	192.00	Repairs to flare	Х	113: Inspection/Maintenance 116: Well Raising	Manual (Go to 7) x Automatic (Go to 9)	Procedures 1 to 3		Yes (Go to 9) No	-	Yes (Go to 10) No		P Madison	12/20/2019
	x Startup Malfunction	(S-64)	12/17/19 9:30	12/17/19 9:32	0.03				117: Gas Collection 118: Construction Activities	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4	х			Yes (Go to 10) No			
9	x Shutdown	Engine #1	12/17/19 10:30	12/17/19 10:32	0.03	20.50	Repairs to flare		113: Inspection/Maintenance 116: Well Raising	Manual (Go to 7) x Automatic (Go to 9)	Procedures 1 to 3		Yes (Go to 9) No	х	Yes (Go to 10) No		P Madison	12/20/2019
	x Startup Malfunction	(S-64)	12/18/19 7:00	12/18/19 7:02	0.03		'		117: Gas Collection 118: Construction Activities	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4	Х	Yes (Go to 9) No		Yes (Go to 10) No			
10	x Shutdown	Engine #1	12/19/19 9:45	12/19/19 9:47	0.03	26.50	Repairs to flare		113: Inspection/Maintenance 116: Well Raising	Manual (Go to 7) x Automatic (Go to 9)	Procedures 1 to 3		Yes (Go to 9) No	х	Yes (Go to 10) No		P Madison	12/20/2019
	x Startup Malfunction	(S-64)	12/20/19 12:15	12/20/19 12:17	0.03		,		117: Gas Collection 118: Construction Activities	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4		Yes (Go to 9) No		Yes (Go to 10) No			
11	x Shutdown	Engine #1	12/30/19 19:30	12/30/19 19:32	0.03	0.67	Low voltage exhaust sensor		113: Inspection/Maintenance 116: Well Raising	Manual (Go to 7)  x Automatic (Go to 9)	Procedures 1 to 3		Yes (Go to 9) No	х	Yes (Go to 10) No		P Madison	12/30/2019
	x Startup Malfunction	(S-64)	12/30/19 20:10	12/30/19 20:12	0.03		Cylinder 17		117: Gas Collection 118: Construction Activities	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4	_	Yes (Go to 9) No		Yes (Go to 10) No			
12	x Shutdown	Engine #1 (S-64)	12/31/19 7:00	12/31/19 7:02	0.03	3.83	exhaust sensor Cylinder 17 replacement		113: Inspection/Maintenance 116: Well Raising	Manual (Go to 7)  x Automatic (Go to 9)	Procedures 1 to 3		Yes (Go to 9) No	х	Yes (Go to 10) No		P Madison	12/31/2019
	x Startup Malfunction	(3-04)	12/31/19 10:50	12/31/19 10:52	0.03		геріасетіепі	$\vdash$	<ul><li>117: Gas Collection</li><li>118: Construction Activities</li></ul>	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4	_	Yes (Go to 9) No	-	Yes (Go to 10) No			

Event No.	Check Applicable Event	Device	(1) Event Start Date/Time	(2) Event End Date/Time	(3) Duration (Hrs)	Downtime (Hrs)	(4) Cause or Reason		(5) Applicable Regulation	(6) Type of Event	(7) Procedures Used (a),(b)		(8) Did Steps aken Vary From (7)	E	(9) Did Event Cause Any Emission Limit Exceedance?	(10) Describe Emission Standard(s) Exceeded (b)	Completed By	(11) Date Entry Completed
13	x Shutdown	Engine #1	12/31/19 12:25	12/31/19 12:27	0.03	0.58	Oil & Filter Change	Х	113: Inspection/Maintenance 116: Well Raising	Manual (Go to 7) x Automatic (Go to 9)	Procedures 1 to 3		Yes (Go to 9) No	Х	Yes (Go to 10) No		P Madison	12/31/2019
.0	x Startup  Malfunction	(S-64)	12/31/19 13:00	12/31/19 13:02	0.03	0.00	on a rinter original		<ul><li>117: Gas Collection</li><li>118: Construction Activities</li></ul>	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4	_	Yes (Go to 9) No		Yes (Go to 10) No		i Madicon	12/01/2010
14	x Shutdown	Engine #1	1/5/20 0:35	1/5/20 0:37	0.03	5.58	Low oil fault	Х	<ul><li>113: Inspection/Maintenance</li><li>116: Well Raising</li></ul>	Manual (Go to 7)  x Automatic (Go to 9)	Procedures 1 to 3		Yes (Go to 9) No	-	Yes (Go to 10) No		P Madison	1/5/2020
14	x Startup Malfunction	(S-64)	1/5/20 6:10	1/5/20 6:12	0.03	5.50	LOW OII TAUIT		<ul><li>117: Gas Collection</li><li>118: Construction Activities</li></ul>	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4	-	Yes (Go to 9) No		Yes (Go to 10) No		i iviauisoii	1/3/2020
15	x Shutdown	Engine #1	1/6/20 3:20	1/6/20 3:22	0.03	3.00	High Engine Oil to Engine	Х	<ul><li>113: Inspection/Maintenance</li><li>116: Well Raising</li></ul>	Manual (Go to 7) x Automatic (Go to 9)	Procedures 1 to 3		Yes (Go to 9) No		Yes (Go to 10) No		P Madison	1/6/2020
15	x Startup Malfunction	(S-64)	1/6/20 6:20	1/6/20 6:22	0.03	3.00	coolant Diff Temp		<ul><li>117: Gas Collection</li><li>118: Construction Activities</li></ul>	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4	_	Yes (Go to 9) No		Yes (Go to 10) No		Piviadison	1/0/2020
16	x Shutdown	Engine #1	1/7/20 11:50	1/7/20 11:52	0.03	0.05	Oil Loydor - Street	Х	<ul><li>113: Inspection/Maintenance</li><li>116: Well Raising</li></ul>	Manual (Go to 7)  x Automatic (Go to 9)	Procedures 1 to 3		Yes (Go to 9) No		Yes (Go to 10) No		D Modicari	1/7/0000
16	x Startup Malfunction	(S-64)	1/7/20 12:05	1/7/20 12:07	0.03	0.25	Oil Leveler malfunction		117: Gas Collection 118: Construction Activities	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4		Yes (Go to 9) No		Yes (Go to 10) No		P Madison	1/7/2020
17	x Shutdown	Engine #1	1/7/20 12:25	1/7/20 12:27	0.03	0.05		Х	113: Inspection/Maintenance 116: Well Raising	Manual (Go to 7) x Automatic (Go to 9)	Procedures 1 to 3		Yes (Go to 9) No		Yes (Go to 10) No		D Madiaan	4 /7/0000
17	x Startup Malfunction	(S-64)	1/7/20 12:40	1/7/20 12:42	0.03	0.25	Oil Leveler malfunction		<ul><li>117: Gas Collection</li><li>118: Construction Activities</li></ul>	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4	_	Yes (Go to 9) No		Yes (Go to 10) No		P Madison	1/7/2020
40	x Shutdown	Engine #1	1/8/20 7:25	1/8/20 7:27	0.03	0.05	O'll and a mark to make	Х	<ul><li>113: Inspection/Maintenance</li><li>116: Well Raising</li></ul>	Manual (Go to 7) x Automatic (Go to 9)	Procedures 1 to 3		Yes (Go to 9) No		Yes (Go to 10) No		D.M. diam.	4 /0 /0000
18	x Startup Malfunction	(S-64)	1/8/20 7:40	1/8/20 7:42	0.03	0.25	Oil Leveler malfunction		<ul><li>117: Gas Collection</li><li>118: Construction Activities</li></ul>	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4	-	Yes (Go to 9) No		Yes (Go to 10) No		P Madison	1/8/2020
	x Shutdown	Engine #1	1/8/20 13:30	1/8/20 13:32	0.03		Shutdown for Air Compressor	Х	113: Inspection/Maintenance 116: Well Raising	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 3	_	Yes (Go to 9) No		Yes (Go to 10) No			
19	x Startup Malfunction	(S-64)	1/8/20 14:20	1/8/20 14:22	0.03	0.83	Installation		117: Gas Collection 118: Construction Activities	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4		Yes (Go to 9) No		Yes (Go to 10) No		P Madison	1/8/2020
	x Shutdown	Engine #1	1/9/20 12:40	1/9/20 12:42	0.03		Shutdown for Air Compressor	х	113: Inspection/Maintenance 116: Well Raising	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 3	_	Yes (Go to 9) No		Yes (Go to 10) No			
20	x Startup Malfunction	(S-64)	1/9/20 13:50	1/9/20 13:52	0.03	1.17	Installation		117: Gas Collection 118: Construction Activities	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4	х	Yes (Go to 9) No		Yes (Go to 10) No		P Madison	1/9/2020
0.1	x Shutdown	Engine #1	1/16/20 11:35	1/16/20 11:37	0.03	0.47	51 JF 6 J		113: Inspection/Maintenance 116: Well Raising	Manual (Go to 7)  x Automatic (Go to 9)	Procedures 1 to 3		Yes (Go to 9) No		Yes (Go to 10) No		5.M .E	4/40/0000
21	x Startup  Malfunction	(S-64)	1/16/20 11:45	1/16/20 11:47	0.03	0.17	Exhaust Temp. Deviation		117: Gas Collection 118: Construction Activities	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4	_	Yes (Go to 9) No		Yes (Go to 10) No		P Madison	1/16/2020
00	x Shutdown	Engine #1	1/16/20 12:00	1/16/20 12:02	0.03	0.00	Edward Tarres Davidson	Х	<ul><li>113: Inspection/Maintenance</li><li>116: Well Raising</li></ul>	Manual (Go to 7) x Automatic (Go to 9)	Procedures 1 to 3		Yes (Go to 9) No		Yes (Go to 10) No		D.M. diam.	4/40/0000
22	x Startup Malfunction	(S-64)	1/16/20 15:00	1/16/20 15:02	0.03	3.00	Exhaust Temp. Deviation		<ul><li>117: Gas Collection</li><li>118: Construction Activities</li></ul>	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4	х	Yes (Go to 9) No	-	Yes (Go to 10) No		P Madison	1/16/2020
00	x Shutdown	Engine #1	1/19/20 10:40	1/19/20 10:42	0.03	4.00		Х	<ul><li>113: Inspection/Maintenance</li><li>116: Well Raising</li></ul>	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 3	_	Yes (Go to 9) No	$\vdash$	Yes (Go to 10) No		D.M. die	4/40/0040
23	x Startup Malfunction	(S-64)	1/19/20 11:45	1/19/20 11:47	0.03	1.08	EEE high voltage testing		<ul><li>117: Gas Collection</li><li>118: Construction Activities</li></ul>	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4		Yes (Go to 9) No	$\vdash$	Yes (Go to 10) No		P Madison	1/19/2019
0.4	x Shutdown	Engine #1	1/20/20 8:25	1/20/20 8:27	0.03	7.47		Х	<ul><li>113: Inspection/Maintenance</li><li>116: Well Raising</li></ul>	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 3		Yes (Go to 9) No	$\vdash$	Yes (Go to 10) No		D.M at	4/00/0000
24	x Startup Malfunction	(S-64)	1/20/20 15:35	1/20/20 15:37	0.03	7.17	EEE high voltage testing		117: Gas Collection 118: Construction Activities	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4		Yes (Go to 9) No	-	Yes (Go to 10) No		P Madison	1/20/2020

Event No.	Check Applicable Event	Device	(1) Event Start Date/Time	(2) Event End Date/Time	(3) Duration (Hrs)	Downtime (Hrs)	(4) Cause or Reason	(5) Applicable Regulation	(6) Type of Event	(7) Procedures Used (a),(b)	(8) Did Steps Taken Vary From (7)	(9) Did Event Cause Any Emission Limit Exceedance?	(10) Describe Emission Standard(s) Exceeded (b)	Completed By	(11) Date Entry Completed
25	x Shutdown	Engine #1	2/5/20 9:10	2/5/20 9:12	0.03	4.42	Oil,filter & valve service	x 113: Inspection/Maintenance 116: Well Raising	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 3	Yes (Go to 9) x No	Yes (Go to 10) No		P Madison	2/5/2020
20	x Startup  Malfunction	(S-64)	2/5/20 13:35	2/5/20 13:37	0.03	1.12	culture control	117: Gas Collection 118: Construction Activities	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4	Yes (Go to 9) x No	Yes (Go to 10) No		i Madicon	2/0/2020
	x Shutdown	Engine #1	2/8/20 14:30	2/8/20 14:32	0.03			x 113: Inspection/Maintenance 116: Well Raising	Manual (Go to 7) x Automatic (Go to 9)	Procedures 1 to 3	Yes (Go to 9)	Yes (Go to 10)			
26	x Startup Malfunction	(S-64)	2/8/20 22:50	2/8/20 22:52	0.03	8.33	Detonation cylinders 19 & 20	117: Gas Collection 118: Construction Activities	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4	Yes (Go to 9)	Yes (Go to 10)		P Madison	2/8/2020
	x Shutdown	Engine #1	2/10/20 15:00	2/10/20 15:02	0.03			x 113: Inspection/Maintenance 116: Well Raising	Manual (Go to 7)  x Automatic (Go to 9)	Procedures 1 to 3	Yes (Go to 9)	Yes (Go to 10)			
27	x Startup	Engine #1 (S-64)	2/10/20 15:20	2/10/20 15:22	0.03	0.33	oil leveler malfunction	117: Gas Collection	x Manual (Go to 7)	Procedures 1 to 4	Yes (Go to 9)	Yes (Go to 10)		P Madison	2/10/2020
	Malfunction		2/10/20 17:15	2/10/20 17:17	0.03			118: Construction Activities  x 113: Inspection/Maintenance	Automatic (Go to 9)  Manual (Go to 7)	Procedures 1 to 3	x No Yes (Go to 9)	Yes (Go to 10)			
28	x Shutdown x Startup	Engine #1 (S-64)	2/10/20 17:40	2/10/20 17:42	0.03	0.42	Detonation Cyl. 20	116: Well Raising 117: Gas Collection	x Automatic (Go to 9) x Manual (Go to 7)	Procedures 1 to 4	Yes (Go to 9)	x No Yes (Go to 10)		P Madison	2/10/2020
	Malfunction x Shutdown	Engine #1	2/10/20 18:25	2/10/20 18:27	0.03			<ul><li>118: Construction Activities</li><li>x 113: Inspection/Maintenance</li><li>116: Well Raising</li></ul>	Automatic (Go to 9)  Manual (Go to 7)  x Automatic (Go to 9)	Procedures 1 to 3	X No Yes (Go to 9)	Yes (Go to 10) x No			
29	x Startup  Malfunction	(S-64)	2/10/20 19:25	2/10/20 19:27	0.03	1.00	Detonation Cyl. 20	117: Gas Collection  118: Construction Activities	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4	Yes (Go to 9)	Yes (Go to 10)		P Madison	2/10/2020
00	x Shutdown	Engine #1	2/11/20 15:00	2/11/20 15:02	0.03	4.00		x 113: Inspection/Maintenance 116: Well Raising	Manual (Go to 7)  x Automatic (Go to 9)	Procedures 1 to 3	Yes (Go to 9)	Yes (Go to 10)		D.M. II	0/44/0000
30	x Startup Malfunction	(S-64)	2/11/20 16:05	2/11/20 16:07	0.03	1.08	Oil Leveler fault	117: Gas Collection 118: Construction Activities	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4	Yes (Go to 9)	Yes (Go to 10)		P Madison	2/11/2020
0.4	x Shutdown	Engine #1	2/17/20 19:30	2/17/20 19:32	0.03	44.75	D. 1. 1.00	x 113: Inspection/Maintenance 116: Well Raising	Manual (Go to 7) x Automatic (Go to 9)	Procedures 1 to 3	Yes (Go to 9)	Yes (Go to 10)		D.M. II	0/40/0000
31	x Startup Malfunction	(S-64)	2/18/20 7:15	2/18/20 7:17	0.03	11.75	Detonation cyl. 20	117: Gas Collection 118: Construction Activities	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4	Yes (Go to 9)	Yes (Go to 10)		P Madison	2/18/2020
	x Shutdown	Engine #1	2/21/20 23:05	2/21/20 23:07	0.03	4.40		x 113: Inspection/Maintenance 116: Well Raising	Manual (Go to 7)  x Automatic (Go to 9)	Procedures 1 to 3	Yes (Go to 9)	Yes (Go to 10)		5.4 "	0/00/0000
32	x Startup Malfunction	(S-64)	2/22/20 3:30	2/22/20 3:32	0.03	4.42	Reverse Power	117: Gas Collection 118: Construction Activities	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4	Yes (Go to 9)	Yes (Go to 10)		P Madison	2/22/2020
33	x Shutdown	Engine #1	2/22/20 4:20	2/22/20 4:22	0.03	0.92	Overspeed fault	x 113: Inspection/Maintenance 116: Well Raising	Manual (Go to 7) x Automatic (Go to 9)	Procedures 1 to 3	Yes (Go to 9)	Yes (Go to 10) x No		P Madison	2/22/2020
33	x Startup Malfunction	(S-64)	2/22/20 5:15	2/22/20 5:17	0.03	0.92	Overspeed rault	117: Gas Collection 118: Construction Activities	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4	Yes (Go to 9) x No	Yes (Go to 10) No		P Madison	2/22/2020
34	x Shutdown	Engine #1	2/26/20 12:10	2/26/20 12:12	0.03	1.00	Low Fuel Pressure	x 113: Inspection/Maintenance 116: Well Raising	Manual (Go to 7) x Automatic (Go to 9)	Procedures 1 to 3	Yes (Go to 9) No	Yes (Go to 10) x No		P Madison	2/26/2020
34	x Startup Malfunction	(S-64)	2/26/20 13:10	2/26/20 13:12	0.03	1.00	Low Fuel Flessure	117: Gas Collection 118: Construction Activities	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4	Yes (Go to 9) x No	Yes (Go to 10) No		r Madison	2/20/2020
25	x Shutdown	Engine #1	2/27/20 1:25	2/27/20 1:27	0.03	9.83	Emergancy stop activated &	x 113: Inspection/Maintenance 116: Well Raising	Manual (Go to 7) x Automatic (Go to 9)	Procedures 1 to 3	Yes (Go to 9) No	Yes (Go to 10) x No		P Madison	2/27/2020
35	x Startup Malfunction	(S-64)	2/27/20 11:15	2/27/20 11:17	0.03	უ.oა 	engine maintenance	117: Gas Collection 118: Construction Activities	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4	Yes (Go to 9) x No	Yes (Go to 10) No		r iviauisui	2/27/2020
20	x Shutdown	Engine #1	3/7/20 20:45	3/7/20 20:47	0.03	0.22	Deternation Cultivation CO	x 113: Inspection/Maintenance 116: Well Raising	Manual (Go to 7) x Automatic (Go to 9)	Procedures 1 to 3	Yes (Go to 9)	Yes (Go to 10) x No		D M41	2/7/2022
36	x Startup Malfunction	(S-64)	3/7/20 21:05	3/7/20 21:07	0.03	0.33	Detonation Cylinder 20	117: Gas Collection 118: Construction Activities	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4	Yes (Go to 9)	Yes (Go to 10)		P Madison	3/7/2020

Event No.	Check Applicable Event	Device	(1) Event Start Date/Time	(2) Event End Date/Time	(3) Duration (Hrs)	Downtime (Hrs)	(4) Cause or Reason	(5) Applicable Regulation	(6) Type of Event	(7) Procedures Used (a),(b)	(8) Did Steps Taken Vary From (7)	(9) Did Event Cause Any Emission Limit Exceedance?	(10) Describe Emission Standard(s) Exceeded (b)	Completed By	(11) Date Entry Completed
37	x Shutdown	Engine #1	3/9/20 21:10	3/9/20 21:12	0.03	0.75	Reverse power	x 113: Inspection/Maintenance 116: Well Raising	Manual (Go to 7) x Automatic (Go to 9)	Procedures 1 to 3	Yes (Go to 9)	Yes (Go to 10) x No		P Madison	3/9/2020
	x Startup  Malfunction	(S-64)	3/9/20 21:55	3/9/20 21:57	0.03			117: Gas Collection 118: Construction Activities	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4	Yes (Go to 9)	Yes (Go to 10)			0,0,=0=0
	x Shutdown	Engine #1	3/10/20 23:45	3/10/20 23:47	0.03		-	x 113: Inspection/Maintenance 116: Well Raising	Manual (Go to 7) x Automatic (Go to 9)	Procedures 1 to 3	Yes (Go to 9)	Yes (Go to 10)			
38	x Startup	(S-64)	3/10/20 23:55	3/10/20 23:57	0.03	0.17	High oil temp	117: Gas Collection 118: Construction Activities	x Manual (Go to 7)	Procedures 1 to 4	Yes (Go to 9)	Yes (Go to 10)		P Madison	3/10/2020
	Malfunction		3/10/20 23:55	3/10/20 23:57	0.03			x 113: Inspection/Maintenance	Automatic (Go to 9)  Manual (Go to 7)	Procedures	Yes (Go to 9)	Yes (Go to 10)			
39	x Shutdown x Startup	Engine #1 (S-64)	3/11/20 0:15	3/11/20 0:17	0.03	0.33	Reverse power	116: Well Raising 117: Gas Collection	x Automatic (Go to 9) x Manual (Go to 7)	1 to 3  Procedures	No Yes (Go to 9)	x No Yes (Go to 10)		P Madison	3/11/2020
	Malfunction		3/11/20 0:30	3/11/20 0:32	0.03			118: Construction Activities  x 113: Inspection/Maintenance	Automatic (Go to 9)  Manual (Go to 7)	1 to 4 Procedures	x No Yes (Go to 9)	No Yes (Go to 10)			
40	x Shutdown x Startup	Engine #1 (S-64)	3/11/20 0:40	3/11/20 0:42	0.03	0.17	Reverese Power	116: Well Raising 117: Gas Collection	x Automatic (Go to 9) x Manual (Go to 7)	1 to 3  Procedures	No Yes (Go to 9)	x No Yes (Go to 10)		P Madison	3/11/2020
	Malfunction	F : "4	3/11/20 18:45	3/11/20 18:47	0.03			118: Construction Activities x 113: Inspection/Maintenance	Automatic (Go to 9)  Manual (Go to 7)	1 to 4 Procedures 1 to 3	x No Yes (Go to 9)	Yes (Go to 10)			
41	x Shutdown x Startup Malfunction	Engine #1 (S-64)	3/11/20 19:00	3/11/20 19:02	0.03	0.25	Reverse power	116: Well Raising 117: Gas Collection 118: Construction Activities	x Automatic (Go to 9) x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4	No Yes (Go to 9) x No	x No Yes (Go to 10)		P Madison	3/11/2020
	x Shutdown	Engine #1	3/11/20 22:00	3/11/20 22:02	0.03			x 113: Inspection/Maintenance 116: Well Raising	Manual (Go to 7)  x Automatic (Go to 9)	Procedures 1 to 3	Yes (Go to 9)	Yes (Go to 10) x No			
42	x Startup  Malfunction	(S-64)	3/11/20 23:25	3/11/20 23:27	0.03	1.42	Reverse Power	117: Gas Collection  118: Construction Activities	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4	Yes (Go to 9)	Yes (Go to 10)		P Madison	3/11/2020
	x Shutdown	Engine #1	3/11/20 23:40	3/11/20 23:42	0.03			x 113: Inspection/Maintenance 116: Well Raising	Manual (Go to 7)  x Automatic (Go to 9)	Procedures 1 to 3	Yes (Go to 9)	Yes (Go to 10)			
43	x Startup  Malfunction	(S-64)	3/11/20 23:55	3/11/20 23:57	0.03	0.25	Reverse Power	117: Gas Collection  118: Construction Activities	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4	Yes (Go to 9)	Yes (Go to 10)		P Madison	3/11/2020
	x Shutdown	Engine #1	3/12/20 3:20	3/12/20 3:22	0.03		Oil leveler malfunction and oil	x 113: Inspection/Maintenance 116: Well Raising	Manual (Go to 7)  x Automatic (Go to 9)	Procedures 1 to 3	Yes (Go to 9)	Yes (Go to 10)			
44	x Startup  Malfunction	(S-64)	3/12/20 7:15	3/12/20 7:17	0.03	3.92	change	117: Gas Collection 118: Construction Activities	x Manual (Go to 7) Automatic (Go to 9)	Procedures	Yes (Go to 9) x No	Yes (Go to 10)		P Madison	3/12/2020
	x Shutdown	Engine #1	3/12/20 8:05	3/12/20 8:07	0.03			x 113: Inspection/Maintenance 116: Well Raising	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 3	Yes (Go to 9)	Yes (Go to 10)			
45	x Startup Malfunction	(S-64)	3/12/20 11:30	3/12/20 11:32	0.03	3.42	Exhaust sensor replacement	117: Gas Collection 118: Construction Activities	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4	Yes (Go to 9)	Yes (Go to 10)		P Madison	3/12/2020
40	x Shutdown	Engine #1	3/13/20 7:45	3/13/20 7:47	0.03	0.00	Danies en IManes	x 113: Inspection/Maintenance 116: Well Raising	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 3	Yes (Go to 9)	Yes (Go to 10)		DMadiana	0/40/0000
46	x Startup Malfunction	(S-64)	3/13/20 10:05	3/13/20 10:07	0.03	2.33	Repairs on J-M pump	117: Gas Collection 118: Construction Activities	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4	Yes (Go to 9)	Yes (Go to 10)		P Madison	3/13/2020
47	x Shutdown	Engine #1	3/20/20 3:00	3/20/20 3:02	0.03	00.50	Detonation on clinder 1 and JW	x 113: Inspection/Maintenance 116: Well Raising	Manual (Go to 7)  x Automatic (Go to 9)	Procedures 1 to 3	Yes (Go to 9)	Yes (Go to 10)		D.M. II	0/04/0000
47	x Startup Malfunction	(S-64)	3/21/20 7:30	3/21/20 7:32	0.03	28.50	high temp	117: Gas Collection 118: Construction Activities	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4	Yes (Go to 9)	Yes (Go to 10)		P Madison	3/21/2020
16	x Shutdown	Engine #1	3/23/20 9:15	3/23/20 9:17	0.03	0.17		x 113: Inspection/Maintenance 116: Well Raising	Manual (Go to 7)  x Automatic (Go to 9)	Procedures 1 to 3	Yes (Go to 9)	Yes (Go to 10)		D.1. "	0/02/05
48	x Startup  Malfunction	(S-64)	3/23/20 9:25	3/23/20 9:27	0.03	0.17	Jacket Water High temp	117: Gas Collection  118: Construction Activities	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4	Yes (Go to 9) x No	Yes (Go to 10)		P Madison	3/23/2020

Event	Check		(1) Event Start	(2) Event End	(3)	Downtime			#1 (5-64) DEVICE DO		(7)		(8) Did Steps		(9) Did Event Cause Anv	(10) Describe Emission	Completed	(11) Date
No.	Applicable Event	Device	Date/Time	Date/Time	Duration (Hrs)	(Hrs)	(4) Cause or Reason		(5) Applicable Regulation	(6) Type of Event	Procedures Used (a),(b)	T	aken Vary From (7)	I	Emission Limit Exceedance?	Standard(s) Exceeded (b)	Ву	Entry Completed
			3/23/20 17:15	3/23/20 17:17	0.03			Х	113: Inspection/Maintenance	Manual (Go to 7)	Procedures		Yes (Go to 9)	_	Yes (Go to 10)			
49	x Shutdown	Engine #1 (S-64)				0.17	Jacket Water High temp and Low fuel pressure		116: Well Raising	x Automatic (Go to 9)	1 to 3	-	No	_	No		P Madison	3/23/2020
	x Startup  Malfunction	(3-04)	3/23/20 17:25	3/23/20 17:27	0.03		Low luer pressure		<ul><li>117: Gas Collection</li><li>118: Construction Activities</li></ul>	x Manual (Go to 7)	Procedures 1 to 4		Yes (Go to 9)		Yes (Go to 10)			
	Manufiction							v	113: Inspection/Maintenance	Automatic (Go to 9)  Manual (Go to 7)	Procedures	<u> </u>	No Yes (Go to 9)	+	Yes (Go to 10)			
	x Shutdown	Engine #1	4/3/20 1:30	4/3/20 1:32	0.03			Ĥ	116: Well Raising	x Automatic (Go to 9)	1 to 3		No	_	No			
50	x Startup	(S-64)				9.67	Low oil level		117: Gas Collection	x Manual (Go to 7)	Procedures	1	Yes (Go to 9)		Yes (Go to 10)		P Madison	4/3/2020
	Malfunction		4/3/20 11:10	4/3/20 11:12	0.03				118: Construction Activities	Automatic (Go to 9)	1 to 4	х	No		No			
	•		4/6/20 12:40	4/6/20 12:42	0.02			х	113: Inspection/Maintenance	Manual (Go to 7)	Procedures		Yes (Go to 9)		Yes (Go to 10)			
51	x Shutdown	Engine #1	4/6/20 13:40	4/6/20 13:42	0.03	19.83	Detonation cyl. 15& 17		116: Well Raising	x Automatic (Go to 9)	1 to 3		No	Х	No		P Madison	4/7/2020
31	x Startup	(S-64)	4/7/20 9:30	4/7/20 9:32	0.03	19.05	Detoriation cyl. 13& 17		117: Gas Collection	x Manual (Go to 7)	Procedures		Yes (Go to 9)		Yes (Go to 10)		F Wadison	4/1/2020
	Malfunction		4/1/20 0.00	4/1/20 5.52	0.00				118: Construction Activities	Automatic (Go to 9)	1 to 4	Х	No		No			
			4/8/20 5:00	4/8/20 5:02	0.03			Х	113: Inspection/Maintenance	Manual (Go to 7)	Procedures		Yes (Go to 9)		Yes (Go to 10)			
52	x Shutdown	Engine #1				1.17	Detonation cyl. 15		116: Well Raising	x Automatic (Go to 9)	1 to 3		No	_	No		P Madison	4/8/2020
	x Startup	(S-64)	4/8/20 6:10	4/8/20 6:12	0.03		,		117: Gas Collection	x Manual (Go to 7)	Procedures	_	Yes (Go to 9)		Yes (Go to 10)			
	Malfunction								118: Construction Activities	Automatic (Go to 9)	1 to 4	_	No		No (O t to)			
	y Chutdows	F #4	4/8/20 7:30	4/8/20 7:32	0.03			Х	113: Inspection/Maintenance	x Manual (Go to 7)	Procedures 1 to 3		Yes (Go to 9)		Yes (Go to 10)			
53	x Shutdown	Engine #1 (S-64)				3.33	Valve Service		116: Well Raising 117: Gas Collection	Automatic (Go to 9)		_	No Yes (Go to 9)		Yes (Go to 10)		P Madison	4/8/2020
	x Startup Malfunction	(0-04)	4/8/20 10:50	4/8/20 10:52	0.03				118: Construction Activities	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4		No		res (Go to 10)			
	Manufiction							v	113: Inspection/Maintenance	Manual (Go to 7)	Procedures	^	Yes (Go to 9)	+	Yes (Go to 10)			
	x Shutdown	Engine #1	4/8/20 20:50	4/8/20 20:52	0.03			Ĥ	116: Well Raising	x Automatic (Go to 9)	1 to 3		No	_	No			
54	x Startup	(S-64)				3.08	Detonation Cyl. 15		117: Gas Collection	x Manual (Go to 7)	Procedures	1	Yes (Go to 9)	4	Yes (Go to 10)		P Madison	4/8/2020
	Malfunction		4/8/20 23:55	4/8/20 23:57	0.03				118: Construction Activities	Automatic (Go to 9)	1 to 4	х	No		No			
	•		4/40/00 00 45	4/40/00 00:47	0.00			х	113: Inspection/Maintenance	Manual (Go to 7)	Procedures		Yes (Go to 9)		Yes (Go to 10)			
55	x Shutdown	Engine #1	4/12/20 22:15	4/12/20 22:17	0.03	0.00	Detenation Cut 15		116: Well Raising	x Automatic (Go to 9)	1 to 3		No	х	No		P Madison	4/42/2020
55	x Startup	(S-64)	4/13/20 7:15	4/13/20 7:17	0.03	9.00	Detonation Cyl. 15		117: Gas Collection	x Manual (Go to 7)	Procedures		Yes (Go to 9)		Yes (Go to 10)		Piviadison	4/13/2020
	Malfunction		4/13/20 7.13	4/13/20 7.17	0.03				118: Construction Activities	Automatic (Go to 9)	1 to 4	Х	No		No			
			4/13/20 15:25	4/13/20 15:27	0.03			Х	113: Inspection/Maintenance	Manual (Go to 7)	Procedures		Yes (Go to 9)		Yes (Go to 10)			
56	x Shutdown	Engine #1	17 10/20 10:20	1710/20 10:21	0.00	6.17	Reverse Power		116: Well Raising	x Automatic (Go to 9)	1 to 3		No	_	No		P Madison	4/13/2020
	x Startup	(S-64)	4/13/20 21:35	4/13/20 21:37	0.03	-			117: Gas Collection	x Manual (Go to 7)	Procedures		Yes (Go to 9)		Yes (Go to 10)			
	Malfunction							_	118: Construction Activities	Automatic (Go to 9)	1 to 4		No		No			
	—a		4/13/20 22:55	4/13/20 22:57	0.03			Х	113: Inspection/Maintenance	Manual (Go to 7)	Procedures		Yes (Go to 9)		Yes (Go to 10)			
57	x Shutdown	Engine #1 (S-64)				0.58	Detonation Cyl. 15		116: Well Raising	x Automatic (Go to 9)	1 to 3	+	No		No Yes (Go to 10)		P Madison	4/13/2020
	x Startup Malfunction	(0-04)	4/13/20 23:30	4/13/20 23:32	0.03				<ul><li>117: Gas Collection</li><li>118: Construction Activities</li></ul>	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4		Yes (Go to 9) No		res (Go to 10)			
	Manufiction							Y	113: Inspection/Maintenance	Manual (Go to 7)	Procedures	^	Yes (Go to 9)		Yes (Go to 10)			
	x Shutdown	Engine #1	4/14/20 1:10	4/14/20 1:12	0.03			Ĥ	116: Well Raising	x Automatic (Go to 9)	1 to 3		No		No			
58	x Startup	(S-64)				7.50	Detonation Cyl. 11		117: Gas Collection	x Manual (Go to 7)	Procedures		Yes (Go to 9)	<u> </u>	Yes (Go to 10)		P Madison	4/14/2020
	Malfunction	, ,	4/14/20 8:40	4/14/20 8:42	0.03				118: Construction Activities	Automatic (Go to 9)	1 to 4	х	No		No			
			444400 40 00	4/4.4/00.40.00				х	113: Inspection/Maintenance	Manual (Go to 7)	Procedures		Yes (Go to 9)		Yes (Go to 10)			
F0	x Shutdown	Engine #1	4/14/20 10:00	4/14/20 10:02	0.03	2.05	Cylinder 9 Low Temp / Ignition		116: Well Raising	x Automatic (Go to 9)	1 to 3		No	х	No		D Modices	4/4 4/0000
59	x Startup	(S-64)	4/14/20 13:15	4/14/20 13:17	0.03	3.25	transformer under-voltage		117: Gas Collection	x Manual (Go to 7)	Procedures		Yes (Go to 9)	L	Yes (Go to 10)		P Madison	4/14/2020
	Malfunction		4/14/20 13.13	4/ 14/20 13.1/	0.03				118: Construction Activities	Automatic (Go to 9)	1 to 4	Х	No		No			
			4/16/20 4:55	4/16/20 4:57	0.03			Х	113: Inspection/Maintenance	Manual (Go to 7)	Procedures		Yes (Go to 9)		Yes (Go to 10)			
60	x Shutdown	Engine #1	1, 10,20 1.00	7/10/20 7.0/	0.00	0.83	Engine Oil Leveler Failure		116: Well Raising	x Automatic (Go to 9)	1 to 3		No	_	No		P Madison	4/16/2020
	x Startup	(S-64)	4/16/20 5:45	4/16/20 5:47	0.03	3.00			117: Gas Collection	x Manual (Go to 7)	Procedures	_	Yes (Go to 9)	-	Yes (Go to 10)			., . 0, 2020
	Malfunction								118: Construction Activities	Automatic (Go to 9)	1 to 4	Х	No		No			

Event No.	Check Applicable Event	Device	(1) Event Start Date/Time	(2) Event End Date/Time	(3) Duration (Hrs)	Downtime (Hrs)	(4) Cause or Reason	(5) Applicable Regulation	(6) Type of Event	(7) Procedures Used (a),(b)	(8) Did Steps Taken Vary From (7)	(9) Did Event Cause Any Emission Limit Exceedance?	(10) Describe Emission Standard(s) Exceeded (b)	Completed By	(11) Date Entry Completed
61	x Shutdown	Engine #1	4/17/20 19:10	4/17/20 19:12	0.03	58.33	Engine faulted for Reverse power. Cylinder 19 Damage -	x 113: Inspection/Maintenance 116: Well Raising	Manual (Go to 7) x Automatic (Go to 9)	Procedures 1 to 3	Yes (Go to 9)	Yes (Go to 10) x No		P Madison	4/20/2020
	x Startup  Malfunction	(S-64)	4/20/20 5:30	4/20/20 5:32	0.03		Head and piston	117: Gas Collection 118: Construction Activities	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4	Yes (Go to 9) x No	Yes (Go to 10) No			
	x Shutdown	Engine #1	4/20/20 19:05	4/20/20 19:07	0.03			x 113: Inspection/Maintenance 116: Well Raising	Manual (Go to 7) x Automatic (Go to 9)	Procedures 1 to 3	Yes (Go to 9)	Yes (Go to 10)			
62	x Startup Malfunction	(S-64)	4/20/20 20:30	4/20/20 20:32	0.03	1.42	High coolant temp	117: Gas Collection 118: Construction Activities	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4	Yes (Go to 9)	Yes (Go to 10)		P Madison	4/20/2020
	x Shutdown	Engine #1	4/21/20 20:20	4/21/20 20:22	0.03			x 113: Inspection/Maintenance	Manual (Go to 7)  x Automatic (Go to 9)	Procedures 1 to 3	Yes (Go to 9)	Yes (Go to 10)			
63	x Startup	Engine #1 (S-64)	4/21/20 21:50	4/21/20 21:52	0.03	1.50	High Coolant temp	117: Gas Collection	x Manual (Go to 7)	Procedures	Yes (Go to 9)	Yes (Go to 10)		P Madison	4/21/2020
	Malfunction		4/22/20 8:10	4/22/20 8:12	0.03			118: Construction Activities  x 113: Inspection/Maintenance	Automatic (Go to 9)  Manual (Go to 7)	Procedures	x No Yes (Go to 9)	Yes (Go to 10)			
64	x Shutdown x Startup	Engine #1 (S-64)	4/22/20 8:20	4/22/20 8:22	0.03	0.17	Reverse Power	116: Well Raising 117: Gas Collection	x Automatic (Go to 9) x Manual (Go to 7)	1 to 3  Procedures 1 to 4	No Yes (Go to 9)	x No Yes (Go to 10)		P Madison	4/22/2020
	Malfunction x Shutdown	Engine #1	4/23/20 0:55	4/23/20 0:57	0.03			118: Construction Activities  x 113: Inspection/Maintenance  116: Well Raising	Automatic (Go to 9)  Manual (Go to 7)  x Automatic (Go to 9)	Procedures 1 to 3	x No Yes (Go to 9)	Yes (Go to 10) x No			
65	x Startup  Malfunction	(S-64)	4/23/20 4:50	4/23/20 4:52	0.03	3.92	High Coolant Temp	117: Gas Collection  118: Construction Activities	x Manual (Go to 7) Automatic (Go to 9)	Procedures	Yes (Go to 9)	Yes (Go to 10)		P Madison	4/23/2020
00	x Shutdown	Engine #1	4/24/20 20:05	4/24/20 20:07	0.03	4.50	Uliab Ocalant Tana	x 113: Inspection/Maintenance 116: Well Raising	Manual (Go to 7)  x Automatic (Go to 9)	Procedures 1 to 3	Yes (Go to 9)	Yes (Go to 10)		DMadiana	4/04/0000
66	x Startup Malfunction	(S-64)	4/24/20 21:35	4/24/20 21:37	0.03	1.50	High Coolant Temp	117: Gas Collection 118: Construction Activities	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4	Yes (Go to 9) x No	Yes (Go to 10) No		P Madison	4/24/2020
07	x Shutdown	Engine #1	4/26/20 10:45	4/26/20 10:47	0.03	4.47	Leve et Level	x 113: Inspection/Maintenance 116: Well Raising	Manual (Go to 7) x Automatic (Go to 9)	Procedures 1 to 3	Yes (Go to 9) No	Yes (Go to 10) x No		DMadiana	4/00/0000
67	x Startup Malfunction	(S-64)	4/26/20 11:55	4/26/20 11:57	0.03	1.17	low oil level	117: Gas Collection 118: Construction Activities	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4	Yes (Go to 9)	Yes (Go to 10)		P Madison	4/26/2020
	x Shutdown	Engine #1	4/27/20 16:45	4/27/20 16:47	0.03	4.00		x 113: Inspection/Maintenance 116: Well Raising	Manual (Go to 7)  x Automatic (Go to 9)	Procedures 1 to 3	Yes (Go to 9)	Yes (Go to 10)		5.4. "	4/07/0000
68	x Startup Malfunction	(S-64)	4/27/20 20:45	4/27/20 20:47	0.03	4.00	Low oil pressure	117: Gas Collection 118: Construction Activities	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4	Yes (Go to 9) x No	Yes (Go to 10)		P Madison	4/27/2020
69	x Shutdown	Engine #1	4/28/20 8:00	4/28/20 8:02	0.03	0.50	High coolant temp	x 113: Inspection/Maintenance 116: Well Raising	Manual (Go to 7) x Automatic (Go to 9)	Procedures 1 to 3	Yes (Go to 9) No	Yes (Go to 10) x No		P Madison	4/28/2020
09	x Startup Malfunction	(S-64)	4/28/20 8:30	4/28/20 8:32	0.03	0.50	nigii coolant temp	117: Gas Collection 118: Construction Activities	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4	Yes (Go to 9) x No	Yes (Go to 10) No		P Madison	4/20/2020
70	x Shutdown	Engine #1	4/28/20 9:20	4/28/20 9:22	0.03	0.17	High differential oil pressure	x 113: Inspection/Maintenance 116: Well Raising	Manual (Go to 7) x Automatic (Go to 9)	Procedures 1 to 3	Yes (Go to 9) No	Yes (Go to 10) x No		P Madison	4/28/2020
70	x Startup Malfunction	(S-64)	4/28/20 9:30	4/28/20 9:32	0.03	0.17	r ligh dillerential on pressure	117: Gas Collection 118: Construction Activities	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4	Yes (Go to 9) x No	Yes (Go to 10) No		Fiviation	4/20/2020
74	x Shutdown	Engine #1	4/28/20 10:20	4/28/20 10:22	0.03	0.22	Low oil lovel	x 113: Inspection/Maintenance 116: Well Raising	Manual (Go to 7) x Automatic (Go to 9)	Procedures 1 to 3	Yes (Go to 9) No	Yes (Go to 10) x No		D Madison	4/28/2020
71	x Startup Malfunction	(S-64)	4/28/20 10:40	4/28/20 10:42	0.03	0.33	Low oil level	117: Gas Collection 118: Construction Activities	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4	Yes (Go to 9) x No	Yes (Go to 10) No		P Madison	4/28/2020
70	x Shutdown	Engine #1	4/28/20 12:10	4/28/20 12:12	0.03	0.4-	Hinto Co. L. C.	x 113: Inspection/Maintenance 116: Well Raising	Manual (Go to 7) x Automatic (Go to 9)	Procedures 1 to 3	Yes (Go to 9) No	Yes (Go to 10) x No		D.M. "	A10010000
72	x Startup Malfunction	(S-64)	4/28/20 12:20	4/28/20 12:22	0.03	0.17	High Coolant temp	117: Gas Collection 118: Construction Activities	x Manual (Go to 7) Automatic (Go to 9)	Procedures	Yes (Go to 9) x No	Yes (Go to 10)		P Madison	4/28/2020

							Willite El O Eligi	ne #1 (3-64) DEVICE DC	WINTIME EGG						
Event No.	Check Applicable Event	Device	(1) Event Start Date/Time	(2) Event End Date/Time	(3) Duration (Hrs)	Downtime (Hrs)	(4) Cause or Reason	(5) Applicable Regulation	(6) Type of Event	(7) Procedures Used (a),(b)	(8) Did Steps Taken Vary From (7)	(9) Did Event Cause Any Emission Limit Exceedance?	(10) Describe Emission Standard(s) Exceeded (b)	Completed By	(11) Date Entry Completed
			4/28/20 19:15	4/28/20 19:17	0.03			x 113: Inspection/Maintenance	Manual (Go to 7)	Procedures	Yes (Go to 9)	Yes (Go to 10)			
73	x Shutdown	Engine #1	4/20/20 10:10	4/20/20 10:17	0.00	5.75	Reverse Power	116: Well Raising	x Automatic (Go to 9)	1 to 3		x No		P Madison	4/29/2020
, 0	x Startup	(S-64)	4/29/20 1:00	4/29/20 1:02	0.03	0.70	Neverse i swer	117: Gas Collection	x Manual (Go to 7)	Procedures	Yes (Go to 9)	Yes (Go to 10)		1 Waaiseii	4/20/2020
	Malfunction		.,_0,_00	.,_0,_0	0.00			118: Construction Activities	Automatic (Go to 9)	1 to 4	x No	No			
			4/29/20 8:45	4/29/20 8:47	0.03			x 113: Inspection/Maintenance	Manual (Go to 7)	Procedures	Yes (Go to 9)	Yes (Go to 10)			
74	x Shutdown	Engine #1		,,,,,		6.33	Reverse power	116: Well Raising	x Automatic (Go to 9)	1 to 3		x No		P Madison	4/29/2020
	x Startup	(S-64)	4/29/20 15:05	4/29/20 15:07	0.03		•	117: Gas Collection	x Manual (Go to 7)	Procedures	Yes (Go to 9)	Yes (Go to 10)			
	Malfunction							118: Construction Activities	Automatic (Go to 9)	1 to 4	x No	No			
	<u> </u>		4/29/20 15:10	4/29/20 15:12	0.03			x 113: Inspection/Maintenance	x Manual (Go to 7)	Procedures	Yes (Go to 9)	Yes (Go to 10)			
75	x Shutdown	Engine #1				0.50	Oil & Filter Service	116: Well Raising	Automatic (Go to 9)	1 to 3	x No	No		P Madison	4/29/2020
	x Startup	(S-64)	4/29/20 15:40	4/29/20 15:42	0.03			117: Gas Collection	x Manual (Go to 7)	Procedures	Yes (Go to 9)	Yes (Go to 10)			
	Malfunction							118: Construction Activities	Automatic (Go to 9)	1 to 4	x No	No			
	<u> </u>		4/29/20 20:15	4/29/20 20:17	0.03			x 113: Inspection/Maintenance	Manual (Go to 7)	Procedures	Yes (Go to 9)	Yes (Go to 10)			
76	x Shutdown	Engine #1 (S-64)				0.75	Reverse Power	116: Well Raising	x Automatic (Go to 9)	1 to 3		x No		P Madison	4/29/2020
	x Startup	(3-64)	4/29/20 21:00	4/29/20 21:02	0.03			117: Gas Collection	x Manual (Go to 7)	Procedures 1 to 4	Yes (Go to 9)	Yes (Go to 10)			
	Malfunction							118: Construction Activities	Automatic (Go to 9)		x No	No (O t to)			
	Chutdaus	F : "4	4/30/20 6:10	4/30/20 6:12	0.03		D 1 104	x 113: Inspection/Maintenance	x Manual (Go to 7)	Procedures 1 to 3	Yes (Go to 9) x No	Yes (Go to 10)			
77	x Shutdown	Engine #1 (S-64)				8.58	Replace JW regulators and crankcase breathers	116: Well Raising	Automatic (Go to 9)			NO (Ca ta 40)		P Madison	4/30/2020
	x Startup	(0-04)	4/30/20 14:45	4/30/20 14:47	0.03		Gaircase Dieduleis	117: Gas Collection	x Manual (Go to 7)	Procedures 1 to 4	Yes (Go to 9) x No	Yes (Go to 10)			
	Malfunction							118: Construction Activities	Automatic (Go to 9)	1 10 4	X INO	INO			

Event No.	Check Applicable Event	Device	(1) Event Start Date/Time	(2) Event End Date/Time	(3) Duration (Hrs)	Downtime (Hrs)	(4) Cause or Reason		(5) Applicable Regulation		(6) Type of Event	(7) Procedures Used (a),(b)	Ta	(8) Did Steps aken Vary From (7)	E	(9) Did Event Cause Any Emission Limit Exceedance?	(10) Describe Emission Standard(s) Exceeded (b)	Completed By	(11) Date Entry Completed
1	x Shutdown	Engine #2	11/2/19 17:45	11/2/19 17:47	0.03	0.17	Low Coolant Pressure	Х	113: Inspection/Maintenance 116: Well Raising	+-	Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 3		Yes (Go to 9) No	-	Yes (Go to 10) No		P Madison	11/2/2019
·	x Startup  Malfunction	(S-65)	11/2/19 17:55	11/2/19 17:57	0.03	0.11	25W GGGIAIN 11555GIG		117: Gas Collection 118: Construction Activities	Х	Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4		Yes (Go to 9) No		Yes (Go to 10) No		. Madicon	11/2/2010
2	x Shutdown	Engine #2	11/2/19 18:10	11/2/19 18:12	0.03	0.33	Johnson Matthey High Pressure	-	113: Inspection/Maintenance 116: Well Raising	х	Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 3		Yes (Go to 9) No	-	Yes (Go to 10) No		P Madison	11/2/2019
2	x Startup Malfunction	(S-65)	11/2/19 18:30	11/2/19 18:32	0.03	0.55	Johnson Matthey Flight Flessure		117: Gas Collection 118: Construction Activities	Х	Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4		Yes (Go to 9) No		Yes (Go to 10) No		1 Wadison	11/2/2019
2	x Shutdown	Engine #2	11/8/19 9:00	11/8/19 9:02	0.03	0.22	Oil Channa	Х	113: Inspection/Maintenance 116: Well Raising	Х	Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 3		Yes (Go to 9) No	-	Yes (Go to 10) No		D. Madiaan	44/0/2040
3	x Startup Malfunction	(S-65)	11/8/19 9:20	11/8/19 9:22	0.03	0.33	Oil Change		117: Gas Collection 118: Construction Activities	х	Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4		Yes (Go to 9) No	-	Yes (Go to 10) No		P Madison	11/8/2019
	x Shutdown	Engine #2	11/27/19 0:30	11/27/19 0:32	0.03	4.00		Х	113: Inspection/Maintenance 116: Well Raising	х	Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 3		Yes (Go to 9) No	-	Yes (Go to 10) No		D.M. II	44/07/0040
4	x Startup Malfunction	(S-65)	11/27/19 1:30	11/27/19 1:32	0.03	1.00	Loss of utility	$\vdash$	117: Gas Collection 118: Construction Activities	+	Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4		Yes (Go to 9) No	-	Yes (Go to 10) No		P Madison	11/27/2019
_	x Shutdown	Engine #2	12/5/19 16:30	12/5/19 16:32	0.03	00.07	Descript to Ordinate 44	Х	113: Inspection/Maintenance 116: Well Raising	+-	Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 3		Yes (Go to 9) No	$\vdash$	Yes (Go to 10) No		DMadiaaa	40/0/0040
5	x Startup Malfunction	(S-65)	12/6/19 16:10	12/6/19 16:12	0.03	23.67	Repairs to Cylinder 11	-	117: Gas Collection 118: Construction Activities	х	Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4	-	Yes (Go to 9) No	-	Yes (Go to 10) No		P Madison	12/6/2019
	x Shutdown	Engine #2	12/7/19 9:25	12/7/19 9:27	0.03			Х	113: Inspection/Maintenance 116: Well Raising	х	Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 3		Yes (Go to 9) No	$\vdash$	Yes (Go to 10) No			
6	x Startup Malfunction	(S-65)	12/7/19 9:40	12/7/19 9:42	0.03	0.25	Detonation cylinder 11		117: Gas Collection 118: Construction Activities	х	Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4	-	Yes (Go to 9) No	-	Yes (Go to 10) No		P Madison	12/7/2019
	x Shutdown	Engine #2	12/9/19 9:00	12/9/19 9:02	0.03			х	113: Inspection/Maintenance 116: Well Raising	х	Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 3		Yes (Go to 9) No	-	Yes (Go to 10) No			
7	x Startup Malfunction	(S-65)	12/19/19 17:00	12/19/19 17:02	0.03	248.00	Repairs to flare	-	117: Gas Collection 118: Construction Activities	х	Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4		Yes (Go to 9) No	$\vdash$	Yes (Go to 10) No		P Madison	12/19/2019
	x Shutdown	Engine #2	12/20/19 6:45	12/20/19 6:47	0.03			Х	113: Inspection/Maintenance 116: Well Raising	х	Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 3		Yes (Go to 9)		Yes (Go to 10)			
8	x Startup  Malfunction	(S-65)	12/20/19 10:45	12/20/19 10:47	0.03	4.00	Repairs to flare		117: Gas Collection 118: Construction Activities	х	Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4		Yes (Go to 9) No		Yes (Go to 10) No		P Madison	12/20/2019
	x Shutdown	Engine #2	12/20/19 19:40	12/20/19 19:42	0.03		Repairs to Cylinder 19	Χ	113: Inspection/Maintenance 116: Well Raising		Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 3		Yes (Go to 9)		Yes (Go to 10) No			
9	x Startup Malfunction	(S-65)	12/21/19 15:45	12/21/19 15:47	0.03	20.08	detonation		117: Gas Collection 118: Construction Activities	_	Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4		Yes (Go to 9) No		Yes (Go to 10) No		P Madison	12/21/2019
	x Shutdown	Engine #2	12/27/19 17:30	12/27/19 17:32	0.03			Х	113: Inspection/Maintenance 116: Well Raising	х	Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 3		Yes (Go to 9) No	-	Yes (Go to 10) No			
10	x Startup Malfunction	(S-65)	12/28/19 15:15	12/28/19 15:17	0.03	21.75	Repairs to cylinder 19 detonation		117: Gas Collection 118: Construction Activities	х	Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4		Yes (Go to 9) No		Yes (Go to 10) No		P Madison	12/28/2019
	x Shutdown	Engine #2	12/30/19 20:50	12/30/19 20:52	0.03			_	113: Inspection/Maintenance 116: Well Raising	Х	Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 3		Yes (Go to 9)		Yes (Go to 10) No			
11	x Startup  Malfunction	(S-65)	12/30/19 21:15	12/30/19 21:17	0.03	0.42	Harness repair		117: Gas Collection 118: Construction Activities	х	Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4		Yes (Go to 9)		Yes (Go to 10)		P Madison	12/30/2019
	x Shutdown	Engine #2	1/8/20 13:30	1/8/20 13:32	0.03		Shutdown for Air Compressor		113: Inspection/Maintenance 116: Well Raising	х	Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 3		Yes (Go to 9)		Yes (Go to 10)			
12	x Startup  Malfunction	(S-65)	1/8/20 14:15	1/8/20 14:17	0.03	0.75	Installation		117: Gas Collection  118: Construction Activities	_	Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4		Yes (Go to 9)		Yes (Go to 10)		P Madison	1/8/2020

Event No.	Check Applicable Event	Device	(1) Event Start Date/Time	(2) Event End Date/Time	(3) Duration (Hrs)	Downtime (Hrs)	(4) Cause or Reason	(5) Applicable Regulation	(6) Type of Event	(7) Procedures Used (a),(b)	(8) Did Steps Taken Vary From (7)	(9) Did Event Cause Any Emission Limit Exceedance?	(10) Describe Emission Standard(s) Exceeded (b)	Completed By	(11) Date Entry Completed
	x Shutdown	Engine #2	1/9/20 12:35	1/9/20 12:37	0.03		Shutdown for Air Compressor	x 113: Inspection/Maintenance	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 3	Yes (Go to 9)	Yes (Go to 10)			
13	x Startup	(S-65)				0.75	Installation	117: Gas Collection	x Manual (Go to 7)	Procedures	Yes (Go to 9)	Yes (Go to 10)		P Madison	1/9/2020
	Malfunction	, ,	1/9/20 13:20	1/9/20 13:22	0.03			118: Construction Activities	Automatic (Go to 9)	1 to 4	x No	No			
			4/0/00 40 00	1/0/00 10 00	0.00			x 113: Inspection/Maintenance	Manual (Go to 7)	Procedures	Yes (Go to 9)	Yes (Go to 10)			
4.4	x Shutdown	Engine #2	1/9/20 13:30	1/9/20 13:32	0.03	0.05	labora on Matthews Facility	116: Well Raising	x Automatic (Go to 9)	1 to 3	No `	x No `		D.M. die en	4/0/0000
14	x Startup	(S-65)	1/0/20 12:45	1/0/20 12:47	0.02	0.25	Johnson Matthey Fault	117: Gas Collection	x Manual (Go to 7)	Procedures	Yes (Go to 9)	Yes (Go to 10)		P Madison	1/9/2020
	Malfunction		1/9/20 13:45	1/9/20 13:47	0.03			118: Construction Activities	Automatic (Go to 9)	1 to 4	x No	No			
			1/9/20 14:10	1/9/20 14:12	0.03			x 113: Inspection/Maintenance	Manual (Go to 7)	Procedures	Yes (Go to 9)	Yes (Go to 10)			
15	x Shutdown	Engine #2	1/9/20 14.10	1/9/20 14.12	0.03	0.17	Johnson Matthey fault	116: Well Raising	x Automatic (Go to 9)	1 to 3	No	x No		P Madison	1/9/2020
13	x Startup	(S-65)	1/9/20 14:20	1/9/20 14:22	0.03	0.17	Johnson Matthey fault	117: Gas Collection	x Manual (Go to 7)	Procedures	Yes (Go to 9)	Yes (Go to 10)		1 Madison	1/9/2020
	Malfunction		173720 14.20	173720 14.22	0.00			118: Construction Activities	Automatic (Go to 9)	1 to 4	x No	No			
			1/9/20 14:40	1/9/20 14:42	0.03			x 113: Inspection/Maintenance	Manual (Go to 7)	Procedures	Yes (Go to 9)	Yes (Go to 10)			
16	x Shutdown	Engine #2	176720 1 1.10	170720 11.12	0.00	0.33	Johnson Matthey fault	116: Well Raising	x Automatic (Go to 9)	1 to 3	No	x No		P Madison	1/9/2020
	x Startup	(S-65)	1/9/20 15:00	1/9/20 15:02	0.03	0.00	comissi matarey radic	117: Gas Collection	x Manual (Go to 7)	Procedures	Yes (Go to 9)	Yes (Go to 10)		i madicon	17072020
	Malfunction		.,6,20 .6.66	.,0,20 .0.02	0.00			118: Construction Activities	Automatic (Go to 9)	1 to 4	x No	No			
			1/14/20 10:00	1/14/20 10:02	0.03			x 113: Inspection/Maintenance	x Manual (Go to 7)	Procedures	Yes (Go to 9)	Yes (Go to 10)			
17	x Shutdown	Engine #2				25.17	Exhaust Gas temp. sensor	116: Well Raising	Automatic (Go to 9)	1 to 3	x No	No		P Madison	1/15/2020
	x Startup	(S-65)	1/15/20 11:10	1/15/20 11:12	0.03		replacement	117: Gas Collection	x Manual (Go to 7)	Procedures	Yes (Go to 9)	Yes (Go to 10)			.,
	Malfunction							118: Construction Activities	Automatic (Go to 9)	1 to 4	x No	No			
	<u> </u>		1/15/20 11:50	1/15/20 11:52	0.03			x 113: Inspection/Maintenance	Manual (Go to 7)	Procedures	Yes (Go to 9)	Yes (Go to 10)			
18	x Shutdown	Engine #2				0.17	Johnson Matthey fault	116: Well Raising	x Automatic (Go to 9)	1 to 3	No	x No		P Madison	1/15/2020
	x Startup	(S-65)	1/15/20 12:00	1/15/20 12:02	0.03		,	117: Gas Collection	x Manual (Go to 7)	Procedures	Yes (Go to 9)	Yes (Go to 10)			
	Malfunction							118: Construction Activities	Automatic (Go to 9)	1 to 4	x No	No			
	L		1/15/20 12:15	1/15/20 12:17	0.03			x 113: Inspection/Maintenance	x Manual (Go to 7)	Procedures	Yes (Go to 9)	Yes (Go to 10)			
19	x Shutdown	Engine #2				0.25	Console error	116: Well Raising	Automatic (Go to 9)	1 to 3	x No	No (O ( 10)		P Madison	1/15/2020
	x Startup	(S-65)	1/15/20 12:30	1/15/20 12:32	0.03			117: Gas Collection	x Manual (Go to 7)	Procedures 1 to 4	Yes (Go to 9)	Yes (Go to 10)			
	Malfunction							118: Construction Activities	Automatic (Go to 9)		x No	No			
	Churkdauur	F : "0	1/15/20 13:35	1/15/20 13:37	0.03			x 113: Inspection/Maintenance	Manual (Go to 7)	Procedures 1 to 3	Yes (Go to 9)	Yes (Go to 10)			
20	x Shutdown	Engine #2 (S-65)				0.17	Johnson Matthey fault	116: Well Raising 117: Gas Collection	x Automatic (Go to 9)			Yes (Go to 10)		P Madison	1/15/2020
	x Startup  Malfunction	(0 00)	1/15/20 13:45	1/15/20 13:47	0.03			118: Construction Activities	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4	Yes (Go to 9) x No	No			
	Ivialiunction							x 113: Inspection/Maintenance	x Manual (Go to 7)		Yes (Go to 9)	Yes (Go to 10)			
	x Shutdown	Engine #2	1/19/20 8:35	1/19/20 8:37	0.03			116: Well Raising	Automatic (Go to 9)	Procedures 1 to 3	x No	No			
21	x Startup	(S-65)				1.42	EEE high voltage testing	117: Gas Collection	x Manual (Go to 7)	Procedures	Yes (Go to 9)	Yes (Go to 10)		P Madison	1/19/2020
	Malfunction	()	1/19/20 10:00	1/19/20 10:02	0.03			118: Construction Activities	Automatic (Go to 9)	1 to 4	x No	No			
	Mananotion							x 113: Inspection/Maintenance	Manual (Go to 7)	Procedures	Yes (Go to 9)	Yes (Go to 10)			
	x Shutdown	Engine #2	1/19/20 10:10	1/19/20 10:12	0.03			116: Well Raising	x Automatic (Go to 9)	1 to 3	No No	x No			
22	x Startup	(S-65)				0.25	Johnson Matthey fault	117: Gas Collection	x Manual (Go to 7)	Procedures	Yes (Go to 9)	Yes (Go to 10)		P Madison	1/19/2020
	Malfunction	( /	1/19/20 10:25	1/19/20 10:27	0.03			118: Construction Activities	Automatic (Go to 9)	1 to 4	x No	No			
	i i i i i i i i i i i i i i i i i i i							x 113: Inspection/Maintenance	x Manual (Go to 7)	Procedures	Yes (Go to 9)	Yes (Go to 10)			
	x Shutdown	Engine #2	1/20/20 8:25	1/20/20 8:27	0.03			116: Well Raising	Automatic (Go to 9)	1 to 3	x No	No			
23	x Startup	(S-65)	1/00/55 := 5	1/00/27 17 7		7.00	EEE high voltage testing	117: Gas Collection	x Manual (Go to 7)	Procedures	Yes (Go to 9)	Yes (Go to 10)		P Madison	1/20/2020
	Malfunction		1/20/20 15:25	1/20/20 15:27	0.03			118: Construction Activities	Automatic (Go to 9)	1 to 4	x No	No			
			4/07/00 40 50	4/07/00 40 50	0.00			x 113: Inspection/Maintenance	x Manual (Go to 7)	Procedures	Yes (Go to 9)	Yes (Go to 10)			
<i>~ :</i>	x Shutdown	Engine #2	1/27/20 13:50	1/27/20 13:52	0.03	0.50	0.11.0.511	116: Well Raising	Automatic (Go to 9)	1 to 3	x No	No			1/07/0000
24	x Startup	(S-65)	1/07/00 14:00	1/07/00 44:00	0.00	0.50	Oil & filter change	117: Gas Collection	x Manual (Go to 7)	Procedures	Yes (Go to 9)	Yes (Go to 10)		P Madison	1/27/2020
	Malfunction		1/27/20 14:20	1/27/20 14:22	0.03			118: Construction Activities	Automatic (Go to 9)	1 to 4	x No	No			

Event No.	Check Applicable Event	Device	(1) Event Start Date/Time	(2) Event End Date/Time	(3) Duration (Hrs)	Downtime (Hrs)	(4) Cause or Reason	(5) Applicable Regulation	(6) Type of Event	(7) Procedures Used (a),(b)	(8) Did Steps Taken Vary From (7)	(9) Did Event Cause Any Emission Limit Exceedance?	(10) Describe Emission Standard(s) Exceeded (b)	Completed By	(11) Date Entry Completed
25 X	x Shutdown	Engine #2	2/5/20 9:20	2/5/20 9:22	0.03	0.25	Johnson-Matthey fault	x 113: Inspection/Maintenance 116: Well Raising	Manual (Go to 7) x Automatic (Go to 9)	Procedures 1 to 3	Yes (Go to 9) No	Yes (Go to 10) x No		P Madison	2/5/2020
	x Startup  Malfunction	(S-65)	2/5/20 9:35	2/5/20 9:37	0.03	0.20		<ul><li>117: Gas Collection</li><li>118: Construction Activities</li></ul>	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4	Yes (Go to 9) x No	Yes (Go to 10)			2,0,2020
	x Shutdown	Engine #2	2/22/20 1:45	2/22/20 1:47	0.03	2.4-		x 113: Inspection/Maintenance 116: Well Raising	Manual (Go to 7) x Automatic (Go to 9)	Procedures 1 to 3	Yes (Go to 9)	Yes (Go to 10)		- · · · ·	0/00/0000
26	x Startup Malfunction	(S-65)	2/22/20 4:55	2/22/20 4:57	0.03	3.17	Reverse power	117: Gas Collection 118: Construction Activities	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4	Yes (Go to 9)	Yes (Go to 10)		P Madison	2/22/2020
	x Shutdown	Engine #2	2/22/20 5:15	2/22/20 5:17	0.03			x 113: Inspection/Maintenance 116: Well Raising	Manual (Go to 7)  x Automatic (Go to 9)	Procedures 1 to 3	Yes (Go to 9)	Yes (Go to 10)			
27	x Startup  Malfunction	(S-65)	2/22/20 5:55	2/22/20 5:57	0.03	0.67	Johnson-Matthey fault	117: Gas Collection  118: Construction Activities	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4	Yes (Go to 9)	Yes (Go to 10)		P Madison	2/22/2020
		Francis a #2	2/24/20 11:30	2/24/20 11:32	0.03			x 113: Inspection/Maintenance	Manual (Go to 7)	Procedures 1 to 3	Yes (Go to 9)	Yes (Go to 10)			
28	x Shutdown x Startup Malfunction	Engine #2 (S-65)	2/24/20 11:50	2/24/20 11:52	0.03	0.33	Engine overspeed	116: Well Raising 117: Gas Collection 118: Construction Activities	x Automatic (Go to 9) x Manual (Go to 7)	Procedures 1 to 4	Yes (Go to 9)	Yes (Go to 10)		P Madison	2/24/2020
	x Shutdown	Engine #2	2/24/20 12:05	2/24/20 12:07	0.03			x 113: Inspection/Maintenance 116: Well Raising	Automatic (Go to 9)  Manual (Go to 7)  x Automatic (Go to 9)	Procedures 1 to 3	Yes (Go to 9)	No Yes (Go to 10) x No			
29	x Startup Malfunction	(S-65)	2/24/20 12:20	2/24/20 12:22	0.03	0.25	Johnson-Matthey fault	117: Gas Collection  118: Construction Activities	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4	Yes (Go to 9)	Yes (Go to 10)		P Madison	2/24/2020
30	x Shutdown	vn Engine #2	2/24/20 22:25	2/24/20 22:27	0.03	7.40	Deterration and 44	x 113: Inspection/Maintenance 116: Well Raising	Manual (Go to 7)  x Automatic (Go to 9)	Procedures 1 to 3	Yes (Go to 9)	Yes (Go to 10) x No		P Madison	2/25/2020
30	x Startup Malfunction	(S-65)	2/25/20 5:50	2/25/20 5:52	0.03	7.42	Detonation cyl. 11	117: Gas Collection 118: Construction Activities	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4	Yes (Go to 9) x No	Yes (Go to 10)		Piwadison	
21	x Shutdown	Engine #2	2/25/20 6:25	2/25/20 6:27	0.03	0.25	Console malfunction	x 113: Inspection/Maintenance 116: Well Raising	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 3	Yes (Go to 9)	Yes (Go to 10)		— P Madison	2/25/2020
31	x Startup Malfunction	(S-65)	2/25/20 6:40	2/25/20 6:42	0.03	0.25	Console mailunction	117: Gas Collection 118: Construction Activities	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4	Yes (Go to 9)	Yes (Go to 10)		Piwadison	2/25/2020
20	x Shutdown	Engine #2	2/25/20 6:50	2/25/20 6:52	0.03	0.07	Laborator Martile and facility	x 113: Inspection/Maintenance 116: Well Raising	Manual (Go to 7) x Automatic (Go to 9)	Procedures 1 to 3	Yes (Go to 9)	Yes (Go to 10)		DMadia	0/05/0000
32	x Startup Malfunction	(S-65)	2/25/20 7:30	2/25/20 7:32	0.03	0.67	Johnson-Matthey fault	117: Gas Collection 118: Construction Activities	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4	Yes (Go to 9)	Yes (Go to 10)		P Madison	2/25/2020
33	x Shutdown	Engine #2	2/26/20 12:15	2/26/20 12:17	0.03	0.42	Electrical malfunctions	x 113: Inspection/Maintenance 116: Well Raising	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 3	Yes (Go to 9) x No	Yes (Go to 10) No		P Madison	2/26/2020
33	x Startup Malfunction	(S-65)	2/26/20 12:40	2/26/20 12:42	0.03	0.42	Electrical manufictions	117: Gas Collection 118: Construction Activities	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4	Yes (Go to 9) x No	Yes (Go to 10) No		P Madison	2/20/2020
34	x Shutdown	Engine #2	2/27/20 7:00	2/27/20 7:02	0.03	6.75	Wiring of new compressor	x 113: Inspection/Maintenance 116: Well Raising	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 3	Yes (Go to 9) x No	Yes (Go to 10) No		P Madison	2/27/2020
34	x Startup Malfunction	(S-65)	2/27/20 13:45	2/27/20 13:47	0.03	0.73	willing of flew compressor	117: Gas Collection 118: Construction Activities	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4	Yes (Go to 9) x No	Yes (Go to 10)		r Madison	2/21/2020
25	x Shutdown Engine #	Engine #2	2/27/20 14:50	2/27/20 14:52	0.03	0.22	Johnson Matthew foult	x 113: Inspection/Maintenance 116: Well Raising	Manual (Go to 7) x Automatic (Go to 9)	Procedures 1 to 3	Yes (Go to 9)	Yes (Go to 10) x No		D. Madiaan	2/27/2020
35	x Startup Malfunction	(S-65)	2/27/20 15:10	2/27/20 15:12	0.03	0.33	Johnson-Matthey fault	117: Gas Collection 118: Construction Activities	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4	Yes (Go to 9) x No	Yes (Go to 10) No		P Madison	2/27/2020
20	x Shutdown	Engine #2	2/27/20 15:20	2/27/20 15:22	0.03	0.05	Concelo Maléria eti ara	x 113: Inspection/Maintenance 116: Well Raising	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 3	Yes (Go to 9)	Yes (Go to 10)		D Modices	2/27/2020
36	x Startup Malfunction	(S-65)	2/27/20 15:35	2/27/20 15:37	0.03	0.25	Console Malfunction	117: Gas Collection 118: Construction Activities	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4	Yes (Go to 9)	Yes (Go to 10)		P Madison	2/27/2020

Event No.	Check Applicable Event	Device	(1) Event Start Date/Time	(2) Event End Date/Time	(3) Duration (Hrs)	Downtime (Hrs)	(4) Cause or Reason	(5) Applicable Regulation	(6) Type of Event	(7) Procedures Used (a),(b)	(8) Did Steps Taken Vary From (7)	(9) Did Event Cause Any Emission Limit Exceedance?	(10) Describe Emission Standard(s) Exceeded (b)	Completed By	(11) Date Entry Completed
37	x Shutdown	Startup (S-65) 2/27/20 16:45 2/27/20 16:47 0.	2/27/20 16:35	2/27/20 16:37	0.03	0.17	Johnson-Matthey fault	x 113: Inspection/Maintenance 116: Well Raising	Manual (Go to 7) x Automatic (Go to 9)	Procedures 1 to 3	Yes (Go to 9) No	Yes (Go to 10) x No		P Madison	2/27/2020
	x Startup Malfunction		0.03	0.17	Common Materioy radic	117: Gas Collection 118: Construction Activities	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4	Yes (Go to 9)	Yes (Go to 10)		i Waaison	2/21/2020		
	x Shutdown	Engine #2	3/10/20 21:45	3/10/20 21:47	0.03			x 113: Inspection/Maintenance 116: Well Raising	Manual (Go to 7)  x Automatic (Go to 9)	Procedures 1 to 3	Yes (Go to 9)	Yes (Go to 10)			
38	x Startup	(S-65)	3/10/20 21:55	3/10/20 21:57	0.03	0.17	High condensation level fault	117: Gas Collection 118: Construction Activities	x Manual (Go to 7)	Procedures 1 to 4	Yes (Go to 9)	Yes (Go to 10)		P Madison	3/10/2020
	Malfunction		3/10/20 22:05	3/10/20 22:07	0.03			x 113: Inspection/Maintenance	Automatic (Go to 9)  Manual (Go to 7)	Procedures	x No Yes (Go to 9)	Yes (Go to 10)			
39	x Shutdown x Startup	Engine #2 (S-65)	3/10/20 22:15	3/10/20 22:17	0.03	0.17	Johnson-Matthey fault	116: Well Raising 117: Gas Collection	x Automatic (Go to 9) x Manual (Go to 7)	1 to 3  Procedures	No Yes (Go to 9)	x No Yes (Go to 10)		P Madison	3/10/2020
	Malfunction		3/10/20 22:45	3/10/20 22:47	0.03			118: Construction Activities  x 113: Inspection/Maintenance	Automatic (Go to 9)  Manual (Go to 7)	1 to 4 Procedures	x No Yes (Go to 9)	No Yes (Go to 10)			
40	x Shutdown x Startup	Engine #2 (S-65)	3/10/20 22:55	3/10/20 22:57	0.03	0.17	Johnson-Matthey fault	116: Well Raising 117: Gas Collection	x Automatic (Go to 9) x Manual (Go to 7)	1 to 3 Procedures	No Yes (Go to 9)	x No Yes (Go to 10)		P Madison	3/10/2020
	Malfunction x Shutdown	Francis a 410	3/10/20 23:50	3/10/20 23:52	0.03			118: Construction Activities x 113: Inspection/Maintenance	Automatic (Go to 9)  Manual (Go to 7)	1 to 4 Procedures 1 to 3	x No Yes (Go to 9)	Yes (Go to 10)			
41	x Startup  Malfunction	Engine #2 (S-65)	3/11/20 0:05	3/11/20 0:07	0.03	0.25	Johnson-Matthey fault	116: Well Raising 117: Gas Collection 118: Construction Activities	x Automatic (Go to 9) x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4	Yes (Go to 9)	x No Yes (Go to 10) No		P Madison	3/11/2020
	x Shutdown	Engine #2	3/12/20 10:50	3/12/20 10:52	0.03	4.47		x 113: Inspection/Maintenance 116: Well Raising	x Manual (Go to 7)  Automatic (Go to 9)	Procedures 1 to 3	Yes (Go to 9)	Yes (Go to 10)	P Madison	0/40/0000	
42	x Startup Malfunction	(S-65)	3/12/20 12:00	3/12/20 12:02	0.03	1.17	Replaced exhaust temp sensor	117: Gas Collection 118: Construction Activities	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4	Yes (Go to 9)	Yes (Go to 10)		P Madison	3/12/2020
40	x Shutdown	Engine #2	3/12/20 12:10	3/12/20 12:12	0.03	0.50	Johnson-Matthey fault	x 113: Inspection/Maintenance 116: Well Raising	Manual (Go to 7) x Automatic (Go to 9)	Procedures 1 to 3	Yes (Go to 9)	Yes (Go to 10)		D.M. II	0/40/0000
43	x Startup Malfunction	(S-65)	3/12/20 12:40	3/12/20 12:42	0.03	0.50		117: Gas Collection 118: Construction Activities	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4	Yes (Go to 9)	Yes (Go to 10)		<ul><li>P Madison</li></ul>	3/12/2020
	x Shutdown	Engine #2	3/13/20 8:55	3/13/20 8:57	0.03	0.50		x 113: Inspection/Maintenance 116: Well Raising	Manual (Go to 7)  x Automatic (Go to 9)	Procedures 1 to 3	Yes (Go to 9)	Yes (Go to 10)		5.4 "	0/40/0000
44	x Startup Malfunction	(S-65)	3/13/20 9:25	3/13/20 9:27	0.03	0.50	Johnson-Matthey fault	117: Gas Collection 118: Construction Activities	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4	Yes (Go to 9)	Yes (Go to 10)		P Madison	3/13/2020
45	x Shutdown	Engine #2	3/27/20 4:25	3/27/20 4:27	0.03	5.08	Detonation on Cylinder 11 &	x 113: Inspection/Maintenance 116: Well Raising	Manual (Go to 7) x Automatic (Go to 9)	Procedures 1 to 3	Yes (Go to 9) No	Yes (Go to 10) x No		P Madison	3/27/2020
43	x Startup Malfunction	(S-65)	3/27/20 9:30	3/27/20 9:32	0.03	3.08	Johnson-Matthey faults	<ul><li>117: Gas Collection</li><li>118: Construction Activities</li></ul>	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4	Yes (Go to 9) x No	Yes (Go to 10) No		F Madison	3/2//2020
46	x Shutdown	Engine #2	3/30/20 14:20	3/30/20 14:22	0.03	0.50	Turbo inlet temp high	x 113: Inspection/Maintenance 116: Well Raising	Manual (Go to 7) x Automatic (Go to 9)	Procedures 1 to 3	Yes (Go to 9) No	Yes (Go to 10) x No		P Madison	3/30/2020
40	x Startup Malfunction	(S-65)	3/30/20 14:50	3/30/20 14:52	0.03	0.50	Turbo illiet temp high	<ul><li>117: Gas Collection</li><li>118: Construction Activities</li></ul>	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4	Yes (Go to 9) x No	Yes (Go to 10) No		i Madison	3/30/2020
47	x Shutdown	Engine #2	3/31/20 4:15	3/31/20 4:17	0.03	0.50	Johnson-Matthey fault	x 113: Inspection/Maintenance 116: Well Raising	Manual (Go to 7) x Automatic (Go to 9)	Procedures 1 to 3	Yes (Go to 9) No	Yes (Go to 10) x No		P Madison	3/31/2020
47	x Startup Malfunction	(S-65)	3/31/20 4:45	3/31/20 4:47	0.03	0.50	Johnson-Waturey raun	<ul><li>117: Gas Collection</li><li>118: Construction Activities</li></ul>	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4	Yes (Go to 9) x No	Yes (Go to 10) No		i iviauisuil	3/31/2020
48	x Shutdown	Engine #2	3/31/20 5:20	3/31/20 5:22	0.03	0.42	high IM/tomp	x 113: Inspection/Maintenance 116: Well Raising	Manual (Go to 7) x Automatic (Go to 9)	Procedures 1 to 3	Yes (Go to 9) No	Yes (Go to 10) x No		P Madison	3/31/2020
48	x Startup Malfunction	(S-65)	3/31/20 5:45	3/31/20 5:47	0.03	0.42	high JW temp	117: Gas Collection 118: Construction Activities	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4	Yes (Go to 9)	Yes (Go to 10)		P Madison	3/31/2020

Event No.	Check Applicable Event	Device	(1) Event Start Date/Time	(2) Event End Date/Time	(3) Duration (Hrs)	Downtime (Hrs)	(4) Cause or Reason	(5) Applicable Regulation	(6) Type of Event	(7) Procedures Used (a),(b)	(8) Did Steps Taken Vary From (7)	(9) Did Event Cause Any Emission Limit Exceedance?	(10) Describe Emission Standard(s) Exceeded (b)	Completed By	(11) Date Entry Completed
49 x S	x Shutdown	Engine #2	3/31/20 5:45	3/31/20 5:47	0.03	0.75	Johnson-Matthey fault	x 113: Inspection/Maintenance 116: Well Raising	Manual (Go to 7) x Automatic (Go to 9)	Procedures 1 to 3	Yes (Go to 9) No	Yes (Go to 10) x No		P Madison	3/31/2020
40	x Startup  Malfunction	(S-65) 3/31/20 6:30 3/31/20 6:32 0.03	0.03	0.70	oomioon mataroy laak	117: Gas Collection 118: Construction Activities	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4	Yes (Go to 9)	Yes (Go to 10)		i Waaison	0/01/2020		
	x Shutdown	Engine #2	4/2/20 18:25	4/2/20 18:27	0.03			x 113: Inspection/Maintenance 116: Well Raising	Manual (Go to 7) x Automatic (Go to 9)	Procedures 1 to 3	Yes (Go to 9)	Yes (Go to 10)			
50	x Startup Malfunction	(S-65)	4/2/20 19:50	4/2/20 19:52	0.03	1.42	SCR Fault	117: Gas Collection 118: Construction Activities	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4	Yes (Go to 9)	Yes (Go to 10)		P Madison	4/2/2020
	x Shutdown	Engine #2	4/5/20 22:50	4/5/20 22:52	0.03			x 113: Inspection/Maintenance	Manual (Go to 7)  x Automatic (Go to 9)	Procedures 1 to 3	Yes (Go to 9)	Yes (Go to 10)			
51	x Startup	(S-65)	4/6/20 6:10	4/6/20 6:12	0.03	7.33	SCR fault	117: Gas Collection	x Manual (Go to 7)	Procedures 1 to 4	Yes (Go to 9)	Yes (Go to 10)		P Madison	4/6/2020
	Malfunction		4/6/20 6:35	4/6/20 6:37	0.03			118: Construction Activities  x 113: Inspection/Maintenance	Automatic (Go to 9)  Manual (Go to 7)	Procedures 1 to 3	x No Yes (Go to 9)	Yes (Go to 10)			
52	x Shutdown x Startup Malfunction	Engine #2 (S-65)	4/6/20 7:05	4/6/20 7:07	0.03	0.50	SCR Fault	116: Well Raising 117: Gas Collection 118: Construction Activities	x Automatic (Go to 9) x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4	Yes (Go to 9)	x No Yes (Go to 10)		P Madison	4/6/2020
	x Shutdown	Engine #2	4/6/20 7:50	4/6/20 7:52	0.03			x 113: Inspection/Maintenance 116: Well Raising	Manual (Go to 7)  X Automatic (Go to 9)	Procedures 1 to 3	Yes (Go to 9)	No Yes (Go to 10) x No			
53	x Startup  Malfunction	(S-65)	4/6/20 8:15	4/6/20 8:17	0.03	0.42	SCR Fault	117: Gas Collection 118: Construction Activities	X Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4	Yes (Go to 9)	Yes (Go to 10)		P Madison	4/6/2020
54	x Shutdown	J	4/9/20 0:05	4/9/20 0:07	0.03	0.33	Johnson-Matthey fault	x 113: Inspection/Maintenance 116: Well Raising	Manual (Go to 7)  x Automatic (Go to 9)	Procedures 1 to 3	Yes (Go to 9) No	Yes (Go to 10) x No		P Madison	4/9/2020
34	x Startup Malfunction	(S-65)	4/9/20 0:25	4/9/20 0:27	0.03	0.55	Johnson-Matthey fault	117: Gas Collection 118: Construction Activities	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4	Yes (Go to 9) x No	Yes (Go to 10) No			
55	x Shutdown	Engine #2	4/9/20 0:40	4/9/20 0:42	0.03	0.25	Johnson-Matthey fault	x 113: Inspection/Maintenance 116: Well Raising	x Manual (Go to 7) x Automatic (Go to 9)	Procedures 1 to 3	Yes (Go to 9) x No	Yes (Go to 10) x No		P Madison	4/9/2020
55	x Startup Malfunction	(S-65)	4/9/20 0:55	4/9/20 0:57	0.03	0.25		117: Gas Collection 118: Construction Activities	Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4	Yes (Go to 9) No	Yes (Go to 10) No		i iviauisoii	41012020
56	x Shutdown	Engine #2	4/9/20 1:10	4/9/20 1:12	0.03	0.05	Jahonan Maddhau fault	x 113: Inspection/Maintenance 116: Well Raising	Manual (Go to 7)  x Automatic (Go to 9)	Procedures 1 to 3	Yes (Go to 9)	Yes (Go to 10)		P Madison	4/0/2020
56	x Startup Malfunction	(S-65)	4/9/20 1:25	4/9/20 1:27	0.03	0.25	Johnson-Matthey fault	117: Gas Collection 118: Construction Activities	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4	Yes (Go to 9) x No	Yes (Go to 10) No		Piviadison	4/9/2020
57	x Shutdown	Engine #2	4/9/20 1:30	4/9/20 1:32	0.03	0.33	High coolant temp	x 113: Inspection/Maintenance 116: Well Raising	Manual (Go to 7) x Automatic (Go to 9)	Procedures 1 to 3	Yes (Go to 9) No	Yes (Go to 10) x No		P Madison	4/9/2020
37	x Startup Malfunction	(S-65)	4/9/20 1:50	4/9/20 1:52	0.03	0.55	riigh coolant temp	117: Gas Collection 118: Construction Activities	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4	Yes (Go to 9) x No	Yes (Go to 10) No		i Madisoli	4/9/2020
58	x Shutdown	Engine #2	4/9/20 2:35	4/9/20 2:37	0.03	0.17	Johnson-Matthey fault	x 113: Inspection/Maintenance 116: Well Raising	Manual (Go to 7) x Automatic (Go to 9)	Procedures 1 to 3	Yes (Go to 9) No	Yes (Go to 10) x No		P Madison	4/9/2020
30	x Startup Malfunction	(S-65)	4/9/20 2:45	4/9/20 2:47	0.03	0.17	Johnson-Matthey fault	117: Gas Collection 118: Construction Activities	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4	Yes (Go to 9) x No	Yes (Go to 10) No		i Madisori	4/9/2020
59	x Shutdown Engine	Engine #2	4/9/20 3:10	4/9/20 3:12	0.03	0.42	High coolant tomp	x 113: Inspection/Maintenance 116: Well Raising	Manual (Go to 7) x Automatic (Go to 9)	Procedures 1 to 3	Yes (Go to 9) No	Yes (Go to 10) x No		D Madison	4/0/2020
J9	x Startup Malfunction	(S-65)	4/9/20 3:35	4/9/20 3:37	0.03	0.42	High coolant temp	117: Gas Collection 118: Construction Activities	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4	Yes (Go to 9) x No	Yes (Go to 10) No		<ul><li>P Madison</li></ul>	4/9/2020
60	x Shutdown	Engine #2	4/9/20 3:50	4/9/20 3:52	0.03	0.50	Johnson Matthew fault	x 113: Inspection/Maintenance 116: Well Raising	Manual (Go to 7) x Automatic (Go to 9)	Procedures 1 to 3	Yes (Go to 9) No	Yes (Go to 10) x No		D Madisas	4/0/2020
60	x Startup Malfunction	(S-65)	4/9/20 4:20	4/9/20 4:22	0.03	0.50	Johnson-Matthey fault	117: Gas Collection 118: Construction Activities	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4	Yes (Go to 9)	Yes (Go to 10)		P Madison	4/9/2020

							William Li & Englis	e #2 (S-65) DEVICE DO				(9) Did Event	(10) Describe		1
Event No.	Check Applicable Event	Device	(1) Event Start Date/Time	(2) Event End Date/Time	(3) Duration (Hrs)	Downtime (Hrs)	(4) Cause or Reason	(5) Applicable Regulation	(6) Type of Event	(7) Procedures Used (a),(b)	(8) Did Steps Taken Vary From (7)	Cause Any Emission Limit Exceedance?	Emission Standard(s) Exceeded (b)	Completed By	(11) Date Entry Completed
			4/13/20 9:35	4/13/20 9:37	0.03			x 113: Inspection/Maintenance	x Manual (Go to 7)	Procedures	Yes (Go to 9)	Yes (Go to 10)			
61	x Shutdown	Engine #2	4/10/20 0.00	4/10/20 5.57	0.00	0.58	Oil & filter change	116: Well Raising	Automatic (Go to 9)	1 to 3	x No	No		P Madison	4/13/2020
	x Startup	(S-65)	4/13/20 10:10	4/13/20 10:12	0.03	0.00	on a mer onange	117: Gas Collection	x Manual (Go to 7)	Procedures	Yes (Go to 9)	Yes (Go to 10)		1 Waaisen	4/10/2020
	Malfunction		17 10/20 10:10	1710/20 10:12	0.00			118: Construction Activities	Automatic (Go to 9)	1 to 4	x No	No			
	<u> </u>		4/14/20 1:55	4/14/20 1:57	0.03		<u> </u>	x 113: Inspection/Maintenance	Manual (Go to 7)	Procedures	Yes (Go to 9)	Yes (Go to 10)			
62	x Shutdown	Engine #2				6.75	Johnson-Matthey fault	116: Well Raising	x Automatic (Go to 9)	1 to 3	No	x No		P Madison	4/14/2020
	x Startup	(S-65)	4/14/20 8:40	4/14/20 8:42	0.03		, , <u>,</u>	117: Gas Collection	x Manual (Go to 7)	Procedures	Yes (Go to 9)	Yes (Go to 10)			
	Malfunction							118: Construction Activities	Automatic (Go to 9)	1 to 4	x No	No			
	<u> </u>		4/14/20 9:30	4/14/20 9:32	0.03		<u> </u>	x 113: Inspection/Maintenance	Manual (Go to 7)	Procedures	Yes (Go to 9)	Yes (Go to 10)			
63	x Shutdown	Engine #2				0.17	Johnson-Matthey fault	116: Well Raising	x Automatic (Go to 9)	1 to 3	No	x No		P Madison	4/14/2020
	x Startup	(S-65)	4/14/20 9:40	4/14/20 9:42	0.03		, 	117: Gas Collection	x Manual (Go to 7)	Procedures	Yes (Go to 9)	Yes (Go to 10)			
	Malfunction							118: Construction Activities	Automatic (Go to 9)	1 to 4	x No	No			
	<u> </u>		4/14/20 16:45	4/14/20 16:47	0.03		-	x 113: Inspection/Maintenance	Manual (Go to 7)	Procedures	Yes (Go to 9)	Yes (Go to 10)			
64	x Shutdown	Engine #2				0.17	JW high temp	116: Well Raising	x Automatic (Go to 9)	1 to 3	No (O ( O)	x No		P Madison	4/14/2020
	x Startup	(S-65)	4/14/20 16:55 4/14/20 16:57	4/14/20 16:57	0.03		orr riight tomp	117: Gas Collection	x Manual (Go to 7)	Procedures	Yes (Go to 9)	Yes (Go to 10)			
	Malfunction							118: Construction Activities	Automatic (Go to 9)	1 to 4	x No	No (O t to)			
	Chutalauna	Engine #2	4/14/20 17:00	4/14/20 17:02	0.03			x 113: Inspection/Maintenance	Manual (Go to 7)	Procedures 1 to 3	Yes (Go to 9)	Yes (Go to 10)			
65	x Shutdown	Engine #2 (S-65)				0.33	JW high temp	116: Well Raising	x Automatic (Go to 9)		No	x No		P Madison	4/14/2020
	x Startup  Malfunction	(3-03)	4/14/20 17:20	4/14/20 17:22	0.03			117: Gas Collection	x Manual (Go to 7)	Procedures 1 to 4	Yes (Go to 9)	Yes (Go to 10)			
	Manufiction							x 113: Inspection/Maintenance	Automatic (Go to 9)  x Manual (Go to 7)		Yes (Go to 9)	No Yes (Go to 10)			
	x Shutdown	Engine #2	4/21/20 6:15 4/21/20 6:17	0.03		Replace Jacket Water	116: Well Raising	Automatic (Go to 9)	Procedures 1 to 3	x No	No				
66	x Startup	(S-65)				3.42	Regulators	117: Gas Collection	x Manual (Go to 7)	Procedures	Yes (Go to 9)	Yes (Go to 10)	P Madisor	P Madison	4/21/2020
	Malfunction	(5 55)	4/21/20 9:40	4/21/20 9:42	0.03		- Trogulatoro	118: Construction Activities	Automatic (Go to 9)	1 to 4	x No	No			
	Wallandiolon							x 113: Inspection/Maintenance	Manual (Go to 7)	Procedures	Yes (Go to 9)	Yes (Go to 10)			
	x Shutdown	Engine #2	4/22/20 11:10	4/22/20 11:12	0.03			116: Well Raising	x Automatic (Go to 9)	1 to 3	No	x No			
67	x Startup	(S-65)				0.25	Crankcase vent filter	117: Gas Collection	x Manual (Go to 7)	Procedures	Yes (Go to 9)	Yes (Go to 10)		P Madison	4/22/2020
	Malfunction	` ,	4/22/20 11:25	4/22/20 11:27	0.03			118: Construction Activities	Automatic (Go to 9)	1 to 4	x No	No (SS to 15)			
							1	x 113: Inspection/Maintenance	Manual (Go to 7)	Procedures	Yes (Go to 9)	Yes (Go to 10)			
	x Shutdown	Engine #2	4/29/20 13:15	4/29/20 13:17	0.03		Detonation Cylinder 18 & J-M	116: Well Raising	x Automatic (Go to 9)	1 to 3	H <sub>No</sub> `	x No			
68	x Startup	(S-65)				2.50	fault	117: Gas Collection	x Manual (Go to 7)	Procedures	Yes (Go to 9)	Yes (Go to 10)		P Madison	4/29/2020
	Malfunction		4/29/20 15:45	4/29/20 15:47	0.03			118: Construction Activities	Automatic (Go to 9)		x No	No			
			1/00/00 10 50	1/00/00 10 50	2.22			x 113: Inspection/Maintenance	Manual (Go to 7)	Procedures	Yes (Go to 9)	Yes (Go to 10)			
00	x Shutdown	Engine #2	4/29/20 16:50	4/29/20 16:52	0.03	0.47	i i	116: Well Raising	x Automatic (Go to 9)	1 to 3	No `	x No `		D.4. II	4/00/0000
69	x Startup	(S-65)	4/00/00 47 00	4/00/00 47 00	0.00	0.17	Johnson-Matthew fault	117: Gas Collection	x Manual (Go to 7)	Procedures	Yes (Go to 9)	Yes (Go to 10)		P Madison	4/29/2020
	Malfunction		4/29/20 17:00	4/29/20 17:02	0.03		T	118: Construction Activities	Automatic (Go to 9)	1 to 4	x No	No			
			4/00/00 47 40	4/00/00 47:40	0.00			x 113: Inspection/Maintenance	Manual (Go to 7)	Procedures	Yes (Go to 9)	Yes (Go to 10)			
70	x Shutdown	Engine #2	4/29/20 17:10	4/29/20 17:12	0.03	0.25	Johnson Metthew fault	116: Well Raising	x Automatic (Go to 9)	1 to 3	No	x No		D Madiaar	4/20/2020
70	70 x Startup (S-65)	4/20/20 47:25	4/20/20 47:27	0.02	0.25	Johnson-Matthew fault	117: Gas Collection	x Manual (Go to 7)	Procedures	Yes (Go to 9)	Yes (Go to 10)		P Madison	4/29/2020	
	Malfunction		4/29/20 17:25	4/29/20 17:27	0.03		ļ	118: Construction Activities	Automatic (Go to 9)	1 to 4	x No	No			

## REDWOOD LANDFILL, INC. WMRE TREATMENT SYSTEM (S-71) DOWNTIME LOG

Event No.	Check Applicable Event	Device	(1) Event Start Date/Time	(2) Event End Date/Time	(3) Duration (Hrs)	Downtime (Hrs)	(4) Cause or Reason	(5) Applicable Regulation	(6) Type of Event	(7) Procedures Used (a),(b)	(8) Did Steps Taken Vary From (7)	(9) Did Event Cause Any Emission Limit Exceedance?	(10) Describe Emission Standard(s) Exceeded (b)	Completed By	(11) Date Entry Completed
No S-71 SSM events in November 2019															
	x Shutdown	Treatment	12/9/19 9:00	12/9/19 9:02	0.03			x 113: Inspection/Maintenance	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 3	Yes (Go to 9)	Yes (Go to 10)			
1	x Startup  Malfunction	System (S-71)	12/17/19 12:40	12/17/19 12:42	0.03	195.67	Repairs to flare	117: Gas Collection 118: Construction Activities	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4	Yes (Go to 9)	Yes (Go to 10)		P Madison	12/17/2019
2	x Shutdown	Treatment	1/20/20 8:40	1/20/20 8:42	0.03	5.00		x 113: Inspection/Maintenance 116: Well Raising	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 3	Yes (Go to 9) x No	Yes (Go to 10)		DMadiana	4/00/0000
2	x Startup Malfunction	System (S-71)	1/20/20 14:00	1/20/20 14:02	0.03	5.33	EEE high voltage testing	117: Gas Collection 118: Construction Activities	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4	Yes (Go to 9) x No	Yes (Go to 10) No		P Madison	1/20/2020
No S-71 SSM events in February 2020															
	No S-71 SSM events in March 2020														
	No S-71 SSM events in April 2020														

## **Emission Control Devices Gas Collection and Control System (GCCS) Downtime Summary**

Redwood Landfill, Nov GCCS DOWNTIME REF	-	November 1, 2019 to A	oril 30, 2020
SHUTDOWN DATE/TIME	START-UP DATE/TIME	TOTAL DOWNTIME (hours)	COMMENTS/ACTION TAKEN
11/07/19 10:48	11/07/19 11:26	0.63	Manual Shutdown to disconnect generator from compressor.
11/27/19 00:28	11/27/19 01:00	0.53	All control devices were shutdown due to a site-wide power outage. Inspected upon restart of the control devices. Visual inspections and PLC checks were
12/09/19 09:00	12/09/19 09:04	0.07	Manual Shutdown for piping Willexa to A60A side.
12/16/19 12:20	12/16/19 12:22	0.03	Manual Shutdown for maintenance & programing.
12/16/19 12:50	12/16/19 12:52	0.03	Manual Shutdown for maintenance & programing.
12/17/19 08:50	12/17/19 08:54	0.07	Manual Shutdown for maintenance.
12/17/19 10:06	12/17/19 10:10	0.07	Flame alarm shutdown. System inspected after restart.
12/18/19 15:58	12/18/19 16:02	0.07	Flame alarm shutdown. System inspected after restart.
01/03/20 08:24	01/03/20 08:26	0.03	A51 Flare Started to check operating parameters.
01/03/20 09:28	01/03/20 09:30	0.03	A51 Flare Started to check operating parameters.
01/15/20 11:12	01/15/20 11:20	0.13	A51 Flare Started to check new flame arrestor.
01/15/20 12:18	01/15/20 12:20	0.03	A51 Flare Started to check new flame arrestor.
01/20/20 08:18	01/20/20 08:20	0.03	A51 Started to check Flowmeter calibration.
01/21/20 07:14	01/21/20 07:16	0.03	A51 Started for engineering test.
01/21/20 12:00	01/21/20 12:02	0.03	A51 Started for engineering test.
01/22/20 06:38	01/22/20 06:40	0.03	A51 Started for Annual Source Test.
01/22/20 12:06	01/22/20 12:08	0.03	A51 Started for Annual Source Test.
		0.00	No GCCS Downtime in February 2020
		0.00	No GCCS Downtime in March 2020
04/21/20 06:30	04/21/20 06:32	0.03	A51 flare started for swapping A60 blowers
04/21/20 06:46	04/21/20 06:48	0.03	A51 flare started for swapping A60 blowers
04/30/20 09:42	04/30/20 09:44	0.03	A51 started for A60 Yokogawa maintenance

Combined Emission Control Devices	
Total 2019 Downtime:	64.63
November 1, 2019 through April 30, 2020 Downtime:	2.00
January 1, 2020 through April 30, 2020 Total Downtime:	0.50
Total 2020 Downtime:	0.50

GCCS Downtime is when emission control devices (flares only) are not operating.

Downtime RLI 2020.05 SAR Appendix v1.xlsx

# APPENDIX C BAAQMD CORRESPONDENCE



**REDWOOD LANDFILL, INC.** 

8950 Redwood Highway P.O. Box 793 Novato, CA 94948 (415) 892-2851 (855) 242-0798 Fax

November 4, 2019

(Via email: compliance@baaqmd.gov)

Director of Compliance and Enforcement Bay Area Air Quality Management District 375 Beale Street, Suite 600 San Francisco, California 94105

Attn: Title V Reports

**Re:** Title V 10-Day Written Report for PG&E Public Safety Power Shutoff (PSPS)

Facility A1179, Redwood Landfill, Inc., Novato, California

Dear Sir or Madam:

The Redwood Landfill, Inc. (RLI) is submitting this 10-day written report to the Bay Area Air Quality Management District (BAAQMD) as required under Title V Permit Condition Section I.F for Monitoring Reports.

The RLI Title V Permit Requirement states that "All instances of non-compliance with the permit shall be reported in writing to the District's Compliance and Enforcement Division within 10 calendar days of the discovery of the incident". This 10-day written report is a follow-up report for the RLI Permit Source S-5 due to the recent PG&E's Public Safety Power Shutoff (PSPS).

The RLI gas collection and control system (GCCS) was shutdown for an extended period from 10/26/2019 5:18 PM through 10/28/2019 9:46 PM, due to the recent PSPS event. During this PSPS event, the GCCS was potentially out of compliance with the BAAQMD regulation 8-34-301.1.

A breakdown report was submitted during the weekend on 10/26/2019 at  $\sim 7:53$  pm via the afterhours phone line (BAAQMD issued RCA #07P68) and updated with event clear date on October 28, 2019 when RLI was able to secure a rental generator and connect it to the GCCS and get it back online (see attachments).

RLI has requested that a Breakdown Relief should be granted as RLI complied with administrative requirements despite its objections to the re-interpretation of Rule 8-34 and:

- 1. The breakdown is not the result of intent, negligence or disregard of air pollution control regulations;
- 2. The breakdown is not the result of improper maintenance;
- 3. The breakdown does not create a public nuisance;

- 4. The breakdown was not caused by an excessively recurrent breakdown of the same equipment; and
- 5. The breakdown did not occur and any emissions did not interfere with attainment or maintenance of any National or California air quality standard.

RLI filed for an Emergency Variance on October 28, 2019, due to the potential length of the PSPS. RLI had been actively seeking a permitted generator to power the flare before the PSPS. On October 28, 2019, RLI secured a generator and arranged for an electrician to make the necessary connections to power the GCCS. The RLI GCCS came back online via generator power on October 28, 2019 at 9:46 pm.

As required, RLI will submit a 30-day follow-up written report and provide additional details as appropriate. RLI is committed to operating its landfill in compliance with all applicable regulations.

If you have any questions regarding this notification, please contact me at (510) 613-2852 or Alisha McCutcheon, Redwood Landfill Technical Manager, at (415) 373-8033.

Thank you,

Redwood Landfill, Inc.

**Michael Chan** 

**Environmental Protection Specialist** 

Stubal Chan

Attachment: RLI RCA Form -RCA Number 07P68 for Breakdown Relief

# BAY AREA AIR QUALITY MANAGEMENT DISTRICT

Received by

#### **COMPLIANCE & ENFORCEMENT DIVISION**

#### **Notification Form**

Reportable Compliance Activity (RCA)

Time

		See back of form f	or instructions →							
I. X BREAKDOWN RELIEF: District Use Only BREAKDOWN REFERENCE #:										
2. MONITOR EXCESS EMISSION or EXCURSION: District Use Only REFERENCE #:										
3. MONITOR IS INOPERATIVE: District Use Only REFERENCE #:										
4. PRESSURE RELIEF DEVICE (PRD): District Use Only PRD REFERENCE #:										
SITE INF	ORMATION AND DESCRIPTION INFO	RMATION (REQUIR	ED)							
Company	Redwood Landfill (RLI)	Site #	A1179							
Address	8950 Redwood Hwy, Novato	Source #	S5							
Reported by	C. Colline/Michael Chan	Phone #	510-613-2852							
Indicated Excess		Fax #								
Allowable Limit		Averaging Time								
Start Time/Date	10/26/2019 5:18 PM	Clear Time	10/28/19 9:46 PM							
Monitor/device type(s)	▶ CEM     ▶ GLM     ▶ Parar	metric ►PRD	► Non-monitor							
Monitor description(s)										
►NO <sub>x</sub> ►SO <sub>2</sub> ►Hydrocarbon Brea	O D ►Opacity ► Lead	· ·	Flow Flow							
	▶ Wind Direction       ▶ Steam       X       ▶ Other (describe) Power Outage									
Unit(s) of Measurement		<b>7</b>								
▶ ppm   ▶ ppb   ▶ min/hr > 20%   ▶ inches H <sub>2</sub> O   ▶ mmHg										
<b>▶</b> psig <b>▶</b> pH	► <sup>0</sup> Fahrenheit	► Other (describe)								
Event Description: breakdown report was submitted on 10/26/2019 at ~7:53 pm via the after ours phone line by RLI because the GCCS cannot continuously operate due to G&E's forced Public Safety Power Shutoff (PSPS). During the PG&E's forced SPS power outage, the GCCS was potentially out of compliance with BAAQMD egulation 8-34-301.1. Please also see our objections and discussion in the ttached cover letter dated 10/28/2019. Update(10/29/2019)(RCA #07P68):										
	and GCCS back online 10/28/20		•							

District Use Only

Date

- ✓ Check the Box numbers 1- 4 that apply to the RCA you are trying to report or request and read the detailed instructions.
- ✓ You will receive an ID # for each RCA you submit. In the case of a request for Breakdown Relief where multiple monitors are affected, you do not need to submit multiple forms, as long as all necessary information is given on one form. RCA reported during other than core business hours will be assigned an ID # the following working day. If you do not receive an ID #, it is your responsibility to contact the BAAQMD to get one.
- ✓ You may submit only one request for breakdown relief per form. However, you may submit multiple indicated excess, inoperative monitors and PRD reports on one form, provided that the start and end times given for the events in the required information section is inclusive of all events. Information on parameters exceeded, units of measurement and allowable limits can be provided in the event description box or when contacted by District staff with questions.
- ✓ Fill out the "Site Information and Description Information Required" areas of this form and email to rca@baagmd.gov
- ✓ A 30-day written follow-up report is required for Breakdown Requests and PRD Releases. Reports for these types of RCA must contain a quantification of emissions, the calculations used to derive the emissions, and their duration. Reference Breakdown Admissions Advisory dated 12/3/04. Send 30-day report letters to: BAAQMD Compliance and Enforcement Division, MAILSTOP: RCA 30-DAY REPORT, 375 Beale Street, Ste. 600 San Francisco, CA 94105. NOTE: You may have additional report requirements under Title V.

#### **Detailed Instructions**

#### Box 1: To Request Breakdown Relief (Regulations 1-112, 1-113, 1-208, 1-431, 1-432)

If you have an equipment malfunction (e.g.; breakdown) that leads to the release of air pollutants above the regulatory or your permitted levels, you may request relief from BAAQMD enforcement action.

- Check Box #1.
- NOTE: Start and end times given for these events in the required information section must be inclusive of all events.
- Fill out all the information in the "Site Information and Description Information (Required)" area of the form.
- Requests for breakdown relief may not be withdrawn and must be called in or faxed to the BAAQMD <u>immediately upon</u> discovery of an equipment malfunction.
- Receipt of an RCA ID# for a breakdown does not mean relief has been granted. An Inspector will visit your facility to determine compliance.

#### Box 2: Monitor Indicates Excess Emission or Excursion (Regulation 1-522.7, 1-523.3, 1-542)

When a BAAQMD-required monitor indicates an excess or excursion, you must report it to the BAAQMD.

- Check Box #2.
- Fill out all the information in the "Site Information and Description Information (Required)" area of the form.
- Any excess emission indicated by a CEM or excursion of a parametric monitor, shall be reported to the BAAQMD within 96 hours.
- Area concentration excesses over the limits prescribed in District regulations shall be reported to the BAAQMD within the next normal working day following the examination of data.

#### Box 3: Monitor Is Inoperative (Regulations 1-522, 1-523, 1-530)

When a BAAQMD-required monitor is inoperative for greater than 24 hours, you must report it to the BAAQMD.

- Check Box #3 only if inoperative for greater than 24 hours.
- Fill out all the information in the "Site Information and Description Information (Required)" area of the form.
- All reports of inoperative monitors must be reported by the following BAAQMD working day and additionally be cleared by a
  notification of resumption of monitoring. To notify the BAAQMD regarding the resumption of monitoring, do not send in a
  separate RCA form; call (415) 749-4979 and give the RCA ID #, date, and the time of resumption.
- Inoperative monitors (except parametric monitors) with downtime greater than 15 days must furnish proof of expedited repair in a follow-up report.

#### Box 4: Pressure Relief Device (PRD) Is Released (Regulation 8-28-401)

When a PRD at your refinery/chemical plant vents to the atmosphere, you must report it to the BAAQMD.

- Check Box #4 only if a pressure relief device is released.
- Separate RCA ID #'s can be applied to monitor(s) affected by a PRD by also checking Box #2 if other monitors record an excess or excursion.
- Fill out all the information in the "Site Information and Description Information (Required)" area of the form.
- All PRD release reports must be reported by the following BAAQMD working day.

Email to ►rca@baaqmd.gov - Telephone ► 415.749.4979 (M-F 8:30 am – 5:00 pm) - After core business hours, email or call ► 415.749.4666 Form Revision Dated: 12-12-18

#### **UPS CampusShip: View/Print Label**

- 1. **Ensure there are no other shipping or tracking labels attached to your package.** Select the Print button on the print dialog box that appears. Note: If your browser does not support this function select Print from the File menu to print the label.
- 2. **Fold the printed label at the solid line below.** Place the label in a UPS Shipping Pouch. If you do not have a pouch, affix the folded label using clear plastic shipping tape over the entire label.

#### 3. GETTING YOUR SHIPMENT TO UPS

#### **Customers with a Daily Pickup**

Your driver will pickup your shipment(s) as usual.

#### **Customers without a Daily Pickup**

Take your package to any location of The UPS Store®, UPS Access Point(TM) location, UPS Drop Box, UPS Customer Center, Staples® or Authorized Shipping Outlet near you. Items sent via UPS Return Services(SM) (including via Ground) are also accepted at Drop Boxes. To find the location nearest you, please visit the Resources area of CampusShip and select UPS Locations.

Schedule a same day or future day Pickup to have a UPS driver pickup all your CampusShip packages. Hand the package to any UPS driver in your area.

UPS Access Point™ CAOAK-LOCKR-UPS CC 8400 PARDEE DR OAKLAND ,CA 94621 UPS Access Point™ ABE'S LOTTO 10125 INTERNATIONAL BLVD OAKLAND ,CA 94603 UPS Access Point™ THE UPS STORE 1271 WASHINGTON AVE SAN LEANDRO ,CA 94577

#### **FOLD HERE**



## Proof of Delivery

Dear Customer,

This notice serves as proof of delivery for the shipment listed below.

#### **Tracking Number**

1Z56E1A01301035610

#### Weight

0.40 LBS

#### **Service**

UPS Next Day Air Saver®

#### Shipped / Billed On

11/04/2019

#### **Delivered On**

11/05/2019 2:40 P.M.

#### **Delivered To**

SAN FRANCISCO, CA, US

#### **Received By**

**JASON** 

#### **Left At**

Mail Room

Thank you for giving us this opportunity to serve you. Details are only available for shipments delivered within the last 120 days. Please print for your records if you require this information after 120 days.

Sincerely,

**UPS** 

Tracking results provided by UPS: 11/05/2019 6:17 P.M. EST

#### **HEARING BOARD RESPONSE**

Hearing Board Member: Dr. Peter Y. Chiu

**DOCKET NO.** 3718 (Waste Management (Redwood Landfill) Emergency Variance)

**Contacted on:** Date: 11/5/2019 Time: 11:32 a.m.

**Decision Rendered:** Date: 11/5/2019 Time: 2:45 pm

**GRANT** (X) Emergency Variance until: 11/27/2019

**DENY** ( ) Emergency Variance



Reason for Hearing Board action (and conditions, if any):

The Hearing Board accepts the following reasons as presented in the response from the Air District staff:

On October 26, 2019, Pacific Gas & Electric (PG&E) executed a Public Safety Power Shutoff (PSPS) event due to extreme wind conditions and increased wildfire risks in PG&E service areas. The PSPS event impacted over 1.3 million Bay Area residents and lasted up to several days in some regions of the Bay Area. Governor Newsom issued a Proclamation of a Stale of Emergency directing collective support from public agencies, stakeholders and organizations to assist and minimize impacts, utilizing maximum discretion to provide relief.

The magnitude and scale of those impacted by the PSPS event was unforeseeable and resultant power outage at the Redwood Landfill was unpreventable. Air District Regulation 8-34-301.1 and associated permit condition #19867.17 requires the landfill to operate gas collection and emissions control systems continuously, however, due to the PSPS event, the facility experienced a power outage, and the collection system and flare shutdown for approximately 52 hours. Due to the extreme wildfire threat, additional PSPS events cannot be ruled out during the proposed variance period. This Emergency Variance shall only apply to PSPS specific events.

The Emergency Variance is granted with the following conditions as recommended by Air District staff:

- 1) Notify Air District Compliance & Enforcement Division via email at Compliance@baaqmd.gov of the following:
- a. Immediate notification to Air District that a PG&E PSPS would impact facility operations;
- b. Within 24 hours of PG&E power restoration, provide notification to the Air District of the total electrical service downtime, including the date and time power was restored at the facility.
- 2) Explore and evaluate options to ensure continuous operation of landfill gas collection and emissions control system during PSPS events. At the conclusion of the variance period, provide a summary of the options to prevent operational downtime and provide an estimated timeline to install backup power and/or other feasible option(s) evaluated.

Applicant advised of decision: Date: 11/5/19 Time: 4:15 p.m.

Person receiving information: Michael Chan & Alisha McCutcheon

cc: Enforcement APCO

Revised 07/15/2015



# BEFORE THE HEARING BOARD OF THE BAY AREA AIR OLLALITY MANAGEMENT D

#### BAY AREA AIR QUALITY MANAGEMENT DISTRICT STATE OF CALIFORNIA

In the Matter of the Application of

Docket No.: 3718

7 WASTE MANAGEMENT –

ORDER GRANTING EMERGENCY VARIANCE

REDWOOD LANDFILL, INCORPORATED

For Emergency Variance from Regulation 8, Rule 34, Section 301.1; and Permit Condition #19867, Item 17.

12

1.3

14

15

11

1

2

3

4

5

6

9

10

The above-entitled matter, being an Application for Emergency Variance (EV) from the provisions of Regulation 8, Rule 34, Section 301.1; and Permit Condition #19867, Item 17 was filed on October 29, 2019, after initial contact by telephone at 4:47 p.m. on October 28, 2019, and having been considered by the Hearing Board,

16 17

18

19

THE HEARING BOARD STATES as the reasons for its decision and FINDS as to those matters in which findings are required:

20

21

22

23

24

25

A. Applicant filed an application under the EV procedures, Hearing Board Rules, Section 2.5. Pursuant to Health and Safety Code Sections 42359 and 42359.5, and the Hearing Board determined that this Application properly could be ruled upon without notice and hearing. Prior to making this determination, and in accordance with Hearing Board Rules Section 2.5.d.2, the Hearing Board requested and received a response to this Application from the Executive Officer/Air Pollution Control Officer for the Bay Area Air Quality Management District (Air District). The Air District staff response recommended the Application for EV be

2627

granted.

28

- B. Applicant operates a landfill gas collection and control system (GCCS) (Source #S-5), located at 8950 Redwood Highway, Novato, CA 94948.
- C. On October 26, 2019, PG&E executed a Public Safety Power Shutoff (PSPS) due to extreme wind conditions and increased wildfire risks. This PSPS event lasted up to several days in some regions of the San Francisco Bay Area. As a result of this PSPS event, the applicant's facility experienced a power outage, and consequently the gas collection and flare shut down for approximately fifty-two (52) hours.
- D. Applicant requested an emergency variance period of October 28, 2019 to November 27, 2019, (30 days).
  - E. Compliance is beyond Applicant's reasonable control.
- F. Due to the extreme wildfire threat, additional PSPS events cannot be ruled out during the Emergency Variance period.
  - G. The Applicant does meet the good cause standard for issuance of an EV. THEREFORE, THE HEARING BOARD ORDERS:

An Emergency Variance from Regulation 8, Rule 34, Section 301.1; and Permit Condition #19867, Item 17, is hereby granted from October 28, 2019, at 4:47 pm, to November 27, 2019 with the following conditions:

A. Notify Air District Compliance & Enforcement Division via email at

Compliance@baaqmd.gov of the following: 1) Immediate notification to Air

District that a PG&E Public Safety Power Shutoff (PSPS) would impact facility
operations; and 2) Within 24 hours of PG&E power restoration, provide

notification to the Air District of the total electrical service downtime, including
the date and time power was restored at the facility; (Air District Staff

Condition 1)

### BEFORE THE HEARING BOARD OF THE

#### BAY AREA AIR OUALITY MANAGEMENT DISTRICT STATE OF CALIFORNIA

**FILED** 

In the Matter of the Application of	)	NOV 1 2 2019
WASTE MANAGEMENT – REDWOOD LANDFILL, INCORPORATED	<ul><li>) No. 3718</li><li>) CERTIFICATION OF SERVIC</li></ul>	HEARING BOARD BAY AREA AIR QUALITY MANAGEMENT DISTRICT
For Emergency Variance from Regulation 8, Rule 34, Section 301.1; and Permit Condition #19867, Item 17.	) ) )	
STATE OF CALIFORNIA ) ss. City and County of San Francisco )		

I, Marcy Hiratzka, do hereby certify under penalty of perjury as follows:

That I am a citizen of the United States, over the age of eighteen years and not a party to the above entitled action; and that I served a true and correct copy of the attached Order Granting Emergency Variance on:

> Michael Chan, Environmental Protection Air Quality Specialist Waste Management Redwood Landfill, Incorporated 172 98th Avenue Oakland, CA 94603

by depositing same in the United States certified mail, return receipt requested, and via email, on November 12, 2019 on

> **Brian Bunger, District Counsel** Bay Area Air Quality Management District 375 Beale Street, Suite 600 San Francisco, California 94105

via email and by hand-delivery deposit of same in the in-box of the District Counsel's office, on November 12, 2019

Marcy Hiratzka, Clerk of the Boards



**REDWOOD LANDFILL, INC.** 

8950 Redwood Highway P.O. Box 793 Novato, CA 94948 (415) 892-2851 (855) 242-0798 Fax

November 22, 2019 (via compliance@baaqmd.gov and rca@baaqmd.gov)

BAAQMD Compliance and Enforcement Division Bay Area Air Quality Management District 375 Beale Street, Suite 600 San Francisco, California 94105 Attn: RCA 30-DAY REPORTS

Re: Facility A1179, Redwood Landfill, Inc., Novato, California

30-Day Written Report for PG&E Public Safety Power Shutoff (PSPS) Breakdown

Episode (RCA #07P68)

Dear Sir or Madam:

Redwood Landfill, Inc. (RLI) submits this 30-day written report to the Bay Area Air Quality Management District (BAAQMD) for RLI Source S-5, pursuant to BAAQMD regulation 1-432. A breakdown report was submitted during the weekend on 10/26/2019 at ~7:53 pm via the afterhours phone line (BAAQMD issued RCA #07P68) and updated with event clear date on October 28, 2019 when RLI was able to secure a rental generator, connect it to the GCCS, and bring the GCCS back online (see attachments). The Breakdown report describes a potential noncompliance with BAAQMD regulation 8-34-301.1 due to the approximate 52 hour shutdown of the RLI gas collection and control system (GCCS) from 10/26/2019 5:18 PM through 10/28/2019 9:46 PM caused by a PG&E forced public safety outage designated as a Public Safety Power Shutoff (PSPS). On November 5, 2019, for the period of October 28, 2019 at 4:47 PM to November 27, 2019, an emergency variance from BAAQMD regulation 8-34-301.1 and associated permit condition #19867, Item 17 was granted by BAAQMD for the PSPS shutdown and any additional PSPS events with notification conditions.

#### Excess emissions:

During the PG&E public safety forced power outage event, the GCCS was potentially out of compliance with the BAAQMD regulation 8-34-301.1 that required continuous operation of GCCS, however, it was not anticipated that RLI violated applicable emission standard(s).

RLI requested that a Breakdown Relief should be granted as RLI complied with administrative requirements despite its objections to the re-interpretation of Rule 8-34 and:

- 1. The breakdown was not the result of intent, negligence or disregard of air pollution control regulations;
- 2. The breakdown was not the result of improper maintenance;

- 3. The breakdown did not create a public nuisance;
- 4. The breakdown was not caused by an excessively recurrent breakdown of the same equipment; and
- 5. The breakdown did not occur, and any emissions did not interfere with attainment or maintenance of any National or California air quality standard.

Chronology of corrective action steps taken to minimize potential excess emissions by restoring power and bringing the system back online and to insure a PSPS breakdown will be minimized in the future:

- Prior to and during the PSPS event, RLI actively sought a rental generator or the potential to relocate a generator from outside the PSPS/fire zone and finally received and put to use a rental generator two days prior to the end of the PSPS event; the rental generator remains onsite. RLI also arranged for an electrician to construct the necessary connections between a generator and the GCCS.
- RLI has been and continues to actively seek a permanent permitted generator
- 10/26/2019: RLI site experiences PSPS on 10/26/2019 5:18 PM
- 10/26/2019: A breakdown report was submitted during the weekend on 10/26/2019 at ~7:53 pm via the afterhours phone line
- 10/28/2019: RLI filed for an Emergency Variance on October 28, 2019, due to the potential length of the 10/26/2019 PSPS event and the uncertainty of future PSPS events
- 10/28/2019: RLI brought the GCCS back online via generator power on 10/28/2019 at 9:46 pm.
- 10/29/2019: BAAQMD issued Reportable Compliance Activity (RCA) #07P68
- 10/30/2019: RLI brought the GCCS back online via PG&E power on 10/30/2019 at 8:30 am.
- 11/4/2019: RLI submitted 10-day Title V written report to the BAAQMD on 11/4/2019
- 11/5/2019: BAAQMD granted Emergency Variance (Docket #3718) on 11/5/2019 (see attachment)
- 11/12/2019: BAAQMD Order Granting Emergency Variance (Docket #3718) to RLI on 11/12/2019 (see attachment)

RLI is committed to operating its landfill in compliance with all applicable regulations and respectfully requests concurrence that breakdown relief is granted, the variance is in effect and/or that no further action applies.

If you have any questions regarding this notification, please contact me at (415) 892-2851 or Alisha McCutcheon, Redwood Landfill Technical Manager, at (415) 373-8033.

Thank you,

Redwood Landfill, Inc.

Ramin S. Khang

Ramin Khany District Manager

Attachment: A - RLI RCA Form - RCA Number 07P68 for Breakdown Relief

B - BAAQMD Granting Emergency Variance – Docket #3718, 11/5/19

C - BAAQMD Order Granting Emergency Variance – Docket #3718, 11/12/19

## Attachment A RLI RCA Form - RCA Number 07P68 for Breakdown Relief



**REDWOOD LANDFILL, INC.** 

8950 Redwood Highway P.O. Box 793 Novato, CA 94948 (415) 892-2851 (855) 242-0798 Fax

Via email: rca@baaqmd.gov

October 29, 2019 (update of 10/28/19 letter)

Compliance & Enforcement Division Bay Area Air Quality Management District 375 Beale Street, Suite 600 San Francisco, California 94105

Re: Update: Reportable Compliance Activity (RCA) Notification (RCA #07P68)

Facility A1179

Redwood Landfill, Inc., Novato, California

On behalf of Redwood Landfill, Inc. (RLI), although RLI disagrees that Breakdown Relief is the appropriate methodology for compliance with Rule 8-34 during an unplanned power outage, due to direction from Bay Area Air Quality Management District (BAAQMD) staff, this letter is to request Breakdown Relief from BAAQMD for the forced power outage due to PG&E's Public Safety Power Shutoff (PSPS). A breakdown report was submitted during the weekend on October 26, 2019 at ~7:53 pm via the after hours phone line by RLI because the GCCS was no longer operating due to PG&E's forced PSPS. BAAQMD's Reportable Compliance Activity (RCA) notification form, as modified, is enclosed. It is not anticipated at this time that RLI violated applicable emission standard(s).

Breakdown Relief should be granted as RLI complied with administrative requirements despite its objections to the re-interpretation of Rule 8-34 and:

- 1. The breakdown is not the result of intent, negligence or disregard of air pollution control regulations;
- 2. The breakdown is not the result of improper maintenance;
- 3. The breakdown does not create a public nuisance;
- 4. The breakdown was not caused by an excessively recurrent breakdown of the same equipment; and
- 5. The breakdown did not occur and any emissions did not interfere with attainment or maintenance of any National or California air quality standard.

RLI had been actively seeking a permitted generator to power the flare during the PSPS. On October 28, 2019, RLI secured a generator and arranged for an electrician to make the necessary

connections to power the GCCS. The RLI GCCS came back online via generator power on October 28, 2019 at 9:46 pm. RLI filed for an Emergency Variance due to the potential length of the PSPS.

If you have any questions regarding this notification, please contact me at (510) 613-2852 or Alisha McCutcheon, Redwood Landfill Technical Manager, at (415) 373-8033.

Thank you,

Redwood Landfill, Inc.

Michael Chan

**Environmental Protection Specialist** 

Autal Chan

# BAY AREA AIR QUALITY MANAGEMENT DISTRICT

Received by

## **COMPLIANCE & ENFORCEMENT DIVISION**

### **Notification Form**

Reportable Compliance Activity (RCA)

Time

			5	See back of form t	for instructions →
1. X BREAKDOWN RELIEF: District Use Only BREAKDOWN REFERENCE #:					
2. MONITOR EXCESS EMISSION or EXCURSION: District Use Only REFERENCE #:					
3. MONITOR IS INOPERATIVE: District Use Only REFERENCE #:					
4. PRESSURE RELIEF DEVICE (PRD): District Use Only PRD REFERENCE #:					
SITE INF	ORMATIC	ON AND DESCRIPT	ION INFOR	MATION (REQUIR	RED)
Company	Redwo	od Landfill	(RLI)	Site #	A1179
Address		Redwood Hwy,	Novato	Source #	S5
Reported by	C. Col	line/Michael C	han	Phone #	510-613-2852
Indicated Excess				Fax #	
Allowable Limit				Averaging Time	
Start Time/Date	10/26	/2019 5:18 I	PM	Clear Time	10/28/19 9:46 PM
Monitor/device type(s)	▶ CE	EM ►GLM	▶ Parame	etric ►PRD	► Non-monitor
Monitor description(s)					
Parameter(s) exceeded					
►NO <sub>x</sub> ►SO		►CO ►CO	_	·H <sub>2</sub> S	ŭ l
►O <sub>2</sub> ►H <sub>2</sub> C		► Opacity ► Le		Gauge Pressure	►Flow
► Hydrocarbon Breakthrough (VOC)					
▶ Wind Direction       ▶ Steam       X       ▶ Other (describe)       Power Outage					
Unit(s) of Measurement					
▶ppm ▶ppb		►min/hr > 20%		► inches H <sub>2</sub> O	►mmHg
<b>▶</b> psig <b>▶</b> pH		▶ <sup>0</sup> Fahrenheit		Other (describe)	
Event Description: A breakdown report was submitted on 10/26/2019 at ~7:53 pm via the after					
nours phone line by RLI because the GCCS cannot continuously operate due to					
PG&E's forced Public Safety Power Shutoff (PSPS). During the PG&E's forced					
PSPS power outage, the GCCS was potentially out of compliance with BAAQMD					
regulation 8-34-301.1. Please also see our objections and discussion in the					
attached cover letter dated 10/28/2019. Update(10/29/2019)(RCA #07P68):					
Generator connected and GCCS back online 10/28/2019 ~9:46 pm.					

District Use Only

Date

# Attachment B BAAQMD Granting Emergency Variance – Docket #3718, 11/5/19

## **HEARING BOARD RESPONSE**

Hearing Board Member: Dr. Peter Y. Chiu

**DOCKET NO.** 3718 (Waste Management (Redwood Landfill) Emergency Variance)

**Contacted on:** Date: 11/5/2019 Time: 11:32 a.m.

**Decision Rendered:** Date: 11/5/2019 Time: 2:45 pm

**GRANT** (X) Emergency Variance until: 11/27/2019

**DENY** ( ) Emergency Variance



Reason for Hearing Board action (and conditions, if any):

The Hearing Board accepts the following reasons as presented in the response from the Air District staff:

On October 26, 2019, Pacific Gas & Electric (PG&E) executed a Public Safety Power Shutoff (PSPS) event due to extreme wind conditions and increased wildfire risks in PG&E service areas. The PSPS event impacted over 1.3 million Bay Area residents and lasted up to several days in some regions of the Bay Area. Governor Newsom issued a Proclamation of a Stale of Emergency directing collective support from public agencies, stakeholders and organizations to assist and minimize impacts, utilizing maximum discretion to provide relief.

The magnitude and scale of those impacted by the PSPS event was unforeseeable and resultant power outage at the Redwood Landfill was unpreventable. Air District Regulation 8-34-301.1 and associated permit condition #19867.17 requires the landfill to operate gas collection and emissions control systems continuously, however, due to the PSPS event, the facility experienced a power outage, and the collection system and flare shutdown for approximately 52 hours. Due to the extreme wildfire threat, additional PSPS events cannot be ruled out during the proposed variance period. This Emergency Variance shall only apply to PSPS specific events.

The Emergency Variance is granted with the following conditions as recommended by Air District staff:

- 1) Notify Air District Compliance & Enforcement Division via email at Compliance@baaqmd.gov of the following:
- a. Immediate notification to Air District that a PG&E PSPS would impact facility operations;
- b. Within 24 hours of PG&E power restoration, provide notification to the Air District of the total electrical service downtime, including the date and time power was restored at the facility.
- 2) Explore and evaluate options to ensure continuous operation of landfill gas collection and emissions control system during PSPS events. At the conclusion of the variance period, provide a summary of the options to prevent operational downtime and provide an estimated timeline to install backup power and/or other feasible option(s) evaluated.

Applicant advised of decision: Date: 11/5/19 Time: 4:15 p.m.

Person receiving information: Michael Chan & Alisha McCutcheon

cc: Enforcement APCO

# Attachment C BAAQMD Order Granting Emergency Variance – Docket #3718, 11/12/19



# BEFORE THE HEARING BOARD OF THE BAY AREA AIR OLLALITY MANAGEMENT D

### BAY AREA AIR QUALITY MANAGEMENT DISTRICT STATE OF CALIFORNIA

In the Matter of the Application of

Docket No.: 3718

8 WASTE MANAGEMENT-

ORDER GRANTING EMERGENCY VARIANCE

REDWOOD LANDFILL, INCORPORATED

For Emergency Variance from Regulation 8,

Rule 34, Section 301.1; and Permit Condition #19867, Item 17.

1.3

The above-entitled matter, being an Application for Emergency Variance (EV) from the provisions of Regulation 8, Rule 34, Section 301.1; and Permit Condition #19867, Item 17 was filed on October 29, 2019, after initial contact by telephone at 4:47 p.m. on October 28, 2019, and having been considered by the Hearing Board,

THE HEARING BOARD STATES as the reasons for its decision and FINDS as to those matters in which findings are required:

A. Applicant filed an application under the EV procedures, Hearing Board Rules, Section 2.5. Pursuant to Health and Safety Code Sections 42359 and 42359.5, and the Hearing Board determined that this Application properly could be ruled upon without notice and hearing. Prior to making this determination, and in accordance with Hearing Board Rules Section 2.5.d.2, the Hearing Board requested and received a response to this Application from the Executive Officer/Air Pollution Control Officer for the Bay Area Air Quality Management District (Air District). The Air District staff response recommended the Application for EV be granted.

- B. Applicant operates a landfill gas collection and control system (GCCS) (Source #S-5), located at 8950 Redwood Highway, Novato, CA 94948.
- C. On October 26, 2019, PG&E executed a Public Safety Power Shutoff (PSPS) due to extreme wind conditions and increased wildfire risks. This PSPS event lasted up to several days in some regions of the San Francisco Bay Area. As a result of this PSPS event, the applicant's facility experienced a power outage, and consequently the gas collection and flare shut down for approximately fifty-two (52) hours.
- D. Applicant requested an emergency variance period of October 28, 2019 to November 27, 2019, (30 days).
  - E. Compliance is beyond Applicant's reasonable control.
- F. Due to the extreme wildfire threat, additional PSPS events cannot be ruled out during the Emergency Variance period.
  - G. The Applicant does meet the good cause standard for issuance of an EV. THEREFORE, THE HEARING BOARD ORDERS:

An Emergency Variance from Regulation 8, Rule 34, Section 301.1; and Permit Condition #19867, Item 17, is hereby granted from October 28, 2019, at 4:47 pm, to November 27, 2019 with the following conditions:

A. Notify Air District Compliance & Enforcement Division via email at

Compliance@baaqmd.gov of the following: 1) Immediate notification to Air

District that a PG&E Public Safety Power Shutoff (PSPS) would impact facility
operations; and 2) Within 24 hours of PG&E power restoration, provide

notification to the Air District of the total electrical service downtime, including
the date and time power was restored at the facility; (Air District Staff

Condition 1)

## BEFORE THE HEARING BOARD OF THE

### BAY AREA AIR OUALITY MANAGEMENT DISTRICT STATE OF CALIFORNIA

**FILED** 

In the Matter of the Application of	)	NOV 1 2 2019
WASTE MANAGEMENT – REDWOOD LANDFILL, INCORPORATED	No. 3718  CERTIFICATION OF SERVICE	HEARING BOARD BAY AREA AIR QUALITY MANAGEMENT DISTRICT
For Emergency Variance from Regulation 8, Rule 34, Section 301.1; and Permit Condition #19867, Item 17.	) ) )	
STATE OF CALIFORNIA ) ss. City and County of San Francisco )		

I, Marcy Hiratzka, do hereby certify under penalty of perjury as follows:

That I am a citizen of the United States, over the age of eighteen years and not a party to the above entitled action; and that I served a true and correct copy of the attached Order Granting Emergency Variance on:

> Michael Chan, Environmental Protection Air Quality Specialist Waste Management Redwood Landfill, Incorporated 172 98th Avenue Oakland, CA 94603

by depositing same in the United States certified mail, return receipt requested, and via email, on November 12, 2019 on

> **Brian Bunger, District Counsel** Bay Area Air Quality Management District 375 Beale Street, Suite 600 San Francisco, California 94105

via email and by hand-delivery deposit of same in the in-box of the District Counsel's office, on November 12, 2019

Marcy Hiratzka, Clerk of the Boards

#### UPS CampusShip: View/Print Label

- 1. **Ensure there are no other shipping or tracking labels attached to your package.** Select the Print button on the print dialog box that appears. Note: If your browser does not support this function select Print from the File menu to print the label.
- 2. **Fold the printed label at the solid line below.** Place the label in a UPS Shipping Pouch. If you do not have a pouch, affix the folded label using clear plastic shipping tape over the entire label.

#### 3. GETTING YOUR SHIPMENT TO UPS

#### **Customers with a Daily Pickup**

Your driver will pickup your shipment(s) as usual.


#### **Customers without a Daily Pickup**

Take your package to any location of The UPS Store®, UPS Access Point(TM) location, UPS Drop Box, UPS Customer Center, Staples® or Authorized Shipping Outlet near you. Items sent via UPS Return Services(SM) (including via Ground) are also accepted at Drop Boxes. To find the location nearest you, please visit the Resources area of CampusShip and select UPS Locations.

Schedule a same day or future day Pickup to have a UPS driver pickup all your CampusShip packages. Hand the package to any UPS driver in your area.

UPS Access Point™ CAOAK-LOCKR-UPS CC 8400 PARDEE DR OAKLAND ,CA 94621 UPS Access Point™ ABE'S LOTTO 10125 INTERNATIONAL BLVD OAKLAND ,CA 94603 UPS Access Point™ THE UPS STORE 1271 WASHINGTON AVE SAN LEANDRO ,CA 94577

#### **FOLD HERE**



# Proof of Delivery

Dear Customer,

This notice serves as proof of delivery for the shipment listed below.

### **Tracking Number**

1Z56E1A01319539678

#### Weight

0.50 LBS

#### **Service**

UPS Next Day Air Saver®

#### Shipped / Billed On

11/22/2019

#### **Delivered On**

11/25/2019 1:39 P.M.

#### **Delivered To**

SAN FRANCISCO, CA, US

#### **Received By**

**JASON** 

#### **Left At**

Mail Room

Thank you for giving us this opportunity to serve you. Details are only available for shipments delivered within the last 120 days. Please print for your records if you require this information after 120 days.

Sincerely,

**UPS** 

Tracking results provided by UPS: 11/25/2019 5:13 P.M. EST



**REDWOOD LANDFILL, INC.** 

8950 Redwood Highway P.O. Box 793 Novato, CA 94948 (415) 892-2851 (855) 242-0798 Fax

November 22, 2019 (via compliance@baaqmd.gov)

Director of Compliance and Enforcement Bay Area Air Quality Management District 375 Beale Street, Suite 600 San Francisco, California 94105 Attn: Title V Reports

Re: Facility A1179, Redwood Landfill, Inc., Novato, California

Title V 30-Day Written Report for PG&E Public Safety Power Shutoff (PSPS)

Breakdown Episode (RCA #07P68)

Dear Sir or Madam:

Redwood Landfill, Inc. (RLI) is submits this 30-day written report to the Bay Area Air Quality Management District (BAAQMD) as required under Title V Permit Condition Section I.F for Monitoring Reports. The 10-day written report was submitted on November 4, 2019, to BAAQMD as required under Title V Permit Condition Section I.F for Monitoring Reports.

The RLI Title V Permit Requirement states that "Within 30 calendar days of the discovery of any incident of non-compliance, the facility shall submit a written report including the probable cause of non-compliance and any corrective or preventative actions.".

A breakdown report was submitted during the weekend on 10/26/2019 at ~7:53 pm via the afterhours phone line (BAAQMD issued RCA #07P68) and updated with event clear date on October 28, 2019 when RLI was able to secure a rental generator, connect it to the GCCS, and bring the GCCS back online (see attachments). The Breakdown report describes a potential noncompliance with BAAQMD regulation 8-34-301.1 due to the approximate 52 hour shutdown of the RLI gas collection and control system (GCCS) from 10/26/2019 5:18 PM through 10/28/2019 9:46 PM caused by a PG&E forced public safety outage designated as a Public Safety Power Shutoff (PSPS). On November 5, 2019, for the period of October 28, 2019 at 4:47 PM to November 27, 2019, an emergency variance from BAAQMD regulation 8-34-301.1 and associated permit condition #19867, Item 17 was granted by BAAQMD for the PSPS shutdown and any additional PSPS events with notification conditions.

#### Excess emissions:

During the PG&E public safety forced power outage event, the GCCS was potentially out of compliance with the BAAQMD regulation 8-34-301.1 that required continuous operation of GCCS, however, it was not anticipated that RLI violated applicable emission standard(s).

RLI requested that a Breakdown Relief should be granted as RLI complied with administrative requirements despite its objections to the re-interpretation of Rule 8-34 and:

- 1. The breakdown was not the result of intent, negligence or disregard of air pollution control regulations;
- 2. The breakdown was not the result of improper maintenance;
- 3. The breakdown did not create a public nuisance;
- 4. The breakdown was not caused by an excessively recurrent breakdown of the same equipment; and
- 5. The breakdown did not occur, and any emissions did not interfere with attainment or maintenance of any National or California air quality standard.

#### Corrective actions:

The corrective actions included sourcing, obtaining, and connecting a rental generator to the GCCS. RLI received, connected, and operated the rental generator at the site on October 28, 2019.

Chronology of corrective action steps taken to minimize potential excess emissions by restoring power and bringing the system back online and to insure a PSPS breakdown will be minimized in the future:

- Prior to and during the PSPS event, RLI actively sought a rental generator or the potential to relocate a generator from outside the PSPS/fire zone and finally received and put to use a rental generator two days prior to the end of the PSPS event; the rental generator remains onsite. RLI also arranged for an electrician to construct the necessary connections between a generator and the GCCS in anticipation of receiving a generator.
- RLI has been and continues to actively seek a permanent permitted generator
- 10/26/2019: RLI site experiences PSPS on 10/26/2019 5:18 PM
- 10/26/2019: A breakdown report was submitted during the weekend on 10/26/2019 at  $\sim 7:53$  pm via the afterhours phone line
- 10/28/2019: RLI filed for an Emergency Variance on October 28, 2019, due to the potential length of the 10/26/2019 PSPS event and the uncertainty of future PSPS events
- 10/28/2019: RLI brought the GCCS came back online via generator power on 10/28/2019 at 9:46 pm.
- 10/29/2019: BAAQMD issued Reportable Compliance Activity (RCA) #07P68
- 10/30/2019: RLI brought the GCCS back online via PG&E power on 10/30/2019 at 8:30 am.
- 11/4/2019: RLI submitted 10-day Title V written report to the BAAQMD on 11/4/2019
- 11/5/2019: BAAQMD granted Emergency Variance (Docket #3718) on 11/5/2019 (see attachment)

• 11/12/2019: BAAQMD Order Granting Emergency Variance (Docket #3718) to RLI on 11/12/2019 (see attachment)

RLI is committed to operating its landfill in compliance with all applicable regulations and respectfully requests concurrence that breakdown relief is granted, the variance is in effect and/or that no further action applies.

If you have any questions regarding this notification, please contact me at (415) 892-2851 or Alisha McCutcheon, Redwood Landfill Technical Manager, at (415) 373-8033.

Thank you,

Redwood Landfill, Inc.

Ramin S. 16 hamy

Ramin Khany District Manager

Attachment: A - RLI RCA Form - RCA Number 07P68 for Breakdown Relief

B - BAAQMD Granting Emergency Variance – Docket #3718, 11/5/19

C - BAAQMD Order Granting Emergency Variance – Docket #3718, 11/12/19

# Attachment A RLI RCA Form - RCA Number 07P68 for Breakdown Relief



**REDWOOD LANDFILL, INC.** 

8950 Redwood Highway P.O. Box 793 Novato, CA 94948 (415) 892-2851 (855) 242-0798 Fax

Via email: rca@baaqmd.gov

October 29, 2019 (update of 10/28/19 letter)

Compliance & Enforcement Division Bay Area Air Quality Management District 375 Beale Street, Suite 600 San Francisco, California 94105

Re: Update: Reportable Compliance Activity (RCA) Notification (RCA #07P68)

Facility A1179

Redwood Landfill, Inc., Novato, California

On behalf of Redwood Landfill, Inc. (RLI), although RLI disagrees that Breakdown Relief is the appropriate methodology for compliance with Rule 8-34 during an unplanned power outage, due to direction from Bay Area Air Quality Management District (BAAQMD) staff, this letter is to request Breakdown Relief from BAAQMD for the forced power outage due to PG&E's Public Safety Power Shutoff (PSPS). A breakdown report was submitted during the weekend on October 26, 2019 at ~7:53 pm via the after hours phone line by RLI because the GCCS was no longer operating due to PG&E's forced PSPS. BAAQMD's Reportable Compliance Activity (RCA) notification form, as modified, is enclosed. It is not anticipated at this time that RLI violated applicable emission standard(s).

Breakdown Relief should be granted as RLI complied with administrative requirements despite its objections to the re-interpretation of Rule 8-34 and:

- 1. The breakdown is not the result of intent, negligence or disregard of air pollution control regulations;
- 2. The breakdown is not the result of improper maintenance;
- 3. The breakdown does not create a public nuisance;
- 4. The breakdown was not caused by an excessively recurrent breakdown of the same equipment; and
- 5. The breakdown did not occur and any emissions did not interfere with attainment or maintenance of any National or California air quality standard.

RLI had been actively seeking a permitted generator to power the flare during the PSPS. On October 28, 2019, RLI secured a generator and arranged for an electrician to make the necessary

connections to power the GCCS. The RLI GCCS came back online via generator power on October 28, 2019 at 9:46 pm. RLI filed for an Emergency Variance due to the potential length of the PSPS.

If you have any questions regarding this notification, please contact me at (510) 613-2852 or Alisha McCutcheon, Redwood Landfill Technical Manager, at (415) 373-8033.

Thank you,

Redwood Landfill, Inc.

Michael Chan

**Environmental Protection Specialist** 

Autal Chan

# BAY AREA AIR QUALITY MANAGEMENT DISTRICT

Received by

## **COMPLIANCE & ENFORCEMENT DIVISION**

### **Notification Form**

Reportable Compliance Activity (RCA)

Time

	See back of form for instructions →					
1. X BREAKDOWN RELIEF: District Use Only BREAKDOWN REFERENCE #:						
2. MONITOR EXCESS EMISSION or EXCURSION: District Use Only REFERENCE #:						
3. MONITOR IS INOPERATIVE: District Use Only REFERENCE #:						
4. PRESSURE RELIEF DEVICE (PRD): District Use Only PRD REFERENCE #:						
SITE INF	ORMATION AND DESCRIPTION INFO	RMATION (REQUIR	ED)			
Company	Redwood Landfill (RLI)	Site #	A1179			
Address	8950 Redwood Hwy, Novato	Source #	S5			
Reported by	C. Colline/Michael Chan	Phone #	510-613-2852			
Indicated Excess		Fax #				
Allowable Limit		Averaging Time				
Start Time/Date	10/26/2019 5:18 PM	Clear Time	10/28/19 9:46 PM			
Monitor/device type(s)	▶ CEM     ▶ GLM     ▶ Parar	metric ►PRD	► Non-monitor			
Monitor description(s)						
Parameter(s) exceeded or not functioning due to inoperation $ \begin{array}{c ccccccccccccccccccccccccccccccccccc$						
▶ Wind Direction       ▶ Steam       X       ▶ Other (describe)       Power Outage						
Unit(s) of Measurement						
▶ppm ▶ppb		► inches H <sub>2</sub> O	►mmHg			
<b>▶</b> psig <b>▶</b> pH	► <sup>0</sup> Fahrenheit	► Other (describe)				
Event Description: A breakdown report was submitted on 10/26/2019 at ~7:53 pm via the after hours phone line by RLI because the GCCS cannot continuously operate due to PG&E's forced Public Safety Power Shutoff (PSPS). During the PG&E's forced PSPS power outage, the GCCS was potentially out of compliance with BAAQMD regulation 8-34-301.1. Please also see our objections and discussion in the attached cover letter dated 10/28/2019. Update(10/29/2019)(RCA #07P68):						
	and GCCS back online 10/28/20					

District Use Only

Date

# Attachment B BAAQMD Granting Emergency Variance – Docket #3718, 11/5/19

## **HEARING BOARD RESPONSE**

Hearing Board Member: Dr. Peter Y. Chiu

**DOCKET NO.** 3718 (Waste Management (Redwood Landfill) Emergency Variance)

**Contacted on:** Date: 11/5/2019 Time: 11:32 a.m.

**Decision Rendered:** Date: 11/5/2019 Time: 2:45 pm

GRANT (X) Emergency Variance until: 11/27/2019

**DENY** ( ) Emergency Variance



Reason for Hearing Board action (and conditions, if any):

The Hearing Board accepts the following reasons as presented in the response from the Air District staff:

On October 26, 2019, Pacific Gas & Electric (PG&E) executed a Public Safety Power Shutoff (PSPS) event due to extreme wind conditions and increased wildfire risks in PG&E service areas. The PSPS event impacted over 1.3 million Bay Area residents and lasted up to several days in some regions of the Bay Area. Governor Newsom issued a Proclamation of a Stale of Emergency directing collective support from public agencies, stakeholders and organizations to assist and minimize impacts, utilizing maximum discretion to provide relief.

The magnitude and scale of those impacted by the PSPS event was unforeseeable and resultant power outage at the Redwood Landfill was unpreventable. Air District Regulation 8-34-301.1 and associated permit condition #19867.17 requires the landfill to operate gas collection and emissions control systems continuously, however, due to the PSPS event, the facility experienced a power outage, and the collection system and flare shutdown for approximately 52 hours. Due to the extreme wildfire threat, additional PSPS events cannot be ruled out during the proposed variance period. This Emergency Variance shall only apply to PSPS specific events.

The Emergency Variance is granted with the following conditions as recommended by Air District staff:

- 1) Notify Air District Compliance & Enforcement Division via email at Compliance@baaqmd.gov of the following:
- a. Immediate notification to Air District that a PG&E PSPS would impact facility operations;
- b. Within 24 hours of PG&E power restoration, provide notification to the Air District of the total electrical service downtime, including the date and time power was restored at the facility.
- 2) Explore and evaluate options to ensure continuous operation of landfill gas collection and emissions control system during PSPS events. At the conclusion of the variance period, provide a summary of the options to prevent operational downtime and provide an estimated timeline to install backup power and/or other feasible option(s) evaluated.

Applicant advised of decision: Date: 11/5/19 Time: 4:15 p.m.

Person receiving information: Michael Chan & Alisha McCutcheon

cc: Enforcement APCO

# Attachment C BAAQMD Order Granting Emergency Variance – Docket #3718, 11/12/19



# BEFORE THE HEARING BOARD OF THE BAY AREA AIR OLLALITY MANAGEMENT D

### BAY AREA AIR QUALITY MANAGEMENT DISTRICT STATE OF CALIFORNIA

In the Matter of the Application of

Docket No.: 3718

8 WASTE MANAGEMENT-

ORDER GRANTING EMERGENCY VARIANCE

REDWOOD LANDFILL, INCORPORATED

For Emergency Variance from Regulation 8,

Rule 34, Section 301.1; and Permit Condition #19867, Item 17.

1.3

The above-entitled matter, being an Application for Emergency Variance (EV) from the provisions of Regulation 8, Rule 34, Section 301.1; and Permit Condition #19867, Item 17 was filed on October 29, 2019, after initial contact by telephone at 4:47 p.m. on October 28, 2019, and having been considered by the Hearing Board,

THE HEARING BOARD STATES as the reasons for its decision and FINDS as to those matters in which findings are required:

A. Applicant filed an application under the EV procedures, Hearing Board Rules, Section 2.5. Pursuant to Health and Safety Code Sections 42359 and 42359.5, and the Hearing Board determined that this Application properly could be ruled upon without notice and hearing. Prior to making this determination, and in accordance with Hearing Board Rules Section 2.5.d.2, the Hearing Board requested and received a response to this Application from the Executive Officer/Air Pollution Control Officer for the Bay Area Air Quality Management District (Air District). The Air District staff response recommended the Application for EV be granted.

- B. Applicant operates a landfill gas collection and control system (GCCS) (Source #S-5), located at 8950 Redwood Highway, Novato, CA 94948.
- C. On October 26, 2019, PG&E executed a Public Safety Power Shutoff (PSPS) due to extreme wind conditions and increased wildfire risks. This PSPS event lasted up to several days in some regions of the San Francisco Bay Area. As a result of this PSPS event, the applicant's facility experienced a power outage, and consequently the gas collection and flare shut down for approximately fifty-two (52) hours.
- D. Applicant requested an emergency variance period of October 28, 2019 to November 27, 2019, (30 days).
  - E. Compliance is beyond Applicant's reasonable control.
- F. Due to the extreme wildfire threat, additional PSPS events cannot be ruled out during the Emergency Variance period.
  - G. The Applicant does meet the good cause standard for issuance of an EV. THEREFORE, THE HEARING BOARD ORDERS:

An Emergency Variance from Regulation 8, Rule 34, Section 301.1; and Permit Condition #19867, Item 17, is hereby granted from October 28, 2019, at 4:47 pm, to November 27, 2019 with the following conditions:

A. Notify Air District Compliance & Enforcement Division via email at

Compliance@baaqmd.gov of the following: 1) Immediate notification to Air

District that a PG&E Public Safety Power Shutoff (PSPS) would impact facility
operations; and 2) Within 24 hours of PG&E power restoration, provide

notification to the Air District of the total electrical service downtime, including
the date and time power was restored at the facility; (Air District Staff

Condition 1)

# BEFORE THE HEARING BOARD OF THE

### BAY AREA AIR OUALITY MANAGEMENT DISTRICT STATE OF CALIFORNIA

In the Matter of the Application of	)	NOV 1 2 2019
WASTE MANAGEMENT – REDWOOD LANDFILL, INCORPORATED	) No. 3718 ) CERTIFICATION OF SERVIC	HEARING BOARD BAY AREA AIR QUALITY MANAGEMENT DISTRICT
For Emergency Variance from Regulation 8, Rule 34, Section 301.1; and Permit Condition #19867, Item 17.	) ) )	
STATE OF CALIFORNIA ) ss. City and County of San Francisco )		

I, Marcy Hiratzka, do hereby certify under penalty of perjury as follows:

That I am a citizen of the United States, over the age of eighteen years and not a party to the above entitled action; and that I served a true and correct copy of the attached Order Granting Emergency Variance on:

> Michael Chan, Environmental Protection Air Quality Specialist Waste Management Redwood Landfill, Incorporated 172 98th Avenue Oakland, CA 94603

by depositing same in the United States certified mail, return receipt requested, and via email, on November 12, 2019 on

> **Brian Bunger, District Counsel** Bay Area Air Quality Management District 375 Beale Street, Suite 600 San Francisco, California 94105

via email and by hand-delivery deposit of same in the in-box of the District Counsel's office, on November 12, 2019

Marcy Hiratzka, Clerk of the Boards

#### UPS CampusShip: View/Print Label

- 1. **Ensure there are no other shipping or tracking labels attached to your package.** Select the Print button on the print dialog box that appears. Note: If your browser does not support this function select Print from the File menu to print the label.
- 2. **Fold the printed label at the solid line below.** Place the label in a UPS Shipping Pouch. If you do not have a pouch, affix the folded label using clear plastic shipping tape over the entire label.

#### 3. GETTING YOUR SHIPMENT TO UPS

#### **Customers with a Daily Pickup**

Your driver will pickup your shipment(s) as usual.


#### **Customers without a Daily Pickup**

Take your package to any location of The UPS Store®, UPS Access Point(TM) location, UPS Drop Box, UPS Customer Center, Staples® or Authorized Shipping Outlet near you. Items sent via UPS Return Services(SM) (including via Ground) are also accepted at Drop Boxes. To find the location nearest you, please visit the Resources area of CampusShip and select UPS Locations.

Schedule a same day or future day Pickup to have a UPS driver pickup all your CampusShip packages. Hand the package to any UPS driver in your area.

UPS Access Point™ CAOAK-LOCKR-UPS CC 8400 PARDEE DR OAKLAND ,CA 94621 UPS Access Point™ ABE'S LOTTO 10125 INTERNATIONAL BLVD OAKLAND ,CA 94603 UPS Access Point™ THE UPS STORE 1271 WASHINGTON AVE SAN LEANDRO ,CA 94577

#### **FOLD HERE**



# Proof of Delivery

Dear Customer,

This notice serves as proof of delivery for the shipment listed below.

### **Tracking Number**

1Z56E1A01319539678

#### Weight

0.50 LBS

#### **Service**

UPS Next Day Air Saver®

#### Shipped / Billed On

11/22/2019

#### **Delivered On**

11/25/2019 1:39 P.M.

#### **Delivered To**

SAN FRANCISCO, CA, US

#### **Received By**

**JASON** 

#### **Left At**

Mail Room

Thank you for giving us this opportunity to serve you. Details are only available for shipments delivered within the last 120 days. Please print for your records if you require this information after 120 days.

Sincerely,

**UPS** 

Tracking results provided by UPS: 11/25/2019 5:13 P.M. EST



#### **REDWOOD LANDFILL, INC.**

8950 Redwood Highway P.O. Box 793 Novato, CA 94948 (415) 892-2851 (855) 242-0798 Fax

December 20, 2019 (via compliance@baaqmd.gov)

Director of Compliance and Enforcement Bay Area Air Quality Management District 375 Beale Street, Suite 600 San Francisco, California 94105 Attn: Variance Report – Docket No. 3718

Re: Facility A1179, Redwood Landfill, Inc., Novato, California

30-Day Emergency Variance Written Report

Dear Sir or Madam:

Redwood Landfill, Inc. (RLI) submits this 30-day emergency variance report to the Bay Area Air Quality Management District (BAAQMD) pursuant to the emergency variance granted on November 5, 2019 for RLI (Docket No. 3718).

Pursuant to Condition B of the Order Granting Emergency Variance (Docket No. 3718) from BAAQMD Regulation 8, Rule 34, Section 301.1 and associated Permit Condition #19867, Item 17, this letter details the steps taken to explore and evaluate options to minimize landfill gas collection and control system (GCCS) downtime during PSPS events. During the variance period, 10/28/2019 to 11/27/2019, no additional PSPS events affected RLI landfill GCCS. Prior to and during the 10/26/2019 PSPS event, RLI actively sought a rental generator or the potential to relocate a generator from outside the PSPS/fire zone. During the PSPS event that started on 10/26/2019, RLI took all required measures to minimize the landfill gas collection and control system downtime by securing a rental generator, hired an electrician to connect the generator to the flare station, and restored power to the GCCS on 10/28/2019 before PG&E ended the PSPS event on 10/30/2019.

A rental generator currently remains onsite as backup power, after the end of the PSPS event, to address future PSPS events. RLI has been and continues to actively seek quotes, evaluate the options, allocate funds, and procure a permanent permitted generator for RLI.

RLI appreciates the timely response from the Hearing Board granting the 30-day variance, to cover the potential of future PG&E forced Public Safety Power Shutdown (PSPS) events. RLI is committed to operating its landfill in compliance with all applicable regulations.

If you have any questions regarding this notification, please contact me at (415) 892-2851 or Alisha McCutcheon, Redwood Landfill Technical Manager, at (415) 373-8033.

Thank you,

Redwood Landfill, Inc.

Ramin S. 16 hang

Ramin Khany District Manager

Attachment: A - BAAQMD Order Granting Emergency Variance – Docket #3718

# Attachment A BAAQMD Order Granting Emergency Variance – Docket #3718



# BEFORE THE HEARING BOARD OF THE BAY AREA AIR OLLALITY MANAGEMENT D

### BAY AREA AIR QUALITY MANAGEMENT DISTRICT STATE OF CALIFORNIA

In the Matter of the Application of

Docket No.: 3718

8 WASTE MANAGEMENT-

ORDER GRANTING EMERGENCY VARIANCE

REDWOOD LANDFILL, INCORPORATED

For Emergency Variance from Regulation 8,

Rule 34, Section 301.1; and Permit Condition #19867, Item 17.

1.3

The above-entitled matter, being an Application for Emergency Variance (EV) from the provisions of Regulation 8, Rule 34, Section 301.1; and Permit Condition #19867, Item 17 was filed on October 29, 2019, after initial contact by telephone at 4:47 p.m. on October 28, 2019, and having been considered by the Hearing Board,

THE HEARING BOARD STATES as the reasons for its decision and FINDS as to those matters in which findings are required:

A. Applicant filed an application under the EV procedures, Hearing Board Rules, Section 2.5. Pursuant to Health and Safety Code Sections 42359 and 42359.5, and the Hearing Board determined that this Application properly could be ruled upon without notice and hearing. Prior to making this determination, and in accordance with Hearing Board Rules Section 2.5.d.2, the Hearing Board requested and received a response to this Application from the Executive Officer/Air Pollution Control Officer for the Bay Area Air Quality Management District (Air District). The Air District staff response recommended the Application for EV be granted.

- B. Applicant operates a landfill gas collection and control system (GCCS) (Source #S-5), located at 8950 Redwood Highway, Novato, CA 94948.
- C. On October 26, 2019, PG&E executed a Public Safety Power Shutoff (PSPS) due to extreme wind conditions and increased wildfire risks. This PSPS event lasted up to several days in some regions of the San Francisco Bay Area. As a result of this PSPS event, the applicant's facility experienced a power outage, and consequently the gas collection and flare shut down for approximately fifty-two (52) hours.
- D. Applicant requested an emergency variance period of October 28, 2019 to November 27, 2019, (30 days).
  - E. Compliance is beyond Applicant's reasonable control.
- F. Due to the extreme wildfire threat, additional PSPS events cannot be ruled out during the Emergency Variance period.
  - G. The Applicant does meet the good cause standard for issuance of an EV. THEREFORE, THE HEARING BOARD ORDERS:

An Emergency Variance from Regulation 8, Rule 34, Section 301.1; and Permit Condition #19867, Item 17, is hereby granted from October 28, 2019, at 4:47 pm, to November 27, 2019 with the following conditions:

A. Notify Air District Compliance & Enforcement Division via email at

Compliance@baaqmd.gov of the following: 1) Immediate notification to Air

District that a PG&E Public Safety Power Shutoff (PSPS) would impact facility
operations; and 2) Within 24 hours of PG&E power restoration, provide

notification to the Air District of the total electrical service downtime, including
the date and time power was restored at the facility; (Air District Staff

Condition 1)

# BEFORE THE HEARING BOARD OF THE

### BAY AREA AIR OUALITY MANAGEMENT DISTRICT STATE OF CALIFORNIA

In the Matter of the Application of	)	NOV 1 2 2019
WASTE MANAGEMENT – REDWOOD LANDFILL, INCORPORATED	) No. 3718 ) CERTIFICATION OF SERVIC	HEARING BOARD BAY AREA AIR QUALITY MANAGEMENT DISTRICT
For Emergency Variance from Regulation 8, Rule 34, Section 301.1; and Permit Condition #19867, Item 17.	) ) )	
STATE OF CALIFORNIA ) ss. City and County of San Francisco )		

I, Marcy Hiratzka, do hereby certify under penalty of perjury as follows:

That I am a citizen of the United States, over the age of eighteen years and not a party to the above entitled action; and that I served a true and correct copy of the attached Order Granting Emergency Variance on:

> Michael Chan, Environmental Protection Air Quality Specialist Waste Management Redwood Landfill, Incorporated 172 98th Avenue Oakland, CA 94603

by depositing same in the United States certified mail, return receipt requested, and via email, on November 12, 2019 on

> **Brian Bunger, District Counsel** Bay Area Air Quality Management District 375 Beale Street, Suite 600 San Francisco, California 94105

via email and by hand-delivery deposit of same in the in-box of the District Counsel's office, on November 12, 2019

Marcy Hiratzka, Clerk of the Boards

## Chan, Michael

From: Chan, Michael

Sent: Friday, December 20, 2019 2:11 PM

**To:** 'compliance@baaqmd.gov'

**Cc:** 'Richard Murray'; McCutcheon, Alisha

**Subject:** Redwood Emergency Variance 30-Day summary report **Attachments:** Redwood 30day Emergency Variance Ltr 12-20-19.pdf

Attached is a copy of Redwood Landfill's Emergency Variance 30-Day Summary Report for the PG&E PSPS event (hardcopy being sent via UPS).

Mike Chan

Michael Chan EP Air Quality Specialist mchan2@wm.com

Waste Management 172 98th Avenue Oakland, CA 94603 Office 510-613-2852

#### **UPS CampusShip: View/Print Label**

- 1. **Ensure there are no other shipping or tracking labels attached to your package.** Select the Print button on the print dialog box that appears. Note: If your browser does not support this function select Print from the File menu to print the label.
- 2. **Fold the printed label at the solid line below.** Place the label in a UPS Shipping Pouch. If you do not have a pouch, affix the folded label using clear plastic shipping tape over the entire label.

#### 3. GETTING YOUR SHIPMENT TO UPS

#### **Customers with a Daily Pickup**

Your driver will pickup your shipment(s) as usual.


#### **Customers without a Daily Pickup**

Take your package to any location of The UPS Store®, UPS Access Point(TM) location, UPS Drop Box, UPS Customer Center, Staples® or Authorized Shipping Outlet near you. Items sent via UPS Return Services(SM) (including via Ground) are also accepted at Drop Boxes. To find the location nearest you, please visit the Resources area of CampusShip and select UPS Locations.

Schedule a same day or future day Pickup to have a UPS driver pickup all your CampusShip packages. Hand the package to any UPS driver in your area.

UPS Access Point™ CAOAK-LOCKR-UPS CC 8400 PARDEE DR OAKLAND ,CA 94621 UPS Access Point™ ABE'S LOTTO 10125 INTERNATIONAL BLVD OAKLAND ,CA 94603 UPS Access Point™ THE UPS STORE 1271 WASHINGTON AVE SAN LEANDRO ,CA 94577

#### **FOLD HERE**



# Proof of Delivery

Dear Customer,

This notice serves as proof of delivery for the shipment listed below.

### **Tracking Number**

1Z56E1A01315461731

#### Weight

0.50 LBS

#### **Service**

UPS Next Day Air Saver®

#### Shipped / Billed On

12/20/2019

#### **Delivered On**

12/23/2019 12:35 P.M.

#### **Delivered To**

SAN FRANCISCO, CA, US

#### **Received By**

JAY

#### **Left At**

Mail Room

Thank you for giving us this opportunity to serve you. Details are only available for shipments delivered within the last 120 days. Please print for your records if you require this information after 120 days.

Sincerely,

**UPS** 

Tracking results provided by UPS: 12/23/2019 4:25 P.M. EST



**REDWOOD LANDFILL, INC.** 

8950 Redwood Highway P.O. Box 793 Novato, CA 94948 (415) 892-2851 (855) 242-0798 Fax

December 23, 2019

Ms. Simrun Dhoot Senior Air Quality Engineer Bay Area Air Quality Management District 375 Beale Street, Suite 600 San Francisco, California 94105

**Re:** Well Actions Letter

Title V Permit Condition Number 19867, Part 17, Facility A1179 Redwood Landfill, Inc., Novato, California

Dear Ms. Dhoot:

On behalf of Redwood Landfill, Inc. (RLI), this letter is to notify the Bay Area Air Quality Management District (BAAQMD) of the well actions recently performed at the RLI, pursuant to Title V Permit A1179 as modified by Application Number (AN) 30065. The well action is summarized below:

• Vertical well RLLC0218 was decommissioned on 12/23/2019.

AN 30065 allows installation of up to 100 new vertical wells, unlimited one-to-one replacement of vertical wells, installation of up to 50 new horizontal collectors, decommissioning of up to 50 vertical wells, and decommissioning of up to 15 horizontal collectors.

As stated in the September 20, 2019 Well Actions Letter, prior to the completion of this well action, RLI had 119 total collectors (110 vertical wells and 9 horizontal collectors) connected to the GCCS. With the completion of this well action, RLI's existing GCCS component count and permitted remaining actions per AN 30065 are listed in the following table:

	Install New Vertical Wells	Decommission Vertical Wells	Install New Horizontal Collectors	Decommission Horizontal Collectors	Replace Vertical Wells*
Actions Permitted Under AN 30065	100	50	50	15	Unlimited
Actions Performed by RLI per AN 30065	12	4	0	0	-
Actions Remaining Under AN 30065	88	46	50	15	Unlimited
Active Collector Count after Actions in this Letter	118 Total Co	ollectors: 109 Vert	ical LFG Well	s and 9 Horizontal	Collectors

<sup>\*</sup>One-for-one well replacement at new optimal locations.

If you have any questions regarding this notification, please contact me at (510) 613-2852 or Alisha McCutcheon, Redwood Landfill Technical Manager, at (415) 373-8033.

Thank you,

Redwood Landfill, Inc.

**Michael Chan** 

**Environmental Protection Specialist** 

Stubal Char

# **UPS CampusShip: View/Print Label**

- 1. **Ensure there are no other shipping or tracking labels attached to your package.** Select the Print button on the print dialog box that appears. Note: If your browser does not support this function select Print from the File menu to print the label.
- 2. **Fold the printed label at the solid line below.** Place the label in a UPS Shipping Pouch. If you do not have a pouch, affix the folded label using clear plastic shipping tape over the entire label.

# 3. GETTING YOUR SHIPMENT TO UPS

# **Customers with a Daily Pickup**

Your driver will pickup your shipment(s) as usual.


# **Customers without a Daily Pickup**

Take your package to any location of The UPS Store®, UPS Access Point(TM) location, UPS Drop Box, UPS Customer Center, Staples® or Authorized Shipping Outlet near you. Items sent via UPS Return Services(SM) (including via Ground) are also accepted at Drop Boxes. To find the location nearest you, please visit the Resources area of CampusShip and select UPS Locations.

Schedule a same day or future day Pickup to have a UPS driver pickup all your CampusShip packages. Hand the package to any UPS driver in your area.

UPS Access Point™ CAOAK-LOCKR-UPS CC 8400 PARDEE DR OAKLAND ,CA 94621 UPS Access Point™ ABE'S LOTTO 10125 INTERNATIONAL BLVD OAKLAND ,CA 94603 UPS Access Point™ THE UPS STORE 1271 WASHINGTON AVE SAN LEANDRO ,CA 94577

# **FOLD HERE**



# Proof of Delivery

Dear Customer,

This notice serves as proof of delivery for the shipment listed below.

# **Tracking Number**

1Z56E1A01315853755

# Weight

0.50 LBS

# **Service**

UPS Next Day Air Saver®

# Shipped / Billed On

12/23/2019

# **Delivered On**

12/26/2019 12:12 P.M.

# **Delivered To**

SAN FRANCISCO, CA, US

# **Received By**

**CARLOS** 

# **Left At**

Mail Room

Thank you for giving us this opportunity to serve you. Details are only available for shipments delivered within the last 120 days. Please print for your records if you require this information after 120 days.

Sincerely,

**UPS** 

Tracking results provided by UPS: 12/26/2019 8:24 P.M. EST



**REDWOOD LANDFILL, INC.** 

8950 Redwood Highway P.O. Box 793 Novato, CA 94948 (415) 892-2851 (855) 242-0798 Fax

February 18, 2020

Ms. Simrun Dhoot Senior Air Quality Engineer Bay Area Air Quality Management District 375 Beale Street, Suite 600 San Francisco, California 94105

**Re:** Well Actions Letter

Title V Permit Condition Number 19867, Part 17, Facility A1179 Redwood Landfill, Inc., Novato, California

Dear Ms. Dhoot:

On behalf of Redwood Landfill, Inc. (RLI), this letter is to notify the Bay Area Air Quality Management District (BAAQMD) of the well actions recently performed at the RLI, pursuant to Title V Permit A1179 as modified by Application Number (AN) 30065. The well action is summarized below:

• Vertical well RLI0108A was decommissioned on 2/17/2020.

AN 30065 allows installation of up to 100 new vertical wells, unlimited one-to-one replacement of vertical wells, installation of up to 50 new horizontal collectors, decommissioning of up to 50 vertical wells, and decommissioning of up to 15 horizontal collectors.

As stated in the December 23, 2019 Well Actions Letter, prior to the completion of this well action, RLI had 118 total collectors (109 vertical wells and 9 horizontal collectors) connected to the GCCS. With the completion of this well action, RLI's existing GCCS component count and permitted remaining actions per AN 30065 are listed in the following table:

	Install New Vertical Wells	Decommission Vertical Wells	Install New Horizontal Collectors	Decommission Horizontal Collectors	Replace Vertical Wells*
Actions Permitted Under AN 30065	100	50	50	15	Unlimited
Actions Performed by RLI per AN 30065	12	5	0	0	-
Actions Remaining Under AN 30065	88	45	50	15	Unlimited
Active Collector Count after Actions in this Letter	117 Total Co	ollectors: 108 Vert	ical LFG Well	s and 9 Horizontal	Collectors

<sup>\*</sup>One-for-one well replacement at new optimal locations.

If you have any questions regarding this notification, please contact me at (510) 613-2852 or Alisha McCutcheon, Redwood Landfill Technical Manager, at (415) 373-8033.

Thank you,

Redwood Landfill, Inc.

**Michael Chan** 

**Environmental Protection Specialist** 

Stubal Char

# **UPS CampusShip: View/Print Label**

- 1. **Ensure there are no other shipping or tracking labels attached to your package.** Select the Print button on the print dialog box that appears. Note: If your browser does not support this function select Print from the File menu to print the label.
- 2. **Fold the printed label at the solid line below.** Place the label in a UPS Shipping Pouch. If you do not have a pouch, affix the folded label using clear plastic shipping tape over the entire label.

# 3. GETTING YOUR SHIPMENT TO UPS

# **Customers with a Daily Pickup**

Your driver will pickup your shipment(s) as usual.

# **Customers without a Daily Pickup**

Take your package to any location of The UPS Store®, UPS Access Point(TM) location, UPS Drop Box, UPS Customer Center, Staples® or Authorized Shipping Outlet near you. Items sent via UPS Return Services(SM) (including via Ground) are also accepted at Drop Boxes. To find the location nearest you, please visit the Resources area of CampusShip and select UPS Locations.

Schedule a same day or future day Pickup to have a UPS driver pickup all your CampusShip packages. Hand the package to any UPS driver in your area.

UPS Access Point™ CAOAK-LOCKR-UPS CC 8400 PARDEE DR OAKLAND ,CA 94621 UPS Access Point™ ABE'S LOTTO 10125 INTERNATIONAL BLVD OAKLAND ,CA 94603 UPS Access Point™ THE UPS STORE 1271 WASHINGTON AVE SAN LEANDRO ,CA 94577

# **FOLD HERE**



# Proof of Delivery

Dear Customer,

This notice serves as proof of delivery for the shipment listed below.

# **Tracking Number**

1Z56E1A01312742059

# Weight

0.50 LBS

# **Service**

UPS Next Day Air Saver®

# Shipped / Billed On

02/18/2020

# **Delivered On**

02/19/2020 12:45 P.M.

# **Delivered To**

SAN FRANCISCO, CA, US

# **Received By**

**JEFF** 

# **Left At**

Mail Room

Thank you for giving us this opportunity to serve you. Details are only available for shipments delivered within the last 120 days. Please print for your records if you require this information after 120 days.

Sincerely,

**UPS** 

Tracking results provided by UPS: 02/19/2020 4:13 P.M. EST



**REDWOOD LANDFILL, INC.** 

8950 Redwood Highway P.O. Box 793 Novato, CA 94948 (415) 892-2851 (855) 242-0798 Fax

March 24, 2020

Ms. Simrun Dhoot Senior Air Quality Engineer Bay Area Air Quality Management District 375 Beale Street, Suite 600 San Francisco, California 94105

**Re:** Well Actions Letter

Title V Permit Condition Number 19867, Part 17, Facility A1179 Redwood Landfill, Inc., Novato, California

Dear Ms. Dhoot:

On behalf of Redwood Landfill, Inc. (RLI), this letter is to notify the Bay Area Air Quality Management District (BAAQMD) of the well actions recently performed at the RLI, pursuant to Title V Permit A1179 as modified by Application Number (AN) 30065. These well actions are summarized below:

- Vertical well RLI00138 was decommissioned on 3/24/2020.
- Vertical well RLI00139 was decommissioned on 3/24/2020.

AN 30065 allows installation of up to 100 new vertical wells, unlimited one-to-one replacement of vertical wells, installation of up to 50 new horizontal collectors, decommissioning of up to 50 vertical wells, and decommissioning of up to 15 horizontal collectors.

As stated in the February 18, 2020 Well Actions Letter, prior to the completion of these well actions, RLI had 117 total collectors (108 vertical wells and 9 horizontal collectors) connected to the GCCS. With the completion of these well actions, RLI's existing GCCS component count and permitted remaining actions per AN 30065 are listed in the following table:

	Install New Vertical Wells	Decommission Vertical Wells	Install New Horizontal Collectors	Decommission Horizontal Collectors	Replace Vertical Wells*	
Actions Permitted Under AN 30065	100	50	50	15	Unlimited	
Actions Performed by RLI per AN 30065	12	7	0	0	-	
Actions Remaining Under AN 30065	88	43	50	15	Unlimited	
Active Collector Count after Actions in this Letter	115 Total Collectors: 106 Vertical LFG Wells and 9 Horizontal Collect					

<sup>\*</sup>One-for-one well replacement at new optimal locations.

If you have any questions regarding this notification, please contact me at (510) 613-2852 or Alisha McCutcheon, Redwood Landfill Technical Manager, at (415) 373-8033.

Thank you,

Redwood Landfill, Inc.

**Michael Chan** 

**Environmental Protection Specialist** 

Autael Chan

# **UPS CampusShip: View/Print Label**

- 1. **Ensure there are no other shipping or tracking labels attached to your package.** Select the Print button on the print dialog box that appears. Note: If your browser does not support this function select Print from the File menu to print the label.
- 2. **Fold the printed label at the solid line below.** Place the label in a UPS Shipping Pouch. If you do not have a pouch, affix the folded label using clear plastic shipping tape over the entire label.

# 3. GETTING YOUR SHIPMENT TO UPS

# **Customers with a Daily Pickup**

Your driver will pickup your shipment(s) as usual.


# **Customers without a Daily Pickup**

Take your package to any location of The UPS Store®, UPS Access Point(TM) location, UPS Drop Box, UPS Customer Center, Staples® or Authorized Shipping Outlet near you. Items sent via UPS Return Services(SM) (including via Ground) are also accepted at Drop Boxes. To find the location nearest you, please visit the Resources area of CampusShip and select UPS Locations.

Schedule a same day or future day Pickup to have a UPS driver pickup all your CampusShip packages. Hand the package to any UPS driver in your area.

UPS Access Point™ CAOAK-LOCKR-UPS CC 8400 PARDEE DR OAKLAND ,CA 94621 UPS Access Point™ ABE'S LOTTO 10125 INTERNATIONAL BLVD OAKLAND ,CA 94603 UPS Access Point™ THE UPS STORE 1271 WASHINGTON AVE SAN LEANDRO ,CA 94577

# **FOLD HERE**



# Proof of Delivery

Dear Customer,

This notice serves as proof of delivery for the shipment listed below.

# **Tracking Number**

1Z56E1A01321764036

# Weight

0.50 LBS

# **Service**

UPS Next Day Air Saver®

# Shipped / Billed On

03/24/2020

# **Delivered On**

03/25/2020 10:46 A.M.

# **Delivered To**

SAN FRANCISCO, CA, US

# **Received By**

FRONT DESK

# **Left At**

Front Desk

Thank you for giving us this opportunity to serve you. Details are only available for shipments delivered within the last 120 days. Please print for your records if you require this information after 120 days.

Sincerely,

**UPS** 

Tracking results provided by UPS: 03/25/2020 1:57 P.M. EST

# APPENDIX D WELLFIELD SSM LOG

# REDWOOD LANDFILL, INC. COLLECTION SYSTEM DOWNTIME LOG

	<del>                                     </del>			T	1		TOLLEGI				(0) Did Front (40) F	Na a wile a		
Event No.	Check Applicable Event	Device	(1) Event Start Date/Time	(2) Event End Date/Time	(3) Duration (Hrs)	Downtime (Hrs)	(4) Cause or Reason	(5) Applicable Regulation	(6) Type of Event	(7) (8) Did Steps Procedures Taken Vary From (7) (7)	Cause Any Em Emission Limit Stan	Describe ission Completed dard(s) By eded (b)	(11) Date Entry Completed	
			9/27/19 13:30	9/27/19 13:32	0.03			113: Inspection/Maintenance	x Manual (Go to 7)	Procedures Yes (Go to 9)	Yes (Go to 10)			
1	x Shutdown x Startup	RLLC0178				3,169.87	Well raising, well located in active fill area	x 116: Well Raising 117: Gas Collection	Automatic (Go to 9)  x Manual (Go to 7)	1 to 3 x No  Procedures Yes (Go to 9)	No Yes (Go to 10)	Mike Chan	2/6/2020	
	Malfunction		2/6/20 15:22	2/6/20 15:24	0.03			118: Construction Activities	Automatic (Go to 9)	1 to 4 x No	No			
			10/24/19 8:30	10/24/19 8:32	0.03			113: Inspection/Maintenance	x Manual (Go to 7)	Procedures Yes (Go to 9)	Yes (Go to 10)			
2	x Shutdown x Startup	RLLC0177				2,526.87	Well raising, well located in active fill area	x 116: Well Raising 117: Gas Collection	Automatic (Go to 9)  x Manual (Go to 7)	1 to 3 x No  Procedures Yes (Go to 9)	No Yes (Go to 10)	Mike Chan	2/6/2020	
	Malfunction		2/6/20 15:22	2/6/20 15:24	0.03		douve illi died	118: Construction Activities	Automatic (Go to 9)	Procedures Yes (Go to 9) 1 to 4 x No	No			
			10/24/19 8:30	10/24/19 8:32	0.03			113: Inspection/Maintenance	x Manual (Go to 7)	Procedures Yes (Go to 9)	Yes (Go to 10)			
3	x Shutdown	RLLC0185	10/24/19 0.30	10/24/19 0.32	0.03	821.00	Well raising, well located in	x 116: Well Raising	Automatic (Go to 9)	1 to 3 x No	No	Mike Chan	11/27/2019	
	x Startup  Malfunction		11/27/19 13:30	11/27/19 13:32	0.03		active fill area	117: Gas Collection 118: Construction Activities	x Manual (Go to 7)	Procedures Yes (Go to 9) 1 to 4 x No	Yes (Go to 10)			
	Mailunction							113: Inspection/Maintenance	Automatic (Go to 9)  x Manual (Go to 7)	Procedures Yes (Go to 9)	No Yes (Go to 10)			
	x Shutdown	DI 104000	11/13/19 10:30	11/13/19 10:32	0.03	4 000 50	Well raising, well located in	x 116: Well Raising	Automatic (Go to 9)	1 to 3 x No	No	Miles Observ	F /4 /0000	
4	Startup	RLI0103C	Well offli	ine as of May 1, 2	020	4,069.50	active fill area	117: Gas Collection	Manual (Go to 7)	Procedures Yes (Go to 9)	Yes (Go to 10)	Mike Chan	5/1/2020	
	Malfunction		vvcii oiiii	THE as of May 1, 2	020			118: Construction Activities	Automatic (Go to 9)	1 to 4 No	No			
	x Shutdown		11/18/19 8:40	11/18/19 8:42	0.03		Mall rejeien well le entert in	113: Inspection/Maintenance x 116: Well Raising	x Manual (Go to 7)	Procedures Yes (Go to 9) 1 to 3 x No	Yes (Go to 10)			
5	x Startun RLLC0175			337.50	Well raising, well located in active fill area	117: Gas Collection	Automatic (Go to 9)  x Manual (Go to 7)	Procedures Yes (Go to 9)	No Yes (Go to 10)	Mike Chan	12/2/2019			
	Malfunction		12/2/19 10:10	12/2/19 10:12	0.03			118: Construction Activities	Automatic (Go to 9)	1 to 4 x No	No			
			11/29/19 18:30	11/29/19 18:32	0.03			113: Inspection/Maintenance	x Manual (Go to 7)	Procedures Yes (Go to 9)	Yes (Go to 10)			
6	x Shutdown	RLLC0186	11/20/10 10:00		0.00	92.25	92.25	Well raising, well located in	x 116: Well Raising	Automatic (Go to 9)	1 to 3 x No	No	Mike Chan	12/3/2019
	x Startup Malfunction		12/3/19 14:45	12/3/19 14:47	0.03		active fill area	117: Gas Collection 118: Construction Activities	x Manual (Go to 7) Automatic (Go to 9)	Procedures Yes (Go to 9) 1 to 4 x No	Yes (Go to 10)			
	Manufiction							113: Inspection/Maintenance	x Manual (Go to 7)	Procedures Yes (Go to 9)	Yes (Go to 10)			
7	x Shutdown	RLLC0218	12/23/19 10:45	12/23/19 10:47	0.03	N/A	Well decommissioned pursuant	x 116: Well Raising	Automatic (Go to 9)	1 to 3 x No	No	Mike Chan	12/23/2019	
′	Startup	KLLC0210		N/A		IN/A	to AN #30065 on 12/23/19	117: Gas Collection		N/A		IVIIKE CHAIT	12/23/2019	
	Malfunction			1	1			118: Construction Activities	Manual (Oa ta 7)		V (0-+-40)			
	x Shutdown		2/5/20 11:33	2/5/20 11:35	0.03		Inspection/maintenance of well	x 113: Inspection/Maintenance	x Manual (Go to 7) Automatic (Go to 9)	Procedures Yes (Go to 9) 1 to 3 x No	Yes (Go to 10)			
8	x Startup	RLLC0242				27.82	located in active fill area	117: Gas Collection	x Manual (Go to 7)	Procedures Yes (Go to 9)	Yes (Go to 10)	Mike Chan	2/6/2020	
	Malfunction		2/6/20 15:22	2/6/20 15:24	0.03			118: Construction Activities	Automatic (Go to 9)	1 to 4 x No	No			
			2/17/20 13:00	2/17/20 13:02	0.03			<u> </u>	x Manual (Go to 7)	Procedures Yes (Go to 9)	Yes (Go to 10)			
9	x Shutdown Startup	RLI0108A				N/A	Well decommissioned pursuant to AN #30065 on 2/17/20	116: Well Raising 117: Gas Collection	Automatic (Go to 9)	1 to 3 x No	No	Mike Chan	2/17/2020	
	Malfunction			N/A			107114 1100000 011 2/11720	118: Construction Activities		N/A				
			2/42/20 7:45	2/42/20 7:47	0.00			x 113: Inspection/Maintenance	x Manual (Go to 7)	Procedures Yes (Go to 9)	Yes (Go to 10)			
10	x Shutdown	RLLC0178	3/12/20 7:45	3/12/20 7:47	0.03	457.92	Inspection/maintenance of well	116: Well Raising	Automatic (Go to 9)	1 to 3 x No	No	Mike Chan	3/31/2020	
.0	x Startup	RELOGITO	3/31/20 9:40	3/31/20 9:42	0.03	107.02	located in active fill area	117: Gas Collection	x Manual (Go to 7)	Procedures Yes (Go to 9)	Yes (Go to 10)	Will Gridin	0/0 1/2020	
	Malfunction			1				118: Construction Activities  x 113: Inspection/Maintenance	Automatic (Go to 9)  x Manual (Go to 7)	1 to 4 x No  Procedures Yes (Go to 9)	No Yes (Go to 10)			
	x Shutdown		3/24/20 13:15	3/24/20 13:17	0.03		Well decommissioned pursuant	116: Well Raising	Automatic (Go to 9)	Procedures Yes (Go to 9) 1 to 3 x No	No			
11	Startup	RLI00138	N/A N/A		to AN #30065 on 3/24/20	117: Gas Collection	(2-2)	N/A	l l	Mike Chan	N/A			
	Malfunction			N/A				118: Construction Activities						
			3/24/20 13:30	3/24/20 13:32	0.03			x 113: Inspection/Maintenance	x Manual (Go to 7)	Procedures Yes (Go to 9)	Yes (Go to 10)			
12	x Shutdown Startup	RLI00139		<u> </u>	<u> </u>	N/A	Well decommissioned pursuant to AN #30065 on 3/24/20	116: Well Raising 117: Gas Collection	Automatic (Go to 9)	1 to 3 x No	No	Mike Chan		
	Malfunction			N/A			12 1 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2	118: Construction Activities	1	N/A				

5/26/2020 RLI 2020.05 SAR Appendix v1.xlsx

# REDWOOD LANDFILL, INC.

# **COLLECTION SYSTEM DOWNTIME LOG**

Even No.	Check Applicable Event	Device	(1) Event Start Date/Time	(2) Event End Date/Time	(3) Duration (Hrs)	Downtime (Hrs)	(4) Cause or Reason	(5) Applicable Regulation	(6) Type of Event	(7) Procedures Used (a),(b)	(8) Did Steps Taken Vary From (7)	(9) Did Event Cause Any Emission Limit Exceedance?	(10) Describe Emission Standard(s) Exceeded (b)	Completed By	(11) Date Entry Completed
10	x Shutdown	DI I 00477	3/30/20 13:40	3/30/20 13:42	0.03	19.83	Inspection/maintenance of well	x 113: Inspection/Maintenance 116: Well Raising	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 3	Yes (Go to 9) x No	Yes (Go to 10) No		Miles Chan	3/31/2020
13	x Startup Malfunction	RLLC0177	3/31/20 9:30	3/31/20 9:32	0.03	19.03	located in active fill area	117: Gas Collection 118: Construction Activities	x Manual (Go to 7) Automatic (Go to 9)	Procedures 1 to 4	Yes (Go to 9) x No	Yes (Go to 10) No		Mike Chan	3/31/2020

5/26/2020 RLI 2020.05 SAR Appendix v1.xlsx

# (a) STANDARD OPERATING PROCEDURES

### Shutdown

Procedure No. Procedure

- Ensure that there is no unsafe conditions present, contact manager immediately Initiate shutdown sequence below by one or more of the following (Note date and time in Section 1 of form above) a. Press Emergency Stop if necessary b. Close On/Off switch(es) or Push On/Off button(s)

  - c. Close adjacent valves if necessary

    Observe that system achieves normal shutdown ranges for levels, pressures, and temperatures (Note date and time in Section 2 of form above)

# 3. Startup

Procedure No.

- <u>Procedure</u>
  Ensure that there is no unsafe conditions present
  Ensure that the system is ready to start by one of the following:

  - a. Valves are in correct position
     b. Levels, pressures, and temperatures are within normal starting range

  - c. Alarms are cleared
    d. Power is on and available to control panel and ready to energized equipment.
- e. Emergency stop is de-energized
  Initiate start sequence (Note time and date in section 1 of form above)
  Observe that system achieves normal shutdown ranges for levels, pressures, and temperatures (Note time and date in Section 2 of form above)

# Malfunction

EQUIPMENT	PURPOSE	MALFUNCTION	COMMON CAUSES	PROCEDURE NOTYPICAL RESPONSE ACTIONS
EQUI MENT	I CKI OSE	EVENT	OCHMINICIT GAGGES	TROOLEGIC NOTIT TOAL NEGI GNOL ACTIONS
LFG Collection and Control Sy	stem	EVENI		
Blower or Other Gas Mover	Applies vacuum to wellfield	Loss of LFG Flow/Blower	-Flame arrestor fouling/deterioration	Repair breakages in extraction piping
Equipment	to control device		-Automatic valve problems -Blower failure (e.g., belt, motor, impeller, coupling, seizing, etc.) -Loss of power -Extraction piping failure -Condensate knock-out problems -Extraction piping blockages	2. Clean flame arrestor 3. Repair blockages in extraction piping 4. Verify automatic valve operation, compressed air/nitrogen supply 5. Notify power utility, if appropriat 6. Provide/utilize auxiliary power source, if necessar 7. Repair Settlement in Collection Piping 8. Repair Blower 9. Activate back-up blower, if available 10. Clean knock-up pot/demister 11. Drain knock-out pot
Extraction Wells and Collection	Conduits for extractions and	Collection well and pipe	-Break/crack in header or lateral piping	12. Repair leaks or breaks in lines or wellheads
Piping	movement of LFG flow	failures	-Leaks at wellheads, valves, flanges, Test ports, seals, couplings, etcCollection piping blockages -Problems due to settlement (e.g. pipe separation, deformation, development of low points	Follow procedures for loss of LFG flow/blower malfunction     H4. Repair blockages in collection piping     Follow procedures the collection piping     Re-install, repair, or replace piping
Blower or Other Gas Mover	Collection and control of	Loss of electrical power	- Force majeure/Act of God (e.g., lightning, flood,	17. Check/reset breaker
Equipment And Control Device	LFG		earthquake, etc.) -Area-wide or local blackout or brown-ou -Interruption in service (e.g. blown service fuse -Electrical line failure -Breaker trip -Transformer failure -Motor starter failure/trip -Overdraw of power -Problems in electrical panel -Damage to electrical equipment from on-site operations	18. Check/repair electrical panel component: 19. Check/repair transformer 20. Check/repair motor starter 21. Check/repair electrical line 22. Test amperage to various equipment 23. Contact electricity supplies 24. Contact/contract electrician 25. Provide auxiliary power (if necessary
LFG Control Device	Combusts LFG	Low temperature conditions	-Problems with temperature -monitoring equipmen	26. Check/repair temperature monitoring equipment
		at control device	-Problems failure of -thermocouple and/or thermocouple wiring  -Change of LFG flow  -Change of LFG quality  -Problems with air louvers  -Problems with airfuel controls  -Change in atmospheric conditions	Check/repair thermocouple and/or wiring     Sellow procedures for loss of flow/blower malfunction     Check/adjust louvers     Check/adjust air/fuel controls
LFG Control Device	Combusts LFG	Loss of Flame	-Problems/failure of thermocouph -Loss/change of LFG flow -Loss/change of LFG quality	Check/repair temperature monitoring equipment     Check/repair thermocoupk     Sollow procedures for loss of flow/blower malfunction
		No. 10 and	-Problems with air/fuel controls -Problems/failure of flame sensor -Problems with temperature monitoring equipmen	34. Check/adjust air/fuel controls 35. Check/adjust/repair flame sensor 36. Check/adjust LFG collectors
Flow Monitoring/	Measures and records gas flow from collection system	Malfunctions of Flow Monitoring/Recording	-Problems with orifice plate, pitot tube, or other in-line flow measuring device	37. Check/adjust/repair flow measuring device and/or wiring
Recording Device	to control	Device Device	-Problems with device controls and/or wiring -Problems with chart recorder	38. Check/repair chart recorder 39. Replace paper in chart recorder
Temperature Monitoring/ Recording Device	Monitors and records combustion temperature of enclosed combustion device	Malfunctions of Temperature Monitoring/Recording Device	-Problems with thermocouple     -Problems with device controls and/or wiring     -Problems with chart recorder	40. Check/adjust/repair thermocouple 41. Check/adjust/repair controller and/or wiring 42. Check/adjust/repair electrical panel component 43. Check/repair chart recorder 44. Replace paper in chart recorder
Control Device	Combusts LFG	Other Control Device Malfunctions	-Control device smoking (i.e. visible emissions) -Problems with flare insulation -Problems with pilot light system -Problems with air louvers -Problems with airfled controllers -Problems with thermocouple -Problems with thermocouple -Problems with burners -Problems with burners -Problems with flame arrester -Alarmed malfunction conditions not covered abov -Unalarmed conditions discovered during inspection not covered abov	45. Site-specific diagnosis procedure: 46. Site-specific responses actions based on diagnosis 47. Open manual louvers 48. Clean pitot orifice 49. Clean/drain flame arrestor 50. Refill propane supply 51. Check/repair pilot sparking system

(b) For each permit limit exceedance complete an "SSM Plan Departure Form".

RLI 2020.05 SAR Appendix v1.xlsx Proc(3) 5/26/2020

# APPENDIX E A-51 AND A-60 FLARE TEMPERATURE REPORTS

Redwood Landfill, Novato, CA

A-51 Flare TEMPERATURE DEVIATION/ INOPERATIVE MONITOR REPORT November 1, 2019 to April 30, 2020

REPORT PREPARED BY:Michael ChanDATE:May 26, 2020TEMPERATURE SENSING DEVICE:ThermocoupleMODEL:Thermo-Electric

START DATE & TIME	END DATE & TIME	TEMP (°F) / FLOW	CAUSE	EXPLANATION	ACTION TAKEN				
No deviations or inoperative monitors during the month of November 2019									
	No deviations or inoperative monitors during the month of December 2019								
	No deviations or inoperative monitors during the month of January 2020								
	No deviations or inoperative monitors during the month of February 2020								
		No deviation	ns or inoperative monitors during the	month of March 2020					
		No deviatio	ns or inoperative monitors during the	e month of April 2020					
COMMENTS:			vith Title V Permit Condition Number I not drop below 1,400 degrees Fahr		•				
	2 The A-51 Flare combustion zone 3-hour average temperature did not drop below the 1,400°F (3/28/19 to 3/15/20) or 1,400°F (3/16/2020 to current) limits established during the January 30, 2019 and January 22, 2020 Annual Source Tests, while the flare was in operation, pursuant to Title V Permit Condition Number 19867, Part 22, and 40 CFR 60.75 b(2)(iii)(B)(2) in Subpart WWW of the NSPS.								

Temp RLI 2020.05 SAR Appendix v1.xlsx


Redwood Landfill, Novato, CA

A-60 Flare TEMPERATURE DEVIATION/ INOPERATIVE MONITOR REPORT November 1, 2019 to April 30, 2020

REPORT PREPARED BY:Michael ChanDATE:May 26, 2020TEMPERATURE SENSING DEVICE:ThermocoupleMODEL:Thermo-Electric

START DATE & TIME	END DATE & TIME	TEMP (°F) / FLOW	CAUSE	EXPLANATION	ACTION TAKEN					
	No deviations or inoperative monitors during the month of November 2019									
	No deviations or inoperative monitors during the month of December 2019									
		No deviations	s or inoperative monitors during the i	month of January 2020						
		No deviations	or inoperative monitors during the r	nonth of February 2020						
	No deviations or inoperative monitors during the month of March 2020									
		No deviatio	ns or inoperative monitors during the	e month of April 2020						
COMMENTS:	1	Zone A 3-hour a	vith Authority To Construct (ATC) 19 average temperature did not drop be are combustion Zone B 3-hour avera	low 1,400 degrees Fahrenheit (°F) v	while the flare was in operation,					
2 The A-60 Flare Zone A combustion zone three-hour average temperature did not drop below 1,559°F (4/4/2017 to 9/19/2019) or 1,535°F (9/20/2019 to current) limits established during the February 8, 2017 and July 25, 2019 Source Tests, pursuant to 40 CFR 60.752 b(2)(iii)(B)(2) in Subpart WWW of the NSPS.  Zone B of the A-60 Flare combustion zone 3-hour average temperature did not drop below the 1,497°F (1/1/2018 to 9/13/18) or 1,555°F (9/14/18 to current) limits established in the July 24, 2017 and July 17, 2018 Source Tests. Pursuant to Title V Condition 19867 Part 30g, the Annual Source Test at A-60 may be conducted while it is operating either zone, provided that each operating zone is tested at least once every five years.										

Temp RLI 2020.05 SAR Appendix v1.xlsx



Emission Control Devices									
A-51 Flare Missing Data Summary	-51 Flare Missing Data Summary								
Redwood Landfill, Novato, CA									
FLARE MISSING DATA REPORT	November 1, 2019 to Apr	il 30, 2020							
Date & Time	Date & Time	Total Missing Data	Total Missing Data	Comments					
		Hours	Days						
There was no missing data for November 2	There was no missing data for November 2019								
There was no missing data for December 2	019								
There was no missing data for January 202	20								
There was no missing data for February 20	There was no missing data for February 2020								
There was no missing data for March 2020									
There was no missing data for April 2020									
1		I		I					

Flare A-51	<u>Hours</u>	<u>Days</u>
Total Missing Data:	0.00	0.00
Total Complete Data:	4,368.00	182.00
Missing Data Percentage:	0.00%	0.00%

Missing Data RLI 2020.05 SAR Appendix v1.xlsx


Emission Control Devices				
A-60 Flare Missing Data Summary				
Redwood Landfill, Novato, CA FLARE MISSING DATA REPORT	November 1, 2019 to Apr	il 30, 2020		
Date & Time	Date & Time	Total Missing Data	Total Missing Data	Comments
		Hours	Days	
here was no missing data for November 2	2019			
here was no missing data for December 2	2019			
here was no missing data for January 202	20			
here was no missing data for February 20	020			
here was no missing data for March 2020				
here was no missing data for April 2020				

Flare A-60	<u>Hours</u>	Days
Total Missing Data:	0.00	0.00
Total Complete Data:	4,368.00	182.00
Missing Data Percentage:	0.00%	0.00%


Missing Data RLI 2020.05 SAR Appendix v1.xlsx

# APPENDIX G COVER INTEGRITY MONITORING REPORTS


West	•		Cover Integrity In	spection Form		
Facility	Waste Managem	ent- Redwood Landfill				
Date	11/26/2019	Received	d Manager	Ramin Khany	Date	11/26/2019
Technician	S. Johnson	Repairs Com	plete Manager	And	Date	12/23/2019
Cell/Pad	Area B		Cell/Pad	//		
needed on I	he slope that was	and 185. Additional cover i recently filled. <u>Corrective</u> re placed in the described	Action:			
needed on I	he slope that was	recently filled. Corrective	Action:			
needed on I Soild and er	the slope that was rosion control wer	recently filled. Corrective	Action: area.	lentified	Repaired	
needed on I Soild and er	the slope that was rosion control wer	recently filled. <u>Corrective</u> re placed in the described	Action: area.	lentified	Repaired	




W		Monthly Cover I	<u>ntegrity ln</u>	spection Fo	orm	
Facility	Waste Management- Redwo	od Landfill				
Date	12/24/2019	Received	Manager	Ramin Khany	Date	12/24/2013
Technician	S. Johnson	Repairs Complete	Manager		Date	
Cell/Pad	Area B		Cell/Pad			
	II186. Additional cover is need See attached map for details. <u>Action</u> :	ed on an area chac was				
Date Id	entified 12/24/2019	Repaired	Date Id	lentified	Repaired	
Cell/Pad			Cell/Pad			
Description	of finding and corrective a	ction:	Description	of finding and o	corrective action:	




VV/MA			Monthly Cover Ir	tegrity in:	spection Form		
Facility	Waste Management- Redwood Landfill 1/29/2020 A Received						
Date				Manager	Ramin Khany	Date	1/29/2020
Technician	5. Johnson	W.	Repairs Complete	Manager	/ sufer	Date	2/25/20
Cell/Pad	Area E			Cell/Pad	-/		
	as recently fille	ed. See atta	onal cover is needed on an ched map for details. d area with additional soil.				
Corrective A	as recently fille action: Operati	ed. See atta ions covere	ched map for details. d area with additional soil.				
Corrective A	as recently fille	ed. See atta	ched map for details. d area with additional soil.		entified	Repaired	1
Corrective A  Date k	as recently fille action: Operati	ed. See atta ions covere 1/29/202	ched map for details. d area with additional soil.  Repaired 2/10/2020	Cell/Pad	lentified		




Facility	Waste Mana	gement- Redwoo	Monthly Cover I			*	
Date	Name and Additional Control of the C			Manager	Ramin Khany	Date	2/25/2020
Technician	hnician S. Johnson Repairs Complete			Manager	Sundy	Date	3/24/
Cell/Pad				Cell/Pad			,,,,,,
Near well LO Corrective A	over is neede C-175- See atta Action: Operat	d in an area that ached map for ac	n: In Area B, was recently filled. Iditional details. Idional cover to the	Безсприо	n of finding and co	orrective action.	
Near well LO Corrective A descriped a	over is needer 5-175- See atta action: Operat rea.	d in an area that ached map for ac tions added addit	was recently filled, iditional details. ional cover to the				
Near well LO Corrective A descriped a	over is neede C-175- See atta Action: Operat	d in an area that ached map for ac tions added addit	was recently filled. Iditional details.		lentified	Repaired	ı



Facility	Waste Management: Red	wood Landfull				
Date	3/24/2020	Received	Manager	Ramin Johany	Date	3/24/2020
Technician	5. Johnson NOO	Repairs Complete	Manager	Any	Date	4-108/2
Cell/Pad	Area B		Cell/Pad	1		1,11
the East side	action Additional	e attached map for	A COLOR OF THE COLOR	n of finding and corre	ctive action:	
the East side additional d Corrective A	e of LC-178 and LC-177-Ser letails. Action: Additional Added to Justicity	hat was recently filled. On e attached map for Cour Wes end Aren		entified	Repaired	
the East side additional d Corrective A	e of LC-178 and LC-177-Ser letails. Action: Additional Added to Justicity	hat was recently filled. Or e attached map for Cour WeS				1



W			Month	ıly Cover lı	ntegrity In:	spection F	orm		
Facility	Waste Manage	ment- Redwoo	od Landfill						
Date	4/30/2020		Rece	eived	Manager	Ramin Khany		Date	4/30/2020
Technician	S. Johnson		Repairs	Complete	Manager			Date	
Cell/Pad	Area D				Cell/Pad				
	f finding and cor slope and flat S		ell LC-234. See		Description o	f finding and co	rrective action:		
	entified	3/23/2020	Repaired		Date Id	entified		Repaired	
Cell/Pad					Cell/Pad				
Description	of finding and	corrective a	ction:		Description	of finding and	corrective ac	ction:	
Date Id	entified		Repaired		Date Id	entified		Repaired	
Cell/Pad					Cell/Pad				
Description	of finding and	corrective a	etion:		Description	of finding and	corrective ac	etion:	



# APPENDIX H SURFACE EMISSIONS MONITORING / COMPONENT LEAK



# **WASTE MANAGEMENT**

172 98<sup>th</sup> Avenue Oakland, CA 94603 (510) 430-8509

January 13, 2020

Ms. Alisha McCutcheon Redwood Landfill, Inc. 8590 Redwood Highway Novato, California 94948

Re: Fourth Quarter 2019 Surface Emissions and Component Leak Monitoring Report for Redwood Landfill, Inc.

Dear Ms. McCutcheon:

This monitoring report for "Redwood Landfill, Inc. (RLI)" contains the results of the Fourth Quarter 2019 Integrated and Instantaneous Surface Emissions Monitoring (SEM) and Component Leak Monitoring. Initial surface emissions monitoring was performed by Roberts Environmental Services, LLC. (RES). Re-monitoring of surface emissions and site-wide component leak monitoring was conducted by RES and/or Waste Management (WM) personnel.

# APPLICABLE REQUIREMENTS

The monitoring discussed in this report was conducted in accordance with the following requirements:

# **Surface Emission Monitoring (SEM)**

- New Source Performance Standard (NSPS), Title 40 of the Code of Federal Regulations (CFR) §60.755 (c) and (d), 40 CFR 60, Appendix A Method 21, promulgated by the United States Environmental Protection Agency (USEPA).
- California Code of Regulations (CCR) Title 17, Subchapter 10, Article 4, Subarticle 6, §95460 to §95476, known as the Assembly Bill 32 (AB32) landfill methane rule (LMR).
- Bay Area Air Quality Management District (BAAQMD) Regulation 8, Rule 34, Section 303 (Landfill Surface Requirements) and Section 607 (Landfill Surface Inspection procedures).

# **Component Leak**

• Bay Area Air Quality Management District (BAAQMD) Regulation 8, Rule 34, Section 301 (Landfill Gas Collection and Emission Control System Requirements) and Section 602 (Collection and Control System Leak Inspection procedures).

• California Code of Regulations (CCR) Title 17, Subchapter 10, Article 4, Subarticle 6, §95464, known as the Assembly Bill 32 (AB32) landfill methane rule (LMR).

# **RLI Plan and Alternative Compliance Measures**

An Alternative Compliance Option (ACO) Request was submitted to the California Air Resources Board (CARB) on March 24, 2011. After receipt of comments, this ACO was amended, restated, and submitted to BAAQMD on July 1, 2016. SEM and Component Leak monitoring was conducted per the methods outlined in the July 1, 2016 ACO.

# **PROCEDURES**

# General

The surface of the RLI disposal area has been divided into two hundred-eight (208), approximately 50,000 square foot monitoring grids. The entire landfill surface is monitored with the exception of active portions of the Landfill, slope areas, and as requested in the approved ACO, areas containing only asbestos-containing waste, inert waste and/or non-decomposable waste which are excluded for safety as allowed by CCR Title 17 §95466.

Field personnel walked the surface of the landfill following the walking pattern as depicted the 2011 RLI AB-32 SEM Plan, which traverses each monitoring grid. Additionally, in accordance with the provisions of 40 CFR 60.753(d) and 60.755(c)(1-3), the entire perimeter of the landfill surface was monitored. During the event, special attention was given to monitoring unusual cover conditions (stressed vegetation, cracks, seeps, etc.) and any areas with unusual odors.

# **Instantaneous Surface Emissions Monitoring**

The Instantaneous SEM was conducted using a Toxic Vapor Analyzer (TVA) 1000 flame ionization detector (FID), which was calibrated to 500 parts per million by volume (ppm<sub>v</sub>) methane, which meets or exceeds all guidelines set forth in the CCR Title 17 §95471(a) and NSPS. The FID was calibrated prior to use in accordance with the United States Environmental Protection Agency (USEPA) Method 21 requirements. The Instantaneous SEM procedures followed the requirements of 40 CFR 60.755 (c) and (d) and CCR Title 17 §95471(c)(2).

RES personnel walked the surface of the landfill on a grid by grid basis with the wand tip held at 2 inches from the landfill surface. While sampling the grid; the technicians also checked any surface impoundments (wells or otherwise) for leaks. Technicians also checked any surface cracks, seeps, or other areas that show evidence of surface emissions (odors or distressed vegetation). Active and sloped areas excluded for safety were documented on field data sheets and maps.

All instantaneous surface monitoring was performed in accordance with the applicable requirements referenced in this report. Any detections of methane above 200 ppm<sub>v</sub> (areas of concern) or 500 ppm<sub>v</sub> (exceedances) for instantaneous were recorded, flagged, and marked on an SEM Map, which, wherever required, is included in the Appendices of this report. Applicable corrective action and re-monitoring timelines are listed below:

- Corrective actions must be initiated within 5 days of the initial exceedance and remonitoring shall be conducted within 10 days of the initial exceedance.
  - o If the re-monitoring event shows the exceedance is corrected, the location shall be re-monitored within 1 month of the initial exceedance.
  - o If the 1-month re-monitoring event shows the location is still corrected, all remonitoring requirements have been completed.
- If either the first 10-day or 1-month re-monitoring events show a second exceedance, additional corrective actions shall be completed and a second re-monitoring event shall be conducted within 10 days of the second exceedance.
- If the second 10-day re-monitoring event shows the second exceedance is corrected, the location shall be re-monitored within 1 month of the initial exceedance. If the 1-month re-monitoring event shows the area is still corrected, monitoring requirements have been completed.

If any location shows three exceedances, an additional well shall be installed within 120 days of the initial exceedance.

# **Integrated Surface Emissions Monitoring**

The Integrated surface monitoring was conducted using a TVA 1000 calibrated to 25 ppm<sub>v</sub> for the integrated monitoring, which meets or exceeds all guidelines set forth in the CCR Title 17 §95471(a). The field technician traversed the grid walking path over a continuous 25-minute period using the TVA 1000 held at 3 inches above the landfill surface. The Integrated monitoring procedures followed the requirements of CCR Title 17 §95471(c)(2).

Grids with results greater than 25 ppm<sub>v</sub> were recorded, marked on the SEM map, and flagged for remediation. Any grids with integrated concentrations greater than 25 ppm<sub>v</sub> are subject to the following re-monitoring timeline:

- Re-monitoring shall be conducted within 10 days of the initial exceedance.
- If the 10-day re-monitoring event shows the exceedance is corrected, all re-monitoring requirements have been completed.
- If either the first 10-day re-monitoring event shows a second grid exceedance, additional corrective actions shall be completed and a second re-monitoring event shall be conducted within 10 days of the second exceedance.
- If the second 10-day re-monitoring event shows the second exceedance is corrected, all re-monitoring requirements have been completed.
- The second 10-day re-monitoring event shows a third grid exceedance, an additional well shall be installed within 120 days of the third exceedance.

# **Component Leak Monitoring Procedures**

RES personnel monitored the exposed LFG components under positive pressure (pipes, wellheads, valves, blowers, and other mechanical appurtenances) using a TVA 1000 calibrated to 500 ppm<sub>v</sub>. All leaks measured one half inch or less from the component exceeding the compliance limit of 500 ppm<sub>v</sub> per requirements outlined in pursuant to CARB Title 17 of California Code of Regulations Subchapter 10, Article 4, Subarticle 6, Section 95464(b)(1)(B) and 1,000 ppm<sub>v</sub> per requirements outlined in BAAQMD 8-34-303 were recorded. Applicable corrective action and re-monitoring timelines are listed below:

- Leaks between 500 and 999 ppm<sub>v</sub> must be corrected and re-monitored within 10 days of the initial exceedance.
- Leaks at or above 1000 ppm<sub>v</sub> must be corrected and re-monitored within 7 days of the initial exceedance.

# FOURTH QUARTER 2019 SEM AND COMPONENT LEAK RESULTS

The following is a summary of the SEM and component leak monitoring results completed for the Fourth Quarter 2019.

# **Instantaneous Surface Emissions Monitoring Results**

The Instantaneous surface monitoring was performed on November 5, 2019 in accordance with the NSPS, BAAQMD 8-34, and CCR Title 17 §95469 and ACO. Results and data from the monitoring are presented in Attachment A

# Initial Monitoring Event Exceedances of 500 ppm<sub>v</sub>

There were three (3) exceedances of  $500 \text{ ppm}_v$  as methane detected on November 5, 2019. Corrective actions to initiate repairs of the exceedances were completed within five days for all locations.

# First Ten-Day Re-Monitoring Results

The first 10-day re-monitoring event was completed on November 14, 2019. All locations were observed at less than 500 ppm<sub>v</sub>.

# One-Month Re-Monitoring Results

The 1-month re-monitoring event was completed on December 4, 2019. All locations were observed at less than 500 ppm<sub>v</sub>.

# Readings between 200 ppm<sub>v</sub> and 499 ppm<sub>v</sub> (Initial and Re-monitored)

There were no readings between 200 ppm<sub>v</sub> and 499 ppm<sub>v</sub> as methane detected during the initial monitoring event on November 5, 2019. Pursuant to CCR Title 17 §95471(c), instantaneous surface emissions exceeding 200 ppm<sub>v</sub> but below 500 ppm<sub>v</sub> are required to be recorded.

# **Integrated Surface Emissions Monitoring Results**

The Integrated surface sampling (ISS) was performed on November 4, 5, and 6, 2019 in accordance with the ACO and requirements outlined in CCR Title 17 §95469.

# Initial Monitoring Event Exceedances of 25 ppm<sub>v</sub>

There were 0 grids with exceedances of 25 ppm<sub>v</sub> as methane detected during the initial monitoring event.

The average methane concentration of each grid was recorded during the monitoring event per applicable requirements. See Attachment B, Integrated SEM 25 ppm<sub>v</sub> Exceedances and Monitoring Log, and SEM Map included in Attachment B, for details.

# **Component Leak Monitoring Results**

Component leak monitoring was conducted per the applicable requirements on November 5, 2019. No leaks greater than 500 ppm<sub>v</sub> were identified. Please see Attachment C, for details.

# WEATHER CONDITIONS

# Wind Speed Conductions during the Surface Emission Monitoring Events

Wind speeds during initial monitoring were monitored using a portable weather station. The station has a strip chart that records the wind speed and direction. After completion of monitoring, the strip chart is reviewed by RES office staff to determine the average and maximum wind speeds during the monitoring and the average wind direction during each grid and ensure that the wind speed requirements are met (no gusts greater than 20 mph, average wind speed cannot exceed 10 mph). These values are documented in the field data sheets. The chart data is scanned and included in Attachment D.

# **Precipitation Requirements**

Per the RLI's ACO, the initial monitoring event was carefully scheduled so that it could be conducted in compliance with the precipitation requirements (no precipitation  $\geq 0.01$ " within 24 hours,  $\geq 0.16$ " within 48 hours, nor  $\geq 0.25$ " within 72 hours). Re-monitoring events are required to adhere to strict timelines. Any conflicts with precipitation requirements are discussed in the results section of this document.

# **EQUIPMENT CALIBRATION**

The portable analyzers were calibrated to meet the instrument specifications requirements of U.S. EPA Method 21. The calibration gas used was methane, diluted to a nominal concentration of 25 ppm<sub>v</sub> in air for integrated sample analyses and 500 ppm<sub>v</sub> in air for instantaneous monitoring to comply with the requirements.

All analyzers were calibrated prior to use with required response time and precision related instrument checks. Calibration records include the following: One time response time test record;

Ms. Alisha McCutcheon Page 6

One time response factor determination for methane; Calibration Precision test records (test to be performed every 3 months); and Daily Instrument Calibration and Background test records for each gas meter that was used during the quarterly monitoring event. The calibration log records are included in Attachment E.

All monitoring was completed in accordance with the applicable regulatory requirements or approved alternatives. If you have any questions regarding this report, please do not hesitate to contact me at (510) 613-2852.

Thank you, Waste Management



**Environmental Protection Specialist** 

Attachel Chan

# Attachment A – Instantaneous Surface Emission Monitoring Event Records

- Monitoring Logs and Exceedances
- Surface Monitoring Weather Data
- SEM Map

# Attachment B – Integrated Surface Emission Monitoring Event Records

- Monitoring Logs and Exceedances
- Surface Monitoring Weather Data
- SEM Map

# Attachment C – Component Leak Monitoring Event Records

• Component Leak Exceedances and Monitoring Logs

# Attachment D – Weather Station Data

• Strip Chart Data

# Attachment E – Calibration Records

• Instrument and Gas Calibration Records

#### Attachment A

Instantaneous Surface Emission Monitoring Event Records

## Table A.1 Instantaneous Landfill Surface Emissions Monitoring Initial Monitoring Event Areas of Concern

**2019 QUARTER:** 4

PERFORMED BY: RES and S. Johnson LANDFILL NAME: Redwood Landfill, Inc.

Grid Number	Flag Number	Date of Monitoring	Concentration of Emission (ppm <sub>v</sub> )	Comments
199	O41	11/5/2019	3,000	Well 3
89	O42	11/5/2019	3,500	Well 219
15	O61	11/5/2019	4,700	Surface
		+		
		+		
Notes: Please refer to fiel	d data sheets for details			

## Table A.2 Instantaneous Landfill Surface Emissions Monitoring Exceedance and Monitoring Logs (NSPS/BAAQMD 8-34)

**2019 QUARTER**: 4

**INITIAL MONITORING PERFORMED BY:** RES and S. Johnson **FOLLOW-UP MONITORING PERFORMED BY:** S. Johnson

Initial	Monitoring	Event		Corrective Action	1st 10	oday Follo	w-Up	1st 30	)-day Follo	w-Up	
Flag	Monitoring	Reading	Repair	Action	Monitoring	No Exced.	Exced.	Monitoring	No Exced.	Exced.	
Number	Date	ppm	Date	Taken	Date	<500 ppm	>500 ppm	Date	<500 ppm	>500 ppm	Comments
O41	11/5/2019	3,000	11/6/2019	Increased BECS/ Vacuum/ Re-Applied Cover and Compact	11/14/2019	9		12/4/2019	32		Well 3
O42	11/5/2019	3,500	11/6/2019	Increased BECS/ Vacuum/ Re-Applied Cover and Compact	11/14/2019	60		12/4/2019	3		Well 219
O61	11/5/2019	4,700	11/6/2019	Re-Applied Cover/ Compact/ Watered	11/14/2019	106		12/4/2019	94		Surface

## Table A.3 Instantaneous Landfill Surface Emissions Monitoring Exceedance and Monitoring Logs (AB-32)

**2019 QUARTER**: 4

**INITIAL MONITORING PERFORMED BY:** RES and S. Johnson **FOLLOW-UP MONITORING PERFORMED BY:** S. Johnson

Initial	Monitoring	Event	1st Re-m	1st Re-mon Event - 10 Days			non Event	- 10 Days	
Flag Number	Monitoring Date	Reading ppm	Monitoring Date	No Exced. <500 ppm	Exced. >500 ppm	Monitoring Date	No Exced. <500 ppm	Exced. >500 ppm	Comments
041	11/5/2019	3,000	11/14/2019	9	000 pp	2410	000 pp	осо рр	Well 3
O42	11/5/2019	3,500	11/14/2019	60					Well 219
O61	11/5/2019	4,700	11/14/2019	106					Surface


# Table A.4 Instantaneous Landfill Surface Emissions Monitoring Areas of Concern Greater than 200 ppmv

**2019 QUARTER**: 4


INITIAL MONITORING PERFORMED BY: RES

FOLLOW-UP MONITORING PERFORMED BY: S. Johnson

Initial	Monitoring	Event	Re-moi	n Event						
Flag	Monitoring	Reading	Monitoring Reading		Comments					
Number	Date	ppm	Date	ppm						
	No 200-499 ppmv locations									



0 .50



D (2)

## Orange Flag Landfill Surface Emissions Monitoring Exceedances and Monitoring Log

Site: RED WOOD

Quarter / \	rear:	4+201	9	i											
Technician	1:	LEIShn		-											
Instrumen	t;	+UA 100	D							-			Page	of	Page
Calibration	Standard:	500					A								
	Initial Mo	onitoring Event		Flori D. 1							. 40				
Flag	Grid	Field Reading	Date	First Re-Monitoring Event - 10 Days  Date No Excd. Excd.		Second Re	-Monitoring Eve	ent - 10 Days	30-Day Follow-up Monitoring						
Number	Number	(ppm)	Monitored	Monitored		Excd.	Date	No Excd.	Excd.	Date	No Excd.	Excd.	Co	mments	
0-4/	200	3,000	11-5-19	Monitored	<500 ppm	>500 ppm	Monitored	<500 ppm	>500 ppm	Monitored	<500 ppm	>500 ppm	1		
0-42	89	3,500	1									оло ррш	75275		
0-61		4,700	1										WE113	C2	
0-		7,100	V										WE1/2	19	
0-			I = I II										SURFRE	ساح	
0-			1												
D-															
). ).															
D-		,				-									
)-			-												
)-														_	
)-															
)-					-			1							
)-							1-5-37								
)-	-														
)-			L		Let 17										
)_						- A									
-			. = 3												
					4	-									
														_	-
	- 167											-			
										V					
-															

Personnel:	LEISHWADE	ERNEST RERING	62
	ARRIVERJONES	Authory Pina	scfA
	AARONALBBIRE		
Date: <u>//</u> -	5-/9 Instrument Us	ed: <u>+UA1000</u>	Grid Spacing:ファ′
Temperatu	re: <u>39</u> Precip:	O Upwind BG:	1.6 Downwind BG: 2.2

GRID ID	STAFF	START	STOP	тос	WII	ND INFOR	MATION	DEMARKS
	INITIALS	TIME	TIME	PPM	AVG SPEED	MAX. SPEED	DIRECTION 16 POINT	REMARKS
161	LW	0545	0600	11	1	2	13	
176	AT	0545	0600	14		N	73	
184	AM	0545	0600	16	1	2	1/1	
190	en	0545	0600	14		2	1)	
196	AP	0545	0600	22	1	2	13	
201	LW	0600	0615	31	1	2	12	
205	AT	2600	0615	18		2	17	
206	AM	0600	0615	24		2	11	
282	ER	0600	0615	20		2	2	
197	AD	0600	0615	36	)	2	12	
198	LW	0615	0630	29	1	2	12	
191	AT	0615	0630	34		2	12	
192	AM	0615	0630	2.2		7	11	
185	AR	0615	0630	46		2	12	
186	AP	0615	0630	41	1	2	12	
177	LW	0630	0645	56	1	2	11	
178	AS	0630	0645	79		2	11	
127	An	0630	0645	24		7	1/	
128	せれ	0630	0645	39		2		
116	AD	0630	0695	46	1	2	11	
117	LW	0645	0700	34	1	2	12	
105	AT	0645	000	30		7.	12	
106	Am	0645	0)00	25	1	7	12	
95	En	0695	0)00	18	1	7	12	
96	AP	0645	0700	14	1	2	12	
83	22	0700	0715	29		2	12	
84	AT	0700	0>15	)>		7	11	
85	An	0000	2/0	15		0	12	
86	370	0700	0)15	12		2	12	
87	Ap	0>00	22/0	16		2	12	*

Attach Calibration Sheet

Attach site map showing grid ID

Page \_\_/\_ of \_\_\_\_

Personnel: LEISHWADE	LANEST REMAIN
ANTIENTONES	ARTRING PERACTA
AARON MCBRIDE	
Date: 11-5-19 Instrument Use	ed: <u>+vA 1000</u> Grid Spacing: <u>25'</u>
Temperature: 47 Precip: 6	Upwind BG: 1.6 Downwind BG: 2.2

GRID ID	STAFF	START	STOP	тос	WII	ND INFOR	MATION	DEMARKS
	INITIALS	TIME	TIME	PPM	AVG SPEED	MAX. SPEED	DIRECTION 16 POINT	REMARKS
97	Lw	0715	0730	35	1	2	9	
98	AT	0715	6>70	21		1	0	
107	As	0715	0770	30		2	(V)	-
108	žΛ	0715	0770	64		1	q	
118	AP	0715	0770	60	)	2	9'	
119	2 w	0730	6745	47	)	人	9	
129	An	0730	0745	32	1	2	9	
100	17m	0730	0745	40	E 57 V.	2	9	
138	in	0730	0745	29		2	9	
139	AP	0730	0745	58	1	2	9	
147	Lw	0748	0800	72	1	2	9	
148	AA	0)45	0800	48		2	g	
155	in	0745	2800	84		7	9	
156	en	0)45	0809	70		1	Ó	
164	Ap	0745	0800	65	1	2	91	
165	LW	0800	0815	114	1	2	11	
172	20	0800	0815	49		7		
173	Da	0800	08/5	55		7		
175	on	0800	0815	74		1		
180	1910	0800	0815	99	1	2	11	
187	2W	0815	0830	61	1	2	17	
188	Ap	0815	6830	38		2	11	
193	An	0815	0878	5)		+		
194	5N	2818	0830	2>		1		
199	AP	0815	6638	83	1	2	11	
200	LW	0830	0845	3,000		2	12	WE17 3
203	AT	0838	0845	45		2	12	
204		0830	0845	71		2	12	
207		0838	2745	34	1	2	12	
208	4	0870	0845	60	1	2	10	

Attach Calibration Sheet Attach site map showing grid ID

Page 2 of 2

Personnel: LEISHWADE AND, EN, TONES	Enrostrennoz
AMONACBANZ	ANTRING PERALLA
Date: 11-5~19 Instrument l	Used: 40 A 600 Grid Spacing: 25
Temperature: 45 Precip: _	Upwind BG: 1.6 Downwind BG: 2.2

GRID ID	STAFF	START	STOP	тос	ııw	ND INFOR	MATION	REMARKS
	INITIALS	TIME	TIME	PPM	AVG SPEED	MAX. SPEED	DIRECTION 16 POINT	REMARKS
195	LW	0845	0900	24	1	2	12	
189	AT	0845	0500	37		2	11	
181	Am	0845	0900	20	1	7	12	
182	EN	1380	0980	41	F 1813	2	1	
183	AP	1845	0900	36	1	1	12	
174	LW	0960	8915	24	1	2	9	
175	AD	8560	0915	57		2	9	
166	20	0900	0915	42		2	9	
167	En	0900	0815	54		2	9	
157	Ap	0500	0915	39	1	2	9	
158	LW	0915	0930	74	18	2	9	
149	Ar	0915	0930	96		2	9	
150	Ain	0915	0570	102		2	g	
40	on	0915	0831	35		7	9	
141	AP	0515	8539	22	1	12	9	
131	LW	0930	0945	9>	1	2	9	
32	AT	0530	0545	29		2	9	
20	An	0830	0545	38		7	9	
21	en	0830	0995	46		2	ėj	
109	NP	0930	8945	52	1	2	9	
110	LW	0945	1000	38	1	2	1/2	
79	AT	0945	1000	41		2	1/2	
60	AM	0545	1000	30		7	1	
88	En	0945	1000	61		7	ll	
89	AD	0545	1000	3,500	1	2	16	WE11 219
76	LW	1000	1015	59	7	2	7	
77	AT	1000	1015	64		1		
70	Dry	1000	10/5	8)		4		
77	on	1000	1015	53	- 11	2		
54	AP	1000	1015	28	1	)	1	

Attach Calibration Sheet Attach site map showing grid ID

Personnel: 6515 h WADE	onnest Renigez
ARRIEN TONES ARREN MCDRIDE	Articly porsett
Date: 12-5-19 Instrument Us	ed: 土vみ1000 Grid Spacing: Z 5 /
Temperature: Precip:	Upwind BG: /- 6 Downwind BG: Z-Z

GRID ID	STAFF	START	STOP	тос	WIN	ND INFOR	NOITAN	DEMARKS
	INITIALS	1	TIME	TIME PPM	AVG SPEED	MAX. SPEED	DIRECTION 16 POINT	REMARKS
65	Lw	1015	1830	31		7	1	
58	Ar	1015	1030	27		2	1	
53	Am	1015	1030	40	1	2	Ì	
48	EN	1075	1870	29	1	1		
43	AP	1815	1030	26	1	2		
38	LW	1030	1045	181	1	Z	1	
33	AT	1030	1645	45		2		
28	Am	1030	1045	62	1	7		
19	EN	1030	1645	25		1		
7	AP	1030	1845	18	1	2	1	
4	CW	1045	1100	16	9	2	j	
1	AT	1045	1100	11		4	1	
8	An	1045	1100	75		1	)	
11	EN	1045	1100	94		2	Ĵ	
12	AP	1045	1100	58	1	2	3	
15	LW	7100	1115	4,700		2	4	SUR FACE
16	AD	1120	1115	66		2	9	
20	An	1100	1.115	55		2	9	
21	in	1/00	1115	72		7	4	
24	AP	1100	1115	146		2	4	
25	LW	1115	1130	58	1	2	Ÿ	
29	RO	1115	1130	66		2	4.	
30	An	1115	1130	47		2	9	
34	25/	1115	1130	135	1	2	4	
35	AP	1115	1170	8 >	12	_	1	
39	Lw	1130	1145	49	1	7	4	
40	AT	1130	1145	58		2	4	
44	An	1130	1145	67		7	4	
45	on	1130	1145	38		2	9	
19	AP	1130	1145	55	11	2	9	

Attach Calibration Sheet Attach site map showing grid ID

Page \_\_\_\_\_\_ of \_\_\_\_\_

Personnel: LEIS 2 Who E	ERNESI Ren. Re	T	
A ANON MEBRIDE			
Date: 11-5-19 Instrument Used	: +VA1060	Grid Spacing: 25/	
Temperature: 62 Precip:	Upwind BG: _	1-6 Downwind BG: 2	, Z

GRID ID	STAFF	START	STOP	TOC	WII	ND INFOR	NOITAM	DEMARKS
	INITIALS	TIME	TIME	PPM	AVG SPEED	MAX. SPEED	DIRECTION 16 POINT	REMARKS
50	LW	1145	1200	29	1	2	J	
54	AT	1145	1200	70		2	1	
55	An	11.45	1200	46		1	3	
59	ET	1145	1200	52		2	3	
60	AD	1145	1200	40	1	Ĺ	3	
66	LW	1200	1215	3 Z	1	2	1	
67	AT	1200	1215	71	1	7	j	
72	An	1200	1215	48		2	3	
73	2n	1200	1215	34		7	3	
28	AP	1200	1215	51	1	2	3	
79	LW	1215	1230	78	1	2	4	
90	Ar	1215	1270	64		2	4	
91	Am	1215	1230	81		2	4	
101	5N	1215	1250	42	1	2	4	
102	Ap	1215	1230	59	1	2	4	
117	LW	1230	1245	77	1	2	4	
112	AT	1270	1245	45		2	9	
22	20	1230	1245	61		2	9	
123	en	1830	1245	57		2	9	
33	AP	1232	1245	38		2	9	
134	LW	1245	1300	26	1	2	9	
142	AD	1245	1300	34		2	14	
43	Am	1245	1300	49		2	9	
51	En	1245	1300	28		2	9	
52	AD	1245	1700	32	1	2	9	
59	LW	1300	1315	46	-1	2	Ý	
60	15	1300	1325	21		2	4	
68	Dan	1300	135	27	- i	2	4	
69	570	1300	1315	15	- 1	2	9	
44	AND	1300	1315	3>	1	2	9	

Attach Calibration Sheet Attach site map showing grid ID

Page  $_{\_}^{\mathcal{S}}$  of  $_{\_}^{>}$ 

Personnel: LEISH WADE	STUESL REAINGZ
ARRIEN JONES ARREN MCBRIDE	Anthony peracta
Date: 11-5-19 Instrument Use	ed:Grid Spacing:
Temperature: <u>6</u>	Upwind BG: 1.6 Downwind BG: 2, 7

GRID ID	STAFF	START	STOP	тос	WII	ND INFOR	MATION	REMARKS
	INITIALS	TIME	TIME	PPM	AVG SPEED	MAX. SPEED	DIRECTION 16 POINT	KEMAKKS
135	641	1315	1330	125	1	2	4	
124	AT	1511	1330	119		2	4	
125	AM	1315	1330	127	1	1	4	
126	EN	1315	1330	145		2	y	
113	AD	1315	1330	22		L	4	
114	in	1330	1345	160	1	2	14	
115	AT	1330	1345	137		7	4	
103	Am	1330	1345	122		1	Ÿ	
104	EN	1330	1345	135		7	4	
92	AP	1330	1345	27		2	4	
93	LW	1345	1400	24	7	2	1	
94	AT	1345	1400	31		4	7	
80	An	1345	1400	25		7	3	
81	EN	1345	1460	16		2	2	
82	AP	1345	1400	30		2	3	
>4	LW	1400	1415	2.2	7	2	9	
75	AT	1400	1415	19		ol	9.	
58	An	1.400	1415	24		2	9	
69	EN	1400	1415	17		7	4	
61	AP	1400	1415	26	1	2	9	
62	LW	1415	1470	31		2	Ĵ	
53	AD	1415	1430	2.1/	1	2	3	
56	An	1415	1430	78		7	J	
5>	en	1415	1430	31		7	C	
57	AP	1415	1430	29	1	2	3	
72	LW.	1430	1.445	20			4	
16	AT	1430	1445	34		2	4	
45	10	1430	1445	2)		2	9.	
41	en	1430	1445	45		1	9	
1/2	100	1430	1445	36		2	4	

Attach Calibration Sheet Attach site map showing grid ID

Page <u>6</u> of <u>></u>

Personnel: 1515 h WADE ARRIEN JONES AARO WA CBRIDE	Anthony penecha
Date: _//-5-/9_ Instrument Use	ed: 4047000 Grid Spacing: 25'
Temperature: _ 69 Precip: 0	Upwind BG: / 6 Downwind BG: 7.7.

GRID ID	STAFF	START	STOP	тос	WI	ND INFOR	MATION	DEMARKS
	INITIALS	TIME	TIME	PPM	AVG SPEED	MAX. SPEED	DIRECTION 16 POINT	REMARKS
36	LW	1445	1500	28	1	1	4	
37	AT	1445	1500	34	9	12	9	
31	Any	1445	1500	19		2	4	
32	ER	1445	1500	22		2	4	
26	AP	1445	1560	47	1	2	4	
2)	6m	1500	1515	18		2	17:	
22	AT	1500	1515	26		2	)7	
23	10	1500	1515	45		2	3	
つつ	EN	1500	1515	22		2	3	
18	AP	1500	1575	15		4	3	
13	LW	1515	1530	27		2	3	
14	Ar	1515	1570	34		2	3	
9	AM	1515	1530	18		2	3	
10	20	1515	1530	15		2	\$	
5'	AP	1515	1530	1)		2	3	
6	LW	1530	1545	11		2	3	
2	AT	1530	151/5	14	1	2	3	
3	AM	1530	1515	16	l	2	7	
						1		
					-			

Attach Calibration Sheet Attach site map showing grid ID

Page \_\_\_\_\_ of \_\_\_\_\_

emperat	:ure:	Pre	cip:	Up	wind BG:		Downv	vind BG:
GRID ID	STAFF	START	STOP	тос	WIN	ND INFORM	MATION	REMARKS
	INITIALS	TIME	TIME	PPM	AVG SPEED	MAX. SPEED	DIRECTION 16 POINT	KEMAKKU
136								Active - + Ra
145								)
153								1
162								
170					4			
17/					4			
163								-
146								1
37								
					1			-
		- 1						
						- 1		
30								

Attach Calibration Sheet Attach site map showing grid ID

Page \_\_\_\_\_ of \_\_\_\_

#### **Attachment B**

Integrated Surface Emission Monitoring Event Records

# Table B.1 Integrated Landfill Surface Monitoring Exceedances and Monitoring Log

**2019 QUARTER**: 4


INITIAL MONITORING PERFORMED BY: RES

FOLLOW-UP MONITORING PERFORMED BY: S. Johnson

LANDFILL NAME: Redwood Landfill, Inc.

Initial	Monitoring	Event	1st Re-m	on Event -	10 Days	2nd Re-n	non Event	- 10 Days	
Exceedance	Monitoring	Reading	Monitoring	No Exced.	No Exced.	Monitoring	No Exced.	No Exced.	
Grid ID No.	Date	ppm	Date	<25 ppm	>25 ppm	Date	<25 ppm	>25 ppm	Comments

No Exceedances



- 140 H

Personnel: 6515 hwART

LEIS LWADE ENVES LACAIRET

ARRIENZONES ANTHONY PERCETA

Cal. Gas Exp. Date: 9-21-20

Date: 11-4-19 Instrument Used: +v A 1000 Grid Spacing: 25'

Temperature: 65 Precip: Dupwind BG: 1.6 Downwind BG: 2-2

GRID	STAFF	START	STOP	тос	WIN	ND INFOR	RMATION	REMARKS
ID	INITIALS	TIME	TIME	PPM	AVG SPEED	MAX. SPEED	DIRECTION 16 POINT	KLMAKKS
161	LW	1305	1330	4.22	1	2	1/	
176	AJ	1305	1300	4.10	4	2	11	
184	AM	1305	1330	3-65	l	1	l)	
150	ER	1305	1330	4.21		2	11	
196	AD	1305	1330	5.16	1	X	11	
201	Lw	1330	1355	4.92	1	2	1/	
205	AT	1330	1355	4,50		7	LI .	
206	An	1300	1322	3-79		2		
202	EN	1330	1355	4.24		7		
197	AP	1330	1355	5-18	1	2	11	
198	LW	1355	1420	5-27		2	11	
151	15	1355	1420	4.82		2		
192	Am	1355	1420	5.0 b		2	li l	
185	En	1355	1420	4-97		2	11	
186	19	1385	1420	5-40	)	d	11	
1>>	LW	1420	1445	8.12	1	2	12	
178	AT	1420	1445	9-46		2	12	
127	An	1420	1445	6.84		2	12	
128	AR	1420	1445	6,20		d	12	
116	10	1420	14115	5-52		2	12	
117	22	1445	1510	5.11	1	2	12	
105	AT	1445	1510	5.41		2	L I	
106	An	1445	1510	4.65		1	12	
95	en	1445	1510	4,29		2	12	
96	Ap	1445	1510	5,13		2	12	
83	LW	1510	1535	4.80	7	2	12	
84	40	1510	1505	4-16	i	2	12	
85	An	1510	1535	4-43		d	1	
86	ER	1510	1535	3-97		2	12	
8>	AP	1510	1535	4.19		2	12	

Attach Calibration Sheet

Attach site map showing grid ID

Page \_\_\_\_\_\_\_ of \_\_\_\_\_\_

Personnel:	CEIC LWADE	ERNOST REMINEZ	
	ARRICA JONES	ANTRONY PERSCH	A
	AARON ACBRIOE		Cal. Gas Exp. Date: <u>9-21-20</u>
Date: _/_	1-4-19 Instrument	Used: +VA1200	_ Grid Spacing: _ ヱゞ゚
Tompera	ture: 6.5 Precin:	(2) Unwind BC:	/ 6 Downwind BG: 7.7

GRID	STAFF	START	STOP	тос	WIN	ND INFOR	MATION	REMARKS
ID	INITIALS	TIME	TIME	PPM	AVG SPEED	MAX. SPEED	DIRECTION 16 POINT	KENAKKS
97	Lw	1535	1600	5-38	1	2	12	
98	AT	1535	1600	4.72		4	14	
107	AM	1535	1600	4-60		7	1	
108	ER	1535	1600	6.13		1	12	
118	AP	1575	1600	5.79	l	1	12	
119	LW	1800	1625	5.45		X	1	
129	AT	1600	1625	7.28		2	12	
130	AM	1400	1625	6.42		7	12	
138	en	1600	1625	5-17		2	12	
139	AP	1600	1625	5.44	1	2	12	
147	LW	1625	1650	5.82		2	1/2	
148	AT	1675	1650	6.13		7	1	
155	An	1625	1650	4.96		7	12	
156	En	1625	1650	5.30		7	12	
164	AP	1625	1650	5.15		1	12	
				-				

Attach Calibration Sheet
Attach site map showing grid ID

Page \_ \_ \_ of \_ \_ \_

te: <u>//</u>	-4-19	Instrume	nt Used: _					p. Date:
			d BG:					
GRID	STAFF	START	STOP	тос	WIN	ID INFOR	MATION	REMARK
ID	INITIALS	TIME	TIME	PPM	AVG SPEED	MAX. SPEED	DIRECTION 16 POINT	
36					1			Active-ti
45								
53								
62	4							
70	,							
3>								
46								
54								
63								
7/								¥
	*							
								1
			ļ-					
							2	

Attach Calibration Sheet Attach site map showing grid ID

Page \_\_\_\_\_ of \_\_\_\_

Personnel: LEISHWAOF	ERNEST RAMPER	
ARRIENTONDS	ANTHORY PERACTA	
AARON MCBRIDE		Cal. Gas Exp. Date: <u>9-2/-20</u>
Date: //-5-79 Instrumer	nt Used:Gr	rid Spacing: 25/
Temperature: 70 Precing	O Unwind BG: //6	Downwind BG: 7-7

GRID STA	STAFF	START	STOP	тос	WII	ND INFOR	RMATION	REMARKS
ID	INITIALS	TIME	TIME	PPM	AVG SPEED	MAX. SPEED	DIRECTION 16 POINT	KLMAKKS
165	LW	1555	1620	8.64	1	2	1/	
172	AT	1515	1620	9.12		1	1)	
173	AM	1555	1620	8-28		2	U	
179	ER	1555	1620	6.87		2	1/	
180	AP	1555	1620	7.35	1	2	11	
/87	LW	1620	1645	6.92	1	2	11	
188	AT	1620	1645	7-35	t,	2	i)	
193	An	1620	1845	6.80	1	1	11	
194	ER	1620	1645	8.75		1	H	
199	AP	1620	1645	7.42		2	11	
200	LW	1645	1710	6.16	1	2	11	
203	AT	1845	1710	5.48	Į.	2		
204	An	1645	1710	5-21	1	7	11	
205	ER	1645	1710	4.54		4	5 L)	
208	Ap	1645	1710	4.79	1	d	11	
195	1 W	1710	1735	5.86	1	2	15	
189	AT	1710	1775	5.22		2	15	
187	An	1710	1735	6-14	)	2	15	
182	ET.	1710	1735	5-31		12	15	
183	AD	1710	1725	5.66	1	d	15	
-			14					

Attach Calibration Sheet Attach site map showing grid ID

Page \_\_\_/\_ of \_\_/\_\_

Personnel: L&is h wADE ARRIVET TONES ERNESL REMINET

ANTON MCBRIDE ANTHONY PERACET Cal. Gas Exp. Date: <u>9-2/-26</u>

Date: 11-6-19 Instrument Used: LUA1000 Grid Spacing: 25'

Temperature: 40 Precip: 0 Upwind BG: 1.6 Downwind BG: 2.2

GRID	STAFF	START	START STOP	тос	WIN	ID INFOR	MATION	REMARKS
ID	INITIALS	TIME	TIME	PPM	AVG SPEED	MAX. SPEED	DIRECTION 16 POINT	REMARKS
174	LW	0545	0610	7.12	1	7	7	
175	AT	0545	0610	9,14		2	9	
166	AM	0545	0610	6.57	1	7	9	
167	5 N	0545	0610	7-14		7	q	
157	AP	0545	2610	7-04	1	1	9	
158	LW	0610	0635	10.28	1	2	9	
149	Ar	0610	0635	13.67		2	4	
150	100	0610	0675	15-54		7	4 -	
140	EN	0620	0635	6.89	1	2	4	
147	AP	0610	0635	6.13	l	2	4	
131	LW	0635	0700	5.95	1	2	16	
132	AT	0675	0700	6-07		2	16	
120	An	0675	0)00	6.45		17	16	
121	en	0671	0)00	7-22		12	16.	
109	Ap	0675	0700	5.40	1	2	16	
110	LW	0700	0725	6-58	1	2	9	
99	AT	0700	0725	617		3	9	
100	12	0700	0725	7.08		1	g	
88	on	0700	0725	6.94		4	Ÿ	
89	Ap	5700	0725	7-12	1	2	9	
>6	LW	0725	0750	8.19	1	2	9	
フフ	NA	0725	0750	7.23	1	2	g	
70	Ans	0)25	0229	7.05		7	1 1	
>1	En	0725	0750	6.82		7	9	
64	AP	0>25	0750	5-20		2	9	
65	LW	0750	0815	6-89	1	2	4	
58	AT	6750	57.80	6.94		2	U .	
53	An	0)50	0815	7.25		7		
48	en	0)50	0815	6-81		2	W.	
43	AD	0)50	0815	6-21	1	2	1/	

Attach Calibration Sheet Attach site map showing grid ID

Page \_\_/\_ of \_\_\_\_\_

Personnel: Leis Lwar	ERNESL RAMINER		
ARRIVEN JOLES	Anthony penech	N	
AARUN MCBRPE		Cal. Gas Ex	кр. Date: <u>9-21-</u> 20
Date: <u>//- 6 ~ / 9</u> Instrument	Used: + VA 1000	_ Grid Spacing: _	25'
Temperature: 4 \$ Precip:	O Unwind BG:	1.6 Downwin	d BG: 2,7

GRID	STAFF	STAFF START	STOP TOC	WIN	ID INFOR	RMATION	REMARKS	
ID	INITIALS	TIME	TIME	PPM	AVG SPEED	MAX. SPEED	DIRECTION 16 POINT	1121111110
38	LW	0815	0840	7.45	1.	d	12	
73	15	0815	0840	6.92		2	17	
28	An	0415	0840	8.39		2	17	
19	en	0815	0849	3.78		2	12	
>	Ap	07/5	0840	3.51		2	12	
4	LW	0840	0905	37.28	1	2	12	
1	Ar	0840	0905	4,65		2	12	
8	10	0440	0505	5-12		2	12	
17	En	0840	0905	4.8/		2	12	
12	AN	0840	0905	4.68	1	1	12	
15	6w	0905	0530	5.2>	1	2	12	
16	17	0905	0930	5.80		1	12	
20	1000	0505	0530	7.54		2	12	
21	EN	0505	0930	13.10		2	12	
24	AP	0885	0920	20.65	1	1	12	
2.5	62	0970	0955	19-13	1	2	11	
29	AT	0530	0955	15-71		2	12	
30	An	0570	0555	11-42		4	14	
34	on	0570	8555	5-88	1	2	12	
35	AP	0530	0955	8-27		2	12	
39	LW	0955	1020	2-82	1	2	90	
40	AT	0955	1020	5.39		2	l	
44	An	2522	1820	5.36		2	l y	
45	EN	0955	1020	16-55		7	9	
49	AP	0555	1020	6,15	1	d	9	
50	2nd	1020	1045	2-69	1	2	12	
54	Ar	1020	1045	5.75		3	12	
55	An	1020	1045	5,12		d	12	
55	3n	1020	1845	6.31		d	12	
60	Ap	1020	1845	5-47	1	2	12	

Attach Calibration Sheet Attach site map showing grid ID

Page \_\_\_\_\_\_ of \_\_\_\_\_

Personnel: LEIG & WADE ENNES L RAN, NOTE

ARN, EN JONES ANTHONY PERSULA

ANTHONY MERCIOE

Cal. Gas Exp. Date: 9-21-20

Date: 11-6-19 Instrument Used: +VA1000 Grid Spacing: ZS

Temperature: 52 Precip: 0 Upwind BG: 1.6 Downwind BG: 2.2

GRID	STAFF	START	STOP	тос	MIM	ND INFOR	RMATION	REMARKS
ID	INITIALS	TIME	TIME	PPM	AVG SPEED	MAX. SPEED	DIRECTION 16 POINT	KEMAKKS
66	Lw	1045	1110	5.84		2	12	
67	AT	1045	1110	6.12	1	2	12	
7 2	AM	1845	1110	5.56	1	7	12	
73	un	1045	1110	5.12		1	12	
78	AP	1045	1110	5.74	1	1	12	
79	LW	1110	1135	6.19	1	2	9.	
90	Ar	1110	1135	6.57		2	9	
91	An	1110	1175	5.43	0	2	9.	
101	en	1110	1135	6.78		2	9	
102	AP	1110	1125	5-44		d	9	
111	LW	1135	1200	7.39	1	2	11	
112	AT	1/35	1200	5.82		12	12	
122	Am	1175	1200	5.26		1	12	
123	on	1135	1200	8.64		2	12	
133	Ap	1135	1200	7.79	1	2	12	
134	LW	1200	1225	6.55	1	2	11	
142	AT	1200	1225	5.78		2	II	
143	100	1200	1225	7.71		d	12	
151	En	1200	12.25	5.65		2	17	
152	AP	1200	1225	7.80	1	2	12	
159	LW	1225	1250	5.39	1	2	12	
160	AT	1225	1250	5.12		2	12	
168	Drs	1725	1250	5.07		4	12	
169	en	1225	1250	6.13		2	12	
144	ap	1225	1250	6.5>	1	d	12	
135	LW	1250	1315	8.76		2	12	
124	Ar	1250	1315	7-15		2	7	
125	As	1250	1315	10.11		2	7	
126	32	1250	1315	9.75		2	12	
113	A-p	1250	1315	6-40		2	12	

Attach Calibration Sheet Attach site map showing grid ID

Page 3 of 5

Personnel:	LEISH WARE	ERNEUL REMIRE	
	ARRIVED TONES	ANTHONY ponacth	
	ARROW MERRINE		Cal. Gas Exp. Date: 9-2/-20
Date: 🔟	1-6~19 Instrument Us	ed: <u> </u>	rid Spacing: 25′
Temnera	ture: 60 Precin:	O Upwind BG: ()	Pownwind RG: 2 2

GRID	STAFF	START	STOP	тос	WIN	ID INFOR	RMATION	REMARKS
ID	INITIALS	TIME	TIME	PPM	AVG SPEED	MAX. SPEED	DIRECTION 16 POINT	KLMAKKS
114	LW	1315	1340	11.45	1	2	D	
115	Ar	1315	1740	13.77	1	2	10	
103	AM	1315	1340	8.65	1	2	lo	
104	5R	1315	1340	5.39		1	10	
92	A-P	1315	1340	5.12	1	L	10	
93	2W	1340	1405	6.14		2	b	
94	Ar	1740	1405	5.51	1"	2	b	
80	An	1340	1405	5.80		7	10	
81	きれ	1740	1405	4.65		2	10	
82	AP	1340	1485	5.18	- 1	2	10	
74	LW	1405	1430	5.37	1	2	U	
>5	AT	1405	1470	6.11		4		
68	AM	1485	1470	5.42		4		
69	in	14.65	1430	5-15		2		
61	AP	1405	1430	5.50	1	2	11	
62	LW	1470	1455	5.44	1	2	11	
63	AT	1430	1455	5.17		2		
56	An	1470	1855	4.20		2		
5>	En	1430	1455	5.89		2		
51	AD	1430	1455	6-17		2	11	
52	ZW	1455	1520	3-25	1	d	11	
46	AT	1455	1520	4-77		7		
45	13	1455	1520	3.22		2		
4)	GN	1455	1520	4.50		2		
42	AD	1455	1570	3.26		7	W.	
36	1.2/	1520	1545	4.77		2		
37	AT	1520	1545	5.16		4		
3/	Am	1520	1545	4.21		4		
32	on	1520	1545	3.45		2		
26	AP	1528	1545	4.18		d	11	

Attach Calibration Sheet Attach site map showing grid ID

Page 4 of 5

Personnel: LEIS 4 WATE	ERNETL RENIREZ	
ARRIVER JONES	ANThony pencula	
AAMIN MCBRIDE		Cal. Gas Exp. Date: 9-21-26
Date: 11-6-19 Instrument Us	sed: <u>\langle UA 1000</u> Grid	d Spacing:
Temperature: 64 Precip:	Upwind BG: / 6	Downwind BG: 2,2

GRID	STAFF	START	STOP	тос	WIN	ND INFOR	RMATION	REMARKS
ID	INITIALS	TIME	TIME	PPM	AVG SPEED	MAX. SPEED	DIRECTION 16 POINT	REMARKS
27	Lw	1545	1610	5.41	1	7	11	
22	AT	1545	1610	4.60		2		
23	An	1845	1610	4,12		2	Li	
17	EN	1545	1610	5.14		1	1/	
18	MP	1545	1610	4,79		2	H	
13	LW	1610	1635	4.52		2	ij l	
14	10	1610	1835	3.61		2	H	
9	An	1610	1635	3.20		7	ti l	
10	en	1610	1635	4.07		7	H	
5	AP	1616	1635	J.85		7	H	
6	LW	1635	1700	4.12		)	H	
2	AT	1635	1700	5.15		7	H I	
3	AM	1635	1700	4,79	1	L	11	
							3	
							1-11	
							1	
				100	1			
	-							

Attach Calibration Sheet Attach site map showing grid ID

Page  $\mathcal{S}$  of  $\mathcal{S}$ 

#### **Attachment C**

Component Leak Monitoring Event Records

#### Table C.1

#### AB-32 Component Leak Monitoring Summary of Component Leaks Greater than 500 ppmv

**2019 QUARTER**: 4

INITIAL MONITORING PERFORMED BY: RES, WM, and BAAQMD FOLLOW-UP MONITORING PERFORMED BY: S. Johnson and F. Parker

Location		Initial Monitoring	9	С	Corrective Action	10-Day Remonitoring		
Location	Date	TOC (ppmv)	Tech	Date	Description	Date	TOC (ppmv)	Tech
			No E	exceedances [	Detected			

#### Table C.2

#### BAAQMD Component Leak Monitoring Summary of Component Leaks Greater than 1,000 ppmv


**2019 QUARTER:** 4

INITIAL MONITORING PERFORMED BY: RES, WM, and BAAQMD FOLLOW-UP MONITORING PERFORMED BY: S. Johnson and F. Parker

Location	Initial Monitoring			C	orrective Action	7-Day Remonitoring					
	Date	TOC (ppmv)	Tech	Date	Description	Date	TOC (ppmv)	Tech			
No Exceedances Detected											

#### REDWOOD 3520+ ENGINE PLANT, CA





LANDFILL NAME: RED Was O

QUARTERLY LFG COMPONENT LEAK MONITORING

INSTRUMENT

FID

MAKE: Thermo Environr MODEL: TVA 1000 S/N: 1036346773

DATE OF SAMPLING: //-5-/9 TECHNICIAN: CEISA WADE


TECHNICIAN: 22134 WADE

LOCATION OF LEAK	LEAK CONCENTRATION (ppmv)	DATE OF DISCOVERY	TECHNICIAN	ACTION TAKEN TO REPAIR LEAK	DATE OF REPAIR	DATE OF ANY REQUIRED RE- MONITORING	RE-MONITORED CONCENTRATION (ppmv)
NO FUL FOR OUL ST							
-							


In the event that an exceedance is detected, please intiate corrective action and re-monitor the exceedance location within 7 days of the initial exceedance.

NOTE: Leaks over 500 ppmv methane are exceedances at any component containing landfill gas, pursuant to CARB Title 17 of California Code of Regulations Subchapter 10, Article 4, Subarticle 6, Section 95464(b)(1)(B).


NOTE: Leaks over 1,000 ppmv methane are exceedances at any component containing landfill gas, pursuant to BAAQMD Regulation 8-34-301.2.




PROJECT NO 70314













#### Attachment D


Weather Station Data




	16-POINT V	VIND DIRECTION	N INDEX	
NO NO	DIRECTION		DEGREES	
		FROM	CENTER	<u>TO</u>
16	NORTH (N)	348.8	369,0	t .1.3
1	NORTH-NORTHEAST (NNE)	011.3	022.5	033.8
2	NORTHEAST (NE)	033,8	045.0	056.3
3	EAST-NORTHEAST (ENE)	056.3	<u>067.5</u>	078.8
4	EAST (E)	078.8	090.0	101.3
5	EAST-SOUTHEAST (ESE)	101.3	112.5	123.8
6	SOUTHEAST (SE)	123.8	135.0	146.3
7	SOUTH-SOUTHEAST (SSE)	146.3	<u>157.5</u>	168.8
8	SOUTH (S)	168.8	180.0	191.3
9	SOUTH-SOUTHWEST (SSW)	191.3	202.5	213.8
10	SOUTHWEST (SW)	213.8	225.0	236.3
11	WEST-SOUTHWEST (WSW)	236.3	<u>247.</u> 5	258.8
12	WEST (W)	258.8	270.0	281.3
13	WEST-NORTHWEST (WNW)	281.3	292.5	303.8
14	NORTHWEST (NW)	30.1.8	315.0	326.3
15	NORTH-NORTHWEST (NNW)	326.3	337.5	348.8







. . .



#### Attachment E

Calibration Records

#### CALIBRATION PRECISION TEST RECORD

Date: 11/14/19

Expiration Date (3 months):  $\frac{20}{1/4}$ 

Time: - AM /3/5 PM

Instrument Make: Photouc Model: Mico FID S/N: CZKF3 40

Measurement #1:

Meter Reading for Zero Air: \_\_\_\_\_\_ ppm (a)

Meter Reading for Calibration Gas: 500, 2 ppm (b)

Measurement #2:

Meter Reading for Zero Air: \_\_\_\_\_\_ ppm (c)

Meter Reading for Calibration Gas: \_\_\_\_\_\_\_ ppm (d)

Measurement #3:

Meter Reading for Zero Air: Or 3 ppm (e)

Meter Reading for Calibration Gas: 505. / ppm (f)

Calculate Precision:

 $\frac{\{|(500) - (b)| + |(500) - (d)| + |(500) - (f)|\}}{3} \times \frac{1}{500} \times 100$ 

O.56 % (must be < than 10%)

Performed By:

#### RESPONSE TIME TEST RECORD

Date: 11/14/19 20
Expiration Date (3 months): 2/14/19

Time: \_\_\_ AM \_\_\_\_\_ PM

Instrument Make: Phetomac Model: MiroFIO S/N: CBMF340

Measurement #1:

Stabilized Reading Using Calibration Gas: 498.6 ppm 90% of the Stabilized Reading: 449.64 ppm Time to Reach 90% of Stabilized Reading after

switching from Zero Air to Calibration Gas: 3,0 seconds (a)

Measurement #2:

Stabilized Reading Using Calibration Gas:

90% of the Stabilized Reading:

Time to Reach 90% of Stabilized Reading after switching from Zero Air to Calibration Gas:

453.42 ppm

453.42 ppm

453.42 ppm

453.42 ppm

453.42 ppm

453.42 ppm

Measurement #3:

Stabilized Reading Using Calibration Gas:

90% of the Stabilized Reading:

Time to Reach 90% of Stabilized Reading after switching from Zero Air to Calibration Gas:

501.7 ppm

451,53 ppm

3.0 seconds (c)

Calculate Response Time:

 $\frac{(a) + (b) + (c)}{3} = \frac{3.33}{\text{seconds (must be less than 30 seconds)}}$ 

Performed By:

## CALIBRATION PROCEDURE AND BACKGROUND DETERMINATION REPORT

Landfill Name: Reduced Landfill Date: 11/14/19

Time: \_\_\_ AM /3/5 PM

Instrument Make: Photoure Model: MUDFIO SN: CRMF390

#### Calibration Procedure

- 1. Allow instrument to internally zero itself while introducing zero air.
- 2. Introduce the calibration gas into the probe.

Stable Reading = 500. 2 ppm

3. Adjust meter to read 500 ppm.

#### **Background Determination Procedure**

- 1. Upwind Reading (highest in 30 seconds): \_\_\_\_\_\_ ppm (a)
- 2. Downwind Reading (highest in 30 seconds): \_\_\_\_\_\_\_ ppm (b)

Calculate Background Value:

$$\frac{(a) + (b)}{2} \quad \text{Background} = \frac{0.2}{2} \text{ppm}$$

Performed By:

## CALIBRATION PROCEDURE AND BACKGROUND DETERMINATION REPORT

Landfill Name: Redwood Landfill Date: 12/4/19

Time: 08/5 AM \_\_\_ PM

Instrument Make: Photocac Model: Micro FEO S/N: LZMF340

#### Calibration Procedure

- 1. Allow instrument to internally zero itself while introducing zero air.
- 2. Introduce the calibration gas into the probe.

Stable Reading = 502.5 ppm

3. Adjust meter to read 500 ppm.

#### Background Determination Procedure

- 1. Upwind Reading (highest in 30 seconds):

  0.0 ppm (a)
- 2. Downwind Reading (highest in 30 seconds): \_\_\_\_\_\_\_ ppm (b)

Calculate Background Value:

$$\frac{(a) \div (b)}{2} \quad \text{Background} = \underbrace{0.2} \text{ppm}$$

Performed By:



LANDFILL NAME: RED WOOD		INSTRUMENT MAKE: 446RAO				
MODEL: + V A 1000	EQUIPMENT #:_			SERIAL #: 1636346773		
MONITORING DATE: //-	5-19		TIME:	0540		

#### Calibration Procedure:

Allow instrument to zero itself while introducing air.

Introduce calibration gas into the probe. Stabilized reading = 500 ppm

Adjust meter settings to read 500 ppm.

### **Background Determination Procedure**

Upwind Background Reading: (Highest in 30 seconds)	Reading:	Background Value:  (Upwind + Downwind)	
1.6 pp	n 2.2 ppm	1-9 ppm	

Background Value = 1-9 ppm

### INSTRUMENT RESPONSE TIME RECORD

Measurement #	Stabilized Reading Using Calibration Gas	90% of the Stabi Reading	lized	Time to Reach 90% of Stabilized Reading after switching from Zero Air to Calibration Gas	
	502 ppm	457	ppm	6	
#2	955 ppm	448	ppm		
#3	500 ppm	450	ppm		
	300	1+2+3)	ppiii	6	
	The Time (	3		#DIV/0!	
				Must be less than 30 seconds	

### CALIBRATION PRECISION RECORD

Calibration Gas Standard = 500 ppm

Measurement #	Meter Reading for Zero Air (A)		Meter Reading for Calibration Gas (B)		Calculate Precision [STD - (B)]	
#1	0.41	ppm	502	ppm	7	
#2	0-26	ppm	455	ppm		
#3	0-18	ppm	500	ppm	7	
Calculate Precision	[STD-B1] + [S	TD-B2] + [S			0, 20 #DIV/0	
					Must be less than 10%	

Performed By: LEISh WADE



LANDFILL NAME: REDWOOD	INSTRUMENT MAKE: + HERMO			
MODEL: 4 V A 1000 EQUIPMENT #:				
MONITORING DATE: //-5-19	TIME: 0540			

### Calibration Procedure:

Allow instrument to zero itself while introducing air.

2. Introduce calibration gas into the probe. Stabilized reading =  $\frac{$60}{}$  ppm

Adjust meter settings to read 500 ppm.

### Background Determination Procedure

Upwind Background Reading: (Highest in 30 seconds)	Downwind Background Reading: (Highest In 30 seconds)	Background Value:  (Upwind + Downwind) 2
1-6 ppm	2.2 ppm	1.9 ppm

Background Value = \_ / -9 ppm

### INSTRUMENT RESPONSE TIME RECORD

Measurement #	Stabilized Reading Using Calibration Gas		90% of the Stabil Reading	ized	Time to Reach 90% of Stabilized Reading after switching from Zero Air to Calibration Gas	
#1	491	ppm	441	ppm	7	
#2	456	ppm	447	ppm	5	
#3	500	ppm	450	ppm	5	
	Calculate Response Time	3	+2+3)		>	#DIV/0!
		_			Must be less than	30 seconds

### CALIBRATION PRECISION RECORD

Calibration Gas Standard = 500 ppm

Measurement #	Meter Reading for Zero Air (A)		Meter Reading for Calibration Gas (B)		Calculate Precision [STD - (B)]	
#1	0.34	ppm	cici	ppm	9	
#2	0.16	ppm	451	ppm	7	
#3	0.11	ppm	500	ppm	7	
Calculate Precision	[STD-B1] + [S	TD-B2] + [S	TD-B3] X 1 X 500	100	0-86 Must be less tha	#DIV/0

Performed By: Anthony percets



LANDFILL NAME: RED WOOD	INSTRUMENT MAKE: +Henro		
MODEL: +UA 1000 EQUIPMENT #:_	12 SERIAL #: 103624674/		
MONITORING DATE://- 5-19	TIME: 0540		

### Calibration Procedure:

Allow instrument to zero itself while introducing air.

2. Introduce calibration gas into the probe. Stabilized reading =  $\sqrt{60}$  ppm

Adjust meter settings to read 500 ppm.

### Background Determination Procedure

Upwind Background Reading: (Highest in 30 seconds)	Downwind Background Reading: (Highest in 30 seconds)	Background Value:  (Upwind + Downwind) 2
(-6. ppn	7,2 ppm	1 - G ppm

Background Value = 1.9 ppm

### INSTRUMENT RESPONSE TIME RECORD

Measurement#	Stabilized Reading Using Calibration Gas		90% of the Stabilized Reading		Time to Reach 90% of Stabilized Reading after switching from Zero Air to Calibration Gas	
	492	ppm	442	ppm		
#2	498	ppm	11115	ppm		
#3	Cad	200	7 7 8		5	
	Soci	ppm	450	ppm	5	
	Calculate Response	Time (14	-2+3)		5	#DIV/0!
					Must be less than	30 seconds

### CALIBRATION PRECISION RECORD

Measurement #	Meter Reading for Zero Air (A)	Meter Reading for Calibration Gas (B)	Calculate Precision [STD – (B)]
#1	0.26 ppm	462 ppm	P
#2	ppm	488 ppm	
#3	():/ <i>C</i> / ppm	500 ppm	2
Calculate Precision	[STD-B1] + [STD-B2] + [S		8 - 6 - #DIV/0! Must be less than 10%

Performed By: AARON MCBR, DE	Date/Time:	11-5-19	6650
------------------------------	------------	---------	------



LANDFILL NAME: REDWOOD	NSTRUME	ENT MAKE: +HERAD
MODEL: +UA1000 EQUIPMENT #:		SERIAL #: 1/62746775
MONITORING DATE: 11-5-19	TIME:	0540

### Calibration Procedure:

Allow instrument to zero itself while introducing air.

Introduce calibration gas into the probe. Stabilized reading = 500 ppm.
 Adjust meter settings to read 500 ppm.

### **Background Determination Procedure**

Upwind Background Reading: (Highest in 30 seconds)	Downwind Background Reading: (Highest in 30 seconds)	Background Value:  (Upwind + Downwind) 2
1.6 ppm	2, 2 ppm	1,9 ppm

Background Value = 1.9 ppm

### INSTRUMENT RESPONSE TIME RECORD

Measurement #	Stabilized Reading Using Calibration Gas  90% of the Stabilized Reading		Stabilized Reading Using Calibration Gas		Time to Reach S Stabilized Read switching from Calibration Gas	ing after Zero Air to
#1	505	ppm	455	ppm	6	
#2	493	ppm	447	ppm	1	
#3	500	ppm	450	ppm	-0	
	Calculate Response	Time (14	2+3)		Must be less than	#DIV/0!

### CALIBRATION PRECISION RECORD

Measurement#	Meter Reading for Zero Air (A)		ero Air (A) Meter Reading for Calibration Gas (B)		Calculate Precision [STD - (B)
#1	0.39	ppm	Sas	ppm	م
#2	0-23	ppm	450	ppm	
#3	0.09	ppm	500	ppm	3
Calculate Precisio	n [STD-B1] + [ST	D-B2] + [S			O - 80 #DIV

Performed By: Enwish RealPET Date/Time: 11-5-19-0590
--



LANDFILL NAME: REDWOOD		IN	STRUMENT	MAKE: AHERAO
MODEL: +UA/050 EC	QUIPMENT #:	15		SERIAL #: 1036346772
MONITORING DATE: 11-5-19			TIME:	0540

#### Calibration Procedure:

Allow instrument to zero itself while introducing air.

Introduce calibration gas into the probe. Stabilized reading = \$000
 Adjust meter settings to read 500 ppm.

### Background Determination Procedure

Upwind Background Reading: (Highest in 30 seconds)		Downwind Background Reading: (Highest in 30 seconds)		Background Value:  (Upwind + Downwind)	
1-6	ppm	2.2	ppm	1.5	ppm

Background Value = 1/9 ppm

### INSTRUMENT RESPONSE TIME RECORD

Measurement#	Stabilized Reading Using Calibration Gas	90% of the Stabilized Reading	Time to Reach 90% of Stabilized Reading after switching from Zero Air to Calibration Gas
#1	489 ppm	439 ppm	The state of the s
#2	495 ppm	445 ppm	5
#3	506 ppm	450 ppm	7
	Calculate Response Time (1	+2+3)	#DIV/0! Must be less than 30 seconds

#### CALIBRATION PRECISION RECORD

Calibration Gas Standard = 500 ppm

Measurement #	Meter Reading for Zero Air (A		ter Reading for Zero Air (A) Meter Reading for Calibration Gas (B)		Calculate Precision [STD – (B)]
#1	0.20	ppm	000	ppm	//
#2	0.64	ppm	455	ppm	
#3	0-07	ppm	500	ppm	0
Calculate Precisio	n [STD-B1] + [STD- 3	B2] + [S	TD-B3] X <u>1</u> X 500	100 1	/ - 0 6 #DIV/0! Must be less than 10%

Performed By: Arrier jouts



LANDFILL NAME: RED WOOD	0	INSTRUME	NT MAKE: HALARD
MODEL: LVA1000	EQUIPMENT #:	10	SERIAL #: 1036346773
MONITORING DATE: // - 4/	-19	TIME:	1300

#### Calibration Procedure:

1. Allow instrument to zero itself while introducing air.

2. Introduce calibration gas into the probe. Stabilized reading = 2.5 ppm

3. Adjust meter settings to read 25 ppm.

#### **Background Determination Procedure**

Upwind Background Reading: (Highest in 30 seconds)	Downwind Background Reading: (Highest in 30 seconds)	Background Value:  (Upwind + Downwind) 2		
/_6 ppm	2.2 ppm	1,9 ppm		

Background Value = 1-9 ppm

#### **INSTRUMENT RESPONSE TIME RECORD**

Measurement #	Stabilized Readi Calibration Gas	ng Using	90% of the Stabil Reading	ized	Time to Reach Stabilized Read switching from Calibration Ga	ding after Zero Air to
#1	23	ppm	20:7	ppm	6,	
#2	24	ppm	21,6	ppm	6	
#3	25	ppm	77.5	ppm	6	
	Calculate Response	Time (1-	<u>+2+3</u> )		6	#DIV/0!
					Must be less that	an 30 seconds

#### **CALIBRATION PRECISION RECORD**

Measurement #	Meter Reading for Z	ero Air (A)	Meter Reading Calibration Ga		Calculate Precision	[STD - (B)]
#1	0.25	ppm	23	ppm	2	
#2	0.16	ppm	24	ppm	1	
#3	0.11	ppm	25	ppm	0	
Calculate Precision	[STD-B1] + [	3 std-B2] + [	STD-B3] X <u>1</u> X 25	1 <u>100</u> 1	Must be less that	#DIV/0!

Performed By: LEIShwAOZ	Date/Time://-4/-19
-------------------------	--------------------



LANDFILL NAME: REDWOOD	INSTRUMENT MAKE: THERAS
MODEL: 4 1000 EQUIPMENT #:	11 SERIAL #: 1036346774
MONITORING DATE: //- 4-19	TIME:/300
Calibration Procedure:	

- 1. Allow instrument to zero itself while introducing air.
- Introduce calibration gas into the probe. Stabilized reading = 25 ppm
- 3. Adjust meter settings to read 25 ppm.

#### **Background Determination Procedure**

Reading:	Downwind Background Reading: (Highest in 30 seconds)	Background Value:  (Upwind + Downwind) 2
/16 ppm	2.2 ppm	1-9 ppm

Background Value = 1.9

#### **INSTRUMENT RESPONSE TIME RECORD**

Measurement #	Stabilized Reading L Calibration Gas	Jsing	90% of the Stabili Reading	zed	Time to Reach 9 Stabilized Readi switching from 2 Calibration Gas	ng after
#1	24	ppm	21,6	ppm	7	
#2	25	ppm	22.5	ppm	7	
#3	25	ppm	27.5	ppm	7	
	Calculate Response Tin	ne ( <u>1</u> -	+2+3)		7	#DIV/0!
					Must be less than	30 seconds

#### CALIBRATION PRECISION RECORD

Measurement #	Meter Reading for Z	его Air (A)	Meter Reading Calibration Ga		Calculate Precision	[STD - (B)]
#1	0.31	ppm	24	ppm	/	
#2	0-19	ppm	25	ppm	D	
#3	0.14	ppm	25	ppm	0	
Calculate Precision	STD-B1] + [S	3 3	STD-B3] X <u>1</u> X 25	1 100	/ - J Must be less tha	#DIV/0!

Performed By:	ANTRONY	PERELLA	Date/Time: _/ 1 - -/ 9 - /</th <th>300</th>	300
---------------	---------	---------	---	-----



LANDFILL NAME: REDW	010	INSTRUMEN	IT MAKE: +HELLO	
MODEL: 4VA1000	EQUIPMENT #:	12	SERIAL #: 103624674/	
MONITORING DATE:	4-19	TIME:	1300	

#### **Calibration Procedure:**

1. Allow instrument to zero itself while introducing air.

2. Introduce calibration gas into the probe. Stabilized reading = 25 ppm

3. Adjust meter settings to read 25 ppm.

#### **Background Determination Procedure**

Upwind Background Reading: (Highest in 30 seconds)	Downwind Background Reading: (Highest in 30 seconds)	Background Value:  (Upwind + Downwind) 2
1-6 ppm	2.2 ppm	1.9 ppm

Background Value = 19 ppm

#### INSTRUMENT RESPONSE TIME RECORD

Measurement #	Stabilized Reading Us Calibration Gas	ing	90% of the Stabi Reading	lized	Time to Reach S Stabilized Read switching from Calibration Gas	ing after Zero Air to
#1	23	ppm	20.5	ppm	5	
#2	25	ppm	22.5	ppm	5	
#3	Zs	ppm	22.5	ppm	5	
	Calculate Response Time	( <u>1</u> 3	+2+3)		5	#DIV/0!
					Must be less than	n 30 seconds

#### **CALIBRATION PRECISION RECORD**

Measurement #			Meter Reading for Calibration Gas (B)		Calculate Precision [STD – (I	
#1	0.27	ppm	23	ppm	7	
#2	0.14	ppm	25	ppm	0	
#3	0-09	ppm	21	ppm	ර	
Calculate Precision	[STD-B1] + [S	TD-B2] + [\$ 3	STD-B3] X <u>1</u> 25	X <u>100</u> 1	. 2 - 6 Must be less tha	#DIV/0!

Performed By: AANOW MCBRIDE	Date/Time: 11-4-19 - 1300



LANDFILL NAME: _ IL EN WOS O		INSTRUMENT	MAKE: AHERNO
MODEL: LUA 1660	EQUIPMENT #:	13	SERIAL #: 1102746775
MONITORING DATE: 11-4#	= 19	TIME:	1700

#### Calibration Procedure:

- 1. Allow instrument to zero itself while introducing air.
- 2. Introduce calibration gas into the probe. Stabilized reading = 25 ppm
- 3. Adjust meter settings to read 25 ppm.

#### **Background Determination Procedure**

Upwind Backgr Reading: (Highest in 30 se	ding:		ground onds)	Background Va	
1-6	ppm	2-2	ppm	1.9	ppm

Background Value = \_\_/\_ S \_\_ppm

#### INSTRUMENT RESPONSE TIME RECORD

Measurement #	Stabilized Reading Using Calibration Gas	90% of the Stabil Reading	zed	Time to Reach 90% of Stabilized Reading after switching from Zero Air to Calibration Gas		
#1	Z4 ppm	21.6	ppm	6		
#2	Z 5 ppm	22,5	ppm	6		
#3	Z5 ppm	22.5	ppm	6		
	Calculate Response Time (1	+2+3)		6	#DIV/0!	
				Must be less than	30 seconds	

#### **CALIBRATION PRECISION RECORD**

Calibration Gas Standard = 25 ppm

Surement # Meter Reading for Zero Air (A) Meter Reading for Calibration Gas (B)					[STD - (B)]
0.41	ppm	24	ppm	/	
0.25	ppm	25	ppm	0	
0.18	ppm	25	ppm	0	
STD-B1] + [S	3 3 3 3 3 3 3 3 3 3 3 3 3 3 3 3 3 3 3	STD-B3] X <u>1</u> 25	1 100 1	1.3	#DIV/0!
	0.41	0.41 ppm 0.25 ppm 0.18 ppm	Calibration Ga  O.4// ppm 2.4  O.2.5 ppm 2.5  O.1.8 ppm 2.5  ISTD-B1] + [STD-B2] + [STD-B3] X 1.3	Calibration Gas (B)         O - 4//       ppm       2 4       ppm         0 - 2 5       ppm       2 5       ppm         0 - 1 8       ppm       2 5       ppm         ISTD-B1] + [STD-B2] + [STD-B3]       X 1 X 100	Calibration Gas (B)         O.4//       ppm       2.4       ppm       /         O.2.5       ppm       2.5       ppm       0         O.18       ppm       2.5       ppm       0         ISTD-B1] + [STD-B2] + [STD-B3] X 1 X 100       1.3       1.3

Performed By: FRUES - REMINEU Date/Time: 11-4-119 ~1300



CALIBRATION	PROCEDURE AN	D BACKGROUND	REPORT -	INTEGRATED

LANDFILL NAME: _ REDNOOD		INSTRUMENT MAKE: HARA 12		
MODEL: FUA 1000	EQUIPMENT #:	15	SERIAL #: 1036346772	
MONITORING DATE: //- 2/-	19	TIME;	1300	

#### **Calibration Procedure:**

- 1. Allow instrument to zero itself while introducing air.
- 2. Introduce calibration gas into the probe. Stabilized reading =  $\frac{2S}{}$  ppm
- 3. Adjust meter settings to read 25 ppm.

#### **Background Determination Procedure**

Upwind Background Reading: (Highest in 30 seconds)	Downwind Background Reading: (Highest in 30 seconds)	Background Value:  (Upwind + Downwind) 2	
1.6 ppm	2.2 ppm	1.9 ppm	

Background Value = / · 4 ppm

#### **INSTRUMENT RESPONSE TIME RECORD**

Measurement #	Stabilized Reading Using Calibration Gas	90% of the Stabilized Reading		Time to Reach 90% of Stabilized Reading after switching from Zero Air to Calibration Gas	
#1	ZY ppm	21.6	ppm	5	
#2	Z Z/ ppm	21.6	ppm	5	
#3	25 ppm	22.5	ppm	5	
	Calculate Response Time (1	<u>+2+3</u> )		5	#DIV/0!
				Must be less than	30 seconds

#### **CALIBRATION PRECISION RECORD**

Measurement #	Meter Reading for Zo			g for as (B)	Calculate Precision [STD – (B)	
#1	0-36	ppm	24	ppm	)	
#2	8.21	ppm	24	ppm	/	
#3	0-13	ppm	25	ppm	0	
Calculate Precisio	n [STD-B1] + [S	3 std-B2] + [5	STD-B3] X <u>1</u> X 25	( <u>100</u> 1	Z - 6 Must be less tha	#DIV/0!

Danfarmad D	ARRIEN JONES	D.L.T.	11 11-10	-1300
Performed By:	THE ILIVE ON NO	Date/Time:	11-4-15	1000



LANDFILL NAME: RED WOOL	7	INSTRUME	NT MAKE: + HORAD
MODEL: 4 1000	_EQUIPMENT #: _	10	SERIAL #: 1636346773
MONITORING DATE: 11-5-	15	TIME:	1550

#### **Calibration Procedure:**

1. Allow instrument to zero itself while introducing air.

2. Introduce calibration gas into the probe. Stabilized reading =  $\frac{25}{}$  ppm

3. Adjust meter settings to read 25 ppm.

#### **Background Determination Procedure**

Upwind Background Reading: (Highest in 30 seconds)	Downwind Background Reading: (Highest in 30 seconds)	Background Value:  (Upwind + Downwind) 2
/, _ ppm	2.2 ppm	1-9 ppm

Background Value = 1-9 ppm

#### INSTRUMENT RESPONSE TIME RECORD

Measurement #	Stabilized Reading Using Calibration Gas		90% of the Stabili Reading	zed	Time to Reach 90% of Stabilized Reading after switching from Zero Air to Calibration Gas	
#1	23	ppm	20.7	ppm	5	
#2	24	ppm	21.6	ppm	5	
#3	25	ppm	22.5	ppm	5	
	Calculate Response	Time ( <u>1</u>	<del>+2+3</del> )		5	#DIV/0!
					Must be less tha	in 30 seconds

#### CALIBRATION PRECISION RECORD

Measurement#	Meter Reading for 2	Meter Reading for Zero Air (A)		g for as (B)	Calculate Precision [STD - (B)]	
#1	0.39	ppm	23	ppm	2	
#2	0-26	ppm	24	ppm	1	
#3	0-15	ppm	25	ppm	ð	
Calculate Precision	[STD-B1] + [	STD-B2] + [5 3	STD-B3] X <u>1</u> X 25	1 100 1	Must be less th	#DIV/0! an 10%

Performed By: LEISHWADE	Date/Time: 17-5-19 - 1550
-------------------------	---------------------------



LANDFILL NAME: _ FED WOOK		_INSTRUME	NT MAKE: + HERAD
MODEL: +va/000	EQUIPMENT #://		SERIAL #: 1036396779
MONITORING DATE: /1-5-/	<u>, , , , , , , , , , , , , , , , , , , </u>	TIME:	1550

#### **Calibration Procedure:**

- 1. Allow instrument to zero itself while introducing air.
- 2. Introduce calibration gas into the probe. Stabilized reading = 25 ppm
- 3. Adjust meter settings to read 25 ppm.

#### **Background Determination Procedure**

Upwind Background Reading: (Highest in 30 seconds)	Downwind Background Reading: (Highest in 30 seconds)	Background Value:  (Upwind + Downwind) 2
1.6 ppm	2.2 ppm	1.9 ppm

Background Value = 1.9 ppm

#### INSTRUMENT RESPONSE TIME RECORD

Measurement #	Stabilized Reading Using Calibration Gas		90% of the Stabili Reading	zed	Time to Reach 90% of Stabilized Reading after switching from Zero Air to Calibration Gas	
#1	24	ppm	21.6	ppm	5	
#2	24	ppm	71.6	ppm	5	
#3	25	ppm	225	ppm	5	
	Calculate Response	Time ( <u>1</u> -	+2+ <u>3</u> )		S	#DIV/0!
					Must be less tha	n 30 seconds

#### **CALIBRATION PRECISION RECORD**

Measurement #	Meter Reading for Z			g for as (B)	Calculate Precision [STD – (B)]	
#1	0.25	ppm	24	ppm	/	
#2	0.16	ppm	24	ppm	/	
#3	0-09	ppm	25	ppm	7	
Calculate Precisio	n [STD-B1] + [S	3 std-B2] + [	STD-B3] X <u>1</u> 25	X <u>100</u> 1	, Z, 6 Must be less th	#DIV/0!

Performed By: <u>Aンとん。                                    </u>	pensit A	Date/Time: _//-5-/9-/550
	/	



LANDFILL NAME: 2 trovos			NSTRUMEN	NT MAKE: + HERAD
MODEL: 1000	EQUIPMENT #: _	12		SERIAL #: 103624674
MONITORING DATE: //-5-	9		_TIME:	1550

#### **Calibration Procedure:**

1. Allow instrument to zero itself while introducing air.

2. Introduce calibration gas into the probe. Stabilized reading = 25 ppm

3. Adjust meter settings to read 25 ppm.

#### **Background Determination Procedure**

Upwind Backg Reading: (Highest in 30 se		Downwind Bac Reading: (Highest in 30 se		Background Value: (Upwind + Downwing) 2	
1.6	ppm	2.2	ppm	1.9	ppm

Background Value = \_\_/-9 \_\_\_ ppm

#### INSTRUMENT RESPONSE TIME RECORD

Measurement #	Stabilized Reading Using Calibration Gas		90% of the Stabil Reading	ized	Time to Reach 90% of Stabilized Reading after switching from Zero Air to Calibration Gas	
#1	24	ppm	21.6	ppm	7	
#2	25	ppm	22.5	ppm	7	
#3	25	ppm	2.2.5	ppm	7	
	Calculate Response Tin	ne ( <u>1</u>	+2+3)		>	#DIV/0!
					Must be less that	an 30 seconds

#### CALIBRATION PRECISION RECORD

Measurement #	Meter Reading for 2	eter Reading for Zero Air (A) Meter Reading for Calibration Gas (B)				[STD - (B)]
#1	0.34	ppm	2.4	ppm	)	
#2	0.21	ppm	28	ppm	0	
#3	0.10	ppm	25	ppm	0	
Calculate Precision	on [STD-B1] + [	STD-B2] + [5 3	STD-B3] X <u>1</u> X 25	100 1	Must be less that	#DIV/0!

Performed By: AANON MCBROT	Date/Time: 1/-5~/5~ 1550	9
----------------------------	--------------------------	---



LANDFILL NAME: Pt D NOOD	INSTRUMENT MAKE: + HERRO
MODEL: LVA 1000 EQUIPMENT #:	13 SERIAL #: 1/027/6775
MONITORING DATE: / l-5-19	TIME: /550

#### Calibration Procedure:

1. Allow instrument to zero itself while introducing air.

2. Introduce calibration gas into the probe. Stabilized reading = 7.8

3. Adjust meter settings to read 25 ppm.

#### **Background Determination Procedure**

Upwind Background Reading: (Highest in 30 seconds)	Downwind Background Reading: (Highest in 30 seconds)	Background Value:  (Upwind + Downwind) 2
/ G ppm	2-2 ppm	1.9 ppm

Background Value = 1.9 ppm

#### INSTRUMENT RESPONSE TIME RECORD

Measurement #	nent # Stabilized Reading Using   90% of the Stabilized   Reading   Reading				lized	Time to Reach 9 Stabilized Read switching from 3 Calibration Gas	ing after
#1	Z3 ppn	20:7	ppm	6			
#2	2s ppn	22.5	ppm	6			
#3	2.5 ppn	27-5	ppm	6			
	Calculate Response Time (	<u>1+2+3</u> ) 3		6	#DIV/0!		
				Must be less than	30 seconds		

#### CALIBRATION PRECISION RECORD

Measurement #			Meter Reading for Calibration Gas (B)		Calculate Precision [STD – (B)	
#1	0.45	ppm	23	ppm	Z	
#2	0.27	ppm	25	ppm	0	
#3	0.16	ppm	25.	ppm	0	
Calculate Precision	[STD-B1] + [S	STD-B2] + [\$ 3	STD-B3] X 1 ) 25	K <u>100</u> 1	, 2.6	#DIV/0!
					Must be less that	an 10%

Performed By: SRNESL RENIREZ	Date/Time:	11-5-19-1550
------------------------------	------------	--------------



LANDFILL NAME: REVINOR		INSTRUMENT	Г МАКЕ: <i>}</i>	MAD
MODEL: FVA1000 EC	QUIPMENT #:/ 5		SERIAL #:	1636346772
MONITORING DATE: 11-5-19	?	TIME:	1550	
Calibration Procedure:				

1. Allow instrument to zero itself while introducing air.

2. Introduce calibration gas into the probe. Stabilized reading = 25

3. Adjust meter settings to read 25 ppm.

#### **Background Determination Procedure**

Upwind Background Reading: (Highest in 30 seconds)	Downwind Background Reading: (Highest in 30 seconds)	Background Value:  (Upwind + Downwind) 2		
1,6 ppm	2.2 ppm	1.9 ppm		

Background Value = \_/-5

#### INSTRUMENT RESPONSE TIME RECORD

Measurement #	Stabilized Reading Using Calibration Gas		90% of the Stabi Reading	lized	Time to Reach 90% of Stabilized Reading after switching from Zero Air to Calibration Gas		
#1	24	ppm	21.6	ppm	5	,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,	
#2	25	ppm	22.5	ppm	5		
#3	25	ppm	22.5	ppm	5		
	Calculate Response	Time ( <u>1</u> -	+2+3)		Must be less than	#DIV/0!	

#### **CALIBRATION PRECISION RECORD**

Measurement #	Meter Reading for Z	leter Reading for Zero Air (A)		g for as (B)	Calculate Precision [STD - (B)]	
#1	0.33	ppm	24	ppm	)	
#2	0.21	ppm	25	ppm	0	
#3	0-14	ppm	25	ppm	Ö	
Calculate Precision	n [STD-B1] + [S	3 3	STD-B3] X <u>1</u> 25	X <u>100</u> 1	. / - ン Must be less th	#DIV/0!

Performed By: ARRIEN	TONES	Date/Time:	11-5-19-1550	



LANDFILL NAME: RED WOUD	1	NSTRUMEN	IT MAKE:	414	ELNO
MODEL: LVA 1000 EQUIPMENT#	10		SERI	AL #:	1036346773
MONITORING DATE: 1)-6-19		_TIME:	05	40	

#### **Calibration Procedure:**

1. Allow instrument to zero itself while introducing air.

2. Introduce calibration gas into the probe. Stabilized reading = 25 ppm

3. Adjust meter settings to read 25 ppm.

#### **Background Determination Procedure**

Upwind Background Reading: (Highest in 30 seconds)	Downwind Background Reading: (Highest in 30 seconds)	Background Value:  (Upwind + Downwind) 2
1.6 ppm	2.2 ppm	1.9 ppm

Background Value = \_\_\_\_\_\_ ppm

#### INSTRUMENT RESPONSE TIME RECORD

Measurement #	Stabilized Read		90% of the Stabili Reading	ized	Time to Reach 9 Stabilized Read switching from Calibration Gas	ing after Zero Air to
#1	24	ppm	21.6	ppm	6	
#2	25	ppm	27.5	ppm	6	
#3	25	ppm	22.5	ppm	6	
	Calculate Respons	e Time ( <u>1</u> 3	<del>+2+3</del> )		4	#DIV/0!
					Must be less than	a 30 seconds

#### CALIBRATION PRECISION RECORD

Meter Reading for 2	Zero Air (A)			Calculate Precision	[STD - (B)]
0-31	ppm	24	ppm	)	
0.26	ppm	25	ppm	0	
0.11	ppm	25	ppm	0	
n [STD-B1] + [	STD-B2] + [5 3	STD-B3] X <u>1</u> X 25	1 <u>00</u> 1	1-3	#DIV/0!
	0.31	0.3/ ppm 0.26 ppm 0.11 ppm	Calibration Ga  0 - 3 / ppm 2 /  0 - 2 6 ppm 2 s  0 - 1 / ppm 2 s  n [STD-B1] + [STD-B2] + [STD-B3] X 1 X	Calibration Gas (B)         0-3/       ppm       2 // ppm         0-26       ppm       2 // ppm         0-1/       ppm       2 // ppm         0-1/       ppm       2 // ppm         ISTD-B1] + [STD-B2] + [STD-B3] X 1 X 100	Calibration Gas (B)         0-3/       ppm       2 // ppm       /         0-26       ppm       2 // ppm       0         0-1/       ppm       2 // ppm       0         n       [STD-B1] + [STD-B2] + [STD-B3] X 1 X 100       1-3

Performed By: LFIS & WARD &	Date/Time: 11-6-19-0545
r chomica by.	Date/Time.



LANDFILL NAME: 2 10 W 00	0	INSTRUME	NT MAKE: + HERNO	
MODEL: 4VA 1000	EQUIPMENT #://		SERIAL #: 1636346779	
MONITORING DATE: 11-6-	9	TIME:	0540	

#### **Calibration Procedure:**

- 1. Allow instrument to zero itself while introducing air.
- 2. Introduce calibration gas into the probe. Stabilized reading = 25 ppm
- 3. Adjust meter settings to read 25 ppm.

#### **Background Determination Procedure**

Upwind Backg Reading: (Highest in 30 se	11	Downwind Background Reading: (Highest in 30 seconds)		Background Va	45.4
1.6	ppm	2-2	ppm	1.9	ppm

Background Value = 1-9 ppm

#### INSTRUMENT RESPONSE TIME RECORD

Measurement #	Stabilized Readir Calibration Gas	ng Using	90% of the Stabili Reading	zed	Time to Reach 9 Stabilized Read switching from Calibration Gas	ing after Zero Air to
#1	24	ppm	21.6	ppm	5	
#2	24	ppm	2126	ppm	5	
#3	25	ppm	22.5	ppm	5	
	Calculate Response	Time (1-	+2+3)		5	#DIV/0!
					Must be less than	30 seconds

#### **CALIBRATION PRECISION RECORD**

Measurement #	Meter Reading for Ze	ero Air (A)	Meter Reading Calibration Ga		Calculate Precision	[STD - (B)]
#1	0.27	ppm	24	ppm	1	
#2	044	ppm	24	ppm	1	
#3	0,09	ppm	25	ppm	0	
Calculate Precision	n [STD-B1] + [S	TD-B2] + [: 3	STD-B3] X <u>1</u> 25	X <u>100</u> 1	. 2.6	#DIV/0!
					Must be less the	an 10%

Performed By:	ANThon	penalta	Date/Time:	
---------------	--------	---------	------------	--



LANDFILL NAME: RED Noop		INSTRUMENT MAKE: + Henab		
MODEL: +VA1000	EQUIPMENT #:	12	SERIAL #: 103624674/	
MONITORING DATE://	-6-19	TIME:	0540	

#### **Calibration Procedure:**

1. Allow instrument to zero itself while introducing air.

2. Introduce calibration gas into the probe. Stabilized reading = 25 ppm

3. Adjust meter settings to read 25 ppm.

#### **Background Determination Procedure**

Upwind Background Reading: (Highest in 30 seconds)	Downwind Background Reading: (Highest in 30 seconds)	Background Value: (Upwind + Downwind) 2
/, 6 ppm	2-2 ppm	1.9 ppm

Background Value = 1.9 ppm

#### INSTRUMENT RESPONSE TIME RECORD

Measurement #	Stabilized Reading Using Calibration Gas		90% of the Stabi Reading	lized	Time to Reach 90% of Stabilized Reading after switching from Zero Air to Calibration Gas		
#1	23	ppm	20.7	ppm	6		
#2	24	ppm	21,6	ppm	6		
#3	25	ppm	22.5	ppm	6		
	6	#DIV/0!					
					Must be less than	n 30 seconds	

#### CALIBRATION PRECISION RECORD

				Calculate Precision [STD – (B)]		
0.24	ppm	ZJ	ppm	7		
0.16	ppm	24	ppm	)		
0-10	ppm	25	ppm	Ŏ		
	TD-B2] + [5	STD-B3] X <u>1</u> X 25	1 <u>100</u> 1	. 4.5	#DIV/0!	
	0.24	0.24 ppm 0.16 ppm	Calibration Ga           ウ・2分         ppm         こう           の・1台         ppm         こう           の210         ppm         こう	Calibration Gas (B)  O Z Y ppm Z ppm O 16 ppm Z Y ppm O 210 ppm Z S ppm	Calibration Gas (B)  O-24 ppm 23 ppm 2  O-16 ppm 24 ppm 3  O-10 ppm 25 ppm 0	

Performed By: AROW MCBRIDE	Date/Time:
----------------------------	------------



LANDFILL NAME: 1200 W 800 INSTRUMENT MAKE					TMAKE: +HERRO	
MODEL: FUA	7000	EQUIPMENT #:	13		SERIAL #: 1/02746775	
MONITORING DAT	E: 11-6~	19		TIME:	0545	

#### **Calibration Procedure:**

1. Allow instrument to zero itself while introducing air.

2. Introduce calibration gas into the probe. Stabilized reading = 25 ppm

3. Adjust meter settings to read 25 ppm.

#### **Background Determination Procedure**

Reading:	wind Background ading: hest in 30 seconds)  Downwind Background Reading: (Highest in 30 seconds)			d Background Value: (Upwind + Downw 2	
1-6	ppm	2.2	ppm	1.9	ppm

Background Value = 1, 9 ppm

#### INSTRUMENT RESPONSE TIME RECORD

Measurement #	Stabilized Reading Using Calibration Gas		90% of the Stabil Reading	ized	Time to Reach 90% of Stabilized Reading after switching from Zero Air to Calibration Gas		
#1	23	ppm	20.7	ppm	7		
#2	25	ppm	22.5	ppm	7		
#3	25	ppm	22-5	ppm	7		
	7	#DIV/0!					
					Must be less tha	n 30 seconds	

#### CALIBRATION PRECISION RECORD

Measurement #	Meter Reading for Zo	ero Air (A)	Meter Reading for Calibration Gas (B)		Calculate Precision [STD – (I		
#1	6.34	ppm	23	ppm	Z		
#2	0.25	ppm	25	ppm	0		
#3	0-17	ppm	25	ppm	Ó		
Calculate Precisio	n [STD-B1] + [S	3 (STD-B2)	STD-B3] X <u>1</u> 25	X <u>100</u> 1	· Z - 6 Must be less th	#DIV/0!	

Performed By:	ERNESZ	Ranner	Date/Time:	17-6-19-0545	



LANDFILL NAME: _ RED WO	.10	1	STRUME	NT MAKE: +HERRO
MODEL: LVA 1000	EQUIPMENT #: _	15		SERIAL #: 1676346777
MONITORING DATE: 11-6	-19		_TIME:	0540

#### **Calibration Procedure:**

- 1. Allow instrument to zero itself while introducing air.
- 2. Introduce calibration gas into the probe. Stabilized reading = 25
- 3. Adjust meter settings to read 25 ppm.

#### **Background Determination Procedure**

Upwind Background Reading: (Highest in 30 seconds)	Downwind Background Reading: (Highest in 30 seconds)	Background Value:  (Upwind + Downwind) 2
//6 ppm	2.2 ppm	1.9 ppm

Background Value = 1.9 ppm

#### INSTRUMENT RESPONSE TIME RECORD

Measurement #	Stabilized Reading Using Calibration Gas		90% of the Stabil Reading	ized	Time to Reach 90% of Stabilized Reading after switching from Zero Air to Calibration Gas	
#1	24	ppm	21.6	ppm	6	
#2	25	ppm	22.5	ppm	6	
#3	25	ppm	22.5	ppm	6	
	Calculate Response	Time ( <u>1</u> ·	+2+3)		6	#DIV/0!
					Must be less that	n 30 seconds

#### **CALIBRATION PRECISION RECORD**

Measurement #	Meter Reading for Zero Air (A) Meter Reading for Calibration Gas (B)		-	Calculate Precision [STD - (B)		
#1	0.41	ppm	24	ppm	1	
#2	0.28	ppm	25	ppm	0	
#3	0.22	ppm	25	ppm	0	
Calculate Precision	[STD-B1] + [S	[STD-B1] + [STD-B2] + [STD-B3] X 1 X 100 3 25 1			. 1.3	#DIV/0!
					Must be less that	an 10%

Performed By: ARRIEN	DONES	Date/Time: 11-6-19-0545



# SURFACE EMISSION MONITORING INSTRUMENT CALIBRATION LOG

Date:		Time:	0830		
TV4   1000 B 	<u>6913</u>				
INSTRUMENT INTEGRITY CHECKLIST		INSTRUMENT CALIBRATION			
attery test	Pass / Fail	Calibration Gas (ppm)	ALIBRATION CHE Actual (ppm)	CK % Accuracy	
eading following ignition eak test	Pass / Fail / NA	500	ςοο RESPONSE TIME	100%	
ean system check neck valve chatter)	Pass / Fail / NA	Calibration Gas, p	P111	750	
supply pressure gauge eceptable range 9.5 - 12)	Pass / Fail / NA	Time required to a 1	ttain 90% of Cal G	as ppm	
te of last factory calibration	10-5-19 Pase / Fail	3. 7 Average 6	6		
instrument within 3 months	Paso / I all	Equal to or less the Instrument calibrat		gas.	

465



# SURFACE EMISSION MONITORING INSTRUMENT CALIBRATION LOG

Date: 11-2-19	_	Time:	0845		
	774				
INSTRUMENT INTEGRITY CHECKLIST		INSTRUMENT CALIBRATION			
attery test	Pass / Fail	Calibration Gas (ppm)	ALIBRATION CHEC Actual (ppm)	K % Accuracy	
eading following ignition ak test	Pass / Fail / NA	500	SØO  RESPONSE TIME	loo4,	
ean system check eck valve chatter)	Pass / Fail / NA	Calibration Gas, p	pm	50	
supply pressure gauge ceptable range 9.5 - 12)	Pass / Fail / NA	Time required to a	ittain 90% of Cal Ga		
te of last factory calibration	10-5-19	2. 7 3. 7 Average 7:	0	Y)	
ctory calibration record nstrument within 3 months	Pass / Fail	Equal to or less the		Ø N gas.	
mments:	-				



## SURFACE EMISSION MONITORING INSTRUMENT CALIBRATION LOG

Reading following ignition  Leak test  Clean system check (check valve chatter)  Pass / Fail / NA  Clean system check (check valve chatter)  Pass / Fail / NA  Calibration Gas, ppm  90% of Calibration Gas, ppm  1.	Date: 11-2-19		Time:	0900	
Battery test  Battery test  Reading following ignition  Leak test  Calibration Gas (ppm)  Calibration Gas (ppm)  Accuracy  Fail / NA  RESPONSE TIME  Calibration Gas, ppm  Pass / Fail / NA  Calibration Gas, ppm  90% of Calibration Gas, ppm  90% of Calibration Gas, ppm  12 supply pressure gauge facceptable range 9.5 - 12)  Calibration Gas, ppm  90% of Calibration Gas, ppm  1.			I		
Reading following ignition  Leak test  Clean system check check valve chatter)  Pass / Fail / NA  Clean system check check valve chatter)  Pass / Fail / NA  Clean system check check valve chatter)  Pass / Fail / NA  Clean system check check valve chatter)  Pass / Fail / NA  Calibration Gas, ppm  90% of Calibration Gas, ppm  1.	INSTRUMENT INTEGRIT	Y CHECKLIST	INSTI	RUMENT CALIBR	ATION
	Reading following ignition  Leak test  Clean system check check valve chatter)  H2 supply pressure gauge acceptable range 9.5 - 12)  Date of last factory calibration	23 ppm Pass / Fail / NA Pass / Fail / NA Pass / Fail / NA (0-5-19	Calibration Gas (ppm)  SOO  Calibration Gas, p 90% of Calibration Time required to a 1.	Actual (ppm)  SOO  RESPONSE TIME  ppm Gas, ppm attain 90% of Cal G	Accuracy  100 >,  100 o  440  Cuso  Cuso  N



## SURFACE EMISSION MONITORING INSTRUMENT CALIBRATION LOG

Date:		Time:	0915	
Model # <u> </u>	275			
INSTRUMENT INTEGRITY	CHECKLIST	INST	RUMENT CALIBR	ATION
Sattery test	ease / Fail	Calibration Gas (ppm)	ALIBRATION CHE Actual (ppm)	CK % Accuracy
teading following ignition eak test	Pass / Fail / NA	500	SOO RESPONSE TIME	100%
lean system check heck valve chatter)	Pass / Fail / NA	Calibration Gas, p		<u>800</u>
supply pressure gauge cceptable range 9.5 - 12)	(Pass / Fail / NA	Time required to a 1.	nttain 90% of Cal G	ias ppm
ate of last factory calibration	10-5-19 Pass / Fail	3.	6	
instrument within 3 months	rass / I all	Equal to or less the Instrument calibra	_	gas. N
omments:				



# SURFACE EMISSION MONITORING INSTRUMENT CALIBRATION LOG

eading following ignition  ppm  Pass / Fail / NA  RESPONSE TIME  Calibration Gas, ppm  supply pressure gauge acceptable range 9.5 - 12)  Pass / Fail / NA  RESPONSE TIME  Calibration Gas, ppm  90% of Calibration Gas, ppm  1.	Operator:	u (m	Time:	0945	
attery test  eading following ignition  eak test  lean system check check valve chatter)  esupply pressure gauge cceptable range 9.5 - 12)  eate of last factory calibration  eater of last factory calibration record					
cattery test  Pass / Fail  Calibration Gas (ppm)  Calibration Gas (ppm)	INSTRUMENT INTEGRIT	Y CHECKLIST	INSTI	RUMENT CALIBR	ATION
Pass / Fail / NA  RESPONSE TIME  Calibration Gas, ppm  Supply pressure gauge cceptable range 9.5 - 12)  Pass / Fail / NA  RESPONSE TIME  Calibration Gas, ppm  90% of Calibration Gas, ppm  Time required to attain 90% of Cal Gas ppm  1. 2. 3. Average  Average	Sattery test	10	Calibration	Actual	
	eak test  clean system check check valve chatter)  2 supply pressure gauge acceptable range 9.5 - 12)  ate of last factory calibration actory calibration record //instrument within 3 months	Pass / Fail / NA Pass / Fail / NA Pass / Fail / NA	Calibration Gas, p 90% of Calibration Time required to a 1. 2. 3. Average	RESPONSE TIME  pm  Gas, ppm  Ittain 90% of Cal G	1450 1450 1450

CUSTOMER:	RES	Vait	# 10	
			1-1	

TECHNICIAN: M DATE: 10-5-19

### GAS CALIBRATION CHECK (PERFORMED AT ROOM TEMPERATURE)

	F	D	
METHANE GAS NOMINAL (ppm)			TOLERANCE (ppm)
100 100		100	+/- 25
500	500	503	+/- 125
10000	10000	10,003	+/- 2500
< 1	ZERO GAS	DON	< 3
1	Pil	0	
ISOBUTYLENE GAS NOMINAL (ppm)	CALIBRATION GAS (ppm)	TVA READING (ppm)	TOLERANCE (ppm)
50	50	1	+/- 12.5
100	100		+/- 25
500	500		+/- 125
< 1	ZERO GAS	1	< 3

CUSTOMER:	ES Wait #11	
SERIAL NUMBER:	1036346774	

### GAS CALIBRATION CHECK (PERFORMED AT ROOM TEMPERATURE)

	FI	D	
METHANE GAS NOMINAL (ppm)			TOLERANCE (ppm)
100	100	100	+/- 25
500	500	500	+/- 125
10000	10000	16,001	+/- 2500
<1	ZERO GAS	0,91	< 3
7	Pil	)	
ISOBUTYLENE GAS NOMINAL (ppm)	CALIBRATION GAS_(ppm)	TVA READING (ppm)	TOLERANCE (ppm)
50	50	1-	+/- 12.5
100	100		+/- 25
500	500		+/- 125
< 1	ZERO GAS		< 3

CUSTOMER: RES WAIT # 12

### GAS CALIBRATION CHECK (PERFORMED AT ROOM TEMPERATURE)

	F	ID	
METHANE GAS NOMINAL (ppm)			TOLERANCE (ppm)
100	100	100	+/- 25
500	500	500	+/- 125
10000	10000	10,000	+/- 2500
< 1	ZERO GAS	0.46	< 3
	PII	D	
ISOBUTYLENE GAS NOMINAL (ppm)	CALIBRATION GAS_(ppm)	TVA READING (ppm)	TOLERANCE (ppm)
50	50	/	+/- 12.5
100	100	/	+/- 25
500	500		+/- 125
<1	ZERO GAS		< 3

CUSTOMER: RES UNIT # 1	13
------------------------	----

### GAS CALIBRATION CHECK (PERFORMED AT ROOM TEMPERATURE)

	F	ID	
METHANE GAS CALIBRATION GAS (ppm)		TVA READING (ppm)	TOLERANCE (ppm)
100	100	99	+/- 25
500	500	495	+/- 125
10000	10000	(0.113	+/- 2500
< 1	ZERO GAS	0.72	< 3
	Pil	D	
ISOBUTYLENE GAS NOMINAL (ppm)  CALIBRATION GAS.(ppm)		TVA READING (ppm)	TOLERANCE (ppm)
50	50	/	+/- 12.5
100	100		+/- 25
500	500		+/- 125
<1	ZERO GAS		< 3

CUSTOMER: RES WANT # 15

SERIAL NUMBER: 1036346772

TECHNICIAN: \_\_\_\_\_\_\_ DATE: \_\_\_\_\_\_\_ LO-S-19

### GAS CALIBRATION CHECK (PERFORMED AT ROOM TEMPERATURE)

	FI	D	
METHANE GAS CALIBRATION GAS (ppm)		TVA READING (ppm)	TOLERANCE (ppm)
100	100 (00		+/- 25
500	500	503	+/- 125
10000 10000		10,069	+/- 2500
< 1	ZERO GAS	0.68	< 3
	Pii		
ISOBUTYLENE GAS NOMINAL (ppm)	CALIBRATION GAS.(ppm)	TVA READING (ppm)	TOLERANCE (ppm)
50	50	1	+/- 12.5
100	100		+/- 25
500	500		+/- 125
<1	ZERO GAS	/	< 3



#### INTERMOUNTAIN SPECIALTY GASES

520 N. Kings Road • Nampa • Idaho • 83687 800-552-5003 • www.isgases.com

#### CERTIFICATE OF ANALYSIS

Certification Analytical Accuracy Composition

Air - Zero

THC < 2 PPM

Oxygen 20.9%  $\pm 2\%$ 

Nitrogen Balance

Lot # 19-6779

Mfg. Date: 4/3/2019

Parent Cylinder ID 001739, 02268

Number:

#### Method of Preparation:

Gravimetric/Pressure Transfilled

#### **Method of Analysis:**

This mix was prepared gravimetrically and is traceable to the NIST by certified weights (ID #CA10814) used to calibrate the scale.

> Analysis By: Tony Janquart Quality Assurance Manager

800-552-5003

Certificate Date: 4/3/2019



Accuracy

- 20.9% Oxygen - Bal. Nitrogen

6ft @ 70°F and 1,000 PSIG

Exp Date 6/26/2023

103

Waiser Avenue, Irvine, CA 92614 353 or (800) 201-8150 Fax (949) 757-0363

Nitrogen

103 L

<u>Lot#</u> 19-6779





#### INTERMOUNTAIN SPECIALTY GASES

520 N. Kings Road • Nampa • Idaho • 83687 800-552-5003 • www.isgases.com

#### CERTIFICATE OF ANALYSIS

Composition Methane

e Certification
500 ppm
Balance

**Analytical Accuracy** 

 $\pm 2\%$ 

Lot#

Air

18-6386

Mfg. Date:

6/4/2018

Parent Cylinder ID

001763

Number:

#### **Method of Preparation:**

Gravimetric/Pressure Transfilled

#### Method of Analysis:

The parent mix was prepared gravimetrically and is traceable to the NIST by certified weights (ID #CA10814) used to calibrate the scale.

Analysis By: Tony Janquart Quality Assurance Manager

800-552-5003

Certificate Date: 6/4/2018

miration (Mole%) Accuracy +/- 2% 500 ppm Balance Exp Date 12/14/2019 0.70°F and 1,000 PSIG 103 L Avenue, Irvine, CA 92614 (800) 201-8150 Fax (949) 757-0363

### **Intermountain Specialty Gases**

520 N. Kings Road Nampa, ID 83687 (USA) Phone (800) 552-5003, Fax (208) 466-9143 www.isgases.com



"Your calibration gas manufacturer since 1992"

### CERTIFICATE OF ANALYSIS

CompositionCertificationAnalytical Accuracy (+/-)Methane500 ppm2%Oxygen20.9 %2%NitrogenBalance UHP

Lot# 18-6641

Mfg. Date: 12/18/2018

Expiration Date:

Transfill Date: see cylinder

Parent Cylinder ID 001763

Number:

#### Method of Preparation:

Gravimetric/Pressure Transfilled


#### Method of Analysis:

The parent mix was prepared gravimetrically and is traceable to the NIST by certified weights (ID #CA10814) used to calibrate the scale.

Analysis By: Tony Janquart

Title: Quality Assurance Manager

Certificate Date: 12/18/2018





#### INTERMOUNTAIN SPECIALTY GASES

520 N. Kings Road ● Nampa ● Idaho ● 83687 800-552-5003 ● www.isgases.com

#### CERTIFICATE OF ANALYSIS

Composition

Certification

Analytical Accuracy

Methane

25 ppm

 $\pm 5\%$ 

Air

Balance

Lot#

17-6074

Mfg. Date:

10/16/2017

Parent Cylinder ID

17161

Number:

#### **Method of Preparation:**

Gravimetric/Pressure Transfilled


#### Method of Analysis:

The parent mix was prepared gravimetrically and is traceable to the NIST by certified weights (ID #CA10814) used to calibrate the scale.

Analysis By: Tony Janquart Quality Assurance Manager

800-552-5003

Certificate Date: 10/16/2017



1991 Kaiser Avenue, Irvine, CA 92614 187-0353 or (800) 201-8150 Fax (949) 757-0363

Ch4 25 ppm/Air

103 L Lot# 17 - 6074

Analysis









#### **WASTE MANAGEMENT**

172 98<sup>th</sup> Avenue Oakland, CA 94603 (510) 430-8509

March 10, 2020

Ms. Alisha McCutcheon Redwood Landfill, Inc. 8590 Redwood Highway Novato, California 94948

Re: First Quarter 2020 Surface Emissions and Component Leak Monitoring Report for Redwood Landfill, Inc.

Dear Ms. McCutcheon:

This monitoring report for "Redwood Landfill, Inc. (RLI)" contains the results of the First Quarter 2020 Integrated and Instantaneous Surface Emissions Monitoring (SEM) and Component Leak Monitoring. Initial surface emissions monitoring was performed by Roberts Environmental Services, LLC. (RES). Re-monitoring of surface emissions and site-wide component leak monitoring was conducted by RES and/or Waste Management (WM) personnel.

#### APPLICABLE REQUIREMENTS

The monitoring discussed in this report was conducted in accordance with the following requirements:

#### **Surface Emission Monitoring (SEM)**

- New Source Performance Standard (NSPS), Title 40 of the Code of Federal Regulations (CFR) §60.755 (c) and (d), 40 CFR 60, Appendix A Method 21, promulgated by the United States Environmental Protection Agency (USEPA).
- California Code of Regulations (CCR) Title 17, Subchapter 10, Article 4, Subarticle 6, §95460 to §95476, known as the Assembly Bill 32 (AB32) landfill methane rule (LMR).
- Bay Area Air Quality Management District (BAAQMD) Regulation 8, Rule 34, Section 303 (Landfill Surface Requirements) and Section 607 (Landfill Surface Inspection procedures).

#### **Component Leak**

• Bay Area Air Quality Management District (BAAQMD) Regulation 8, Rule 34, Section 301 (Landfill Gas Collection and Emission Control System Requirements) and Section 602 (Collection and Control System Leak Inspection procedures).

• California Code of Regulations (CCR) Title 17, Subchapter 10, Article 4, Subarticle 6, §95464, known as the Assembly Bill 32 (AB32) landfill methane rule (LMR).

#### **RLI Plan and Alternative Compliance Measures**

An Alternative Compliance Option (ACO) Request was submitted to the California Air Resources Board (CARB) on March 24, 2011. After receipt of comments, this ACO was amended, restated, and submitted to BAAQMD on July 1, 2016. SEM and Component Leak monitoring was conducted per the methods outlined in the July 1, 2016 ACO.

#### **PROCEDURES**

#### General

The surface of the RLI disposal area has been divided into two hundred-eight (208), approximately 50,000 square foot monitoring grids. The entire landfill surface is monitored with the exception of active portions of the Landfill, slope areas, and as requested in the approved ACO, areas containing only asbestos-containing waste, inert waste and/or non-decomposable waste which are excluded for safety as allowed by CCR Title 17 §95466.

Field personnel walked the surface of the landfill following the walking pattern as depicted the 2011 RLI AB-32 SEM Plan, which traverses each monitoring grid. Additionally, in accordance with the provisions of 40 CFR 60.753(d) and 60.755(c)(1-3), the entire perimeter of the landfill surface was monitored. During the event, special attention was given to monitoring unusual cover conditions (stressed vegetation, cracks, seeps, etc.) and any areas with unusual odors.

#### **Instantaneous Surface Emissions Monitoring**

The Instantaneous SEM was conducted using a Toxic Vapor Analyzer (TVA) 1000 flame ionization detector (FID), which was calibrated to 500 parts per million by volume (ppm<sub>v</sub>) methane, which meets or exceeds all guidelines set forth in the CCR Title 17 §95471(a) and NSPS. The FID was calibrated prior to use in accordance with the United States Environmental Protection Agency (USEPA) Method 21 requirements. The Instantaneous SEM procedures followed the requirements of 40 CFR 60.755 (c) and (d) and CCR Title 17 §95471(c)(2).

RES personnel walked the surface of the landfill on a grid by grid basis with the wand tip held at 2 inches from the landfill surface. While sampling the grid; the technicians also checked any surface impoundments (wells or otherwise) for leaks. Technicians also checked any surface cracks, seeps, or other areas that show evidence of surface emissions (odors or distressed vegetation). Active and sloped areas excluded for safety were documented on field data sheets and maps.

All instantaneous surface monitoring was performed in accordance with the applicable requirements referenced in this report. Any detections of methane above 200 ppm<sub>v</sub> (areas of concern) or 500 ppm<sub>v</sub> (exceedances) for instantaneous were recorded, flagged, and marked on an SEM Map, which, wherever required, is included in the Appendices of this report. Applicable corrective action and re-monitoring timelines are listed below:

- Corrective actions must be initiated within 5 days of the initial exceedance and remonitoring shall be conducted within 10 days of the initial exceedance.
  - o If the re-monitoring event shows the exceedance is corrected, the location shall be re-monitored within 1 month of the initial exceedance.
  - o If the 1-month re-monitoring event shows the location is still corrected, all remonitoring requirements have been completed.
- If either the first 10-day or 1-month re-monitoring events show a second exceedance, additional corrective actions shall be completed and a second re-monitoring event shall be conducted within 10 days of the second exceedance.
- If the second 10-day re-monitoring event shows the second exceedance is corrected, the location shall be re-monitored within 1 month of the initial exceedance. If the 1-month re-monitoring event shows the area is still corrected, monitoring requirements have been completed.

If any location shows three exceedances, an additional well shall be installed within 120 days of the initial exceedance.

#### **Integrated Surface Emissions Monitoring**

The Integrated surface monitoring was conducted using a TVA 1000 calibrated to 25 ppm<sub>v</sub> for the integrated monitoring, which meets or exceeds all guidelines set forth in the CCR Title 17 §95471(a). The field technician traversed the grid walking path over a continuous 25-minute period using the TVA 1000 held at 3 inches above the landfill surface. The Integrated monitoring procedures followed the requirements of CCR Title 17 §95471(c)(2).

Grids with results greater than 25 ppm<sub>v</sub> were recorded, marked on the SEM map, and flagged for remediation. Any grids with integrated concentrations greater than 25 ppm<sub>v</sub> are subject to the following re-monitoring timeline:

- Re-monitoring shall be conducted within 10 days of the initial exceedance.
- If the 10-day re-monitoring event shows the exceedance is corrected, all re-monitoring requirements have been completed.
- If either the first 10-day re-monitoring event shows a second grid exceedance, additional corrective actions shall be completed and a second re-monitoring event shall be conducted within 10 days of the second exceedance.
- If the second 10-day re-monitoring event shows the second exceedance is corrected, all re-monitoring requirements have been completed.
- The second 10-day re-monitoring event shows a third grid exceedance, an additional well shall be installed within 120 days of the third exceedance.

#### **Component Leak Monitoring Procedures**

RES personnel monitored the exposed LFG components under positive pressure (pipes, wellheads, valves, blowers, and other mechanical appurtenances) using a TVA 1000 calibrated to 500 ppm<sub>v</sub>. All leaks measured one half inch or less from the component exceeding the compliance limit of 500 ppm<sub>v</sub> per requirements outlined in pursuant to CARB Title 17 of California Code of Regulations Subchapter 10, Article 4, Subarticle 6, Section 95464(b)(1)(B) and 1,000 ppm<sub>v</sub> per requirements outlined in BAAQMD 8-34-303 were recorded. Applicable corrective action and re-monitoring timelines are listed below:

- Leaks between 500 and 999 ppm<sub>v</sub> must be corrected and re-monitored within 10 days of the initial exceedance.
- Leaks at or above 1000 ppm<sub>v</sub> must be corrected and re-monitored within 7 days of the initial exceedance.

#### FIRST QUARTER 2020 SEM AND COMPONENT LEAK RESULTS

The following is a summary of the SEM and component leak monitoring results completed for the First Quarter 2020.

#### **Instantaneous Surface Emissions Monitoring Results**

The Instantaneous surface monitoring was performed on January 30, 2020 in accordance with the NSPS, BAAQMD 8-34, and CCR Title 17 §95469 and ACO. Results and data from the monitoring are presented in Attachment A

#### Initial Monitoring Event Exceedances of 500 ppm<sub>v</sub>

There were two (2) exceedances of 500 ppm<sub>v</sub> as methane detected on January 30, 2020. Corrective actions to initiate repairs of the exceedances were completed within five days for all locations.

#### First Ten-Day Re-Monitoring Results

The first 10-day re-monitoring event was completed on February 7, 2020. All locations were observed at less than 500 ppm<sub>v</sub>.

#### One-Month Re-Monitoring Results

The 1-month re-monitoring event was completed on February 27, 2020. All locations were observed at less than 500 ppm<sub>v</sub>.

#### Readings between 200 ppm<sub>v</sub> and 499 ppm<sub>v</sub> (Initial and Re-monitored)

There were no readings between 200 ppm<sub>v</sub> and 499 ppm<sub>v</sub> as methane detected during the initial monitoring event on January 30, 2020. Pursuant to CCR Title 17 §95471(c), instantaneous surface emissions exceeding 200 ppm<sub>v</sub> but below 500 ppm<sub>v</sub> are required to be recorded.

#### **Integrated Surface Emissions Monitoring Results**

The Integrated surface sampling (ISS) was performed on January 29, 30, and 31, 2020 in accordance with the ACO and requirements outlined in CCR Title 17 §95469.

#### Initial Monitoring Event Exceedances of 25 ppm<sub>v</sub>

There were 0 grids with exceedances of 25 ppm<sub>v</sub> as methane detected during the initial monitoring event.

The average methane concentration of each grid was recorded during the monitoring event per applicable requirements. See Attachment B, Integrated SEM 25 ppm<sub>v</sub> Exceedances and Monitoring Log, and SEM Map included in Attachment B, for details.

#### **Component Leak Monitoring Results**

Component leak monitoring was conducted per the applicable requirements on January 30, 2020. No leaks greater than 500 ppm<sub>v</sub> were identified. Please see Attachment C, for details.

#### WEATHER CONDITIONS

#### Wind Speed Conductions during the Surface Emission Monitoring Events

Wind speeds during initial monitoring were monitored using a portable weather station. The station has a strip chart that records the wind speed and direction. After completion of monitoring, the strip chart is reviewed by RES office staff to determine the average and maximum wind speeds during the monitoring and the average wind direction during each grid and ensure that the wind speed requirements are met (no gusts greater than 20 mph, average wind speed cannot exceed 10 mph). These values are documented in the field data sheets. The chart data is scanned and included in Attachment D.

#### **Precipitation Requirements**

Per the RLI's ACO, the initial monitoring event was carefully scheduled so that it could be conducted in compliance with the precipitation requirements (no precipitation  $\geq 0.01$ " within 24 hours,  $\geq 0.16$ " within 48 hours, nor  $\geq 0.25$ " within 72 hours). Re-monitoring events are required to adhere to strict timelines. Any conflicts with precipitation requirements are discussed in the results section of this document.

#### **EQUIPMENT CALIBRATION**

The portable analyzers were calibrated to meet the instrument specifications requirements of U.S. EPA Method 21. The calibration gas used was methane, diluted to a nominal concentration of 25 ppm<sub>v</sub> in air for integrated sample analyses and 500 ppm<sub>v</sub> in air for instantaneous monitoring to comply with the requirements.

All analyzers were calibrated prior to use with required response time and precision related instrument checks. Calibration records include the following: One time response time test record;

Ms. Alisha McCutcheon Page 6

One time response factor determination for methane; Calibration Precision test records (test to be performed every 3 months); and Daily Instrument Calibration and Background test records for each gas meter that was used during the quarterly monitoring event. The calibration log records are included in Attachment E.

All monitoring was completed in accordance with the applicable regulatory requirements or approved alternatives. If you have any questions regarding this report, please do not hesitate to contact me at (510) 613-2852.

Thank you, Waste Management

Michael Chan

**Environmental Protection Specialist** 

Attachel Chan

#### Attachment A – Instantaneous Surface Emission Monitoring Event Records

- Monitoring Logs and Exceedances
- Surface Monitoring Weather Data
- SEM Map

#### Attachment B – Integrated Surface Emission Monitoring Event Records

- Monitoring Logs and Exceedances
- Surface Monitoring Weather Data
- SEM Map

#### Attachment C - Component Leak Monitoring Event Records

• Component Leak Exceedances and Monitoring Logs

#### Attachment D – Weather Station Data

• Strip Chart Data

#### Attachment E – Calibration Records

• Instrument and Gas Calibration Records

#### Attachment A

Instantaneous Surface Emission Monitoring Event Records

## Table A.1 Instantaneous Landfill Surface Emissions Monitoring Initial Monitoring Event Areas of Concern

**2020 QUARTER**: 1 **PERFORMED BY**: RES

Grid Number	Flag Number	Date of Monitoring	Concentration of Emission (ppm <sub>v</sub> )	Comments
174	01	1/30/2020	873	Well 210
187	02	1/30/2020	16,000	Well 102
	d data sheets for details			

# Table A.2 Instantaneous Landfill Surface Emissions Monitoring Exceedance and Monitoring Logs (NSPS/BAAQMD 8-34)

**2020 QUARTER**: 1

INITIAL MONITORING PERFORMED BY: RES

FOLLOW-UP MONITORING PERFORMED BY: S. Johnson

Initia	Monitoring	Event		Corrective Action	1st 10	oday Follo	w-Up	1st 30	-day Follo	w-Up	
Flag Number	Monitoring Date	Reading ppm	Repair Date	Action Taken	Monitoring Date	No Exced. <500 ppm	Exced. >500 ppm	Monitoring Date	No Exced. <500 ppm	Exced. >500 ppm	Comments
01	1/30/2020	873	1/31/2020	Increased BECS/ Vacuum	2/7/2020	0		2/27/2020	1.5		Well 210
O2	1/30/2020	16,000	1/31/2020	Increased and Fixed BECS	2/7/2020	0		2/27/2020	3.7		Well 102
-											

# Table A.3 Instantaneous Landfill Surface Emissions Monitoring Exceedance and Monitoring Logs (AB-32)

**2020 QUARTER**: 1

INITIAL MONITORING PERFORMED BY: RES

FOLLOW-UP MONITORING PERFORMED BY: S. Johnson

Monitoring	Event	1st Re-n	1st Re-mon Event - 10 Days			non Event		
Monitoring	Reading	Monitoring	No Exced.	Exced.	Monitoring	No Exced.	Exced.	1
Date	ppm	Date	<500 ppm	>500 ppm	Date	<500 ppm	>500 ppm	Comments
1/30/2020	873	2/7/2020	0					Well 210
1/30/2020	16,000	2/7/2020	0					Well 102
	Monitoring Date 1/30/2020	Date ppm 1/30/2020 873	Monitoring Date         Reading ppm         Monitoring Date           1/30/2020         873         2/7/2020	Monitoring Date         Reading ppm         Monitoring Date         No Exced. <500 ppm           1/30/2020         873         2/7/2020         0	Monitoring Date         Reading ppm         Monitoring Date         No Exced.         Exced.           1/30/2020         873         2/7/2020         0	Monitoring Date         Reading ppm         Monitoring Date         No Exced.          Exced.          Monitoring Date           1/30/2020         873         2/7/2020         0         Date         Date	Monitoring DateReading ppmMonitoring DateNo Exced. So0 ppmExced. So0 ppmMonitoring DateNo Exced. So0 ppm1/30/20208732/7/20200	Monitoring DateReading ppmMonitoring DateNo Exced. <500 ppmExced. >500 ppmMonitoring DateNo Exced. <500 ppmExced. Date1/30/20208732/7/20200Date<500 ppm


# Table A.4 Instantaneous Landfill Surface Emissions Monitoring Areas of Concern Greater than 200 ppmv

**2020 QUARTER**: 1

INITIAL MONITORING PERFORMED BY: RES

FOLLOW-UP MONITORING PERFORMED BY: S. Johnson

Initial	Monitoring	Event	Re-moi	n Event	
Flag	Monitoring	Reading	Monitoring Reading		Comments
Number	Date	ppm	Date		
		No	locations		




SURFACE EMISSIONS MONITORING

GRID MAP

PROJECT NO

140521



## Orange Flag Landfill Surface Emissions Monitoring Exceedances and Monitoring Log

Site: REDWOOD	
---------------	--

Quarter /		15+ 202	0							9			Page of	Page
Technicia		LEISH WAR	) E										, 490 01	1 090
Instrumer		+VA 1000	7											
Calibratio	n Standard:		cat .											_
Flag	Initial M Grid	onitoring Event		First Re-M	onitoring Even	t - 10 Days	Second Re	-Monitoring Eve	nt - 10 Days	30-Da	y Follow-up Mo	nitoring	Comments	-
		Field Reading	Date	Date	No Excd.	Excd.	Date	No Excd.	Excd	Date	No Excd.	Excd.		
Number O- i	Number	(ppm)	Monitored	Monitored	<500 ppm	>500 ppm	Monitored	<500 ppm	>500 ppm	Monitored	<500 ppm	>500 ppm		
_	174	873	1-30-20										Warrala	
0-2	187	16,000	1										WELL 102	
0-		,											100017 700	
0-														
0-														
0-														-
0-														
0-														
0-														
0-														
0-														
0-														
0-														
0-														
0-														
0-									7					
0-														
0-								-						
0-														
0-														
0-														
0-														
0-														
0-												1 - V		
0-										/.				
0-												7		

ersonnel: LEICHWADE ANTLING PERSULA AARON MUBRIDE NICK BENKS ERNEST PLAIRE
Date: 1-30-20 Instrument Used: $\frac{1}{2}$ Grid Spacing: $\frac{2}{5}$
Temperature: 50 Precip: 0 Upwind BG: 1-8 Downwind BG: 2-4

GRID ID	STAFF	START	STOP	TOC PPM	NII	ND INFOR	DEMARKS	
	INITIALS	TIME	TIME		AVG SPEED	MAX. SPEED	DIRECTION 16 POINT	REMARKS
1	CW	0600	0615	17	2	3	9	
2	AM	0600	0615	13	2	7	9	
3	en	0600	0615	11	7	Í	G G	
4	10	0600	0615	17	1	9	9	
5	NB	0600	0615	24	2	3	9	
6	LW	0615	0630	14	2	J	9	
7	A.	0615	6630	16	7	3	9	
8	en	0665	0630	11	1	]	9	
9	AP	0665	2830	9	2	3	q	
10	NB	0615	2830	19	2	3	9	
11	LW	0630	0645	28	3	4	3	
12	AM	0830	0645	17	]	4	3	
13	EN	0630	0845	14	3	9	5	
14	np	0630	0645	12	3	4	3	
15	NB	2830	0645	57	2	3	9	
16	LW	0645	0700	42	7	3	9	
17	12	0845	0700	20	7	2	9	
18	en	0845	0700	12	7	2	9	
19	NP	6845	Caca	39	7	7	4	
20	NB	0645	0700	54	2	2	4	
2)	LW	0)00	8715	99		J	4	
22	An	0700	0711	65		3	9	
23	en	0700	0>15	22	7	3	9	
24	10	0700	6715	71	4	2	4	
25		0000	2715	89	2	3	4	
26	LW	8715	0730	57	2	4	2	
57	An	0715	6730	40	7	4	1	
31	En	0)15	0770	21	4	9	7	
35		2772	0730	18	7	9	8	
36	NB	07/5	0730	14	2	y	2	•

Attach Calibration Sheet Attach site map showing grid ID

Personnel: LEIS & WAOK ANTHONY DERELFAT  AARON MIBRIAGE NICH BENES  LENGS + REALDER
Date: 1-30-20 Instrument Used: 104 1000 Grid Spacing: 25'
Temperature: 59 Precip: 0 Upwind BG: 1-8 Downwind BG: 2.4

GRID ID	STAFF	START	STOP	тос	WII	ND INFOR	DEMARKS	
	INITIALS	TIME	TIME	PPM	AVG SPEED	MAX. SPEED	DIRECTION 16 POINT	REMARKS
37	LW	0730	0745	21	12	3	2	
41	Am	0230	0745	18	2	3	2	
42	en	0770	0745	14	2	3	12	
46	AD	6730	0745	26	1	2	2	
47	NB	0730	0745	16	d	3	2	
51	LW	0745	0800	20	2	3	1	
52	Am	0745	6800	24	7	3	3	
56	en	0745	0800	19		J	3	
55	AP	0745	0800	12	1	3	7	
60	NB	0)45	0860	88	d	7	3	
61	6W	0800	0815	64	2	3	4	
62	An	0880	0815	38	2	3	4	
63	en	0800	0815	52	7	3	4	
67	AP	0800	0815	47	7	3	9	
68	NB	0800	688	35		7	4	
69	LW	0815	0830	27		J	y	
>3	Ans	2872	6870	40	2	3	9	
> 4/	EN	2886	0820	23	2	2	9	
25	RP	9872	0830	46	,	7	9	
82	NB	5812	0830	39	2	3	4	
79	LW	0830	0845	58		~	3	
80		0830	0845	62		J	1	
81	en	2870	0845	15		3	3	
91	AP	0820	8885	72			3	
92	NB	0830	0845	64			J	
93	LW	2845	0900	52			2	
94	-	0845	6500	68	~		2	
102		0845	0500	40	0			
103		0845	0800	29		3	7	
104	NB	0845	0500	43	2	3	2	

Attach Calibration Sheet

Attach site map showing grid ID

Page 2 of >

Personnel: LEISH WAOK  AARON MURPIOE  BENESL PRIMINED	NICK BONICS
	ed: <u>4v41000</u> Grid Spacing: <u>25</u>
Temperature: Precip:	Upwind BG: /- 8 Downwind BG: Z.4

GRID ID	STAFF	START	STOP TIME	TOC PPM	WIN	ND INFOR	REMARKS	
	INITIALS	TIME			AVG SPEED	MAX. SPEED	DIRECTION 16 POINT	REMARKS
112	LW	0900	0915	39	2	3	¥	
113	AM	0900	0915	27	2	3	4	
114	ER	0500	0915	44	2	J	9	
115	AP	0900	6915	36	2	2	4	
123	NB	0900	0915	67	2	1	4	
124	6W	0915	0930	50	2	Ĩ	16	
125	An	0515	0972	31	2	J	16	
126	EN	0915	0570	46	2	3	1,6	
139	NO	0915	0530	20	1	13	16	
135	NB	0915	0530	31	2	3	16	
143	LW	0930	0945	46	2	J.	12	
144	Am	0530	0945	10>	4	J	12	
152	ER	0970	6845	45	L	J	12	
160	NP	0970	0585	32	2	J	12	
168	NB	0878	0545	24	2	3	12	
169	LW	0945	1000	51	d	3	12	
182	AM	0945	1860	19	2	2	1,2	
183	CR	0945	1000	24	2	J	12	
175	NP	0545	1000	32	2	J	12	
167	NB	0545	1660	29	2	3	12	
158	LW	1000	1015	66	2	7	11	
159	Mrs	1000	1015	81	4	3	11	
150	ER	1000	1015	129	7	3	11	
151	AP	1800	1815	99	2	3	11	
141	NB	1000	1815	34	2	4	11	
142	LW	1015	1030	48		3	12	
132	An	10/5	1030	20		3	12	
133	en	1815	1830	51	2	3	12	
12)	AP	1345	1030	36	2	1	12	
122	NB	18/5	1070	.08		1	12	

Attach Calibration Sheet

Attach site map showing grid ID

Page 3 of >

Personnel: LEISHWARE ANNOW MUBRIOF ERNEST RAMPEZ	NICK BENKS
Date: 1~30-20 Instrument	Used: <u>+v+1000</u> Grid Spacing: 25'
Temperature: <u>\$7</u> Precip:	D Upwind BG: /- 8 Downwind BG: 2, 4

GRID ID	STAFF INITIALS	START TIME	STOP TIME	TOC PPM	WIND INFORMATION			DEMARKS
					AVG SPEED	MAX. SPEED	DIRECTION 16 POINT	REMARKS
110	6W	1030	1045	32	2	3	10	
111	AM	1030	1045	26	2	3	b	
100	en	1000	1045	71	1	3	10	
101	Ap	1830	1845	44	7	3	10	
97	NB	1030	1045	32	2	1	10	
98	LW	1045	1100	28	2	3	9	
99	AM	1845	1/00	36	2	3	9	
107	en	1045	1/80	24	2	J	9	
108	AP	1845	1/00	55	2	.3	9	
109	NB	1345	1/00	62	2	1	9	
118	LW	1100	1115	94	2	3	b	
119	AM	1180	1115	57	2	1	10	
120	en	1100	1.115	32	2	3	10	
129	AP	1/60	1115	>1	2	)	b	
130	NB	1100	1115	34	d	3	10	
131	LW	1115	1130	22		3	11	
138	AM	1115	1130	28	2	)	1	
139	ER	1115	1130	41		)	li i	
140	AP	1115	1130	22	2	3	u	
47	NB	1115	1130	38			1/	
148	LW	1130	1145	84		J	11	
149	As	1130	1145	9)		3		
155	en.	1130	1145	63		3		
156		1170	1145	49	2	$\mathcal{C}$		
157	ND	1130	1145	82			11'	
164		1145	1200	47		9	II I	
65		1145	1200	113		4	li	
66	EN	1145	1200	54	3	9	11	
72	AP	1145	1200	67	7	9	II I	
73	NB	1195	1200	54	1 (	4	ii	

Attach Calibration Sheet Attach site map showing grid ID

Page 4 of 5

Personnel: LEISHWAOK  AARON MIBRIOZ- ENNEST RENIREN	ANTIONY PENCULIS
Date: 1-30-20 Instrument Us	ed: LUA 1000 Grid Spacing: 251
Temperature: <u>59</u> Precip:	Upwind BG: 1.8 Downwind BG: 2-4

GRID ID	STAFF	START	STOP	тос	WII	ND INFOR	MATION	DEMARKS
	INITIALS	TIME	TIME	PPM	AVG SPEED	MAX. SPEED	DIRECTION 16 POINT	REMARKS
174	LW	1200	1215	873	3	6	9	W#11210
179	AM	1200	1215	54	3	6	9	7,. 2, 5
180	OR	1200	1215	46	3	lo	9	
181	AP	1200	1215	60	3	6	G	
187	NB	1200	1215	16,000	3	b	9	WEI1 102
188	6W	1215	1230	44	4	le	9	
189	AM	1215	1200	70	de	b	9	
193	on	1215	1230	41	4	الم	9	
194	NP	12.15	1230	36	4	6	g	7,
195	NB	1215	1230	59	9	6	9	
199	LU	1230	1245	40	9	6	9	
200	An	1230	1245	23	4	6	19	
203	ER	1230	1245	18	4	b	9	
204	NB	1230	1245	26	4	6	S	
207	AP	1230	1245	15	4	6	9	
208	LU	1245	1300	31	4	8	9	
206	An	1245	1300	16	9	8	9	
202	EN	12.45	1300	2>	4	g	9	
197	NP	1245	1300	15	4	y	G	
198	NB	1245	1300	18	4	8'	q	
205	LW	1300	1315	4>	9	8	9	
201	AM	1300	1315	32	4	8	19	
96	en	1300	1315	15	4	X	9	
90	AP	1300	1345	18	Y	8	g	
191	NB	1300	1315	36	4	8	9	
92	LW	1315	1330	41	Ý	6	9	
184	Visi	13/5	1330	52	4.1	6	9	
185		1315	1330	39	Ý	6	q	
86	NO	1315	1338	25	91	6	9	
>6	NB	1315	1330	19	4		G	

Attach Calibration Sheet

Attach site map showing grid ID

Page \_\_\_\_\_ of \_\_\_\_\_

Personnel: LEISGWADE  AARON MUBRIDE  ERNESL RENIDEZ	NICK BENKS
Date: 1-30-20 Instrument Use	ed: <u>+v+1000</u> Grid Spacing: <u>25</u>
Temperature: $62$ Precip: $6$	Upwind BG: _/-8 Downwind BG: 2-9

GRID ID	STAFF	START	STOP	тос	IIW	ND INFOR	MATION	DEMARKS
	INITIALS	TIME	TIME TIME F		AVG SPEED	MAX. SPEED	DIRECTION 16 POINT	REMARKS
177	LW	1330	1345	22	4	8	10	
178	Am	1330	1345	59	9	8	lo	
170	En	1330	1345	36	4	8	b	
171	AD	1330	1345	フフ	9	8	10	
161	NB	1330	1345	54	9	8	10	
162	62	1345	1400	20	9	7	9	
123	Am	1345	1400	51	4	7	9	
153	en	1345	1400	71	9	7	9	
154	AP	1345	1400	99	9	7	9	
145	NB	1345	1400	50	9	7	9	
146	LW	1400	1415	107	Ý	6	il	
136	AM	1400	1415	32	40	b	1	
132	EN	1480	1415	>1	4	b		
127	NP	1400	140	20	4	6		
128	NB	1400	1415	81	9	6	1/	
116	1.W	1415	1430	19	4	8	12	
117	An	1415	1430	28	4	8	1,2	
105	th	1415	1430	16	9	0	17	
106	AD	1415	1430	45	4	Y	17	
95	NB	1415	1430	38	y	8	12	
96	LW	1430	1445	15	4	7	Ÿ.	
83	AM	1430	1441	11	4	)	9	
84	ER	1420	1445	1>	4	1	9	
85	AP	1470	1445	14	Ÿ	7	9	
86	NB	1430	1418	11	9	7	9	
82	LW	1445	1500	16	4	7	9	
88	AM	1445	1500	19	9	1	q	
76	en.	1445	1500	81	9	1	9	
70	AP	1445	1500	47	9	7	0	
54	NB	1445	1500	32	4 '	1	9	-

Attach Calibration Sheet

Attach site map showing grid ID

Personnel: LEIS 4 WAOZ  AMON MIRMAT  ERNES L REMIRED	NICHE BENJES
Date: <u>j-30-20</u> Instrument Us	ed: <u></u>
Temperature: <u>68</u> Precip:	O Upwind BG: 1.8 Downwind BG: 24

GRID ID	STAFF	START	STOP	тос	WI	ND INFOR	MATION	DEMARKS
	INITIALS	TIME	TIME	PPM	AVG SPEED	MAX. SPEED	DIRECTION 16 POINT	REMARKS
89	LW	1500	1515	52	9	6	9	
90	AM	1500	1515	49	9.	6	q	
לע	En	1500	1515	>1	9	T,	G	
78	AP	1500	1515	47	9	6	9	
71	NB	6500	1515	38	9	6	9	
72	24	1515	1530	91	Y	le	9	
65	Im	1515	1530	36	4	6	9	
66	EN	1515	1530	65	4	6	9	
58	AP	1515	1530	47	9	6	G	
59	NB	1515	1500	42	4	6	9	
53	LW	1530	1545	89	9	Le le	9	
54	An	1530	1545	76	9	b	9	
48	EN.	1530	1545	51	4	6	9	
49	AP	1530	1545	3>	4	6	9	
43	NB	1530	1545	68	Y	6	9	
44	LW	1545	1600	107	9	6	9	
38	As	1545	1600	51	4	6	9	
39	LN	1545	1600	140	9	b	9	
33	AXP	1545	1660	72	4	b	9	
34	NB	1545	1600	124	4	6	9	
28	LW	1600	1615	64	9	6	9	
29	AM	1600	1615	91	9	6	9	
		1						
	auntian Ch							

Attach Calibration Sheet Attach site map showing grid ID

Page \_\_\_\_\_\_ of \_\_\_\_\_

)ate: _/_	30-20	Instru	ment Used	d:;t		Gri	d Spacing:	
emperat	ture:	Pre	cip:	Up	wind BG:		Downv	vind BG:
GRID ID	STAFF	START	STOP	тос	WIN	ND INFORM	1ATION	REMARKS
	INITIALS	TIME		PPM	AVG SPEED	MAX. SPEED	DIRECTION 16 POINT	
30								Active ings.
35								1
40								
45								
50								
55								N
					-			
				1				
					15-14			
					4 _ 11			
						7		
- 4								
						3		
		- 1						

Attach Calibration Sheet Attach site map showing grid ID

#### **Attachment B**

Integrated Surface Emission Monitoring Event Records

# Table B.1 Integrated Landfill Surface Monitoring Exceedances and Monitoring Log

**2020 QUARTER**: 1


INITIAL MONITORING PERFORMED BY: RES

FOLLOW-UP MONITORING PERFORMED BY: S. Johnson

LANDFILL NAME: Redwood Landfill, Inc.

Initial I	Monitoring	Event	1st Re-mon Event - 10 Days			2nd Re-n	non Event		
Exceedance	Monitoring	Reading	Monitoring	Monitoring No Exced. No Exced. Monitoring No Exced. No				No Exced.	
Grid ID No.	Date	ppm	Date	<25 ppm	>25 ppm	Date	<25 ppm	>25 ppm	Comments

No Exceedances



DESCNED BY

SURFACE EMISSIONS MONITORING PROJECT NO 140521

**GRID MAP** 

Personnel: Long & WAD &	ANTHONY DURACHA	
FRNES L REMINEZ	NICIC BENIES	Cal. Gas Exp. Date: 9-21-20
Date: 1-29-20 Instrumer	nt Used: +JA1000 G	Grid Spacing:
Temperature: 6/ Precip:	Upwind BG: /-	8 Downwind BG: 2-4

GRID	STAFF	START	STOP	TOC	1IW	ND INFOR	RMATION	REMARKS
ID	INITIALS	TIME	TIME	PPM	AVG SPEED	MAX. SPEED	DIRECTION 16 POINT	KEMAKKS
ī	LW	1305	1330	3,89	3	5	12	
Z	AM	1305	1330	3.60	3	5	12	
3	en	1305	1330	4,15	3	5	1)_	
4	Apr	1305	1330	3.72	3	5	1)2	
5	NB	1305	1330	3.54	3	5	12	
6	LW	1330	1355	4-51	4	6	12	
7	AM	1330	1355	5.77	9	b	12	
8.	en	1330	1355	4.35	4	6,	12	
9	AP	1330	1355	5.58	4	6	12	
10	NB	1330	1355	4.12	4	6	12	
11	20	1355	1420	4.55	y	6.	1)	
12	AM	1755	1420	6.74	9	6	12	
13	en	1355	1420	5.90	9	6	12	
14	AP	1355	1428	4.82	9	6	12	
15	NB	1355	1420	7-35	4	6	12	
16	6W	1420	1445	8.12	9	6	9	
17	Am	1420	1445	6.45	Ÿ	6	9	
18	En	1420	1445	5.10	9	6	9	
19	AP	1420	1445	5.71	9	6	9	
20	NE	1420	1445	9.14	9	6	9	
21	LW	1445	1510	8-70	4	6	9	
22	An	1445	1510	6,32	Ÿ	6	9	
23	an	1445	1510	6-17	9	b	9	
24	AP	1445	1510	8-91	1 4	6	9	
25	NB	1445	1510	7-45	4	6	9'	
2.6	LW	1510	1535	5-42	9	6	9	
27	AM	1510	1535	3.98	Ý	6	4	
31	EVZ	1510	1535	6.76	4	6	q	
32	49	1510	15.32	5.32	Ÿ	6	9	
36	NB	1510	1535	7.28	y	6	9	

Attach Calibration Sheet Attach site map showing grid ID

Page \_\_/\_\_ of \_\_\_\_\_\_

### REDWOOD LANDFILL INTEGRATED LANDFILL SURFACE MONITORING

Personnel: LEISH WADE	ANTHONY PERSCHA	
ERNUST REMINE	NICK RONKS	Cal. Gas Exp. Date: <u>9-21-2</u> 0
	sed: 4v4/000 G	rid Spacing: 2.5
Temperature: 6.3 Precin:		

GRID	STAFF	START	STOP	тос	WIN	ID INFOR	RMATION	REMARKS
ID	INITIALS	TIME	TIME	PPM	AVG SPEED	MAX. SPEED	DIRECTION 16 POINT	KEMAKKS
37	LW	1535	1600	4.12	4	6	10	
417	AM	1535	1600	7-28	9	6	b	
42	en	1535	1600	5-51	4	6	10	
46	Ap	1535	1600	8.13	4	6	D	
47	NB	1535	1600	5.28	9	6	10	
51	LW	1600	1625	7.22	4	6	9	
52	Am	1600	1625	4.96	9	b	9	
56	ER	1600	1625	8.3/	9	b	9	
5>	Ap	1600	1625	5-46	4	6	9	
60	NB	1600	1625	7.91	9	6	9	
61	12W	1625	1650	5.27	9	6	10	
62	Am	1625	1650	5.70	40	6	10	
63	en	1625	1850	4.28	9	4	10	
67	AP	1625	1650	5.84	9	6	10	
68	NB	1625	1650	5-12	4	6	10	
69	LW	1650	1715	4.77	2	4	9	
73	AM	1650	1715	5.55	3	4	9	
74	ER	1650	1715	4.32	2	4.	9	
75	AP	1650	1715	5.04	3	9	9	
82	NB	1650	1715	5-29	3	4	9	
79	Lw	1715	1740	7.13	9	6	8	
80	AN	1715	1740	5.90	4	6	2	
8/	ER	1715	1740	6.67	9	4	Y	
91	AP	1715	171/0	8.30	9	6	ð	
92	NB	1715	1740	6-19	4	6	8	

Attach Calibration Sheet Attach site map showing grid ID

Page  $\frac{Z}{}$  of  $\frac{2}{}$ 

-								p. Date:
ate: <u>/</u> -	29-20	Instrume	nt Used: _			Grid S	Spacing: _	
emperat	ure:	Precip	:	_ Upwind	BG:		Downwin	d BG:
GRID	STAFF	START	STOP	тос	1IW	ND INFOR	MATION	REMARKS
ID	INITIALS	TIME	TIME	PPM	AVG SPEED	MAX. SPEED	DIRECTION 16 POINT	KEIMKO
30								Active thas
35								
40								
45						/ ===1		
50	//				0 -			
55								V
					1 = V			
	1							
								-
	1							
	1							
				-			-	
				4	11			
					-			

Attach Calibration Sheet Attach site map showing grid ID

Page \_\_\_\_\_\_\_\_ of \_\_\_\_\_\_

Personnel: LEIST NA.		ntheny penset	/-	
	Paninez	71616 1341010	Cal. Gas E	xp. Date: <u>9-21-20</u>
Date: /-30-28	Instrument Used:	LUA 1000	_ Grid Spacing: _	25'
Temperature: _>0	Precip:	Upwind BG: /	28 Downwir	nd BG: 2・4

GRID	STAFF	START	STOP	тос	WIN	ID INFOR	MATION	REMARKS
ID	INITIALS	TIME	TIME	PPM	AVG SPEED	MAX. SPEED	DIRECTION 16 POINT	
93	LW	1825	1650	6,2/	.4	6	10	
94	Am	1625	1650	5.34	90	6	10	
102	En-	1625	1650	7-18	9	0	10	
103		1625	1650	6.40	4	6	10	
104		1625	1650	6-06	9	6	10	
112	22	1650	1715	5.94	3	4	b	
113	Am	1650	1715	6-17	3	4	b	
114	ER	1650	1715	5.69	3	9	10	
115	AP	1850	1715	6.18	3	4	10	
123	NB	1650	1715	6.34	3	9	10	
124	LW	1715	1740	5.26	2	3	8	
125	13	1715	1740	5-19	7	)	8	
156	en	1715	1740	6.13	7	3	Υ,	
134	AP	1715	1740	5.51	7	3	X	
135	NB	1715	1740	5-20	2	7	8	
		/=						
		(I)						
						1		

Attach Calibration Sheet Attach site map showing grid ID

Page \_\_\_\_\_ of \_\_\_\_\_\_

#### REDWOOD LANDFILL INTEGRATED LANDFILL SURFACE MONITORING

Personnel: LEIS & WAOX

AND MIRRIOR NICLE BONKS

ENNES DE RINELLE

Cal. Gas Exp. Date: 9-21-20

Date: 1-31-20 Instrument Used: +valooo Grid Spacing: 25'

Temperature: 45 Precip: 0 Upwind BG: 1.8 Downwind BG: 2.4

GRID	STAFF	START	STOP	тос	WIND INFORMATION			REMARKS
ID	INITIALS	TIME	TIME	PPM	AVG SPEED	MAX. SPEED	DIRECTION 16 POINT	KEIMIKKO
143	LW	0550	0615	5.81	2	4	3	
144	Am	0550	2615	6.13	3	4	J	
152	En	0550	0615	6.81	J	9	3	
160	AM	0550	0615	5.39	3	4	J	
168	NB	0550	0615	4.22	3	7	3	
169	CW	2615	0640	5-10	2	5	2	
182	Im	8615	0640	4.77	2	5	2	
183	on	0615	0640	5.54	7	3	2	
195	NO	0615	0640	6.13	7	5	æ	
167	NB	0615	0640	5.91	2	5	7	
118	LW	0640	0765	6.37	2	J	2	
159	An	0640	0705	6-92	2	)	1	
150	EN	0640	0)05	10.24	2	2	2	
151	NP	0640	6705	13.7/	1	J	2	
141	NB	0840	0)05	6.54	1	7	2	
142	62	0705	0770	7-18	2	3	7	
132	An	0705	0730	5.45	2	3	2	
133	En	0705	0730	6.03	d	3	7	
12/	AP	0705	0730	5.58	1	3	1	
122	NB	0)05	0730	7.13	2	3	7	
11 D	LW	6730	0755	6.90	3	4	4	
111	AM	0730	0755	5.84	3	4	4	
100	en	0730	0755	7.26	3	4	4	
101	NP	0730	0755	6-81	7	4	4	
97	NB	0730	0755	5.40	3	4	4	
98	6W	0755	0820	5-26	2	3	3	
99	1200	0>55	0820	6.3/	2	3	3	
107	EN	0755	0820	5-25	1	3	2	
108	AP	0755	0820	4.26	2	3	3	
109	NB	0>55	0820	5-05	2	3	3	

Attach Calibration Sheet

Attach site map showing grid ID

Page \_\_\_\_\_ of \_\_\_\_\_

Personnel: LEICH WADE	Anthory PERCEPA	
AMON ACRAIDE	NICK BENKS	
ERNUSL REMINEZ		Cal. Gas Exp. Date: 9-21-20

Date: 1-3/-20 Instrument Used:  $\frac{1}{2}$  Grid Spacing:  $\frac{2}{2}$ 

Temperature: 49 Precip: D Upwind BG: 1-8 Downwind BG: 2.4

GRID	STAFF	START	STOP	тос	WIND INFORMATION			REMARKS
ID	INITIALS	TIME	TIME	PPM	AVG SPEED	MAX. SPEED	DIRECTION 16 POINT	KLMAKKS
118	LW	0820	0845	4.72	2	5	4	
119	Am	0820	0845	5-07	2	5	4	
120	ER	0820	0845	4-95	7	5	4	
129	AP	0859	0845	6.13	1	5	9	
130	NB	0820	0845	5.50	2	5	4	
131	LW	0845	0910	7-38	3	5	7	
138	100	0845	8910	6.55	3	5	7	
139	en	0845	0910	6-29	2	5	1	
140	AP	0845	0510	5-51	2	5	1	
147	NB	0845	0910	8.75	3	5	7	
148	LW	0910	0935	6.91	2	4	7	
145	11	0910	0935	6.14	1	9	7	
155	En	0910	0535	7.21	1	9	7	
156	AP	0910	0535	6.84	2	14	7	
157	NB	0910	0535	8.20	2	9	勺	
169	LW	0935	1000	8,13	2	1	4	
165	AM	0935	1000	7-21	1	]	9	
166	en	0535	1000	8.40	1	3	9	
172	AP	052	1000	6.91	1 2	7	4	
173	NB	0535	1000	7-55	2	3	4	
174	LW	1000	1025	8.13	2	1	j	
179	AM	1000	1025	6.47	1	3		
180	en	1000	1025	6.28	7	7		
18/	110	1000	1825	7-1/	2	3	1	
187	NB	1000	1825	6.41	2	3	1	
188	60	1025	1050	5.32	x	J	12	
189	nm	1025	1050	5-15	2	7	12	
193	され	1025	1850	6.37	1	3		
184	A.P	1025	1050	5.45	2	3	12	
155	as	1025	1850	6-76	2	3	12	

Attach Calibration Sheet Attach site map showing grid ID

Page  $\frac{2}{\sqrt{2}}$  of  $\frac{1}{\sqrt{2}}$ 

Personnel: LEISHUNDE	NILLE BENKS	-
ETWEST REAINER	70.000	Cal. Gas Exp. Date: <u>9-21-20</u>
Date: /-3/-20 Instrument Us	sed: <u> </u>	rid Spacing: 25/
Temperature: Precip:	D Upwind BG: 1,4	Downwind BG: 214

GRID	STAFF	START	STOP TIME	тос	WIND INFORMATION			REMARKS
ID	INITIALS	TIME		PPM	AVG SPEED	MAX. SPEED	DIRECTION 16 POINT	KEMAKKS
189	LW	1050	1115	5.36	2	4	9	
200	AM	1050	1115	5-72	2	9	9	-
203	en	1050	1115	6.17	2	4	9	
204	10	1050	1115	5.51	人	9	9	
207	NB	1850	1115	5.38	2	4	9	
208	LW	1/15	1140	5.96	3	5	1)	
206	1.m	1115	1140	6.13	3	5	U	
202	en	1115	1140	5.69	3	5	V	
197	NP	1115	1140	4.21	2	5	11	
198	NB	11/5	1140	5-38	3	5	11	
205	(W	1140	1285	4.15	2	4	U	
201	nn	1140	1205	3.76	2	14	11	
196	en	1140	1205	3.24	1	4	1)	
190	MP	1140	1205	4.07	2	4	111	
191	NB	1140	1205	5.16	2	4	1/	
192	LN	1205	1230	5-28	3	4	12	
184	AM	1205	1230	4.51	13	9	12	
185	en	1205	1230	5-23	3	4	12	
186	NP	1205	1230	6-90	2	4	12	
176	NB	1205	1270	4-28	3	4	12	
/ブフ	(W	1200	1255	5.28	2	3	12	
178	113	1230	1255	4.61	2	2	12	
170	ER	1270	12.55	5.70	2	2	12	
17)	AP	12.30	1255	6.13	2	3	12	
161	NO	1230	1255	4.28	2	3	12	
162	22	1255	1320	5-94	2	4	9	
163	Ans	1255	1320	7.26	2	14	9	
153	m	1255	1320	6.8)	2	4	2	
154	NP	1255	1320	8-50	7	9	9	
145	as	1255	1328	5.27	2	4	9	

Attach Calibration Sheet Attach site map showing grid ID

Page <u>J</u> of <u>S</u>

### REDWOOD LANDFILL INTEGRATED LANDFILL SURFACE MONITORING

Personnel: Land WAOt	AN/hany pences	
AARON MUBRIDY	NICK BENKS	Cal Cas Fire Pater (12) 2
ENNEST REMIREZ	_	Cal. Gas Exp. Date: <u>9-21-20</u>
Date: <u>/- 3/ - 20</u> Instrumer	nt Used: <u>Lua 1600</u> Gi	rid Spacing: 25/
Temperature: 62 Precin	D Unwind BG: / S	Downwind BG: 7-4

GRID	STAFF	START	STOP	STOP TOC	WIND INFORMATION			REMARKS
ID	INITIALS	TIME	TIME	PPM	AVG SPEED	MAX. SPEED	DIRECTION 16 POINT	11211111110
146	LW	1320	1345	9.14	2	4	9	
136	AM	1320	1375	5.71	J	9	9	
13>	EN	1320	1345	6.89	2	9	9	
127	AP	1320	1345	5.42	2	4	9	
128	NB	1320	1345	4-76	2	4	9	
116	LW	1345	1410	5.18	2	4	9	
117	AM	1345	1410	9.51	L	4	9	
105	5N	1345	1410	5-37	7	9	9	
106	AP	1345	1410	4.76	2	4	9	
95	NB	1345	1410	4.10	2	4	9	
96	LW	1410	1435	3.82	2	4	11	
83	1m	1410	1405	4.15	1	4	l U	
84	in	1410	1425	3.67	7	9	11	
82	NP	1410	1435	4.14	1	4	$\eta$	
86	NB	1410	1435	3.89	2	4	1/	
(8	LW	1435	1500	4.50	3	5	9	
88	AM	1475	1500	4.70	3	5	9	
89	GR	1475	1500	6.35	3	5	9	
90	NO	1435	1500	6.84	2	5	9	
76	NB	1435	1500	5.51	3	5	9	
7>	LU	1500	1525	7-13	3	4	9	
ラを	M	1500	1525	5-89	1	4	9	
70	en	1500	1525	4-57	1	4	9	
7/	NP	1500	1525	6-13	2	4	C)	
72	NB	1508	1525	7.30	]	4	9	
64	LW	1525	1550	5.58	8	5	9	
65	1 m	1525	1550	8-13	3	5	9	
66	th	1525	1550	6.47	3	5	9	
58	AP	1525	1550	6-21	13	5	C	
59	NB	1525	1550	9.46	3	5	9	

Attach Calibration Sheet Attach site map showing grid ID

Page  $\frac{9}{2}$  of  $\frac{5}{2}$ 

### REDWOOD LANDFILL INTEGRATED LANDFILL SURFACE MONITORING

Personnel: LEISHWAOK	Autlony poracta	
Ennest renner	wick Benles	Cal. Gas Exp. Date: <u>9-2/-2</u> p
Date: <u>/~3/-20</u> Instrument U	lsed: <u> </u>	rid Spacing:
Temperature: _65 Precip:	D Upwind BG: 1/8	Downwind BG: 2-4

GRID	STAFF	START	STOP	тос	WIN	ND INFOR	RMATION	REMARKS
ID	INITIALS	TIME	TIME	PPM	AVG SPEED	MAX. SPEED	DIRECTION 16 POINT	
53	LW	1550	1615	5.87	3	5	9	
54	AM	1550	1615	7-33	3	4	9	
48	EN	1550	1615	5-51	2	5	9	
49	AP	1550	1615	6-79	2	7	9	
43	ND	1550	1615	5.45	3	5	9	
44	LW	1615	1640	8-22	1 4	7	12	
38	An	1615	1640	6.17	1 4	7	12	
35	en	1615	1640	8.50	4	1	2	
33	AP	1615	1640	6-01	9	1	12	
34	NB	1615	1648	9.57	1	7	11	
28	LW	1640	1705	7-11	19	Ĵ	12	
25	AM	1640	1705	8.44	14	7	12	
						1 1 1 1		
				1				
				4				
					1			
						LE		

Attach Calibration Sheet Attach site map showing grid ID

Page S of S

#### **Attachment C**

Component Leak Monitoring Event Records

# Table C.1 AB-32 Component Leak Monitoring Summary of Component Leaks Greater than 500 ppmv

**2020 QUARTER**: 1

INITIAL MONITORING PERFORMED BY: RES

FOLLOW-UP MONITORING PERFORMED BY: S. Johnson

LANDFILL NAME: Redwood Landfill, Inc.

Location	Initial Monitoring			C	Corrective Action	10-Day Remonitoring			
	Date	TOC (ppmv)	Tech	Date	Description	Date	TOC (ppmv)	Tech	
	No Exceedances Detected								

#### Table C.2

#### BAAQMD Component Leak Monitoring Summary of Component Leaks Greater than 1,000 ppmv

**2020 QUARTER**: 1

INITIAL MONITORING PERFORMED BY: RES

FOLLOW-UP MONITORING PERFORMED BY: S. Johnson

LANDFILL NAME: Redwood Landfill, Inc.

Location	Initial Monitoring			Corrective Action		7-Day Remonitoring			
Location	Date	TOC (ppmv)	Tech	Date	Description	Date	TOC (ppmv)	Tech	
	No Exceedances Detected								

### REDWOOD 3520+ ENGINE PLANT, CA



LANDFILL NAME:  $\mathcal{RED} \bowtie \circ \mathcal{O}$  QUARTERLY LFG COMPONENT LEAK MONITORING

INSTRUMENT

FID

MAKE: Thermo Environr MODEL: TVA 1000

S/N: 1036346773


DATE OF SAMPLING: 1-30-2 D TECHNICIAN: LEISH WAD L


				1 2				
LOCATION OF LEAK	LEAK CONCENTRATION (ppmv)	DATE OF DISCOVERY	TECHNICIAN	ACTION TAKEN TO REPAIR LEAK	DATE OF REPAIR	DATE OF ANY REQUIRED RE- MONITORING	RE-MONITORED CONCENTRATION (ppmv)	
NOTREGEDENCES								
			S					
N.								
-								


In the event that an exceedance is detected, please intiate corrective action and re-monitor the exceedance location within 7 days of the initial exceedance.


NOTE: Leaks over 500 ppmv methane are exceedances at any component containing landfill gas, pursuant to CARB Title 17 of California Code of Regulations Subchapter 10, Article 4, Subarticle 6, Section 95464(b)(1)(B).


NOTE: Leaks over 1,000 ppmv methane are exceedances at any component containing landfill gas, pursuant to BAAQMD Regulation 8-34-301.2.
















#### Attachment D


Weather Station Data




	16-POINT WIND DIRECTION INDEX							
NO.	DIRECTION		DEGREES					
		FROM	CENTER	<u>TO</u>				
16	NORTH (N)	348.8	369.0	t .1.3				
1	NORTH-NORTHEAST (NNE)	011.3	022.5	033.8				
2	NORTHEAST (NE)	033,8	045.0	056.3				
3	EAST-NORTHEAST (ENE)	056.3	<u>067.5</u>	078.8				
4	EAST (E)	078.8	090.0	101.3				
5	EAST-SOUTHEAST (ESE)	101.3	112.5	123.8				
6	SOUTHEAST (SE)	123.8	<u>135.0</u>	146.3				
7	SOUTH-SOUTHEAST (SSE)	146.3	<u>157.5</u>	168.8				
8	SOUTH (S)	168.8	180.0	191.3				
9	SOUTH-SOUTHWEST (SSW)	191.3	202.5	213.8				
10	SOUTHWEST (SW)	213.8	225.0	236.3				
11	WEST-SOUTHWEST (WSW)	236.3	<u>247.</u> 5	258.8				
12	WEST (W)	258.8	270.0	281.3				
13	WEST-NORTHWEST (WNW)	281.3	292.5	303.8				
14	NORTHWEST (NW)	30.1.8	315.0	326.3				
15	NORTH-NORTHWEST (NNW)	326.3	337.5	348.8				









#### Attachment E

Calibration Records

#### CALIBRATION PRECISION TEST RECORD

Date: 2/4/2020

Expiration Date (3 months): 5/7/2020

Time: \_\_\_\_ AM \_\_/250 PM

Instrument Make: Aut uc Model: Mus FTO S/N: L&WF340

Measurement #1:

Meter Reading for Zero Air: 0.3 ppm (a)

Meter Reading for Calibration Gas: 499.7 ppm (b)

Measurement #2:

Meter Reading for Zero Air: \_\_\_\_\_\_ ppm (c)

Meter Reading for Calibration Gas: 497.7 ppm (d)

Measurement #3:

Meter Reading for Zero Air: 0.5 ppm (e)

Meter Reading for Calibration Gas: 497.5 ppm (f)

Calculate Precision:

 $\frac{\{|(500) - (b)| + |(500) - (d)| + |(500) - (f)|\}}{3} \times \frac{1}{500} \times 100$ 

0.32 % (must be < than 10%)

Performed By:

#### RESPONSE TIME TEST RECORD

Date: 2/4/2020

Expiration Date (3 months): 5/7/2020

Time: \_\_\_\_ AM \_\_/250 PM

Instrument Make: Photonic Model: Mich FIO S/N: CZMF340

Measurement #1:

Stabilized Reading Using Calibration Gas: 500. / ppm 90% of the Stabilized Reading: 90% of the Stabilized Reading:

Time to Reach 90% of Stabilized Reading after switching from Zero Air to Calibration Gas: \_\_\_\_\_\_ seconds (a)

Measurement #2:

Stabilized Reading Using Calibration Gas: 500. 2 ppm 90% of the Stabilized Reading: 950. 18 ppm Time to Reach 90% of Stabilized Reading after

3 \_\_ seconds (b) switching from Zero Air to Calibration Gas:

Measurement #3:

Stabilized Reading Using Calibration Gas: 417.4 ppm 90% of the Stabilized Reading: 447.46 ppm Time to Reach 90% of Stabilized Reading after

switching from Zero Air to Calibration Gas: 2 seconds (c)

Calculate Response Time:

 $\frac{(a) + (b) + (c)}{3} = \frac{2.33}{\text{seconds (must be less than 30 seconds)}}$ Performed By:

# CALIBRATION PROCEDURE AND BACKGROUND DETERMINATION REPORT

Landfill Name! Rulevard Carle! Date: 2/7/2020

Time: \_\_\_\_ AM \_/250 PM

Instrument Make: Photocac Model: Micro FIO S/N: \_C2MF 350

#### Calibration Procedure

- 1. Allow instrument to internally zero itself while introducing zero air.
- 2. Introduce the calibration gas into the probe.

Stable Reading = 500,3 ppm

3. Adjust meter to read 500 ppm.

#### Background Determination Procedure

- 1. Upwind Reading (highest in 30 seconds): \_\_\_\_\_\_ ppm (a)
- 2. Downwind Reading (highest in 30 seconds): \_\_\_\_\_\_ ppm (b)

Calculate Background Value:

$$\frac{(a) + (b)}{2} \quad \text{Background} = \frac{0.25}{\text{ppm}}$$

Performed By:

#### CALIBRATION PROCEDURE AND BACKGROUND **DETERMINATION REPORT**

Landfill Name: Reduced Landfill Date: 2/27/20

Time: //20 AM \_\_\_\_ PM

Instrument Make: Photovac Model: MIUDFID SN: CZMF340

#### Calibration Procedure

- 1. Allow instrument to internally zero itself while introducing zero air.
- 2. Introduce the calibration gas into the probe.

3. Adjust meter to read 500 ppm.

#### Background Determination Procedure

1. Upwind Reading (highest in 30 seconds):

2. Downwind Reading (highest in 30 seconds):

Calculate Background Value:

(a) + (b) Background = 
$$0.3$$
 ppm

Performed By:



LANDFILL NAME: 12 80 h	100P	11	NSTRUME	ENT MAKE: _ flere o
MODEL: LUA 1000	EQUIPMENT #: _			SERIAL #: /036346777
MONITORING DATE: _/-	30-20		TIME:	0555

#### Calibration Procedure:

1. Allow instrument to zero itself while introducing air.

2. Introduce calibration gas into the probe. Stabilized reading = 500 ppm

Adjust meter settings to read 500 ppm.

#### Background Determination Procedure

Upwind Background Reading: (Highest in 30 seconds)	Downwind Background Reading: (Highest in 30 seconds)	Background Value:  (Upwind + Downwind) 2
1.8 ppm	7.4 ppm	7./ ppm

Background Value = 2./ ppm

#### INSTRUMENT RESPONSE TIME RECORD

Measurement #	Stabilized Reading Using Calibration Gas		90% of the Stabil Reading	ized	Time to Reach 90% of Stabilized Reading after switching from Zero Air to Calibration Gas	
#1	490	ppm	440	ppm	7	
#2	500	ppm	450	ppm	7	
#3	500	ppm	450	ppm	>	
	Calculate Response	Time ( <u>1</u> 4	·2+ <u>3</u> )		#DIV	

#### CALIBRATION PRECISION RECORD

Calibration Gas Standard = 500 ppm

Measurement#	Meter Reading for 2	ero Air (A)	Meter Reading for Calibration Gas (B)		Calculate Precision [STD -	
#1	0.41	ppm	490	ppm	10	
#2	0.27	ppm	500	ppm	70	
#3	0.18	ppm	500	ppm	>	
Calculate Precisio	n [STD-B1] + [S	3 3	500 STD-B3] X 1 3	1 100	O-66	#DIV/0!

Performed By: 68155W10E Date/Time: 1-30-20 - 0555



LANDFILL NAME: 1200000		INSTRUME	ENT MAKE: Affen no
MODEL: 40 A 1000	EQUIPMENT #:/_		SERIAL #: 1036396779
MONITORING DATE: 1-30-20		TIME: _	0555

#### Calibration Procedure:

Allow instrument to zero itself while introducing air.

2. Introduce calibration gas into the probe. Stabilized reading = 560 ppm

Adjust meter settings to read 500 ppm.

## Background Determination Procedure

Upwind Background Reading: (Highest in 30 seconds)	Downwind Background Reading: (Highest in 30 seconds)	Background Value:  (Upwind + Downwind) 2
/ - F ppm	2.4 ppm	7./ ppm

Background Value = 2./ ppm

### INSTRUMENT RESPONSE TIME RECORD

Measurement#	Stabilized Reading Calibration Gas	90% of the Stabi Reading	lized	Time to Reach 90% of Stabilized Reading after switching from Zero Air to Calibration Gas		
#1	487	ppm	437	ppm	>	
#2	498	ppm	948	ppm	2	
#3	500	ppm	450	ppm	2	
	Calculate Response T	ime ( <u>11</u>	+2+3)		> Must be less than	#DIV/0!

#### CALIBRATION PRECISION RECORD

Calibration Gas Standard = 500 ppm

Measurement #	Meter Reading for Z	Meter Reading for Zero Air (A)		g for as (B)	Calculate Precision [STD - (B)]
#1	0-36	ppm	487	ppm	1.5
#2	0-14	ppm	458	ppm	2
#3	0.08	ppm	500	ppm	8
Calculate Precisio	n <u>[STD-B1] + [S</u>	3 3	5TD-B3] X 1 X 500	100	/_ > #DIV/0! Must be less than 10%

Performed By: Anthony penactor

Date/Time: 1-30-20 -0555



LANDFILL NAME: 1200 L	1000	 NSTRUME	ENT MAKE: +HERRO
MODEL: FUA 1000	EQUIPMENT #:		SERIAL #: 103624674/
MONITORING DATE: /-	30-20	TIME:	0555

#### Calibration Procedure:

Allow instrument to zero itself while introducing air.

Introduce calibration gas into the probe. Stabilized reading = 500
 Adjust meter settings to read 500 ppm.

## Background Determination Procedure

Upwind Backgro Reading: (Highest in 30 sec		Downwind Bac Reading: (Highest in 30 se		Background Va	
118	ppm	2.4	ppm	7.1	ppm

Background Value = 2./ ppm

### INSTRUMENT RESPONSE TIME RECORD

Measurement #	Stabilized Reading Using Calibration Gas		90% of the Stabi Reading	lized	Time to Reach 90% of Stabilized Reading after switching from Zero Air to Calibration Gas	
#1	504	ppm	454	ppm	6	
#2	499	ppm	449	ppm	6	
#3	500	ppm	450	ppm	6	
	Calculate Response	Time (14 3	<del>-2+3</del> )		Must be less than	#DIV/0!

### CALIBRATION PRECISION RECORD

Measurement #	Meter Reading for	Zero Air (A)	Meter Reading for Calibration Gas (B)		Calculate Precision	[STD - (B)]
#1	0-3/	ppm	584	ppm	- 22	
#2	0.20	ppm	475	ppm	9	
#3	0-15	ppm	500	ppm	2	-
Calculate Precisio	n [STD-B1] + [	STD-B2] + [S	5TD-B3] X 1 X 500	100 1	0.33	#DIV/0!
		3		1	O. 33 Must be less tha	n

Performed By: AARON MEBRIDE	Date/Time: 1-30-20-0550	
-----------------------------	-------------------------	--



LANDFILL NAME: AGDIVEDD		_INSTRUM	ENT MAKE: +Herro
MODEL: +VALOOD E	QUIPMENT #:/		SERIAL #: //02746775
MONITORING DATE: 1-30-20		TIME:	6550

#### Calibration Procedure:

1. Allow instrument to zero itself while introducing dir.

2. Introduce calibration gas into the probe. Stabilized reading = 500 ppm

3. Adjust meter settings to read 500 ppm.

# Background Determination Procedure

Reading:		Downwind Background Reading: (Highest in 30 seconds)		Background Va	
1.8	ppm	204	ppm	2./	ppm

Background Value = 21/ ppm

### INSTRUMENT RESPONSE TIME RECORD

Measurement #	Stabilized Reading Using Calibration Gas		Calibration Gas   90% of the Stabilized   Reading		Time to Reach 90% of Stabilized Reading after switching from Zero Air to Calibration Gas	
	494	ppm	444	ppm	5	
#2	501	ppm	451	ppm	5	
#3	500	ppm	450	ppm	· ·	
	Calculate Response Tim	e ( <u>1</u> 4	-2+3)		#DIV/0! Must be less than 30 seconds	

#### CALIBRATION PRECISION RECORD

Calibration Gas Standard = 500 ppm

Measurement #	Meter Reading for Z	ero Air (A)	Meter Reading Calibration Gas		Calculate Precision	[STD - (B)]
#1	0.47	ppm	494	ppm		
#2	0-22	ppm	501	ppm	/	
#3	0-11	ppm	500	ppm		***
Calculate Precision	[STD-B1] + [S	3 3		100 1	O - 76 Must be less that	#DIV/0!

Performed By: BRNIST Ran MAN Date/Time: 1-30-20 - 0555



LANDFILL NAME: REDWOOT	0	 NSTRUMENT MAKE: +Henno
MODEL: LUATOD	EQUIPMENT #: _	SERIAL #: /036346772
MONITORING DATE: 1-30	-20	TIME: 0555

#### Calibration Procedure:

1. Allow instrument to zero itself while introducing air.

2. Introduce calibration gas into the probe. Stabilized reading = 500 ppm

3. Adjust meter settings to read 500 ppm.

#### **Background Determination Procedure**

Upwind Background Reading: (Highest in 30 seconds)	Downwind Background Reading: (Highest in 30 seconds)	Background Value:  (Upwind + Downwind) 2
/. 8 ppm	2.4 ppm	2-/ ppm

Background Value = 2./ ppm

#### INSTRUMENT RESPONSE TIME RECORD

Measurement #	Calibration Gas Reading		lized	Stabilized Read	to Reach 90% of illized Reading after ching from Zero Air to pration Gas	
#1	495	ppm	445	ppm	6	
#2	500	ppm	450	ppm	6	
#3	500	ppm	450	bồm	1	
	Calculate Response	Time (14	+2+3)	-	Must be less than	#DIV/0!

#### CALIBRATION PRECISION RECORD

Measurement #	Meter Reading for Zo	ero Air (A)	Meter Reading Calibration Ga		Calculate Precision	[STD - (B)]
#1	0.26	ppm	995	ppm		
#2	0-19	ppm	500	ppm	3	
#3	0 2 14	ppm	500	ppm	Ô	-
Calculate Precision	[STD-B1] + [S	TD-B2] + [S	5TD-B3] X 1 X 500	100	0.33	#DIV/0!
					Must be less that	n 10%

Performed By: <u>Rick Bonks</u>	Date/Time: /-30-20 -0555	
---------------------------------	--------------------------	--



LANDFILL NAME: REDWOOD		INSTRUME	NT MAKE: _ +HGRMO
MODEL: LUA 1000 E	QUIPMENT #:	10	SERIAL #: 1036346773
MONITORING DATE: 1-29-	20	TIME:	1700

#### Calibration Procedure:

1. Allow instrument to zero itself while introducing air.

2. Introduce calibration gas into the probe. Stabilized reading = 25 ppm

3. Adjust meter settings to read 25 ppm.

#### **Background Determination Procedure**

Upwind Background Reading: (Highest in 30 seconds)	Downwind Background Reading: (Highest in 30 seconds)	Background Value:  (Upwind + Downwind) 2
/, 8 ppm	2. 4 ppm	ZL/ ppm

Background Value = 2. / ppm

#### INSTRUMENT RESPONSE TIME RECORD

Measurement #	Stabilized Reading Using Calibration Gas		90% of the Stabili Reading	zed	Time to Reach 90% of Stabilized Reading after switching from Zero Air to Calibration Gas	
#1	24	ppm	21-6	ppm	フ	
#2	25	ppm	22.5	ppm	7	
#3	25	ppm	22.5	ppm	7	
	Calculate Response	Time ( <u>1</u> -	+2+3)		7	#DIV/0!
					Must be less tha	n 30 seconds

#### CALIBRATION PRECISION RECORD

Meter Reading for Zero Air (A) Meter Reading for Calibration Gas (B)		Calculate Precision	[STD - (B)]		
0.41	ppm	24	ppm	/	_
0.26	ppm	25	ppm	0	
0-14	ppm	25	ppm	8	-
n [STD-B1] + [S	3 3 TD-B2] + [5		X <u>100</u> 1	, 1-3	#DIV/0!
	0.41	0.41 ppm 0.26 ppm 0-14 ppm	Calibration G  0.4/ ppm 2.4  0.26 ppm 2.5  0-14 ppm 2.5  [STD-B1] + [STD-B2] + [STD-B3] X 1	Calibration Gas (B)         O · 4/       ppm       Z · 4       ppm         O · 2 · 6       ppm       Z · 5       ppm         O · 1 · 4       ppm       Z · 5       ppm         O · 1 · 4       ppm       Z · 5       ppm         ISTD-B1] + [STD-B2] + [STD-B3] X · 1 X · 100       X · 1 X · 100	Calibration Gas (B)  O · 4// ppm Z 4 ppm /  O · 2 6 ppm Z 5 ppm O  O · 1 4 ppm Z 5 ppm 8  [STD-B1] + [STD-B2] + [STD-B3] X 1 X 100 2 3 3

Performed By: Leishwao D	Date/Time:_	1-29-20	-1300
--------------------------	-------------	---------	-------



LANDFILL NAME: PEDWOOD		IN	_INSTRUMENT MAKE: +HERNO			
MODEL: LVA1000	EQUIPMENT #:	//		SERIAL #: 1036346779		
MONITORING DATE: 1-29-12	>		TIME:	1300		

#### Calibration Procedure:

Allow instrument to zero itself while introducing air.
 Introduce calibration gas into the probe. Stabilized reading = 25 ppm

3. Adjust meter settings to read 25 ppm.

#### **Background Determination Procedure**

Upwind Background Reading: (Highest in 30 seconds)	Downwind Background Reading: (Highest in 30 seconds)	Background Value:  (Upwind + Downwind) 2
/-8 ppm	2.4 ppm	2. / ppm

Background Value = 2./ ppm

#### INSTRUMENT RESPONSE TIME RECORD

Measurement #	Stabilized Reading Using Calibration Gas		90% of the Stabilize Reading	zed	Time to Reach 90% of Stabilized Reading after switching from Zero Air to Calibration Gas	
#1	23	ppm	20.7	ppm	7	
#2	25	ppm	225	ppm	>	
#3	25	ppm	22,5	ppm	2	
	Calculate Response	Time ( <u>1</u> -	<u>+2+3</u> )		7	#DIV/0!
					Must be less than	30 seconds

#### CALIBRATION PRECISION RECORD

Measurement #	Meter Reading for Z	eter Reading for Zero Air (A)		Meter Reading for Calibration Gas (B)		[STD - (B)]
#1	6.45	ppm	27	ppm	7	
#2	0.31	ppm	25	ppm	0	
#3	6-13	ppm	25	ppm	0	
Calculate Precision	STD-B1] + [S	3 std-B2] + [5	STD-B3] X 1 ) 25	1 100 1	. 2-6	#DIV/0
					Must be less th	an 10%

Performed By:	ANTHONY	Denseta	Date/Time:	1-29-20	-1300
	/	p c c c c	Date/Time:	1 21	, -



LANDFILL NAME: RED WOOD		INSTRUMENT MAKE:				
MODEL: _ + 1000	EQUIPMENT #:	12	SERIAL #:_	1036246741		
MONITORING DATE: 1-25-	-20	TIME:	1300			

#### **Calibration Procedure:**

- Allow instrument to zero itself while introducing air.
   Introduce calibration gas into the probe. Stabilized reading = \_\_\_\_\_\_\_ ppr
- 3. Adjust meter settings to read 25 ppm.

#### **Background Determination Procedure**

Upwind Background Reading: (Highest in 30 seconds)	Downwind Background Reading: (Highest in 30 seconds)	Background Value:  (Upwind + Downwind) 2	
) - 8 ppm	2.4 ppm	2.1 ppm	

Background Value = 2.1 ppm

#### INSTRUMENT RESPONSE TIME RECORD

Measurement #	Stabilized Reading Using Calibration Gas		90% of the Stabil Reading	ized	Time to Reach 90% of Stabilized Reading after switching from Zero Air to Calibration Gas	
#1	24	ppm	21.6	ppm	6	-
#2	24	ppm	21.6	ppm	6	
#3	25	ppm	22.5	ppm	6	
	6	#DIV/0!				
					Must be less than	30 seconds

#### CALIBRATION PRECISION RECORD

Measurement #	including for		Meter Reading for Zero Air (A) Meter Reading for Calibration Gas (B)		_	Calculate Precision	[STD - (B)]
#1	0.38	ppm	24	ppm	1		
#2	0.22	ppm	24	ppm	1		
#3	0-16	ppm	25	ppm	0		
Calculate Precision	[STD-B1] + [S	TD-B2] + [5 3	STD-B3] X <u>1</u> 25	X <u>100</u> 1	. 2.6	#DIV/0!	
					Must be less that	an 10%	

Performed By: AARON MUBRIDE	Date/Time:	1-29-20-1300



LANDFILL NAME: 100000	INSTRUMEN	NT MAKE: HHER 10
MODEL: 404 1000 EQUIPMENT #:	13	SERIAL #: 1162746775
MONITORING DATE: _ /~ 2ら-2つ	TIME:	1300

#### Calibration Procedure:

Allow instrument to zero itself while introducing air.
 Introduce calibration gas into the probe. Stabilized reading = 25 ppm

3. Adjust meter settings to read 25 ppm.

#### **Background Determination Procedure**

Upwind Backgro Reading: (Highest in 30 sec	11	Downwind Background Reading: (Highest in 30 seconds)		Background Val	
1-8	ppm	2.4	ppm	7.1	ppm

Background Value = 2./ ppm

#### INSTRUMENT RESPONSE TIME RECORD

Measurement #	Stabilized Read Calibration Gas		90% of the Stabi Reading	lized	Time to Reach 9 Stabilized Readi switching from 2 Calibration Gas	ing after Zero Air to
#1	23	ppm	20.7	ppm	5	
#2	24	ppm	21.6	ppm	5	
#3	25	ppm	72.5	ppm	5	
	Calculate Respons	e Time ( <u>1</u> -	+2+3)		5	#DIV/0!
					Must be less than	30 seconds

#### CALIBRATION PRECISION RECORD

Calibration Gas Standard = 25 ppm

Meter Reading for Ze	ro Air (A)			Calculate Precision	1 [STD – (B)]
0.51	ppm	2.3	ppm	7	
0,26	ppm	24	ppm	)	
0-11	ppm	25	ppm	0	
[STD-B1] + [ST	TD-B2] + [5 3	STD-B3] X <u>1</u> 25	X <u>100</u> 1	4.8	#DIV/0!
	0.51	0,26 ppm 0-1/ ppm	Calibration G  O · S / ppm 23  O · 26 ppm 24  O · 1/ ppm 25  [STD-B1] + [STD-B2] + [STD-B3] X 1	Calibration Gas (B)  O · S / ppm Z 3 ppm  O · 2 6 ppm Z 4 ppm  O · 1 / ppm Z 5 ppm  [STD-B1] + [STD-B2] + [STD-B3] X 1 X 100	Calibration Gas (B)  O · S / ppm 2 ppm 2  O · 2 6 ppm 2 / ppm /  O - 1 / ppm 2 S ppm 3  [STD-B1] + [STD-B2] + [STD-B3] X 1 X 100 4 8

Performed By: ERNES LRAMIREZ Date/Time: 1-29-20 -/ 300



LANDFILL NAME: REDWOOD		STRUMEN	IT MAKE: + HER 10
MODEL: 1000	EQUIPMENT #: 15		SERIAL #: 1636346772
MONITORING DATE: 1-29-2	D	TIME:	1300

#### Calibration Procedure:

Allow instrument to zero itself while introducing air.
 Introduce calibration gas into the probe. Stabilized reading = 25 ppm

3. Adjust meter settings to read 25 ppm.

#### **Background Determination Procedure**

Upwind Background Reading: (Highest in 30 seconds)	Downwind Background Reading: (Highest in 30 seconds)	Background Value:  (Upwind + Downwind) 2
1.8 ppm	2. 2/ ppm	2./ ppm

Background Value = Z-/ ppm

#### **INSTRUMENT RESPONSE TIME RECORD**

Measurement #	Stabilized Read Calibration Gas		90% of the Stabili Reading	zed	Time to Reach Stabilized Read switching from Calibration Gas	ing after Zero Air to
#1	24	ppm	21-6	ppm	5	
#2	25	ppm	22.5	ppm	5	
#3	25	ppm	27.5	ppm	5	
	Calculate Response	e Time ( <u>1</u> - 3	+2+3)		5	#DIV/0!
					Must be less that	30 seconds

#### CALIBRATION PRECISION RECORD

Measurement #	Meter Reading for Ze	ro Air (A)	Meter Reading Calibration Ga		Calculate Precision [STD	- (B)]
#1	0.18	ppm	24	ppm	,	
#2	0.14	ppm	25	ppm	2	_
#3	0.06	ppm	25	ppm	9	
Calculate Precision	STD-B1] + [STD-B1]	TD-B2] + [5 3	STD-B3] X 1 ) 25	1 100	. / . >	#DIV/0
					Must be less than 10%	6

Performed By: NICL BENKS	Date/Time: _/-21-20 -/300



ANDFILL NAME: REDWOOD		NSTRUMENT MAKE: +Herro
MODEL: LUATUOD	EQUIPMENT #: 10	SERIAL #: 1036346773
MONITORING DATE: 1-36-2	0	TIME:

#### Calibration Procedure:

Allow instrument to zero itself while introducing air.
 Introduce calibration gas into the probe. Stabilized reading = 25 ppm

3. Adjust meter settings to read 25 ppm.

#### **Background Determination Procedure**

Upwind Background Reading: (Highest in 30 seconds)	Downwind Background Reading: (Highest in 30 seconds)	Background Value:  (Upwind + Downwind) 2
1.8 ppm	2-4 ppm	2. / ppm

Background Value = 2 - / ppm

#### INSTRUMENT RESPONSE TIME RECORD

Measurement # Stabilized Reading Using Calibration Gas			90% of the Stabili Reading	zed	Time to Reach 90% of Stabilized Reading after switching from Zero Air to Calibration Gas	
#1	24	ppm	21.6	ppm	5	
#2	25	ppm	22.5	ppm	フ	
#3	25	ppm	2.2.5	ppm	7	
	Calculate Response T	ïme ( <u>1</u> - 3	+2+3)		7	#DIV/0!
					Must be less than	30 seconds

#### CALIBRATION PRECISION RECORD

Measurement #	Meter Reading for Zer	eter Reading for Zero Air (A)		g for as (B)	Calculate Precision [STD -	
#1	0-45	ppm	211	ppm	7	
#2	6.2/	ppm	25	ppm	0	_
#3	0-16	ppm	25	ppm	0	
Calculate Precision	[STD-B1] + [ST	D-B2] + [S	STD-B3] X <u>1</u> X 25	1 100	, 7.3	#DIV/0!
					Must be less that	an 10%

Performed By: LAISS WADE	Date/Time: 1-30-20-1620	
--------------------------	-------------------------	--



LANDFILL NAME: RED WOOD		INS	INSTRUMENT MAKE: _ LHENGO		
MODEL: LUA1000	EQUIPMENT #: _	11	SERIAL #: 103634677 4		
MONITORING DATE: 1-30-	20		TIME: 1620		

#### Calibration Procedure:

1. Allow instrument to zero itself while introducing air.

2. Introduce calibration gas into the probe. Stabilized reading = 25 ppm

3. Adjust meter settings to read 25 ppm.

#### **Background Determination Procedure**

Upwind Background Reading: (Highest in 30 seconds)		Downwind Back Reading: (Highest in 30 sec		Background Va (Upwind + Do	
1-8	ppm	2.4	ppm	2.1	ppm

Background Value = 2./ ppm

#### INSTRUMENT RESPONSE TIME RECORD

Measurement #	Stabilized Reading Using Calibration Gas		90% of the Stabil Reading	ized	Time to Reach 90% of Stabilized Reading after switching from Zero Air to Calibration Gas	
#1	23	ppm	20.7	ppm	6	
#2	25	ppm	22.5	ppm	6	
#3	75	ppm	72.5	ppm	6	
	Calculate Response	Time ( <u>1-</u> 3	<del>+2+3</del> )		6	#DIV/0!
					Must be less that	30 seconds

#### CALIBRATION PRECISION RECORD

Calibration Gas Standard = 25 ppm

Measurement #	Meter Reading for Ze	Meter Reading for Zero Air (A)		ng for ias (B)	Calculate Precision [STD – (B	
#1	0.56	ppm	23	ppm	2	
#2	0.18	ppm	25	ppm	ð	
#3	0-72	ppm	25	ppm	O	
Calculate Precision	n [STD-B1] + [S	TD-B2] + [5 3	STD-B3] X <u>1</u> 25	X <u>100</u> 1	・ こ・6 Must be less th	#DIV/0!

Performed By:	ANTRO	NY	porcita	
		-	/	۰

\_Date/Time: 1-30-20-1620



LANDFILL NAME: REDWOOD		INSTRUM	ENT MAKE: +HERMO
MODEL: EVALOOD	_EQUIPMENT#:_	12	SERIAL #: 103629678/
MONITORING DATE: 1-30-2	D	TIME:	1620

#### Calibration Procedure:

1. Allow instrument to zero itself while introducing air.

2. Introduce calibration gas into the probe. Stabilized reading = 25 ppm

3. Adjust meter settings to read 25 ppm.

#### **Background Determination Procedure**

Upwind Background Reading: (Highest in 30 seconds)	Downwind Background Reading: (Highest in 30 seconds)	Background Value:  (Upwind + Downwind) 2
/ 8 ppm	2,4 ppm	2,, ppm

Background Value = Z./ ppm

#### INSTRUMENT RESPONSE TIME RECORD

Measurement #	Stabilized Reading Using Calibration Gas		90% of the Stabili Reading	zed	Time to Reach 90% of Stabilized Reading after switching from Zero Air to Calibration Gas	
#1	24	ppm	21.6	ppm	フ	
#2	24	ppm	21.6	ppm	7	
#3	25	ppm	22.5	ppm	7	
	Calculate Response T	ime ( <u>1</u> . 3	+2+3)		7	#DIV/0!
					Must be less than	30 seconds

#### CALIBRATION PRECISION RECORD

Measurement #	Meter Reading for Ze	eter Reading for Zero Air (A)		ng for ias (B)	Calculate Precision [STD	
#1	0-31	ppm	24	ppm	,	
#2	0.18	ppm	29	ppm	,	
#3	0-10	ppm	25	ppm	0	
Calculate Precision	[STD-B1] + [ST	TD-B2] + [5 3	STD-B3] X <u>1</u> 25	X <u>100</u> 1	. 2.6	#DIV/0!
					Must be less th	an 10%

Performed By: _	AARON MCBIDE	Date/Time:	1-30-20	-1620



LANDFILL NAME: REDWOOD		INSTRUMENT MAKE: HIGHA &			
MODEL: LVA1600	EQUIPMENT #:	13	SERIAL #: //02746775		
MONITORING DATE: 1-30	-20	TIME	:_ 1620		

#### Calibration Procedure:

1. Allow instrument to zero itself while introducing air.

2. Introduce calibration gas into the probe. Stabilized reading = 25 ppm

3. Adjust meter settings to read 25 ppm.

#### **Background Determination Procedure**

Upwind Background Reading: (Highest in 30 seconds)	Downwind Background Reading: (Highest in 30 seconds)	Background Value:  (Upwind + Downwind) 2
1.8 ppm	2, 9 ppm	2.1 ppm

Background Value = 2./ ppm

#### INSTRUMENT RESPONSE TIME RECORD

Measurement #	Stabilized Reading Using Calibration Gas		90% of the Stabil Reading	lized	Time to Reach 90% of Stabilized Reading after switching from Zero Air to Calibration Gas	
#1	23	ppm	20:7	ppm	5	
#2	24	ppm	21.6	ppm	5	
#3	25	ppm	22.5	ppm	5	
	Calculate Response 1	Time ( <u>1-</u> 3	+2+3)		Must be less than	#DIV/0!

#### CALIBRATION PRECISION RECORD

Measurement #	Meter Reading for Zero Air (A)		eter Reading for Zero Air (A) Meter Reading for Calibration Gas (B)		Calculate Precision	[STD - (B)]
#1	0.25	ppm	23	ppm	2	
#2	0-17	ppm	24	ppm	)	
#3	0-14	ppm	25	ppm	7	
Calculate Precision	on [STD-B1] + [ST	D-B2] + [5	STD-B3] X <u>1</u> 25	X <u>100</u>	. 4.0	#DIV/0!
					Must be less th	an 10%

Performed Bv:	ERNOSE REMINER	Date/Time:	1-30-20-1620
Chomica by.	0,0.00	Date/Time:	7-30-60-76-



INSTRUMENT MAKE: + HON A D
15 SERIAL #: 1036346772
TIME: 1620

#### Calibration Procedure:

1. Allow instrument to zero itself while introducing air.

2. Introduce calibration gas into the probe. Stabilized reading = 2s ppm

Adjust meter settings to read 25 ppm.

#### **Background Determination Procedure**

Reading:	Downwind Background Reading: (Highest in 30 seconds)	Background Value:  (Upwind + Downwind) 2		
1-8 ppm	2. // ppm	2-/ ppm		

Background Value = 2 · / ppm

#### INSTRUMENT RESPONSE TIME RECORD

Measurement #	Stabilized Reading Using Calibration Gas		90% of the Stabili Reading	zed	Time to Reach 90% of Stabilized Reading after switching from Zero Air to Calibration Gas	
#1	24	ppm	21.6	ppm	5	
#2	2/	ppm	22.5	ppm	5	
#3	25	ppm	22.5	ppm	5	
	Calculate Response Tim	e ( <u>1</u>	+2+3)		5	#DIV/0!
					Must be less than	30 seconds

#### CALIBRATION PRECISION RECORD

Meter Reading for Ze	Meter Reading for Zero Air (A)		_	Calculate Precision [S	TD – (B)]
0.44	ppm	24	ppm	1	
0.21	ppm	25	ppm	0	
0.13	ppm	25	ppm	3	
Calculate Precision [STD-B1] + [STD-B2] + [STD-B3] X 1 X 100 25 1			.1.3	#DIV/0!	
	0.71	0.21 ppm 0.13 ppm	Calibration G  6-44 ppm 24  0-21 ppm 25  0-13 ppm 75  n [STD-B1] + [STD-B2] + [STD-B3] X 1	Calibration Gas (B)         6-44       ppm       24       ppm         0-21       ppm       25       ppm         0-13       ppm       25       ppm         ppm	Calibration Gas (B)  0-44 ppm 24 ppm 1  0-21 ppm 25 ppm 0  0.13 ppm 25 ppm 0  ISTD-B1] + [STD-B2] + [STD-B3] X 1 X 100

Performed By: Nic 1C 13921CS	Date/Time: _/-30-20-/620



LANDFILL NAME: ZEO WOOD		INSTRUMENT MAKE: +Horas					
MODEL: LVA	1000	_EQUIPMENT #: _	10		SERIAL #:	1036746773	
MONITORING DA	TE: 1-3/-2	0		TIME:	0545		

#### Calibration Procedure:

1. Allow instrument to zero itself while introducing air.

2. Introduce calibration gas into the probe. Stabilized reading = 25 ppm

3. Adjust meter settings to read 25 ppm.

#### **Background Determination Procedure**

Reading: Read		Downwind Back Reading: (Highest in 30 sec		Background Val	
1.8	ppm	2.4	ppm	2.1	ppm

Background Value = 2./ ppm

#### INSTRUMENT RESPONSE TIME RECORD

Measurement #	Stabilized Reading Using Calibration Gas		90% of the Stabil Reading	ized	Time to Reach 90% of Stabilized Reading after switching from Zero Air to Calibration Gas	
#1	23	ppm	20.7	ppm	フ	
#2	24	ppm	2.1.6	ppm	7	
#3	25	ppm	22.5	ppm	7	
	Must be less than	#DIV/0!				

#### CALIBRATION PRECISION RECORD

Measurement #			Meter Readin Calibration G		Calculate Precision [STD – (B)]	
#1	0.33	ppm	23	ppm	7	
#2	6.21	ppm	24	ppm	1	
#3	0-18	ppm	25	ppm	D	
Calculate Precision	[STD-B1] + [S	TD-B2] + [\$	STD-B3] X <u>1</u> 25	X <u>100</u> 1	ゲック Must be less th	#DIV/0!

Performed By:	SUNDE	Date/Time:	1-31-20	- 6545



LANDFILL NAME: PEDWOOD	2	iN	STRUMENT	MAKE: +HERMO
MODEL: 4UA1000	EQUIPMENT #:	11		SERIAL #: 103634677 4
MONITORING DATE: / 3/- 2	20		TIME:	8545

#### Calibration Procedure:

1. Allow instrument to zero itself while introducing air.

2. Introduce calibration gas into the probe. Stabilized reading = 25 ppm

3. Adjust meter settings to read 25 ppm.

#### **Background Determination Procedure**

Upwind Background Reading: (Highest in 30 seconds)	Downwind Background Reading: (Highest in 30 seconds)	Background Value:  (Upwind + Downwind) 2
1,8 ppm	2.4 ppm	Z <sub>1</sub> / ppm

Background Value = 21/ ppm

#### INSTRUMENT RESPONSE TIME RECORD

Stabilized Readi Calibration Gas	90% of the Stabil Reading	ized	Time to Reach 90% of Stabilized Reading after switching from Zero Air to Calibration Gas		
24	ppm	21.6	ppm	7	
24	ppm	21.6	ppm	2	
25	ppm	22.5	ppm	)	
Calculate Response Time (1+2+3) 3					#DIV/0!
	Calibration Gas  2 4  2 9  2 5	2 4 ppm 2 4 ppm 2 5 ppm	Calibration Gas  Reading  2 4 ppm 21.6  2 4 ppm 21.6  2 5 ppm 22.5	Calibration Gas  Reading  2 4 ppm 21.6 ppm 24 ppm 21.6 ppm 25 ppm 22.5 ppm	Calibration Gas  Reading  Stabilized Read switching from Calibration Gas  2 4 ppm 21.6 ppm 7  2 4 ppm 21.6 ppm 7  2 5 ppm 22.5 ppm 7

#### CALIBRATION PRECISION RECORD

Calibration Gas Standard = 25 ppm

Measurement #	Meter Reading for Zero Air (A) Meter Reading for Calibration Gas (B)		Calculate Precision	1 [STD – (B)]		
#1	0.47	ppm	24	ppm	7	
#2	0.30	ppm	24	ppm	1	
#3	0-17	ppm	25	ppm	ð	
Calculate Precision	STD-B1] + [S	TD-B2] + [5	STD-B3] X <u>1</u> 25	X <u>100</u> 1	.2.6	#DIV/0!
					Must be less th	nan 10%

Performed By:	ANTA	ony	pons	CAN	Date

Date/Time: 1-31-20 - 8545



LANDFILL NAME: 1NST		INSTRUME	ENT MAKE: +11Enno	
MODEL: +VA1000	EQUIPMENT #: _	12	SERIAL #: 103629674	
MONITORING DATE:	1-31-20	TIME:	0545	

#### Calibration Procedure:

- 1. Allow instrument to zero itself while introducing air.
- 2. Introduce calibration gas into the probe. Stabilized reading = 2 5 ppm
- Adjust meter settings to read 25 ppm.

#### **Background Determination Procedure**

Upwind Background Reading: (Highest in 30 seconds)	Downwind Background Reading: (Highest in 30 seconds)	Background Value:  (Upwind + Downwind) 2
1. 7 ppm	2.4 ppm	Z./ ppm

Background Value = Z / ppm

#### INSTRUMENT RESPONSE TIME RECORD

Measurement #	Stabilized Reading Using Calibration Gas		90% of the Stabil Reading	ized	Time to Reach 90% of Stabilized Reading after switching from Zero Air to Calibration Gas	
#1	24	ppm	21.6	ppm	6	
#2	25	ppm	22,5	ppm	6	
#3	25	ppm	22.5	ppm	6	
	Calculate Response Time	3	+2+3)			DIV/0!

#### CALIBRATION PRECISION RECORD

Measurement #	easurement # Meter Reading for Zero Air (A) Meter Reading for Calibration Gas (B)		_	Calculate Precision	[STD - (B)]	
#1	0.45	ppm	24	ppm	)	
#2	0.26	ppm	25	ppm	0	
#3	0.14	ppm	25	ppm	6	
Calculate Precisio	n [STD-B1] + [S	3 (STD-B2)	STD-B3] X 1 25	X <u>100</u> 1	ハノス Must be less th	#DIV/0!

Performed By:	_ Date/Time:_	1-31,20-0595	



LANDFILL NAME: R&D	WOOD	INSTRUMENT MAKE: HHEROE			
MODEL: 1000	EQUIPMENT #:	13	SERIAL #: 1102346775		
MONITORING DATE: 1- 7/	'-20	TIME:	8545		

#### **Calibration Procedure:**

1. Allow instrument to zero itself while introducing air.

2. Introduce calibration gas into the probe. Stabilized reading = 25 ppm

3. Adjust meter settings to read 25 ppm.

#### **Background Determination Procedure**

Upwind Background Reading: (Highest in 30 seconds)	Downwind Back Reading: (Highest in 30 sec		Background Value:  (Upwind + Downwind) 2		
/ F ppm	2.4	ppm	21/	ppm	

Background Value = 2/ ppm

#### INSTRUMENT RESPONSE TIME RECORD

Measurement #	Stabilized Reading Using Calibration Gas		90% of the Stabil Reading	ized	Time to Reach 90% of Stabilized Reading after switching from Zero Air to Calibration Gas	
#1	23	ppm	20.7	ppm	5	
#2	25	ppm	22.5	ppm	5	
#3	25	ppm	275	ppm	5	
	5	#DIV/0!				
					Must be less than	30 seconds

#### CALIBRATION PRECISION RECORD

Measurement #	surement # Meter Reading for Zero Air (A) Meter Reading for Calibration Gas (B)		Calculate Precision	n [STD - (B)]		
#1	0.26	ppm	23	ppm	2	
#2	0-12	ppm	25	ppm	0	
#3	0.08	ppm	25	ppm	0	
alculate Precision [STD-B1] + [STD-B2] + [STD-B3] X 1 X 100 25 1					. 2.6	#DIV/0!
					Must be less th	nan 10%

Performed By: <u>CRNSS &amp; Reninn</u> Date/1	Time: 1-31-20-054	3
--	-------------------	---



LANDFILL NAME: REDWOO	0	INSTRUMEN	NT MAKE: 14ERAB	
MODEL: LUA 1000	_EQUIPMENT#:_	15		SERIAL #: 1036346772
MONITORING DATE: 1-3/-	20		TIME:	0545

#### Calibration Procedure:

1. Allow instrument to zero itself while introducing air.

2. Introduce calibration gas into the probe. Stabilized reading = 25 ppm

Adjust meter settings to read 25 ppm.

#### **Background Determination Procedure**

Upwind Background Reading: (Highest in 30 seconds)	Downwind Backg Reading: (Highest in 30 second		Background Value:  (Upwind + Downwind) 2		
1.8 ppm	2.4	ppm	2.1	ppm	

Background Value = 21/ ppm

#### INSTRUMENT RESPONSE TIME RECORD

Measurement #	Stabilized Reading Using Calibration Gas		90% of the Stabi Reading	lized	Time to Reach 90% of Stabilized Reading after switching from Zero Air to Calibration Gas	
#1	24	ppm	21.6	ppm	6	
#2	25	ppm	21.6	ppm	6	
#3	25	ppm	22.5	ppm	6	
Calculate Response Time (1+2+3) 3					6	#DIV/0!
					Must be less tha	an 30 seconds

#### CALIBRATION PRECISION RECORD

Measurement #	Meter Reading for Z	Meter Reading for Zero Air (A)		g for as (B)	Calculate Precision [STD - (B)	
#1	0.41	ppm	24	ppm	7	
#2	0.67	ppm	25	ppm	0	
#3	0-14	ppm	25	ppm	0	
Calculate Precisio	n [STD-B1] + [	STD-B2] + [5 3	STD-B3] X 1 25	X <u>100</u> 1	Must be less th	#DIV/0!

Date/Time:	1-31-20-	0545
	Date/Time: _	Date/Time: 1-31-20-



Site:					
Purpose:					
Operator:	Much	4			
Date:/-3-20		Time:	0630		
Model # TVA 1000 B					
Serial # <u>#10 1036346</u>	773				
INSTRUMENT INTEGRIT	Y CHECKLIST	INSTR	UMENT CALIBR	ATION	
	00	CA	LIBRATION CHE	CK	
Battery test	Pass / Fail	Calibration	Actual	%	
Pooding following ignition	23	Gas (ppm)	(ppm)	Accuracy	
Reading following ignition	ppm	500	500	100%	
eak test	Pass / Fail / NA	300	50	100 /,	
	0		RESPONSE TIME	Ξ	
Clean system check	Pass / Fail / NA	Calibration Gos. p	om	500	
check valve chatter)		Calibration Gas, ppm  90% of Calibration Gas, ppm			
H <sub>2</sub> supply pressure gauge	Pass / Fail / NA	Time required to a			
acceptable range 9.5 - 12)	<b>O 1 1 1 1 1 1 1 1</b>	1.	2	эцо ррт	
	1-3-20	2.			
Date of last factory calibration	1 7 70	3.	ì		
actory calibration record	Pass / Fail	Average	6	~	
v/instrument within 3 months	(J. 7. U.)	Equal to or less th		₩ N	
		Instrument calibra	ted to CVY	_gas.	
Comments:					



Site:		
Purpose:		
Operator:	Mu M	
Date:		Time: 0615
Model #_ TCA 1000 1		
Serial # #// 1036	346774	
INSTRUMENT INTEGRITY	CHECKLIST	INSTRUMENT CALIBRATION
Battery test	Pass / Fail	CALIBRATION CHECK Calibration Actual % Gas (ppm) (ppm) Accuracy
Reading following ignition	2.2 ppm	
Leak test	Pass / Fail / NA	SOO SOO (OO),
Clean system check (check valve chatter)	Fass / Fail / NA	Calibration Gas, ppm 500
H₂ supply pressure gauge (acceptable range 9.5 - 12)	Pags / Fail / NA	90% of Calibration Gas, ppm  Time required to attain 90% of Cal Gas ppm  1.
Date of last factory calibration	1-3-20	$\begin{bmatrix} 2. & \frac{9}{3} \end{bmatrix}$
Factory calibration record w/instrument within 3 months	Páss / Fail	Average 9.0  Equal to or less than 30 seconds? N  Instrument calibrated to CH4 gas.
Comments:		



Site:				
Purpose:				
Operator:	M			
Date: 1-3-70		Time:	0600	
Model#				
Serial # # 12 10362	4674			
INSTRUMENT INTEGRITY	CHECKLIST	INSTR	RUMENT CALIBRA	ATION
		CA	LIBRATION CHEC	CK
Battery test	Pass / Fail	Calibration	Actual	%
Reading following ignition	_2-3ppm	Gas (ppm)	(ppm)	Accuracy
reading following ignition	ppiii	500	500	100%
Leak test	Rass / Fail / NA			,
Clean system check	Rass / Fail / NA		RESPONSE TIME	
(check valve chatter)	rass/Fall/INA	Calibration Gas, p	pm ·	500
<b>,</b>	$\sim$	90% of Calibration		-150
H <sub>2</sub> supply pressure gauge	Pass / Fail / NA	Time required to a	ttain 90% of Cal G	as ppm
(acceptable range 9.5 - 12)		1		
Date of last factory calibration	1-3-20	2.	7	
		3. Average	6	
Factory calibration record w/instrument within 3 months	Pass/Fail	Equal to or less th		Ø N
winstrament within 3 months			ted to Ctty	
Comments:				



ose:	
ator: Mu	24
1-3-20	Time:
el#_TVA 1000 13	
# #13 1102746775	

INSTRUMENT INTEGRITY CHECKLIST		INSTRUMENT CALIBRATION		
	14	CALIBRATION CHECK		
Battery test	Pass / Fail	Calibration	Actual	%
Pooding following ignition	19	Gas (ppm)	(ppm)	Accuracy
Reading following ignition	ppm	500	500	100%
Leak test	Pass / Fail / NA			1007/
			RESPONSE TIME	
Clean system check	Pass / Fail / NA	0.175 (1.00		500
(check valve chatter)		Calibration Gas, p		
	60 1- 1111	90% of Calibration		450
H <sub>2</sub> supply pressure gauge	eas / Fail / NA	Time required to a	attain 90% of Cal C	as ppm
(acceptable range 9.5 - 12)		1		
Date of last factory calibration	1-3-20	2. 6		
Date of last factory calibration	1 7 60	3.	7	
Factory calibration record	Pass / Fail	Average6	3	253
w/instrument within 3 months	.(323 / 1 011	Equal to or less th	an 30 seconds?	(Y) N
		Instrument calibra	ted to ClH	gas.

Comments:			



Operator:		Time:	0515	
Model# <u>+ VA 1000 B</u> Serial # <u>#15 / 03</u> B				
INSTRUMENT INTEGRIT	Y CHECKLIST	INSTE	RUMENT CALIBRA	ATION
Battery test	Pass / Fail	CA Calibration Gas (ppm)	ALIBRATION CHEC Actual (ppm)	CK % Accuracy
Reading following ignition Leak test	2.3 ppm Pass/Fail/NA	500	SOO RESPONSE TIME	100%
Clean system check check valve chatter)	Pass / Fail / NA	Calibration Gas, p	opm	500
H <sub>2</sub> supply pressure gauge (acceptable range 9.5 - 12)	Pass / Fail / NA	Time required to a	attain 90% of Cal G	as ppm
Date of last factory calibration	1-3-20	2. <u>7</u> 3.	2	
Factory calibration record w/instrument within 3 months	Pass / Fail	Average 6 Equal to or less the Instrument calibration	nan 30 seconds?	
Comments:				

465

# Environmental Inc.

CUSTOMER:	RES	UN A #10	

SERIAL NUMBER: <u>1036346773</u>

# GAS CALIBRATION CHECK (PERFORMED AT ROOM TEMPERATURE)

	FI	D	
METHANE GAS NOMINAL (ppm)	CALIBRATION GAS (ppm)	TVA READING (ppm)	TOLERANCE (ppm)
100	100	100	+/- 25
500	500	500	+/- 125
10000	10000	10,001	+/- 2500
< 1	ZERO GAS	0,53	< 3
	Pil	)	
ISOBUTYLENE GAS NOMINAL (ppm)	CALIBRATION GAS_(ppm)	TVA READING (ppm)	TOLERANCE (ppm)
50	50	/	+/- 12.5
100	100		+/- 25
500	500		+/- 125
<1	ZERO GAS		< 3

# Environmental Inc.

CUSTOMER: RES UNIT #	//
SERIAL NUMBER: 1036346774	
TECHNICIAN: Mu M	DATE: /-3-20

# GAS CALIBRATION CHECK (PERFORMED AT ROOM TEMPERATURE)

	FI	ID	
METHANE GAS NOMINAL (ppm)	CALIBRATION GAS (ppm)	TVA READING (ppm)	TOLERANCE (ppm)
100	100	99	+/- 25
500	500	500	+/- 125
10000	10000	10,021	+/- 2500
<1	ZERO GAS	0,56	< 3
	Pil	D	
ISOBUTYLENE GAS NOMINAL (ppm)	CALIBRATION GAS_(ppm)	TVA READING (ppm)	TOLERANCE (ppm)
50	50	,	+/- 12.5
100	100		+/- 25
500	500		+/- 125
<1	ZERO GAS		< 3

# TVA1000B CALIBRATION VERIFICATION Environmental Inc.

CUSTOMER:	RES UNIT #1	7
SERIAL NUMBER:	1036246741	
TECHNICIAN:	Mr M	DATE: 1-3-20

## GAS CALIBRATION CHECK (PERFORMED AT ROOM TEMPERATURE)

	FI	ID	
METHANE GAS NOMINAL (ppm)	CALIBRATION GAS (ppm)	TVA READING (ppm)	TOLERANCE (ppm)
100	100	100	+/- 25
500	500	499	+/- 125
10000	10000	10,001	+/- 2500
< 1	ZERO GAS	0.57	< 3
	Pil	D	
ISOBUTYLENE GAS NOMINAL (ppm)	CALIBRATION GAS.(ppm)	TVA READING (ppm)	TOLERANCE (ppm)
50	50	7	+/- 12.5
100	100 100		+/- 25
500	500		+/- 125
< 1	ZERO GAS		< 3

# Environmental Inc.

CUSTOMER: RES COURT #	13	
SERIAL NUMBER: 1102746773	>	
TECHNICIAN: Mu M	DATE: _	1-300

# GAS CALIBRATION CHECK (PERFORMED AT ROOM TEMPERATURE)

		D	
METHANE GAS NOMINAL (ppm)	CALIBRATION GAS (ppm)	TVA READING (ppm)	TOLERANCE (ppm)
100	100	100	+/- 25
500	500	500	+/- 125
10000	10000	10,000	+/- 2500
< 1	ZERO GAS	0,67	< 3
	PII	D	
ISOBUTYLENE GAS NOMINAL (ppm)	CALIBRATION GAS.(ppm)	TVA READING (ppm)	TOLERANCE (ppm)
50	50	1	+/- 12.5
100	100		+/- 25
500	500		+/- 125
<1	ZERO GAS	/	< 3

# Environmental Inc.

CUSTOMER:	RES	Chit	#15	

SERIAL NUMBER: 1036346772

# GAS CALIBRATION CHECK (PERFORMED AT ROOM TEMPERATURE)

FID			
METHANE GAS NOMINAL (ppm)	CALIBRATION GAS (ppm)	TVA READING (ppm)	TOLERANCE (ppm)
100	100	100	+/- 25
500	500	500	+/- 125
10000	10000	(01000	+/- 2500
<1	ZERO GAS	0.73	< 3
	Pil		
ISOBUTYLENE GAS NOMINAL (ppm)	CALIBRATION GAS_(ppm)	TVA READING (ppm)	TOLERANCE (ppm)
50	50	/	+/- 12.5
100	100		+/- 25
500	500		+/- 125
<1	ZERO GAS		< 3



#### INTERMOUNTAIN SPECIALTY GASES

520 N. Kings Road • Nampa • Idaho • 83687 800-552-5003 • www.isgases.com

#### CERTIFICATE OF ANALYSIS

 $\begin{array}{c|c} \underline{\text{Composition}} & \underline{\text{Certification}} & \underline{\text{Analytical Accuracy}} \\ \text{Air - Zero} & & & & \\ \hline \text{THC} & & <2 \text{ PPM} \\ \text{Oxygen} & & 20.9\% & & \pm 2\% \\ \text{Nitrogen} & & \text{Balance} & & & \\ \end{array}$ 

Lot#

19-6779

Mfg. Date:

4/3/2019

Parent Cylinder ID

001739, 02268

Number:

#### **Method of Preparation:**

Gravimetric/Pressure Transfilled


#### Method of Analysis:

This mix was prepared gravimetrically and is traceable to the NIST by certified weights (ID #CA10814) used to calibrate the scale.

Analysis By: Tony Janquart Quality Assurance Manager

800-552-5003

Certificate Date: 4/3/2019





#### INTERMOUNTAIN SPECIALTY GASES

520 N. Kings Road ● Nampa ● Idaho ● 83687 800-552-5003 ● www.isgases.com

#### CERTIFICATE OF ANALYSIS

Composition

Certification

Analytical Accuracy

Methane

25 ppm

 $\pm 5\%$ 

Air

Balance

Lot#

17-6074

Mfg. Date:

10/16/2017

Parent Cylinder ID

17161

Number:

#### **Method of Preparation:**

Gravimetric/Pressure Transfilled


#### Method of Analysis:

The parent mix was prepared gravimetrically and is traceable to the NIST by certified weights (ID #CA10814) used to calibrate the scale.

Analysis By: Tony Janquart Quality Assurance Manager

800-552-5003

Certificate Date: 10/16/2017





520 N. Kings Road ● Nampa ● Idaho ● 83687 800-552-5003 ● www.isgases.com

## CERTIFICATE OF ANALYSIS

Composition

Certification

Analytical Accuracy

Methane

500 ppm

 $\pm 2\%$ 

Air Balance

Lot#

19-6955

Mfg. Date:

7/24/2019

Parent Cylinder ID

001763

Number:

## **Method of Preparation:**

Gravimetric/Pressure Transfilled


## Method of Analysis:

The parent mix was prepared gravimetrically and is traceable to the NIST by certified weights (ID #CA10814) used to calibrate the scale.

Analysis By: Tony Janquart Quality Assurance Manager

800-552-5003

Certificate Date: 7/24/2019









#### **WASTE MANAGEMENT**

172 98<sup>th</sup> Avenue Oakland, CA 94603 (510) 430-8509

April 1, 2020

Ms. Alisha McCutcheon Redwood Landfill, Inc. 8590 Redwood Highway Novato, California 94948

Re: March 2020 Surface Emissions Monitoring Report for Redwood Landfill, Inc.

Dear Ms. McCutcheon:

This monitoring report for "**Redwood Landfill, Inc. (RLI)**" contains the results of the March 2020 Surface Emissions Monitoring (SEM). Initial surface emissions monitoring was performed by Roberts Environmental Services, LLC. (RES).

#### APPLICABLE REQUIREMENTS

The monitoring discussed in this report was conducted in accordance with the following requirements:

#### **Surface Emission Monitoring (SEM)**

- New Source Performance Standard (NSPS), Title 40 of the Code of Federal Regulations (CFR) §60.755 (c) and (d), 40 CFR 60, Appendix A Method 21, promulgated by the United States Environmental Protection Agency (USEPA).
- Bay Area Air Quality Management District (BAAQMD) Regulation 8, Rule 34, Section 303 (Landfill Surface Requirements) and Section 607 (Landfill Surface Inspection procedures).

#### **PROCEDURES**

#### General

Per NSPS and 8-34 rules, the entire surface of the landfill was monitored following a serpentine path with a 100' spacing. Active portions of the Landfill, slope areas, and as requested in the approved ACO, areas containing only asbestos-containing waste, inert waste and/or non-decomposable waste which are excluded for safety as allowed by the NSPS and 8-34.

Field personnel walked the surface of the landfill using the gridlines normally used for monitoring required by AB32 (see Attachment A map). These grids typically have dimensions of 500' x 100'. A consistent 100' spacing was achieved by walking on the 500' long borderline shared by two grids. Additionally, in accordance with the provisions of 40 CFR 60.753(d) and

60.755(c)(1-3), the entire perimeter of the landfill surface was monitored. During the event, special attention was given to monitoring unusual cover conditions (stressed vegetation, cracks, seeps, etc.) and any areas with unusual odors.

#### **Instantaneous Surface Emissions Monitoring**

The Instantaneous SEM was conducted using a Toxic Vapor Analyzer (TVA) 1000 flame ionization detector (FID), which was calibrated to 500 parts per million by volume (ppm<sub>v</sub>) methane, which meets or exceeds all guidelines set forth in the NSPS and 8-34. The FID was calibrated prior to use in accordance with the United States Environmental Protection Agency (USEPA) Method 21 requirements.

RES personnel walked the surface of the landfill with the wand tip held at 2 inches from the landfill surface. While sampling the grid; the technicians also checked any surface impoundments (wells or otherwise) for leaks. Technicians also checked any surface cracks, seeps, or other areas that show evidence of surface emissions (odors or distressed vegetation). Active and sloped areas excluded for safety were documented on the map included in Attachment A.

All instantaneous surface monitoring was performed in accordance with the applicable requirements referenced in this report. Any detections of methane above 500 ppm<sub>v</sub> (exceedances) for instantaneous were recorded, flagged, and marked on an SEM Map, which, wherever required, is included in the Appendices of this report. Applicable corrective action and re-monitoring timelines are listed below:

- Corrective actions must be initiated within 5 days of the initial exceedance and remonitoring shall be conducted within 10 days of the initial exceedance.
  - o If the re-monitoring event shows the exceedance is corrected, the location shall be re-monitored within 1 month of the initial exceedance.
  - o If the 1-month re-monitoring event shows the location is still corrected, all remonitoring requirements have been completed.
- If either the first 10-day or 1-month re-monitoring events show a second exceedance, additional corrective actions shall be completed and a second re-monitoring event shall be conducted within 10 days of the second exceedance.
- If the second 10-day re-monitoring event shows the second exceedance is corrected, the location shall be re-monitored within 1 month of the initial exceedance. If the 1-month re-monitoring event shows the area is still corrected, monitoring requirements have been completed.

If any location shows three exceedances, an additional well shall be installed within 120 days of the initial exceedance.

#### **MARCH 2020 SEM RESULTS**

The Instantaneous surface monitoring was performed on March 11 and 12, 2020 in accordance with the NSPS and BAAQMD 8-34. Results and data from the monitoring are presented in Attachment A.

#### Initial Monitoring Event Exceedances of 500 ppm<sub>v</sub>

There were no exceedances of 500 ppm<sub>v</sub> as methane detected on March 11 and 12, 2020. No remonitoring was required.

#### WEATHER CONDITIONS

#### Wind Speed Conductions during the Surface Emission Monitoring Events

Wind speeds during initial monitoring were monitored using a portable weather station. The station has a strip chart that records the wind speed and direction. The chart data is scanned and included in Attachment B.

#### **EQUIPMENT CALIBRATION**

The portable analyzers were calibrated to meet the instrument specifications requirements of U.S. EPA Method 21. The calibration gas used was methane, diluted to a nominal concentration of 25 ppm<sub>v</sub> in air for integrated sample analyses and 500 ppm<sub>v</sub> in air for instantaneous monitoring to comply with the requirements.

All analyzers were calibrated prior to use with required response time and precision related instrument checks. Calibration records include the following: Response time test record; Response factor determination for methane; Calibration Precision test records; and Daily Instrument Calibration and Background test records for each gas meter that was used during the monitoring event. The calibration log records are included in Attachment C.

All monitoring was completed in accordance with the applicable regulatory requirements or approved alternatives. If you have any questions regarding this report, please do not hesitate to contact me at (510) 613-2852.

Thank you,

Waste Management

Michael Chan

**Environmental Protection Specialist** 

Attachel Chan

## Attachment A – Instantaneous Surface Emission Monitoring Event Records

- SEM Map
- Monitoring Logs and Exceedances

## Attachment B – Weather Station Data

• Strip Chart Data

### **Attachment C – Calibration Records**

• Instrument and Gas Calibration Records

## Attachment A

Surface Emission Monitoring Event Records



JOB NUMBER: 15341

## Instantaneous Landfill Surface Emissions Monitoring Exceedance and Monitoring Logs (NSPS/BAAQMD 8-34)

2020 Month: March

INITIAL MONITORING PERFORMED BY: RES FOLLOW-UP MONITORING PERFORMED BY: LANDFILL NAME: Redwood Landfill, Inc.

Initia	l Monitorin	g Event		Corrective Action	1st 1	0-day Follo	w-Up	1st 3	0-day Follo	w-Up	
Flag	Monitoring	Reading	Repair	Action	Monitoring	No Exced.	Exced.	Monitoring	No Exced.	Exced.	
Number	Date	ppm	Date	Taken	Date	<500 ppm	>500 ppm	Date	<500 ppm	>500 ppm	Comments
				N	o Exceedan	ces					

## Orange Flag Landfill Surface Emissions Monitoring Exceedances and Monitoring Log

Site: LEDNOOD

Quarter /		15+ WSP.	5										Page (	- f D
Technicia		6531W40	-										rage (	of Pag
Instrumer		+VA1000												
Calibratio	n Standard:	500990												
-	Initial Mo	onitoring Event		First Re-N	nonitoring Event	t - 10 Days	Second Re	-Monitoring Eve	nt - 10 Days	30-Da	y Follow-up Mo	nitorina	Comm	ents
Flag	Grid	Field Reading	Date	Date	No Excd.	Excd.	Date	No Excd.	Excd.	Date	No Excd.	Excd.	00111111	Unito
Number O-	Number	(ppm)	Monitored	Monitored	<500 ppm	>500 ppm	Monitored	<500 ppm	>500 ppm	Monitored	<500 ppm	>500 ppm		
											j.		NO SKCESOS	HC MS
0-														1
0-														
0-														
0-	1												-	_
0-														
0-								-						
0-														
0-						1								
0-														
0-														
0-									-		-			
0-														
0-									-					
0-			-											
0-						-								
0-														
0-									-					
0-														
0-			1											
0-														
0-														
0-							-							
0-											-			
0-														
							, t			(7				


## Attachment B

Weather Station Data



	16-POINT V	VIND DIRECTION	N INDEX	
NO NO	DIRECTION		DEGREES	
		FROM	CENTER	<u>TO</u>
16	NORTH (N)	348.8	369,0	t .1.3
1	NORTH-NORTHEAST (NNE)	011.3	022.5	033.8
2	NORTHEAST (NE)	033,8	045.0	056.3
3	EAST-NORTHEAST (ENE)	056.3	<u>067.5</u>	078.8
4	EAST (E)	078.8	090.0	101.3
5	EAST-SOUTHEAST (ESE)	101.3	112.5	123.8
6	SOUTHEAST (SE)	123.8	135.0	146.3
7	SOUTH-SOUTHEAST (SSE)	146.3	<u>157.5</u>	168.8
8	SOUTH (S)	168.8	180.0	191.3
9	SOUTH-SOUTHWEST (SSW)	191.3	202.5	213.8
10	SOUTHWEST (SW)	213.8	225.0	236.3
11	WEST-SOUTHWEST (WSW)	236.3	<u>247.</u> 5	258.8
12	WEST (W)	258.8	270.0	281.3
13	WEST-NORTHWEST (WNW)	281.3	292.5	303.8
14	NORTHWEST (NW)	30.1.8	315.0	326.3
15	NORTH-NORTHWEST (NNW)	326.3	337.5	348.8

## **WIND SPEED & DIRECTION CHART ROLL**




\_

Τ

in the

26

## **WIND SPEED & DIRECTION CHART ROLL**



---

## **Attachment C**

Calibration Records



LANDFILL NAME: 12 ED WOOD	INSTRUMENT MAKE: +HERMO	
MODEL: + VA 1000 EQUIPMENT #:_		SERIAL #: /036346773
MONITORING DATE: 3-//-20		TIME:1640

## Calibration Procedure:

1. Allow instrument to zero itself while introducing air.

2. Introduce calibration gas into the probe. Stabilized reading = 500 ppm

3. Adjust meter settings to read 500 ppm.

## Background Determination Procedure

Upwind Background Reading: (Highest in 30 seconds)	Downwind Background Reading: (Highest in 30 seconds)	Background Value:  (Upwind + Downwind) 2
1.8 ppm	2-6 ppm	2.2 ppm

Background Value = 2.2 ppm

## INSTRUMENT RESPONSE TIME RECORD

Measurement#	Stabilized Reading Calibration Gas	Using	90% of the Stabili Reading	zed	Time to Reach ! Stabilized Read switching from Calibration Gas	ing after Zero Air to
#1	498	ppm	448	ppm	6	
#2	500	ppm	450	ppm	6	
#3	500	ppm	450	ppm	6	
	Calculate Response Tir	me (14 3	-2+3)		Must be less than	#DIV/0!

## CALIBRATION PRECISION RECORD

Measurement #	Meter Reading for Ze	ero Air (A)	Meter Reading Calibration Gas	for (B)	Calculate Precision [STD – (B)]
#1	0.31	ppm	498	ppm	7
#2	0.25	ppm	500	ppm	D
#3	6.18	ppm	500	ppm	0
Calculate Precisio	on [STD-B1] + [S	TD-B2] + [S	5TD-B3] X 1 X 500	100 1	O, / 3 #DIV/0. Must be less than 10%

Performed By: LEISh W MOE	Date/Time: 3-1/-20-1640
---------------------------	-------------------------



LANDFILL NAME: 12 60	wood	INSTRUMENT MAKE: +HER MA			
MODEL: LUN1000	EQUIPMENT #:	11	SERIAL #: 1036346774		
MONITORING DATE:	3-11-20	TIME:	1640		

## Calibration Procedure:

 Allow instrument to zero itself while introducing air. Introduce calibration gas into the probe. Stabilized reading = 500 ppm

Adjust meter settings to read 500 ppm.

## Background Determination Procedure

Upwind Background Reading: (Highest in 30 seconds)	Downwind Background Reading: (Highest in 30 seconds)	Background Value:  (Upwind + Downwind) 2
1-8 ppm	2-6 PI	om 2.2 ppm

Background Value = 2.2 ppm

## INSTRUMENT RESPONSE TIME RECORD

Measurement#	Stabilized Reading Calibration Gas	90% of the Stabil Reading	ized	Time to Reach 90% of Stabilized Reading after switching from Zero Air to Calibration Gas		
#1	506	ppm	456	ppm	7	
#2	498	ppm	448	ppm	7	
#3	500	ppm	450	ppm	7	
	Calculate Response T	ime ( <u>1-</u> 3	+2+3)		Must be less than	#DIV/0!

## CALIBRATION PRECISION RECORD

Measurement #	Meter Reading for Zero Air	A) Meter Reading for Calibration Gas (B)	Calculate Precision [STD – (B)]
#1	0-19 PI	om 506 ppm	6
#2	0-11 PI	om 498 ppm	2
#3	0-06 PR	om <sub>500</sub> ppm	0
Calculate Precisio	[STD-B1] + [STD-B2] 3		0-53 #DIV/0!
			Must be less than 10%

Performed By: ANTRONY PERSILA	Date/Time: 3-11-20 - 1640
-------------------------------	---------------------------



LANDFILL NAME: A DO WOOD			INSTRUMEN	IT MAKE: /	YERM O
MODEL: LUA1000	EQUIPMENT #:	12			: 1036246741
MONITORING DATE:	3-11-20		TIME:	1640	

## Calibration Procedure:

Allow instrument to zero itself while introducing air.
 Introduce calibration gas into the probe. Stabilized reading = 500 ppm.
 Adjust meter settings to read 500 ppm.

## **Background Determination Procedure**

Reading:	Downwind Background Reading: (Highest in 30 seconds)	Background Value: (Upwind + Downwind) 2	
1-8 ppm	2.6 ppm	7.7 ppm	

Background Value = 2.2 ppm

## INSTRUMENT RESPONSE TIME RECORD

Stabilized Reading Using Calibration Gas		90% of the Stabili Reading	zed	Time to Reach 90% of Stabilized Reading after switching from Zero Air to Calibration Gas	
#1	502	ppm	452	ppm	6
#2	495	ppm	445	ppm	6
#3	500	ppm	450	ppm	6
	Calculate Response Tim	ne ( <u>14</u> 3	·2+3)		#DIV/0! Must be less than 30 seconds

## CALIBRATION PRECISION RECORD

Measurement #	Meter Reading for Zero	Air (A)	Meter Reading Calibration Ga		Calculate Precision [STD – (B)]
#1	0.24	ppm	502	ppm	2
#2	0.13	ppm	49.5	ppm	
#3	0.10	ppm	500	ppm	<u></u>
Calculate Precision	STD-B1] + [STD-3	B2] + [S		100	0-96 #DIV/0
					Must be less than 10%

Performed By: ARON MURRO U	Date/Time: 3-11-20- /6 40
----------------------------	---------------------------



LANDFILL NAME: REDWOOD	INSTRUMENT MAKE: +KERMO		
MODEL: 4VA 1000 EQUIPMENT #:_	1.3 SERIAL #: //62746775		
MONITORING DATE: 3-1/-20	TIME:		

## Calibration Procedure:

1. Allow instrument to zero itself while introducing air. Introduce calibration gas into the probe. Stabilized reading = 500 ppm.
 Adjust meter settings to read 500 ppm.

## **Background Determination Procedure**

Reading:	Downwind Background Reading: (Highest in 30 seconds)	Background Value:  (Upwind + Downwind) 2
/- 8 ppm	2.6 ppm	2, 2 ppm

Background Value = 2-2 ppm

## INSTRUMENT RESPONSE TIME RECORD

Stabilized Reading Using Calibration Gas		90% of the Stabiliz Reading	ed	Time to Reach 90% of Stabilized Reading after switching from Zero Air to Calibration Gas	
#1	490	ppm	440	ppm	6
#2	502 1	ppm	452	ppm	6
#3		ppm	450	ppm	6
	Calculate Response Time	3	+2+3)		#DIV/0

## CALIBRATION PRECISION RECORD

Calibration Gas Standard = 500 ppm

Measurement #	Meter Reading for Zero Air (A)		Meter Reading for Calibration Gas (B)		Calculate Precision [STD – (B)]
#1	0.16	ppm	490	ppm	10
#2	0.08	ppm	507	ppm	2
#3	0-05	ppm	500	ppm	0
Calculate Precisio	on [STD-B1] + [ST	D-B2] + [S		100	Must be less than 10%

Performed By:	NICKB	snks
---------------	-------	------

Date/Time: 3-11-20- 1640



LANDFILL NAME: PED WOOD		INSTRUMENT MAKE: +HERMO			
MODEL: +VA1000	EQUIPMENT #:	10	SERIAL #: 1036346773	_	
MONITORING DATE:	7-12-20	TIME:	0530		

## Calibration Procedure:

1. Allow instrument to zero itself while introducing air.

2. Introduce calibration gas into the probe. Stabilized reading = \_\_\_\_\_\_ppm

Adjust meter settings to read 500 ppm.

## **Background Determination Procedure**

Upwind Background Reading: (Highest in 30 seconds)	Downwind Background Reading: (Highest in 30 seconds)	Background Value:  (Upwind + Downwind) 2
/-8 ppm	2.6 ppm	Z. 2 ppm

Background Value = 2.2 ppm

## INSTRUMENT RESPONSE TIME RECORD

Measurement #	Calibration Gas Reading		ized	Time to Reach 90% of Stabilized Reading afte switching from Zero Ai Calibration Gas		
#1	506	ppm	456	ppm	6	
#2	500	ppm	450	ppm	6	
#3	500	ppm	450	ppm	6	
	Calculate Response Ti	me ( <u>14</u>	+2+3)		Must be less that	#DIV/0!

## CALIBRATION PRECISION RECORD

Measurement #	Meter Reading for Ze	Meter Reading for Zero Air (A) Meter Reading for Calculate Precision Calibration Gas (B)							Calculate Precision [STD - (B)]
#1	0-27	ppm	506	ppm	7				
#2	0-20	ppm	500	ppm	6				
#3	0-17	ppm	500	ppm	0				
Calculate Precisio	n [STD-B1] + [S1	[D-B2] + [S		( <u>100</u> 1	0.40 #DIV/0! Must be less than 10%				

Performed By: LUSS A WADE	Date/Time: _ 3~/2-20 - 053	0
Performed By: Long & WANZ	Date/Time: 3-/2-20 - 053	Ĉ



LANDFILL NAME: PLD W 800		INSTRUMEN	IT MAKE: + HURAD
MODEL: 4VA 1000 EQUIPMEN	NT#:		SERIAL #: 1076746774
MONITORING DATE: 3-12-20		TIME:	0530

## Calibration Procedure:

 Allow instrument to zero itself while introducing air. Aniow instrument to zero itself while introducing air.
 Introduce calibration gas into the probe. Stabilized reading = \_\_\_\_\_\_ ppm
 Adjust meter settings to read 500 ppm.

## **Background Determination Procedure**

Upwind Background Reading: (Highest in 30 seconds)	Downwind Background Reading: (Highest in 30 seconds)		Background Value:  (Upwind + Downwind) 2	
1 - 8 ppm	2.6	ppm	7-2	ppm

Background Value = 2.2 ppm

## INSTRUMENT RESPONSE TIME RECORD

Measurement #	Stabilized Readin Calibration Gas	g Using	90% of the Stabilized Reading		Time to Reach 90% of Stabilized Reading after switching from Zero Air to Calibration Gas	
#1	495	ppm	445	ppm	.5	
#2	501	ppm	451	ppin	.5	
#3	560	ppm	450	ppm	5	
	Calculate Response	Time ( <u>1+</u> 3	-2+3)		Must be less that	#DIV/0!

## CALIBRATION PRECISION RECORD

Measurement #	Meter Reading for Ze	Meter Reading for Zero Air (A) Meter Reading for Calculate F										The second control of the second seco		[STD - (B)]
#1	0-32	ppm	485	ppm										
#2	0-24	ppm	501	ppm	/									
#3	0-17	ppm	500	ppm	0	_								
Calculate Precisio	n [STD-B1] + [S	TD-B2] + [S		100 1	0/40 Must be less th	#DIV/0!								

Performed By: ANThony pERICHN	Date/Time: 3-12-20-0530
-------------------------------	-------------------------



LANDFILL NAME: REDWOOD INS			INSTRUMENT MAKE: LITER 10			
MODEL: TVA 1000	EQUIPMENT #:	12	SERIAL#:	1036246741		
MONITORING DATE:	3-12-20	TIME:	0500			

## Calibration Procedure:

1. Allow instrument to zero itself while introducing air.

2. Introduce calibration gas into the probe. Stabilized reading = 500

3. Adjust meter settings to read 500 ppm.

## **Background Determination Procedure**

Upwind Back Reading: (Highest In 30 s	1	Reading:		Background Va		
1.8	ppm	2,6	3.0	ppm	2.2	ppm

Background Value = 2.2 ppm

## INSTRUMENT RESPONSE TIME RECORD

Measurement#	Calibration Gas Reading		lized	Time to Reach 90% of Stabilized Reading after switching from Zero Air to Calibration Gas		
#1	489	ppm	439	ppm	7	
#2	500	ppm	4.50	ppm	7	
#3	500	ppm	450	ppm	7	
	Calculate Response	Time (14	2+3)		7	#DIV/0!
					Must be less that	n 30 seconds

## CALIBRATION PRECISION RECORD

Measurement#	Meter Reading for Ze	ero Air (A)	Meter Reading Calibration Ga		Calculate Precision	[STD - (B)]
#1	0-41	ppm	485	ppm	11	
#2	0.26	ppm	500	ppm	D	
#3	0.11	ppm	500	ppm	8	-
Calculate Precision	on [STD-B1] + [S	TD-B2] + [S	5TD-B3] X <u>1</u> X 500	100	0.73	#DIV/0!
				-	Must be less tha	n 10%

Performed By: AARON ACURNING	Date/Time: 3-12-20- \$0530
------------------------------	----------------------------



LANDFILL NAME: RED NO	6 D	INSTRUMENT	MAKE: +HERRE
MODEL: FUA 1060	EQUIPMENT #: / 3	3	SERIAL #: _// 02746775
MONITORING DATE: 3-12	20	TIME:	0530

## Calibration Procedure:

- 1. Allow instrument to zero itself while introducing air.
- 2. Introduce calibration gas into the probe. Stabilized reading =  $\frac{560}{}$  ppm
- 3. Adjust meter settings to read 500 ppm.

## **Background Determination Procedure**

Upwind Background Reading: (Highest in 30 seconds)	Downwind Background Reading: (Highest in 30 seconds)	Background Value:  (Upwind + Downwind) 2
7.8 ppm	2.6 ppm	Z.Z ppm

Background Value = Z, Z ppm

## INSTRUMENT RESPONSE TIME RECORD

Measurement #	Stabilized Reading Calibration Gas	Using	90% of the Stabi Reading	lized	Time to Reach Stabilized Reac switching from Calibration Gas	ding after Zero Air to
#1	506	ppm	456	ppm	6	
#2	495	ppm	445	ppm	-	
#3	500	ppm	450	ppm	6	
	Calculate Response Ti	ime (1-	+2+3)		6	#DIV/0!
					Must be less tha	n 30 seconds

## CALIBRATION PRECISION RECORD

Measurement #	Meter Reading for 2	Zero Air (A)	Meter Reading Calibration Ga	g for as (B)	Calculate Precision	[STD - (B)]
#1	0.36	ppm	506	ppm	/	
#2	0.20	ppm	1195	ppm	6	
#3	0-15	ppm	500	ppm	7	
Calculate Precisio	n [STD-B1] + [	STD-B2] + [S	5TD-B3] X <u>1</u> X 500	100	0-73 Must be less than	#DIV/0

Performed By:	NICLE	Bonks	Date/Time:	7-12-20	05 70	
			Date/Time.	3 12 20		



## SURFACE EMISSION MONITORING INSTRUMENT CALIBRATION LOG

Site:				
Purpose:	1 0 1			
Operator:	MIN			
Date: 3-7-20		Time:	0400	
Model # +UA 1000 B				
Serial # #10 1036340	5773			
INSTRUMENT INTEGRIT	Y CHECKLIST	INSTR	UMENT CALIBRA	ATION
Datta and and	0		LIBRATION CHE	
Battery test	eass / Fail	Calibration Gas (ppm)	Actual (ppm)	% Accuracy
Reading following ignition				Accuracy
₋eak test	Pass / Fail / NA	500	500	100 /
can lest	Pags / Fall / NA		RESPONSE TIME	
Clean system check	Pass / Fail / NA		,	
check valve chatter)	· ·	Calibration Gas, p		666
H <sub>2</sub> supply pressure gauge	Pass / Fail / NA	90% of Calibration Time required to a		450
acceptable range 9.5 - 12)		1.	)	аз ррш
Date of last factory calibration	1-3-20	2. 9		
Pate of last factory calibration	- 1 - 1 - 1	3. 9		
actory calibration record	(Pass / Fail	Average S.		6
v/instrument within 3 months		Equal to or less that Instrument calibrat		
		modument camprat	ed to(	_ yas. 
Comments:				



## SURFACE EMISSION MONITORING INSTRUMENT CALIBRATION LOG

Site:				
Purpose:				
Operator:	Mul.			
Date: 3-7-20		Time:	0918	
Model # TVA 1000	5			
Serial # <u>#// /03634</u>	6774			
INSTRUMENT INTEGRIT	Y CHECKLIST	INSTR	RUMENT CALIBRA	ATION
		CA	ALIBRATION CHE	CK
Battery test	(Pás)s / Fail	Calibration	Actual	%
Reading following ignition	1.2 ppm	Gas (ppm)	(ppm)	Accuracy
reading following ignition		500	SOO	100%
₋eak test	Pass / Fail / NA	700		100%
			RESPONSE TIME	
Clean system check check valve chatter)	pass / Fail / NA	Calibration Gas, p	unm (	500
ondok valve chatter)		90% of Calibration	Pill	(50
H <sub>2</sub> supply pressure gauge	Pass / Fail / NA		attain 90% of Cal G	
acceptable range 9.5 - 12)		1. <u>6</u>		
Date of last factory calibration	1-3-20	2. 9		
Date of last factory calibration		3		
actory calibration record	(Pass / Fail	Average	ا ا	(C)
v/instrument within 3 months		Equal to or less th Instrument calibra	<b>^</b> • •	₩ N
		instrument calibra	led to <u>C199</u>	_gas.
Comments:				



## SURFACE EMISSION MONITORING INSTRUMENT CALIBRATION LOG

Site:				
Purpose:	My M	1		
Date: 3-7-20		Time:	0930	
Model #				
Serial # #12 10362	46741			
INSTRUMENT INTEGRIT	CHECKLIST	INSTE	RUMENT CALIBRA	TION
Battery test	Pass / Fail	CAlibration Gas (ppm)	ALIBRATION CHEC Actual (ppm)	K % Accuracy
Reading following ignition Leak test	<u>2, b</u> ppm Pass / Fail / NA	560	500	100%
Clean system check (check valve chatter)	Pass / Fail / NA	Calibration Gas, p	,piii	00
H <sub>2</sub> supply pressure gauge (acceptable range 9.5 - 12)	fass / Fail / NA	1.	attain 90% of Cal Ga	as ppm
Date of last factory calibration	1-3-20	3.		
Factory calibration record w/instrument within 3 months	Pass / Fail	Average So Equal to or less the Instrument calibration	nan 30 seconds?	<b>℘</b> N gas.
Comments:				



## SURFACE EMISSION MONITORING INSTRUMENT CALIBRATION LOG

Time: 0995
INCTRUMENT OAL IRRATION
INCTRUMENT OALURDATION
INCTOLLEGATION OALIDD ATION
INSTRUMENT CALIBRATION
CALIBRATION CHECK Calibration Actual %
Gas (ppm) (ppm) Accuracy
S00 S00 100%
RESPONSE TIME  Calibration Gas, ppm
90% of Calibration Gas, ppm <u>450</u> Time required to attain 90% of Cal Gas ppm 1.
2. <u>6</u> 3.
Average 6.0  Equal to or less than 30 seconds? N  Instrument calibrated to 6.44 gas.



520 N. Kings Road • Nampa • Idaho • 83687 800-552-5003 • www.isgases.com

## CERTIFICATE OF ANALYSIS

 $\begin{array}{c|c} \underline{\text{Composition}} & \underline{\text{Certification}} & \underline{\text{Analytical Accuracy}} \\ \text{Air - Zero} & & & & \\ \hline \text{THC} & & <2 \text{ PPM} \\ \text{Oxygen} & & 20.9\% & & \pm 2\% \\ \text{Nitrogen} & & \text{Balance} & & & \\ \hline \end{array}$ 

Lot#

19-6779

Mfg. Date:

4/3/2019

Parent Cylinder ID

001739, 02268

Number:

## **Method of Preparation:**

Gravimetric/Pressure Transfilled


## Method of Analysis:

This mix was prepared gravimetrically and is traceable to the NIST by certified weights (ID #CA10814) used to calibrate the scale.

Analysis By: Tony Janquart Quality Assurance Manager

800-552-5003

Certificate Date: 4/3/2019





520 N. Kings Road ● Nampa ● Idaho ● 83687 800-552-5003 ● www.isgases.com

## CERTIFICATE OF ANALYSIS

Composition

Certification

Analytical Accuracy

Methane

25 ppm

 $\pm 5\%$ 

Air

Balance

Lot#

17-6074

Mfg. Date:

10/16/2017

Parent Cylinder ID

17161

Number:

## Method of Preparation:

Gravimetric/Pressure Transfilled


## Method of Analysis:

The parent mix was prepared gravimetrically and is traceable to the NIST by certified weights (ID #CA10814) used to calibrate the scale.

Analysis By: Tony Janquart Quality Assurance Manager

800-552-5003

Certificate Date: 10/16/2017





520 N. Kings Road ● Nampa ● Idaho ● 83687 800-552-5003 ● www.isgases.com

## CERTIFICATE OF ANALYSIS

Composition

Certification

Analytical Accuracy

Methane

500 ppm

 $\pm 2\%$ 

Air Balance

Lot#

19-6955

Mfg. Date:

7/24/2019

Parent Cylinder ID

001763

Number:

## **Method of Preparation:**

Gravimetric/Pressure Transfilled


## Method of Analysis:

The parent mix was prepared gravimetrically and is traceable to the NIST by certified weights (ID #CA10814) used to calibrate the scale.

Analysis By: Tony Janquart Quality Assurance Manager

800-552-5003

Certificate Date: 7/24/2019



# APPENDIX I WELLFIELD MONITORING LOGS

Wellfield Monitoring Report -

November 5, 6, 7, 11, 12, 15, and 27, 2019

Device Name	Date Time	CH4 (Methane) (%)	CO2 (Carbon Dioxide) (%)	O2 (Oxygen) (%)	Balance Gas (%)	Initial Static Pressure ("H2O)	Initial Temperature (°F)	Adjusted Static Pressure ("H2O)	Adjusted Temperature (°F)
RLHC0153	11/7/19 15:05	54.4	41.3	0	4.3	-1.1	102	-1.2	102
RLHC0156	11/15/19 8:53	58.4	37.9	0	3.7	-0.2	98	-0.3	99
RLI00003	11/6/19 15:51	38.2	45.1	0.7	16	-21.7	80	-16	79
RLI00008	11/12/19 10:48	59.4	36.2	0.1	4.3	-47.2	90	-47.3	83
RLI00016	11/15/19 7:32	28.4	25.7	0	45.9	-29.9	67	-28.2	66
RLI00017	11/15/19 7:37	41.6	32.1	0.2	26.1	-21.9	68	-20.9	68
RLI00018	11/15/19 7:47	30.9	28.2	0.1	40.8	-4.9	56	-4.9	56
RLI00019	11/15/19 7:52	56.7	35.7	0	7.6	-36.2	56	-36.7	56
RLI00029	11/5/19 12:10	50.9	37.3	1.6	10.2	-49.1	91	-49.1	89
RLI00034	11/15/19 8:22	58.1	39.6	0	2.3	-32	78	-32.4	78
RLI00035	11/15/19 8:18	48.6	36	0	15.4	-35.6	75	-33.6	75
RLI00045	11/15/19 8:11	53.9	33	0	13.1	-1	64	-1.1	67
RLI00047	11/15/19 8:08	48.4	35.2	0	16.4	-1.7	75	-1.8	74
RLI00047	11/5/19 12:28	52.6	42	0	5.4	-10.6	98	-11.5	98
RLI00083	11/5/19 11:15	54.5	34.2	2	9.3	-46	94	-45.9	94
RLI00089	11/6/19 14:38	45.3	34.2	2.8	17	-34.6	104	-45.9	104
RLI00089 RLI00095	11/6/19 14:38	45.3 51.9	34.9	0	11.9	-34.6 -2.1	94	-28.3 -2.1	94
							_		
RLI00132 RLI00134	11/11/19 14:16 11/12/19 10:03	58 54.7	38.5 39	0	3.5 6.3	-12.1 -15.4	104 110	-13.9 -19.8	104 110
				0	7				
RLI00135	11/12/19 10:07	54.1	38.9			-29.1	106	-30.4	107
RLI00137	11/5/19 14:40	62.6	33.7	0.8	2.9	-43.1	95	-41.9	96
RLI00138	11/7/19 9:03	55.1	22.6	4.1	18.2	-43.1	70	-44.6	69
RLI00139	11/7/19 9:17	54.6	22.1	4.7	18.6	-46.1	56	-46.1	56
RLI00140	11/7/19 8:37	63.4	28.9	1.4	6.3	-45.1	72	-45.3	72
RLI00141	11/5/19 16:05	53.5	34.9	0.4	11.2	-16.9	92	-17.7	93
RLI00142	11/7/19 8:31	57.4	31.8	0.9	9.9	-45	89	-44.9	89
RLI00220	11/11/19 14:41	49.7	37.4	8.0	12.1	-1.1	63	-0.8	63
RLI0100C	11/15/19 8:27	60.7	39.1	0	0.2	-36.3	75	-36	76
RLI0102C	11/11/19 9:30	56.5	37.9	0.6	5	-41.8	92	-41.7	92
RLI0103C	11/12/19 9:58	59.8	40.1	0	0.1	-34.8	105	-34.9	105
RLI0105C	11/15/19 9:15	53.8	38.5	0	7.7	-17.6	107	-17.9	107
RLI0106C	11/12/19 11:18	60.6	39.3	0	0.1	-44.7	103	-44.7	103
RLI0107C	11/15/19 9:05	48.5	34.2	2.4	14.9	-38.8	107	-35	107
RLI0108A	11/12/19 11:14	35.7	29.9	3.2	31.2	-1.4	80	-1.3	81
RLI0114A	11/15/19 9:27	39.6	28	4.8	27.6	-32.1	75	-30.2	74
RLI0115E	11/6/19 10:39	53.3	33.5	2.2	11	-38.9	74	-39.7	77
RLI0116E	11/5/19 14:49	54.5	37.6	1.3	6.6	-37.3	91	-37.4	91
RLI0117D	11/5/19 12:24	59.1	40.7	0.1	0.1	-41.6	96	-41.3	97
RLI0120D	11/5/19 11:08	16.9	14.8	11.5	56.8	-1.7	89	-1.4	90
RLI0120D	11/5/19 11:11	32.8	23.1	6.4	37.7	-1.4	90	-1.3	90
RLI0120D	11/5/19 15:29	43.8	28	4.7	23.5	-1.8	95	-1.8	95
RLI0124G	11/5/19 10:13	54.3	36.9	0	8.8	-9.2	89	-9.6	89
RLI0126C	11/11/19 9:19	61.5	31.1	1.5	5.9	-42.7	82	-42.5	83
RLI0127B	11/12/19 10:33	54.7	38.2	0	7.1	-33.1	75	-33.9	74
RLI0128A	11/15/19 9:10	49.9	38.4	0.6	11.1	-0.3	107	-0.4	108
RLI0129E	11/15/19 8:43	62.3	37.2	0	0.5	-45.4	79	-45.6	79
RLI0130E	11/15/19 8:48	53	35.3	0	11.7	-10.7	77	-10.9	77
RLIHC101	11/5/19 10:23	55.3	38.4	0.1	6.2	-32.9	92	-32.9	92
RLIHC102	11/5/19 10:16	52.5	39.4	0	8.1	-6.6	94	-6.6	94
RLIHC105	11/6/19 14:46	47.9	40.3	0	11.8	-6.2	98	-2.3	98
RLIHC107	11/6/19 14:54	44.2	38.8	0	17	-0.6	120	-0.5	120
RLLC0165	11/7/19 8:48	47	34.3	0.1	18.6	-21.7	97	-17.2	96
RLLC0166	11/7/19 8:54	48.9	34	0	17.1	-45.1	100	-43.3	100
RLLC0169	11/7/19 8:41	51.5	33.1	0.6	14.8	-35.8	103	-35.7	103
RLLC0170	11/7/19 8:44	48.9	35.5	0	15.6	-9.6	79	-9.6	79
RLLC0171	11/6/19 14:49	34	34.3	0	31.7	-0.3	99	-0.3	99
	, 0, . 0 1 1. 10	_ J.	J 1.0			J. 5.5		3.0	00

Wellfield Monitoring Report -

November 5, 6, 7, 11, 12, 15, and 27, 2019

		CH4	CO2	02		Initial Static	Initial	Adjusted Static	Adjusted
Device Name	Date Time	(Methane)	(Carbon	(Oxygen)	Balance	Pressure	Temperature	Pressure	Temperature
2011001141110	24.0 1	(%)	Dioxide) (%)	(%)	Gas (%)	("H2O)	(°F)	("H2O)	(°F)
RLHC0153	11/7/19 15:05	54.4	41.3	0	4.3	-1.1	102	-1.2	102
RLHC0156	11/15/19 8:53	58.4	37.9	0	3.7	-0.2	98	-0.3	99
RLLC0175	11/12/19 10:17	59.5	40.4	0	0.1	-44.4	101	-44	102
RLLC0176	11/11/19 14:27	53.5	44.9	0	1.6	-0.1	95	-0.3	102
RLLC0179	11/15/19 10:26	46.7	33.7	0	19.6	-2.2	84	-2.2	84
RLLC0180	11/12/19 9:37	57.8	40.2	0	2	-1.1	80	-1.4	85
RLLC0181	11/12/19 11:10	55.6	38.5	0	5.9	-10.6	104	-11.5	104
RLLC0183	11/12/19 10:28	49.6	36.6	0	13.8	-3.8	79	-3.8	79
RLLC0184	11/12/19 10:43	51.6	36.9	0	11.5	-7.5	99	-7.5	99
RLLC0185	11/27/19 13:41	52.4	47.5	0	0.1	-0.3	82	-0.4	84
RLLC0186	11/12/19 15:29	57.3	38.5	0.1	4.1	-7.4	95	-9.2	96
RLLC0187	11/12/19 9:51	57.3	39.8	0	2.9	-41.7	102	-42	102
RLLC0188	11/12/19 9:48	53	39.7	0	7.3	-3.5	101	-4	102
RLLC0189	11/12/19 9:44	54.9	39.8	0	5.3	-4.8	106	-5.1	107
RLLC0190	11/12/19 9:41	47.4	38.6	0	14	-1	96	-1.1	96
RLLC0191	11/5/19 10:45	53.2	36.3	0	10.5	-1.1	87	-1.2	89
RLLC0193	11/6/19 10:44	52.1	38.3	0.6	9	-15	105	-15.7	105
RLLC0194	11/7/19 14:54	49.8	39	0	11.2	-19.8	101	-16.8	101
RLLC0195	11/7/19 14:57	50.9	38.2	0	10.9	-13.6	100	-13.6	101
RLLC0196	11/7/19 15:02	58.4	38.6	0.3	2.7	-39.7	106	-39.6	106
RLLC0198	11/7/19 14:38	47.3	36.8	0	15.9	-14	111	-10.7	110
RLLC0199	11/7/19 14:35	50.1	38.8	0	11.1	-14.6	109	-14.1	109
RLLC0200	11/7/19 14:27	45.3	34.9	0	19.8	-2	96	-1.5	96
RLLC0201	11/7/19 14:10	45.4	35.6	0	19	-3.5	106	-2.5	106
RLLC0202	11/7/19 14:50	54.4	39.4	0	6.2	-9.4	103	-14.7	103
RLLC0203	11/11/19 8:17	53.8	38.5	0	7.7	-16.4	101	-17.7	102
RLLC0204	11/11/19 8:19	51.6	38.4	0.2	9.8	-2.5	100	-2.5	101
RLLC0205	11/15/19 9:20	39.9	34.4	0	25.7	-0.1	91	-0.1	91
RLLC0206	11/11/19 9:16	46.7	34.4	0.2	18.7	-1.1	102	-0.8	101
RLLC0207	11/11/19 9:22	39.3	32.8	0	27.9	-0.6	90	-0.3	90
RLLC0208	11/11/19 9:26	53.3	36.9	1.1	8.7	-3.6	76	-5.3	75
RLLC0209	11/11/19 9:13	45.5	35	0	19.5	-1	100	-0.7	99
RLLC0210	11/11/19 8:22	43.1	36.5	0	20.4	-0.3	101	-0.2	100
RLLC0212	11/6/19 15:27	51.9	39.1	0.7	8.3	-20.2	87	-20.2	87
RLLC0213	11/6/19 15:08	41.2	34.1	0	24.7	-1.6	84	-1.6	85
RLLC0214	11/6/19 15:20	56.8	36.9	0	6.3	-2.4	102	-4.6	102
RLLC0215	11/6/19 15:16	53.7	38	0	8.3	-2.9	95	-3.7	95
RLLC0217	11/5/19 11:31	53.6	38	0	8.4	-9	94	-9.9	94
RLLC0218	11/5/19 14:45	54.6	39.3	0.7	5.4	-36.1	91	-36.1	92
RLLC0219	11/6/19 14:10	52.1	39.4	0.3	8.2	-2.7	103	-3.6	102
RLLC0221	11/7/19 14:47	57.2	39.8	0	3	-10.6	103	-13.6	104
RLLC0222	11/5/19 15:17	51.2	39	0.6	9.2	-8	101	-8	101
RLLC0223	11/5/19 15:14	51.2	41.1	0.1	7.6	-3.9	100	-4	100
RLLC0224	11/5/19 15:10	50.7	38.1	1.2	10	-1.5	106	-1.5	107
RLLC0225	11/7/19 14:07	41.4	34.6	0	24	-6.5	102	-4.3	101
RLLC0226	11/6/19 15:23	53.3	38.3	0.5	7.9	-4.7	96 87	-5.3 -3.1	96 87
RLLC0227 RLLC0228	11/5/19 11:25	53.5 51.6	36.7	0	9.8 10.6	-2.6	109	-3.1 -4.4	109
RLLC0228 RLLC0229	11/7/19 14:42 11/7/19 14:32	51.6 40.5	37.8 36.9	0	22.6	-4.4 -0.7	109	-4.4	109
RLLC0229 RLLC0230	11/5/19 15:02	52.1	42.6	0	5.3	-0. <i>1</i> -2.1	110	-0.0	110
RLLC0230 RLLC0231	11/6/19 14:26	54.7	38.1	0.3	6.9	-2.1	95	-2.1	94
RLLC0231	11/6/19 14:30	51.7	38.8	0.3	9.4	-1.7	93	-2.4	93
RLLC0232	11/5/19 14:59	53.2	42.2	0.1	4.6	-2.0	100	-1.3	101
RLLC0233	11/5/19 12:13	51.2	43	0.2	5.6	-7.3	91	-7.3	91
RLLC0234	11/12/19 15:42	51.3	43.5	0.2	5.2	-7.5 -7.5	91	-7.5 -7.5	92
RLLC0235	11/5/19 12:16	52.5	41.7	0.2	5.6	-4.2	90	-4.7	90
INCLUDEDO	11/0/10 12.10	JZ.J	71.7	٠.٧	5.0	-4.2	90	7.7	30

Wellfield Monitoring Report -

November 5, 6, 7, 11, 12, 15, and 27, 2019

Device Name	Date Time	CH4 (Methane) (%)	CO2 (Carbon Dioxide) (%)	O2 (Oxygen) (%)	Balance Gas (%)	Initial Static Pressure ("H2O)	Initial Temperature (°F)	Adjusted Static Pressure ("H2O)	Adjusted Temperature (°F)
RLHC0153	11/7/19 15:05	54.4	41.3	0	4.3	-1.1	102	-1.2	102
RLHC0156	11/15/19 8:53	58.4	37.9	0	3.7	-0.2	98	-0.3	99
RLLC0235	11/12/19 15:45	50.7	41.8	0	7.5	-5.4	90	-5.2	91
RLLC0236	11/5/19 12:20	52.1	41.2	0	6.7	-1.7	90	-1.7	90
RLLC0236	11/12/19 15:49	50.3	40.6	0	9.1	-2	90	-1.7	90
RLLC0237	11/5/19 14:43	52.2	40.4	0.3	7.1	-3.4	98	-3.3	98
RLLC0238	11/5/19 12:34	52.6	41.1	0	6.3	-2.5	98	-2.9	98
RLLC0239	11/5/19 14:52	52.7	40.1	0	7.2	-0.2	100	-0.3	100
RLLC0240	11/5/19 14:56	52.5	40.3	0	7.2	-1.5	101	-1.6	101
RLLC0241	11/5/19 12:06	54.8	43	0.5	1.7	-30.2	98	-33.2	99
RLLC0241	11/12/19 15:38	55.1	43.4	0.3	1.2	-34.3	98	-36.3	98
RLLC0242	11/5/19 12:02	52.9	44	0	3.1	-1.6	99	-1.9	99
RLLC0242	11/12/19 15:35	49.8	43	0	7.2	-1.9	99	-1.5	99
RLLC0243	11/5/19 10:33	51.2	44.8	0	4	-0.1	97	-0.1	97
RLLC0244	11/5/19 10:30	52.5	44.5	0	3	-0.5	100	-0.5	100
RLLC0245	11/5/19 10:27	46.4	45.9	0	7.7	-0.2	93	-0.2	93

There are 119 total collectors; 110 vertical wells and 9 horizontal collectors at RLI.

Wellfield Monitoring RLI 2020.05 SAR Appendix v1.xlsx

<sup>%=</sup> percent

<sup>°</sup>F= degrees Fahrenheit

<sup>&</sup>quot;H2O = in. w.c.= inches in water column

Wellfield Monitoring Report -

December 2, 3, 4, 5, 10, 16, 17, 19, 20, 23, and 30, 2019

		CUA	CO2	00		Initial Ct-t:	Initial	Adiusta - Ot-1	A diversed
Device Name	Date Time	CH4 (Methane)	(Carbon	O2 (Oxygen)	Balance	Initial Static Pressure	Initial Temperature	Adjusted Static Pressure	Adjusted Temperature
Bovico Manio	Dato Timo	(%)	Dioxide)	(%)	Gas (%)	("H2O)	(°F)	("H2O)	(°F)
RLHC0153	12/16/19 10:09	57.5	(%) 41.2	0	1.3	-1	98	-1.2	99
RLHC0156	12/23/19 8:53	56.6	36.4	1.6	5.4	-5.9	61	-23.7	73
RLI00003	12/17/19 14:30	52	39.8	0	8.2	-22	65	-22.7	65
RLI00008	12/17/19 13:52	62	37.6	0.1	0.3	-33.4	70	-33.3	69
RLI00016	12/23/19 9:11	61.6	30.6	1.8	6	-40.1	50	-40.1	50
RLI00017	12/23/19 9:15	62.6	37.2	0	0.2	-12.8	61	-21.6	64
RLI00018	12/23/19 9:20	51.3	28.2	3.6	16.9	-6.5	48	-5.6	46
RLI00019	12/23/19 9:25	61.3	37.5	0.6	0.6	-47.1	48	-47	49
RLI00029	12/4/19 10:34	59.7	40.2	0	0.1	-8.6	78	-25.5	83
RLI00034	12/17/19 14:20	60.6	38.7	0.1	0.6	-19.1	76	-19.2	77
RLI00035	12/23/19 9:38	60.3	39.6	0	0.1	-15.6	72	-17.1	73
RLI00045	12/23/19 9:47	62.7	35.8	0	1.5	-2	66	-2.6	68
RLI00047	12/23/19 9:44	61.5	38.4	0	0.1	-1.6	68	-1.8	70
RLI00065	12/4/19 10:48	48.5	41	0	10.5	-13.7	96	-11.1	96
RLI00083	12/4/19 9:35	61.5	38.4	0	0.1	-46.9	93	-47.1	93
RLI00089	12/20/19 14:38	47.8	36.5	2.2	13.5	-24.8	97	-21.5	97
RLI00095	12/3/19 15:58	56.3	36.5	0	7.2	-1.1	93	-1.4	94
RLI00132	12/17/19 14:14	55.2	38.4	0	6.4	-15.7	101	-17	102
RLI00134	12/17/19 11:34	59.7	40.2	0	0.1	-17	107	-19.3	108
RLI00135	12/17/19 11:38	59.9	39.8	0	0.3	-23.7	103	-24.4	103
RLI00137	12/19/19 11:25	63.9	35.7	0.3	0.1	-27.1	69	-26	68
RLI00138	12/19/19 11:13	60.6	24.5	3.3	11.6	-26.4	67	-26.9	67
RLI00139	12/19/19 10:53	26.4	26.7	4.6	42.3	-26.8	52	-15.9	53
RLI00140	12/10/19 12:46	68.5	29.8	0.7	1	-31.6	62	-31.5	62
RLI00141	12/10/19 13:11	51.1	35.5	0	13.4	-14.5	90	-14.5	90
RLI00142	12/20/19 14:43	62.3	33.6	0.7	3.4	-43.7	79	-43.7	79
RLI00220	12/20/19 14:15	57.5	40.4	0.1	2	-0.9	51	-1.2	52
RLI0100C	12/17/19 14:26	60.1	39.8	0	0.1	-20.8	76	-20.8	76
RLI0102C	12/17/19 11:08	60.7	39.1	0.1	0.1	-32.7	89	-32.5	89
RLI0105C	12/17/19 11:03	56.6	38.3	0	5.1	-15.3	104	-15.4	104
RLI0106C RLI0107C	12/17/19 14:38	60.5 59.1	39 40.5	0.3	0.2	-32.5 -7.2	89 97	-32.5 -11.6	89
RLI0107C	12/17/19 14:53 12/17/19 14:46	34.6	30.5	0.2	34.6	-7.2	57	-2.2	99 56
RLI0108A RLI0114A	12/17/19 14:40	64.5	33.2	1	1.3	-2.5	65	-1.2	65
RLI0115E	12/5/19 14:03	61.1	38.8	0	0.1	-42.3	70	-39.9	70
RLI0116E	12/19/19 11:32	58	41.9	0	0.1	-17.8	57	-18.2	57
RLI0117D	12/4/19 10:55	57.6	42.3	0	0.1	-45.5	90	-45.4	90
RLI0120D	12/4/19 9:31	49	30.2	4.1	16.7	-1.2	58	-1	58
RLI0124G	12/2/19 14:19	47.4	35.4	0.1	17.1	-10.3	86	-9.7	86
RLI0126C	12/16/19 10:53	61	30.6	1.9	6.5	-32.4	67	-32.3	67
RLI0127B	12/17/19 14:03	56.4	38.5	0	5.1	-26.1	105	-26.3	105
RLI0128A	12/17/19 14:49	52.1	39.5	0	8.4	-1.6	101	-1.6	101
RLI0129E	12/23/19 8:59	63.7	35.4	0.2	0.7	-45.1	75	-45.1	76
RLI0130E	12/23/19 8:49	64.5	35.1	0.3	0.1	-21	74	-25	75
RLIHC101	12/3/19 15:34	52.9	38	0	9.1	-34	91	-34	91
RLIHC102	12/3/19 15:30	52.1	38.8	0	9.1	-6.6	94	-6.7	94
RLIHC105	12/19/19 8:32	55.7	42.3	0	2	-1.6	90	-2.9	91
RLIHC107	12/19/19 8:26	57	42.9	0	0.1	-0.9	113	-1.8	114
RLLC0165	12/10/19 12:53	62.9	37	0	0.1	-26.3	80	-30.6	81
RLLC0166	12/10/19 12:58	61.1	32.4	0	6.5	-31.1	84	-31.3	82
RLLC0169	12/10/19 13:01	59.4	34.3	0	6.3	-25.6	101	-27.8	101
RLLC0170	12/10/19 13:03	45.1	34.9	0	20	-7.8	76	-7.8	76
RLLC0171	12/19/19 8:29	47.8	41.5	0	10.7	-0.7	56	-0.8	55
RLLC0175	12/17/19 11:25	54.7	45.2	0	0.1	-20.3	86	-23	87
RLLC0176	12/17/19 14:11	51.5	48.4	0	0.1	-0.2	97	-0.2	97
RLLC0179	12/4/19 9:13	31.9	23.3	0.3	44.5	-42.3	52	-42.3	52

Wellfield Monitoring Report -

December 2, 3, 4, 5, 10, 16, 17, 19, 20, 23, and 30, 2019

Device Name	Date Time	CH4 (Methane) (%)	CO2 (Carbon Dioxide) (%)	O2 (Oxygen) (%)	Balance Gas (%)	Initial Static Pressure ("H2O)	Initial Temperature (°F)	Adjusted Static Pressure ("H2O)	Adjusted Temperature (°F)
RLHC0153	12/16/19 10:09	57.5	41.2	0	1.3	-1	98	-1.2	99
RLHC0156	12/23/19 8:53	56.6	36.4	1.6	5.4	-5.9	61	-23.7	73
RLLC0180	12/17/19 11:46	58.3	41.6	0	0.1	-1.6	83	-1.7	85
RLLC0181	12/17/19 14:42	58.1	39.8	0	2.1	-9.1	103	-10	103
RLLC0183	12/17/19 14:07	47.1	34.1	0	18.8	-3.9	72	-4	72
RLLC0184	12/17/19 13:58	59.9	39.2	0	0.9	-4	95	-4.1	95
RLLC0185	12/17/19 11:29	54.5	45.4	0	0.1	-0.2	88	-0.5	90
RLLC0186	12/17/19 11:20	59.2	40.6	0	0.2	-7.8	90	-11.1	92
RLLC0187	12/17/19 11:16	59.9	40	0	0.1	-33	99	-33.1	99
RLLC0188	12/17/19 11:12	56.5	39.5	0	4	-4.8	100	-5.3	100
RLLC0189	12/17/19 11:42	56.3	39.5	0	4.2	-5.8	106	-6.3	106
RLLC0190	12/17/19 13:41	58.3	40.4	0.1	1.2	-0.9	85	-1.1	86
RLLC0191	12/3/19 15:51	44.2	34.4	0	21.4	-1.3	85	-1.1	84
RLLC0193	12/5/19 14:09	49.8	38.6	0	11.6	-21.2	107	-16.3	107
RLLC0194	12/16/19 9:51	56.5	40.7	0.1	2.7	-15.8	101	-18.2	101
RLLC0194	12/16/19 9:55	56.7	38.8	0.1	4.5	-13.6	91	-10.2	92
RLLC0195	12/16/19 10:05	59.8	40.1	0	0.1	-30.6	105	-27.1	104
RLLC0190	12/16/19 9:31	57.7	37.3	1.3	3.7	-20.2	95	-29.7	96
RLLC0198 RLLC0199	12/16/19 9:31	56.9	38.5	1.3	3.7	-20.2 -25.1	107	-20.5 -29.8	108
RLLC0199	12/16/19 9:27	62	37.8	0	0.2	-25.1	86	-29.6	91
					5			-2.3 -5.3	
RLLC0201	12/16/19 8:17	54.6	40.3	0.1	-	-4.3	102 97		103
RLLC0202	12/16/19 9:42	51.8	36.8	1.8	9.6	-13.7	_	-13.7	97
RLLC0203	12/16/19 10:34	59.5	40.4	0	0.1	-22.1	99	-25.8	99
RLLC0204	12/16/19 10:37	56.1	38.3	0.7	4.9	-7.5	96	-10	97
RLLC0205	12/16/19 10:43	45.1	34.1	0	20.8	-0.1	88	-0.1	88
RLLC0206	12/16/19 10:50	62.3	37.6	0	0.1	-0.2	89	-0.5	94
RLLC0207	12/16/19 10:56	60.7	39.2	0	0.1	-0.1	82	-0.2	85
RLLC0208	12/16/19 10:59	59.6	39.4	0.1	0.9	-4.6	70	-11.2	72
RLLC0209	12/16/19 10:47	61	38.9	0	0.1	-0.3	94	-0.5	94
RLLC0210	12/16/19 10:40	50.6	38.4	0	11	-0.3	96	-0.3	96
RLLC0212	12/10/19 15:10	55.8	40.2	0.3	3.7	-11.9	87	-12.2	87
RLLC0213	12/10/19 15:00	35.4	28.8	0.1	35.7	-2.6	56	-2.2	57
RLLC0214	12/10/19 15:07	58.9	37.9	0	3.2	-6.1	98	-7.3	98
RLLC0215	12/10/19 15:03	51.9	35.5	0	12.6	-4.6	93	-4.6	94
RLLC0217	12/4/19 9:41	50.9	37.9	0	11.2	-10.3	92	-10.2	92
RLLC0218	12/19/19 11:28	56.7	43.1	0	0.2	-16.7	56	-16.9	56
RLLC0219	12/20/19 14:22	50.6	38	0.5	10.9	-2.4	99	-2.4	99
RLLC0221	12/16/19 9:39	58.9	40.8	0.1	0.2	-14.9	97	-27.9	97
RLLC0222	12/10/19 15:40	56.5	42.1	0	1.4	-5	100	-5.7	100
RLLC0223	12/10/19 18:13	54.9	41.8	0.4	2.9	-2.7	102	-3	103
RLLC0224	12/10/19 18:16	58.6	41.3	0	0.1	-0.8	104	-1.5	104
RLLC0225	12/16/19 9:18	51.3	37	0.4	11.3	-12.5	93	-12.5	93
RLLC0226	12/10/19 15:16	58.1	41.2	0	0.7	-3.3	94	-4.6	95
RLLC0227	12/3/19 16:03	53.5	36.1	0	10.4	-3.2	86	-3.4	86
RLLC0228	12/16/19 9:35	59.6	40	0.2	0.2	-8.5	92	-17.2	97
RLLC0229	12/20/19 14:33	57.8	42.1	0	0.1	-0.9	85	-1.2	85
RLLC0230	12/19/19 8:19	55.4	43.7	0	0.9	-1.6	109	-1.9	109
RLLC0231	12/19/19 11:42	52.5	38.4	0	9.1	-2.5	93	-2.5	93
RLLC0232	12/20/19 14:26	56.7	41	0	2.3	-4.4	91	-4.8	92
RLLC0233	12/19/19 8:14	57.3	42	0	0.7	-0.8	98	-1	98
RLLC0234	12/4/19 10:37	55	44	0.3	0.7	-7.7	91	-9.4	91
RLLC0234	12/30/19 14:03	54.1	42.9	0.3	2.7	-9.8	90	-11.4	91
RLLC0235	12/4/19 10:40	52.5	42.4	0.2	4.9	-5.2	90	-5.9	90
RLLC0235	12/30/19 13:59	53.8	41.5	0.2	4.5	-6.1	89	-6.9	89
RLLC0236	12/4/19 10:44	54	41.3	0	4.7	-1.6	89	-1.9	90
RLLC0236	12/30/19 13:54	56	41	0	3	-1.9	89	-2.4	89
					·	l	l		

Wellfield Monitoring Report -

December 2, 3, 4, 5, 10, 16, 17, 19, 20, 23, and 30, 2019

Device Name	Date Time	CH4 (Methane) (%)	CO2 (Carbon Dioxide) (%)	O2 (Oxygen) (%)	Balance Gas (%)	Initial Static Pressure ("H2O)	Initial Temperature (°F)	Adjusted Static Pressure ("H2O)	Adjusted Temperature (°F)
RLHC0153	12/16/19 10:09	57.5	41.2	0	1.3	-1	98	-1.2	99
RLHC0156	12/23/19 8:53	56.6	36.4	1.6	5.4	-5.9	61	-23.7	73
RLLC0237	12/4/19 11:05	56.4	42.6	0	1	-3.8	99	-4.9	99
RLLC0238	12/4/19 11:01	45.6	39.2	0	15.2	-2.7	100	-1.8	100
RLLC0239	12/4/19 11:51	55.1	40.5	0	4.4	-0.3	98	-0.5	99
RLLC0240	12/4/19 11:48	51.8	38.6	0.1	9.5	-1.9	103	-1.9	104
RLLC0241	12/4/19 9:53	54.8	44.8	0	0.4	-34.8	97	-37	98
RLLC0241	12/30/19 14:07	54.3	43.6	0.2	1.9	-38.7	97	-39	97
RLLC0242	12/4/19 9:48	52.9	44	0	3.1	-1.7	97	-2.3	98
RLLC0242	12/30/19 14:10	53.9	43.7	0	2.4	-2.4	97	-3.1	98
RLLC0243	12/3/19 15:46	49.3	44	0	6.7	-0.3	94	-0.2	94
RLLC0244	12/3/19 15:43	51.4	43.9	0	4.7	-0.5	99	-0.5	99
RLLC0245	12/3/19 15:41	44	46.7	0	9.3	-0.2	88	-0.2	88

There are 118 total collectors; 109 vertical wells and 9 horizontal collectors at RLI.

Wellfield Monitoring RLI 2020.05 SAR Appendix v1.xlsx

<sup>%=</sup> percent

<sup>°</sup>F= degrees Fahrenheit

<sup>&</sup>quot;H2O = in. w.c.= inches in water column

Wellfield Monitoring Report -

January 2, 6, 7, 8, and 14, 2020

		CUA	CO2	00		i+i-  C+-+i-	Initial	A -1:41 C4-4:-	Adiusted
Device Name	Date Time	CH4 (Methane)	(Carbon	O2 (Oxygen)	Balance	Initial Static Pressure	Initial Temperature	Adjusted Static Pressure	Adjusted Temperature
Device Name	Date Time	(%)	Dioxide) (%)	(%)	Gas (%)	("H2O)	(°F)	("H2O)	(°F)
RLHC0153	1/6/20 11:06	58	41	0	1	-1.2	99	-1.5	99
RLHC0156	1/8/20 9:08	61.3	38.6	0	0.1	-1.5	74	-3.2	81
RLI00003	1/7/20 8:36	49.9	46.1	0	4	-14.2	61	-13.5	61
RLI00008	1/7/20 13:43	62.9	36.6	0.4	0.1	-48.1	69	-48.3	70
RLI00016	1/7/20 14:00	62.7	30.2	1.4	5.7	-47	62	-47.7	62
RLI00017	1/7/20 13:56	61.9	36.7	0.5	0.9	-33.6	67	-39.1	68
RLI00018	1/7/20 13:51	62.3	31.8	0	5.9	-7	65	-9.3	66
RLI00019	1/7/20 13:47	61.7	35.8	0.9	1.6	-46.8	61	-46.7	61
RLI00029	1/6/20 9:04	60.5	39.4	0	0.1	-46.8	83	-49.2	83
RLI00034	1/7/20 14:25	59.4	40.5	0	0.1	-31.3	77	-32.1	77
RLI00035	1/7/20 14:31	60.5	39.4	0	0.1	-25	73	-27.1	74
RLI00045	1/7/20 14:39	50.2	34.3	0	15.5	-5.3	71	-5.3	71
RLI00047	1/7/20 14:36	56.6	37.3	0	6.1	-3.9	74	-4	75
RLI00065	1/6/20 8:54	50.4	43.9	0	5.7	-10.2	96	-10.2	96
RLI00083	1/2/20 14:00	61.5	38.4	0	0.1	-46.7	92	-46.5	93
RLI00089	1/6/20 8:13	43.4	34.7	3.4	18.5	-22.5	93	-16.2	92
RLI00095	1/2/20 14:04	60.7	37.3	0	2	-2	93	-2.3	93
RLI00132	1/7/20 10:20	50.4	36.6	0	13	-26.7	102	-26.7	102
RLI00134	1/7/20 10:38	58.3	39.9	0	1.8	-25.8	108	-29	108
RLI00135	1/7/20 10:41	55.6	39.2	0.1	5.1	-32	103	-32.2	103
RLI00137	1/6/20 8:31	63.4	36.3	0.2	0.1	-44	70	-44.5	73
RLI00138	1/8/20 8:11	31.8	15.9	9.8	42.5	-8	59	-8.3	60
RLI00138	1/8/20 8:16	35.1	17	8.7	39.2	-8.3	61	-6.6	59
RLI00138	1/8/20 9:56	70.4	29.5	0	0.1	-46.7	53	-46.7	53
RLI00138	1/8/20 10:00	68.9	28	0.8	2.3	-47.1	52	-46.3	52
RLI00139	1/8/20 9:51	56.1	21.1	4.3	18.5	-2.6	56	-13	57
RLI00140	1/8/20 7:50	63.2	27.9	2	6.9	-46.4	55	-46.4	55
RLI00141	1/6/20 10:09	54.9	35.5	0.2	9.4	-20.7	91	-21.6	91
RLI00142	1/8/20 7:53	60.6	31.9	0.6	6.9	-46	76	-45.9	76
RLI00220	1/6/20 7:41	52.4	38.6	0.5	8.5	-1.3	41	-1.3	41
RLI0100C	1/7/20 8:41	55.1	36.8	1.2	6.9	-35.4	75	-35.3	75
RLI0102C	1/7/20 8:32	60	38.9	0.3	0.8	-42.3	90	-42.4	90
RLI0105C	1/7/20 9:33	48.4	36.4	1	14.2	-19.9	104	-19.2	105
RLI0106C	1/7/20 9:26	57.3	37.4	1.2	4.1	-45.4	96	-45.4	96
RLI0107C	1/7/20 9:17	54.5	36.4	1.2	7.9	-16.3	99	-18.1	100
RLI0108A	1/7/20 14:06	11	15.1	1.8	72.1	-12.2	68	-2.5	67
RLI0114A	1/6/20 9:33	49.8	28.9	3.7	17.6	-27.6	65	-25	65
RLI0115E	1/2/20 14:32	61	38.7	0.2	0.1	-38.6	78	-37.6	80
RLI0116E	1/6/20 8:35	51.7	35.7	2.5	10.1	-45.8	53	-45.9	53
RLI0117D	1/6/20 8:48	57	42.8	0	0.2	-42.2	91	-42.5	91
RLI0120D	1/2/20 14:16	50.9	30.3	3.4	15.4	-3.4	67	-3.4	68
RLI0124G	1/2/20 13:25	53.6	36.7	0	9.7	-9.1	86	-9.8	86
RLI0126C	1/7/20 8:21	56.7	28.9	3	11.4	-41.5	54	-41.4	54
RLI0127B	1/7/20 10:29	54.6	37.8	0	7.6	-36.7	105	-36.9	105
RLI0128A	1/7/20 9:22	45.1	36.5	0	18.4	-1.8	107	-1 46.1	107
RLI0129E RLI0130E	1/8/20 9:20 1/8/20 9:13	65 58.2	34.6 35.2	0.2	0.2 6.6	-46 -30.1	72 75	-46.1 -34	72 76
RLIHC101	1/2/20 13:32	53.5	35.2	0	8.1	-30.1 -32.1	91	-34	91
RLIHC101 RLIHC102	1/2/20 13:32	53.9	40.2	0	5.9	-7.3	94	-32.1	94
RLIHC102	1/14/20 7:57	50.5	39.3	0.1	10.1	-7.3 -9.8	95	-9.8	95
RLIHC105	1/6/20 8:10	51.1	41.2	0.1	7.7	-4.8	92	-4.8	92
RLIHC107	1/6/20 8:00	28.4	30	0.1	41.5	-5.4	126	-4.6	124
RLLC0165	1/8/20 8:34	61.9	37.7	0.3	0.1	-45.1	73	-45.9	73
RLLC0166	1/8/20 8:42	51.1	31.4	2	15.5	-46.9	74	-46.8	73
				. –				1	
RLLC0169	1/8/20 8:31	60.6	35.6	0.6	3.2	-41.7	101	-44	101

Wellfield Monitoring Report -

January 2, 6, 7, 8, and 14, 2020

		CHA	CO2	02		Initial Ctatio	Initial	Adjusted Statio	Adjusted
Device Name	Date Time	CH4 (Methane)	(Carbon	O2 (Oxygen)	Balance	Initial Static Pressure	Initial Temperature	Adjusted Static Pressure	Adjusted Temperature
Device Name	Date Time	(%)	Dioxide) (%)	(%)	Gas (%)	("H2O)	(°F)	("H2O)	(°F)
RLHC0153	1/6/20 11:06	58	41	0	1	-1.2	99	-1.5	99
RLHC0156	1/8/20 9:08	61.3	38.6	0	0.1	-1.5	74	-3.2	81
RLLC0171	1/6/20 8:08	20.4	28.2	0.8	50.6	-1.1	62	-0.7	62
RLLC0175	1/7/20 10:02	60.3	39.5	0.1	0.1	-32.5	92	-32.2	92
RLLC0176	1/7/20 10:12	50.5	49.3	0	0.2	-0.1	91	-0.2	91
RLLC0179	1/2/20 13:51	43.4	27.5	0.1	29	-49.3	69	-48.8	69
RLLC0180	1/7/20 10:44	53.1	39.5	0	7.4	-3.7	90	-4.1	91
RLLC0181	1/7/20 14:11	52	38.9	0	9.1	-14.1	103	-13.8	103
RLLC0183	1/7/20 10:24	38.8	31.7	0.5	29	-5.6	72	-4.9	70
RLLC0184	1/7/20 10:34	59.6	39.1	0	1.3	-8.1	95	-8.9	97
RLLC0185	1/7/20 10:08	51.7	48.2	0	0.1	-0.8	88	-0.8	88
RLLC0186	1/7/20 9:55	53.9	39.8	0	6.3	-16.9	94	-19.4	94
RLLC0187	1/7/20 9:50	57.2	38.2	1	3.6	-43.4	99	-42.8	99
RLLC0188	1/7/20 9:45	54.5	39.8	0	5.7	-7.8	103	-8.2	104
RLLC0189	1/7/20 9:41	55.9	39.1	0	5	-8.8	106	-9.9	107
RLLC0190	1/7/20 9:38	41.7	33.8	0	24.5	-2.5	102	-2.1	100
RLLC0191	1/2/20 13:48	55.3	36.1	0	8.6	-0.7	75	-1	78
RLLC0193	1/2/20 14:36	54.7	39.5	0	5.8	-12.7	106	-13.5	106
RLLC0194	1/6/20 11:19	54.6	40.5	0	4.9	-21.9	99	-26	99
RLLC0195	1/6/20 11:15	60.2	39.7	0	0.1	-42.8	78	-44.5	78
RLLC0196	1/6/20 11:12	50.6	34.1	2.8	12.5	-28.5	100	-28.5	100
RLLC0198	1/6/20 14:02	60.3	39.2	0.3	0.2	-36.5	95	-37.9	95
RLLC0199	1/6/20 13:59	58.5	41.4	0	0.1	-43.1	103	-44.5	103
RLLC0200	1/6/20 13:49	51.8	36.4	0	11.8	-7.3	95	-7.3	95
RLLC0201	1/6/20 13:46	54.7	40	0	5.3	-22.5	98	-26.4	99
RLLC0202	1/6/20 14:14	56.9	37.7	1.2	4.2	-8.4	94	-14.4	96
RLLC0203	1/7/20 7:57	59.5	39.5	0.7	0.3	-42.7	88	-44.7	89
RLLC0204	1/7/20 8:00	56.9	38.9	0.5	3.7	-3.9	95	-7.1	96
RLLC0205	1/8/20 11:55	45.7	34.1	0	20.2	-0.2	85	-0.1	85
RLLC0206	1/7/20 8:14	45.8	33.2	0.3	20.7	-1	96	-0.8	94
RLLC0207	1/7/20 8:24	50.1	34.8	0	15.1	-0.1	80	-0.1	82
RLLC0208	1/7/20 8:28	56.3	37.4	1.2	5.1	-9.4	66	-15.7	68
RLLC0209	1/7/20 8:10	43.6	33.8	0	22.6	-0.9	94	-0.6	93
RLLC0210	1/7/20 8:03	48.3	36.6	0	15.1	-0.4	98	-0.3	98
RLLC0212	1/6/20 10:31	56.6	40.9	0	2.5	-28.1	87	-29.5	87
RLLC0212	1/14/20 7:47	55.7	40.6	0.4	3.3	-30.6	87	-30.8	87
RLLC0213	1/6/20 10:14	67.1	32.5	0	0.4	-9.3	66	-23.3	70
RLLC0214	1/6/20 10:21	62.1	37.6	0.1	0.2	-43.2	92	-44.6	93
RLLC0215	1/6/20 10:18	60.1	39.8	0	0.1	-3	85	-4.8	88
RLLC0217	1/6/20 14:25	56.8	38.2	0	5	-9.7	91	-11.6	92
RLLC0219	1/6/20 9:36	43.9	34.6	1.6	19.9	-2.5	98	-1.5	98
RLLC0221	1/6/20 14:10	58.5	41.4	0	0.1	-44.8	94	-45.8	94
RLLC0222	1/6/20 7:50	57.4	41.7	0.1	0.8	-10.8	97	-12	98
RLLC0222	1/14/20 7:24	55.6	41.8	0	2.6	-12.3	97	-15.6	98
RLLC0223	1/6/20 7:53	53.3	42.2	0	4.5	-4.9	98	-5.2	98
RLLC0223	1/14/20 7:28	53.5	42.3	0	4.2	-5.4	98	-6.4	99
RLLC0224	1/6/20 7:56	57.2	40.9	0.1	1.8	-3.2	103	-4	104
RLLC0224	1/14/20 7:31	55.9	40.9	0	3.2	-4.1	103	-6.1	104
RLLC0225	1/6/20 13:43	43.1	33.6	0.2	23.1	-17.2	94	-14.7	94
RLLC0226	1/6/20 10:25	58.2	41.7	0	0.1	-28.8	90	-31.8	90
RLLC0226	1/14/20 7:43	57.9	41.7	0.2	0.2	-37.9	87	-43.3	89
RLLC0227	1/2/20 14:10	55.7	36.6	0	7.7	-3.7	83	-4.3	82
RLLC0228	1/6/20 14:07	59.6	40.3	0	0.1	-8.4	96	-28.5	102
RLLC0229	1/6/20 13:55	57	40.8	0	2.2	-1.7	104	-2.1	105
RLLC0230	1/6/20 8:04	49.7	41	0	9.3	-2.8	109	-2.1	109
RLLC0231	1/6/20 9:29	49.1	37.4	0	13.5	-3.4	92	-2.9	92

Wellfield Monitoring Report -

January 2, 6, 7, 8, and 14, 2020

Device Name	Date Time	CH4 (Methane) (%)	CO2 (Carbon Dioxide) (%)	O2 (Oxygen) (%)	Balance Gas (%)	Initial Static Pressure ("H2O)	Initial Temperature (°F)	Adjusted Static Pressure ("H2O)	Adjusted Temperature (°F)
RLHC0153	1/6/20 11:06	58	41	0	1	-1.2	99	-1.5	99
RLHC0156	1/8/20 9:08	61.3	38.6	0	0.1	-1.5	74	-3.2	81
RLLC0232	1/6/20 9:24	49.6	39.1	0	11.3	-4.8	91	-3.5	91
RLLC0233	1/6/20 8:20	49.3	40.2	0	10.5	-1.7	98	-1.5	98
RLLC0234	1/6/20 9:07	52.4	42.1	0.2	5.3	-11.2	91	-12.4	91
RLLC0235	1/6/20 9:10	50.5	40.2	0.5	8.8	-7.1	89	-7.1	89
RLLC0236	1/6/20 9:14	49.3	39.5	0	11.2	-2.5	89	-2	89
RLLC0237	1/6/20 8:27	57.6	41.9	0	0.5	-5.2	96	-6.9	97
RLLC0238	1/6/20 8:43	53.8	46.1	0	0.1	-1.7	97	-2	97
RLLC0239	1/6/20 8:38	54.3	40.3	0	5.4	-0.9	98	-1.1	98
RLLC0240	1/6/20 8:17	50.9	39.2	0.2	9.7	-1.8	98	-1.8	98
RLLC0241	1/6/20 9:01	53.9	43.8	0	2.3	-39	97	-39.6	97
RLLC0242	1/6/20 8:57	47	41	0	12	-3.3	98	-2.5	98
RLLC0243	1/2/20 13:45	51.4	48.5	0	0.1	-0.4	92	-0.4	92
RLLC0244	1/2/20 13:43	54	45.9	0	0.1	-0.5	98	-0.6	98
RLLC0245	1/2/20 13:39	49.3	48.6	0	2.1	-0.2	90	-0.2	89

There are 118 total collectors; 109 vertical wells and 9 horizontal collectors at RLI.

Wellfield Monitoring RLI 2020.05 SAR Appendix v1.xlsx

<sup>%=</sup> percent

<sup>°</sup>F= degrees Fahrenheit

<sup>&</sup>quot;H2O = in. w.c.= inches in water column

Wellfield Monitoring Report -

February 5, 6, 11, 12, 13, 14, and 17, 2020

Device Name	Date Time	CH4 (Methane) (%)	CO2 (Carbon Dioxide) (%)	O2 (Oxygen) (%)	Balance Gas (%)	Initial Static Pressure ("H2O)	Initial Temperature (°F)	Adjusted Static Pressure ("H2O)	Adjusted Temperature (°F)
RLHC0153	2/12/20 10:08	52.4	40	0	7.6	-1.9	101	-2.2	101
RLHC0156	2/13/20 13:25	48.2	33.4	0.5	17.9	-0.7	95	-0.6	95
RLI00003	2/12/20 15:14	61.9	37.7	0.0	0.4	-36.3	76	-37.5	76
RLI00003	2/12/20 13:14	62.1	36.6	0.2	1.1	-46.4	97	-46.4	97
RLI00006	2/12/20 13:37	51.7	26.5	2.2	19.6	-46.6	79	-46.6	79
RLI00010 RLI00017	2/12/20 13:37	51.7	34.3	0.9	13.1	-40.0	77	-40.0	77
RLI00017 RLI00018	2/12/20 13:46	57.1	33.5	0.9	8.5	-37.4	83	-37.3 -41.3	83
+									
RLI00019	2/12/20 13:51 2/5/20 9:44	60.9	33.6	1.4	4.1	-45.1	80	-45	79
RLI00029		52.1	38.1	1.7	8.1	-39.9	82	-40.1	82
RLI00034	2/12/20 15:06	56	38	1.4	4.6	-27.1	80	-25.7	80
RLI00035	2/12/20 15:01	59.8	39.6	0	0.6	-31.2	77	-36.6	77
RLI00045	2/12/20 14:48	37.5	30.1	0.2	32.2	-5.4	83	-4.5	84
RLI00047	2/12/20 14:52	43.9	33.5	0	22.6	-5.1	83	-4.9	84
RLI00065	2/5/20 9:06	51.2	44	0	4.8	-7.1	97	-7.1	97
RLI00083	2/5/20 8:25	55.3	34.8	2.2	7.7	-46.3	91	-46.3	91
RLI00083	2/11/20 8:07	57.6	35.2	1.5	5.7	-45.4	91	-45.3	91
RLI00089	2/13/20 14:03	49.8	36.1	2.5	11.6	-11.7	97	-10.6	97
RLI00095	2/11/20 8:03	52.7	35.8	0	11.5	-3	93	-3.3	93
RLI00132	2/13/20 9:23	51.4	35.6	0.4	12.6	-28.3	102	-28.3	102
RLI00134	2/13/20 9:47	56	39.4	0	4.6	-31.1	109	-33	109
RLI00135	2/13/20 10:22	56.6	39.9	0	3.5	-33.7	105	-33.6	106
RLI00137	2/12/20 8:22	63.7	36.2	0	0.1	-42	75	-40.1	75
RLI00138	2/17/20 8:27	60.8	23.9	3.2	12.1	-45.3	57	-45.3	56
RLI00139	2/17/20 8:24	43.4	30	2.3	24.3	-45.2	56	-45.2	56
RLI00140	2/11/20 8:49	63.5	27.9	1.5	7.1	-44.2	69	-44.1	69
RLI00141	2/11/20 9:28	49.3	34.2	0.5	16	-20.8	89	-20.2	90
RLI00142	2/11/20 8:53	63	32.8	0.1	4.1	-43.7	83	-43.6	84
RLI00220	2/5/20 7:28	51.2	38.6	0.5	9.7	-0.7	40	-0.7	40
RLI0100C	2/12/20 15:10	60.5	39.4	0	0.1	-29.2	84	-29.3	84
RLI0102C	2/13/20 9:14	60	39.4	0.4	0.2	-40.6	88	-40.4	88
RLI0105C	2/13/20 10:27	51	36.7	1	11.3	-16.1	105	-16.1	105
RLI0106C	2/13/20 8:40	54.8	35.7	1.5	8	-44	95	-44.1	95
RLI0107C	2/12/20 11:18	54	36.5	0	9.5	-10.3	101	-11.4	102
RLI0108A	2/12/20 14:07	16	14.6	8.6	60.8	-43.7	82	-43.7	82
RLI0108A	2/12/20 14:11	16	14.5	8.5	61	-43.6	80	-43.1	80
RLI0108A	2/13/20 13:53	2.4	11.9	5.4	80.3	-43.6	66	-43.7	66
RLI0108A	2/14/20 11:16	0.6	2.8	18.1	78.5	-44.8	67	-44.8	66
RLI0108A	2/17/20 8:15	1.9	5.5	14.5	78.1	-45.4	61	-45.2	57
RLI0114A	2/11/20 18:16	49.3	29.8	2.9	18	-34.1	83	-26.4	83
RLI0115E	2/11/20 18:03	60.8	37.7	0.3	1.2	-37.5	77	-35.9	77
RLI0116E	2/12/20 8:27	53.3	36.7	1.9	8.1	-42	65	-42.4	65
RLI0117D	2/12/20 8:32	59.3	40.5	0	0.2	-38.2	92	-41.5	92
RLI0117D	2/5/20 8:21	45.7	30.2	4.8	19.3	-3.3	65	-2.5	66
RLI0120D RLI0120D	2/11/20 8:11	45.4	29	4.8	20.8	-3.3 -4.1	73	-3.2	73
RLI0120D RLI0124G	2/5/20 7:50	48.9	35.9	0	15.2	-16.9	82	-15.4	81
RLI0124G RLI0124G		49.7	35.8	0			82	-13.4	81
+	2/11/20 8:18				14.5	-13.5 40.8			
RLI0126C	2/13/20 9:03	60.5	30.2	2	7.3	-40.8	67	-40.8	67
RLI0127B	2/13/20 9:37	52.8	36.9	0.7	9.6	-33	104	-33.2	104
RLI0128A	2/12/20 11:22	50	38.6	0	11.4	-0.4	104	-0.4	104
RLI0129E	2/13/20 13:35	66.3	32.7	0.8	0.2	-44.7	75	-44.6	75
RLI0130E	2/13/20 13:29	54	34.7	0	11.3	-29.2	77	-30.4	77
RLIHC101	2/5/20 7:56	54.1	38.6	0	7.3	-33.1	90	-33.1	90
RLIHC101	2/11/20 8:25	53.5	37.5	0.4	8.6	-33.2	91	-32.8	90
RLIHC102	2/5/20 7:54	50.8	39.3	0	9.9	-9.6	95	-9.6	95
RLIHC102	2/11/20 8:21	51.1	39	0	9.9	-9.9	95	-9.9	95
RLIHC105	2/12/20 8:50	45.7	39.2	0	15.1	-5.4	93	-3.2	93

Wellfield Monitoring Report -

February 5, 6, 11, 12, 13, 14, and 17, 2020

Device Name	Date Time	CH4 (Methane) (%)	CO2 (Carbon Dioxide) (%)	O2 (Oxygen) (%)	Balance Gas (%)	Initial Static Pressure ("H2O)	Initial Temperature (°F)	Adjusted Static Pressure ("H2O)	Adjusted Temperature (°F)
RLHC0153	2/12/20 10:08	52.4	40	0	7.6	-1.9	101	-2.2	101
RLHC0156	2/13/20 13:25	48.2	33.4	0.5	17.9	-0.7	95	-0.6	95
RLIHC107	2/12/20 8:42	29.5	31.5	0.3	38.8	-1.2	126	-0.3	125
RLLC0165	2/13/20 14:16	62.8	37.1	0.2	0.1	-45.6	77	-44.7	78
RLLC0166	2/13/20 14:10	63.3	36.6	0	0.1	-45.2	85	-44.7 -45	85
RLLC0160	2/13/20 14:19	59.3	35.5	0	5.2	-43.2 -42.4	101	-43.1	101
RLLC0109		48.7	35.3	0	16	-42.4	83	-43.1	79
	2/13/20 14:10	-							
RLLC0171	2/12/20 8:46	22.8	29.5	0.8	46.9	-5.4	93	-0.5	91
RLLC0175	2/13/20 10:37 2/13/20 9:28	59.6	40.2	0	0.2	-29.1	92	-29.3	93
RLLC0176		38.5	42.9	-	18.6	-1	94	-0.5	95
RLLC0177	2/6/20 14:49	58.8	41.1	0	0.1	-5.4	95	-6.5	96
RLLC0177	2/11/20 18:42	55.6	42.2	0.3	1.9	-26.4	102	-29	103
RLLC0178	2/6/20 14:42	62	37.9	0	0.1	-20.3	71	-24.5	71
RLLC0179	2/11/20 8:38	42.3	31.5	0	26.2	-13.1	74	-5.6	73
RLLC0180	2/13/20 10:16	56	39.8	0	4.2	-4.1	92	-4.4	93
RLLC0181	2/12/20 14:01	53.4	39.2	0	7.4	-14.1	104	-15.6	104
RLLC0183	2/13/20 9:33	32	29.9	0.1	38	-6.5	84	-5.7	84
RLLC0184	2/13/20 9:42	57	38.7	0	4.3	-13.3	99	-13.7	99
RLLC0185	2/6/20 14:52	51.5	44.7	0	3.8	-2.1	103	-2.2	103
RLLC0186	2/13/20 9:52	54.5	40.1	0	5.4	-17.6	96	-18.5	96
RLLC0187	2/13/20 10:02	60	39.9	0	0.1	-41.6	99	-42	99
RLLC0188	2/13/20 10:06	56	40.9	0	3.1	-8.7	105	-9.3	105
RLLC0189	2/13/20 10:11	51.5	38.7	0	9.8	-10.5	108	-10.5	108
RLLC0190	2/13/20 10:18	38.6	34.5	0.1	26.8	-2.3	94	-2	94
RLLC0191	2/5/20 8:11	48.8	35.9	0	15.3	-2	86	-1.7	85
RLLC0193	2/11/20 18:08	52.5	38.5	0	9	-14.9	106	-16.3	107
RLLC0194	2/12/20 10:21	52.8	39.7	0	7.5	-25.6	101	-27.9	102
RLLC0195	2/12/20 10:18	46	35.4	0	18.6	-42.3	85	-38.9	85
RLLC0196	2/12/20 10:04	51	34.7	2.5	11.8	-25	102	-25	102
RLLC0198	2/12/20 9:39	52.2	37	0.8	10	-37.6	98	-37.1	97
RLLC0199	2/12/20 9:36	52.3	38.9	0	8.8	-42.9	106	-43.5	106
RLLC0200	2/12/20 9:31	37.3	31.9	0.6	30.2	-5.2	98	-4.1	98
RLLC0201	2/12/20 9:11	41.3	35.1	0.7	22.9	-3.8	105	-3.2	105
RLLC0202	2/12/20 11:07	53.3	38.5	0.1	8.1	-13.4	98	-20.1	100
RLLC0203	2/12/20 11:12	47	36	0	17	-39.3	96	-33	96
RLLC0204	2/13/20 8:44	49.8	37	0.4	12.8	-3.6	101	-3.6	101
RLLC0205	2/13/20 8:50	28.2	28.5	0.5	42.8	-0.3	88	-0.2	87
RLLC0206	2/13/20 8:57	38.4	32.7	0.4	28.5	-3.9	101	-3	101
RLLC0207	2/13/20 9:06	57.3	37	0.4	5.3	-0.1	77	-0.3	82
RLLC0208	2/13/20 9:08	49.9	34.9	2.7	12.5	-9.2	72	-9.2	72
RLLC0208	2/13/20 9:08	49.9	34.9	0	22	-9.2	93	-9.2	93
RLLC0209	2/13/20 8:47	27.7	29.2						100
				0	43.1	-1.6 -20.7	101	-1.1 -29.4	
RLLC0212 RLLC0213	2/12/20 7:53 2/12/20 7:37	57.9	41 32.7	0.3	0.8	-29.7 -15.7	88 68	-29.4 -19.4	88 69
		57.2 54.9		0.9	10.1	-15.7 -41.4	68 94		94
RLLC0214	2/12/20 7:46		36		8.2			-42.2 10.2	
RLLC0215	2/12/20 7:41	59.1	36.2	0	4.7	-5.1	92	-10.2	94
RLLC0217	2/5/20 7:35	47.9	37.2	0.6	14.3	-13.8	91	-11.2	91
RLLC0217	2/11/20 8:44	52.5	38.4	0	9.1	-10.5	92	-12.5	92
RLLC0219	2/11/20 18:21	42.1	35.6	0.7	21.6	-18.5	102	-8.5	102
RLLC0221	2/12/20 9:47	50.4	37	0.4	12.2	-39.2	97	-39.3	97
RLLC0222	2/11/20 14:00	44.5	37.9	0.2	17.4	-15.6	97	-11.3	97
RLLC0223	2/11/20 13:56	42.2	38.2	0	19.6	-6.2	98	-4.4	98
RLLC0224	2/11/20 13:53	47.3	38.7	0	14	-5.8	101	-4.5	101
RLLC0225	2/12/20 9:07	26.6	27.5	1.5	44.4	-29.6	96	-15	94
RLLC0226	2/12/20 7:50	58	41.9	0	0.1	-39.2	85	-42.8	86
RLLC0227	2/11/20 7:58	54.8	35.9	0	9.3	-5.4	79	-8.3	80

Wellfield Monitoring Report - Fe

February 5, 6, 11, 12, 13, 14, and 17, 2020

Device Name	Date Time	CH4 (Methane) (%)	CO2 (Carbon Dioxide) (%)	O2 (Oxygen) (%)	Balance Gas (%)	Initial Static Pressure ("H2O)	Initial Temperature (°F)	Adjusted Static Pressure ("H2O)	Adjusted Temperature (°F)
RLHC0153	2/12/20 10:08	52.4	40	0	7.6	-1.9	101	-2.2	101
RLHC0156	2/13/20 13:25	48.2	33.4	0.5	17.9	-0.7	95	-0.6	95
RLLC0228	2/12/20 9:44	51.3	35.9	1.7	11.1	-15.9	102	-15.9	102
RLLC0229	2/12/20 9:58	48.7	38.4	0	12.9	-1.7	103	-1.3	102
RLLC0230	2/12/20 8:39	50.8	41.5	0	7.7	-3.3	110	-3.3	110
RLLC0231	2/12/20 10:54	49.1	37.3	0	13.6	-2.8	93	-2.2	93
RLLC0232	2/11/20 18:31	52.7	39.6	0.1	7.6	-2.8	89	-3.3	89
RLLC0233	2/5/20 10:51	46.8	39	0.2	14	-1.1	99	-0.8	99
RLLC0234	2/5/20 9:40	50.6	41.4	0.6	7.4	-10.7	91	-10.7	91
RLLC0235	2/5/20 9:37	49.5	40.3	0.4	9.8	-5.2	89	-4.2	89
RLLC0236	2/5/20 9:32	49.9	39.4	0	10.7	-1.5	89	-1.3	89
RLLC0237	2/5/20 10:59	55.1	41.4	0	3.5	-7.4	94	-8.6	94
RLLC0238	2/5/20 11:05	54	44.4	0	1.6	-2.1	97	-2.4	97
RLLC0239	2/5/20 10:56	48.8	38.5	0	12.7	-0.8	97	-0.5	97
RLLC0240	2/5/20 10:53	50.5	39.1	0	10.4	-0.9	99	-0.9	99
RLLC0241	2/5/20 9:12	52.3	43.6	0	4.1	-37.8	97	-37.7	97
RLLC0242	2/5/20 9:09	47.6	52.3	0	0.1	-2.4	98	-1.6	97
RLLC0243	2/5/20 8:07	53.3	46.6	0	0.1	-0.4	93	-0.5	93
RLLC0244	2/5/20 8:04	54.5	45.4	0	0.1	-0.6	98	-0.8	98
RLLC0245	2/5/20 8:01	52.9	47	0	0.1	-0.5	94	-0.6	94

There are 117 total collectors; 108 vertical wells and 9 horizontal collectors at RLI.

<sup>%=</sup> percent

<sup>°</sup>F= degrees Fahrenheit

<sup>&</sup>quot;H2O = in. w.c.= inches in water column

Wellfield Monitoring Report -

March 2, 3, 9, 10, 11, and 13, 2020

		CH4	CO2	02		Initial Static	Initial	Adjusted Static	Adjusted
Device Name	Date Time	(Methane)	(Carbon	(Oxygen)	Balance	Pressure	Temperature	Pressure	Temperature
Bovies Hame	Buto Timo	(%)	Dioxide) (%)	(%)	Gas (%)	("H2O)	(°F)	("H2O)	(°F)
RLHC0153	3/3/20 8:48	47.5	39.1	0	13.4	-2.5	101	-2	101
RLHC0156	3/11/20 12:31	61.7	36.8	0	1.5	-0.2	91	-0.9	94
RLI00003	3/9/20 13:44	51.1	44.1	0.1	4.7	-17.5	74	-17.6	74
RLI00008	3/2/20 13:42	56.7	34.6	0.6	8.1	-48	78	-47.8	79
RLI00016	3/9/20 13:07	32.2	25.6	0.3	41.9	-45.6	74	-42.6	73
RLI00017	3/9/20 13:13	40.1	31.2	0.4	28.3	-37.6	75	-34.4	75
RLI00018	3/9/20 13:22	36.1	28	1.5	34.4	-43.4	77	-43.4	77
RLI00019	3/9/20 13:28	59.2	32.2	1.5	7.1	-45.7	72	-46.2	72
RLI00029	3/3/20 7:29	60.6	39.3	0	0.1	-49.3	87	-49.3	87
RLI00029	3/9/20 9:51	50.7	37.6	1.4	10.3	-47.9	87	-47.8	87
RLI00034	3/9/20 13:57	53.5	37.1	1.4	8	-27.2	78	-28.3	79
RLI00035	3/9/20 14:06	55.3	37.4	0.2	7.1	-38.2	76	-38.9	76
RLI00045	3/9/20 14:10	45.8	29.8	0.2	24.2	-6.6	74	-1.8	74
RLI00047	3/9/20 14:14	49.7	33.9	0.2	16.4	-2.5	78	-2.4	79
RLI00065	3/3/20 7:38	51.3	42.6	0	6.1	-5.3	98	-5.3	99
RLI00083	3/2/20 9:09	56.3	35	1.6	7.1	-46.1	92	-46.1	92
RLI00083 RLI00089	3/10/20 7:43	47.7	36	3	13.3	-40.1	97	-3.7	96
RLI00095	3/2/20 9:04	44.2	34.4	0	21.4	-3.4	94	-2.7	94
RLI00095 RLI00132	3/2/20 9.04	52.1	36.4	0	11.5	-31.2	102	-2.7	102
RLI00132 RLI00134	3/2/20 14:05	51.7	38.3	0	10	-31.2	102	-34.2	102
RLI00134 RLI00134	3/9/20 9:19	51.7	37.9	0	10.4	-34.1	109	-34.8	109
				0		-34.5		-34.6	
RLI00135	3/2/20 10:59	54.5	38.6		6.9		106		105
RLI00135	3/9/20 9:23	55	38.6	0	6.4	-35.4	99	-35.9	100
RLI00137	3/9/20 9:35	57.2	32.5	1.9	8.4	-43.5	84	-42.3	85
RLI00138	3/10/20 6:58	67.5	30.8	0.7	1	-47	49	-47.1	47
RLI00139	3/10/20 7:15	12.3	16	9.7	62	-38.5	48	-42.8	48
RLI00139	3/10/20 7:17	9.8	13	11.8	65.4	-47.2	50	-47.1	50
RLI00139	3/13/20 13:43	31.7	28	5.6	34.7	-44.5	70	-44.4	70
RLI00140	3/10/20 6:50	60.7	26.5	2.5	10.3	-46.8	59	-46.8	57
RLI00141	3/10/20 9:03	51.5	35.2	0	13.3	-20.1	91	-20.2	92
RLI00142	3/10/20 6:54	61.9	32.6	0.4	5.1	-46.3	79	-46.2	80
RLI00220	3/2/20 8:28	50.5	38.6	0.5	10.4	-0.9	51	-0.9	51
RLI0100C	3/9/20 13:52	60.7	39.2	0	0.1	-30.2	83	-30	83
RLI0102C	3/11/20 10:54	57.8	38.5	0.4	3.3	-41.4	90	-41.2	90
RLI0105C	3/11/20 10:09	50.4	37.6	0.2	11.8	-17	106	-17.1	106
RLI0106C	3/11/20 10:03	56.1	36.6	0.9	6.4	-45.2	99	-45.2	99
RLI0107C	3/11/20 7:58	59.9	40	0	0.1	-2.1	88	-5.1	91
RLI0114A	3/2/20 13:22	51.4	29.2	3.2	16.2	-27.5	87	-29.5	88
RLI0115E	3/2/20 11:37	55.5	36.2	0.6	7.7	-37.7	84	-41.2	85
RLI0116E	3/10/20 8:18	56.8	37.9	1.2	4.1	-42.5	66	-42	66
RLI0117D	3/10/20 8:23	60	39.8	0.1	0.1	-43.7	91	-40.9	91
RLI0120D	3/2/20 9:14	45.5	29.4	4.2	20.9	-5.6	81	-3.1	81
RLI0124G	3/2/20 8:33	50.6	36	0	13.4	-12.7	84	-12.7	84
RLI0126C	3/11/20 10:39	60.1	30.6	1.6	7.7	-41.6	80	-41.5	80
RLI0127B	3/2/20 13:52	50.5	35.4	1	13.1	-31.6	103	-31.8	103
RLI0128A	3/11/20 9:58	51.4	38.9	0	9.7	-0.3	106	-0.4	106
RLI0129E	3/11/20 12:38	53	28.4	3.7	14.9	-45.2	80	-45.3	80
RLI0130E	3/11/20 12:26	45.9	32.5	0	21.6	-28.1	79	-24.9	79
RLIHC101	3/2/20 8:44	55.9	38.9	0	5.2	-35.2	92	-35.3	93
RLIHC102	3/2/20 8:38	49.9	38.2	0	11.9	-9.9	97	-9.4	97
RLIHC105	3/10/20 7:38	50.4	40	0	9.6	-2.5	93	-2.5	93
RLIHC107	3/3/20 13:32	43.8	38	0	18.2	-0.7	123	-0.3	123
RLLC0165	3/10/20 7:31	60.1	36.6	1	2.3	-47.1	84	-46.7	85
RLLC0166	3/10/20 7:28	58.5	33.3	1.8	6.4	-47.6	85	-47.3	85
RLLC0169	3/10/20 8:36	54.4	34.5	0	11.1	-45	101	-45.4	101
RLLC0170	3/10/20 8:34	49.5	35.2	0	15.3	-9.3	68	-9.3	68

Wellfield Monitoring Report -

March 2, 3, 9, 10, 11, and 13, 2020

Device Name	Date Time	CH4 (Methane) (%)	CO2 (Carbon Dioxide) (%)	O2 (Oxygen) (%)	Balance Gas (%)	Initial Static Pressure ("H2O)	Initial Temperature (°F)	Adjusted Static Pressure ("H2O)	Adjusted Temperature (°F)
RLHC0153	3/3/20 8:48	47.5	39.1	0	13.4	-2.5	101	-2	101
RLHC0156	3/11/20 12:31	61.7	36.8	0	1.5	-0.2	91	-0.9	94
RLLC0171	3/3/20 13:35	39.5	37.7	0	22.8	-0.2	96	-0.6	96
RLLC0171	3/2/20 10:50	59.9	40	0	0.1	-30	91	-30	92
RLLC0176	3/2/20 10:45	38.4	41.5	0	20.1	-0.4	96	-0.1	96
RLLC0177	3/2/20 10:25	53	43.2	0	3.8	-36.5	105	-36.2	105
RLLC0177	3/11/20 10:59	52.2	43.1	0	4.7	-36.8	104	-36.2	104
RLLC0178	3/2/20 10:40	44.9	43.3	1.3	10.5	-39.4	72	-37.7	70
RLLC0179	3/2/20 9:17	41.4	31.4	0	27.2	-3.6	77	-3.6	77
RLLC0180	3/9/20 8:49	50.9	37.5	0	11.6	-4.2	94	-4.2	94
RLLC0181	3/11/20 10:13	49.6	37.9	0	12.5	-17.5	104	-17	105
RLLC0183	3/2/20 13:55	39.4	30.4	0.4	29.8	-3	78	-3	78
RLLC0184	3/2/20 13:47	50.8	36.9	0	12.3	-13.7	99	-13.7	100
RLLC0185	3/2/20 10:31	25.4	36.8	1.2	36.6	-1.2	105	-1.3	109
RLLC0186	3/9/20 9:11	47.9	37.4	0	14.7	-19.5	96	-17.8	96
RLLC0187	3/9/20 9:14	56.9	38.9	0	4.2	-43.2	99	-43.6	100
RLLC0188	3/9/20 9:06	46.3	37.8	0	15.9	-9.9	103	-8.4	103
RLLC0189	3/9/20 9:00	44.9	36.2	0	18.9	-10.9	107	-8.1	107
RLLC0190	3/9/20 8:53	33.8	32.2	0	34	-2.3	93	-2	91
RLLC0191	3/10/20 9:07	49	34.6	0.1	16.3	-1.1	82	-1.1	83
RLLC0193	3/2/20 13:17	52.9	38	0	9.1	-17.8	107	-18.5	107
RLLC0194	3/3/20 8:35	49.9	39.4	0	10.7	-28.6	101	-27.1	101
RLLC0195	3/3/20 8:40	43.4	34.5	0	22.1	-39.5	87	-32.8	87
RLLC0196	3/3/20 8:45	59.6	39.7	0	0.7	-27.2	105	-27.3	105
RLLC0190	3/3/20 8:45	38.1	31.9	0.1	29.9	-38.7	103	-27.3	103
RLLC0190		51.4			9.7	-43.9		-44.4	
	3/3/20 8:20		38.9	0			108		108
RLLC0200	3/3/20 8:12	50.7	35.8	0	13.5	-1.4	91	-1.5	91
RLLC0201	3/3/20 8:08	49	38.4	0	12.6	-2.4	106	-2.4	106
RLLC0202	3/11/20 7:45	54.6	37.5	0.2	7.7	-2.8	89	-5.5	91
RLLC0203	3/11/20 7:50	46.6	36.1	0	17.3	-24.1	96	-21.6	96
RLLC0204	3/11/20 10:21	48.8	36.6	0	14.6	-2.8	102	-2.7	102
RLLC0205	3/11/20 10:29	32.8	30.8	0	36.4	-0.2	88	-0.1	88
RLLC0206	3/11/20 10:35	52.3	33.6	0	14.1	-0.5	98	-0.6	99
RLLC0207	3/11/20 10:47	45.1	33.2	0	21.7	-0.1	84	-0.1	85
RLLC0208	3/11/20 10:50	50.6	35.7	1.4	12.3	-7	79	-7	79
RLLC0209	3/11/20 10:32	51.6	35.4	0	13	-0.3	94	-0.3	94
RLLC0210	3/11/20 10:25	32.9	31.7	0	35.4	-0.7	100	-0.4	99
RLLC0212	3/2/20 9:47	54.9	39.3	0.5	5.3	-28.4	88	-28.2	88
RLLC0213	3/2/20 9:32	29.5	26.4	0	44.1	-14.6	80	-10.4	80
RLLC0214	3/2/20 9:40	46.8	34.1	0.2	18.9	-37.6	96	-16.7	95
RLLC0215	3/2/20 9:35	42.9	32.7	0	24.4	-10	95	-8.1	95
RLLC0217	3/10/20 6:47	51.2	40	0	8.8	-13.3	94	-13	93
RLLC0219	3/2/20 13:26	47.2	37.4	0.2	15.2	-3.3	101	-1.9	101
RLLC0221	3/11/20 7:42	45	33.9	0.2	21.1	-36	100	-28.1	100
RLLC0221	3/2/20 10:08	49.8	38.8	0.5	10.9	-11.3	98	-9.9	98
RLLC0222		49.8	40.4	0.5	9.8		99	-9.9 -4.7	99
	3/2/20 10:11					-5.3			
RLLC0224	3/2/20 10:14	49.9	38.3	0.2	11.6	-4.4	102	-3.8	102
RLLC0225	3/3/20 8:04	40.8	32.6	1.4	25.2	-5.6	96	-5.6	96
RLLC0226	3/2/20 9:43	59.3	40.6	0	0.1	-43.7	87	-44.7	87
RLLC0227	3/2/20 9:21	41.5	32	1	25.5	-8.5	80	-5.4	80
RLLC0228	3/3/20 8:29	43	33.6	0	23.4	-11.4	107	-8.3	107
RLLC0229	3/3/20 8:16	42.9	34.5	1.4	21.2	-0.7	97	-0.7	97
RLLC0230	3/3/20 13:28	51.3	41.6	0	7.1	-3.1	111	-3.2	111
RLLC0231	3/2/20 13:31	52.5	37.8	0	9.7	-1.7	92	-2.1	92
RLLC0232	3/2/20 13:35	51.7	38.8	0	9.5	-3.4	89	-3.4	89
			39.5	0	13	-0.9	100	-0.7	100

Wellfield Monitoring Report -

March 2, 3, 9, 10, 11, and 13, 2020

Device Name	Date Time	CH4 (Methane) (%)	CO2 (Carbon Dioxide) (%)	O2 (Oxygen) (%)	Balance Gas (%)	Initial Static Pressure ("H2O)	Initial Temperature (°F)	Adjusted Static Pressure ("H2O)	Adjusted Temperature (°F)
RLHC0153	3/3/20 8:48	47.5	39.1	0	13.4	-2.5	101	-2	101
RLHC0156	3/11/20 12:31	61.7	36.8	0	1.5	-0.2	91	-0.9	94
RLLC0234	3/3/20 7:25	53.3	41.3	0.5	4.9	-8.8	91	-9.9	91
RLLC0235	3/3/20 7:22	51.8	39.8	0.5	7.9	-3.3	89	-3.3	90
RLLC0236	3/3/20 7:41	52.2	39.8	0	8	-1.3	89	-1.8	89
RLLC0237	3/9/20 9:38	53.1	39.7	0	7.2	-9.5	93	-10.6	93
RLLC0238	3/9/20 9:42	54.3	41.5	0	4.2	-3.2	97	-4	97
RLLC0239	3/9/20 10:43	47.7	36.7	0	15.6	-0.7	97	-0.5	97
RLLC0240	3/9/20 10:41	52.6	37.8	0.1	9.5	-1.1	99	-1.2	99
RLLC0241	3/3/20 7:33	53.3	43.4	0	3.3	-39.2	98	-39.4	99
RLLC0242	3/9/20 9:46	53	46.9	0	0.1	-2.5	99	-3.4	99
RLLC0243	3/2/20 8:53	47.9	42.1	0	10	-0.6	97	-0.4	97
RLLC0244	3/2/20 8:49	43.5	38.4	0	18.1	-0.4	98	-0.3	98
RLLC0245	3/2/20 8:46	32.6	35	0	32.4	-0.7	95	-0.4	95

There are 115 total collectors; 106 vertical wells and 9 horizontal collectors at RLI.

Wellfield Monitoring RLI 2020.05 SAR Appendix v1.xlsx

<sup>%=</sup> percent

<sup>°</sup>F= degrees Fahrenheit

<sup>&</sup>quot;H2O = in. w.c.= inches in water column

Wellfield Monitoring Report -

April 1, 2, 3, 6, 7, 8, and 9, 2020

		CH4	CO2	O2		Initial Static	Initial	Adjusted Static	Adjusted
Device Name	Date Time	(Methane)	(Carbon Dioxide)	(Oxygen)	Balance Gas (%)	Pressure	Temperature	Pressure	Temperature
		(%)	(%)	(%)	Oa3 (70)	("H2O)	(°F)	("H2O)	(°F)
RLHC0153	4/7/20 9:26	48.9	39.7	0	11.4	-1.7	101	-1.4	101
RLHC0156	4/8/20 8:56	54.7	34.5	0.6	10.2	-10.2	91	-13.4	96
RLI00003	4/1/20 9:28	50.3	37.7	0.2	11.8	-46.2	73	-46.4	73
RLI00008	4/7/20 10:27	54.7	34.8	0.6	9.9	-49	83	-48.4	83
RLI00016	4/1/20 9:56	28.7	23.8	1.1	46.4	-29.8	62	-28.7	62
RLI00017	4/1/20 9:50	37	29.9	0.5	32.6	-31.7	69	-28.1	68
RLI00018	4/1/20 9:46	31.2	26.8	1.9	40.1	-42	67	-41.6	68
RLI00019	4/1/20 9:42	47.1	28.3	3.7	20.9	-48.4	61	-48.3	61
RLI00029	4/7/20 8:50	59.8	40.1	0	0.1	-48.8	84	-48.7	85
RLI00034	4/7/20 9:59	59	40.9	0	0.1	-27.8	78	-28.2	78
RLI00035	4/7/20 10:03	55.5	38.7	0	5.8	-40.2	75	-41.1	75
RLI00045	4/7/20 10:11	60.3	33.2	0	6.5	-1.5	68	-2.1	70
RLI00047	4/7/20 10:08	62.2	37.7	0	0.1	-0.3	68	-0.6	71
RLI00065	4/7/20 8:37	50.8	42	0	7.2	-4.9	99	-5	99
RLI00083	4/1/20 11:30	55.3	34.1	2	8.6	-43.6	92	-43.6	92
RLI00089	4/7/20 9:17	47.8	36.9	2.4	12.9	-9.9	104	-5.1	104
RLI00095	4/1/20 11:26	54.8	35.7	0	9.5	-1.3	94	-1.7	95
RLI00132	4/7/20 10:48	55.6	38	0	6.4	-26.2	102	-29.3	102
RLI00134	4/6/20 8:31	45.9	35.4	1.9	16.8	-37.1	109	-32.6	110
RLI00135	4/6/20 8:35	48.8	35.9	1.9	13.4	-39	107	-34.8	107
RLI00137	4/1/20 10:14	59.9	32.2	1.6	6.3	-42.6	81	-41.9	81
RLI00140	4/2/20 14:00	66.5	29	0.9	3.6	-46.8	79	-46.9	79
RLI00141	4/1/20 10:25	51.8	35.2	0	13	-20.2	91	-20.2	91
RLI00142	4/1/20 10:20	61.3	32.3	0.5	5.9	-46.9	83	-46.9	83
RLI00220	4/6/20 8:51	51.4	39.3	0.4	8.9	-1.2	45	-1.3	46
RLI0100C	4/7/20 9:54	60.6	39.3	0	0.1	-30	76	-30.4	76
RLI0102C	4/7/20 9:50	59.6	38.5	1.8	0.1	-42.9	91	-42.8	92
RLI0105C	4/8/20 9:08	52.1	37.4	0.1	10.4	-16.6	106	-17	106
RLI0106C	4/1/20 9:34	57.4	35.9	1.3	5.4	-46.1	98	-46	98
RLI0107C	4/7/20 11:31	55.6	38.4	0	6	-5.2	97	-9.1	100
RLI0114A	4/6/20 10:34	51.9	29.5	3.4	15.2	-26.8	68	-24.8	68
RLI0115E	4/1/20 10:08	60.4	36.6	0.7	2.3	-41.3	66	-41.6	67
RLI0116E RLI0117D	4/7/20 8:16 4/7/20 8:34	58.5 58.6	38.7 41.3	0.7	2.1 0.1	-38.8 -43.4	61 90	-38.5 -41.4	61 90
RLI0117D RLI0120D	4/1/20 6.34	51.1	34.4	1.5	13	-43.4	75	-41.4	75
1	4/2/20 8:48								
RLI0124G RLI0126C	4/8/20 9:12	50.1 57.1	35.1	1.7	14.4	-12 -40.7	83 74	-12 -40.7	73
RLI0120C	4/7/20 10:42	54.2	38.1	0	7.7	-35.8	106	-36	107
RLI0127B RLI0128A	4/7/20 10:42	58.9	41	0	0.1	-0.1	90	-0.5	107
RLI0129E	4/1/20 9:21	63.4	33.3	0.8	2.5	-46.6	77	-46.4	77
RLI0130E	4/8/20 8:50	51	33.9	0.0	15.1	-18.1	76	-18.2	76
RLIHC101	4/2/20 8:55	52.3	37.1	0.5	10.1	-36.7	92	-36.7	92
RLIHC102	4/2/20 8:51	52.5	38.7	0.0	8.8	-7.4	97	-7.6	97
RLIHC105	4/7/20 9:14	43.8	38.6	0.2	17.4	-2.6	91	-1.9	91
RLIHC107	4/6/20 9:04	36.1	35.8	0.2	28.1	-0.4	121	-0.4	121
RLLC0165	4/2/20 14:12	57.6	35.3	1.4	5.7	-46.5	91	-47.1	91
RLLC0166	4/2/20 14:15	62.4	35.2	0.6	1.8	-47.2	90	-47.1	91
RLLC0169	4/2/20 14:09	51.9	33.7	0	14.4	-45.2	101	-45.5	101
RLLC0170	4/2/20 14:03	51.8	35.2	0	13	-9.7	80	-9.7	81
RLLC0170	4/2/20 14:05	52.4	35.5	0	12.1	-14	92	-14	93
RLLC0170	4/9/20 9:39	51.3	35	0.1	13.6	-10.5	67	-10.6	69
RLLC0170	4/9/20 9:41	52.7	35.2	0	12.1	-31.8	92	-31.7	93
RLLC0171	4/3/20 9:47	34.8	35	0	30.2	-1.7	92	-1.7	93
RLLC0171	4/3/20 9:49	35.6	35.5	0	28.9	-10	102	-10	103
RLLC0175	4/2/20 11:09	59.5	40.4	0	0.1	-28.8	92	-29	91
-		· · · · · · · · · · · · · · · · · · ·		0.3	18.1	-0.1	96	-0.1	95

Wellfield Monitoring Report -

April 1, 2, 3, 6, 7, 8, and 9, 2020

		CH4	CO2	O2		Initial Static	Initial	Adjusted Static	Adjusted
Device Name	Date Time	(Methane)	(Carbon	(Oxygen)	Balance	Pressure	Temperature	Pressure	Temperature
		(%)	Dioxide) (%)	(%)	Gas (%)	("H2O)	(°F)	("H2O)	(°F)
RLHC0153	4/7/20 9:26	48.9	39.7	0	11.4	-1.7	101	-1.4	101
RLHC0156	4/8/20 8:56	54.7	34.5	0.6	10.2	-10.2	91	-13.4	96
RLLC0177	4/2/20 10:42	55.8	43.2	0	1	-36.4	105	-37.9	106
RLLC0178	4/2/20 10:57	58.7	41.2	0	0.1	-44.4	62	-44.4	61
RLLC0179	4/1/20 11:38	40.8	30.9	0	28.3	-4.1	78	-4.1	79
RLLC0179	4/2/20 10:12	39	30.4	0	30.6	-4.2	78	-4.2	78
RLLC0179	4/2/20 10:14	40.3	31.1	0	28.6	-25.5	84	-25.6	84
RLLC0180	4/6/20 8:12	52.4	38.1	0	9.5	-4	92	-4.5	93
RLLC0181	4/8/20 9:34	55.4	38.5	0	6.1	-9	104	-10.2	104
RLLC0183	4/3/20 11:18	33.2	28.7	2	36.1	-3.6	66	-3.7	67
RLLC0183	4/3/20 11:24	31	30.1	0	38.9	-14.1	91	-14.1	91
RLLC0184	4/7/20 10:31	44.8	35.4	0	19.8	-14.7	100	-13.8	99
RLLC0185	4/2/20 10:50	23.7	33.8	2.2	40.3	-0.6	76	-0.6	76
RLLC0185	4/2/20 10:52	29.3	34.5	1.8	34.4	-8.9	113	-8.9	114
RLLC0186	4/6/20 8:23	48.9	38.2	0	12.9	-17.2	95	-15.8	95
RLLC0187	4/6/20 8:26	48.9	35	2.5	13.6	-44.4	100	-42.7	100
RLLC0188	4/6/20 8:19	48.6	38.5	0	12.9	-7.2	105	-6.2	105
RLLC0189	4/6/20 8:15	47.6	37.1	0	15.3	-8.3	108	-6.9	108
RLLC0190	4/3/20 11:08	37.2	33.5	0	29.3	-1.2	82	-1.2	82
RLLC0190	4/3/20 11:10	40	34.6	0	25.4	-5	104	-5	104
RLLC0191	4/2/20 9:11	47.4	35	0	17.6	-1.5	87	-1.4	87
RLLC0191	4/2/20 9:30	47	34.5	0	18.5	-3.2	93	-3.2	93
RLLC0193	4/6/20 10:30	51	38.8	0	10.2	-16.9	108	-16.9	108
RLLC0194	4/7/20 9:39	52.7	40.2	0	7.1	-24.7	101	-25.3	101
RLLC0195	4/7/20 9:34	43.3	34.4	0	22.3	-27.4	88	-18.8	88
RLLC0196	4/7/20 9:31	59.8	40.1	0	0.1	-25.5	104	-26.1	105
RLLC0198	4/8/20 9:55	44.4	35	0	20.6	-20.3	111	-12.2	110
RLLC0199	4/8/20 9:59	48.3	37.6	0	14.1	-42.5	110	-39.8	110
RLLC0200	4/3/20 10:04	48.9	35.1	0	16	-1	84	-1	85
RLLC0200	4/3/20 10:05	49.8	35.2	0	15	-9.9	96	-10	97
RLLC0200	4/9/20 8:42	45.6	34.1	0	20.3	-1.5	86	-1.5	87
RLLC0200	4/9/20 8:44	46.9	35	0	18.1	-28.9	100	-28.9	100
RLLC0201	4/3/20 9:57	48.7	37.7	0	13.6	-2.4	106	-2.4	106
RLLC0201	4/3/20 9:59	49	38	0	13	-12.6	107	-12.7	107
RLLC0201	4/9/20 8:34	57.6	39.3	0	3.1	-1.6	104	-1.6	105
RLLC0201	4/9/20 8:36	57.8	39.9	0	2.3	-16.7	108	-16.8	108
RLLC0202	4/8/20 9:44	53.8	38.2	0	8	-1.9	97	-4.9	101
RLLC0203	4/8/20 9:26	52.1	38	0	9.9	-19	97	-21.3	98
RLLC0204	4/8/20 9:22	50.5	37.7	0	11.8	-2.5	103	-2.6	103
RLLC0205	4/8/20 9:16	33.9	32	0	34.1	-0.2	88	-0.1	88
RLLC0206	4/3/20 10:39	54.5	35.1	0	10.4	-0.7	99	-1	100
RLLC0206	4/3/20 10:40	54.8	35.2	0	10	-5.1	101	-5.2	101
RLLC0206	4/9/20 9:23	49.5	34.8	0	15.7	-1.3	100	-1.3	100
RLLC0206	4/9/20 9:26	49.9	35.2	0	14.9	-10.9	104	-10.9	104
RLLC0207	4/3/20 10:45	36.8	30.3	0	32.9	-0.1	61	-0.1	61
RLLC0207	4/3/20 10:47	39.4	31.5	0	29.1	-6.7	62	-6.7	62
RLLC0208	4/3/20 10:50	59.7	40.2	0	0.1	-11.4	74	-25.3	78
RLLC0208	4/3/20 10:52	59.9	40	0	0.1	-41.9	87	-41.7	87
RLLC0209	4/3/20 10:33	52.8	35.5	0	11.7	-0.3	93	-0.5	93
RLLC0209	4/3/20 10:35	53.3	36	0	10.7	-3.4	97	-3.4	97
RLLC0209	4/9/20 9:16	47.6	35	0	17.4	-0.5	93	-0.5	93
RLLC0209	4/9/20 9:19	48.2	35.4	0	16.4	-10.8	97	-10.8	97
RLLC0210	4/8/20 9:19	37.7	34	0	28.3	-0.5	100	-0.3	100
RLLC0212	4/8/20 8:36	58.7	41.2	0	0.1	-21.9	90	-21.7	90
RLLC0212	4/8/20 8:40	58.7	41.2	0	0.1	-22	90	-21.9	90

Wellfield Monitoring Report -

April 1, 2, 3, 6, 7, 8, and 9, 2020

Device Name	Date Time	CH4 (Methane) (%)	CO2 (Carbon Dioxide) (%)	O2 (Oxygen) (%)	Balance Gas (%)	Initial Static Pressure ("H2O)	Initial Temperature (°F)	Adjusted Static Pressure ("H2O)	Adjusted Temperature (°F)
RLHC0153	4/7/20 9:26	48.9	39.7	0	11.4	-1.7	101	-1.4	101
RLHC0156	4/8/20 8:56	54.7	34.5	0.6	10.2	-10.2	91	-13.4	96
RLLC0213	4/3/20 11:40	38.2	28.1	0	33.7	-6	75	-6	75
RLLC0213	4/3/20 11:42	39	28.4	0	32.6	-24.7	81	-24.9	82
RLLC0214	4/6/20 9:40	48	35.1	0	16.9	-11.5	94	-9.2	94
RLLC0215	4/6/20 9:44	44.9	33.5	0	21.6	-6.6	94	-5.7	94
RLLC0217	4/2/20 13:57	50.9	37.6	0.9	10.6	-9.1	93	-9.2	94
RLLC0219	4/3/20 11:31	52.3	39.7	0	8	-1	98	-1.8	99
RLLC0219	4/3/20 11:33	51.6	39	0.1	9.3	-9	104	-9	104
RLLC0221	4/8/20 9:50	53.9	38	0	8.1	-18.2	100	-20.8	101
RLLC0222	4/6/20 9:01	52.8	41.1	0	6.1	-11	99	-11.7	99
RLLC0223	4/6/20 9:08	54.6	42.3	0	3.1	-4.5	99	-5.4	99
RLLC0224	4/6/20 9:11	53.6	40.4	0	6	-3.8	102	-4.6	102
RLLC0225	4/8/20 10:12	47.5	36.1	0	16.4	-4	99	-3.5	99
RLLC0226	4/6/20 9:50	58.5	41.4	0	0.1	-46.3	89	-46	89
RLLC0227	4/1/20 11:21	52.7	34.6	0.2	12.5	-3.9	78	-4.4	78
RLLC0228	4/3/20 10:20	59.8	38.4	0	1.8	-2.1	96	-6.9	100
RLLC0228	4/9/20 9:00	41	33.6	0	25.4	-7.5	101	-7.5	101
RLLC0228	4/9/20 9:02	39.5	33.2	0.1	27.2	-39.8	109	-39.9	109
RLLC0229	4/3/20 10:10	48.2	38.1	0	13.7	-0.8	94	-0.8	94
RLLC0229	4/3/20 10:12	49.5	39	0	11.5	-2.4	104	-2.5	104
RLLC0229	4/9/20 8:49	39.4	35.8	0	24.8	-2	104	-2	105
RLLC0229	4/9/20 8:52	39.7	36.4	0	23.9	-20.7	112	-20.8	112
RLLC0230	4/6/20 10:16	50.2	40.5	0	9.3	-3.4	111	-3.4	111
RLLC0231	4/6/20 10:39	52.3	38.1	0	9.6	-1.4	90	-2.1	91
RLLC0232	4/7/20 11:15	55.1	39.5	0	5.4	-3	89	-3.3	90
RLLC0233	4/6/20 10:12	51.2	39.7	0	9.1	-1.1	100	-1.1	100
RLLC0233	4/7/20 8:20	47.8	39.4	0	12.8	-1.1	99	-1	99
RLLC0233	4/7/20 8:22	48.7	39.9	0	11.4	-6.7	102	-6.7	102
RLLC0233	4/8/20 13:49	47.9	39	0	13.1	-0.5	98	-0.5	98
RLLC0233	4/8/20 13:51	49.2	39.7	0	11.1	-11.6	101	-11.6	101
RLLC0234	4/7/20 8:54	52.9	41.7	0	5.4	-9.9	93	-10.8	93
RLLC0235	4/7/20 8:58	55	41.9	0	3.1	-3.1	91	-3.9	91
RLLC0236	4/7/20 9:03	49.4	38.8	0	11.8	-1.6	89	-1.4	89
RLLC0237	4/7/20 8:27	52	39.9	0	8.1	-6.4	91	-6.6	91
RLLC0238	4/7/20 8:30	52.4	41.8	0	5.8	-5.1	96	-5.6	96
RLLC0239	4/6/20 10:23	48.7	37.8	0	13.5	-0.4	98	-0.3	98
RLLC0240	4/6/20 10:20	51.3	38.8	0	9.9	-1.2	99	-1.2	99
RLLC0241	4/7/20 8:44	52.4	43.3	0	4.3	-39.4	101	-39.1	101
RLLC0242	4/7/20 8:40	52.4	47.5	0	0.1	-4.1	100	-4.7	100
RLLC0243	4/2/20 9:06	55.4	44.5	0	0.1	-0.3	96	-0.5	97
RLLC0244	4/2/20 9:03	56.7	43.1	0	0.2	-0.5	99	-0.7	100
RLLC0245	4/2/20 8:58	49.9	43.4	0	6.7	-0.3	92	-0.3	92
RLLC0245	4/2/20 9:24	49.7	43	0.1	7.2	-5.7	99	-5.6	100
RLLC0245	4/8/20 13:35	51.2	43.6	0.4	4.8	-0.5	94	-0.5	95
RLLC0245	4/8/20 13:39	52.4	44	0	3.6	-20.4	102	-20.3	102

There are 115 total collectors; 106 vertical wells and 9 horizontal collectors at RLI.

Wellfield Monitoring RLI 2020.05 SAR Appendix v1.xlsx

<sup>%=</sup> percent

<sup>°</sup>F= degrees Fahrenheit

<sup>&</sup>quot;H2O = in. w.c.= inches in water column

# APPENDIX J WELLFIELD DEVIATION LOGS

# REDWOOD LANDFILL, INC WELLFIELD DEVIATIONS AND 15-DAY REMONITORING REPORT

MONITORING PERFORMED BY: Mark McKeever and Sean Johnson

UPDATED DATE: 05/26/20
FLOW SENSING DEVICE: Landtec GEM

Well ID	Time	CH₄ (%)	CO <sub>2</sub> (%)	O <sub>2</sub> (%)	Balance Gas (%)	Initial Static Pressure (" w.c.)	Initial Temperature (°F)	Adjusted Static Pressure (" w.c.)	Adjusted Temperature (°F)	Comments	Duration of Exceedance (Days)
RLI0120D	11/5/19 11:08	16.9	14.8	11.5	56.8	-1.7	89	-1.4	90	NSPS/EG CAI;Dec. Flow/Vac.	
RLI0120D	11/5/19 11:11	32.8	23.1	6.4	37.7	-1.4	90	-1.3	90	NSPS/EG CAI;Dec. Flow/Vac.	
RLI0120D	11/5/19 15:29	43.8	28	4.7	23.5	-1.8	95	-1.8	95	No Adj. Made	0
RLI0120D w	as monitored on 1	11/5/2019 a	ind was four	nd to be in	exceedance f	for oxygen. Corre	ctive actions were	nitiated. The well	was re-monitored	I on 11/5/2019. The exceedance was cleared on 11/5/2019	
						No	well exceedances	in December 2	019.		
RLI00138	1/8/20 8:11	31.8	15.9	9.8	42.5	-8	59	-8.3	60	NSPS/EG CAI;Barely Open	
RLI00138	1/8/20 8:16	35.1	17	8.7	39.2	-8.3	61	-6.6	59	Dec. Flow/Vac.;NSPS/EG CAI	
RLI00138	1/8/20 9:56	70.4	29.5	0	0.1	-46.7	53	-46.7	53	Inc. Flow/Vac.	0
RLI00138 wa	as monitored on 1	/8/2020 and	d was found	to be in ex	ceedance fo	r oxygen. Correct	ive actions were in	tiated. The well v	vas re-monitored o	on 1/8/2020. The exceedance was cleared on 1/8/2020.	
RLI0108A	2/12/20 14:07	16	14.6	8.6	60.8	-43.7	82	-43.7	82	NSPS/EG CAI	
RLI0108A	2/12/20 14:11	16	14.5	8.5	61	-43.6	80	-43.1	80	NSPS/EG CAI;Barely Open;Dec. Flow/Vac.	
RLI0108A	2/13/20 13:53	2.4	11.9	5.4	80.3	-43.6	66	-43.7	66	NSPS/EG CAI;Barely Open	
RLI0108A	2/14/20 11:16	0.6	2.8	18.1	78.5	-44.8	67	-44.8	66	NSPS/EG CAI;Barely Open;Dec. Flow/Vac.	
RLI0108A	2/17/20 8:15	1.9	5.5	14.5	78.1	-45.4	61	-45.2	57	Barely Open;NSPS/EG CAI	5
	as monitored on 2				exceedance f	for oxygen. Corre	ctive actions were i	nitiated. The well	was re-monitored	on 2/13/2020, 2/14/2020, and 2/17/2020. Well RLI0108A	•
RLI00139	3/10/20 7:15	12.3	16	9.7	62	-38.5	48	-42.8	48	NSPS/EG CAI;Barely Open	
RLI00139	3/10/20 7:17	9.8	13	11.8	65.4	-47.2	50	-47.1	50	Barely Open;NSPS/EG CAI;Dec. Flow/Vac.	
RLI00139	3/13/20 13:43	31.7	28	5.6	34.7	-44.5	70	-44.4	70	NSPS/EG CAI;Barely Open	3
	as monitored on 3 5 on 3/24/2020.	/10/2020 ar	nd was foun	nd to be in e	xceedance f	or oxygen. Correc	ctive actions were i	nitiated. The well	was re-monitored	on 3/10/2020 and 3/13/2020. Well RLI00139 decommission	oned pursuant
						1	No well exceedan	ces in April 2020	).	·	

Well Deviation Report RLI 2020.05 SAR Appendix v1.xlsx

# APPENDIX K MONTHLY LANDFILL GAS FLOW RATES

#### Yearly LFG for A-51 & A-60 Flares and S64 & S65 Engines (Engines #1 & #2)

Month	A-51 Flare Total Flow Corrected to HHV of 500 BTU/scf (scf)	A-60 Flare Total Flow Corrected to HHV of 500 BTU/scf (scf)	S-64 Engine Total Flow Corrected to HHV of 500 BTU/scf (scf)	S-65 Engine Total Flow Corrected to HHV of 500 BTU/scf (scf)	Combined A-51, A-60, S64, and S65 Corrected to HHV of 500 BTU/scf (scf)	_	Consecutive 12- Month Corrected Total for A-60 Flare (scf)	Consecutive 12- Month Corrected Total for S-64 Engine (#1) (scf)	Consecutive 12- Month Corrected Total for S-65 Engine (#2) (scf)	Combined A-51, A-60, S 64, and S-65 Corrected 12-Month Throughput <sup>1</sup>
May-19	359,425	72,844,691	33,173,968	32,753,467	139,131,551	20,136,570	732,479,772	353,513,769	349,379,854	1,455,509,964
Jun-19	1,953,080	74,502,493	25,819,953	29,211,006	131,486,532	22,089,650	745,196,724	353,271,912	353,558,984	1,474,117,269
Jul-19	0	75,154,413	32,306,708	31,309,176	138,770,298	18,667,386	763,388,831	359,706,275	360,511,498	1,502,273,990
Aug-19	12,729,084	81,386,151	20,523,222	25,534,172	140,172,628	31,396,470	789,773,417	350,511,651	357,134,743	1,528,816,280
Sep-19	4,523,142	70,759,263	24,737,412	26,349,899	126,369,717	28,658,345	807,926,445	348,652,080	355,936,760	1,541,173,629
Oct-19	3,440,722	60,255,670	21,479,455	22,502,695	107,678,541	26,817,355	816,240,535	339,431,431	345,201,859	1,527,691,180
Nov-19	95,904	61,957,370	24,055,775	25,637,735	111,746,784	26,633,919	817,726,068	339,960,652	347,008,336	1,531,328,975
Dec-19	9,551,094	69,027,971	16,381,240	13,144,857	108,105,162	35,807,080	832,532,646	321,960,468	327,376,254	1,517,676,448
Jan-20	1,425,218	67,952,766	25,610,471	25,251,350	120,239,805	35,135,791	842,427,521	318,599,193	321,375,535	1,517,538,040
Feb-20	0	66,206,251	24,224,108	24,529,452	114,959,811	35,135,791	849,046,138	313,224,192	318,175,286	1,515,581,406
Mar-20	0	61,289,914	26,420,068	26,705,291	114,415,273	34,863,306	836,430,849	306,102,948	314,039,339	1,491,436,442
Apr-20	210,062	61,717,075	20,236,086	25,380,894	107,544,116	34,287,730	823,054,029	294,968,466	308,309,993	1,460,620,218

Notes:

<sup>1</sup>Pursuant to Title V Permit Condition Number 19867 Part 20, as modified in renewal application dated September 22, 2016 to match BAAQMD Permit To Operate, the throughput of landfill gas (with an HHV of 500 BTU/scf) to the A-51 and A-60 Landfill Gas Flares shall each not exceed 4,320,000 scf during any one day, and the combined throughput of landfill gas (with an HHV of 500 BTU/scf) to the A-51 and A-60 Flares shall not exceed 2,625 million scf during any consecutive 12-month period.

HHV= higher heating value BTU = British Thermal Units scf= standard cubic feet

Yearly LFG for A-51 and A-60 RLI 2020.05 SAR Appendix v1.xlsx

# MONTHLY LFG Input to Flare (A-51) WM - REDWOOD LANDFILL, Novato, CA

#### A-51 (Flare)

Month	Total Available Runtime (hours)	Total Downtime (hours)	Total Runtime (hours)	Average Flow (scfm)	Average CH <sub>4</sub> (%) <sup>1</sup>	Total Flow LFG Volume (scf)	Total Flow LFG Volume Corrected to HHV of 500 BTU/scf	Total CH₄ Volume (scf)	Total Heat Input (MMBTU)	CO Emission Factor (lb/MMBtu) <sup>1</sup>	CO Emissions (tons)	SO2 Emission Factor (lb/MMscf) <sup>2</sup>	SO2 Emissions (tons) <sup>2</sup>
November-19	721.00	720.20	0.80	1,925	51.2	92,394	95,904	47,336	48	0.030	0.00	131.38	0.01
December-19	744.00	665.67	78.33	1,958	51.2	9,201,558	9,551,094	4,714,262	4,776	0.030	0.07	131.38	0.60
January-20	744.00	730.20	13.80	1,658	51.2	1,373,060	1,425,218	703,464	713	0.030	0.01	127.25	0.09
February-20	696.00	696.00	0.00	0		0	0	0	0	0.030	0.00	127.25	0.00
March-20	743.00	743.00	0.00	0		0	0	0	0	0.020	0.00	127.25	0.00
April-20	720.00	717.60	2.40	1,476	48.8	212,610	210,062	103,683	105	0.020	0.00	TBD	TBD
TOTAL/ AVG:	4,368.00	4,272.67	95.33	1,902	50.6	10,879,622	11,282,278	5,568,745	5,641.14				

#### NOTES:

#### The A-51 Flare commenced operation on June 21, 2005.

1CH<sub>4</sub> content and CO emission factor was determined from the January 30, 2019 (March 28, 2019 - March 15, 2020) and January 22, 2020 (March 16, 2020 - present) source tests.

Pursuant to Title V Permit Condition Number 19867 Part 20, as modified by Authority To Construct (ATC) 19098, the throughput of landfill gas (with an HHV of 500 BTU/scf) to the A-51 Landfill Gas Flare shall not exceed 4,320,000 scf during any one day, and shall not exceed 2,625 million scf combined with the A-60 Landfill Gas Flare during any consecutive 12-month period. scfm= standard cubic feet per minute

BTU/scf= British thermal unit per square cubic feet scf= standard cubic feet

MMBTU= million British thermal units

LFG= landfill gas

CH<sub>4</sub>= methane

HHV= higher heating value

<sup>&</sup>lt;sup>2</sup>SO<sub>2</sub> emission factors are calculated on a quarterly basis and are derived from the average of all weekly samples and the quarterly lab sample (flare inlets only). SO2 Emissions are updated at the end of each quarter when the quarterly average emission factor is calculated.

#### A-51 Flare Heat Input Rate

MONTH: Nov-19

Date	Runtime (hours)	CH4 (%)*	Average Flow (scfm)	Total Flow LFG Volume (scf)	CH4 Volume (scf)	Heating Value of CH4 (BTU/scf)	Heat Input (MMBTU) / Day	Total Flow LFG Volume Corrected to HHV of 500 BTU/scf
11/1/2019	0.00	51.2	0	0	0	1,013	0	0
11/2/2019	0.00	51.2	0	0	0	1,013	0	0
11/3/2019	0.00	51.2	0	0	0	1,013	0	0
11/4/2019	0.00	51.2	0	0	0	1,013	0	0
11/5/2019	0.00	51.2	0	0	0	1,013	0	0
11/6/2019	0.00	51.2	0	0	0	1,013	0	0
11/7/2019	0.00	51.2	0	0	0	1,013	0	0
11/8/2019	0.00	51.2	0	0	0	1,013	0	0
11/9/2019	0.00	51.2	0	0	0	1,013	0	0
11/10/2019	0.00	51.2	0	0	0	1,013	0	0
11/11/2019	0.00	51.2	0	0	0	1,013	0	0
11/12/2019	0.00	51.2	0	0	0	1,013	0	0
11/13/2019	0.00	51.2	0	0	0	1,013	0	0
11/14/2019	0.00	51.2	0	0	0	1,013	0	0
11/15/2019	0.00	51.2	0	0	0	1,013	0	0
11/16/2019	0.00	51.2	0	0	0	1,013	0	0
11/17/2019	0.00	51.2	0	0	0	1,013	0	0
11/18/2019	0.00	51.2	0	0	0	1,013	0	0
11/19/2019	0.00	51.2	0	0	0	1,013	0	0
11/20/2019	0.00	51.2	0	0	0	1,013	0	0
11/21/2019	0.00	51.2	0	0	0	1,013	0	0
11/22/2019	0.00	51.2	0	0	0	1,013	0	0
11/23/2019	0.00	51.2	0	0	0	1,013	0	0
11/24/2019	0.00	51.2	0	0	0	1,013	0	0
11/25/2019	0.00	51.2	0	0	0	1,013	0	0
11/26/2019	0.00	51.2	0	0	0	1,013	0	0
11/27/2019	0.80	51.2	1,925	92,394	47,336	1,013	48	95,904
11/28/2019	0.00	51.2	0	0	0	1,013	0	0
11/29/2019	0.00	51.2	0	0	0	1,013	0	0
11/30/2019	0.00	51.2	0	0	0	1,013	0	0
Totals/ Average:	0.80	51.2	1,925	92,394.0	47,336	1,013	48	95,904
Notes:					,	Maximum:	48	95,904

#### The A-51 Flare commenced operation on June 21, 2005.

\*CH<sub>4</sub> content was determined from the January 31, 2018 (March 16, 2018 - March 27, 2019) and January 30, 2019 (March 28, 2019 - present) source tests. Pursuant to Title V Permit Condition Number 19867 Part 20, as modified by Authority To Construct (ATC) 19098, the throughput of landfill gas (with an HHV of 500 BTU/scf) to the A-51 Landfill Gas Flare shall not exceed 4,320,000 scf during any one day, and shall not exceed 2,625 million scf combined with the A-60 Landfill Gas Flare during any consecutive 12-month period.

scfm= standard cubic feet per minute

BTU/scf= British thermal unit per square cubic feet

scf= standard cubic feet

MMBTU= million British thermal units

LFG= landfill gas

CH<sub>4</sub>= methane

HHV= higher heating value

A51

#### A-51 Flare Heat Input Rate

MONTH: Dec-19

Date	Runtime (hours)	CH4 (%)*	Average Flow (scfm)	Total Flow LFG Volume (scf)	CH4 Volume (scf)	Heating Value of CH4 (BTU/scf)	Heat Input (MMBTU) / Day	Total Flow LFG Volume Corrected to HHV of 500 BTU/scf
12/1/2019	0.00	51.2	0	0	0	1,013	0	0
12/2/2019	0.00	51.2	0	0	0	1,013	0	0
12/3/2019	0.00	51.2	0	0	0	1,013	0	0
12/4/2019	0.00	51.2	0	0	0	1,013	0	0
12/5/2019	0.00	51.2	0	0	0	1,013	0	0
12/6/2019	0.00	51.2	0	0	0	1,013	0	0
12/7/2019	0.00	51.2	0	0	0	1,013	0	0
12/8/2019	0.00	51.2	0	0	0	1,013	0	0
12/9/2019	14.97	51.2	2,248	2,018,299	1,034,041	1,013	1,047	2,094,967
12/10/2019	24.00	51.2	1,982	2,853,591	1,461,989	1,013	1,481	2,961,989
12/11/2019	24.00	51.2	1,880	2,707,676	1,387,232	1,013	1,405	2,810,532
12/12/2019	14.33	51.2	1,774	1,525,987	781,813	1,013	792	1,583,954
12/13/2019	0.00	51.2	0	0	0	1,013	0	0
12/14/2019	0.00	51.2	0	0	0	1,013	0	0
12/15/2019	0.00	51.2	0	0	0	1,013	0	0
12/16/2019	0.47	51.2	1,695	47,461	24,316	1,013	25	49,264
12/17/2019	0.57	51.2	1,428	48,544	24,871	1,013	25	50,388
12/18/2019	0.00	51.2	0	0	0	1,013	0	0
12/19/2019	0.00	51.2	0	0	0	1,013	0	0
12/20/2019	0.00	51.2	0	0	0	1,013	0	0
12/21/2019	0.00	51.2	0	0	0	1,013	0	0
12/22/2019	0.00	51.2	0	0	0	1,013	0	0
12/23/2019	0.00	51.2	0	0	0	1,013	0	0
12/24/2019	0.00	51.2	0	0	0	1,013	0	0
12/25/2019	0.00	51.2	0	0	0	1,013	0	0
12/26/2019	0.00	51.2	0	0	0	1,013	0	0
12/27/2019	0.00	51.2	0	0	0	1,013	0	0
12/28/2019	0.00	51.2	0	0	0	1,013	0	0
12/29/2019	0.00	51.2	0	0	0	1,013	0	0
12/30/2019	0.00	51.2	0	0	0	1,013	0	0
12/31/2019	0.00	51.2	0	0	0	1,013	0	0
Totals/ Average:	78.33	51.2	1,958	9,201,558.0	4,714,262	1,013	4,776	9,551,094
Notes:						Maximum:	1,481	2,961,989

#### The A-51 Flare commenced operation on June 21, 2005.

\*CH<sub>4</sub> content was determined from the January 31, 2018 (March 16, 2018 - March 27, 2019) and January 30, 2019 (March 28, 2019 - present) source tests. Pursuant to Title V Permit Condition Number 19867 Part 20, as modified by Authority To Construct (ATC) 19098, the throughput of landfill gas (with an HHV of 500 BTU/scf) to the A-51 Landfill Gas Flare shall not exceed 4,320,000 scf during any one day, and shall not exceed 2,625 million scf combined with the A-60 Landfill Gas Flare during any consecutive 12-month period.

scfm= standard cubic feet per minute

BTU/scf= British thermal unit per square cubic feet

scf= standard cubic feet

MMBTU= million British thermal units

LFG= landfill gas

CH<sub>4</sub>= methane

HHV= higher heating value

A51 RLI 2020.05 SAR Appendix v1.xlsx

#### A-51 Flare Heat Input Rate

MONTH: Jan-20

Date	Runtime (hours)	CH4 (%)*	Average Flow (scfm)	Total Flow LFG Volume (scf)	CH4 Volume (scf)	Heating Value of CH4 (BTU/scf)	Heat Input (MMBTU) / Day	Total Flow LFG Volume Corrected to HHV of 500 BTU/scf
1/1/2020	0.00	51.2	0	0	0	1,013	0	0
1/2/2020	0.00	51.2	0	0	0	1,013	0	0
1/3/2020	1.03	51.2	1,485	92,088	47,180	1,013	48	95,586
1/4/2020	0.00	51.2	0	0	0	1,013	0	0
1/5/2020	0.00	51.2	0	0	0	1,013	0	0
1/6/2020	0.00	51.2	0	0	0	1,013	0	0
1/7/2020	0.00	51.2	0	0	0	1,013	0	0
1/8/2020	0.00	51.2	0	0	0	1,013	0	0
1/9/2020	0.00	51.2	0	0	0	1,013	0	0
1/10/2020	0.00	51.2	0	0	0	1,013	0	0
1/11/2020	0.00	51.2	0	0	0	1,013	0	0
1/12/2020	0.00	51.2	0	0	0	1,013	0	0
1/13/2020	0.00	51.2	0	0	0	1,013	0	0
1/14/2020	0.00	51.2	0	0	0	1,013	0	0
1/15/2020	0.97	51.2	2,359	136,819	70,097	1,013	71	142,016
1/16/2020	0.00	51.2	0	0	0	1,013	0	0
1/17/2020	0.00	51.2	0	0	0	1,013	0	0
1/18/2020	0.00	51.2	0	0	0	1,013	0	0
1/19/2020	0.00	51.2	0	0	0	1,013	0	0
1/20/2020	1.63	51.2	2,238	219,287	112,348	1,013	114	227,617
1/21/2020	4.73	51.2	1,539	437,111	223,946	1,013	227	453,715
1/22/2020	5.43	51.2	1,496	487,755	249,893	1,013	253	506,283
1/23/2020	0.00	51.2	0	0	0	1,013	0	0
1/24/2020	0.00	51.2	0	0	0	1,013	0	0
1/25/2020	0.00	51.2	0	0	0	1,013	0	0
1/26/2020	0.00	51.2	0	0	0	1,013	0	0
1/27/2020	0.00	51.2	0	0	0	1,013	0	0
1/28/2020	0.00	51.2	0	0	0	1,013	0	0
1/29/2020	0.00	51.2	0	0	0	1,013	0	0
1/30/2020	0.00	51.2	0	0	0	1,013	0	0
1/31/2020	0.00	51.2	0	0	0	1,013	0	0
Totals/ Average:	13.80	51.2	1,658	1,373,060.0	703,464	1,013	713	1,425,218
lotes:	ı	1	•		· · · · · · · · · · · · · · · · · · ·	Maximum:	253	506,283

The A-51 Flare commenced operation on June 21, 2005.

Pursuant to Title V Permit Condition Number 19867 Part 20, as modified by Authority To Construct (ATC) 19098, the throughput of landfill gas (with an HHV of 500 BTU/scf) to the A-51 Landfill Gas Flare shall not exceed 4,320,000 scf during any one day, and shall not exceed 2,625 million scf combined with the A-60 Landfill Gas Flare during any consecutive 12-month period.

scfm= standard cubic feet per minute

BTU/scf= British thermal unit per square cubic feet

scf= standard cubic feet

MMBTU= million British thermal units

LFG= landfill gas

CH<sub>4</sub>= methane

HHV= higher heating value

<sup>\*</sup>CH<sub>4</sub> content was determined from the January 30, 2019 (March 28, 2019 - present) source test.

#### A-51 Flare Heat Input Rate

MONTH: Feb-20

Date	Runtime (hours)	CH4 (%)*	Average Flow (scfm)	Total Flow LFG Volume (scf)	CH4 Volume (scf)	Heating Value of CH4 (BTU/scf)	Heat Input (MMBTU) / Day	Total Flow LFG Volume Corrected to HHV of 500 BTU/scf
2/1/2020	0.00	51.2	0	0	0	1,013	0	0
2/2/2020	0.00	51.2	0	0	0	1,013	0	0
2/3/2020	0.00	51.2	0	0	0	1,013	0	0
2/4/2020	0.00	51.2	0	0	0	1,013	0	0
2/5/2020	0.00	51.2	0	0	0	1,013	0	0
2/6/2020	0.00	51.2	0	0	0	1,013	0	0
2/7/2020	0.00	51.2	0	0	0	1,013	0	0
2/8/2020	0.00	51.2	0	0	0	1,013	0	0
2/9/2020	0.00	51.2	0	0	0	1,013	0	0
2/10/2020	0.00	51.2	0	0	0	1,013	0	0
2/11/2020	0.00	51.2	0	0	0	1,013	0	0
2/12/2020	0.00	51.2	0	0	0	1,013	0	0
2/13/2020	0.00	51.2	0	0	0	1,013	0	0
2/14/2020	0.00	51.2	0	0	0	1,013	0	0
2/15/2020	0.00	51.2	0	0	0	1,013	0	0
2/16/2020	0.00	51.2	0	0	0	1,013	0	0
2/17/2020	0.00	51.2	0	0	0	1,013	0	0
2/18/2020	0.00	51.2	0	0	0	1,013	0	0
2/19/2020	0.00	51.2	0	0	0	1,013	0	0
2/20/2020	0.00	51.2	0	0	0	1,013	0	0
2/21/2020	0.00	51.2	0	0	0	1,013	0	0
2/22/2020	0.00	51.2	0	0	0	1,013	0	0
2/23/2020	0.00	51.2	0	0	0	1,013	0	0
2/24/2020	0.00	51.2	0	0	0	1,013	0	0
2/25/2020	0.00	51.2	0	0	0	1,013	0	0
2/26/2020	0.00	51.2	0	0	0	1,013	0	0
2/27/2020	0.00	51.2	0	0	0	1,013	0	0
2/28/2020	0.00	51.2	0	0	0	1,013	0	0
2/29/2020	0.00	51.2	0	0	0	1,013	0	0
Totals/ Average:	0.00			0.0	0	1,013	0	0
Notes:						Maximum:	0	0

#### The A-51 Flare commenced operation on June 21, 2005.

\*CH<sub>4</sub> content was determined from the January 30, 2019 (March 28, 2019 - present) source test.

Pursuant to Title V Permit Condition Number 19867 Part 20, as modified by Authority To Construct (ATC) 19098, the throughput of landfill gas (with an HHV of 500 BTU/scf) to the A-51 Landfill Gas Flare shall not exceed 4,320,000 scf during any one day, and shall not exceed 2,625 million scf combined with the A-60 Landfill Gas Flare during any consecutive 12-month period.

scfm= standard cubic feet per minute

BTU/scf= British thermal unit per square cubic feet

scf= standard cubic feet

MMBTU= million British thermal units

LFG= landfill gas

CH<sub>4</sub>= methane

HHV= higher heating value

A51

#### A-51 Flare Heat Input Rate

MONTH: Mar-20

Date	Runtime (hours)	CH4 (%)*	Average Flow (scfm)	Total Flow LFG Volume (scf)	CH4 Volume (scf)	Heating Value of CH4 (BTU/scf)	Heat Input (MMBTU) / Day	Total Flow LFG Volume Corrected to HHV of 500 BTU/scf
3/1/2020	0.00	51.2	0	0	0	1,013	0	0
3/2/2020	0.00	51.2	0	0	0	1,013	0	0
3/3/2020	0.00	51.2	0	0	0	1,013	0	0
3/4/2020	0.00	51.2	0	0	0	1,013	0	0
3/5/2020	0.00	51.2	0	0	0	1,013	0	0
3/6/2020	0.00	51.2	0	0	0	1,013	0	0
3/7/2020	0.00	51.2	0	0	0	1,013	0	0
3/8/2020	0.00	51.2	0	0	0	1,013	0	0
3/9/2020	0.00	51.2	0	0	0	1,013	0	0
3/10/2020	0.00	51.2	0	0	0	1,013	0	0
3/11/2020	0.00	51.2	0	0	0	1,013	0	0
3/12/2020	0.00	51.2	0	0	0	1,013	0	0
3/13/2020	0.00	51.2	0	0	0	1,013	0	0
3/14/2020	0.00	51.2	0	0	0	1,013	0	0
3/15/2020	0.00	51.2	0	0	0	1,013	0	0
3/16/2020	0.00	48.8	0	0	0	1,013	0	0
3/17/2020	0.00	48.8	0	0	0	1,013	0	0
3/18/2020	0.00	48.8	0	0	0	1,013	0	0
3/19/2020	0.00	48.8	0	0	0	1,013	0	0
3/20/2020	0.00	48.8	0	0	0	1,013	0	0
3/21/2020	0.00	48.8	0	0	0	1,013	0	0
3/22/2020	0.00	48.8	0	0	0	1,013	0	0
3/23/2020	0.00	48.8	0	0	0	1,013	0	0
3/24/2020	0.00	48.8	0	0	0	1,013	0	0
3/25/2020	0.00	48.8	0	0	0	1,013	0	0
3/26/2020	0.00	48.8	0	0	0	1,013	0	0
3/27/2020	0.00	48.8	0	0	0	1,013	0	0
3/28/2020	0.00	48.8	0	0	0	1,013	0	0
3/29/2020	0.00	48.8	0	0	0	1,013	0	0
3/30/2020	0.00	48.8	0	0	0	1,013	0	0
3/31/2020	0.00	48.8	0	0	0	1,013	0	0
Totals/ Average:	0.00			0.0	0	1,013	0	0
lotes:	•					Maximum:	0	0

The A-51 Flare commenced operation on June 21, 2005.

\*CH<sub>4</sub> content was determined from the January 30, 2019 (March 28, 2019 - March 15, 2020) and January 22, 2020 (March 16, 2020 - present) source tests. Pursuant to Title V Permit Condition Number 19867 Part 20, as modified by Authority To Construct (ATC) 19098, the throughput of landfill gas (with an HHV of 500 BTU/scf) to the A-51 Landfill Gas Flare shall not exceed 4,320,000 scf during any one day, and shall not exceed 2,625 million scf combined with the A-60 Landfill Gas Flare during any consecutive 12-month period.

scfm= standard cubic feet per minute

BTU/scf= British thermal unit per square cubic feet

scf= standard cubic feet

MMBTU= million British thermal units

LFG= landfill gas

CH<sub>4</sub>= methane

HHV= higher heating value

A51 RLI 2020.05 SAR Appendix v1.xlsx

#### A-51 Flare Heat Input Rate

MONTH: Apr-20

Date	Runtime (hours)	CH4 (%)*	Average Flow (scfm)	Total Flow LFG Volume (scf)	CH4 Volume (scf)	Heating Value of CH4 (BTU/scf)	Heat Input (MMBTU) / Day	Total Flow LFG Volume Corrected to HHV of 500 BTU/scf
4/1/2020	0.00	48.8	0	0	0	1,013	0	0
4/2/2020	0.00	48.8	0	0	0	1,013	0	0
4/3/2020	0.00	48.8	0	0	0	1,013	0	0
4/4/2020	0.00	48.8	0	0	0	1,013	0	0
4/5/2020	0.00	48.8	0	0	0	1,013	0	0
4/6/2020	0.00	48.8	0	0	0	1,013	0	0
4/7/2020	0.00	48.8	0	0	0	1,013	0	0
4/8/2020	0.00	48.8	0	0	0	1,013	0	0
4/9/2020	0.00	48.8	0	0	0	1,013	0	0
4/10/2020	0.00	48.8	0	0	0	1,013	0	0
4/11/2020	0.00	48.8	0	0	0	1,013	0	0
4/12/2020	0.00	48.8	0	0	0	1,013	0	0
4/13/2020	0.00	48.8	0	0	0	1,013	0	0
4/14/2020	0.63	48.8	992	37,679	18,375	1,013	19	37,227
4/15/2020	0.00	48.8	0	0	0	1,013	0	0
4/16/2020	0.00	48.8	0	0	0	1,013	0	0
4/17/2020	0.00	48.8	0	0	0	1,013	0	0
4/18/2020	0.00	48.8	0	0	0	1,013	0	0
4/19/2020	0.00	48.8	0	0	0	1,013	0	0
4/20/2020	0.00	48.8	0	0	0	1,013	0	0
4/21/2020	0.23	48.8	1,168	16,355	7,976	1,013	8	16,159
4/22/2020	0.00	48.8	0	0	0	1,013	0	0
4/23/2020	0.00	48.8	0	0	0	1,013	0	0
4/24/2020	0.00	48.8	0	0	0	1,013	0	0
4/25/2020	0.00	48.8	0	0	0	1,013	0	0
4/26/2020	0.00	48.8	0	0	0	1,013	0	0
4/27/2020	0.00	48.8	0	0	0	1,013	0	0
4/28/2020	0.00	48.8	0	0	0	1,013	0	0
4/29/2020	0.00	48.8	0	0	0	1,013	0	0
4/30/2020	1.53	48.8	1,724	158,576	77,332	1,013	78	156,675
Totals/ Average:	2.40	48.8	1,476	212,610.0	103,683	1,013	105	210,062
Notes:	ı				· · · · · · · · · · · · · · · · · · ·	Maximum:	78	156,675

#### The A-51 Flare commenced operation on June 21, 2005.

\*CH<sub>4</sub> content was determined from the January 30, 2019 (March 28, 2019 - March 15, 2020) and January 22, 2020 (March 16, 2020 - present) source tests. Pursuant to Title V Permit Condition Number 19867 Part 20, as modified by Authority To Construct (ATC) 19098, the throughput of landfill gas (with an HHV of 500 BTU/scf) to the A-51 Landfill Gas Flare shall not exceed 4,320,000 scf during any one day, and shall not exceed 2,625 million scf combined with the A-60 Landfill Gas Flare during any consecutive 12-month period.

scfm= standard cubic feet per minute

BTU/scf= British thermal unit per square cubic feet

scf= standard cubic feet

MMBTU= million British thermal units

LFG= landfill gas

CH<sub>4</sub>= methane

HHV= higher heating value

A51

# MONTHLY LFG Input to Flare (A-60) WM - REDWOOD LANDFILL, Novato, CA

#### A-60 (Flare)

Month	Total Available Runtime (hours)	Total Downtime (hours)	Total Runtime (hours)	Average Flow (scfm)	Average CH <sub>4</sub> (%) <sup>1</sup>	Total Flow LFG Volume (scf)	Total Flow LFG Volume Corrected to HHV of 500 BTU/scf	Total CH₄ Volume (scf)	Total Heat Input (MMBTU)	CO Emission Factor (lb/MMBtu) <sup>1</sup>	CO Emissions (tons)	SO2 Emission Factor (lb/MMBtu) <sup>2</sup>	SO2 Emissions (tons) <sup>2</sup>
November-19	721.00	2.00	719.00	1,500	47.3	64,699,102	61,957,370	30,581,130	30,979	0.100	1.55	131.38	4.25
December-19	744.00	78.47	665.53	1,805	47.3	72,082,590	69,027,971	34,071,062	34,514	0.100	1.73	131.38	4.73
January-20	744.00	14.10	729.90	1,620	47.3	70,959,805	67,952,766	33,540,358	33,976	0.100	1.70	127.25	4.51
February-20	696.00	0.00	696.00	1,656	47.3	69,136,004	66,206,251	32,678,308	33,103	0.100	1.66	127.25	4.40
March-20	743.00	0.00	743.00	1,436	47.3	64,002,110	61,289,914	30,251,685	30,645	0.100	1.53	127.25	4.07
April-20	720.00	1.87	718.13	1,496	47.3	64,448,173	61,717,075	30,462,525	30,859	0.100	1.54	TBD	TBD
TOTAL/ AVG:	4,368.00	96.43	4,271.57	1,581	47.3	405,327,784	388,151,347	191,585,068	194,075.67	-			

#### NOTES:

#### The A-60 Flare commenced operation on April 1, 2009.

<sup>1</sup>CH<sub>4</sub> content and CO emission factor was determined from the July 25, 2019 (9/20/19 to current) source test.

Pursuant to Title V Permit Condition Number 19867 Part 20, as modified by Authority To Construct (ATC) 19098, the throughput of landfill gas (with an HHV of 500 BTU/scf) to the A-60 Landfill Gas Flare shall not exceed 4,320,000 scf during any one day, and shall not exceed 2,625 million scf combined with the A-51 Landfill Gas Flare during any consecutive 12-month period.

BTU/scf= British thermal unit per square cubic feet scf= standard cubic feet

MMBTU= million British thermal units

LFG= landfill gas

CH₄= methane

HHV= higher heating value

<sup>&</sup>lt;sup>2</sup>SO<sub>2</sub> emission factors are calculated on a quarterly basis and are derived from the average of all weekly samples and the quarterly lab sample (flare inlets only). SO<sub>2</sub> Emissions are updated at the end of each quarter when the quarterly average emission factor is calculated.

#### A-60 Flare Heat Input Rate

MONTH: Nov-19

Date	Runtime (hours)	CH4 (%)*	Average Flow (scfm)	Total LFG Volume (scf)	CH4 Volume (scf)	Heating Value of CH4 (BTU/scf)	Heat Input (MMBTU) / Day	Total Flow Corrected to HHV of 500 BTU/scf
11/1/2019	24.00	47.3	1,593	2,294,153	1,084,370	1,013	1,098	2,196,934
11/2/2019	24.00	47.3	1,607	2,314,432	1,093,956	1,013	1,108	2,216,354
11/3/2019	25.00	47.3	1,565	2,346,801	1,109,255	1,013	1,124	2,247,351
11/4/2019	24.00	47.3	1,606	2,312,694	1,093,134	1,013	1,107	2,214,690
11/5/2019	24.00	47.3	1,605	2,311,065	1,092,364	1,013	1,107	2,213,130
11/6/2019	24.00	47.3	1,594	2,295,771	1,085,135	1,013	1,099	2,198,484
11/7/2019	23.37	47.3	1,575	2,207,972	1,043,636	1,013	1,057	2,114,406
11/8/2019	24.00	47.3	1,580	2,275,440	1,075,525	1,013	1,090	2,179,014
11/9/2019	24.00	47.3	1,544	2,223,192	1,050,829	1,013	1,064	2,128,981
11/10/2019	24.00	47.3	1,593	2,293,838	1,084,222	1,013	1,098	2,196,633
11/11/2019	24.00	47.3	1,527	2,198,586	1,039,199	1,013	1,053	2,105,417
11/12/2019	24.00	47.3	1,579	2,273,152	1,074,444	1,013	1,088	2,176,823
11/13/2019	24.00	47.3	1,491	2,146,887	1,014,763	1,013	1,028	2,055,909
11/14/2019	24.00	47.3	1,468	2,114,391	999,403	1,013	1,012	2,024,790
11/15/2019	24.00	47.3	1,470	2,116,330	1,000,319	1,013	1,013	2,026,647
11/16/2019	24.00	47.3	1,469	2,115,001	999,691	1,013	1,013	2,025,374
11/17/2019	24.00	47.3	1,472	2,119,580	1,001,856	1,013	1,015	2,029,759
11/18/2019	24.00	47.3	1,664	2,395,822	1,132,426	1,013	1,147	2,294,295
11/19/2019	24.00	47.3	1,455	2,095,231	990,347	1,013	1,003	2,006,442
11/20/2019	24.00	47.3	1,448	2,085,723	985,852	1,013	999	1,997,337
11/21/2019	24.00	47.3	1,403	2,020,386	954,970	1,013	967	1,934,769
11/22/2019	24.00	47.3	1,404	2,022,167	955,812	1,013	968	1,936,474
11/23/2019	24.00	47.3	1,409	2,029,510	959,282	1,013	972	1,943,506
11/24/2019	24.00	47.3	1,411	2,032,367	960,633	1,013	973	1,946,242
11/25/2019	24.00	47.3	1,406	2,024,575	956,950	1,013	969	1,938,780
11/26/2019	24.00	47.3	1,416	2,039,045	963,789	1,013	976	1,952,637
11/27/2019	22.63	47.3	1,431	1,942,772	918,284	1,013	930	1,860,444
11/28/2019	24.00	47.3	1,409	2,029,331	959,198	1,013	972	1,943,335
11/29/2019	24.00	47.3	1,402	2,019,561	954,580	1,013	967	1,933,979
11/30/2019	24.00	47.3	1,391	2,003,327	946,907	1,013	959	1,918,433
otals/ Average:	719.00	47.3	1,500	64,699,102.0	30,581,130	1,013	30,979	61,957,370
otes:	•	•				Maximum:	1,147	2,294,295

#### The A-60 Flare commenced operation on April 1, 2009.

\*CH<sub>4</sub> content was determined from the July 17, 2018 (9/14/18 to 9/19/19) and July 25, 2019 (9/20/19 to current) source test.

Pursuant to Title V Permit Condition Number 19867 Part 30(g), the Annual Source Test at A-60 may be conducted while it is operating in either zone, providing that each operating zone is tested at least once every five years.

Pursuant to Title V Permit Condition Number 19867 Part 20, as modified by Authority To Construct (ATC) 19098, the throughput of landfill gas (with an HHV of 500 BTU/scf) to the A-60 Landfill Gas Flare shall not exceed 4,320,000 scf during any one day, and shall not exceed 2,207,520,000 scf combined with the A-51 Landfill Gas Flare during any consecutive 12-month period.

scfm= standard cubic feet per minute

BTU/scf= British thermal unit per square cubic feet

scf= standard cubic feet

MMBTU= million British thermal units

LFG= landfill gas

CH<sub>4</sub>= methane

HHV= higher heating value

A60 RLI 2020.05 SAR Appendix v1.xlsx

#### A-60 Flare Heat Input Rate

MONTH: Dec-19

Date	Runtime (hours)	CH4 (%)*	Average Flow (scfm)	Total LFG Volume (scf)	CH4 Volume (scf)	Heating Value of CH4 (BTU/scf)	Heat Input (MMBTU) / Day	Total Flow Corrected to HHV of 500 BTU/scf
12/1/2019	24.00	47.3	1,390	2,001,720	946,147	1,013	958	1,916,894
12/2/2019	24.00	47.3	1,358	1,955,506	924,303	1,013	936	1,872,638
12/3/2019	24.00	47.3	1,345	1,936,760	915,443	1,013	927	1,854,687
12/4/2019	24.00	47.3	1,355	1,950,543	921,957	1,013	934	1,867,886
12/5/2019	24.00	47.3	1,534	2,208,344	1,043,811	1,013	1,057	2,114,762
12/6/2019	24.00	47.3	1,796	2,585,848	1,222,245	1,013	1,238	2,476,268
12/7/2019	24.00	47.3	1,469	2,116,047	1,000,186	1,013	1,013	2,026,376
12/8/2019	24.00	47.3	1,442	2,076,685	981,580	1,013	994	1,988,682
12/9/2019	8.97	47.3	1,438	773,759	365,730	1,013	370	740,970
12/10/2019	0.00	47.3	0	0	0	1,013	0	0
12/11/2019	0.00	47.3	0	0	0	1,013	0	0
12/12/2019	9.77	47.3	2,349	1,376,477	650,615	1,013	659	1,318,147
12/13/2019	24.00	47.3	2,352	3,386,917	1,600,884	1,013	1,622	3,243,391
12/14/2019	24.00	47.3	2,339	3,367,880	1,591,886	1,013	1,613	3,225,161
12/15/2019	24.00	47.3	2,324	3,346,220	1,581,648	1,013	1,602	3,204,418
12/16/2019	23.47	47.3	2,346	3,303,299	1,561,360	1,013	1,582	3,163,316
12/17/2019	23.40	47.3	2,380	3,341,353	1,579,347	1,013	1,600	3,199,758
12/18/2019	23.93	47.3	2,206	3,167,902	1,497,363	1,013	1,517	3,033,657
12/19/2019	24.00	47.3	2,105	3,031,824	1,433,043	1,013	1,452	2,903,345
12/20/2019	24.00	47.3	2,044	2,942,749	1,390,940	1,013	1,409	2,818,045
12/21/2019	24.00	47.3	2,001	2,880,850	1,361,683	1,013	1,379	2,758,769
12/22/2019	24.00	47.3	1,779	2,561,050	1,210,524	1,013	1,226	2,452,521
12/23/2019	24.00	47.3	1,712	2,464,584	1,164,928	1,013	1,180	2,360,143
12/24/2019	24.00	47.3	1,632	2,350,058	1,110,795	1,013	1,125	2,250,470
12/25/2019	24.00	47.3	1,626	2,341,354	1,106,681	1,013	1,121	2,242,135
12/26/2019	24.00	47.3	1,609	2,316,602	1,094,981	1,013	1,109	2,218,432
12/27/2019	24.00	47.3	1,732	2,494,148	1,178,901	1,013	1,194	2,388,454
12/28/2019	24.00	47.3	1,941	2,794,970	1,321,090	1,013	1,338	2,676,529
12/29/2019	24.00	47.3	1,584	2,280,555	1,077,943	1,013	1,092	2,183,913
12/30/2019	24.00	47.3	1,607	2,313,484	1,093,508	1,013	1,108	2,215,446
12/31/2019	24.00	47.3	1,677	2,415,102	1,141,539	1,013	1,156	2,312,758
Totals/ Average:	665.53	47.3	1,805	72,082,590.0	34,071,062	1,013	34,514	69,027,971
lotes:						Maximum:	1,622	3,243,391

The A-60 Flare commenced operation on April 1, 2009.

\*CH<sub>4</sub> content was determined from the July 17, 2018 (9/14/18 to 9/19/19) and July 25, 2019 (9/20/19 to current) source test.

Pursuant to Title V Permit Condition Number 19867 Part 30(g), the Annual Source Test at A-60 may be conducted while it is operating in either zone, providing that each operating zone is tested at least once every five years.

Pursuant to Title V Permit Condition Number 19867 Part 20, as modified by Authority To Construct (ATC) 19098, the throughput of landfill gas (with an HHV of 500 BTU/scf) to the A-60 Landfill Gas Flare shall not exceed 4,320,000 scf during any one day, and shall not exceed 2,207,520,000 scf combined with the A-51 Landfill Gas Flare during any consecutive 12-month period.

scfm= standard cubic feet per minute

BTU/scf= British thermal unit per square cubic feet

scf= standard cubic feet

MMBTU= million British thermal units

LFG= landfill gas

CH<sub>4</sub>= methane

HHV= higher heating value

A60 RLI 2020.05 SAR Appendix v1.xlsx

#### A-60 Flare Heat Input Rate

MONTH: Jan-20

Date	Runtime (hours)	CH4 (%)*	Average Flow (scfm)	Total LFG Volume (scf)	CH4 Volume (scf)	Heating Value of CH4 (BTU/scf)	Heat Input (MMBTU) / Day	Total Flow Corrected to HHV of 500 BTU/scf
1/1/2020	24.00	47.3	1,558	2,243,326	1,060,346	1,013	1,074	2,148,261
1/2/2020	24.00	47.3	1,565	2,253,204	1,065,015	1,013	1,079	2,157,721
1/3/2020	22.90	47.3	1,569	2,156,275	1,019,200	1,013	1,032	2,064,899
1/4/2020	24.00	47.3	1,565	2,253,551	1,065,179	1,013	1,079	2,158,053
1/5/2020	24.00	47.3	1,695	2,440,531	1,153,558	1,013	1,169	2,337,109
1/6/2020	24.00	47.3	1,640	2,361,984	1,116,432	1,013	1,131	2,261,891
1/7/2020	24.00	47.3	1,589	2,288,380	1,081,642	1,013	1,096	2,191,406
1/8/2020	24.00	47.3	1,612	2,321,659	1,097,372	1,013	1,112	2,223,275
1/9/2020	24.00	47.3	1,565	2,254,045	1,065,413	1,013	1,079	2,158,526
1/10/2020	24.00	47.3	1,511	2,176,078	1,028,560	1,013	1,042	2,083,863
1/11/2020	24.00	47.3	1,515	2,181,773	1,031,252	1,013	1,045	2,089,317
1/12/2020	24.00	47.3	1,518	2,186,429	1,033,453	1,013	1,047	2,093,775
1/13/2020	24.00	47.3	1,516	2,183,321	1,031,984	1,013	1,045	2,090,799
1/14/2020	24.00	47.3	1,919	2,763,357	1,306,148	1,013	1,323	2,646,255
1/15/2020	22.87	47.3	2,125	2,916,140	1,378,363	1,013	1,396	2,792,564
1/16/2020	24.00	47.3	1,797	2,587,614	1,223,080	1,013	1,239	2,477,960
1/17/2020	24.00	47.3	1,613	2,323,163	1,098,082	1,013	1,112	2,224,715
1/18/2020	24.00	47.3	1,590	2,289,522	1,082,181	1,013	1,096	2,192,500
1/19/2020	24.00	47.3	1,706	2,456,911	1,161,301	1,013	1,176	2,352,795
1/20/2020	22.43	47.3	1,877	2,525,883	1,193,902	1,013	1,209	2,418,845
1/21/2020	19.20	47.3	1,707	1,966,953	929,714	1,013	942	1,883,600
1/22/2020	18.50	47.3	1,610	1,787,125	844,715	1,013	856	1,711,393
1/23/2020	24.00	47.3	1,552	2,234,424	1,056,138	1,013	1,070	2,139,737
1/24/2020	24.00	47.3	1,546	2,226,746	1,052,509	1,013	1,066	2,132,384
1/25/2020	24.00	47.3	1,548	2,229,147	1,053,644	1,013	1,067	2,134,683
1/26/2020	24.00	47.3	1,533	2,208,110	1,043,701	1,013	1,057	2,114,538
1/27/2020	24.00	47.3	1,573	2,265,583	1,070,866	1,013	1,085	2,169,575
1/28/2020	24.00	47.3	1,543	2,221,832	1,050,187	1,013	1,064	2,127,678
1/29/2020	24.00	47.3	1,543	2,222,602	1,050,551	1,013	1,064	2,128,416
1/30/2020	24.00	47.3	1,533	2,208,093	1,043,693	1,013	1,057	2,114,521
1/31/2020	24.00	47.3	1,546	2,226,044	1,052,178	1,013	1,066	2,131,712
Totals/ Average:	729.90	47.3	1,620	70,959,805.0	33,540,358	1,013	33,976	67,952,766
Notes:					•	Maximum:	1,396	2,792,564

The A-60 Flare commenced operation on April 1, 2009.

Pursuant to Title V Permit Condition Number 19867 Part 30(g), the Annual Source Test at A-60 may be conducted while it is operating in either zone, providing that each operating zone is tested at least once every five years.

Pursuant to Title V Permit Condition Number 19867 Part 20, as modified by Authority To Construct (ATC) 19098, the throughput of landfill gas (with an HHV of 500 BTU/scf) to the A-60 Landfill Gas Flare shall not exceed 4,320,000 scf during any one day, and shall not exceed 2,207,520,000 scf combined with the A-51 Landfill Gas Flare during any consecutive 12-month period.

scfm= standard cubic feet per minute

BTU/scf= British thermal unit per square cubic feet

scf= standard cubic feet

MMBTU= million British thermal units

LFG= landfill gas

CH<sub>4</sub>= methane

HHV= higher heating value

A60 RLI 2020.05 SAR Appendix v1.xlsx

<sup>\*</sup>CH<sub>4</sub> content was determined from the July 25, 2019 (9/20/19 to current) source test.

#### A-60 Flare Heat Input Rate

MONTH: Feb-20

MONTH.	Feb-20							
Date	Runtime (hours)	CH4 (%)*	Average Flow (scfm)	Total LFG Volume (scf)	CH4 Volume (scf)	Heating Value of CH4 (BTU/scf)	Heat Input (MMBTU) / Day	Total Flow Corrected to HHV of 500 BTU/scf
2/1/2020	24.00	47.3	1,559	2,245,449	1,061,350	1,013	1,075	2,150,294
2/2/2020	24.00	47.3	1,553	2,235,836	1,056,806	1,013	1,071	2,141,089
2/3/2020	24.00	47.3	1,550	2,232,264	1,055,118	1,013	1,069	2,137,668
2/4/2020	24.00	47.3	1,553	2,236,244	1,056,999	1,013	1,071	2,141,479
2/5/2020	24.00	47.3	1,667	2,401,129	1,134,934	1,013	1,150	2,299,377
2/6/2020	24.00	47.3	1,527	2,198,376	1,039,100	1,013	1,053	2,105,216
2/7/2020	24.00	47.3	1,560	2,245,707	1,061,472	1,013	1,075	2,150,541
2/8/2020	24.00	47.3	1,880	2,706,960	1,279,491	1,013	1,296	2,592,248
2/9/2020	24.00	47.3	1,730	2,490,950	1,177,390	1,013	1,193	2,385,392
2/10/2020	24.00	47.3	1,822	2,624,052	1,240,303	1,013	1,256	2,512,853
2/11/2020	24.00	47.3	1,801	2,594,124	1,226,157	1,013	1,242	2,484,194
2/12/2020	24.00	47.3	1,682	2,421,466	1,144,547	1,013	1,159	2,318,852
2/13/2020	24.00	47.3	1,647	2,371,523	1,120,941	1,013	1,136	2,271,026
2/14/2020	24.00	47.3	1,616	2,326,882	1,099,840	1,013	1,114	2,228,277
2/15/2020	24.00	47.3	1,608	2,315,385	1,094,406	1,013	1,109	2,217,267
2/16/2020	24.00	47.3	1,607	2,313,606	1,093,565	1,013	1,108	2,215,563
2/17/2020	24.00	47.3	1,714	2,467,646	1,166,375	1,013	1,182	2,363,075
2/18/2020	24.00	47.3	1,811	2,608,511	1,232,957	1,013	1,249	2,497,971
2/19/2020	24.00	47.3	1,606	2,312,843	1,093,205	1,013	1,107	2,214,832
2/20/2020	24.00	47.3	1,605	2,311,702	1,092,665	1,013	1,107	2,213,740
2/21/2020	24.00	47.3	1,629	2,345,606	1,108,691	1,013	1,123	2,246,207
2/22/2020	24.00	47.3	1,761	2,536,423	1,198,883	1,013	1,214	2,428,938
2/23/2020	24.00	47.3	1,589	2,287,978	1,081,452	1,013	1,096	2,191,021
2/24/2020	24.00	47.3	1,663	2,394,056	1,131,591	1,013	1,146	2,292,604
2/25/2020	24.00	47.3	1,745	2,512,569	1,187,608	1,013	1,203	2,406,095
2/26/2020	24.00	47.3	1,573	2,264,774	1,070,484	1,013	1,084	2,168,800
2/27/2020	24.00	47.3	1,954	2,813,081	1,329,651	1,013	1,347	2,693,872
2/28/2020	24.00	47.3	1,510	2,173,713	1,027,442	1,013	1,041	2,081,598
2/29/2020	24.00	47.3	1,491	2,147,149	1,014,886	1,013	1,028	2,056,160
Totals/ Average:	696.00	47.3	1,656	69,136,004.0	32,678,308	1,013	33,103	66,206,251
Notes:	•	•		•		Maximum:	1,347	2,693,872

#### The A-60 Flare commenced operation on April 1, 2009.

Pursuant to Title V Permit Condition Number 19867 Part 30(g), the Annual Source Test at A-60 may be conducted while it is operating in either zone, providing that each operating zone is tested at least once every five years.

Pursuant to Title V Permit Condition Number 19867 Part 20, as modified by Authority To Construct (ATC) 19098, the throughput of landfill gas (with an HHV of 500 BTU/scf) to the A-60 Landfill Gas Flare shall not exceed 4,320,000 scf during any one day, and shall not exceed 2,207,520,000 scf combined with the A-51 Landfill Gas Flare during any consecutive 12-month period.

scfm= standard cubic feet per minute

BTU/scf= British thermal unit per square cubic feet

scf= standard cubic feet

MMBTU= million British thermal units

LFG= landfill gas

CH<sub>4</sub>= methane

HHV= higher heating value

<sup>\*</sup>CH<sub>4</sub> content was determined from the July 25, 2019 (9/20/19 to current) source test.

#### A-60 Flare Heat Input Rate

MONTH: Mar-20

Date	Runtime (hours)	CH4 (%)*	Average Flow (scfm)	Total LFG Volume (scf)	CH4 Volume (scf)	Heating Value of CH4 (BTU/scf)	Heat Input (MMBTU) / Day	Total Flow Corrected to HHV of 500 BTU/scf
3/1/2020	24.00	47.3	1,488	2,143,026	1,012,938	1,013	1,026	2,052,212
3/2/2020	24.00	47.3	1,452	2,091,599	988,630	1,013	1,001	2,002,964
3/3/2020	24.00	47.3	1,415	2,037,258	962,945	1,013	975	1,950,926
3/4/2020	24.00	47.3	1,403	2,020,509	955,028	1,013	967	1,934,887
3/5/2020	24.00	47.3	1,392	2,004,442	947,434	1,013	960	1,919,500
3/6/2020	24.00	47.3	1,391	2,003,209	946,851	1,013	959	1,918,320
3/7/2020	24.00	47.3	1,389	2,000,774	945,700	1,013	958	1,915,988
3/8/2020	23.00	47.3	1,378	1,901,965	898,996	1,013	911	1,821,366
3/9/2020	24.00	47.3	1,403	2,020,909	955,217	1,013	968	1,935,270
3/10/2020	24.00	47.3	1,453	2,091,677	988,667	1,013	1,002	2,003,039
3/11/2020	24.00	47.3	1,485	2,139,052	1,011,059	1,013	1,024	2,048,406
3/12/2020	24.00	47.3	1,644	2,366,899	1,118,755	1,013	1,133	2,266,598
3/13/2020	24.00	47.3	1,483	2,136,150	1,009,688	1,013	1,023	2,045,627
3/14/2020	24.00	47.3	1,438	2,070,601	978,705	1,013	991	1,982,856
3/15/2020	24.00	47.3	1,438	2,071,247	979,010	1,013	992	1,983,474
3/16/2020	24.00	47.3	1,439	2,072,863	979,774	1,013	993	1,985,022
3/17/2020	24.00	47.3	1,444	2,079,428	982,877	1,013	996	1,991,309
3/18/2020	24.00	47.3	1,446	2,081,729	983,965	1,013	997	1,993,512
3/19/2020	24.00	47.3	1,446	2,082,427	984,295	1,013	997	1,994,181
3/20/2020	24.00	47.3	1,945	2,800,630	1,323,765	1,013	1,341	2,681,949
3/21/2020	24.00	47.3	1,647	2,371,654	1,121,003	1,013	1,136	2,271,151
3/22/2020	24.00	47.3	1,408	2,026,917	958,057	1,013	971	1,941,023
3/23/2020	24.00	47.3	1,440	2,073,874	980,252	1,013	993	1,985,990
3/24/2020	24.00	47.3	1,371	1,973,589	932,850	1,013	945	1,889,955
3/25/2020	24.00	47.3	1,323	1,905,454	900,645	1,013	912	1,824,707
3/26/2020	24.00	47.3	1,299	1,870,448	884,099	1,013	896	1,791,185
3/27/2020	24.00	47.3	1,428	2,056,124	971,862	1,013	984	1,968,992
3/28/2020	24.00	47.3	1,293	1,862,424	880,306	1,013	892	1,783,501
3/29/2020	24.00	47.3	1,287	1,853,562	876,118	1,013	888	1,775,014
3/30/2020	24.00	47.3	1,289	1,855,982	877,261	1,013	889	1,777,332
3/31/2020	24.00	47.3	1,344	1,935,688	914,936	1,013	927	1,853,660
Totals/ Average:	743.00	47.3	1,436	64,002,110.0	30,251,685	1,013	30,645	61,289,914
lotes:						Maximum:	1,341	2,681,949

The A-60 Flare commenced operation on April 1, 2009.

Pursuant to Title V Permit Condition Number 19867 Part 30(g), the Annual Source Test at A-60 may be conducted while it is operating in either zone, providing that each operating zone is tested at least once every five years.

Pursuant to Title V Permit Condition Number 19867 Part 20, as modified by Authority To Construct (ATC) 19098, the throughput of landfill gas (with an HHV of 500 BTU/scf) to the A-60 Landfill Gas Flare shall not exceed 4,320,000 scf during any one day, and shall not exceed 2,207,520,000 scf combined with the A-51 Landfill Gas Flare during any consecutive 12-month period.

scfm= standard cubic feet per minute

BTU/scf= British thermal unit per square cubic feet

scf= standard cubic feet

MMBTU= million British thermal units

LFG= landfill gas

CH<sub>4</sub>= methane

HHV= higher heating value

A60

<sup>\*</sup>CH<sub>4</sub> content was determined from the July 25, 2019 (9/20/19 to current) source test.

#### A-60 Flare Heat Input Rate

MONTH: Apr-20

Date	Runtime (hours)	CH4 (%)*	Average Flow (scfm)	Total LFG Volume (scf)	CH4 Volume (scf)	Heating Value of CH4 (BTU/scf)	Heat Input (MMBTU) / Day	Total Flow Corrected to HHV of 500 BTU/scf
4/1/2020	24.00	47.3	1,296	1,866,179	882,081	1,013	894	1,787,097
4/2/2020	24.00	47.3	1,341	1,931,397	912,908	1,013	925	1,849,551
4/3/2020	24.00	47.3	1,573	2,264,907	1,070,547	1,013	1,084	2,168,928
4/4/2020	24.00	47.3	1,306	1,880,540	888,869	1,013	900	1,800,849
4/5/2020	24.00	47.3	1,331	1,917,238	906,215	1,013	918	1,835,992
4/6/2020	24.00	47.3	1,756	2,528,797	1,195,279	1,013	1,211	2,421,635
4/7/2020	24.00	47.3	1,577	2,270,993	1,073,423	1,013	1,087	2,174,756
4/8/2020	24.00	47.3	1,567	2,256,924	1,066,773	1,013	1,081	2,161,283
4/9/2020	24.00	47.3	1,476	2,125,487	1,004,648	1,013	1,018	2,035,416
4/10/2020	24.00	47.3	1,365	1,965,401	928,980	1,013	941	1,882,114
4/11/2020	24.00	47.3	1,352	1,946,274	919,939	1,013	932	1,863,797
4/12/2020	24.00	47.3	1,394	2,007,098	948,689	1,013	961	1,922,044
4/13/2020	24.00	47.3	1,763	2,538,855	1,200,033	1,013	1,216	2,431,267
4/14/2020	24.00	47.3	1,825	2,627,896	1,242,120	1,013	1,258	2,516,535
4/15/2020	24.00	47.3	1,384	1,992,255	941,673	1,013	954	1,907,830
4/16/2020	24.00	47.3	1,365	1,966,125	929,322	1,013	941	1,882,807
4/17/2020	24.00	47.3	1,446	2,082,917	984,526	1,013	997	1,994,650
4/18/2020	24.00	47.3	1,923	2,768,770	1,308,706	1,013	1,326	2,651,439
4/19/2020	24.00	47.3	1,922	2,768,063	1,308,372	1,013	1,325	2,650,762
4/20/2020	24.00	47.3	1,569	2,259,672	1,068,072	1,013	1,082	2,163,915
4/21/2020	23.70	47.3	1,525	2,168,532	1,024,994	1,013	1,038	2,076,637
4/22/2020	24.00	47.3	1,379	1,985,972	938,703	1,013	951	1,901,813
4/23/2020	24.00	47.3	1,444	2,079,407	982,867	1,013	996	1,991,289
4/24/2020	24.00	47.3	1,378	1,984,947	938,219	1,013	950	1,900,832
4/25/2020	24.00	47.3	1,329	1,913,879	904,627	1,013	916	1,832,775
4/26/2020	24.00	47.3	1,356	1,952,784	923,017	1,013	935	1,870,032
4/27/2020	24.00	47.3	1,400	2,016,537	953,150	1,013	966	1,931,083
4/28/2020	24.00	47.3	1,455	2,095,807	990,619	1,013	1,003	2,006,994
4/29/2020	24.00	47.3	1,604	2,309,114	1,091,442	1,013	1,106	2,211,261
4/30/2020	22.43	47.3	1,468	1,975,406	933,709	1,013	946	1,891,695
Totals/ Average:	718.13	47.3	1,496	64,448,173.0	30,462,525	1,013	30,859	61,717,075
otes:	•	•			•	Maximum:	1,326	2,651,439

#### The A-60 Flare commenced operation on April 1, 2009.

Pursuant to Title V Permit Condition Number 19867 Part 30(g), the Annual Source Test at A-60 may be conducted while it is operating in either zone, providing that each operating zone is tested at least once every five years.

Pursuant to Title V Permit Condition Number 19867 Part 20, as modified by Authority To Construct (ATC) 19098, the throughput of landfill gas (with an HHV of 500 BTU/scf) to the A-60 Landfill Gas Flare shall not exceed 4,320,000 scf during any one day, and shall not exceed 2,207,520,000 scf combined with the A-51 Landfill Gas Flare during any consecutive 12-month period.

scfm= standard cubic feet per minute

BTU/scf= British thermal unit per square cubic feet

scf= standard cubic feet

MMBTU= million British thermal units

LFG= landfill gas

CH<sub>4</sub>= methane

HHV= higher heating value

A60

<sup>\*</sup>CH<sub>4</sub> content was determined from the July 25, 2019 (9/20/19 to current) source test.

#### **MONTHLY LFG Input to Landfill Gas Engine (S-64)**

WM - REDWOOD LANDFILL, Novato, CA

#### S-64 (Engine #1)

Month	Total Available Runtime (hours)	Total Downtime (hours)	Total Runtime (hours)	Average Flow (scfm)	Average CH <sub>4</sub> (%) <sup>1</sup>	Total Flow LFG Volume (scf)	Total Flow LFG Volume Corrected to HHV of 500 BTU/scf	Total CH₄ Volume (scf)	Total Heat Input (MMBTU)	CO Emission Factor (lb/MMBtu) <sup>1</sup>	CO Emissions (tons)	SO2 Emission Factor (lb/MMBtu) <sup>2</sup>	SO2 Emissions (tons) <sup>2</sup>
November-19	721.00	13.75	707.25	587	47.7	24,892,100	24,055,775	11,873,532	12,028	0.093	0.56	1.50	1.87E-02
December-19	744.00	245.08	498.92	566	47.7	16,950,751	16,381,240	8,085,508	8,191	0.093	0.38	1.50	1.27E-02
January-20	744.00	22.75	721.25	612	47.7	26,500,847	25,610,471	12,640,904	12,805	0.093	0.60	1.50	1.99E-02
February-20	696.00	43.50	652.50	640	47.7	25,066,285	24,224,108	11,956,618	12,112	0.093	0.57	1.50	1.88E-02
March-20	743.00	42.17	700.83	650	47.7	27,338,590	26,420,068	13,040,507	13,210	0.093	0.62	1.50	2.06E-02
April-20	720.00	159.50	560.50	623	47.7	20,939,615	20,236,086	9,988,196	10,118	0.093	0.47	1.50	1.57E-02
TOTAL/ AVG:	4,368.00	526.75	3,841.25	615	47.7	141,688,188	136,927,748	67,585,265	68,464				

#### NOTES:

The S-64 Engine (#1) commenced operation on April 27, 2017.

 $<sup>^{1}\</sup>text{CH}_{4}$ , CO, and SO $_{2}$  content was determined from the July 18 & 19, 2018 (9/14/18 - current) source test.

#### S-64 Engine (#1) Heat Input Rate

MONTH: Nov-19

Date	Runtime (hours)	CH4 (%)*	Average Flow (scfm)	Total LFG Volume (scf)	CH4 Volume (scf)	Heating Value of CH4 (BTU/scf)	Heat Input (MMBTU)/Day	Total Flow Corrected to HHV of 500 BTU/scf
11/01/2019	24.00	47.7	521	750,636	358,053	1,013	363	725,416
11/02/2019	24.00	47.7	526	756,822	361,004	1,013	366	731,395
11/03/2019	25.00	47.7	534	769,335	366,973	1,013	372	743,487
11/04/2019	24.00	47.7	553	795,730	379,563	1,013	384	768,995
11/05/2019	24.00	47.7	579	833,734	397,691	1,013	403	805,723
11/06/2019	24.00	47.7	571	856,358	408,483	1,013	414	827,586
11/07/2019	24.00	47.7	601	865,374	412,783	1,013	418	836,299
11/08/2019	23.42	47.7	582	837,979	399,716	1,013	405	809,825
11/09/2019	24.00	47.7	603	867,919	413,997	1,013	419	838,758
11/10/2019	21.50	47.7	538	775,431	369,881	1,013	375	749,378
11/11/2019	24.00	47.7	606	872,834	416,342	1,013	422	843,509
11/12/2019	22.58	47.7	555	799,431	381,328	1,013	386	772,571
11/13/2019	24.00	47.7	605	871,391	415,654	1,013	421	842,114
11/14/2019	24.00	47.7	589	847,989	404,491	1,013	410	819,499
11/15/2019	24.00	47.7	568	818,411	390,382	1,013	395	790,914
11/16/2019	24.00	47.7	563	811,290	386,985	1,013	392	784,032
11/17/2019	24.00	47.7	561	808,027	385,429	1,013	390	780,879
11/18/2019	15.75	47.7	338	487,212	232,400	1,013	235	470,843
11/19/2019	24.00	47.7	556	801,308	382,224	1,013	387	774,385
11/20/2019	24.00	47.7	555	798,778	381,017	1,013	386	771,940
11/21/2019	24.00	47.7	589	848,223	404,602	1,013	410	819,725
11/22/2019	24.00	47.7	598	861,407	410,891	1,013	416	832,466
11/23/2019	24.00	47.7	597	860,176	410,304	1,013	416	831,276
11/24/2019	24.00	47.7	595	857,455	409,006	1,013	414	828,646
11/25/2019	24.00	47.7	595	856,374	408,491	1,013	414	827,602
11/26/2019	24.00	47.7	590	849,667	405,291	1,013	411	821,120
11/27/2019	23.00	47.7	613	883,188	421,280	1,013	427	853,514
11/28/2019	24.00	47.7	655	943,250	449,930	1,013	456	911,558
11/29/2019	24.00	47.7	662	953,352	454,749	1,013	461	921,321
11/30/2019	24.00	47.7	662	953,019	454,590	1,013	460	921,000
Totals/ Average:	707.25	47.7	587	24,892,099.7	11,873,532	1,013	12,028	24,055,775
otes:		1				Maximum:	461	921,321

The S-64 Engine (#1) commenced operation on April 27, 2017.

\*Methane (CH<sub>4</sub>) content was determined from the July 18 & 19, 2018 (9/14/18 - 9/5/19) and July 10 & 11, 2019 (9/6/19 - current) source tests.

#### S-64 Engine (#1) Heat Input Rate

MONTH: Dec-19

Date	Runtime (hours)	CH4 (%)*	Average Flow (scfm)	Total LFG Volume (scf)	CH4 Volume (scf)	Heating Value of CH4 (BTU/scf)	Heat Input (MMBTU)/Day	Total Flow Corrected to HHV of 500 BTU/scf
12/01/2019	24.00	47.7	654	942,356	449,504	1,013	455	910,695
12/02/2019	24.00	47.7	648	932,998	445,040	1,013	451	901,651
12/03/2019	24.00	47.7	642	924,034	440,764	1,013	446	892,989
12/04/2019	24.00	47.7	637	917,966	437,870	1,013	444	887,124
12/05/2019	24.00	47.7	636	916,250	437,051	1,013	443	885,466
12/06/2019	24.00	47.7	630	906,790	432,539	1,013	438	876,323
12/07/2019	23.00	47.7	557	802,156	382,628	1,013	388	775,205
12/08/2019	24.00	47.7	570	820,408	391,334	1,013	396	792,844
12/09/2019	9.50	47.7	212	305,529	145,737	1,013	148	295,264
12/10/2019	0.00							·
12/11/2019	0.00							
12/12/2019	0.00							
12/13/2019	0.00							
12/14/2019	0.00							
12/15/2019	0.00							
12/16/2019	0.00							
12/17/2019	1.00	47.7	5	7,353	3,507	1,013	4	7,106
12/18/2019	17.00	47.7	141	202,472	96,579	1,013	98	195,669
12/19/2019	9.75	47.7	76	109,661	52,308	1,013	53	105,977
12/20/2019	11.75	47.7	257	370,448	176,704	1,013	179	358,001
12/21/2019	24.00	47.7	570	820,127	391,200	1,013	396	792,572
12/22/2019	24.00	47.7	575	827,887	394,902	1,013	400	800,072
12/23/2019	24.00	47.7	578	833,034	397,357	1,013	403	805,046
12/24/2019	24.00	47.7	583	839,444	400,415	1,013	406	811,240
12/25/2019	24.00	47.7	582	838,308	399,873	1,013	405	810,142
12/26/2019	24.00	47.7	550	792,344	377,948	1,013	383	765,723
12/27/2019	24.00	47.7	558	803,316	383,182	1,013	388	776,326
12/28/2019	24.00	47.7	558	803,633	383,333	1,013	388	776,633
12/29/2019	24.00	47.7	577	830,893	396,336	1,013	401	802,977
12/30/2019	23.33	47.7	548	789,712	376,692	1,013	382	763,179
12/31/2019	19.58	47.7	426	613,633	292,703	1,013	297	593,016
Totals/ Average:	498.92	47.7	566	16,950,751.2	8,085,508	1,013	8,191	16,381,240
Notes:	•	•			•	Maximum:	455	910,695

The S-64 Engine (#1) commenced operation on April 27, 2017.

\*Methane (CH<sub>4</sub>) content was determined from the July 18 & 19, 2018 (9/14/18 - 9/5/19) and July 10 & 11, 2019 (9/6/19 - current) source tests.

#### S-64 Engine (#1) Heat Input Rate

MONTH: Jan-20

Date	Runtime (hours)	CH4 (%)*	Average Flow (scfm)	Total LFG Volume (scf)	CH4 Volume (scf)	Heating Value of CH4 (BTU/scf)	Heat Input (MMBTU)/Day	Total Flow Corrected to HHV of 500 BTU/scf
1/01/2020	24.00	47.7	551	793,742	378,615	1,013	384	767,074
1/02/2020	24.00	47.7	552	795,499	379,453	1,013	384	768,771
1/03/2020	24.00	47.7	561	807,864	385,351	1,013	390	780,721
1/04/2020	24.00	47.7	560	806,744	384,817	1,013	390	779,639
1/05/2020	18.42	47.7	419	602,964	287,614	1,013	291	582,706
1/06/2020	21.00	47.7	479	690,369	329,306	1,013	334	667,174
1/07/2020	23.50	47.7	531	764,829	364,824	1,013	370	739,132
1/08/2020	22.92	47.7	507	729,916	348,170	1,013	353	705,392
1/09/2020	22.83	47.7	557	801,491	382,311	1,013	387	774,562
1/10/2020	24.00	47.7	587	844,975	403,053	1,013	408	816,585
1/11/2020	24.00	47.7	586	844,176	402,672	1,013	408	815,813
1/12/2020	24.00	47.7	586	844,360	402,759	1,013	408	815,991
1/13/2020	24.00	47.7	586	844,386	402,772	1,013	408	816,017
1/14/2020	24.00	47.7	580	835,874	398,712	1,013	404	807,790
1/15/2020	24.00	47.7	614	884,275	421,799	1,013	427	854,566
1/16/2020	20.83	47.7	547	787,772	375,767	1,013	381	761,304
1/17/2020	24.00	47.7	657	946,671	451,562	1,013	457	914,864
1/18/2020	24.00	47.7	656	944,453	450,504	1,013	456	912,721
1/19/2020	22.92	47.7	590	848,966	404,957	1,013	410	820,443
1/20/2020	16.83	47.7	596	617,348	294,475	1,013	298	596,607
1/21/2020	24.00	47.7	658	947,616	452,013	1,013	458	915,778
1/22/2020	24.00	47.7	665	957,657	456,802	1,013	463	925,481
1/23/2020	24.00	47.7	662	953,550	454,843	1,013	461	921,512
1/24/2020	24.00	47.7	662	953,520	454,829	1,013	461	921,484
1/25/2020	24.00	47.7	659	948,882	452,617	1,013	459	917,001
1/26/2020	24.00	47.7	660	949,749	453,030	1,013	459	917,839
1/27/2020	24.00	47.7	661	952,353	454,273	1,013	460	920,356
1/28/2020	24.00	47.7	660	950,979	453,617	1,013	460	919,028
1/29/2020	24.00	47.7	658	947,019	451,728	1,013	458	915,201
1/30/2020	24.00	47.7	660	949,918	453,111	1,013	459	918,003
1/31/2020	24.00	47.7	662	952,931	454,548	1,013	460	920,915
Totals/ Average:	721.25	47.7	612	26,500,846.6	12,640,904	1,013	12,805	25,610,471
Notes:					, , , , , , , ,	Maximum:	463	925,481

The S-64 Engine (#1) commenced operation on April 27, 2017.
\*Methane (CH<sub>4</sub>) content was determined from the July 10 & 11, 2019 (9/6/19 - current) source test.

#### S-64 Engine (#1) Heat Input Rate

MONTH: Feb-20

Date	Runtime (hours)	CH4 (%)*	Average Flow (scfm)	Total LFG Volume (scf)	CH4 Volume (scf)	Heating Value of CH4 (BTU/scf)	Heat Input (MMBTU)/Day	Total Flow Corrected to HHV of 500 BTU/scf
2/01/2020	24.00	47.7	660	949,845	453,076	1,013	459	917,932
2/02/2020	24.00	47.7	656	945,283	450,900	1,013	457	913,523
2/03/2020	24.00	47.7	658	947,139	451,785	1,013	458	915,317
2/04/2020	24.00	47.7	659	949,510	452,916	1,013	459	917,608
2/05/2020	19.58	47.7	523	753,734	359,531	1,013	364	728,410
2/06/2020	24.00	47.7	658	947,883	452,140	1,013	458	916,036
2/07/2020	24.00	47.7	659	949,046	452,695	1,013	459	917,160
2/08/2020	15.67	47.7	415	598,003	285,247	1,013	289	577,911
2/09/2020	24.00	47.7	662	953,279	454,714	1,013	461	921,251
2/10/2020	22.25	47.7	549	791,063	377,337	1,013	382	764,485
2/11/2020	22.92	47.7	537	773,935	369,167	1,013	374	747,933
2/12/2020	24.00	47.7	614	883,829	421,586	1,013	427	854,134
2/13/2020	24.00	47.7	628	904,737	431,560	1,013	437	874,340
2/14/2020	24.00	47.7	643	925,308	441,372	1,013	447	894,219
2/15/2020	24.00	47.7	646	930,808	443,995	1,013	450	899,534
2/16/2020	24.00	47.7	647	931,005	444,089	1,013	450	899,725
2/17/2020	19.50	47.7	521	750,751	358,108	1,013	363	725,527
2/18/2020	16.75	47.7	411	591,777	282,278	1,013	286	571,895
2/19/2020	24.00	47.7	641	922,359	439,965	1,013	446	891,370
2/20/2020	24.00	47.7	644	927,003	442,180	1,013	448	895,857
2/21/2020	23.08	47.7	624	898,187	428,435	1,013	434	868,010
2/22/2020	19.58	47.7	520	748,549	357,058	1,013	362	723,399
2/23/2020	24.00	47.7	658	947,973	452,183	1,013	458	916,123
2/24/2020	24.00	47.7	657	946,248	451,360	1,013	457	914,456
2/25/2020	24.00	47.7	655	942,574	449,608	1,013	455	910,905
2/26/2020	23.00	47.7	615	885,543	422,404	1,013	428	855,791
2/27/2020	14.17	47.7	346	498,916	237,983	1,013	241	482,153
2/28/2020	24.00	47.7	643	925,972	441,689	1,013	447	894,862
2/29/2020	24.00	47.7	657	946,027	451,255	1,013	457	914,242
otals/ Average:	652.50	47.7	640	25,066,285.0	11,956,618	1,013	12,112	24,224,108
otes:						Maximum:	461	921,251

The S-64 Engine (#1) commenced operation on April 27, 2017.
\*Methane (CH<sub>4</sub>) content was determined from the July 10 & 11, 2019 (9/6/19 - current) source test.

#### S-64 Engine (#1) Heat Input Rate

MONTH: Mar-20

Date	Runtime (hours)	CH4 (%)*	Average Flow (scfm)	Total LFG Volume (scf)	CH4 Volume (scf)	Heating Value of CH4 (BTU/scf)	Heat Input (MMBTU)/Day	Total Flow Corrected to HHV of 500 BTU/scf
3/01/2020	24.00	47.7	656	944,354	450,457	1,013	456	912,626
3/02/2020	24.00	47.7	656	944,191	450,379	1,013	456	912,468
3/03/2020	24.00	47.7	658	948,045	452,218	1,013	458	916,193
3/04/2020	24.00	47.7	660	950,993	453,623	1,013	460	919,041
3/05/2020	24.00	47.7	658	948,045	452,218	1,013	458	916,193
3/06/2020	24.00	47.7	662	953,965	455,041	1,013	461	921,914
3/07/2020	23.67	47.7	651	938,126	447,486	1,013	453	906,607
3/08/2020	23.00	47.7	665	917,274	437,540	1,013	443	886,456
3/09/2020	23.25	47.7	642	924,757	441,109	1,013	447	893,687
3/10/2020	23.75	47.7	627	903,092	430,775	1,013	436	872,750
3/11/2020	21.67	47.7	552	794,848	379,143	1,013	384	768,143
3/12/2020	16.67	47.7	427	615,427	293,559	1,013	297	594,750
3/13/2020	21.67	47.7	577	830,181	395,996	1,013	401	802,288
3/14/2020	24.00	47.7	628	903,623	431,028	1,013	437	873,263
3/15/2020	24.00	47.7	628	904,138	431,274	1,013	437	873,761
3/16/2020	24.00	47.7	628	904,000	431,208	1,013	437	873,627
3/17/2020	24.00	47.7	631	909,233	433,704	1,013	439	878,685
3/18/2020	24.00	47.7	631	908,387	433,301	1,013	439	877,867
3/19/2020	24.00	47.7	641	922,534	440,049	1,013	446	891,539
3/20/2020	3.00	47.7	82	117,448	56,022	1,013	57	113,502
3/21/2020	16.50	47.7	415	596,897	284,720	1,013	288	576,842
3/22/2020	24.00	47.7	671	965,537	460,561	1,013	467	933,096
3/23/2020	23.67	47.7	614	884,554	421,932	1,013	427	854,835
3/24/2020	24.00	47.7	679	977,796	466,409	1,013	472	944,944
3/25/2020	24.00	47.7	673	969,713	462,553	1,013	469	937,133
3/26/2020	24.00	47.7	665	957,209	456,589	1,013	463	925,049
3/27/2020	24.00	47.7	664	956,873	456,428	1,013	462	924,724
3/28/2020	24.00	47.7	669	963,949	459,804	1,013	466	931,562
3/29/2020	24.00	47.7	667	961,062	458,427	1,013	464	928,772
3/30/2020	24.00	47.7	668	961,314	458,547	1,013	465	929,016
3/31/2020	24.00	47.7	667	961,025	458,409	1,013	464	928,736
Totals/ Average:	700.83	47.7	650	27,338,589.8	13,040,507	1,013	13,210	26,420,068
Notes:						Maximum:	472	944,944

The S-64 Engine (#1) commenced operation on April 27, 2017.
\*Methane (CH<sub>4</sub>) content was determined from the July 10 & 11, 2019 (9/6/19 - current) source test.

#### S-64 Engine (#1) Heat Input Rate

MONTH: Apr-20

Date	Runtime (hours)	CH4 (%)*	Average Flow (scfm)	Total LFG Volume (scf)	CH4 Volume (scf)	Heating Value of CH4 (BTU/scf)	Heat Input (MMBTU)/Day	Total Flow Corrected to HHV of 500 BTU/scf
4/01/2020	24.00	47.7	669	963,935	459,797	1,013	466	931,549
4/02/2020	24.00	47.7	671	966,501	461,021	1,013	467	934,029
4/03/2020	14.33	47.7	374	538,851	257,032	1,013	260	520,746
4/04/2020	24.00	47.7	670	965,168	460,385	1,013	466	932,740
4/05/2020	24.00	47.7	663	954,168	455,138	1,013	461	922,110
4/06/2020	13.67	47.7	377	542,580	258,811	1,013	262	524,350
4/07/2020	14.50	47.7	383	552,005	263,306	1,013	267	533,459
4/08/2020	16.42	47.7	410	590,617	281,724	1,013	285	570,773
4/09/2020	24.00	47.7	623	897,341	428,032	1,013	434	867,192
4/10/2020	24.00	47.7	649	934,787	445,894	1,013	452	903,380
4/11/2020	24.00	47.7	653	940,324	448,535	1,013	454	908,731
4/12/2020	22.25	47.7	604	869,402	414,705	1,013	420	840,192
4/13/2020	10.00	47.7	229	329,396	157,122	1,013	159	318,329
4/14/2020	13.25	47.7	336	483,248	230,509	1,013	234	467,012
4/15/2020	24.00	47.7	648	933,089	445,083	1,013	451	901,739
4/16/2020	23.17	47.7	631	908,289	433,254	1,013	439	877,773
4/17/2020	19.17	47.7	526	757,762	361,452	1,013	366	732,303
4/18/2020	0.00							
4/19/2020	0.00							
4/20/2020	17.08	47.7	387	557,182	265,776	1,013	269	538,462
4/21/2020	22.50	47.7	555	799,754	381,483	1,013	386	772,884
4/22/2020	23.83	47.7	596	858,499	409,504	1,013	415	829,655
4/23/2020	20.08	47.7	502	722,531	344,647	1,013	349	698,255
4/24/2020	22.50	47.7	571	821,782	391,990	1,013	397	794,172
4/25/2020	24.00	47.7	614	884,709	422,006	1,013	427	854,985
4/26/2020	22.83	47.7	576	829,576	395,708	1,013	401	801,704
4/27/2020	20.00	47.7	493	709,666	338,510	1,013	343	685,822
4/28/2020	18.08	47.7	415	596,907	284,725	1,013	288	576,852
4/29/2020	15.42	47.7	348	501,005	238,980	1,013	242	484,172
4/30/2020	15.42	47.7	368	530,541	253,068	1,013	256	512,716
otals/ Average:	560.50	47.7	623	20,939,615.2	9,988,196	1,013	10,118	20,236,086
otes:						Maximum:	467	934,029

S64

The S-64 Engine (#1) commenced operation on April 27, 2017.
\*Methane (CH<sub>4</sub>) content was determined from the July 10 & 11, 2019 (9/6/19 - current) source test.

#### **MONTHLY LFG Input to Landfill Gas Engine (S-65)**

WM - REDWOOD LANDFILL, Novato, CA

#### S-65 (Engine #2)

Month	Total Available Runtime (hours)	Total Downtime (hours)	Total Runtime (hours)	Average Flow (scfm)	Average CH <sub>4</sub> (%) <sup>1</sup>	Total Flow LFG Volume (scf)	Total Flow LFG Volume Corrected to HHV of 500 BTU/scf	Total CH₄ Volume (scf)	Total Heat Input (MMBTU)	CO Emission Factor (lb/MMBtu) <sup>1</sup>	CO Emissions (tons)	SO2 Emission Factor (lb/MMBtu) <sup>2</sup>	SO2 Emissions (tons) <sup>2</sup>
November-19	721.00	1.83	719.17	613	47.8	26,455,128	25,637,735	12,654,361	12,819	0.093	0.59	1.5895	2.10E-02
December-19	744.00	318.17	425.83	531	47.8	13,563,947	13,144,857	6,488,083	6,572	0.093	0.30	1.5895	1.08E-02
January-20	744.00	37.17	706.83	614	47.8	26,056,424	25,251,350	12,463,648	12,626	0.093	0.59	1.5895	2.07E-02
February-20	696.00	20.92	675.08	625	47.8	25,311,510	24,529,452	12,107,330	12,265	0.093	0.57	1.5895	2.01E-02
March-20	743.00	10.17	732.83	627	47.8	27,556,720	26,705,291	13,181,289	13,353	0.093	0.62	1.5895	2.19E-02
April-20	720.00	26.50	693.50	629	47.8	26,190,098	25,380,894	12,527,588	12,690	0.093	0.59	1.5895	2.08E-02
TOTAL/ AVG:	4,368.00	414.75	3,953.25	612	47.8	145,133,827	140,649,578	69,422,299	70,325				

#### NOTES:

The S-65 Engine (#2) commenced operation on April 27, 2017.  $^{1}$ CH<sub>4</sub>, CO, and SO<sub>2</sub> content was determined from the July 10 & 11, 2019 (9/6/19 - current) source test.

#### S-65 Engine (#2) Heat Input Rate

MONTH: Nov-19

Date	Runtime (hours)	CH4 (%)*	Average Flow (scfm)	Total LFG Volume (scf)	CH4 Volume (scf)	Heating Value of CH4 (BTU/scf)	Heat Input (MMBTU)/Day	Total Flow Corrected to HHV of 500 BTU/scf
11/01/2019	24.00	47.8	582	837,618	400,660	1,013	406	811,738
11/02/2019	23.50	47.8	557	801,578	383,421	1,013	388	776,812
11/03/2019	25.00	47.8	588	847,285	405,284	1,013	411	821,106
11/04/2019	24.00	47.8	599	861,914	412,282	1,013	418	835,283
11/05/2019	24.00	47.8	618	889,475	425,465	1,013	431	861,993
11/06/2019	24.00	47.8	602	903,671	432,255	1,013	438	875,750
11/07/2019	24.00	47.8	633	910,983	435,753	1,013	441	882,836
11/08/2019	23.67	47.8	618	889,246	425,356	1,013	431	861,771
11/09/2019	24.00	47.8	637	916,698	438,487	1,013	444	888,374
11/10/2019	24.00	47.8	639	920,870	440,482	1,013	446	892,417
11/11/2019	24.00	47.8	640	921,325	440,700	1,013	446	892,859
11/12/2019	24.00	47.8	638	918,051	439,134	1,013	445	889,686
11/13/2019	24.00	47.8	638	918,903	439,542	1,013	445	890,511
11/14/2019	24.00	47.8	643	925,891	442,884	1,013	449	897,284
11/15/2019	24.00	47.8	632	910,543	435,543	1,013	441	882,409
11/16/2019	24.00	47.8	627	903,245	432,052	1,013	438	875,337
11/17/2019	24.00	47.8	625	899,564	430,291	1,013	436	871,770
11/18/2019	24.00	47.8	632	910,021	435,293	1,013	441	881,904
11/19/2019	24.00	47.8	621	893,609	427,443	1,013	433	865,999
11/20/2019	24.00	47.8	618	890,017	425,724	1,013	431	862,518
11/21/2019	24.00	47.8	626	901,351	431,146	1,013	437	873,501
11/22/2019	24.00	47.8	630	906,895	433,798	1,013	439	878,875
11/23/2019	24.00	47.8	630	907,205	433,946	1,013	440	879,175
11/24/2019	24.00	47.8	630	906,883	433,792	1,013	439	878,863
11/25/2019	24.00	47.8	627	903,092	431,979	1,013	438	875,189
11/26/2019	24.00	47.8	622	896,163	428,664	1,013	434	868,474
11/27/2019	23.00	47.8	521	750,713	359,091	1,013	364	727,518
11/28/2019	24.00	47.8	554	798,374	381,889	1,013	387	773,706
11/29/2019	24.00	47.8	561	807,251	386,135	1,013	391	782,310
11/30/2019	24.00	47.8	560	806,693	385,868	1,013	391	781,768
Totals/ Average:	719.17	47.8	613	26,455,128.3	12,654,361	1,013	12,819	25,637,735
otes:	•	•			•	Maximum:	449	897,284

The S-65 Engine (#1) commenced operation on April 27, 2017.

\*Methane (CH<sub>4</sub>) content was determined from the July 18 & 19, 2018 (9/14/18 - 9/5/19) and July 10 & 11, 2019 (9/6/19 - current) source tests.

#### S-65 Engine (#2) Heat Input Rate

MONTH: Dec-19

Date	Runtime (hours)	CH4 (%)*	Average Flow (scfm)	Total LFG Volume (scf)	CH4 Volume (scf)	Heating Value of CH4 (BTU/scf)	Heat Input (MMBTU)/Day	Total Flow Corrected to HHV of 500 BTU/scf
12/01/2019	24.00	47.8	554	798,068	381,742	1,013	387	773,409
12/02/2019	24.00	47.8	583	840,075	401,836	1,013	407	814,119
12/03/2019	24.00	47.8	614	884,097	422,893	1,013	428	856,781
12/04/2019	24.00	47.8	604	870,300	416,293	1,013	422	843,410
12/05/2019	16.50	47.8	415	596,932	285,532	1,013	289	578,488
12/06/2019	7.83	47.8	143	205,936	98,506	1,013	100	199,573
12/07/2019	23.75	47.8	551	793,078	379,356	1,013	384	768,574
12/08/2019	24.00	47.8	555	799,800	382,571	1,013	388	775,088
12/09/2019	9.00	47.8	207	298,189	142,634	1,013	144	288,976
12/10/2019	0.00					·		•
12/11/2019	0.00							
12/12/2019	0.00							
12/13/2019	0.00							
12/14/2019	0.00							
12/15/2019	0.00							
12/16/2019	0.00							
12/17/2019	0.00							
12/18/2019	0.00							
12/19/2019	7.00	47.8	155	222,790	106,568	1,013	108	215,907
12/20/2019	15.67	47.8	293	421,593	201,662	1,013	204	408,567
12/21/2019	8.25	47.8	147	211,527	101,181	1,013	102	204,992
12/22/2019	24.00	47.8	342	492,909	235,774	1,013	239	477,679
12/23/2019	24.00	47.8	418	601,920	287,918	1,013	292	583,322
12/24/2019	24.00	47.8	497	716,399	342,677	1,013	347	694,264
12/25/2019	24.00	47.8	496	714,886	341,954	1,013	346	692,798
12/26/2019	24.00	47.8	542	781,090	373,621	1,013	378	756,956
12/27/2019	17.50	47.8	410	590,228	282,325	1,013	286	571,991
12/28/2019	8.75	47.8	191	275,259	131,665	1,013	133	266,754
12/29/2019	24.00	47.8	550	792,234	378,952	1,013	384	767,757
12/30/2019	23.58	47.8	544	783,449	374,749	1,013	380	759,242
12/31/2019	24.00	47.8	606	873,188	417,675	1,013	423	846,209
Totals/ Average:	425.83	47.8	531	13,563,946.7	6,488,083	1,013	6,572	13,144,857
Notes:						Maximum:	428	856,781

The S-65 Engine (#1) commenced operation on April 27, 2017.

\*Methane (CH<sub>4</sub>) content was determined from the July 18 & 19, 2018 (9/14/18 - 9/5/19) and July 10 & 11, 2019 (9/6/19 - current) source tests.

#### S-65 Engine (#2) Heat Input Rate

MONTH: Jan-20

Date	Runtime (hours)	CH4 (%)*	Average Flow (scfm)	Total LFG Volume (scf)	CH4 Volume (scf)	Heating Value of CH4 (BTU/scf)	Heat Input (MMBTU)/Day	Total Flow Corrected to HHV of 500 BTU/scf
1/01/2020	24.00	47.8	604	869,834	416,070	1,013	421	842,959
1/02/2020	24.00	47.8	603	868,234	415,305	1,013	421	841,408
1/03/2020	24.00	47.8	609	876,903	419,452	1,013	425	849,809
1/04/2020	24.00	47.8	611	879,662	420,771	1,013	426	852,482
1/05/2020	24.00	47.8	622	895,686	428,436	1,013	434	868,012
1/06/2020	24.00	47.8	614	883,484	422,600	1,013	428	856,187
1/07/2020	24.00	47.8	607	874,283	418,199	1,013	424	847,270
1/08/2020	23.25	47.8	578	832,497	398,211	1,013	403	806,775
1/09/2020	22.50	47.8	545	785,402	375,684	1,013	381	761,135
1/10/2020	24.00	47.8	606	873,108	417,636	1,013	423	846,131
1/11/2020	24.00	47.8	610	878,117	420,032	1,013	425	850,986
1/12/2020	24.00	47.8	607	874,143	418,132	1,013	424	847,135
1/13/2020	24.00	47.8	607	874,327	418,220	1,013	424	847,313
1/14/2020	10.00	47.8	247	356,168	170,367	1,013	173	345,164
1/15/2020	12.25	47.8	276	398,050	190,401	1,013	193	385,752
1/16/2020	24.00	47.8	625	900,003	430,501	1,013	436	872,196
1/17/2020	24.00	47.8	633	911,263	435,887	1,013	442	883,108
1/18/2020	24.00	47.8	632	910,363	435,457	1,013	441	882,236
1/19/2020	22.33	47.8	568	817,808	391,184	1,013	396	792,539
1/20/2020	17.00	47.8	588	608,349	290,993	1,013	295	589,553
1/21/2020	24.00	47.8	626	901,867	431,393	1,013	437	874,001
1/22/2020	24.00	47.8	634	913,612	437,011	1,013	443	885,384
1/23/2020	24.00	47.8	630	907,439	434,058	1,013	440	879,401
1/24/2020	24.00	47.8	629	905,693	433,223	1,013	439	877,709
1/25/2020	24.00	47.8	628	903,764	432,300	1,013	438	875,840
1/26/2020	24.00	47.8	630	906,980	433,838	1,013	439	878,957
1/27/2020	23.50	47.8	593	853,678	408,342	1,013	414	827,301
1/28/2020	24.00	47.8	624	898,801	429,926	1,013	436	871,030
1/29/2020	24.00	47.8	622	895,075	428,144	1,013	434	867,419
1/30/2020	24.00	47.8	625	899,559	430,289	1,013	436	871,765
1/31/2020	24.00	47.8	627	902,271	431,586	1,013	437	874,393
Totals/ Average:	706.83	47.8	614	26,056,424.1	12,463,648	1,013	12,626	25,251,350
lotes:	1	1				Maximum:	443	885,384

The S-65 Engine (#1) commenced operation on April 27, 2017.
\*Methane (CH<sub>4</sub>) content was determined from the July 10 & 11, 2019 (9/6/19 - current) source test.

#### S-65 Engine (#2) Heat Input Rate

MONTH: Feb-20

Date	Runtime (hours)	CH4 (%)*	Average Flow (scfm)	Total LFG Volume (scf)	CH4 Volume (scf)	Heating Value of CH4 (BTU/scf)	Heat Input (MMBTU)/Day	Total Flow Corrected to HHV of 500 BTU/scf
2/01/2020	24.00	47.8	624	898,874	429,961	1,013	436	871,101
2/02/2020	24.00	47.8	622	896,179	428,672	1,013	434	868,489
2/03/2020	24.00	47.8	622	895,149	428,180	1,013	434	867,492
2/04/2020	24.00	47.8	627	902,812	431,845	1,013	437	874,918
2/05/2020	23.75	47.8	609	877,239	419,613	1,013	425	850,135
2/06/2020	24.00	47.8	625	899,759	430,384	1,013	436	871,958
2/07/2020	24.00	47.8	625	899,567	430,292	1,013	436	871,773
2/08/2020	24.00	47.8	636	915,485	437,907	1,013	444	887,199
2/09/2020	24.00	47.8	628	904,968	432,876	1,013	439	877,007
2/10/2020	24.00	47.8	632	909,947	435,258	1,013	441	881,832
2/11/2020	24.00	47.8	636	916,323	438,307	1,013	444	888,011
2/12/2020	24.00	47.8	630	906,833	433,768	1,013	439	878,814
2/13/2020	24.00	47.8	627	902,354	431,626	1,013	437	874,473
2/14/2020	24.00	47.8	628	904,360	432,585	1,013	438	876,417
2/15/2020	24.00	47.8	631	908,363	434,500	1,013	440	880,297
2/16/2020	24.00	47.8	632	909,591	435,087	1,013	441	881,487
2/17/2020	24.00	47.8	634	913,645	437,026	1,013	443	885,416
2/18/2020	24.00	47.8	639	920,312	440,216	1,013	446	891,877
2/19/2020	24.00	47.8	633	912,168	436,320	1,013	442	883,984
2/20/2020	24.00	47.8	634	912,995	436,716	1,013	442	884,786
2/21/2020	24.00	47.8	632	909,476	435,032	1,013	441	881,376
2/22/2020	20.17	47.8	522	751,688	359,557	1,013	364	728,463
2/23/2020	24.00	47.8	638	919,352	439,756	1,013	445	890,946
2/24/2020	21.83	47.8	544	783,626	374,834	1,013	380	759,414
2/25/2020	17.25	47.8	427	614,365	293,871	1,013	298	595,382
2/26/2020	23.58	47.8	613	882,019	421,899	1,013	427	854,766
2/27/2020	16.50	47.8	377	542,753	259,617	1,013	263	525,984
2/28/2020	24.00	47.8	625	900,673	430,822	1,013	436	872,844
2/29/2020	24.00	47.8	625	900,637	430,804	1,013	436	872,810
Totals/ Average:	675.08	47.8	625	25,311,510.0	12,107,330	1,013	12,265	24,529,452
otes:						Maximum:	446	891,877

The S-65 Engine (#1) commenced operation on April 27, 2017.
\*Methane (CH<sub>4</sub>) content was determined from the July 10 & 11, 2019 (9/6/19 - current) source test.

#### S-65 Engine (#2) Heat Input Rate

MONTH: Mar-20

Date	Runtime (hours)	CH4 (%)*	Average Flow (scfm)	Total LFG Volume (scf)	CH4 Volume (scf)	Heating Value of CH4 (BTU/scf)	Heat Input (MMBTU)/Day	Total Flow Corrected to HHV of 500 BTU/scf
3/01/2020	24.00	47.8	625	900,139	430,566	1,013	436	872,327
3/02/2020	24.00	47.8	626	901,603	431,266	1,013	437	873,746
3/03/2020	24.00	47.8	626	901,978	431,446	1,013	437	874,110
3/04/2020	24.00	47.8	628	904,063	432,443	1,013	438	876,130
3/05/2020	24.00	47.8	633	911,914	436,199	1,013	442	883,738
3/06/2020	24.00	47.8	632	910,437	435,492	1,013	441	882,307
3/07/2020	24.00	47.8	633	911,625	436,060	1,013	442	883,458
3/08/2020	23.00	47.8	633	873,202	417,681	1,013	423	846,223
3/09/2020	24.00	47.8	635	914,982	437,666	1,013	443	886,711
3/10/2020	23.33	47.8	590	850,260	406,708	1,013	412	823,989
3/11/2020	23.92	47.8	633	911,469	435,986	1,013	442	883,307
3/12/2020	22.33	47.8	584	840,307	401,946	1,013	407	814,344
3/13/2020	23.50	47.8	592	851,810	407,449	1,013	413	825,491
3/14/2020	24.00	47.8	596	858,737	410,762	1,013	416	832,205
3/15/2020	24.00	47.8	596	858,550	410,673	1,013	416	832,023
3/16/2020	24.00	47.8	595	857,390	410,118	1,013	415	830,899
3/17/2020	24.00	47.8	600	863,401	412,993	1,013	418	836,724
3/18/2020	24.00	47.8	599	862,903	412,755	1,013	418	836,241
3/19/2020	24.00	47.8	608	875,926	418,984	1,013	424	848,862
3/20/2020	24.00	47.8	663	954,563	456,599	1,013	463	925,070
3/21/2020	24.00	47.8	652	938,817	449,067	1,013	455	909,810
3/22/2020	24.00	47.8	646	929,564	444,641	1,013	450	900,843
3/23/2020	24.00	47.8	654	941,220	450,217	1,013	456	912,139
3/24/2020	24.00	47.8	655	943,706	451,406	1,013	457	914,548
3/25/2020	24.00	47.8	649	935,093	447,286	1,013	453	906,201
3/26/2020	24.00	47.8	640	921,508	440,788	1,013	447	893,036
3/27/2020	18.92	47.8	499	718,786	343,819	1,013	348	696,577
3/28/2020	24.00	47.8	635	914,051	437,221	1,013	443	885,809
3/29/2020	24.00	47.8	634	912,569	436,512	1,013	442	884,373
3/30/2020	23.50	47.8	609	877,644	419,806	1,013	425	850,527
3/31/2020	22.33	47.8	561	808,505	386,734	1,013	392	783,524
Totals/ Average:	732.83	47.8	627	27,556,720.2	13,181,289	1,013	13,353	26,705,291
Notes:						Maximum:	463	925,070

The S-65 Engine (#1) commenced operation on April 27, 2017.
\*Methane (CH<sub>4</sub>) content was determined from the July 10 & 11, 2019 (9/6/19 - current) source test.

#### S-65 Engine (#2) Heat Input Rate

MONTH: Apr-20

Date	Runtime (hours)	CH4 (%)*	Average Flow (scfm)	Total LFG Volume (scf)	CH4 Volume (scf)	Heating Value of CH4 (BTU/scf)	Heat Input (MMBTU)/Day	Total Flow Corrected to HHV of 500 BTU/scf
4/01/2020	24.00	47.8	620	893,245	427,269	1,013	433	865,646
4/02/2020	22.58	47.8	575	828,566	396,331	1,013	401	802,966
4/03/2020	24.00	47.8	637	917,941	439,081	1,013	445	889,579
4/04/2020	24.00	47.8	621	893,760	427,515	1,013	433	866,145
4/05/2020	22.83	47.8	584	841,670	402,599	1,013	408	815,665
4/06/2020	16.92	47.8	421	605,671	289,712	1,013	293	586,957
4/07/2020	24.00	47.8	635	914,960	437,655	1,013	443	886,690
4/08/2020	24.00	47.8	631	909,156	434,879	1,013	441	881,065
4/09/2020	21.75	47.8	528	760,758	363,895	1,013	369	737,252
4/10/2020	24.00	47.8	628	903,958	432,393	1,013	438	876,028
4/11/2020	24.00	47.8	630	907,525	434,099	1,013	440	879,485
4/12/2020	24.00	47.8	633	911,270	435,890	1,013	442	883,114
4/13/2020	23.42	47.8	620	892,266	426,800	1,013	432	864,697
4/14/2020	16.58	47.8	396	570,530	272,903	1,013	276	552,902
4/15/2020	24.00	47.8	599	862,294	412,463	1,013	418	835,651
4/16/2020	24.00	47.8	622	896,127	428,647	1,013	434	868,439
4/17/2020	24.00	47.8	633	911,095	435,807	1,013	441	882,945
4/18/2020	24.00	47.8	657	945,592	452,308	1,013	458	916,376
4/19/2020	24.00	47.8	658	947,636	453,285	1,013	459	918,356
4/20/2020	24.00	47.8	641	923,499	441,740	1,013	447	894,965
4/21/2020	20.58	47.8	525	755,421	361,343	1,013	366	732,081
4/22/2020	23.75	47.8	632	909,593	435,088	1,013	441	881,489
4/23/2020	24.00	47.8	646	930,533	445,105	1,013	451	901,782
4/24/2020	24.00	47.8	642	924,329	442,137	1,013	448	895,770
4/25/2020	24.00	47.8	642	924,254	442,101	1,013	448	895,697
4/26/2020	24.00	47.8	643	926,514	443,182	1,013	449	897,887
4/27/2020	24.00	47.8	650	935,559	447,509	1,013	453	906,652
4/28/2020	24.00	47.8	650	935,444	447,454	1,013	453	906,542
4/29/2020	21.08	47.8	542	780,784	373,475	1,013	378	756,660
4/30/2020	24.00	47.8	646	930,150	444,922	1,013	451	901,411
otals/ Average:	693.50	47.8	629	26,190,098.1	12,527,588	1,013	12,690	25,380,894
otes:	•	•				Maximum:	459	918,356

S65

The S-65 Engine (#1) commenced operation on April 27, 2017. \*Methane ( $CH_4$ ) content was determined from the July 10 & 11, 2019 (9/6/19 - current) source test.

## APPENDIX L VOC SOILS LOGS

#### **Redwood Landfill**

Facility Number A1179
Title V Permit Condition Number 19867, Part 14

#### **VOC Laden Soil**

Month	VOC Emission Rate (lbs/month)	12-Month Rolling Total (lbs)
May-19	0.00	0.00
June-19	0.00	0.00
July-19	0.00	0.00
August-19	0.00	0.00
September-19	0.00	0.00
October-19	0.00	0.00
November-19	0.00	0.00
December-19	0.00	0.00
January-20	0.00	0.00
February-20	0.00	0.00
March-20	0.00	0.00
April-20	0.00	0.00
TOTALS:	0.00	

VOC Laden Soils is defined as soils containing concentrations of VOC less than 50 parts per million by weight (ppm<sub>w</sub>).

# APPENDIX M H<sub>2</sub>S TWICE WEEKLY AND QUARTERLY MONITORING

## REDWOOD LANDFILL, INC. Novato, CA

Total Reduced Sulfur Content - Quarter 4 - 2019

Date	H₂S Reading (ppm <sub>v</sub> )	Calculated TRS (ppm <sub>v</sub> )
10/3/2019	1,082.1	1,098.3
10/7/2019	1,019.1	1,034.4
10/13/2019	1,011.2	1,026.4
10/14/2019	998.7	1,013.7
10/17/2019	944.2	958.4
10/21/2019	997.4	1,012.4
10/25/2019	1,025.0	1,040.4
10/29/2019	1,050.0	1,065.8
10/31/2019	1,066.7	1,082.7
11/4/2019	978.9	993.6
11/7/2019	963.4	977.8
11/11/2019	916.2	929.9
11/14/2019	958.6	973.0
11/14/19*	1,514.1	1,534.7
11/19/2019	962.6	977.0
11/21/2019	979.8	994.5
11/26/2019	953.8	968.1
11/27/2019	917.5	931.2
12/2/2019	947.7	961.9
12/5/2019	982.6	997.4
12/9/2019	1,041.8	1,057.4
12/12/2019	1,000.0	1,015.0
12/16/2019	1,050.0	1,065.8
12/19/2019	850.0	862.8
12/23/2019	1,027.2	1,042.6
12/27/2019	1,000.9	1,015.9
12/30/2019	1,033.3	1,048.8
Quarterly Average:	1,010.1	1,025.2

ppm<sub>v</sub>= parts per million by volume

TRS= total reduced sulfur

#### Title V Permit Condition Number 19867 Part 31b

As of March 31, 2005, the Permit Holder shall analyze the landfill gas for H2S concentration on a weekly basis. The landfill gas sample shall be drawn from the main landfill gas header using a Draeger/RAE tube. The TRS content of the landfill gas shall be calculated using the average ratio of TRS/H2S for this site according to the following equation: TRS=1.015\*H2S measured by the Draeger/RAE Tube. The Permit Holder shall maintain records of all Draeger/RAE tube test dates and test results and shall summarize the average H2S concentrations and the calculated TRS content of the landfill gas on a quarterly basis. Each Draeger/RAE tube test result (after conversion to TRS content) and the quarterly laboratory analysis in Part 31a shall be compared to the Peak TRS Limit in Part 18c. The concentration of TRS in collected landfill gas shall not exceed a peak of 410 ppmv, and on a rolling quarterly basis, the Permit Holder shall determine the annual average TRS content for comparison to the Annual Average TRS Limit of 350 ppmv.

#### November 22, 2016 Compliance Agreement

Per Condition 2.1 of the Compliance Agreement, H2S sampling using Draeger/RAE tubes shall be twice per week. Analytical sampling shall remain on quarterly intervals.

<sup>\*</sup> Quarterly LFG lab analysis

## REDWOOD LANDFILL, INC. Novato, CA

Total Reduced Sulfur Content - Quarter 1 - 2020

Date	H₂S Reading (ppm <sub>v</sub> )	Calculated TRS (ppm <sub>v</sub> )
1/2/2020	1,046.0	1,061.7
1/6/2020	988.1	1,002.9
1/9/2020	1,000.0	1,015.0
1/13/2020	1,107.9	1,124.6
1/16/2020	988.4	1,003.2
1/20/2020	1,007.7	1,022.9
1/23/2020	1,019.0	1,034.3
1/27/2020	1,003.1	1,018.1
1/30/2020	999.8	1,014.8
2/3/2020	971.6	986.1
2/6/2020	1,027.4	1,042.8
2/10/2020	980.3	995.0
2/13/2020	910.4	924.0
2/17/2020	965.3	979.8
2/18/20*	1,298.9	1,307.5
2/20/2020	978.5	993.2
2/24/2020	991.4	1,006.3
2/26/2020	1,025.5	1,040.9
3/2/2020	931.7	945.6
3/5/2020	952.7	967.0
3/9/2020	944.4	958.6
3/12/2020	943.4	957.6
3/17/2020	952.6	966.9
3/19/2020	935.2	949.2
3/23/2020	920.8	934.7
3/26/2020	977.1	991.8
3/30/2020	951.4	965.7
Quarterly Average:	993.3	1,007.8

ppm<sub>v</sub>= parts per million by volume

TRS= total reduced sulfur

\* Quarterly LFG lab analysis

#### Title V Permit Condition Number 19867 Part 31b

As of March 31, 2005, the Permit Holder shall analyze the landfill gas for H2S concentration on a weekly basis. The landfill gas sample shall be drawn from the main landfill gas header using a Draeger/RAE tube. The TRS content of the landfill gas shall be calculated using the average ratio of TRS/H2S for this site according to the following equation: TRS=1.015\*H2S measured by the Draeger/RAE Tube. The Permit Holder shall maintain records of all Draeger/RAE tube test dates and test results and shall summarize the average H2S concentrations and the calculated TRS content of the landfill gas on a quarterly basis. Each Draeger/RAE tube test result (after conversion to TRS content) and the quarterly laboratory analysis in Part 31a shall be compared to the Peak TRS Limit in Part 18c. The concentration of TRS in collected landfill gas shall not exceed a peak of 410 ppmv, and on a rolling quarterly basis, the Permit Holder shall determine the annual average TRS content for comparison to the Annual Average TRS Limit of 350 ppmv.

#### November 22, 2016 Compliance Agreement

Per Condition 2.1 of the Compliance Agreement, H2S sampling using Draeger/RAE tubes shall be twice per week. Analytical sampling shall remain on quarterly intervals.

## REDWOOD LANDFILL, INC. Novato, CA

#### **Total Reduced Sulfur Content - Quarter 2 - 2020**

Date	H₂S Reading (ppm <sub>v</sub> )	Calculated TRS (ppm <sub>v</sub> )
4/2/2020	973.9	988.5
4/6/2020	918.5	932.3
4/9/2020	936.9	951.0
4/13/2020	976.2	990.8
4/16/2020	943.8	958.0
4/20/2020	899.4	912.9
4/23/2020	941.8	955.9
4/23/20*	603.5	609.1
4/27/2020	921.0	934.9
4/30/2020	905.6	919.2
Quarterly Average:	TBD	TBD

H<sub>2</sub>S= hydrogen sulfide

ppm<sub>v</sub>= parts per million by volume

TRS= total reduced sulfur

#### Title V Permit Condition Number 19867 Part 31b

As of March 31, 2005, the Permit Holder shall analyze the landfill gas for H2S concentration on a weekly basis. The landfill gas sample shall be drawn from the main landfill gas header using a Draeger/RAE tube. The TRS content of the landfill gas shall be calculated using the average ratio of TRS/H2S for this site according to the following equation: TRS=1.015\*H2S measured by the Draeger/RAE Tube. The Permit Holder shall maintain records of all Draeger/RAE tube test dates and test results and shall summarize the average H2S concentrations and the calculated TRS content of the landfill gas on a quarterly basis. Each Draeger/RAE tube test result (after conversion to TRS content) and the quarterly laboratory analysis in Part 31a shall be compared to the Peak TRS Limit in Part 18c. The concentration of TRS in collected landfill gas shall not exceed a peak of 410 ppmv, and on a rolling quarterly basis, the Permit Holder shall determine the annual average TRS content for comparison to the Annual Average TRS Limit of 350 ppmv.

#### November 22, 2016 Compliance Agreement

Per Condition 2.1 of the Compliance Agreement, H2S sampling using Draeger/RAE tubes shall be twice per week. Analytical sampling shall remain on quarterly intervals.

<sup>\*</sup> Quarterly LFG lab analysis

## REDWOOD LANDFILL, INC. Novato. CA

#### **Rolling Quarterly Average Total Reduced Sulfur Content**

Year	Quarter	Calculated TRS (ppm <sub>v</sub> )	Rolling Quarterly Average Annual TRS (ppm <sub>v</sub> )	Quarterly SO <sub>2</sub> Emission Factor (lb/MMscf)
2019	2	1,187	898.0	200.53
2019	3	936	946.1	158.10
2019	4	778	962.8	131.38
2020	1	753	913.5	127.25
2020	2*	TBD	TBD	TBD

<sup>\*</sup>Quarterly results will be calculated at the end of the quarter.

 $H_2S$  = hydrogen sulfide

ppm<sub>v</sub> = parts per million by volume

TRS = total reduced sulfur

TBD = To Be Determined.

Quarterly SO2 Emission Factor based on TRS concentrations to Flares A-51 and A-60 only.

#### Title V Permit Condition Number 19867 Part 31b

As of March 31, 2005, the Permit Holder shall analyze the landfill gas for H<sub>2</sub>S concentration on a weekly basis. The landfill gas sample shall be drawn from the main landfill gas header using a Draeger/RAE tube. The TRS content of the landfill gas shall be calculated using the average ratio of TRS/H<sub>2</sub>S for this site according to the following equation: TRS=1.015\*H<sub>2</sub>S measured by the Draeger/RAE Tube. The Permit Holder shall maintain records of all Draeger/RAE tube test dates and test results and shall summarize the average H<sub>2</sub>S concentrations and the calculated TRS content of the landfill gas on a quarterly basis. Each Draeger/RAE tube test result (after conversion to TRS content) and the quarterly laboratory analysis in Part 31a shall be compared to the Peak TRS Limit in Part 18c. On a rolling quarterly basis, the Permit Holder shall determine the annual average TRS content for comparison to the Annual Average TRS Limit of 350 ppm<sub>v</sub>.

 $SO2\ EF = Calculated\ TRS\ (ppmv)*0.0283168\ m3/scf*1000\ L/m3*1\ mol/22.4\ L*64.06\ g/mol*1\ lb/453.592\ g*273.15\ K/288.7\ K$ 

## APPENDIX N PERFORMANCE TEST REPORT

#### Redwood Landfill, Inc

**BAAQMD** Facility # 1179

### Annual Compliance Emissions Test Report #19180

Source Test for Landfill Gas Flare-Source A-60A and S-71

#### Located at:

8950 Redwood Highway Novato, CA 94948

#### Performed and Reported by:

Blue Sky Environmental, Inc 624 San Gabriel Avenue Albany, CA 94706

#### **Prepared For:**

SCS Engineers
Dave Bearden
3117 Fite Circle Suite 108
Sacramento, CA 95827
DBearden@scsengineers.com
(916) 361-1297

#### For Submittal To:

Bay Area Air Quality Management District
Attn: Marco Hernandez & Gloria Espena
Source Test Division
375 Beale Street, Suite 600
San Francisco, CA 94105
mhernandez@baaqmd.gov & gespena@baaqmd.gov

#### **Testing Performed On:**

Willexa S-71 on July 24<sup>th</sup>, 2019 Flare A-60-A on July 25<sup>th</sup>, 2019

#### Final Report Submitted On:

September 20th, 2019

#### **REVIEW AND CERTIFICATION**

#### Team Leader:

The work performed herein was conducted under my supervision, and I certify that: a) the details and results contained within this report are to the best of my knowledge an authentic and accurate representation of the test program; b) that the sampling and analytical procedures and data presented in the report is authentic and accurate: c) that all testing details and conclusions are accurate and valid, and: d) that the production rate and/or heat input rate during the source test are reported accurately.

If this report is submitted for Compliance purposes it should only be reproduced in its entirety. If there are any questions concerning this report, please contact me at (510) 508 3469.

Guy Worthington

Mhohigh

Project Manager

#### TABLE of CONTENTS

SECTION	1. INTRODUCTION
1.1.	Summary
SECTION	2. SOURCE TEST PROGRAM
2.1.	Overview4
2.2.	POLLUTANTS TESTED4
2.3.	Test Date(s)4
2.4.	SAMPLING AND OBSERVING PERSONNEL
2.5.	SOURCE/PROCESS DESCRIPTION
2.6.	Source Operating Conditions
SECTION	3. SAMPLING AND ANALYSIS PROCEDURES5
3.1.	PORT LOCATION
3.2.	POINT DESCRIPTION/LABELING - PORTS/STACK
3.3.	SAMPLE TRAIN DESCRIPTION
3.4.	SAMPLING PROCEDURE DESCRIPTION
Instrum	ENTATION AND ANALYTICAL PROCEDURES
SECTION	4. APPENDICES
A.	Tabulated Results
B.	Calculations
	Laboratory Reports
D.	Field Data Sheets
E.	Strip Charts
	Process Information
G.	Calibration Certifications and Quality Assurance Records
Н.	Sample Train Configuration and Stack Diagrams
<i>I</i> .	Related Correspondence (Source Test Plan)
J.	BAAQMD Permit

#### **SECTION 1. INTRODUCTION**

#### 1.1. Summary

Blue Sky Environmental, Inc was contracted to perform the compliance emissions testing on the A-60A Landfill Gas Flare, located at Redwood Landfill, 8950 Redwood Highway, Novato, California. Table 1.1 summarizes the source test information. Table 1.2 summarizes the results compared to the emission limits.

**Table 1.1 Source Test Information** 

Test Location:	Redwood Landfill, 8950 Redwood Highway, Novato, California 94948 Mailing Address PO Box 793, Novato, CA 94948
Source Contact:	Alisha McCutcheon (415) 892-2851
Source Tested:	Enclosed Landfill Gas Flare (A-60 A) and LFG Treatment System (S-71)
Source Test Dates:	July 25th, 2019
Test Objective:	Determine Compliance with Regulation 8, Rule 34 and Permit to Operate A1179, Condition 19867, 30
Test Performed By:	Blue Sky Environmental, Inc 624 San Gabriel Ave., Albany, CA 94706 Guy Worthington (510) 508 3469 blueskyenvironmental@yahoo.com
Test Parameters:	Landfill Gas O <sub>2</sub> , N <sub>2</sub> , CO <sub>2</sub> , BTU, THC, CH <sub>4</sub> , NMOC, HHV, F-Factor, Sulfur & VOC Species, Volumetric Flow Rate Flare Emissions THC, CH <sub>4</sub> , NMOC, NOx, CO, O <sub>2</sub> , SO <sub>2</sub> , Volumetric Flow Rate, Temperature. Gas Treatment Waste Gas Flow, VOC, NMOC, TRS, Fixed Gases

Table 1.2. Compliance Summary

#### **SECTION 2. SOURCE TEST PROGRAM**

A60-A @ 1585°F	Average Test	Permit Limit	Compliance Status
NOx, lbs/MMBTU	0.05	0.06	In Compliance
NOx, ppm @ 15% O <sub>2</sub>	11.8	15	In Compliance
CO, lbs/MMBTU	0.10	0.20	In Compliance
CO, ppm @ 15% O <sub>2</sub>	40.2	82	In Compliance
NMOC, (ppmvd @ 3% O <sub>2</sub> as CH <sub>4</sub> )	11.9	30	In Compliance
CH <sub>4</sub> Destruction Efficiency %	99.97	99	In Compliance
SO <sub>2</sub> , ppm	37.7	300	In Compliance
SO <sub>2</sub> , lbs/MMBTU	0.19	1.69	In Compliance

#### 2.1. Overview

This performance test was conducted to demonstrate that the A-60 (A) landfill gas flare is operating in accordance with the Bay Area Air Quality Management District (BAAQMD) Title V Permit A1179 and Regulation 8 Rule 34. The A-60 flare is divided into two discrete zones A (larger) and B (smaller). Only zone A of Flare A-60 was tested. Also the Willexa System S-71 waste gas to the Flare A60 (B) was tested. Willexa emissions were tested during startup purge of the 1" line, during stages 6/7/8 on the 12' line while the flow is ramping up, and Stage 9 when the flow is stabilized and the temperature of the Willexa desorption beds is increasing.

#### 2.2. Pollutants Tested

The following EPA and ASTM sampling and analytical methods were used while testing the Flare A60-A:

EPA 3A CO<sub>2</sub> and O<sub>2</sub>

EPA 10 CO
Modified EPA 18 NMOC
EPA 7E NO<sub>X</sub>
EPA 6C SO<sub>2</sub>

EPA 19 Flow Rate Calculation, DSCFM EPA 25C LFG Gas analysis for NMOC by GC

EPA TO-15 VOC Species

ASTM 1945/3588 LFG Gas analysis for BTU and F-Factor

ASTM D-5504 Sulfur Species, H<sub>2</sub>S and TRS

The following EPA and ASTM sampling and analytical methods were used while testing the Willexa S-71:

EPA 25C LFG Gas analysis for NMOC by GC

EPA TO-15 VOC Species

ASTM 1945/3588 LFG Gas analysis for BTU and F-Factor

ASTM D-5504 Sulfur Species, H<sub>2</sub>S and TRS

#### 2.3. Test Date(s)

Testing was conducted on the Willexa S-71 July 24th and the Flare A60-A July 25th, 2019.

#### 2.4. Sampling and Observing Personnel

Guy Worthington and Wesley Alder representing Blue Sky Environmental Inc., performed testing.

Sean Johnson and Michael Chan of Waste Management and Dave Bearden of SCS Engineers were present to operate and oversee the Flare operation and assist in coordinating testing and the collection of process data during testing, and provided the Yokogawa Flare data.

The BAAQMD was notified of the test in a plan submitted by SCS Engineers on July 10<sup>th</sup>, 2019. A Source Test Protocol acknowledgement was requested and received by SCS Engineers (NST # 5532, provided on July 12<sup>th</sup>, 2019), but no observers were present to witness the testing. A copy of the source test protocol and documentation can be found in Appendix I.

#### 2.5. Source/Process Description

The enclosed LFG flare A-60 consists of 3,000 standard cubic feet per minute (scfm) multiple nozzle burner manufactured by Perennial Energy. The flare shell is approximately 45 feet high and has an inside diameter of approximately 136 inches. Zone A is a large segment, with 4 ports requiring unique - not perpendicular - traverses of 133 inches in length. The Willexa system is designed to remove non-methane organics and chlorinated compounds from up to 1,875 SCFM of landfill gas. The Willexa waste gas is vented at separate times through 1" and 12" diameter pipes to the Flare A60(B-side). The Willexa has four cycles, Depress Cycle #1, Regen Cycle, Depress Cycle #2 and Stabilization.

#### 2.6. Source Operating Conditions

The flare operating temperature and the landfill gas inlet flow rate are shown contained in Appendix-F. There is no condensate injection. The waste gas flows and characterization is found in Appendix A, Table 3. The Flare A-60 requires annual testing (either side A or side B), with no longer than 5 years between tests on A and B.

The A60–A flare was operated at approximately 1,585 Degrees Fahrenheit (°F). The landfill gas methane content was 47.3 percent (%).

#### SECTION 3. SAMPLING AND ANALYSIS PROCEDURES

#### 3.1. Port location

The two unequal stack segments in the A-60 (A&B) flare present a unique sampling configuration, as the cross-section is neither round, square, rectangular or oval. The A-60A Flare sampling was conducted via adjacent flange ports both with a 133 inch traverse path length. The port is located approximately 35 feet above grade, accessed by a 40-foot boom-lift. The 4-inch flange port is available ~4 stack diameters downstream from the burners and ~1 stack diameter upstream from the exit.

#### 3.2. Point description/Labeling – ports/stack

Blue Sky Environmental conducted traverses and found Oxygen (O<sub>2</sub>) stratification of more than 10%. Subsequent CEM sampling was conducted using the same traverse points.

#### 3.3. Sample train description

Sampling system diagrams are included in the Appendix H. Additional descriptive information is included in the following section.

#### 3.4. Sampling procedure description

Three 50 minute test runs were performed on the Flare A60-A on July 25th, 2019. Waste Gas testing occurred over an approximate 4 hour period on July 24th, 2019.

EPA Method 3A (O<sub>2</sub>, CO<sub>2</sub>), 10 (CO) and 7E (NO<sub>x</sub>) are continuous monitoring techniques using instrumental analyzers. Sampling is performed by extracting exhaust flue gas from the stack, conditioning the sample and analyzing it by continuous monitoring gas analyzers in a CEM test van. The sampling system consists of a stainless steel sample probe, teflon sample line, glass-fiber particulate filter, glass moisture-knockout condensers in ice, followed by thermoelectric coolers (optional), teflon sample transfer tubing, diaphragm pump and a stainless steel/teflon manifold and flow control/delivery system. A constant sample and calibration gas supply pressure of 5 PSI was provided to each analyzer to avoid pressure variable response differences. The entire sampling system was leak checked prior to and at the end of the sampling program.

The sampling and analytical system (for EPA Methods) was checked for linearity with zero, mid (40-60%) and high span (80-100%) calibrations and is checked for system bias at the beginning and end of each run. System bias is determined by introducing calibration gas to the probe and pulling it through the entire sampling system. Individual test run calibrations usually use the calibration gas that most closely matches the stack gas effluent. Along with the Sampling System Bias, the Zero and Calibration Drift values were determined for each test. Methods 3A, 7E and 10 all defer to EPA Method 7E for the calculations of effluent concentration, Span, Calibration Gas, Analyzer Calibration Error (Linearity), Sampling System Bias, Zero Drift, Calibration Drift and Response Time. In addition, the NOx analyzer NO<sub>2</sub> to NO conversion efficiency check defers to EPA Method 20 section 5.6 for the criteria and procedure.

All calibration gases are EPA Protocol #1. The analyzer data recording system consists of a Honeywell DPR3000 or using OMEGA 3-pen flat-bed strip chart recorder supported by a Data Acquisition System (DAS).

**EPA Method 18** is used to determine emissions of volatile organics analyzed by gas chromatograph/mass spectroscopy (GC/MS). Gaseous emissions are drawn through a purged, short teflon sample line to a tedlar bag located in a rigid leak proof bag container. Sample is drawn into the bag by evacuating the container to below stack gas pressure to allow sample flow into the bag without using a pump to avoid contamination. Using a rotometer at the probe tip prior to sampling, the negative pressure inside the container is adjusted with an adjustable flow orifice to maintain a constant integrated sample flow for the test duration. The bag samples are taken to a laboratory and analyzed within 72 hours.

**EPA TO-15/ASTM 1945/ASTM5504/EPA 25C** Sampling consists of collecting gases in pre-evacuated 6-Liter SUMMA canisters with pre-set flow controllers set to integrate over the desired test duration. The SUMMA® passivated canisters allow holding times up to 14 days for the TO-15 Method list of volatile organics. The SILCO canisters have a silanized (glass) lining that permits longer holding times (up to 72 hours) for reactive sulfur compounds. The sample gas is drawn by the canister vacuum through a micro-filter, pre-set orifice flow controller and on/off valve into the canister. The flow controller consisted of capillary orifice tubing designed to sample for a pre-set duration of 0.5 – 1.0 hours depending on the Permit requirements. The canister vacuum is monitored with a vacuum gauge to verify sample collection, and ideally drawn down to ~5"Hg Vacuum to minimize compound condensation inside the canister.

The samples are analyzed for volatile organics by EPA Method TO-15 using GC/MS (gas chromatography/mass spectroscopy and for tentatively identified compounds, not included in the TO-15 list. The samples were also analyzed for 20 sulfur compounds by ASTM Method D-5504 GC/SCD (gas chromatography/sulfur chemiluminescent detector).

#### System Performance Criteria

 Instrument Linearity
 ≤2% Full Scale (checked routinely)

 Instrument Bias
 ≤5% Full Scale (checked routinely)

 System Response Time
 ≤± 2 minutes (checked routinely)

NOx Converter Efficiency (EPA 7E)  $\geq$  90% (monthly checks)
Instrument Zero Drift  $\leq$   $\pm$  3% Full Scale (complied)
Instrument Span Drift  $\leq$   $\pm$  3% Full Scale (complied)

Concurrent with the exhaust sampling, Blue Sky collected a total of three integrated 6-liter summa canister samples of the LFG for analysis. The samples were collected using Teflon tubing connections, and the tubing was purged prior to sampling. The gas sample was controlled with a orifice to collect a 60-minute integrated sample. All the samples were analyzed for NMOC, HHV, F-Factor, Fixed Gases and Sulfur Species (incl. H<sub>2</sub>S and TRS) and VOC Compounds

The inlet volumetric Flow Rate and Flare Temperature was continuously measured and recorded by the facility Yokogawa monitors.

Willexa S-71 Description: The Landfill Gas (LFG) that is supplied to the engines is pre-treated in an alternating twin-bed system to remove particulates and liquid aerosols in a pre-filter, then sulfurs are removed by twin-bed expendable media, then siloxanes and NMOCs are removed in a twin-bed regenerative media, and finally the gas is polished in expendable twin carbon vessels where final siloxanes, sulfurs and non-methane organics are removed. The Willexa siloxane scrubber system is regenerated using a Temperature Swing Adsorption (TSA) process. The Willexa system is designed to remove non-methane organics and chlorinated compounds from up to 1875 SCFM of landfill gas. The concentration of contaminants being removed from the Landfill Gas and the Landfill Gas flowrate will determine the length of time before a Vessel is purged and put back into service. Currently each vessel (bed) is on-line for approximately 19 hours before regeneration. The volume of gas absorbed by the Willexa prior to a purge is dependent upon the volume of gas burned in engines 1 and 2 during that period. SCF = Rate (SCFM) x duration (Hours).

The Willexa has main four stages (cycles) consisting of multiple steps, that are generally described below:

- 3.1 Depress Cycle #1 1" line,  $\sim$ 100 SCFM initially for a few minutes. This cycle removes the landfill gas from the vessel sends it to the Flare and introduces O2 before the regen cycle starts.
- 3.2. Regen Cycle -12" line from Willexa to the Flare.
  - a. Starts at 300 SCFM and ramps up to  $\sim$ 2000 SCFM  $\sim$ 25 minutes.
  - b. Once at 2000 SCFM system then starts the heating cycle.
  - c. Heats media for an extended time  $\sim$  10-12 hours.
  - d. Heat Off, while blower continues to cool down media to 170 degrees or for approximately 6 hours.
  - e. Blower ramps down from ~2000 SCFM to 0 SCFM in a few minutes.
  - f. Shuts down blower.
- 3.3. Depress Cycle #2 O2 Purge -1" line, for  $\sim 30-45$  minutes at  $\sim 60$  SCFM.
- 3.4. Stabilization Cycle Shuts off valve to flare to stabilize methane.

The sampling of the Willexa Waste Gas (Step 4/5) (Regen Cycle 12-inch line) was performed by collecting two consecutive 1-hr integrated samples during the Regen desorption cycle. The Waste Gas from the 1" Depress Cycle (3.1) was sampled at Step 4/5 for approximately 10-15 minutes, for organics and sulfur compounds. The sampling port will be shared by the Valprobe used for the flow measurement. Rather than sample directly into the SILCO SUMMA, a bag sample was collected under pressure from the source, and this sample was transferred into the SILCO SUMMA immediately following the collection. The 1" line was sampled during the purge Process Step 4/5, and the 12" line was sampled for 1-hour during Process Steps 6/7/8 and 1-hour during Step 9.

The facility does not have flow meters for the Willexa purge system, on either the 1" or 12" lines. Blue Sky measured the flows using a Shortridge ADM 880C high accuracy digital manometer with a Velprobe. The 1" purge line is used in a short burst of a few minutes at the beginning and end of the Willexa Purge cycle. The Willexa purge essentially all occurs through the 12" line. A standard pitot cannot fit into the 1" or 12" line, whereas the Velprobe can, so the Velprobe was used for the 1" location. The transducer in the ADM was calibrated against an incline manometer for the range encountered in the 1" and 12" lines.

During the initial ramp up in part 3.2(a) above, to track the flow a Velprobe was used at the center of the 12" line. The center point has highest velocity and was exaggerate the flow slightly. The amount of bias was determined when the system is at full flow by traversing 8 points on each of two axis and the mid-point.

#### Instrumentation and Analytical procedures

The following continuous emissions analyzers were used:

Instrumentation	Parameter	Principle
TECO 42i	$NO_x$	Chemiluminescence
TECO 48C	CO	GFC/IR
TECO 48C	SO <sub>2</sub>	GFC/IR
Servomex 1440	CO <sub>2</sub>	IR
Servomex 1440	$O_2$	Paramagnetic

All calibration gases are EPA Protocol #1. The analyzer data recording system consists of Omega 3 channel strip chart recorders, which can be supported by a Data Acquisition System (DAS).

The instrument response was recorded on strip charts and DAS and some data is manually reduced. The averages were corrected for drift using BAAQMD & EPA Method 7E equations.

#### Comments: Limitation and Data Qualifications:

Blue Sky Environmental has reviewed this report for accuracy, and concluded that the test procedures were followed and accurately described and documented. The review included the following items:

Review of the general text Review of calculations Review of CEMS data Review of supporting documentation

The services described in this report were performed in a manner consistent with the generally accepted professional testing principles and practices. No other warranty, expressed or implied, is made. These services were performed in a manner consistent with our agreement with our client. The report is solely for the use and information of our client unless otherwise noted. Any reliance on this report by a third party is at such party's sole risk.

Opinions contained in this report pertain to conditions existing when services were performed and are intended only for the client, purposes, locations, time frames, and operating parameters indicated. We are not responsible for the impacts of any changes in environmental standards, practices, or regulations, subsequent to this, and do not warranty the accuracy of information supplied by others.

#### **SECTION 4. APPENDICES**

<b>A.</b>	Tabulated Results
В.	Calculations
C.	Laboratory Reports
D.	Field Data Sheets
E.	Strip Charts
F.	Process Information
G.	Calibration Certifications and Quality Assurance Record
н.	Sample Train Configuration and Stack Diagrams
I.	Related Correspondence (Source Test Plan)
J.	BAAQMD Permit

## A Tabulated Results

#### TABLE #1

#### Redwood Landfill Flare A-60A 1,585°F

RUN	RUN 1	RUN 2	RUN 3	AVERAGE	LIMITS
Test Date	7/25/19	7/25/19	7/25/19		
Test Time	0909-0949	1023-1059	1128-1207		1
Test Minutes	30	30	30		1
Standard Temp., °F	70	70	70		
Flare Temperature, °F	1,585	1,585	1,585	1,585	1
LFG Fuel Flow Rate, SCFM	1,423	1,430	1,432	1,428	]
Total Fuel Heat Input, MMBTU/Hr	41.1	41.0	41.1	41.1	]
Exhaust Flow Rate, DSCFM (Method 19)	21,486	22,018	20,370	21,291	
Oxygen, O <sub>2</sub> , %	14.5	14.7	14.1	14.4	]
Carbon Dioxide, CO <sub>2</sub> , %	5.5	5.4	5.8	5.6	
NOx, ppm	12.8	12.6	13.4	12.9	
NOx, ppm @ 15% O <sub>2</sub>	11.8	11.9	11.7	11.8	15
NOx, lbs/hr	1.96	1.97	1.95	1.96	1
NOx, lbs/MMBTU	0.05	0.05	0.05	0.05	0.06
CO, ppm	46.4	44.3	41.0	43.9	
CO, ppm @ 15% O <sub>2</sub>	42.8	41.9	35.8	40.2	82
CO, lbs/hr	4.33	4.23	3.63	4.06	]
CO, lbs/MMBTU	0.11	0.10	0.09	0.10	0.20
Total Reduced Sulfur as H <sub>2</sub> S in fuel, ppm	935	781	897	871	410
SO <sub>2</sub> , ppm	29.3	41.0	43.0	37.7	300
SO <sub>2</sub> , lbs/hr	6.25	8.97	8.70	7.98	]
SO <sub>2</sub> , lbs/MMBTU	0.15	0.22	0.21	0.19	1.69
THC, ppm (M18)	23.8	12.7	9.1	15.2	
THC, lbs/hr as CH <sub>4</sub>	1.3	0.7	0.5	0.8	]
CH <sub>4</sub> , ppm (M18)	20.6	8.1	3.9	10.9	]
CH <sub>4</sub> , lbs/hr	1.10	0.44	0.20	0.58	1
NMHC, ppm as CH <sub>4</sub> (M18)	3.1	4.6	5.2	4.3	1
NMHC, lbs/hr as CH <sub>4</sub>	0.17	0.25	0.26	0.23	]
NMHC, ppm @ 3% O <sub>2</sub> as CH <sub>4</sub>	8.7	13.2	13.8	11.9	30
LFG INLET NMOC ppm as CH <sub>4</sub> (25C)	1,115	1,180	1,146	1,147.0	OR
LFG INLET NMOC lbs/hr as CH <sub>4</sub>	3.9	4.2	4.1	4.1	OK
Total NMOC Removal Efficiency	95.8%	94.0%	93.5%	>94.4%	98
LFG INLET CH <sub>4</sub> ppm	475,000	471,000	472,000	472,667	
LFG INLET CH <sub>4</sub> lbs/hr	1,678	1,672	1,678	1,676	]
CH <sub>4</sub> Removal Efficiency	99.9%	100.0%	100.0%	99.97%	99
INLET THC (TOC) lbs/hr as CH <sub>4</sub>	1,681.9	1,676.2	1,681.9	1,680	
THC (TOC) Removal Efficiency	99.92%	99.96%	99.97%	99.952%	98

#### WHERE,

ppm = Parts Per Million Concentration

Lbs/hr = Pound Per Hour Emission Rate

Tstd. = Standard Temp. (°R = °F+460)

MW = Molecular Weight

DSCFM = Dry Standard Cubic Feet Per Minute

NOx = Oxides of Nitrogen as NO<sub>2</sub> (MW = 46)

CO = Carbon Monoxide (MW = 28)

 $\label{eq:TOC} {\rm TOC} = {\rm THC} = {\rm Total\ Organic\ Carbon\ as\ Methane\ including\ CH_4\ (MW=16)}$ 

THC = Total Hydrocarbons as Methane (MW = 16)

NMHC = Total Non-Methane Hydrocarbons as Methane (MW = 16)

 $SO_2$  = Sulfur Dioxide as  $SO_2$  (MW = 64.1)

#### CALCULATIONS,

PPM @  $15\% O_2 = ppm * 5.9 / (20.9 - \%O_2)$ 

PPM @  $3\% O_2 = ppm * 17.9 / (20.9 - \%O_2)$ 

Lbs/hr = ppm x 8.223 E-05 x DSCFM x MW / Tstd. °R

Lbs/MMBtu = (Lbs/hr)/(MMBtu/hr)

Lbs/day = Lbs/hr \* 24

 $Removal \; Efficiency = (inlet \; lbs/hr- \; outlet \; lbs/hr) \; / \; inlet \; lbs/hr$ 

 $<\!\!\text{Value}=2\% \text{ of Analyzer Range}$ 

#### TABLE #2

#### Redwood Landfill

#### Landfill Gas Characterization

RUN			A60(A) R1-LFG	A60(A) R2-LFG	A60(A) R3-LFG	LIMITS
Test Date			7/25/19	7/25/19	7/25/19	
Average TNMHC as Hexane		ppm	186	197	191	
Acrylonitrile		ppb	<172	<191	<172	300
Benzene		ppb	464	493	451	1,500
Benzyl Chloride	Chloromethylbenzene	ppb	<86	<96	<86	500
Carbon Tetrachloride		ppb	<86	<96	<86	200
Chlorobenzene		ppb	<86	<96	<86	200
Chloroethane		ppb	118	109	111	500
Chloroform		ppb	<86	<96	<86	200
1,1 Dichloroethane	Ethylidene Dichloride	ppb	<86	<96	<86	500
1,1 Dichloroethene	Vinylidene Chloride	ppb	<86	<96	<86	500
1,2 Dichloroethane	Ethylene Dichloride	ppb	91	<96	88	200
1,4 Dichlorobenzene		ppb	215	185	188	1,000
Ethylbenzene		ppb	2,340	2,240	2,190	4,000
Ethlyene Dibromide	1,2 Dibromoethane	ppb	<86	<96	<86	200
Hexane		ppb	301	303	308	2,000
Isopropyl Alcohol	IPA	ppb	2,510	2,720	2,640	10,000
Methyl Alcohol	Methanol	ppb	8,890	10,400	10,600	300,000
Methyl Ethyl Ketone	MEK	ppb	4,500	4,630	4,710	15,000
Methylene Chloride		ppb	<172	<191	<172	1,000
Methyl tert Butyl Ether	MTBE	ppb	<86	<96	<86	500
Perchloroethylene	Tetrachloroethylene	ppb	<86	<96	<86	1,000
Styrene		ppb	155	135	167	500
Toluene		ppb	4,330	4,320	4,210	20,000
1,1,1 Trichlororethane		ppb	<86	<96	<86	200
1,1,2,2 Tetrachloroethane		ppb	<86	<96	<86	200
Trichloroethylene	Trichloroethene	ppb	<86	<96	<86	500
Vinyl Chloride		ppb	106	108	100	2,000
Xylenes		ppb	4,900	4,720	4,610	20,000
Carbon Disulfide		ppm	< 0.086	< 0.096	< 0.086	
Carbonyl Sulfide		ppm	< 0.086	< 0.096	< 0.086	
Dimethyl Sulfide		ppm	0.138	0.187	0.176	
Ethyl Mercaptan		ppm	0.141	0.166	0.170	
Methyl Mercaptan		ppm	1.04	0.908	0.895	
Hydrogen Sulfide		ppm	927	773	889	
TRS as H2S		ppm	935	781	897	410

#### TABLE # 3

## Redwood Landfill 7/24/19

#### S-71 Willexa Waste Gas Characterization (Permit Condition 30)

RUN			Willexa 1" Run 1	Willexa 12" Run 1	Willexa 12" Run 2
SOURCE			1"	12"	12"
PROCESS STEP			4/5	6/7/8	9
Test Date			7/24/19	7/24/19	7/24/19
Test Time			1218-1229	1234-1355	1527-1627
GAS FLOW VELOCITY, FPM			2,564.3	1,192.5	2,050.3
GAS FLOW RATE, SCFM			14	937	1,611
$O_2$		%	1.6	19.8	21.2
$N_2$		%	12.9	73.9	78.7
$CO_2$		%	38.2	5.1	< 0.2
CH <sub>4</sub>		%	47.3%	1.1%	3.4%
TRS as H2S		ppm	0.241	< 0.084	< 0.086
NMOC (as Carbon)		ppm	321	319	604
NMOC (as Hexane)		ppm	54	53	101
Acrylonitrile		ppb	<162	<16.8	<17.2
Benzene		ppb	165	114	<8.6
Benzyl Chloride	Chloromethylbenzene	ppb	<81	<8.4	<8.6
Carbon Tetrachloride	<u></u>	ppb	<81	<8.4	<8.6
Chlorobenzene		ppb	<81	<8.4	<8.6
Chloroethane		ppb	101	26.4	<8.6
Chloroform		ppb	<81	<8.4	<8.6
1,1 Dichloroethane	Ethylidene Dichloride	ppb	<81	<8.4	<8.6
1,1 Dichloroethene	Vinylidene Chloride	ppb	<81	<8.4	<8.6
1,2 Dichloroethane	Ethylene Dichloride	ppb	<81	<8.4	<8.6
1,4 Dichlorobenzene	Edificite Bioliginae	ppb	<81	<8.4	<8.6
Ethylbenzene		ppb	<81	<8.4	<8.6
Ethlyene Dibromide	1,2 Dibromoethane	ppb	<81	<8.4	<8.6
Hexane	1,2 Dioromochane	ppb	239	101	<8.6
Isopropyl Alcohol	IPA	ppb	1,090	862	3,480
Methyl Alcohol	Methanol	ppb	2,150	1,610	8,770
Methyl Ethyl Ketone	MEK	ppb	1,860	1,450	7,150
Methylene Chloride	1141111	ppb	<162	<16.8	<17.2
Methyl tert Butyl Ether	MTBE	ppb	<81	<8.4	53.5
Perchloroethylene	Tetrachloroethylene	ppb	<81	<8.4	<8.6
Styrene	Tetracinoroccinyiene	ppb	<81	<8.4	<8.6
Toluene		ppb	<81	<8.4	<8.6
1.1.1 Trichlororethane		ppb	<81	<8.4	<8.6
1,1,2,2 Tetrachloroethane		ppb	<81	<8.4	<8.6
Trichloroethylene	Trichloroethene	ppb	<81	12.7	<8.6
Vinyl Chloride	THEMOTOGRAPH	ppb	89.4	16.9	<8.6
Xylenes		ppb	<243	<25.2	<25.8
Carbon Disulfide		ppm	0.159	< 0.084	< 0.086
Carbonyl Sulfide		ppm	<0.081	<0.084	<0.086
Dimethyl Sulfide		ppm	0.082	<0.084	<0.086
Ethyl Mercaptan		ppm	<0.082	<0.084	<0.086
Methyl Mercaptan			<0.081	<0.084	<0.086
Hydrogen Sulfide		ppm	<0.081	<0.084	<0.086
TRS as H2S		ppm	0.241	<0.084	<0.086
11W ad 1140		ppm	0.241	<u></u> ~0.064	~0.060

#### Redwood Landfill, Inc.

**BAAQMD Facility # A1179** 

### **Annual Compliance Emissions Test Report #20025**

Source Test for Landfill Gas Flare- Source A-51

#### Located at:

8950 Redwood Highway Novato, CA 94948

#### **Prepared For:**

SCS Engineers
Dave Bearden
3117 Fite Circle Suite 108
Sacramento, CA 95827
DBearden@scsengineers.com

#### For Submittal To:

**BAAQMD** 

Marco Hernandez & Gloria Espena Compliance & Enforcement Division 375 Beale Street, Suite 600 San Francisco, CA 94105 mhernandez@baaqmd.gov & gespena@baaqmd.gov

#### **Testing Performed On:**

January 22<sup>nd</sup>, 2020

#### Final Report Submitted On:

March 16th, 2020

#### Performed and Reported by:

Blue Sky Environmental, Inc. 624 San Gabriel Avenue Albany, CA 94706 blueskyenvironmental@yahoo.com (510) 525 1261 office (510) 508 3469 cell

#### **REVIEW AND CERTIFICATION**

#### Team Leader:

The work performed herein was conducted under my supervision, and I certify that: a) the details and results contained within this report are to the best of my knowledge an authentic and accurate representation of the test program; b) that the sampling and analytical procedures and data presented in the report is authentic and accurate: c) that all testing details and conclusions are accurate and valid, and: d) that the production rate and/or heat input rate during the source test are reported accurately.

If this report is submitted for Compliance purposes it should only be reproduced in its entirety. If there are any questions concerning this report, please contact me at (925) 338-4875.

Chuck Arrivas, QSTI

Project Manager

#### TABLE of CONTENTS

SECTION	N 1. INTRODUCTION	3
1.1.	SUMMARY	3
SECTION	N 2. SOURCE TEST PROGRAM	3
2.1.	Overview	4
2.2.	POLLUTANTS TESTED	4
2.3.	TEST DATE(S)	4
2.4.	SAMPLING AND OBSERVING PERSONNEL	4
2.5.	SOURCE/PROCESS DESCRIPTION	4
2.6.	SOURCE OPERATING CONDITIONS	4
SECTION	N 3. SAMPLING AND ANALYSIS PROCEDURES	5
3.1.	PORT LOCATION	5
3.2.	POINT DESCRIPTION/LABELING – PORTS/STACK	5
3.3.	SAMPLE TRAIN DESCRIPTION	5
3.4.	SAMPLING PROCEDURE DESCRIPTION	5
3.5.	INSTRUMENTATION AND ANALYTICAL PROCEDURES	5
3.6.	COMMENTS: LIMITATIONS AND DATA QUALIFICATIONS	9
SECTION	N 4. APPENDICES	10
A.	Tabulated Results	
B.	Calculations	
С.	Laboratory Reports	
	Field Data Sheets	
	Strip Charts	
	Process Information	
G.	Calibration Certifications and Quality Assurance Records	
Н.	Sample Train Configuration and Stack Diagrams	
I.	Related Correspondence (Source Test Plan)	
J.	Permit to Operate	

#### **SECTION 1. INTRODUCTION**

#### 1.1. Summary

Blue Sky Environmental, Inc was contracted to perform the annual compliance emissions testing on the A-51 Landfill Gas Flare at Redwood Landfill, 8950 Redwood Highway, Novato, California. Table 1.1 summarizes the source test information. Table 1.2 summarizes the results compared to the emission limits.

**Table 1.1 Source Test Information** 

Test Location:	Redwood Landfill, 8950 Redwood Highway, Novato, California 94948 Mailing Address PO Box 793, Novato, CA 94948				
Source Contact:	Alisha McCutcheon (415) 892-2851				
Source Tested:	Enclosed Landfill Gas Flare ( A-51)				
Source Test Dates:	January 22 <sup>nd</sup> , 2020				
<b>Test Objective:</b> Determine Compliance with Regulation 8, Rule 34 and Title A1179, Condition 19867					
Test Performed By:	Blue Sky Environmental, Inc. 624 San Gabriel Ave., Albany, CA 94706 Guy Worthington (510) 508 3469				
Test Parameters:	Landfill Gas O2, N2, CO2, BTU, THC, CH4, NMOC, HHV, F-Factor, Sulfur & VOC Species, Volumetric Flow Rate Flare Emissions THC, CH4, NMOC, NOx, CO, O2, SO2, Volumetric Flow Rate, Temperature.				

Table 1.2. Compliance Summary

<u>A51 @ 1,419°F</u>	Average Test	Permit Limit	Compliance Status
NOx, lbs/MMBTU	0.057	0.06	In Compliance
NOx, ppm @15% O <sub>2</sub>	14.2	15	In Compliance
CO, lbs/MMBTU	0.020	0.20	In Compliance
CO, ppm @15% O <sub>2</sub>	8.2	82	In Compliance
NMOC, (ppmvd @ 3% O <sub>2</sub> as CH <sub>4</sub> )	3.3	30	In Compliance
CH <sub>4</sub> Destruction Efficiency, %	99.993	99	In Compliance
Total Reduced Sulfur as H <sub>2</sub> S in fuel, ppm	934	410	Exceeds Limits <sup>1</sup>
SO <sub>2</sub> , ppm	58.57	300	In Compliance
SO <sub>2</sub> , lbs/MMBTU	0.07	1.69	In Compliance

<sup>&</sup>lt;sup>1</sup> On October 6<sup>th</sup>, 2016 Redwood Landfill proposed a permit modification to increase the peak limit. This modification is still under review by BAAQMD. Per the November 2016 Compliance Agreement between Redwood Landfill and BAAQMD enforcement actions are not expected if the Agreement is complied with.

#### **SECTION 2. SOURCE TEST PROGRAM**

#### 2.1. Overview

This annual performance test was conducted to demonstrate that the A-51 landfill gas flare is operating in accordance with the Bay Area Air Quality Management District (BAAQMD) Title V Permit A1179 and Regulation 8 Rule 34.

#### 2.2. Pollutants Tested

The following CARB, EPA and ASTM sampling and analytical methods were used:

EPA Method 1 Sample and Traverse Point Determination EPA Method 3A O2 and CO2, Stack Gas Molecular Weight

EPA 4 part 4.16 Moisture Calculated

EPA 7E NOX Emissions & NO2 Converter Efficiency

EPA 10 CO Emissions EPA Method 18 CH4 Emissions

EPA Method 19 Calculation of Stack Gas Flow Rate
EPA 19 Flow Rate Calculation, DSCFM
EPA 25C LFG Gas analysis for NMOC by GC

EPA TO-15 VOC Species

ASTM 1945 LFG Gas analysis for BTU and F-Factor

ASTM D-5504 Sulfur Species, H<sub>2</sub>S and TRS

#### 2.3. Test Date(s)

Testing was conducted on January 22<sup>nd</sup>, 2020

#### 2.4. Sampling and Observing Personnel

Chuck Arrivas and Kurt Mussatti representing Blue Sky Environmental, Inc, performed testing.

Sean Johnson and Mike Chan of Waste Management and Dave Bearden of SCS Engineers were present to operate and oversee the Flare operation and assist in coordinating testing and the collection of process data during testing, and provided the Yokogawa Flare data.

The BAAQMD was notified of the test in a plan submitted by SCS Engineers on January 6<sup>th</sup>, 2020. A Source Test Protocol acknowledgement was requested and received by SCS Engineers (NST # 5782), No representatives from the BAAQMD were present to witness testing. A copy of the source test protocol and confirmation email from BAAQMD can be found in Appendix I.

#### 2.5. Source/Process Description

The enclosed landfill gas flare A-51 consists of a 90 million British Thermal Units per hour (MMBtu/hr) multiple nozzle burner manufactured by Perennial Energy. The flare shell is approximately 45 feet high and has an approximately 136 inch inside diameter.

#### 2.6. Source Operating Conditions

The flare operating temperature and the landfill gas flow rate records are contained in Appendix-F. There is no condensate injection.

The A–51 flare was operated at approximately 1,419 Degrees Fahrenheit (°F). The average landfill gas flow rate was 1,496 Standard Cubic Feet Per Minute (SCFM).

The landfill gas methane content ranged between 47.8 and 49.3 percent (%).

#### SECTION 3. SAMPLING AND ANALYSIS PROCEDURES

#### 3.1. Port location

The A-51 Flare sampling was conducted in the 136 inch diameter Inside Diameter (ID) stack, via ports approximately 35 feet above grade, accessed by a 40 foot boom-lift. Two of the four, 4-inch flange ports are available ~4 stack diameters downstream from the burners and ~1 stack diameter upstream from the exit.

#### 3.2. Point description/Labeling – ports/stack

Blue Sky Environmental conducted 16 point traverses and found Oxygen (O<sub>2</sub>) and other gases were stratified at 10 percent (%) or more, therefore subsequent CEM sampling runs were traversing all 16 points.

The traverse points for the 136 inch diameter exhaust stack with 4 inch ports were 4.35, 14.28, 26.38, 43.9, 92.07, 109.6, 121.7 and 131.6 inches

#### 3.3. Sample train description

Sampling system diagrams are included in the Appendix H. Additional descriptive information is included in the following section.

#### 3.4. Sampling procedure description

Three, runs of at least 32-minutes were performed, completely traversing the stack on two diameters during each test run of the flare.

#### 3.5. Instrumentation and Analytical Procedures

Sampling & Traverse Points Selection by EPA Method 1. This method is used to determine the duct or stack area and appropriate traverse points that represent equal areas of the duct for sampling and velocity measurements.

Stack Gas Molecular Weight by EPA Method 3/3A. This method is used to determine the molecular weight of the stack gas. Measurements of gas constituents %O<sub>2</sub> and %CO<sub>2</sub> were obtained from the CEMS system.

**EPA Method 19 (gas)** was used to determine stack gas volumetric flow rates using oxygen based F-factors. F-factors are ratios of combustion gas volumes generated from heat input. The heating value of the fuel in Btu per cubic foot is determined from analysis of the fuel gas samples using ASTM D1946/3588 gas chromatography analytical procedures. Total fuel consumption was measured by CARB Method 1, 2, 3 and 4. The total cubic feet per hour of fuel multiplied times the Btu/cf provides million Btu per hour (MMBtu) heat input. The heat input in MMBtu/hr is multiplied by the F-factor (DSCF/MMBtu) and adjusted for the measured oxygen content of the source to determine volumetric flow rate. The flow rates were used to determine emission rates.

Stack Gas Moisture by EPA Method 4-16.4 is an acceptable alternative to EPA Method 4 for the determination of moisture using F-factors. In this case the mole fraction of the moisture in the ambient air is calculated using equations in EPA Method 4-16.4 from 1) the measured ambient relative humidity, ambient temperature and barometric pressure, 2) the mole fraction from free water in the fuel, calculated from the moisture % in the fuel which is determined by the analytical lab to be the balance after all the major gaseous components have been summed, and 3) the mole fraction from the hydrogen in the fuel. To determine the moisture in the fuel, the raw fuel analysis before normalization to 100% is referenced.

EPA Method 3A (O<sub>2</sub>, CO<sub>2</sub>), 10 (CO) and 7E (NO<sub>x</sub>) are continuous monitoring techniques using instrumental analyzers. Sampling is performed by extracting exhaust flue gas from the stack, conditioning the sample and analyzing it by continuous monitoring gas analyzers in a CEM test van. The sampling system consists of a stainless steel sample probe, Teflon sample line, glass-fiber particulate filter, glass moisture-knockout condensers in ice, followed by thermoelectric coolers (optional), Teflon sample transfer tubing, diaphragm pump and a stainless steel/Teflon manifold and flow control/delivery system. A constant sample and calibration gas supply pressure of 5 PSI was provided to each analyzer to avoid pressure variable response differences. The entire sampling system was leak checked prior to and at the end of the sampling program.

The sampling and analytical system (for EPA Methods) was checked for linearity with zero, mid (40-60%) and high span (80-100%) calibrations, and is checked for system bias at the beginning and end of each run. System bias is determined by introducing calibration gas to the probe and pulling it through the entire sampling system. Individual test run calibrations usually use the calibration gas that most closely matches the stack gas effluent. Along with the Sampling System Bias, the Zero and Calibration Drift values were determined for each test. Methods 3A, 7E and 10 all defer to EPA Method 7E for the calculations of effluent concentration, Span, Calibration Gas, Analyzer Calibration Error (Linearity), Sampling System Bias, Zero Drift, Calibration Drift and Response Time. In addition, the NOx analyzer NO2 to NO conversion efficiency check defers to EPA Method 20 section 5.6 for the criteria and procedure.

All calibration gases are EPA Protocol #1. The analyzer data recording system consists of a Honeywell DPR3000 strip chart recorder supported by a Data Acquisition System (DAS).

**EPA Method 25C/18: Sampling for Total Hydrocarbons, Methane and Non-Methane Hydrocarbons.** EPA Method 25A/18 (FID/GC Method) employs a heated TECO 55C FID with GC column, heated Teflon sample gas transfer lines to provide a continuous sample to the heated FID/GC Hydrocarbon Analyzer. Heated lines were used if necessary to avoid moisture or hydrocarbon condensation. Methane is determined by the calibrated GC method in the TECO 55C NMHC/CH<sub>4</sub>/THC Analyzer. Calibration gases are selected to fall within 25-35%, 45-55% and 80-90% of Range for Methane, Total Hydrocarbon and Non-Methane Hydrocarbons.

Calibrations are performed through the probe and entire sample system. The system linearity check was performed prior to testing and during testing and calibration drift checks were performed after every run. All data was corrected according to EPA Method 25A. In some cases where the drift exceeded 3%, the system was re-calibrated and the average was calculated with and without the recalibration values. Both sets of values are reported in the calculation section of the appendices, but only the highest values of the two methods were used in the Tabulated results.

**ASTM D1945/3588** gas chromotography analytical procedures. Total fuel consumption for each source is monitored by a dedicated fuel gas meter. The total cubic feet per hour of fuel multiplied times the Btu/cf provides million Btu per hour (MMBtu) heat input. The heat input in MMBtu/hr is multiplied by the F-factor (DSCF/MMBtu) and adjusted for the measured oxygen content of the source to determine volumetric flow rate. The flow rates were used to determine emission rates.

ASTM Method 5504: Sampling for H<sub>2</sub>S and Sulfur species in fuels. Sampling consisted of pre-evacuated 6-Liter SILCO SUMMA canisters with pre-set flow controllers set to integrate over the desired test duration. The SILCO canisters have a silanized (glass) lining that permits longer holding times (up to 72 hours) for reactive sulfur compounds. The flow controller, valve and canister are designed so that no sample contacts stainless steel components that can remove hydrogen sulfide. The flow controllers consisted of capillary orifice tubing designed to sample for pre-set durations such as 1-hr, 2-hrs and 4-hrs. The samples were analyzed for 20 sulfur compounds by ASTM Method D-5504 GC/SCD (gas chromatography/sulfur chemiluminescent detector).

**TO-15** is the analytical strategy for Compendium Method TO-15 involves using a high resolution gas chromatograph (GC) coupled to a mass spectrometer. Mass spectra for individual peaks in the total ion chromatogram are examined with respect to the fragmentation pattern of ions corresponding to various VOCs including the intensity of primary and secondary ions. The fragmentation pattern is compared with stored spectra taken under similar conditions, in order to identify the compound. For any given compound, the intensity of the primary fragment is compared with the system response to the primary fragment for known amounts of the compound. This establishes the compound concentration that exists in the sample.

#### System Performance Criteria

Instrument Linearity $\leq 2\%$  Full Scale (complied)Instrument Bias $\leq 5\%$  Full Scale (complied)System Response Time $\leq \pm 2$  minutes (complied)

 $NO_X$  Converter Efficiency (EPA 7E)  $\geq 90\%$  (complied)

Instrument Zero Drift≤± 3% Full Scale (complied)Instrument Span Drift≤± 3% Full Scale (complied)

Concurrent with the exhaust sampling, Blue Sky collected four 6-liter Summa canister samples of the LFG for analysis. The samples were collected using Teflon tubing connections, and the tubing and the summa canisters were filled and purged prior to sampling. The gas sample was controlled with a rotameter to collect a 30-minute integrated sample. All the samples were analyzed for NMOC, HHV, F-Factor, Fixed Gases. One sample A51 Header was analyzed for Sulfur Species (incl. H<sub>2</sub>S and TRS) and VOC Compounds. Three additional samples were collected and analyzed for EPA Method 18.

The inlet volumetric Flow Rate and Flare Temperature was continuously measured and recorded by the facility Yokogawa monitors.

#### Instrumentation and Analytical procedures

The following continuous emissions analyzers were used:

Instrumentation	Parameter	Principle
TECO 42C	$NO_X$	Chemiluminescence
TECO 48C	CO	GFC/IR
Ratfisch RS-55	THC	FID
Fuji ZRH	CO <sub>2</sub>	IR
Servomex 1440	$O_2$	Paramagnetic

All calibration gases are EPA Protocol #1. The analyzer data recording system consists of DPR or Omega 3 channel strip chart recorders, which can be supported by a Data Acquisition System (DAS).

The instrument response was recorded on strip charts and DAS and some data is manually reduced. The averages were corrected for drift using EPA Method 7E equations.

#### 3.6. Comments: Limitations and Data Qualifications

The measured emissions meet the Permit required limits. There is a large variation in the TNMOC Runs #2 & #3 compared to Run #1. Seems to be from the C6+ fraction..

Blue Sky Environmental has reviewed this report for accuracy, and concluded that the test procedures were followed and accurately described and documented. The review included the following items:

Review of the general text Review of calculations Review of CEMS data Review of supporting documentation

The services described in this report were performed in a manner consistent with the generally accepted professional testing principles and practices. No other warranty, expressed or implied, is made. These services were performed in a manner consistent with our agreement with our client. The report is solely for the use and information of our client unless otherwise noted. Any reliance on this report by a third party is at such party's sole risk.

Opinions contained in this report pertain to conditions existing when services were performed and are intended only for the client, purposes, locations, time frames, and operating parameters indicated. We are not responsible for the impacts of any changes in environmental standards, practices, or regulations, subsequent to this, and do not warranty the accuracy of information supplied by others.

#### **SECTION 4. APPENDICES**

<b>A.</b>	Tabulated Results
В.	Calculations
C.	Laboratory Reports
D.	Field Data Sheets
E.	Strip Charts
F.	Process Information
G.	Calibration Certifications and Quality Assurance Record
н.	Sample Train Configuration and Stack Diagrams
I.	Related Correspondence (Source Test Plan)
J.	Permit to Operate

# A Tabulated Results

#### TABLE #1

#### Redwood Landfill Flare A-51 1,419°F

RUN	1	2	3	AVERAGE	LIMITS
Test Date	1/22/20	1/22/20	1/22/20		
Test Time	0853-0928	0950-1025	1049-1125		
Standard Temp., °F	70	70	70		
Flare Temperature, °F Average	1,420	1,417	1,419	1,419	
Fuel Flow Rate, SCFM	1,496	1,495	1,496	1,496	
Fuel Heat Input, MMBTU/Hr	43.5	44.7	44.8	44.3	
Exhaust Flow Rate, DSCFM (Method 19)	23,289	23,345	24,917	23,851	
Oxygen, O <sub>2</sub> , %	14.71	14.56	14.93	14.73	
Carbon Dioxide, CO <sub>2</sub> , %	4.89	5.15	4.85	4.96	
Water Vapor, H <sub>2</sub> O, % M4.16	4.06	4.23	4.14	4.14	
NOx, ppm	14.7	15.5	14.4	14.9	
NOx, ppm @ 15% O <sub>2</sub>	14.0	14.5	14.2	14.2	15
NOx, lbs/hr	2.44	2.59	2.56	2.53	
NOx, lbs/MMBTU	0.056	0.058	0.057	0.057	0.06
CO, ppm	9.1	7.4	9.2	8.6	
CO, ppm @ 15% O <sub>2</sub>	8.7	6.9	9.1	8.2	82
CO, lbs/hr	0.92	0.75	1.00	0.89	
CO, lbs/MMBTU	0.021	0.017	0.022	0.020	0.20
TRS as H <sub>2</sub> S, ppm in Fuel				934	410
SO <sub>2</sub> , ppm	16.81	16.68	7.37	58.57	300
SO2, ppm @ 15% O <sub>2</sub>	16.0	15.5	7.3	12.9	
SO2, ppm @ 3% O <sub>2</sub>	48.6	47.1	22.1	39.3	
SO2, lbs/hr	3.89	3.87	1.83	3.20	
SO2, lbs/MMBTU	0.09	0.09	0.04	0.07	1.69
THC, ppm (25A) wet	<2.0	2.73	5.45	3.39	
THC, ppm dry	<2.08	2.85	5.69	3.54	
THC, lbs/hr as CH <sub>4</sub>	< 0.121	0.165	0.352	0.212	
CH <sub>4</sub> , ppm	1.3	1.9	3.6	2.3	
CH <sub>4</sub> , lbs/hr	0.075	0.110	0.223	0.136	
TNMHC, ppm as CH <sub>4</sub>	0.7	0.8	1.9	1.13	
TNMHC, lbs/hr as CH <sub>4</sub>	0.040	0.048	0.114	0.068	
TNMHC, ppm as Hexane (C <sub>6</sub> H <sub>14</sub> ) @ 3% O <sub>2</sub>	0.34	0.39	0.93	0.55	360
TNMHC, ppm @ 3% O <sub>2</sub> as CH <sub>4</sub>	2.0	2.3	5.6	3.3	30
INLET TNMOC (Method 25C), ppmC	757	1,213	2,400	1,457	
INLET NMOC, lbs/hr as CH <sub>4</sub>	2.8	4.5	8.9	5.4	or
NMOC Removal Efficiency	98.56%	98.93%	98.72%	98.74%	98
INLET CH <sub>4</sub> , ppm	478,000	492,000	493,000	487,667	
INLET CH <sub>4</sub> , lbs/hr	1,775.1	1,825.9	1,830.9	1,811	
CH <sub>4</sub> Removal Efficiency	>99.996%	>99.994%	>99.988%	>99.993%	99
INLET THC (TOC), ppm as CH <sub>4</sub>	478,757	493,213	495,400	489,123	
INLET THC (TOC), lbs/hr as CH <sub>4</sub>	1,778	1,830	1,840	1,816	
THC (TOC) Removal Efficiency	99.993%	99.991%	99.981%	99.988%	98

< Value = 2% of Analyzer Range

#### WHERE,

ppm = Parts Per Million Concentration

Lbs/hr = Pound Per Hour Emission Rate

Tstd. = Standard Temp. (°R = °F+460)

MW = Molecular Weight

 $DSCFM = Dry \ Standard \ Cubic \ Feet \ Per \ Minute$ 

NOx = Oxides of Nitrogen as NO<sub>2</sub> (MW = 46)

CO = Carbon Monoxide (MW = 28)

TOC = THC = Total Organic Carbon as Methane including CH<sub>4</sub> (MW = 16)

THC = Total Hydrocarbons as Methane (MW = 16)

NMOC = Total Non-Methane Organic Carbon as Methane (MW = 16)

 $SO_2$  = Sulfur Dioxide as  $SO_2$  (MW = 64.1)

#### CALCULATIONS,

PPM @ 15%  $O_2 = ppm * 5.9 / (20.9 - \%O_2)$ 

PPM @  $3\% O_2 = ppm * 17.9 / (20.9 - \%O_2)$ 

Lbs/hr = ppm x 8.223 E-05 x DSCFM x MW / Tstd. °R

Lbs/day = Lbs/hr \* 24

 $Removal\ Efficiency = (inlet\ lbs/hr-\ outlet\ lbs/hr)\ /\ inlet\ lbs/hr$ 

#### TABLE # 2

#### Redwood Landfill

#### Landfill Gas Characterization

RUN			RLI	LIMITS
Test Date			1/22/20	
Acrylonitrile		17 ppb	<16.3	300
Benzene		35 ppb	459	1,500
Benzyl Chloride	Chloromethylbenzene	35 ppb	<8.2	500
Carbon Tetrachloride		36 ppb	<8.2	200
Chlorobenzene		53 ppb	<8.2	200
Chloroethane		10 ppb	91.6	500
Chloroform		30 ppb	<8.2	200
1,1 Dichloroethane	Ethylidene Dichloride	24 ppb	10.4	500
1,1 Dichloroethene	Vinylidene Chloride	18 ppb	<8.2	500
1,2 Dichloroethane	Ethylene Dichloride	18 ppb	89.0	200
1,4 Dichlorobenzene		65 ppb	<8.2	1,000
Ethylbenzene		54 ppb	778	4,000
Ethlyene Dibromide	1,2 Dibromoethane	51 ppb	<8.2	200
Hexane		29 ppb	339	2,000
Isopropyl Alcohol	IPA	16 ppb	3,840	10,000
Methyl Alcohol	Methanol	16 ppb	8,380	300,000
Methyl Ethyl Ketone (MEK)	2-Butanone	27 ppb	5,250	15,000
Methylene Chloride		19 ppb	32.4	1,000
Methyl tert Butyl Ether	MTBE	ppb	8.53	500
Perchloroethylene	Tetrachloroethylene	52 <sub>ppb</sub>	46.2	1,000
Styrene		ppb	29.3	500
Toluene		48 ppb	3,400	20,000
1,1,1 Trichlororethane		34 ppb	<8.2	200
1,1,2,2 Tetrachloroethane		58 ppb	<8.2	200
Trichloroethylene	Trichloroethene	41 ppb	55.0	500
Vinyl Chloride		6 ppb	90.5	2,000
Xylenes		5+9 ppb	1,416	20,000
Carbon Disulfide		ppm	< 0.082	
Carbonyl Sulfide		ppm	< 0.082	
Dimethyl Sulfide		ppm	0.326	
Ethyl Mercaptan		ppm	0.165	
Methyl Mercaptan		ppm	1.12	
Hydrogen Sulfide		ppm	928	
TRS as H2S		ppm	934	410

## **APPENDIX O**

# S-55 STATIC PRESSURE PERFORMANCE TEST (LEAK TEST)



#### EPIC Environmental Compliance Systems, Inc.

39120 Argonaut Way # 643, Fremont, CA 94538
www:epiccompliance.com ■ contact@epiccompliance.com
■ 888-700-EPIC ■ Fax 415-296-6110 ■

## Letter of Transmittal

Date:	4/3/2020
Date.	4/ J/ ZUZU

To:	Bay	Area	AQI	MD

gdfresults@baaqmd.gov

Attn: Hiroshi Doi

Re: Testing Results Redwood Landfill 8950 Redwood Hwy Novato, CA 94945

Inspector Doi,

Enclosed is a copy of the test results from testing performed at subject site on April 2<sup>nd</sup>, 2020.

Test	Passed	Failed	Notes
TP-206.3	✓	_	

If you have any questions or need any further information please feel free to contact us at 1-888-700-EPIC.

Thank you,

EPIC Environmental Compliance Systems, Inc.

### Form 1

## **Summary of Source Test Data TP206.3**

	Static Pres	ssure	Performa	ance Test			
GDF Name and Address:			PHASE II SYSTEM TYPE (Check One)				
Redwood Lan	dfill	Ва	Balance ✓				
8950 Redwoo	d Hwy						
Novato, CA 9	4945	Va	ac Assist				
GDF Represent	tative and Title:	Ot	her				
	Alisha McCutcheon						
GDF Phone #	415-408-9055						
GDF#	8573	Ma	anufacturer:				
<b>3</b> Β1 #		Pe	ermit Conditi	ons:			
Manifolded? _	No				1		
	TANK #:		1	2	3	4	
1. Product Grad	le	87					
2. Actual Tank (	Capacity, gallons	1000					
3. Gasoline Vol	ume	720					
4. Ullage, gallor		280					
(ullage = cap 5. Initial Pressu	acity-volume)						
(inches water		2	2.00				
6. Pressure Aft	er 1 Minute	1	.99				
7. Pressure Aft	er 2 Minutes	1	.97				
8. Pressure Aft	er 3 Minutes	1.96					
9. Pressure After	er 4 Minutes	1	.94				
10. Final Pressu	ure After 5 Minutes	1.92					
11. Allowable Final Pressure		0.94					
Pass/Fail		Pass					
Test Conducted by:			Test Company:				
Brian Dunahay			EDIC En	vironmonto	l Compliance S	vetome Inc	
3/4/			EPIC Environmental Compliance Systems, Inc. 39120 Argonaut Way # 643 Fremont, CA 94538				
Date of Test: 4/2/2020							

California Air Resources Board

May 2, 2008

## **APPENDIX P**

# ROLLING QUARTERLY LFG INPUT AND CO AND SO2 EMISSIONS

## **QUARTERLY LFG Input to all LFG-Fired Combustion Equipment** WM - REDWOOD LANDFILL, Novato, CA

Quarter	Month	Total LFG Throughput (MMscf)				Monthly	Quarterly Total	Rolling 4-Qtr
		A-51	A-60	S-64	S-65	Total (MMscf)	(MMscf)	Total (MMscf)
2019 Q2	April	0.76	75.06	29.29	29.03	134.13	396.54	1,449.30
	May	0.35	72.81	30.97	30.56	134.69		
	June	1.88	74.47	24.11	27.26	127.71		
	July	0.00	75.12	30.16	29.21	134.50	399.26	1,498.08
2019 Q3	August	12.26	81.35	19.16	23.82	136.60		
	September	4.36	71.95	25.14	26.71	128.16		
	October	3.31	62.92	22.23	23.22	111.68	339.62	1,498.94
2019 Q4	November	0.09	64.70	24.89	26.46	116.14		
	December	9.20	72.08	16.95	13.56	111.80		
2020 Q1	January	1.37	70.96	26.50	26.06	124.89	363.30	1,498.72
	February	0.00	69.14	25.07	25.31	119.51		
	March	0.00	64.00	27.34	27.56	118.90		
	April	0.21	64.45	20.94	26.19	111.79	111.79	1,213.97
2020 Q2	May					0.00		
	June					0.00		

Pursuant to Title V Permit Condition Number 25634 Part 1, the total landfill gas throughput to the landfill gas combustion equipment at Plant #1179 shall not exceed 2,625 million scf of landfill gas during any consecutive rolling 4-quarter period.

S-66, and S-67 have not been installed.

## QUARTERLY CO EMISSIONS From All LFG-Fired Combustion Equipment WM - REDWOOD LANDFILL, Novato, CA

Quarter	Month	Tota	al CO Emi	issions (to	ons)	Monthly Total (tons)	Quarterly Total (tons)	Rolling 4-Qtr Total (tons)
		A-51	A-60	S-64	S-65			
2019 Q2	April	0.01	3.57	0.65	0.31	4.54	13.41	42.65
	May	0.00	3.46	0.69	0.33	4.48		
	June	0.01	3.54	0.54	0.30	4.39		
	July	0.00	3.57	0.67	0.32	4.56	12.20	48.26
2019 Q3	August	0.10	3.87	0.43	0.26	4.65		
	September	0.03	1.77	0.58	0.61	2.99		
	October	0.03	1.51	0.50	0.52	2.56	7.75	45.30
2019 Q4	November	0.00	1.55	0.56	0.59	2.71		
	December	0.07	1.73	0.38	0.30	2.48		
	January	0.01	1.70	0.60	0.59	2.89	8.45	41.80
2020 Q1	February	0.00	1.66	0.57	0.57	2.79		
	March	0.00	1.53	0.62	0.62	2.77		
	April	0.00	1.54	0.47	0.59	2.60	2.60	31.00
2020 Q2	May					0.00		
	June					0.00		

Pursuant to Title V Permit Condition Number 25634 Part 2, the total CO emissions from all landfill gas combustion equipment at Plant #1179 shall not exceed 237.5 tons during any consecutive rolling 4-quarter period. S-66, and S-67 have not been installed.

## QUARTERLY SO<sub>2</sub> EMISSIONS From All LFG-Fired Combustion Equipment WM - REDWOOD LANDFILL, Novato, CA

Quarter	Month	Tota	al SO <sub>2</sub> Em	issions (t	ons)	Monthly Total (tons)	Quarterly Total	Rolling 4-Qtr
		A-51	A-60	S-64	S-65		(tons)	Total (tons)
2019 Q2	April	0.08	7.53	0.02	0.03	7.65	22.73	60.44
	May	0.03	7.30	0.02	0.03	7.39		
	June	0.19	7.47	0.02	0.02	7.70		
2019 Q3	July	0.00	5.94	0.02	0.03	5.99	19.49	68.39
	August	0.97	6.43	0.01	0.02	7.44		
	September	0.34	5.69	0.02	0.02	6.07		
	October	0.22	4.13	0.02	0.02	4.39	14.04	71.96
2019 Q4	November	0.01	4.25	0.02	0.02	4.30		
	December	0.60	4.73	0.01	0.01	5.36		
2020 Q1	January	0.09	4.51	0.02	0.02	4.64	13.20	69.47
	February	0.00	4.40	0.02	0.02	4.44		
	March	0.00	4.07	0.02	0.02	4.11		
2020 Q2	April	TBD	TBD	0.02	0.02	TBD	TBD	TBD
	May					0.00		
	June					0.00		

Pursuant to Title V Permit Condition Number 25634 Part 3, the total SO2 emissions from all landfill gas combustion equipment at Plant #1179 shall not exceed 99 tons during any consecutive rolling 4-quarter period.

TBD=To Be Determined.

SO2 emissions from flares are updated at the end of each quarter when the quarterly average emission factor is calculated.