



## PUBLIC WORKS DEPARTMENT

### PUBLIC SERVICES DIVISION

231 North Whisman Road, P.O. Box 7540

Mountain View, CA 94039-7540

650-903-6329 | [MountainView.gov](http://MountainView.gov)

January 18, 2023

**TV Tracking # 997 (Semi-Annual)**

Mr. Jeffrey Gove, Director  
Compliance and Enforcement  
Bay Area Air Quality Management District  
375 Beale Street, Suite 600  
San Francisco, CA 94105  
Via Email: [compliance@baaqmd.gov](mailto:compliance@baaqmd.gov)

**1.  RECEIVED IN  
ENFORCEMENT: 01/18/2023**

TITLE V, START-UP, SHUTDOWN, MALFUNCTION PLAN AND BAY AREA AIR QUALITY MANAGEMENT DISTRICT RULE 8-34, SEMIANNUAL MONITORING REPORTS FOR THE SHORELINE LANDFILL, MOUNTAIN VIEW, CALIFORNIA (FACILITY NO. A2740)

Dear Mr. Gove:

Enclosed are the Title V, Startup, Shutdown, Malfunction (SSM) Plan and Bay Area Air Quality Management District (BAAQMD) Regulation 8, Rule 34, Semiannual Monitoring Reports for the Shoreline Landfill, Mountain View, California (Facility No. A2740). These reports are for the period from July 1, 2022 through December 31, 2022 and pertain to the landfill gas (LFG) collection and control system (GCCS) operated at the landfill. The Title V report also addresses the diesel-powered emergency generators located at the landfill site.

#### Title V Report

The Title V report meets the requirements specified in the Title V permit, BAAQMD guidance on Title V report submittals and Regulation 2, Rule 6. The report includes the signed certification by the Responsible Official of the City of Mountain View.

#### SSM Plan Report

The City of Mountain View revised and implemented the revised SSM Plan on February 18, 2009, as required by 40 CFR Part 63, Subpart AAAA, the Maximum Achievable Control Technology standards for landfills. This section includes SSM reports for the landfill gas collection and emission control system operated at the landfill. The SSM reports for microturbines are not required pursuant to Title V permit condition revisions dated March 9, 2017. All SSM activities during this reporting period were consistent with the SSM Plan with no deviations.

#### Rule 8-34 Report

The Rule 8-34 report includes various testing, monitoring, maintenance, start-up, shutdown and malfunction, and repair records as required by BAAQMD, Rule 8-34-411. This report also satisfies

the requirements under the New Source Performance Standards (NSPS) for municipal solid waste landfills (40 CFR Part 60, Subpart WWW) and Emission Guidelines (EG, 40 CFR Part 60, Subpart CC), including 40 CFR 60.757(f).

The Rule 8-34 report is organized into the following sections:

- Section I—Source Performance Test Reports. The flare station and microturbine source performance tests were conducted on February 1 and February 2, 2022. The source performance test report was included in the first semiannual reporting period for 2022.
- Section II—Landfill Gas Collection System Downtime. This section includes landfill gas collection system downtime and explanations of repairs related to the downtime. Gas collection system shutdowns and records are summarized in this section.
- Section III—Emission Control System Downtime. This section includes emission control system shutdowns and reasons for each shutdown. Flare station shutdowns and records are summarized in this section.
- Section IV—Quarterly Landfill Gas Emission Monitoring. This section includes quarterly landfill surface emission monitoring and component checks performed by City staff. A Century OVA 108 portable organic vapor analyzer (OVA) was used to monitor emissions. The OVA was calibrated and tested prior to each use. All component leaks and surface emissions detected during quarterly monitoring were recorded and were below the allowable limits or were below the allowable limits after repair. Component leaks and monitoring records are summarized in this section.
- Section V—Monthly Landfill Gas Wellhead Monitoring. This section includes wellhead monitoring performed by City staff. The Envision ENV200 gas analyzers were used to measure well performance in the field. The instruments were calibrated and tested prior to each use.
- Section VI—Monthly Landfill Gas Wellhead Repairs for Exceedances. This section includes wellhead problem investigations, monitoring, and repairs performed in response to wellhead exceedances. However, the oxygen concentrations measured at the main header during monthly monitoring of exempted wellheads are included. A summary of field monitoring results and records is enclosed.
- Section VII—Continuous Temperature- and Flow-Monitoring Records. This section includes continuous temperature and flow monitoring charts for the flare station.

Mr. Jeffrey Gove

January 18, 2023

Page 3

- Section VIII—Landfill Gas Flow Meter Calibration. The flow meter calibration certificates for the flow meters located at the flare station was included in the first semiannual reporting period for 2022.

I believe this report is true, accurate, and complete. If any further information is required or you have any questions, please call Tina Tseng, Principal Civil Engineer, at 650-903-6187 or me at 650-903-6140.

Sincerely,



Lisa Au  
Assistant Public Works Director

Enclosures:

1. Title V Semiannual Monitoring Report (with Certification Statement)
2. Start-Up, Shutdown Malfunction Plan Semiannual Report
3. BAAQMD Rule 8-34 Report

cc: Mr. Raymond Salalila, [RSalalila@baaqmd.gov](mailto:RSalalila@baaqmd.gov)

PWD, SLCM, PCE—Tseng, AE—Sharma, F/c



**TITLE V, SSM PLAN  
AND BAAQMD RULE 8-34  
SEMIANNUAL MONITORING REPORTS  
2022 – SECOND INCREMENT**

**CITY OF MOUNTAIN VIEW  
SHORELINE LANDFILL  
MOUNTAIN VIEW, CALIFORNIA  
(FACILITY NO. A2740)**

# **TITLE V SEMINANNUAL REPORT**

**2022– SECOND INCREMENT**

**CITY OF MOUNTAIN VIEW  
SHORELINE LANDFILL  
MOUNTAIN VIEW, CALIFORNIA  
(FACILITY NO. A2740)**

**CITY OF MOUNTAIN VIEW**  
**TITLE V SEMI-ANNUAL MONITORING REPORT**

**SITE NAME:** City of Mountain View – Shoreline Landfill

**FACILITY ID #** A2740

**REPORTING PERIOD:** 7/1/2022 – 12/31/2022

**CERTIFICATION:**

Based on information and belief formed after reasonable inquiry, the statements and information provided in this document are true, accurate, complete, and addresses all deviations during the reporting period:

  
\_\_\_\_\_  
Kimbra McCarthy (Jan 18, 2023 17:37 PST)  
Signature of Responsible Official

\_\_\_\_\_  
Jan 18, 2023  
Date

\_\_\_\_\_  
Kimbra McCarthy  
Name of Responsible Official (please print)

\_\_\_\_\_  
City Manager  
Title of Responsible Official (please print)

Mail to:

*Director of Compliance and Enforcement  
BAAQMD  
Bay Area Metro Center, 375 Beale Street, Suite 600  
San Francisco, CA 94105  
Attn: Title V reports*

**CITY OF MOUNTAIN VIEW**  
**TITLE V SEMI-ANNUAL MONITORING REPORT**

**SITE NAME:** City of Mountain View – Shoreline Landfill

**FACILITY ID #** A2740

**REPORTING PERIOD:** 7/1/2022 – 12/31/2022

List of Permitted Sources and Abatement Devices

PERMIT UNIT NUMBER	EQUIPMENT DESCRIPTION
S-1	Landfill and Gas Collection System
A-6	Landfill Gas Flare
A-7	Landfill Gas Flare
A-8	Landfill Gas Flare
S-11	Diesel Engine For Emergency Standby Generator (at Flare Station)
S-14	Diesel Engine For Emergency Standby Generator (at Sewer Pump Station)
S-16	Microturbine (at Flare Station)
S-17	Microturbine (at Sewage Pump Station)

**CITY OF MOUNTAIN VIEW**  
**Shoreline Landfill – Facility ID # A2740**  
**TITLE V SEMI ANNUAL MONITORING REPORT (7/1/2022 – 12/31/2022)**  
**PERMITTED UNITS: S-1 LANDFILL AND GAS COLLECTION SYSTEM; A-6, A-7, and A-8 LANDFILL GAS FLARES**

Type of Limit	Monitoring Requirement Citation	Citation of Limit	Limit	Parameter Monitored	Monitoring Frequency * (P/C/N)	Compliance	Comments/Corrective Action Taken
Amount of Waste Accepted	BAAQMD 8-34-501.7	BAAQMD Condition # 16065, Part 1	0 tons/day and ≤ 12,725,000 tons (cumulative amount of all wastes) and ≤ 18,852,000 yd <sup>3</sup> (cumulative amount of all wastes and cover materials)	Records  Closed Landfill  No waste accepted	P/A	Continuous Yes	
Gas Flow	BAAQMD 8-34-501.10 and 508	BAAQMD 8-34-301 and 301.1	Landfill gas collection system shall operate continuously (except as indicated in Condition # 16065, Part 3) and all collected gases shall be vented to a properly operating control system	Gas Flow Meter and Recorder (every 15 minutes)	C	Continuous Yes	
Gas Flow	BAAQMD 8-34-501.1, 501.2, 501.10, and 508 and BAAQMD Condition # 16065, Part 6	BAAQMD Condition # 16065, Parts 2-3	Landfill gas collection system shall operate continuously (except as indicated in Condition # 16065, Part 3) and all collected gases shall be vented to a properly operating control system	Gas Flow Meter, Flare Alarms, and Records of Collection and Control Systems Downtime	C,P/E	Continuous Yes	
Collection System Installation Dates	BAAQMD 8-34-501.7 and 501.8 and BAAQMD Condition # 16065, Parts 15a-b	BAAQMD 8-34-304.1	For Inactive/Closed Areas: collection system components must be installed and operating by 2 years + 60 days after initial waste placement	Records	P/E	Continuous Yes	

<p style="text-align: center;"><b>CITY OF MOUNTAIN VIEW</b>  <b>Shoreline Landfill – Facility ID # A2740</b>  <b>TITLE V SEMI ANNUAL MONITORING REPORT (7/1/2022 – 12/31/2022)</b>  <b>PERMITTED UNITS: S-1 LANDFILL AND GAS COLLECTION SYSTEM; A-6, A-7, and A-8 LANDFILL GAS FLARES</b></p>							
Type of Limit	Monitoring Requirement Citation	Citation of Limit	Limit	Parameter Monitored	Monitoring Frequency * (P/C/N)	Compliance	Comments/Corrective Action Taken
Collection and Control Systems Shutdown Time	BAAQMD 8-34-501.1	BAAQMD 8-34-113.2	≤ 240 hours/year and ≤ 5 consecutive days	Operating Records	P/D	Continuous Yes	
Startup Shutdown or Malfunction Procedures	40 CFR 63.1980(a-b)	40 CFR 63.6(e)	Minimize Emissions by Implementing SSM Plan	Records (all occurrences, duration of each, corrective actions)	P/E	Continuous Yes	
Periods of In-operation for Parametric Monitors	BAAQMD 1-523.4	BAAQMD 1-523.2	≤ 15 consecutive days/incident and ≤ 30 calendar days/12 month period	Operating Records for All Parametric Monitors (for gas flow and temperature monitors)	P/D	Continuous Yes	
Continuous Monitors	40 CFR 60.7(b)	40 CFR 60.13(e)	Requires Continuous Operation except for breakdowns, repairs, calibration, and required span adjustments	Operating Records for All Continuous Monitors (for gas flow and temperature Monitors)	P/D	Continuous Yes	
Wellhead Pressure	BAAQMD 8-34-414, 501.9, and 505.1	BAAQMD 8-34-305.1	< 0 psig	Monthly Inspection and Records	P/M	Continuous Yes	
Temperature of Gas at Wellhead	BAAQMD 8-34-414, 501.9 and 505.2	BAAQMD 8-34-305.2	< 55 °C (131 °F) (Wells listed in BAAQMD Condition # 16065, Part 5a are excluded from this limit.)	Monthly Inspection and Records	P/M	Continuous Yes	

**CITY OF MOUNTAIN VIEW**  
**Shoreline Landfill – Facility ID # A2740**  
**TITLE V SEMI ANNUAL MONITORING REPORT (7/1/2022 – 12/31/2022)**  
**PERMITTED UNITS: S-1 LANDFILL AND GAS COLLECTION SYSTEM; A-6, A-7, and A-8 LANDFILL GAS FLARES**

Type of Limit	Monitoring Requirement Citation	Citation of Limit	Limit	Parameter Monitored	Monitoring Frequency * (P/C/N)	Compliance	Comments/Corrective Action Taken
Temperature of Gas at Wellhead	BAAQMD 8-34-414, 501.9 and 505.2	BAAQMD Condition # 16065, Part 5a	$\leq 140$ °F (This limit applies only to wells listed in BAAQMD Condition # 16065, Part 5a)	Monthly Inspection and Records	P/M	Continuous Yes	
Gas Concentrations at Wellhead	BAAQMD 8-34-414, 501.9 and 505.3 or 505.4	BAAQMD 8-34-305.3 or 305.4	$N_2 < 20\%$ <b>OR</b> $O_2 < 5\%$ (Wells listed in BAAQMD Condition # 16065, Part 5b are excluded from these limits.)	Monthly Inspection and Records	P/M	Continuous Yes	
Gas Concentrations at Header	BAAQMD Condition # 16065, Part 5b	BAAQMD Condition # 16065, Part 5b	$O_2 \leq 5\%$ by volume, dry basis <b>AND</b> $CH_4 \geq 35\%$ by volume, dry basis	Monthly Inspection and Records	P/M	Intermittent Yes	
Well Shutdown Limits	BAAQMD 8-34-117.6 and 501.1	BAAQMD 8-34-117.4	No more than 5 wells at a time or 10% of total collection system, whichever is less	Records	P/D	Continuous Yes	
Well Shutdown Limits	BAAQMD 8-34-117.6 and 501.1	BAAQMD 8-34-117.5	$\leq 24$ hours per well	Records	P/D	Continuous Yes	
TOC (Total Organic Compounds Plus Methane)	BAAQMD 8-34-501.6 and 503 and BAAQMD Condition # 16065, Part 15c	BAAQMD 8-34-301.2	Component Leak Limit: $\leq 1000$ ppmv as methane at 1 cm from component (see BAAQMD Condition # 16065, Part 5c for Clarifications about vaults)	Quarterly Inspection of collection and control system components with Portable Analyzer and Records	P/Q	Continuous Yes	

<p style="text-align: center;"><b>CITY OF MOUNTAIN VIEW</b>  <b>Shoreline Landfill – Facility ID # A2740</b>  <b>TITLE V SEMI ANNUAL MONITORING REPORT (7/1/2022 – 12/31/2022)</b>  <b>PERMITTED UNITS: S-1 LANDFILL AND GAS COLLECTION SYSTEM; A-6, A-7, and A-8 LANDFILL GAS FLARES</b></p>							
Type of Limit	Monitoring Requirement Citation	Citation of Limit	Limit	Parameter Monitored	Monitoring Frequency * (P/C/N)	Compliance	Comments/Corrective Action Taken
TOC	BAAQMD 8-34-415, 416, 501.6, 506 and 510 and BAAQMD Condition # 16065, Part 15c	BAAQMD 8-34-303	Surface Leak Limit: $\leq$ 500 ppmv as methane at 2 inches above surface (see BAAQMD Condition # 16065, Part 5c for clarifications about vaults)	Monthly Visual Inspection of Cover, Quarterly Inspection of Surface with Portable Analyzer, Reinspections as Needed, and Records	P/M, Q, and E	Continuous Yes	
Non-Methane Organic Compounds (NMOC)	BAAQMD 8-34-412 and 501.4 and BAAQMD Condition # 16065, Parts 13 and 15c	BAAQMD 8-34-301.3	$\geq$ 98% removal by weight OR $<$ 30 ppmv, dry basis @ 3% O <sub>2</sub> , expressed as methane (applies to flares only)	Source Tests and Records	P/A	Continuous Yes	
Temperature of Combustion Zone (CT)	BAAQMD 8-34-501.3 and 507	BAAQMD Condition # 16065, Part 7 (Updated: December 9, 2015)	CT $\geq$ 1577 °F, averaged over any 3-hour period (applies to each flares)	Temperature Sensor and Recorder	C	Continuous Yes	
SO <sub>2</sub>	BAAQMD Condition # 16065, Parts 13 and 15c or Parts 14 and 15c	BAAQMD Regulation 9-1-302	$\leq$ 300 ppm (dry basis)	Annual Source Test At Flare or Sulfur Analysis of Landfill Gas at Header and Records	P/A	Continuous Yes	

<p style="text-align: center;"><b>CITY OF MOUNTAIN VIEW</b>  <b>Shoreline Landfill – Facility ID # A2740</b>  <b>TITLE V SEMI ANNUAL MONITORING REPORT (7/1/2022 – 12/31/2022)</b>  <b>PERMITTED UNITS: S-1 LANDFILL AND GAS COLLECTION SYSTEM; A-6, A-7, and A-8 LANDFILL GAS FLARES</b></p>							
Type of Limit	Monitoring Requirement Citation	Citation of Limit	Limit	Parameter Monitored	Monitoring Frequency * (P/C/N)	Compliance	Comments/Corrective Action Taken
SO <sub>2</sub>	BAAQMD Condition # 16065, Parts 13f and 15c or 14 and 15c	BAAQMD Condition # 16065, Part 12 BAAQMD Regulation 9-1-302	≤ 9 ppm (dry basis) (applies to each flare A-6, A-7, and A-8)	Sulfur Analysis of Landfill Gas and Records	P/A	Continuous Yes	
Landfill Gas Sulfur Content	BAAQMD Condition # 16065, Parts 14 and 15c	BAAQMD Condition # 16065, Part 12	≤ 150 ppmv, expressed as H <sub>2</sub> S (applies if SO <sub>2</sub> testing is not conducted at flare exhaust)	Sulfur Analysis of Landfill Gas and Records	P/A	Continuous Yes	
NO <sub>x</sub>	BAAQMD Condition # 16065, Parts 13 and 15c	BAAQMD Condition # 16065, Part 9a (Updated: December 9, 2015)	≤ 0.06 lbs/MMBTU or ≤ 15 ppmv, as NO <sub>2</sub> at 15% O <sub>2</sub> , dry basis (applies to A-6, A-7, and A-8 flares only)	Source Tests and Records	P/A	Continuous Yes	
CO	BAAQMD Condition # 16065, Parts 13 and 15c	BAAQMD Condition # 16065, Part 10a	< 0.20 lbs/MMBTU or ≤ 83 ppmv, at 15% O <sub>2</sub> , dry basis (applies to A-6 A-7, and A-8 flares only)	Source Tests and Records	P/A	Continuous Yes	

\* Monitoring Frequency Legend

P = Periodic Monitoring / on an A = Annual, Q = Quarterly, M = Monthly, W = Weekly, D = Daily or E = Event basis  
C = Continuous Monitoring

<p style="text-align: center;"><b>CITY OF MOUNTAIN VIEW</b>  <b>Shoreline Landfill – Facility ID # A2740</b>  <b>TITLE V SEMI ANNUAL MONITORING REPORT (7/1/2022 – 12/31/2022)</b>  <b>PERMITTED UNITS: S-11 AND S-14 DIESEL ENGINES FOR EMERGENCY STANDBY GENERATORS</b></p>							
<b>Type of Limit</b>	<b>Monitoring Requirement Citation</b>	<b>Citation of Limit</b>	<b>Limit</b>	<b>Parameter Monitored</b>	<b>Monitoring Frequency * (P/C)</b>	<b>Compliance</b>	<b>Comments/Corrective Action Taken</b>
Liquid Fuel Sulfur Content	BAAQMD Condition # 24175, Part 5f	BAAQMD Regulation 9-1-304	Fuel Sulfur Limit: ≤ 0.5% S by weight	Vendor Certification	P/E	Continuous Yes	
Liquid Fuel Sulfur Content	BAAQMD Condition # 24175, Part 5f	CCR Title 17, Section 93115.5(b) and CCR Title 13, Section 2281(a)(1-5)	Standby Engines must use CARB Diesel Fuel or other CARB Approved Alternative Fuel which has Fuel Sulfur Limits of: ≤ 15 ppmw of S	Vendor Certification	P/E	Continuous Yes	
Operating Hours	BAAQMD Regulation 9-8-530 and BAAQMD Condition # 24175, Parts 4 and 5a-d and CCR Title 17, Section 93115.10(e)(1)&(g)(1)	BAAQMD Condition # 24175, Part 1 and CCR Title 17, Section 93115.6 (b)(3)(A)(1)(b)	For S-11 Diesel Engine: Operating hours for Reliability-Related Activities: ≤ 30 hours in a calendar year	Hour Meter and Records	P/C, M	Continuous Yes	
Operating Hours	BAAQMD Regulation 9-8-530 and BAAQMD Condition # 24175, Parts 4 and 5a-d and CCR Title 17, Section 93115.10(e)(1)&(g)(1)	BAAQMD Regulation 9-8-330.3 and BAAQMD Condition # 24175, Part 2b	For S-14 Diesel Engine Operating hours for Reliability-Related Activities: ≤ 50 hours in a calendar year  (Effective 1/1/2012)	Hour Meter and Records	P/C, M	Continuous Yes  (Effective 1/1/2012)	

<p style="text-align: center;"><b>CITY OF MOUNTAIN VIEW</b>  <b>Shoreline Landfill – Facility ID # A2740</b>  <b>TITLE V SEMI ANNUAL MONITORING REPORT (7/1/2022 – 12/31/2022)</b>  <b>PERMITTED UNITS: S-11 AND S-14 DIESEL ENGINES FOR EMERGENCY STANDBY GENERATORS</b></p>							
Type of Limit	Monitoring Requirement Citation	Citation of Limit	Limit	Parameter Monitored	Monitoring Frequency * (P/C)	Compliance	Comments/Corrective Action Taken
Operating Hours	40 CFR 63.6625(f) and 63.6655(f)(2)	40 CFR 63.6640 (f)(2)(i)	Operating Hours for Maintenance Checks, Readiness Testing, and Other Non-Emergency Operation:  < 100 hours in a calendar year	Hour Meter and Records	C & P/M	Continuous  Yes	
Operating Hours	40 CFR 63.6625(f) and 63.6655(f)(2)	40 CFR 63.6640 (f)(4)	Operating Hours for Non-Emergency Operation:  < 50 hours in a calendar year	Hour Meter and Records	C & P/M	Continuous  Yes	
Maintenance	40 CFR §63.6625(f); 63.6655(e)	40 CFR §63.6603(a)	Every 500 hours or annually, whichever comes first: Change oil and filter; unless following oil analysis program under §63.6625(j)	Non-resettable Hour Meter; Records	C  P/E	Continuous  Yes	
Maintenance	40 CFR §63.6625(f); 63.6655(e)	40 CFR §63.6603(a)	Every 1000 hours or annually, whichever comes first: Inspect spark plugs and replace as necessary	Non-resettable Hour Meter; Records	C  P/E	Continuous  Yes	
Maintenance	40 CFR §63.6625(f); 63.6655(e)	40 CFR §63.6603(a)	Every 500 hours or annually, whichever comes first: Inspect hoses and belts and replace as necessary	Non-resettable Hour Meter; Records	C  P/E	Continuous  Yes	

\* Monitoring Frequency Legend

P = Periodic Monitoring / on an A = Annual, Q = Quarterly, M = Monthly, W = Weekly, D = Daily or E = Event basis

C = Continuous Monitoring

<p style="text-align: center;"><b>CITY OF MOUNTAIN VIEW</b>  <b>Shoreline Landfill – Facility ID # A2740</b>  <b>TITLE V SEMI ANNUAL MONITORING REPORT (7/1/2022 – 12/31/2022)</b>  <b>PERMITTED UNITS: S-16 MICROTURBINE, AND S-17 MICROTURBINE</b></p>							
Type of Limit	Monitoring Requirement Citation	Citation of Limit	Limit	Parameter Monitored	Monitoring Frequency * (P/C)	Compliance	Comments/Corrective Action Taken
TOC (Total Organic Compounds Plus Methane)	BAAQMD 8-34-501.6 and 503 and BAAQMD Condition # 16065, Part 15c	BAAQMD 8-34-301.2	≤ 1000 ppmv as methane (component leak limit)	Quarterly Inspection of Control System Components with Portable Analyzer and Records	P/Q	Continuous Yes	
Non-Methane Organic Compounds (NMOC)	BAAQMD 8-34-412 and 501.4 and BAAQMD Condition # 24989, Parts 2 and 3	BAAQMD 8-34-301.4	≥ 98% removal by weight OR < 120 ppmv, dry basis @ 3% O <sub>2</sub> , expressed as methane	Source Tests and Records	P/A	Continuous Yes	
Volatile Organic Compounds (VOC)	CCR Title 17 Section 95204	BAAQMD Condition # 24989, Part 1	< 1.0 lbs/MW-hr	CARB Certification	P/E	Continuous Yes	
NO <sub>x</sub>	CCR Title 17 Section 95204	BAAQMD Condition # 24989, Part 1	< 0.5 lbs/MW-hr	CARB Certification	P/E	Continuous Yes	
CO	CCR Title 17 Section 95204	BAAQMD Condition # 24989, Part 1	< 6.0 lbs/MW-hr	CARB Certification	P/E	Continuous Yes	

\* Monitoring Frequency Legend

P = Periodic Monitoring / on an A = Annual, Q = Quarterly, M = Monthly, W = Weekly, D = Daily or E = Event basis  
C = Continuous Monitoring

# **SSM PLAN REPORT**

**2022 – SECOND INCREMENT**

**CITY OF MOUNTAIN VIEW  
SHORELINE LANDFILL  
MOUNTAIN VIEW, CALIFORNIA  
(FACILITY NO. A2740)**

**CITY OF MOUNTAIN VIEW**  
**SHORELINE LANDFILL, FACILITY ID A2740**  
**EMISSION CONTROL SYSTEM SHUTDOWN SUMMARY**  
**July 1 - December 31, 2022**

Period	Duration Hours: Minutes
<b>Total shutdown duration from January 1 - June 30, 2022</b>	<b>17:32</b>
<b>Total shutdown duration from July 1 - December 31, 2022</b>	<b>19:36</b>
<b>Total shutdown duration from January 1 - December 31, 2022</b>	<b>37:08</b>

Date	Description * (July 1 - December 31, 2022) Maintenance, operation and repairs requiring Flare station Shutdown	Shutdown	Start up	Duration Hours: Minutes
7/26/2022	Telstar to replace controller	8:53 PM	9:24 PM	0:31
7/27/2022	Clean separator & clean and replace flame detection bulbs	7:43 AM	10:57 AM	3:14
8/2/2022	Clean honeywell U.V. bulbs	9:24 AM	9:29 AM	0:05
9/8/2022	Change out belt on air compressor	1:48 PM	2:27 PM	0:39
9/19/2022	Blower change from #1 to #2	9:00 AM	9:30 AM	0:30
9/25/2022	High temperature for Flare #3	6:24 PM	8:03 PM	1:39
10/18/2022	Install Google/Bloomenergy flow meter	11:53 AM	11:59 AM	0:06
10/24/2022	Checked off header by liquid	7:42 AM	8:42 AM	1:00
10/25/2022	Low gas flow	11:24 AM	11:26 AM	0:02
10/25/2022	Low gas flow	11:45 AM	11:53 AM	0:08
10/26/2022	Google/Bloomenergy flow spike	3:38 PM	3:40 PM	0:02
10/27/2022	Take flow #1 out of alarm	8:20 AM	8:33 AM	0:13
10/30/2022	Take out two (2) sumps on Vista	5:22 PM	7:25 PM	2:03
10/31/2022	Blower change from #2 to #3	8:31 AM	8:53 AM	0:22
11/1/2022	Low gas flow	11:58 PM	12:05 AM	0:07
11/2/2022	Calibrate flow meters at inlets (Telstar)	7:20 AM	8:51 AM	1:31
11/3/2022	Telstar to replace flow meter at Vista	7:24 AM	10:53 AM	3:29
11/16/2022	Clean knockout	9:26 AM	10:03 AM	0:37
11/19/2022	Reset Flare #1	12:18 PM	12:30 PM	0:12
11/21/2022	Restart Flare #1	12:25 PM	12:44 PM	0:19
11/28/2022	Low gas flow	10:53 PM	11:00 PM	0:07
11/28/2022	Low gas flow	11:58 PM	12:05 AM	0:07
11/29/2022	Blower change from #3 to #1	12:30 PM	12:42 PM	0:12
12/16/2022	Restart Flare #1	8:42 AM	9:05 AM	0:23
12/20/2022	Annual air compressor maintenance	10:27 AM	12:25 PM	1:58

\* - Monitoring records are attached.

**SSM PLAN REPORT FORM /  
FLARE STATION DAILY CHECKLIST**  
City of Mountain View Flare Station

Date

July 26<sup>th</sup>, 2022

S M T W Th F S

**AM MONITORING**

Name Jason R. Bean

Arrival Time 7:20 AM Departure Time 7:30 AM

GEM# ENVISION #4 Manometer  yes /  no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>44.6</u>	<u>32.2</u>	<u>1.8</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1	<u>1632</u>	<u>2.84"</u>	<u>116</u>
Flare #2	<u>1632</u>	<u>2.01"</u>	<u>228</u>
Flare #3			

Blower Oper.	RPM	Hours
Blower #1		
Blower #2		
Blower #3	<u>2100</u>	<u>30343.8</u>

Air Compressor Hours: 9556.2

Google SCFM: am: 27 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>46.9</u>	<u>44.7</u>	<u>42.0</u>
CO2 %	<u>33.0</u>	<u>31.4</u>	<u>29.5</u>
O2 %	<u>1.3</u>	<u>0.4</u>	<u>3.5</u>
Vacuum	<u>-40.2"</u>	<u>-39.4"</u>	<u>-40.0"</u>
SCFM	<u>154</u>	<u>151</u>	<u>119</u>
Temperature	<u>77</u>	<u>77</u>	<u>74</u>

Time of Shutdown: 8:53 AM

Time of Start-Up: 9:24 AM

Duration of Shutdown/Malfunction: 31 min

Reason for Shutdown/Malfunction: REPLACED CONTROLLER

- Air-Compressor System
- Blower
- High Gas Flow
- High Temperature
- LEL
- Low Gas Flow
- Low Temperature
- UV Scanner System
- Power Failure
- Scheduled Preventive Maintenance

TelStar here to replace controller

**PM MONITORING**

Name \_\_\_\_\_

Arrival Time \_\_\_\_\_ Departure Time \_\_\_\_\_

GEM# \_\_\_\_\_ Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3			

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			

Back Up Generator Running yes /  no

Control Room Bypass yes /  no

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed isolating all LFG in the piping system to avoid excess emissions, and notified the staff.

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.

Comments and/or Description of Malfunction and Affected Equipment:

Time of Shutdown: 8:53 AM

Time of Start-Up: 9:24 AM

Duration of Shutdown/Malfunction: 31 min

Emission Exceedence: yes\* /  no

SSM Plan Procedures Followed:  yes\*  no\*

If SSM Plan Procedure not followed, explain procedure used:

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc. continued on the back side?

yes /  no

Signature 

Date 7/26/22

**SSM PLAN REPORT FORM /  
FLARE STATION DAILY CHECKLIST**  
City of Mountain View Flare Station

Date

July 27<sup>th</sup>, 2022

s m t w th f s

**AM MONITORING**

Name Jason R. Bean

Arrival Time 6:38 AM Departure Time 6:48 AM

GEM# EN001N #4 Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>44.5</u>	<u>31.1</u>	<u>1.8</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1	<u>1620</u>	<u>1.54"</u>	<u>90</u>
Flare #2			
Flare #3	<u>1621</u>	<u>0.99"</u>	<u>280</u>

Blower Oper.	RPM	Hours
Blower #1		
Blower #2		
Blower #3	<u>2100</u>	<u>80366.7</u>

Air Compressor Hours: 9564.2

Google SCFM: am: 16 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>46.4</u>	<u>44.6</u>	<u>42.4</u>
CO2 %	<u>32.7</u>	<u>31.4</u>	<u>34.4</u>
O2 %	<u>13</u>	<u>0.7</u>	<u>3.6</u>
Vacuum	<u>-41.0"</u>	<u>-40.2"</u>	<u>-40.9"</u>
SCFM	<u>155</u>	<u>152</u>	<u>122</u>
Temperature	<u>77</u>	<u>77</u>	<u>74</u>

**PM MONITORING**

Name \_\_\_\_\_

Arrival Time \_\_\_\_\_ Departure Time \_\_\_\_\_

GEM# \_\_\_\_\_ Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3			

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			

Back Up Generator Running yes / no

Control Room Bypass yes / no

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed isolating all LFG in the piping system to avoid excess emissions, and notified the staff.

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.

Comments and/or Description of Malfunction and Affected Equipment:

Time of Shutdown: 7:43 AM

Time of Start-Up: 10:57 AM

Duration of Shutdown/Malfunction: 3hr 14 min

Reason for Shutdown/Malfunction:

- Air-Compressor System
- Blower
- High Gas Flow
- High Temperature
- LEL
- Low Gas Flow
- Low Temperature
- UV Scanner System
- Power Failure
- Scheduled Preventive Maintenance

Clean Separator, Clean and replace Flame detector bulbs

Signature Jason R. Bean

Date 7/27/22

Emission Exceedence: yes\* / no

SSM Plan Procedures Followed: yes / no\*

If SSM Plan Procedure not followed, explain procedure used:

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc. continued on the back side?

yes / no

**SSM PLAN REPORT FORM /  
FLARE STATION DAILY CHECKLIST**  
City of Mountain View Flare Station

Date 8-2-22  
s m  w th f s

**AM MONITORING**

Name Leon Rosario  
Arrival Time 6:48 AM Departure Time 6:56 AM  
GEM# EN V #4 Manometer (yes) no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>45.2</u>	<u>33.2</u>	<u>2.0</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1	<u>1620</u>	<u>2.36"</u>	<u>109</u>
Flare #2	<u>/</u>	<u>/</u>	<u>/</u>
Flare #3	<u>1626</u>	<u>1.58"</u>	<u>350</u>

Blower Oper.	RPM	Hours
Blower #1	<u>2100</u>	<u>7943.5</u>
Blower #2	<u>/</u>	<u>/</u>
Blower #3	<u>/</u>	<u>/</u>

Air Compressor Hours: 9612.7

Google SCFM: am: 8 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>47.5</u>	<u>45.2</u>	<u>42.8</u>
CO2 %	<u>32.7</u>	<u>32.0</u>	<u>29.7</u>
O2 %	<u>1.7</u>	<u>0.8</u>	<u>3.4</u>
Vacuum	<u>-39.6"</u>	<u>-38.4"</u>	<u>-39.3"</u>
SCFM	<u>191</u>	<u>148</u>	<u>126</u>
Temperature	<u>77</u>	<u>77</u>	<u>74</u>

Time of Shutdown: 9:24 AM

Time of Start-Up: 9:29 AM

Duration of Shutdown/Malfunction: 5 min

Reason for Shutdown/Malfunction:

- Air-Compressor System
- Blower
- High Gas Flow
- High Temperature
- LEL
- Low Gas Flow
- Low Temperature
- UV Scanner System
- Power Failure
- Scheduled Preventive Maintenance

Clean Honeywell UV Bulbs.

**PM MONITORING**

Name \_\_\_\_\_  
Arrival Time \_\_\_\_\_ Departure Time \_\_\_\_\_  
GEM# \_\_\_\_\_ Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %

Flare Operation	Temp.	Vac.	SCFM
Flare #1	<u>/</u>	<u>/</u>	<u>/</u>
Flare #2	<u>/</u>	<u>/</u>	<u>/</u>
Flare #3	<u>/</u>	<u>/</u>	<u>/</u>

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			

Back Up Generator Running yes / no

Control Room Bypass yes / no

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed isolating all LFG in the piping system to avoid excess emissions, and notified the staff. yes / no

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.

Comments and/or Description of Malfunction and Affected Equipment:

Emission Exceedence: yes\* / no


SSM Plan Procedures Followed: yes / no\*

If SSM Plan Procedure not followed, explain procedure used:

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc. continued on the back side?

yes / no

Signature 

Date 8/2/22

**SSM PLAN REPORT FORM /  
FLARE STATION DAILY CHECKLIST**  
City of Mountain View Flare Station

Date 9-8-22  
 S m t w **th** f s

**AM MONITORING**

Name LEON ROSACCO

Arrival Time 7:18 AM Departure Time 7:29 AM  
 GEM# ENU #4 Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>45.1</u>	<u>33.1</u>	<u>1.8</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1	<u>1618</u>	<u>2.17"</u>	<u>103</u>
Flare #2			
Flare #3	<u>1617</u>	<u>1.45"</u>	<u>337</u>

Blower Oper.	RPM	Hours
Blower #1	<u>2100</u>	<u>18837.0</u>
Blower #2		
Blower #3		

Air Compressor Hours: 9920

Google SCFM: am: 47 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>48.2</u>	<u>44.0</u>	<u>41.6</u>
CO2 %	<u>33.6</u>	<u>33.0</u>	<u>30.3</u>
O2 %	<u>1.4</u>	<u>0.7</u>	<u>4.0</u>
Vacuum	<u>-39.3"</u>	<u>-38.4"</u>	<u>-39.0"</u>
SCFM	<u>185</u>	<u>157</u>	<u>125</u>
Temperature	<u>79</u>	<u>78</u>	<u>76</u>

Time of Shutdown: 1:48 pm

Time of Start-Up: 2:27 pm

Duration of Shutdown/Malfunction: 39 min

Reason for Shutdown/Malfunction:

- Air-Compressor System    Blower    High Gas Flow
- High Temperature    LEL    Low Gas Flow
- Low Temperature    UV Scanner System
- Power Failure    Scheduled Preventive Maintenance

D T D changing out belt  
on Air Compressor

**PM MONITORING**

Name \_\_\_\_\_

Arrival Time \_\_\_\_\_ Departure Time \_\_\_\_\_  
 GEM# \_\_\_\_\_ Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3			

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			

Back Up Generator Running yes / no

Control Room Bypass yes / no

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed isolating all LFG in the piping system to avoid excess emissions, and notified the staff.

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.

Comments and/or Description of Malfunction and Affected Equipment:

yes / no

Emission Exceedence:

yes\* / no

SSM Plan Procedures Followed:

yes no\*

If SSM Plan Procedure not followed, explain procedure used:

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc. continued on the back side?

yes / no

Signature 

Date 9/8/22

**SSM PLAN REPORT FORM /**  
**FLARE STATION DAILY CHECKLIST**  
 City of Mountain View Flare Station

Date

9-19-22

S M T W Th F S

**AM MONITORING**

Name LEON ROSARIO

Arrival Time 8:43 AM Departure Time \_\_\_\_\_  
 GEM# CNV #4 Manometer (yes) no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>43.0</u>	<u>31.1</u>	<u>2.5</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1	<u>1629</u>	<u>2.26"</u>	<u>105</u>
Flare #2	<u>/</u>	<u>/</u>	<u>/</u>
Flare #3	<u>1627</u>	<u>1.47"</u>	<u>342</u>

Blower Oper.	RPM	Hours
Blower #1	<u>2100</u>	<u>190969</u>
Blower #2	<u>/</u>	<u>/</u>
Blower #3	<u>/</u>	<u>/</u>

Air Compressor Hours: 1001.9

Google SCFM: am: 47 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>46.2</u>	<u>43.8</u>	<u>38.6</u>
CO2 %	<u>32.3</u>	<u>31.6</u>	<u>28.0</u>
O2 %	<u>7.0</u>	<u>1.0</u>	<u>4.9</u>
Vacuum	<u>-39.5"</u>	<u>-38.3"</u>	<u>-39.3"</u>
SCFM	<u>190</u>	<u>161</u>	<u>126</u>
Temperature	<u>77</u>	<u>77</u>	<u>74</u>

**PM MONITORING**

Name \_\_\_\_\_

Arrival Time \_\_\_\_\_ Departure Time \_\_\_\_\_  
 GEM# \_\_\_\_\_ Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3			

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			
Back Up Generator Running			yes / no

Control Room Bypass yes / no

The facility's program logic controller yes / no automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed isolating all LFG in the piping system to avoid excess emissions, and notified the staff.

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.

Comments and/or Description of Malfunction and Affected Equipment:

Time of Shutdown: 9 AM

Time of Start-Up: 9:30 AM

Duration of Shutdown/Malfunction: 30 min

Reason for Shutdown/Malfunction:

- Air-Compressor System
- Blower
- High Gas Flow
- High Temperature
- LEL
- Low Gas Flow
- Low Temperature
- UV Scanner System
- Power Failure
- Scheduled Preventive Maintenance

Blower change from #1 to #2

Emission Exceedence: yes\* / no


SSM Plan Procedures Followed: yes / no\*

If SSM Plan Procedure not followed, explain procedure used:

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc. continued on the back side?

yes / no



9/19/22

**SSM PLAN REPORT FORM /  
FLARE STATION DAILY CHECKLIST**  
City of Mountain View Flare Station

Date

9/25/22

s m t w th f s

**AM MONITORING**

Name LEON ROSENG  
Arrival Time 7:15pm Departure Time 8:30pm  
GEM# FNV #9 Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>45.8</u>	<u>32.2</u>	<u>2.2</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1	<u>1618</u>	<u>3.25"</u>	<u>106</u>
Flare #2	<u>/</u>	<u>/</u>	<u>/</u>
Flare #3	<u>1627</u>	<u>2.22"</u>	<u>341</u>

Blower Oper.	RPM	Hours
Blower #1	<u>/</u>	<u>/</u>
Blower #2	<u>2100</u>	<u>63209.6</u>
Blower #3	<u>/</u>	<u>/</u>

Air Compressor Hours: 10048.1

Google SCFM: am: 0 pm: 54

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>48.2</u>	<u>42.8</u>	<u>40.2</u>
CO2 %	<u>33.2</u>	<u>30.8</u>	<u>27.9</u>
O2 %	<u>1.3</u>	<u>1.1</u>	<u>9.5</u>
Vacuum	<u>-39.2"</u>	<u>-38.6</u>	<u>-39.3</u>
SCFM	<u>203</u>	<u>165</u>	<u>135</u>
Temperature	<u>76</u>	<u>74</u>	<u>75</u>

**PM MONITORING**

Name \_\_\_\_\_  
Arrival Time \_\_\_\_\_ Departure Time \_\_\_\_\_  
GEM# \_\_\_\_\_ Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3			

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			

Back Up Generator Running yes / no

Control Room Bypass yes / no

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed isolating all LFG in the piping system to avoid excess emissions, and notified the staff.

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.

Comments and/or Description of Malfunction and Affected Equipment:

Time of Shutdown: 6:24 pm

Time of Start-Up: 8:03 pm

Duration of Shutdown/Malfunction: 1 hr 39 min

Reason for Shutdown/Malfunction:

- Air-Compressor System
- Blower
- High Gas Flow
- High Temperature
- LEL
- Low Gas Flow
- Low Temperature
- UV Scanner System
- Power Failure
- Scheduled Preventive Maintenance

flare #3 high temp

Emission Exceedence:

yes\* / no

SSM Plan Procedures Followed:

yes / no\*

If SSM Plan Procedure not followed, explain procedure used:

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc. continued on the back side?

yes / no

Signature

Date

**SSM PLAN REPORT FORM /  
FLARE STATION DAILY CHECKLIST**  
City of Mountain View Flare Station

Date

October 18<sup>th</sup>, 2022

S M  T W Th F S

**AM MONITORING**

Name JASON R BEAN

Arrival Time 6:49 AM Departure Time 7:00 AM

GEM# ENVISION #1 Manometer  yes  no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>42.7</u>	<u>31.2</u>	<u>21.6</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1	<u>1623</u>	<u>1.57"</u>	<u>89</u>
Flare #2			
Flare #3	<u>1629</u>	<u>0.92"</u>	<u>275</u>

Blower Oper.	RPM	Hours
Blower #1		
Blower #2	<u>2100</u>	<u>63748.2</u>
Blower #3		

Air Compressor Hours: 10254.4

Google SCFM: am: 52 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>46.1</u>	<u>43.2</u>	<u>37.3</u>
CO2 %	<u>33.0</u>	<u>32.0</u>	<u>27.1</u>
O2 %	<u>1.9</u>	<u>1.0</u>	<u>5.3</u>
Vacuum	<u>-41.3"</u>	<u>-40.3"</u>	<u>-41.1"</u>
SCFM	<u>187</u>	<u>158</u>	<u>134</u>
Temperature	<u>73</u>	<u>74</u>	<u>71</u>

Time of Shutdown: 11:53 PM

Time of Start-Up: 11:59 AM

Duration of Shutdown/Malfunction: 6 min

Reason for Shutdown/Malfunction:

- Air-Compressor System
- Blower
- High Gas Flow
- High Temperature
- LEL
- Low Gas Flow
- Low Temperature
- UV Scanner System
- Power Failure
- Scheduled Preventive Maintenance

Bloom Flow Meter Inspection

Signature

Date

**PM MONITORING**

Name \_\_\_\_\_

Arrival Time \_\_\_\_\_ Departure Time \_\_\_\_\_

GEM# \_\_\_\_\_ Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3			

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			

Back Up Generator Running yes /

Control Room Bypass yes /

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed isolating all LFG in the piping system to avoid excess emissions, and notified the staff.

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.

Comments and/or Description of Malfunction and Affected Equipment:

Emission Exceedence: yes\* /

SSM Plan Procedures Followed: yes /  no\*

If SSM Plan Procedure not followed, explain procedure used:

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc. continued on the back side?

yes /  no

**SSM PLAN REPORT FORM /  
FLARE STATION DAILY CHECKLIST**  
City of Mountain View Flare Station

Date 10/29/22  
 s  m t w th f s

**AM MONITORING**

Name LEON ROSARZO  
 Arrival Time 7:20 AM Departure Time 7:39 AM  
 GEM# FNV #4 Manometer yes  no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>40.1</u>	<u>30.6</u>	<u>3.0</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1	<u>1622</u>	<u>1.58"</u>	<u>90</u>
Flare #2			
Flare #3	<u>1629</u>	<u>0.92"</u>	<u>276</u>

Blower Oper.	RPM	Hours
Blower #1		
Blower #2	<u>7100</u>	<u>13892.7</u>
Blower #3		

Air Compressor Hours: 10306.3

Google SCFM: am: 41 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>43.5</u>	<u>42.8</u>	<u>34.0</u>
CO2 %	<u>31.2</u>	<u>31.5</u>	<u>25.8</u>
O2 %	<u>7.5</u>	<u>1.0</u>	<u>6.1</u>
Vacuum	<u>-42.0"</u>	<u>-41.1"</u>	<u>-41.9"</u>
SCFM	<u>190</u>	<u>161</u>	<u>128</u>
Temperature	<u>71</u>	<u>72</u>	<u>69</u>

**PM MONITORING**

Name \_\_\_\_\_  
 Arrival Time \_\_\_\_\_ Departure Time \_\_\_\_\_  
 GEM# \_\_\_\_\_ Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3			

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			

Back Up Generator Running yes /  no

Control Room Bypass yes /  no

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed isolating all LFG in the piping system to avoid excess emissions, and notified the staff.

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.

Comments and/or Description of Malfunction and Affected Equipment:

Time of Shutdown: 7:42 AM  
 Time of Start-Up: 8:42 AM  
 Duration of Shutdown/Malfunction: 1 hr

Emission Exceedence: yes\* /  no


SSM Plan Procedures Followed:  yes / no\*

If SSM Plan Procedure not followed, explain procedure used:

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc. continued on the back side?

yes /  no



10/29/22

**SSM PLAN REPORT FORM /  
FLARE STATION DAILY CHECKLIST**  
City of Mountain View Flare Station

Date 10/25/22  
s m  t w th f s

**AM MONITORING**

Name LEON ROSARIO

Arrival Time 7:39 am Departure Time 8:49 am

GEM# ENV #4 Manometer  yes / no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>42.1</u>	<u>31.8</u>	<u>7.8</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1	<u>1590</u>	<u>1.99"</u>	<u>86</u>
Flare #2			
Flare #3	<u>1601</u>	<u>1.21"</u>	<u>264</u>

Blower Oper.	RPM	Hours
Blower #1		
Blower #2	<u>2100</u>	<u>63916.1</u>
Blower #3		

Air Compressor Hours: 10315.6

Google SCFM: am: 34 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>47.5</u>	<u>43.1</u>	<u>36.9</u>
CO2 %	<u>33.7</u>	<u>32.2</u>	<u>26.8</u>
O2 %	<u>1.6</u>	<u>1.1</u>	<u>5.5</u>
Vacuum	<u>-41.4"</u>	<u>-40.5"</u>	<u>-41.3"</u>
SCFM	<u>148</u>	<u>160</u>	<u>136</u>
Temperature	<u>77</u>	<u>77</u>	<u>70</u>

Time of Shutdown:	<u>11:24 AM</u>	<u>11:45 AM</u>
Time of Start-Up:	<u>11:26 AM</u>	<u>11:53 AM</u>
Duration of Shutdown/Malfunction:	<u>2 min</u>	<u>8 min</u>

Reason for Shutdown/Malfunction: Low Gas flow

- Air-Compressor System
- Blower
- High Gas Flow
- High Temperature
- LEL
- Low Gas Flow
- Low Temperature
- UV Scanner System
- Power Failure
- Scheduled Preventive Maintenance

**PM MONITORING**

Name \_\_\_\_\_

Arrival Time \_\_\_\_\_ Departure Time \_\_\_\_\_

GEM# \_\_\_\_\_ Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %

Flare Operation	Tc/inp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3			

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			

Back Up Generator Running yes /  no

Control Room Bypass yes /  no

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed isolating all LFG in the piping system to avoid excess emissions, and notified the staff.

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.

Comments and/or Description of Malfunction and Affected Equipment:

Emission Exceedence: yes\* /  no


SSM Plan Procedures Followed:  yes / no\*

If SSM Plan Procedure not followed, explain procedure used:

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc. continued on the back side?

yes /  no



10/25/22

**SSM PLAN REPORT FORM /  
FLARE STATION DAILY CHECKLIST**  
City of Mountain View Flare Station

Date 10/26/22  
s m t w th f s

**AM MONITORING**

Name LEON ROSALDO  
Arrival Time 6:54 AM Departure Time 7:05 AM  
GEM# GUV #4 Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>43.0</u>	<u>31.3</u>	<u>2.7</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1	<u>1621</u>	<u>1.65"</u>	<u>91</u>
Flare #2	<u>—</u>	<u>—</u>	<u>—</u>
Flare #3	<u>1619</u>	<u>0.97"</u>	<u>784</u>

Blower Oper.	RPM	Hours
Blower #1	<u>—</u>	<u>—</u>
Blower #2	<u>2160</u>	<u>1393.9.3</u>
Blower #3	<u>—</u>	<u>—</u>

Air Compressor Hours: 10324.1

Google SCFM: am: 37 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>48.2</u>	<u>43.7</u>	<u>36.7</u>
CO2 %	<u>33.5</u>	<u>32.2</u>	<u>27.0</u>
O2 %	<u>1.5</u>	<u>1.0</u>	<u>5.6</u>
Vacuum	<u>-42.0"</u>	<u>-41.2"</u>	<u>-41.9"</u>
SCFM	<u>150</u>	<u>167</u>	<u>126</u>
Temperature	<u>71</u>	<u>71</u>	<u>69</u>

Time of Shutdown: 3:38 pm

Time of Start-Up: 3:40 pm

Duration of Shutdown/Malfunction: 2 min

Reason for Shutdown/Malfunction:

- Air-Compressor System
- Blower
- High Gas Flow
- High Temperature
- LEL
- Low Gas Flow
- Low Temperature
- UV Scanner System
- Power Failure
- Scheduled Preventive Maintenance

Google flow Spice

**PM MONITORING**

Name \_\_\_\_\_  
Arrival Time \_\_\_\_\_ Departure Time \_\_\_\_\_  
GEM# \_\_\_\_\_ Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3			

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			

Back Up Generator Running yes / no

Control Room Bypass yes / no

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed isolating all LFG in the piping system to avoid excess emissions, and notified the staff.

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.

yes / no

Comments and/or Description of Malfunction and Affected Equipment:

Time of Shutdown:	<u>3:38 pm</u>
Time of Start-Up:	<u>3:40 pm</u>
Duration of Shutdown/Malfunction:	<u>2 min</u>

Emission Exceedence: yes\* / no

SSM Plan Procedures Followed: yes / no\*

If SSM Plan Procedure not followed, explain procedure used:

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc. continued on the back side?

yes / no

Signature

Date 10/26/22

**SSM PLAN REPORT FORM /**  
**FLARE STATION DAILY CHECKLIST**  
 City of Mountain View Flare Station

Date 10/27/22  
 s m t w **th** f s

**AM MONITORING**

Name LEON VASQUEZ  
 Arrival Time 8:18 Am Departure Time 8:46 Am  
 GEM# GIV #4 Manometer (yes) no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>43.2</u>	<u>31.4</u>	<u>2.9</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1	<u>1612</u>	<u>1.59"</u>	<u>90</u>
Flare #2	<u>/</u>	<u>/</u>	<u>/</u>
Flare #3	<u>1615</u>	<u>1.62"</u>	<u>288</u>

Blower Oper.	RPM	Hours
Blower #1	<u>/</u>	<u>/</u>
Blower #2	<u>2100</u>	<u>63965.0</u>
Blower #3	<u>/</u>	<u>/</u>

Air Compressor Hours: 10333.6

Google SCFM: am: 27 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>48.3</u>	<u>44.1</u>	<u>34.7</u>
CO2 %	<u>33.3</u>	<u>32.6</u>	<u>25.4</u>
O2 %	<u>1.5</u>	<u>0.9</u>	<u>6.1</u>
Vacuum	<u>-42.0"</u>	<u>-41.1"</u>	<u>-41.7</u>
SCFM	<u>150</u>	<u>156</u>	<u>123</u>
Temperature	<u>70</u>	<u>72</u>	<u>68</u>

Time of Shutdown: 8:20 am

Time of Start-Up: 8:33 am

Duration of Shutdown/Malfunction: 13 min

Reason for Shutdown/Malfunction:

- Air-Compressor System
- Blower
- High Gas Flow
- High Temperature
- LEL
- Low Gas Flow
- Low Temperature
- UV Scanner System
- Power Failure
- Scheduled Preventive Maintenance

Take flare #1 out of  
Alarm

**PM MONITORING**

Name \_\_\_\_\_  
 Arrival Time \_\_\_\_\_ Departure Time \_\_\_\_\_  
 GEM# \_\_\_\_\_ Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3			

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			

Back Up Generator Running yes / no

Control Room Bypass yes / no

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed isolating all LFG in the piping system to avoid excess emissions, and notified the staff.

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.

Comments and/or Description of Malfunction and Affected Equipment:

yes / no

Emission Exceedence:

yes\* / no

SSM Plan Procedures Followed:


yes / no\*

If SSM Plan Procedure not followed, explain procedure used:

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc. continued on the back side?

yes / no

Signature 

Date 10/27/22

**SSM PLAN REPORT FORM /  
FLARE STATION DAILY CHECKLIST**  
City of Mountain View Flare Station

Date

October 30<sup>th</sup>, 2022

S m t w th f s

**AM MONITORING**

Name Jason R. Bean

Arrival Time 5:30 pm Departure Time 11:30 pm

GEM# EVN01N #4 Manometer  yes /  no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>43.3</u>	<u>32.1</u>	<u>3.1</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3	<u>1625</u>	<u>0.99"</u>	<u>264</u>

Blower Oper.	RPM	Hours
Blower #1		
Blower #2	<u>2100</u>	<u>30344.3</u>
Blower #3		

Air Compressor Hours: 10362.0

Google SCFM: am: 41 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>48.5</u>	<u>0.1</u>	<u>37.4</u>
CO2 %	<u>33.9</u>	<u>0.1</u>	<u>28.1</u>
O2 %	<u>1.6</u>	<u>20.1</u>	<u>5.5</u>
Vacuum	<u>-40.5"</u>	<u>-40.1"</u>	<u>-40.9"</u>
SCFM	<u>151</u>	<u>0</u>	<u>144</u>
Temperature	<u>70</u>	<u>70</u>	<u>63</u>

Time of Shutdown: 5:22 pm

Time of Start-Up: 7:25 pm

Duration of Shutdown/Malfunction: 2hr 3min

Reason for Shutdown/Malfunction:

- Air-Compressor System
- Blower
- High Gas Flow
- High Temperature
- LEL
- Low Gas Flow
- Low Temperature
- UV Scanner System
- Power Failure
- Scheduled Preventive Maintenance

2 Sumps out on Vista

**PM MONITORING**

Name \_\_\_\_\_

Arrival Time \_\_\_\_\_ Departure Time \_\_\_\_\_

GEM# \_\_\_\_\_ Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3			

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			

Back Up Generator Running yes /  no

Control Room Bypass yes /  no

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed isolating all LFG in the piping system to avoid excess emissions, and notified the staff.

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.

Comments and/or Description of Malfunction and Affected Equipment:

Emission Exceedence: yes\* /  no


SSM Plan Procedures Followed:  yes / no\*

If SSM Plan Procedure not followed, explain procedure used:

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc. continued on the back side?

yes /  no

Signature 

Date 10/30/22

**SSM PLAN REPORT FORM /  
FLARE STATION DAILY CHECKLIST**  
City of Mountain View Flare Station

Date October 31<sup>st</sup>, 2012  
s m t w th f s

**AM MONITORING**

Name Adrian Vega  
Arrival Time 8:30 AM Departure Time 9:39 AM  
GEM# ENCLISION # 4 Manometer yes no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>434</u>	<u>22.4</u>	<u>3.0</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2	<u>1600</u>	<u>0.84"</u>	<u>147</u>
Flare #3	<u>1629</u>	<u>1.06"</u>	<u>295</u>

Blower Oper.	RPM	Hours
Blower #1		
Blower #2		
Blower #3	<u>2100</u>	<u>30368.5</u>

Air Compressor Hours: 10364.1

Google SCFM: am: 30 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>48.5</u>	<u>44.7</u>	<u>38.2</u>
CO2 %	<u>34.9</u>	<u>33.6</u>	<u>28.2</u>
O2 %	<u>1.6</u>	<u>1.1</u>	<u>5.5</u>
Vacuum	<u>-41.5"</u>	<u>-40.7"</u>	<u>-41.3"</u>
SCFM	<u>150</u>	<u>235</u>	<u>120</u>
Temperature	<u>70</u>	<u>71</u>	<u>69</u>

Time of Shutdown: 8:31 AM

Time of Start-Up: 8:53 AM

Duration of Shutdown/Malfunction: 22 min

Reason for Shutdown/Malfunction:

- Air-Compressor System     Blower     High Gas Flow
- High Temperature     LEL     Low Gas Flow
- Low Temperature     UV Scanner System
- Power Failure     Scheduled Preventive Maintenance

Change from blower #2 to #3

**PM MONITORING**

Name \_\_\_\_\_  
Arrival Time \_\_\_\_\_ Departure Time \_\_\_\_\_  
GEM# \_\_\_\_\_ Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %

Flare Operation	Tc/inp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3			

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			

Back Up Generator Running yes / no

Control Room Bypass yes / no

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed isolating all LFG in the piping system to avoid excess emissions, and notified the staff.

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.

Comments and/or Description of Malfunction and Affected Equipment:

Time of Shutdown: 8:31 AM

Time of Start-Up: 8:53 AM

Duration of Shutdown/Malfunction: 22 min

Emission Exceedence: yes\* / no

SSM Plan Procedures Followed: yes / no\*

If SSM Plan Procedure not followed, explain procedure used:

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc. continued on the back side? yes / no

Signature

Date

**SSM PLAN REPORT FORM /  
FLARE STATION DAILY CHECKLIST**  
City of Mountain View Flare Station

Date November 1<sup>ST</sup>, 2022  
 S M  W Th F S

**AM MONITORING**

Name Jason R Bean  
 Arrival Time 5:24pm Departure Time 5:35pm  
 GEM# ENVIRON #4 Manometer  yes / no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>43.6</u>	<u>31.9</u>	<u>2.9</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1	<u>1615</u>	<u>1.26"</u>	<u>80</u>
Flare #2			
Flare #3	<u>1610</u>	<u>0.99"</u>	<u>284</u>

Blower Oper.	RPM	Hours
Blower #1		
Blower #2		
Blower #3	<u>2100</u>	<u>30388.5</u>

Air Compressor Hours: 10369.6

Google SCFM: am: 33 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>48.5</u>	<u>45.3</u>	<u>37.6</u>
CO2 %	<u>34.5</u>	<u>33.8</u>	<u>27.7</u>
O2 %	<u>1.8</u>	<u>1.1</u>	<u>5.7</u>
Vacuum	<u>-41.4"</u>	<u>-40.5"</u>	<u>-41.3"</u>
SCFM	<u>151</u>	<u>201</u>	<u>145</u>
Temperature	<u>70</u>	<u>71</u>	<u>69</u>

Time of Shutdown: 11:58 AM

Time of Start-Up: 12:05 pm

Duration of Shutdown/Malfunction: 7 min

Reason for Shutdown/Malfunction:

- Air-Compressor System
- Blower
- High Gas Flow
- High Temperature
- LEL
- Low Gas Flow
- Low Temperature
- UV Scanner System
- Power Failure
- Scheduled Preventive Maintenance

Vista flow meter.

**PM MONITORING**

Name \_\_\_\_\_  
 Arrival Time \_\_\_\_\_ Departure Time \_\_\_\_\_  
 GEM# \_\_\_\_\_ Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %

Flare Operation	Tel/hp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3			

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			

Back Up Generator Running yes /

Control Room Bypass yes /

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed isolating all LFG in the piping system to avoid excess emissions, and notified the staff.

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.

Comments and/or Description of Malfunction and Affected Equipment:

Emission Exceedence: yes\* /

SSM Plan Procedures Followed:  yes / no\*

If SSM Plan Procedure not followed, explain procedure used:

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc. continued on the back side? yes /

Jason R Bean

11/1/22

**SSM PLAN REPORT FORM /  
FLARE STATION DAILY CHECKLIST**  
City of Mountain View Flare Station

Date November 2<sup>nd</sup>, 2022  
 S m t w th f s

**AM MONITORING**

Name JASON R. BRAUN  
 Arrival Time 7:10 AM Departure Time 7:22 PM  
 GEM# ENVISION #4 Manometer  yes  no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>41.2</u>	<u>30.8</u>	<u>3.4</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1	<u>1632</u>	<u>1.60"</u>	<u>90</u>
Flare #2			
Flare #3	<u>1631</u>	<u>1.02"</u>	<u>289</u>

Blower Oper.	RPM	Hours
Blower #1		
Blower #2		
Blower #3	<u>2100</u>	<u>304142</u>

Air Compressor Hours: 10377.2

Google SCFM: am: 34 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>46.7</u>	<u>44.1</u>	<u>34.2</u>
CO2 %	<u>33.4</u>	<u>32.3</u>	<u>25.6</u>
O2 %	<u>2.3</u>	<u>1.2</u>	<u>6.4</u>
Vacuum	<u>-42.2"</u>	<u>-41.3"</u>	<u>-42.0"</u>
SCFM	<u>153</u>	<u>184</u>	<u>158</u>
Temperature	<u>69</u>	<u>70</u>	<u>68</u>

**PM MONITORING**

Name \_\_\_\_\_  
 Arrival Time \_\_\_\_\_ Departure Time \_\_\_\_\_  
 GEM# \_\_\_\_\_ Manometer \_\_\_\_\_ yes / no

LFG to Flares

CH4 %	CO2 %	O2 %

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3			

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			

Back Up Generator Running yes /

Control Room Bypass yes /

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed isolating all LFG in the piping system to avoid excess emissions, and notified the staff.

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.


Comments and/or Description of Malfunction and Affected Equipment:

Time of Shutdown:	<u>7:20 AM</u>
Time of Start-Up:	<u>8:51 AM</u>
Duration of Shutdown/Malfunction:	<u>1hr 31 min</u>

Reason for Shutdown/Malfunction:

- Air-Compressor System
- Blower
- High Gas Flow
- High Temperature
- LEL
- Low Gas Flow
- Low Temperature
- UV Scanner System
- Power Failure
- Scheduled Preventive Maintenance

Calibrate flow meters at  
inlets (Ristar)

Signature 

Date 11/2/22

Emission Exceedence: yes\* /

SSM Plan Procedures Followed:  yes / no\*

If SSM Plan Procedure not followed, explain procedure used:

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc. continued on the back side?

yes  no →

**SSM PLAN REPORT FORM /  
FLARE STATION DAILY CHECKLIST**  
City of Mountain View Flare Station

Date November 3<sup>rd</sup>, 2022

s m t w  f s

**AM MONITORING**

Name Adrian Vega

Arrival Time 7:00 AM Departure Time 7:15 AM

GEM# ENVISION #4 Manometer  yes / no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>41.1</u>	<u>30.7</u>	<u>3.5</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3	<u>1625</u>	<u>1.46"</u>	<u>3617</u>

Blower Oper.	RPM	Hours
Blower #1		
Blower #2		
Blower #3	<u>2100</u>	<u>304365</u>

Air Compressor Hours: 10385.1

Google SCFM: am: 33 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>47.1</u>	<u>42.9</u>	<u>32.7</u>
CO2 %	<u>33.8</u>	<u>32.3</u>	<u>24.8</u>
O2 %	<u>2.3</u>	<u>1.4</u>	<u>7.0</u>
Vacuum	<u>-42.7"</u>	<u>-41.1"</u>	<u>-41.9"</u>
SCFM	<u>155</u>	<u>113</u>	<u>164</u>
Temperature	<u>68</u>	<u>69</u>	<u>67</u>

**PM MONITORING**

Name \_\_\_\_\_

Arrival Time \_\_\_\_\_ Departure Time \_\_\_\_\_

GEM# \_\_\_\_\_ Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3			

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			

Back Up Generator Running yes /

Control Room Bypass yes /

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed isolating all LFG in the piping system to avoid excess emissions, and notified the staff.

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.

Comments and/or Description of Malfunction and Affected Equipment:

Time of Shutdown:	<u>7:24 AM</u>
Time of Start-Up:	<u>10:53 AM</u>
Duration of Shutdown/Malfunction:	<u>3hr 29min</u>

Emission Exceedence: yes\* /

SSM Plan Procedures Followed:  yes / no\*

If SSM Plan Procedure not followed, explain procedure used:

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc. continued on the back side?

yes /

Signature 

Date 11/03/22

**SSM PLAN REPORT FORM /  
FLARE STATION DAILY CHECKLIST**  
City of Mountain View Flare Station

Date November 16<sup>th</sup>, 2022  
s m t  th f s

**AM MONITORING**

Name Miguel Varela

Arrival Time 7:10 a.m. Departure Time 7:20 a.m.

GEM# ENVISION #4

Manometer

yes  no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>42.5</u>	<u>31.8</u>	<u>2.8</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1	/	/	/
Flare #2	/	/	/
Flare #3	<u>1619</u>	<u>1.50"</u>	<u>353</u>

Blower Oper.	RPM	Hours
Blower #1	/	/
Blower #2	/	/
Blower #3	<u>2100</u>	<u>30747.9</u>

Air Compressor Hours: 10503.7

Google SCFM: am: 33 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>46.5</u>	<u>42.1</u>	<u>36.3</u>
CO2 %	<u>34.5</u>	<u>32.5</u>	<u>26.3</u>
O2 %	<u>1.8</u>	<u>1.0</u>	<u>6.1</u>
Vacuum	<u>-42.6"</u>	<u>-41.7"</u>	<u>-42.3"</u>
SCFM	<u>175</u>	<u>232</u>	<u>128</u>
Temperature	<u>63</u>	<u>65</u>	<u>63</u>

**PM MONITORING**

Name \_\_\_\_\_

Arrival Time \_\_\_\_\_

Departure Time \_\_\_\_\_

GEM# \_\_\_\_\_

Manometer

yes / no

LFG to Flares

CH4 %	CO2 %	O2 %

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3			

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			

Back Up Generator Running  yes /  no

Control Room Bypass  yes /  no

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed isolating all LFG in the piping system to avoid excess emissions, and notified the staff.

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.

Comments and/or Description  
of Malfunction and Affected Equipment:

Time of Shutdown: 9:26 am

Time of Start-Up: 10:03 am

Duration of Shutdown/Malfunction: 37 min

Reason for Shutdown/Malfunction:

- Air-Compressor System
- Blower
- High Gas Flow
- High Temperature
- LEL
- Low Gas Flow
- Low Temperature
- UV Scanner System
- Power Failure
- Scheduled Preventive Maintenance

Clean Knockout

Emission Exceedence:  yes\* /  no\*


SSM Plan Procedures Followed:  yes /  no\*

If SSM Plan Procedure not followed, explain procedure used:

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other  
information, etc. continued on the back side?

yes /  no

Signature 

Date 11/16/22

**SSM PLAN REPORT FORM /  
FLARE STATION DAILY CHECKLIST**  
City of Mountain View Flare Station

Date 11-19-72  
s m t w th f  s

**AM MONITORING**

Name LEON ROSARIO  
Arrival Time 12:10 pm Departure Time 12:31 pm  
GEM# ENV # 4 Manometer yes  no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>92.8</u>	<u>31.7</u>	<u>7.7</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1	/	/	/
Flare #2	/	/	/
Flare #3	<u>1623</u>	<u>1.59"</u>	<u>360</u>

Blower Oper.	RPM	Hours
Blower #1	/	/
Blower #2	/	/
Blower #3	<u>2100</u>	<u>30823.3</u>

Air Compressor Hours: 10526.9

Google SCFM: am: 32 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>47.3</u>	<u>43.6</u>	<u>37.0</u>
CO2 %	<u>33.5</u>	<u>37.8</u>	<u>27.1</u>
O2 %	<u>1.5</u>	<u>0.9</u>	<u>5.9</u>
Vacuum	<u>-41.6"</u>	<u>-40.7"</u>	<u>-41.3"</u>
SCFM	<u>175</u>	<u>222</u>	<u>125</u>
Temperature	<u>63</u>	<u>66</u>	<u>67</u>

Time of Shutdown: 12:18 pm

Time of Start-Up: 12:30 pm

Duration of Shutdown/Malfunction: 12 min

Reason for Shutdown/Malfunction:

- Air-Compressor System
- Blower
- High Gas Flow
- High Temperature
- LEL
- Low Gas Flow
- Low Temperature
- UV Scanner System
- Power Failure
- Scheduled Preventive Maintenance

Reset flare #1

**PM MONITORING**

Name \_\_\_\_\_  
Arrival Time \_\_\_\_\_ Departure Time \_\_\_\_\_  
GEM# \_\_\_\_\_ Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3			

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			

Back Up Generator Running yes /  no

Control Room Bypass yes /  no

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed isolating all LFG in the piping system to avoid excess emissions, and notified the staff.

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.

Comments and/or Description of Malfunction and Affected Equipment:

Time of Shutdown:	<u>12:18 pm</u>
Time of Start-Up:	<u>12:30 pm</u>
Duration of Shutdown/Malfunction:	<u>12 min</u>

Emission Exceedence: yes\* /  no

SSM Plan Procedures Followed:  yes / no\*

If SSM Plan Procedure not followed, explain procedure used:

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc. continued on the back side? yes /  no



11/19/72

**SSM PLAN REPORT FORM /  
FLARE STATION DAILY CHECKLIST**  
City of Mountain View Flare Station

Date November 21<sup>st</sup>, 2022  
 S  M  T  W  TH  F  S

**AM MONITORING**

Name Adrian Vega  
 Arrival Time 6:40 AM Departure Time 7:00 AM  
 GEM# Envision #4 Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>48.8</u>	<u>31.3</u>	<u>3.0</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3	<u>1619</u>	<u>1.60"</u>	<u>3605</u>

Blower Oper.	RPM	Hours
Blower #1		
Blower #2		
Blower #3	<u>2100</u>	<u>30865.8</u>

Air Compressor Hours: 10539.6

Google SCFM: am: 34 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>48.3</u>	<u>48.4</u>	<u>33.8</u>
CO2 %	<u>34.7</u>	<u>32.9</u>	<u>24.6</u>
O2 %	<u>1.6</u>	<u>1.1</u>	<u>7.6</u>
Vacuum	<u>-42.4"</u>	<u>-41.5"</u>	<u>-42.3"</u>
SCFM	<u>175</u>	<u>236</u>	<u>124</u>
Temperature	<u>61</u>	<u>64</u>	<u>62</u>

**PM MONITORING**

Name \_\_\_\_\_  
 Arrival Time \_\_\_\_\_ Departure Time \_\_\_\_\_  
 GEM# \_\_\_\_\_ Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3			

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			

Back Up Generator Running yes / no

Control Room Bypass yes / no

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed isolating all LFG in the piping system to avoid excess emissions, and notified the staff.

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.

Comments and/or Description of Malfunction and Affected Equipment:

Time of Shutdown: <u>12:25 PM</u>
Time of Start-Up: <u>12:44 PM</u>
Duration of Shutdown/Malfunction: <u>21 min</u>

Reason for Shutdown/Malfunction:

- Air-Compressor System
- Blower
- High Gas Flow
- High Temperature
- LEL
- Low Gas Flow
- Low Temperature
- UV Scanner System
- Power Failure
- Scheduled Preventive Maintenance

Restart Flare #1

Emission Exceedence: yes\* / no

SSM Plan Procedures Followed: yes / no

If SSM Plan Procedure not followed, explain procedure used:

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc, continued on the back side? yes / no

Adrian Vega

11/21/22

**SSM PLAN REPORT FORM /  
FLARE STATION DAILY CHECKLIST**  
City of Mountain View Flare Station

Date November 28<sup>th</sup> 2022  
 s m t w th f s

**AM MONITORING**

Name JASON R. BEAN  
 Arrival Time 6:55AM Departure Time 7:00pm  
 GEM# ENVISION #4 Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>43.0</u>	<u>32.0</u>	<u>3.2</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1	<u>1661</u>	<u>2.14"</u>	<u>102</u>
Flare #2			
Flare #3	<u>1645</u>	<u>1.45"</u>	<u>338</u>

Blower Oper.	RPM	Hours
Blower #1		
Blower #2		
Blower #3	<u>2100</u>	<u>31035.5</u>

Air Compressor Hours: 10596.0

Google SCFM: am: 33 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>49.3</u>	<u>43.2</u>	<u>34.4</u>
CO2 %	<u>34.5</u>	<u>32.5</u>	<u>24.7</u>
O2 %	<u>1.3</u>	<u>0.9</u>	<u>7.4</u>
Vacuum	<u>-42.0"</u>	<u>-41.0"</u>	<u>-41.6"</u>
SCFM	<u>172</u>	<u>226</u>	<u>128</u>
Temperature	<u>60</u>	<u>63</u>	<u>62</u>

**PM MONITORING**

Name \_\_\_\_\_  
 Arrival Time \_\_\_\_\_ Departure Time \_\_\_\_\_  
 GEM# \_\_\_\_\_ Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3			

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			

Back Up Generator Running yes / no

Control Room Bypass yes / no

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed isolating all LFG in the piping system to avoid excess emissions, and notified the staff.

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.

Comments and/or Description of Malfunction and Affected Equipment:

Time of Shutdown:	<u>10:53pm</u>	<u>11:58pm</u>
Time of Start-Up:	<u>11:00 pm</u>	<u>12:05 pm</u>
Duration of Shutdown/Malfunction:	<u>7 min</u>	<u>7 min</u>

Emission Exceedence: yes\* / no


SSM Plan Procedures Followed: yes / no\*

If SSM Plan Procedure not followed, explain procedure used:

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc. continued on the back side?

yes / no

Signature 

Date 11/28/22

**SSM PLAN REPORT FORM /  
FLARE STATION DAILY CHECKLIST**  
City of Mountain View Flare Station

Date November 29<sup>th</sup>, 2022  
s m d w th f s

**AM MONITORING**

Name Miguel Varcia

Arrival Time 6:45 a.m. Departure Time 7:00 a.m.

GEM# ENVISION #4

Manometer  yes  no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>42.1</u>	<u>31.5</u>	<u>3.3</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1	<u>1626</u>	<u>1.54"</u>	<u>89</u>
Flare #2	/	/	/
Flare #3	<u>1627</u>	<u>0.99"</u>	<u>287</u>

Blower Oper.	RPM	Hours
Blower #1	/	/
Blower #2	/	/
Blower #3	<u>2100</u>	<u>31057.5</u>

Air Compressor Hours: 10603.8

Google SCFM: am: 34 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>48.2</u>	<u>47.2</u>	<u>33.8</u>
CO2 %	<u>34.1</u>	<u>32.5</u>	<u>24.3</u>
O2 %	<u>1.6</u>	<u>1.1</u>	<u>7.7</u>
Vacuum	<u>-42.7"</u>	<u>-41.8"</u>	<u>-42.6"</u>
SCFM	<u>176</u>	<u>234</u>	<u>133</u>
Temperature	<u>60</u>	<u>63</u>	<u>61</u>

Time of Shutdown: 12:50 pm

Time of Start-Up: 12:42 pm

Duration of Shutdown/Malfunction: 12 min

Reason for Shutdown/Malfunction:

- Air-Compressor System
- Blower
- High Gas Flow
- High Temperature
- LEL
- Low Gas Flow
- Low Temperature
- UV Scanner System
- Power Failure
- Scheduled Preventive Maintenance

Blower change #3 to  
#1

**PM MONITORING**

Name \_\_\_\_\_

Arrival Time \_\_\_\_\_ Departure Time \_\_\_\_\_

GEM# \_\_\_\_\_ Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3			

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			

Back Up Generator Running yes /  no

Control Room Bypass yes /  no

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed isolating all LFG in the piping system to avoid excess emissions, and notified the staff.

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.

Comments and/or Description of Malfunction and Affected Equipment:

Emission Exceedence: yes\* /  no

SSM Plan Procedures Followed:  yes / no\*

If SSM Plan Procedure not followed, explain procedure used:

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc. continued on the back side?

yes /  no



Date 11/29/22

**SSM PLAN REPORT FORM /  
FLARE STATION DAILY CHECKLIST**  
City of Mountain View Flare Station

Date 12-16-22  
s m t w th f s

**AM MONITORING**

Name Leon Rosario  
Arrival Time 8:30 Am Departure Time 8:47 AM  
GEM# ENV #4 Manometer yes no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>44.5</u>	<u>32.7</u>	<u>23</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3	<u>1624</u>	<u>1.30"</u>	<u>331</u>

Blower Oper.	RPM	Hours
Blower #1	<u>2100</u>	<u>19501.1</u>
Blower #2		
Blower #3		

Air Compressor Hours: 10734.3

Google SCFM: am: 32 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>45.9</u>	<u>42.7</u>	<u>49.8</u>
CO2 %	<u>37.6</u>	<u>32.2</u>	<u>29.9</u>
O2 %	<u>2.6</u>	<u>1.1</u>	<u>3.4</u>
Vacuum	<u>-42.7"</u>	<u>-41.4"</u>	<u>-42.6"</u>
SCFM	<u>187</u>	<u>235</u>	<u>102</u>
Temperature	<u>57</u>	<u>59</u>	<u>56</u>

**PM MONITORING**

Name \_\_\_\_\_  
Arrival Time \_\_\_\_\_ Departure Time \_\_\_\_\_  
GEM# \_\_\_\_\_ Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3			

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			

Back Up Generator Running yes / no

Control Room Bypass yes / no

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed isolating all LFG in the piping system to avoid excess emissions, and notified the staff.

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.

Comments and/or Description of Malfunction and Affected Equipment:

Time of Shutdown: 8:52 AM  
Time of Start-Up: 9:05 AM  
Duration of Shutdown/Malfunction: 23 min.

Emission Exceedence: yes\* / no

SSM Plan Procedures Followed: yes / no\*

If SSM Plan Procedure not followed, explain procedure used:

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc. continued on the back side? yes / no

Levi

12/16/22

Date

**SSM PLAN REPORT FORM /  
FLARE STATION DAILY CHECKLIST**  
City of Mountain View Flare Station

Date 12-20-22  
s m t w th f s

**AM MONITORING**

Name Leon Rosario  
Arrival Time 7:40 AM Departure Time 7:49 AM  
GEM# ENV # 4 Manometer (yes) no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>43.5</u>	<u>32.3</u>	<u>2.5</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1	<u>1681</u>	<u>207"</u>	<u>104</u>
Flare #2	<u>/</u>	<u>/</u>	<u>/</u>
Flare #3	<u>1664</u>	<u>1.90"</u>	<u>339</u>

Blower Oper.	RPM	Hours
Blower #1	<u>7100</u>	<u>19596.0</u>
Blower #2	<u>/</u>	<u>/</u>
Blower #3	<u>/</u>	<u>/</u>

Air Compressor Hours: 10765.1

Google SCFM: am: 32 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>44.1</u>	<u>41.6</u>	<u>42.8</u>
CO2 %	<u>32.9</u>	<u>37.9</u>	<u>29.8</u>
O2 %	<u>2.8</u>	<u>1.0</u>	<u>3.8</u>
Vacuum	<u>-42.5"</u>	<u>-41.6"</u>	<u>-42.4"</u>
SCFM	<u>184</u>	<u>239</u>	<u>80</u>
Temperature	<u>56</u>	<u>59</u>	<u>57</u>

**PM MONITORING**

Name \_\_\_\_\_  
Arrival Time \_\_\_\_\_ Departure Time \_\_\_\_\_  
GEM# \_\_\_\_\_ Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3			

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			

Back Up Generator Running yes / no

Control Room Bypass yes / no

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed isolating all LFG in the piping system to avoid excess emissions, and notified the staff.

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.

Comments and/or Description of Malfunction and Affected Equipment:

Time of Shutdown: 10:27 AM  
Time of Start-Up: 12:25 PM  
Duration of Shutdown/Malfunction: 1 hr 58 min

Reason for Shutdown/Malfunction:

- Air-Compressor System     Blower     High Gas Flow
- High Temperature     LEL     Low Gas Flow
- Low Temperature     UV Scanner System
- Power Failure     Scheduled Preventive Maintenance

Annual A/C maintenance  
by O&P compression

Signature 

Date 12/20/22

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc. continued on the back side?

yes / no

**CITY OF MOUNTAIN VIEW**  
**SHORELINE LANDFILL, FACILITY ID A2740**  
**LANDFILL GAS COLLECTION SYSTEM SHUTDOWN SUMMARY**  
**July 1 - December 31, 2022**

Well ID	Reasons for Shutdown *	Date: Time		Shutdown Duration Hours: Minutes
		Shutdown	Start-up	
VB-08	Install new valve assembly and testport	7/22/22 9:00 AM	7/22/22 11:00 AM	2:00
B-12	Install new saddle, valve, and testport	8/25/22 10:00 AM	8/25/22 12:30 PM	2:30
NEB-13	Install new valve assembly, testport, and lateral	9/8/22 10:00 AM	9/8/22 12:00 PM	2:00
NEB-03	Belly in lateral	9/12/22 8:00 AM	9/12/22 10:30 AM	2:30

- \* SSM plan report forms are attached for shutdown and startup events.
- \* Flare station shutdowns are included in section III – Emission control system shutdown

**SSM PLAN FORM / LANDFILL GAS REPAIR  
CITY OF MOUNTAIN VIEW**

**RESPONSE TO LANDFILL GAS COLLECTION AND EMISSIONS CONTROL SYSTEM LEAK?**

NO       YES

**If Yes, Concentration Above Background (ppmv)**

(If form completed in response to landfill gas collection and emissions control system leak,  
repair must be completed within 7 calendar days)

**DATE:** Identified 7/18/22      **TIME:** 8:00 am / pm  
Shutdown/Malfunction 7/22/22  
Startup 7/22/22  
Shutdown/Malfunction na na am / pm

**LOCATION:** Well # UB08      **SITE:** Back Nine  
Grid # WW-32      Vista  
Sump # na      Northshore  
Crittenden  
Cell 6A NE  
Front Nine  
Control Device

**AFFECTED EQUIPMENT**

**HEADER**

Gas Line  
Air Line  
Condensate Line  
Valve Assembly

**LATERAL**

Gas Line  
 Air Line  
 Condensate Line  
 Valve Assembly

Casing  
Pump  
**SUMP/DRAIN**  
 Pump

**DESCRIPTION/ PROCEDURE FOR THE REPAIR:** Excavate valve assembly and testport from well to header. Install new valve assembly, testport. Backfill. Set boxes and compact to grade.

Cause/Reason for Shutdown/Malfunction:

Lateral valve broken, crimp in testport

SSM Plan Procedures Followed:

yes     no

Explain procedure used, if SSM Plan Procedure not followed:

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

If Emission Exceedence and SSM Procedures are not followed it must be reported to EPA/BAAQMD within 48 hours per SSM plan  
(Report to EEC immediately and complete departure report)


Jean R. Bear  
Signature

7/22/22  
Date

JUL 22 2022  
ENGR. & ENVIRONMENTAL  
COMPLIANCE DIVISION

# VISTA - COMPLETE SYSTEM MAP

04/30/2018



<input type="checkbox"/> SURFACE SWEEP	<input type="checkbox"/> CAP INSPECTION	100' GRID	YES <input type="checkbox"/>	NO <input type="checkbox"/>	LEAKS DETECTED OR FOUND																														
Map Scale: 1" = 300' 0 62.5 125 250 Feet																																			
<table border="1"> <tr> <td colspan="2">Inspection Date :</td> <td colspan="2">Start Time :</td> <td colspan="2">Finish Time:</td> </tr> <tr> <td colspan="2">Weather</td> <td colspan="2"></td> <td colspan="2"></td> </tr> <tr> <td colspan="2">Instrument(s) Used</td> <td colspan="2"></td> <td colspan="2">JUL 22 2022</td> </tr> <tr> <td colspan="2">Inspector(s)</td> <td colspan="2"></td> <td colspan="2">ENGR. &amp; ENVIRONMENTAL</td> </tr> <tr> <td colspan="2">Comments</td> <td colspan="2">Location of Repair</td> <td colspan="2">COMPLIANCE DIVISION</td> </tr> </table>						Inspection Date :		Start Time :		Finish Time:		Weather						Instrument(s) Used				JUL 22 2022		Inspector(s)				ENGR. & ENVIRONMENTAL		Comments		Location of Repair		COMPLIANCE DIVISION	
Inspection Date :		Start Time :		Finish Time:																															
Weather																																			
Instrument(s) Used				JUL 22 2022																															
Inspector(s)				ENGR. & ENVIRONMENTAL																															
Comments		Location of Repair		COMPLIANCE DIVISION																															
<p>MPH WIND SPEED PPM GAS READING % CH4 GAS READING (L)=LOW AREA (C)=CRACK (O)=ODOR (W)=STANDING WATER</p>																																			



8:20



[Done](#)

8 of 16



**SSM PLAN FORM / LANDFILL GAS REPAIR  
CITY OF MOUNTAIN VIEW**

**RESPONSE TO LANDFILL GAS COLLECTION AND EMISSIONS CONTROL SYSTEM LEAK?**

NO \_\_\_\_\_ YES \_\_\_\_\_

**If Yes, Concentration Above Background (ppmv)** \_\_\_\_\_

(If form completed in response to landfill gas collection and emissions control system leak, repair must be completed within 7 calendar days)

<b>DATE:</b>	Identified <u>8/24/22</u>	<b>TIME:</b>	<u>700</u> am / pm
	<u>Shutdown/Malfunction</u> <u>8/25/22</u>	<u>1000</u> am / pm	
	Startup <u>8/25/22</u>	<u>1230</u> am / pm	
	Shutdown/Malfunction <u>na</u>	<u>na</u> am / pm	

<b>LOCATION:</b>	Well # <u>B-12</u>	<b>SITE:</b>	Back Nine
	Grid # <u>P-55</u>		Vista
	Sump # <u>na</u>		Northshore
			Crittenden
			Cell 6A NE
		<input checked="" type="checkbox"/>	Front Nine
			Control Device

**AFFECTED EQUIPMENT**

<b>HEADER</b>	<b>LATERAL</b>	<b>SUMP/DRAIN</b>
<input checked="" type="checkbox"/> Gas Line	<input checked="" type="checkbox"/> Gas Line	Casing
<input type="checkbox"/> Air Line	<input type="checkbox"/> Air Line	Pump
<input type="checkbox"/> Condensate Line	<input type="checkbox"/> Condensate Line	
<input type="checkbox"/> Valve Assembly	<input checked="" type="checkbox"/> Valve Assembly	Pump

**DESCRIPTION/ PROCEDURE FOR THE REPAIR:** Excavate lateral valve and testport. to header. Install new saddle, valve and testport. Reset boxes compact dirt and set to grade.

Cause/Reason for Shutdown/Malfunction:

Lateral valve broken

SSM Plan Procedures Followed:

yes no

Explain procedure used, if SSM Plan Procedure not followed:

If Emmission Exceedence and SSM Procedures are not followed it must be reported to EPA/BAAQMD within 48 hours per SSM plan

**(Report to EEC immediately and complete departure report)**

Jaron R. Bean  
Signature


8/30/22  
Date

AUG 30 2022

ENGR. & ENVIRONMENTAL  
COMPLIANCE DIVISION

# FRONT NINE - COMPLETE SYSTEM MAP

04/30/2018



<input type="checkbox"/> SURFACE SWEEP	<input type="checkbox"/> CAP INSPECTION	100' GRID	YES <input type="checkbox"/>	NO <input type="checkbox"/>	LEAKS DETECTED OR FOUND
Inspection Date : <b>AUG 30 2022</b>					
Start Time : <b>10:00 AM</b>					
Finish Time: <b>12:00 PM</b>					
Weather					
Instrument(s) Used					
Inspector(s)					
Comments <b>Location of Repair</b> ENGR. & ENVIRONMENTAL COMPLIANCE DIVISION					
(L)=LOW AREA (C)=CRACK					
(O)=ODOR (W)=STANDING WATER					



**SSM PLAN FORM / LANDFILL GAS REPAIR**  
**CITY OF MOUNTAIN VIEW**

**RESPONSE TO LANDFILL GAS COLLECTION AND EMISSIONS CONTROL SYSTEM LEAK?**

NO       YES

**If Yes, Concentration Above Background (ppmv)**

(If form completed in response to landfill gas collection and emissions control system leak,  
repair must be completed within 7 calendar days)

**DATE:** Identified 9/1/22      **TIME:** 7:00 am / pm  
Shutdown/Malfunction 9/8/22      10:00 am / pm  
Startup 9/8/22      12:00 am / pm  
Shutdown/Malfunction na      na am / pm

**LOCATION:** Well # NFB-13      **SITE:** \_\_\_\_\_ Back Nine  
Grid # 0-63      \_\_\_\_\_ Vista  
Sump # \_\_\_\_\_ Northshore  
Crittenden  
 Cell 6A NE  
Front Nine  
Control Device

**AFFECTED EQUIPMENT**

<u>HEADER</u>	<u>LATERAL</u>	<u>SUMP/DRAIN</u>
Gas Line	<input checked="" type="checkbox"/> Gas Line	<input checked="" type="checkbox"/> Casing
Air Line	<input type="checkbox"/> Air Line	<input type="checkbox"/> Pump
Condensate Line	<input type="checkbox"/> Condensate Line	
Valve Assembly	<input checked="" type="checkbox"/> Valve Assembly	<input type="checkbox"/> Pump

**DESCRIPTION/ PROCEDURE FOR THE REPAIR:** Excavate well, valve, test port and lateral. Raise well install new valve assembly test port and lateral. Backfill, compact and set boxes to grade.

Cause/Reason for Shutdown/Malfunction:

SSM Plan Procedures Followed:

yes  no

Explain procedure used, if SSM Plan Procedure not followed:


Break at valve and test port depression around well.

If Emission Exceedence and SSM Procedures are not followed it must be reported to EPA/BAAQMD within 48 hours per SSM plan

**(Report to EEC immediately and complete departure report)**

  
Signature

9/8/22  
Date



**SSM PLAN FORM / LANDFILL GAS REPAIR  
CITY OF MOUNTAIN VIEW**

**RESPONSE TO LANDFILL GAS COLLECTION AND EMISSIONS CONTROL SYSTEM LEAK?**

NO       YES

**If Yes, Concentration Above Background (ppmv)**

(If form completed in response to landfill gas collection and emissions control system leak,  
repair must be completed within 7 calendar days)

**DATE:** Identified 9/8/22      **TIME:** 7:00 am / pm  
Shutdown/Malfunction 9/8/22      8:00 am / pm  
Startup 9/8/22      10:30 am / pm  
Shutdown/Malfunction na      na am / pm

**LOCATION:** Well # NGB-03      **SITE:** Back Nine  
Grid # G-70      Vista  
Sump # \_\_\_\_\_ Northshore  
Crittenden  
 Cell 6A NE  
Front Nine  
Control Device

**AFFECTED EQUIPMENT**

**HEADER**  
Gas Line      **LATERAL**  
Air Line      Gas Line  
Condensate Line      Air Line  
Valve Assembly      Condensate Line  
Valve Assembly      Valve Assembly

Casing  
 Pump  
**SUMP/DRAIN**  
 Pump

**DESCRIPTION/ PROCEDURE FOR THE REPAIR:** Excavate boxes. Raise grill, install new tee, valve, support and lateral. Backfill, compact and set boxes to grade

Cause/Reason for Shutdown/Malfunction:

Belly in lateral

SSM Plan Procedures Followed:

yes    no

Explain procedure used, if SSM Plan Procedure not followed:

If Emission Exceedence and SSM Procedures are not followed it must be reported to EPA/BAAQMD within 48 hours per SSM plan


(Report to EEC immediately and complete departure report)

  
Signature

9/8/22  
Date

# 6A NORTHEAST - COMPLETE SYSTEM MAP

04/30/2018



■ CONDENSATE PUMP STATION      ▽ HC TRANSITION  
 ♦ CONNECTION POINT      ● LGFWELL      ○ PROBES\_REGULATORY      ○ VENTTRENCHBOXES      - - - AIR\_CONDEN\_LINES  
 ] END CAP      ▲ HEADERVERVALVE      + SUMP      ○ VENTTRENCHSUMP      — LFLATERALS  
 ■ PROBES\_OUTSIDE      ▵ LFGLATERALVALVE      □ TESTPORT      — HEADER  
 ■ PROBES\_INSIDE      ▲ VALVE      — HEADER\_10\_0\_1\_SHP      — PROPERTY\_BOUND  
 ■ — HORIZONTAL HEADER      — VENT TRENCHBOXES

Map Scale: 1" = 375'

N

SURFACE SWEEP       CAP INSPECTION      100' GRID      YES  NO  LEAKS DETECTED OR FOUND

\_\_\_\_\_ MPH WIND SPEED

\_\_\_\_\_ PPM GAS READING

\_\_\_\_\_ % CH4 GAS READING

①=LOW AREA      ②=ODOR

③=CRACK      ④=STANDING WATER

Inspection Date :		Start Time :	Finish Time:
Weather			
Instrument(s) Used			
Inspector(s)			
Comments			



# **BAAQMD RULE 8-34 REPORT**

**2022 – SECOND INCREMENT**

**CITY OF MOUNTAIN VIEW  
SHORELINE LANDFILL  
MOUNTAIN VIEW, CALIFORNIA  
(FACILITY NO. A2740)**

## **SECTION I**

### **SOURCE PERFORMANCE TEST REPORT**

**CITY OF MOUNTAIN VIEW  
SHORELINE LANDFILL, FACILITY ID A2740  
SOURCE PERFORMANCE TEST  
July 1 - December 31, 2022**

The annual source performance tests for the three flares and two microturbines located at the City of Mountain View Closed Shoreline Landfill Facility was performed on February 8, 9 and 11, 2022, and the source performance test report was included in the 2022 First Increment Semi-Annual Report.

## **SECTION II**

**LANDFILL GAS COLLECTION SYSTEM DOWNTIME**

**CITY OF MOUNTAIN VIEW**  
**SHORELINE LANDFILL, FACILITY ID A2740**  
**LANDFILL GAS COLLECTION SYSTEM SHUTDOWN SUMMARY**  
**July 1 - December 31, 2022**

Well ID	Reasons for Shutdown *	Date: Time		Shutdown Duration Hours: Minutes
		Shutdown	Start-up	
VB-08	Install new valve assembly and testport	7/22/22 9:00 AM	7/22/22 11:00 AM	2:00
B-12	Install new saddle, valve, and testport	8/25/22 10:00 AM	8/25/22 12:30 PM	2:30
NEB-13	Install new valve assembly, testport, and lateral	9/8/22 10:00 AM	9/8/22 12:00 PM	2:00
NEB-03	Belly in lateral	9/12/22 8:00 AM	9/12/22 10:30 AM	2:30

- \* SSM plan report forms are attached for shutdown and startup events.
- \* Flare station shutdowns are included in section III – Emission control system shutdown

**SSM PLAN FORM / LANDFILL GAS REPAIR  
CITY OF MOUNTAIN VIEW**

**RESPONSE TO LANDFILL GAS COLLECTION AND EMISSIONS CONTROL SYSTEM LEAK?**

NO       YES

**If Yes, Concentration Above Background (ppmv)**

(If form completed in response to landfill gas collection and emissions control system leak, repair must be completed within 7 calendar days)

<b>DATE:</b>	Identified <u>7/18/22</u>	<b>TIME:</b>	<u>8:00</u> <input checked="" type="radio"/> am / pm
	Shutdown/Malfunction <u>7/22/22</u>		<u>9:00</u> <input checked="" type="radio"/> am / pm
	Startup <u>7/22/22</u>		<u>11:00</u> <input checked="" type="radio"/> am / pm
	Shutdown/Malfunction <u>na</u>		<u>na</u> am / pm

<b>LOCATION:</b>	Well # <u>UB08</u>	<b>SITE:</b>	Back Nine
	Grid # <u>WW-32</u>		<input checked="" type="checkbox"/> Vista
	Sump # <u>na</u>		Northshore
			Crittenden
			Cell 6A NE
			Front Nine
			Control Device

**AFFECTED EQUIPMENT**

<b>HEADER</b>	<b>LATERAL</b>	<b>SUMP/DRAIN</b>
Gas Line	<input checked="" type="checkbox"/> Gas Line	Casing
Air Line	<input type="checkbox"/> Air Line	Pump
Condensate Line	<input type="checkbox"/> Condensate Line	
Valve Assembly	<input checked="" type="checkbox"/> Valve Assembly	Pump

**DESCRIPTION/ PROCEDURE FOR THE REPAIR:** Excavate valve assembly and testport from well to header. Install new valve assembly, testport. Backfill. Set boxes and compact to grade.

Cause/Reason for Shutdown/Malfunction:

Lateral valve broken, crimp in testport

SSM Plan Procedures Followed:

yes    no

Explain procedure used, if SSM Plan Procedure not followed:

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

If Emission Exceedence and SSM Procedures are not followed it must be reported to EPA/BAAQMD within 48 hours per SSM plan  
(Report to EEC immediately and complete departure report)

Jean R. Bear  
Signature


7/22/22  
Date

JUL 22 2022

ENGR. & ENVIRONMENTAL  
COMPLIANCE DIVISION

# VISTA - COMPLETE SYSTEM MAP

04/30/2018



■ CONDENSATE PUMP STATION      ▽ HC TRANSITION      ▶ LGGLATERALVALVE      ○ PROBES\_INSIDE      ■ SUMP      ○ VENTTRENCHBOXES      - - - AIR\_CONDEN\_LINES      — HORIZONTAL HEADER      — VENTTRENCHBOXES  
 ♦ CONNECTION POINT      □ HEADERVERVALVE      ● LFGWELL      ○ PROBES\_OUTSIDE      ▲ TESTPORT      ○ VENTTRENCHSUMP      — HEADER      — LGGLATERALS  
 ] END CAP      + PIEZOMETER      ○ PROBES\_REGULATORY      ▷ VALVE      — HEADER\_10\_01\_SHP      PROPERTY\_BOUND      Map Scale: 1" = 300'  
 0 62.5 125 250 Feet

SURFACE SWEEP     CAP INSPECTION    100' GRID    YES  NO  LEAKS DETECTED OR FOUND

— MPH WIND SPEED

— PPM GAS READING

— % CH4 GAS READING

(L)=LOW AREA    (C)=CRACK

(O)=ODOR    (W)=STANDING WATER

Inspection Date :		Start Time :	Finish Time:
Weather			
Instrument(s) Used		JUL 22 2022	
Inspector(s)		ENGR. & ENVIRONMENTAL	
Comments		COMPLIANCE DIVISION	

*Location of Repair*



8:20



[Done](#)

8 of 16



**SSM PLAN FORM / LANDFILL GAS REPAIR  
CITY OF MOUNTAIN VIEW**

**RESPONSE TO LANDFILL GAS COLLECTION AND EMISSIONS CONTROL SYSTEM LEAK?**

NO \_\_\_\_\_ YES \_\_\_\_\_

**If Yes, Concentration Above Background (ppmv)** \_\_\_\_\_

(If form completed in response to landfill gas collection and emissions control system leak, repair must be completed within 7 calendar days)

<b>DATE:</b>	Identified <u>8/24/22</u>	<b>TIME:</b>	<u>700</u> am / pm
	<u>Shutdown/Malfunction</u> <u>8/25/22</u>	<u>1000</u> am / pm	
	Startup <u>8/25/22</u>	<u>1230</u> am / pm	
	Shutdown/Malfunction <u>na</u>	<u>na</u> am / pm	

<b>LOCATION:</b>	Well # <u>B-12</u>	<b>SITE:</b>	Back Nine
	Grid # <u>P-55</u>		Vista
	Sump # <u>na</u>		Northshore
			Crittenden
			Cell 6A NE
		<input checked="" type="checkbox"/>	Front Nine
			Control Device

**AFFECTED EQUIPMENT**

<b>HEADER</b>	<b>LATERAL</b>	<b>SUMP/DRAIN</b>
<input checked="" type="checkbox"/> Gas Line	<input checked="" type="checkbox"/> Gas Line	Casing
<input type="checkbox"/> Air Line	<input type="checkbox"/> Air Line	Pump
<input type="checkbox"/> Condensate Line	<input type="checkbox"/> Condensate Line	
<input type="checkbox"/> Valve Assembly	<input checked="" type="checkbox"/> Valve Assembly	Pump

**DESCRIPTION/ PROCEDURE FOR THE REPAIR:** Excavate lateral valve and testport. to header. Install new saddle, valve and testport. Reset boxes compact dirt and set to grade.

Cause/Reason for Shutdown/Malfunction:

Lateral valve broken

SSM Plan Procedures Followed:

yes no

Explain procedure used, if SSM Plan Procedure not followed:

If Emmission Exceedence and SSM Procedures are not followed it must be reported to EPA/BAAQMD within 48 hours per SSM plan

**(Report to EEC immediately and complete departure report)**

Jaron R. Bean  
Signature


8/30/22  
Date

AUG 30 2022

ENGR. & ENVIRONMENTAL  
COMPLIANCE DIVISION

# FRONT NINE - COMPLETE SYSTEM MAP

04/30/2018



<input type="checkbox"/> SURFACE SWEEP	<input type="checkbox"/> CAP INSPECTION	100' GRID	YES <input type="checkbox"/>	NO <input type="checkbox"/>	LEAKS DETECTED OR FOUND																																				
<table border="1"> <tr> <td colspan="2">Inspection Date :</td> <td colspan="2">Start Time :</td> <td colspan="2">Finish Time:</td> </tr> <tr> <td colspan="2">AUG 30 2022</td> <td colspan="2"></td> <td colspan="2"></td> </tr> <tr> <td colspan="2">Weather</td> <td colspan="2"></td> <td colspan="2"></td> </tr> <tr> <td colspan="2">Instrument(s) Used</td> <td colspan="2"></td> <td colspan="2"></td> </tr> <tr> <td colspan="2">Inspector(s)</td> <td colspan="2"></td> <td colspan="2"></td> </tr> <tr> <td colspan="2">Comments</td> <td colspan="2"><i>Location of Repair</i></td> <td colspan="2">ENGR. &amp; ENVIRONMENTAL COMPLIANCE DIVISION</td> </tr> </table>						Inspection Date :		Start Time :		Finish Time:		AUG 30 2022						Weather						Instrument(s) Used						Inspector(s)						Comments		<i>Location of Repair</i>		ENGR. & ENVIRONMENTAL COMPLIANCE DIVISION	
Inspection Date :		Start Time :		Finish Time:																																					
AUG 30 2022																																									
Weather																																									
Instrument(s) Used																																									
Inspector(s)																																									
Comments		<i>Location of Repair</i>		ENGR. & ENVIRONMENTAL COMPLIANCE DIVISION																																					
MPH WIND SPEED PPM GAS READING % CH4 GAS READING (L)=LOW AREA (C)=CRACK (O)=ODOR (W)=STANDING WATER																																									



**SSM PLAN FORM / LANDFILL GAS REPAIR**  
**CITY OF MOUNTAIN VIEW**

**RESPONSE TO LANDFILL GAS COLLECTION AND EMISSIONS CONTROL SYSTEM LEAK?**

NO       YES

**If Yes, Concentration Above Background (ppmv)**

(If form completed in response to landfill gas collection and emissions control system leak,  
repair must be completed within 7 calendar days)

**DATE:** Identified 9/1/22      **TIME:** 7:00 am / pm

Shutdown/Malfunction 9/8/22      10:00 am / pm  
Startup 9/8/22      12:00 am / pm  
Shutdown/Malfunction na      na am / pm

**LOCATION:** Well # NFB-13      **SITE:** Back Nine  
Grid # 0-63      Vista  
Sump # \_\_\_\_\_  
Northshore  
Crittenden  
 Cell 6A NE  
Front Nine  
Control Device

**AFFECTED EQUIPMENT**

<u>HEADER</u>	<u>LATERAL</u>	<u>SUMP/DRAIN</u>
Gas Line	<input checked="" type="checkbox"/> Gas Line	<input checked="" type="checkbox"/> Casing
Air Line	<input type="checkbox"/> Air Line	<input type="checkbox"/> Pump
Condensate Line	<input type="checkbox"/> Condensate Line	
Valve Assembly	<input checked="" type="checkbox"/> Valve Assembly	<input type="checkbox"/> Pump

**DESCRIPTION/ PROCEDURE FOR THE REPAIR:** Excavate well, valve, test port and lateral. Raise well install new valve assembly test port and lateral. Backfill, compact and set boxes to grade.

Cause/Reason for Shutdown/Malfunction:

SSM Plan Procedures Followed:

yes     no

Explain procedure used, if SSM Plan Procedure not followed:

Break at valve and test port depression around well.

If Emission Exceedence and SSM Procedures are not followed it must be reported to EPA/BAAQMD within 48 hours per SSM plan

**(Report to EEC immediately and complete departure report)**

  
Signature

9/1/22  
Date



**SSM PLAN FORM / LANDFILL GAS REPAIR  
CITY OF MOUNTAIN VIEW**

**RESPONSE TO LANDFILL GAS COLLECTION AND EMISSIONS CONTROL SYSTEM LEAK?**

NO       YES

**If Yes, Concentration Above Background (ppmv)**

(If form completed in response to landfill gas collection and emissions control system leak, repair must be completed within 7 calendar days)

**DATE:** Identified 9/8/22      **TIME:** 7:00 am / pm  
Shutdown/Malfunction 9/8/22      8:00 am / pm  
Startup 9/8/22      10:30 am / pm  
Shutdown/Malfunction na      na am / pm

**LOCATION:** Well # NGB-03      **SITE:** Back Nine  
Grid # G-70      Vista  
Sump # \_\_\_\_\_ Northshore  
Crittenden  
Cell 6A NE  
Front Nine  
Control Device

**AFFECTED EQUIPMENT**

<b>HEADER</b>	<b>LATERAL</b>
Gas Line	<input checked="" type="checkbox"/> Gas Line
Air Line	<input checked="" type="checkbox"/> Air Line
Condensate Line	<input checked="" type="checkbox"/> Condensate Line
Valve Assembly	<input checked="" type="checkbox"/> Valve Assembly

<b>SUMP/DRAIN</b>
<input checked="" type="checkbox"/> Casing
<input checked="" type="checkbox"/> Pump
Pump

**DESCRIPTION/ PROCEDURE FOR THE REPAIR:** Excavate boxes. Raise Grill, install new Tee, valve, support and lateral. Backfill, compact and set boxes to grade

Cause/Reason for Shutdown/Malfunction:

Belly in lateral

SSM Plan Procedures Followed:

yes     no

Explain procedure used, if SSM Plan Procedure not followed:

If Emission Exceedence and SSM Procedures are not followed it must be reported to EPA/BAAQMD within 48 hours per SSM plan


(Report to EEC immediately and complete departure report)

Jean R. Bean  
Signature

9/8/22  
Date

# 6A NORTHEAST - COMPLETE SYSTEM MAP

04/30/2018



■ CONDENSATE PUMP STATION      ▽ HC TRANSITION  
 ♦ CONNECTION POINT      ● LGFWELL      ○ PROBES\_REGULATORY      ○ VENTTRENCHBOXES      - - - AIR\_CONDEN\_LINES  
 ] END CAP      ▲ HEADERVERVALVE      + PIEZOMETER      □ SUMP      ○ VENTTRENCHSUMP      — LFLATERALS  
 ] PROBE\_3\_INSIDE      □ LFGLATERALVALVE      △ TESTPORT      ■ PROPERTY\_BOUND  
 ○ PROBES\_OUTSIDE      ▷ VALVE      ■ HEADER      — HEADER\_10\_0\_3HP      □ VENT TRENCHBOXES  
 ■ HORIZONTAL HEADER

Map Scale: 1" = 375'      N

SURFACE SWEEP       CAP INSPECTION      100' GRID      YES  NO  LEAKS DETECTED OR FOUND

\_\_\_\_ MPH WIND SPEED

\_\_\_\_ PPM GAS READING

\_\_\_\_ % CH4 GAS READING

(L)=LOW AREA      (C)=CRACK

(O)=ODOR      (W)=STANDING WATER

Inspection Date :		Start Time :	Finish Time:
Weather			
Instrument(s) Used			
Inspector(s)			
Comments			



## **SECTION III**

### **EMISSION CONTROL SYSTEM DOWNTIME**

**CITY OF MOUNTAIN VIEW**  
**SHORELINE LANDFILL, FACILITY ID A2740**  
**EMISSION CONTROL SYSTEM SHUTDOWN SUMMARY**  
**July 1 - December 31, 2022**

Period	Duration Hours: Minutes
<b>Total shutdown duration from January 1 - June 30, 2022</b>	<b>17:32</b>
<b>Total shutdown duration from July 1 - December 31, 2022</b>	<b>19:36</b>
<b>Total shutdown duration from January 1 - December 31, 2022</b>	<b>37:08</b>

Date	Description * (July 1 - December 31, 2022) Maintenance, operation and repairs requiring Flare station Shutdown	Shutdown	Start up	Duration Hours: Minutes
7/26/2022	Telstar to replace controller	8:53 PM	9:24 PM	0:31
7/27/2022	Clean separator & clean and replace flame detection bulbs	7:43 AM	10:57 AM	3:14
8/2/2022	Clean honeywell U.V. bulbs	9:24 AM	9:29 AM	0:05
9/8/2022	Change out belt on air compressor	1:48 PM	2:27 PM	0:39
9/19/2022	Blower change from #1 to #2	9:00 AM	9:30 AM	0:30
9/25/2022	High temperature for Flare #3	6:24 PM	8:03 PM	1:39
10/18/2022	Install Google/Bloomenergy flow meter	11:53 AM	11:59 AM	0:06
10/24/2022	Checked off header by liquid	7:42 AM	8:42 AM	1:00
10/25/2022	Low gas flow	11:24 AM	11:26 AM	0:02
10/25/2022	Low gas flow	11:45 AM	11:53 AM	0:08
10/26/2022	Google/Bloomenergy flow spike	3:38 PM	3:40 PM	0:02
10/27/2022	Take flow #1 out of alarm	8:20 AM	8:33 AM	0:13
10/30/2022	Take out two (2) sumps on Vista	5:22 PM	7:25 PM	2:03
10/31/2022	Blower change from #2 to #3	8:31 AM	8:53 AM	0:22
11/1/2022	Low gas flow	11:58 PM	12:05 AM	0:07
11/2/2022	Calibrate flow meters at inlets (Telstar)	7:20 AM	8:51 AM	1:31
11/3/2022	Telstar to replace flow meter at Vista	7:24 AM	10:53 AM	3:29
11/16/2022	Clean knockout	9:26 AM	10:03 AM	0:37
11/19/2022	Reset Flare #1	12:18 PM	12:30 PM	0:12
11/21/2022	Restart Flare #1	12:25 PM	12:44 PM	0:19
11/28/2022	Low gas flow	10:53 PM	11:00 PM	0:07
11/28/2022	Low gas flow	11:58 PM	12:05 AM	0:07
11/29/2022	Blower change from #3 to #1	12:30 PM	12:42 PM	0:12
12/16/2022	Restart Flare #1	8:42 AM	9:05 AM	0:23
12/20/2022	Annual air compressor maintenance	10:27 AM	12:25 PM	1:58

\* - Monitoring records are attached.

**SSM PLAN REPORT FORM /  
FLARE STATION DAILY CHECKLIST**  
City of Mountain View Flare Station

Date July 26<sup>th</sup>, 2022  
S M T W Th F S

**AM MONITORING**

Name Jason R. Bean  
Arrival Time 7:20 AM Departure Time 7:30 AM  
GEM# ENVISION #4 Manometer  yes /  no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>44.6</u>	<u>32.2</u>	<u>1.8</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1	<u>1632</u>	<u>2.84"</u>	<u>116</u>
Flare #2	<u>1632</u>	<u>2.01"</u>	<u>228</u>
Flare #3			

Blower Oper.	RPM	Hours
Blower #1		
Blower #2		
Blower #3	<u>2100</u>	<u>30343.8</u>

Air Compressor Hours: 9556.2

Google SCFM: am: 27 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>46.9</u>	<u>44.7</u>	<u>42.0</u>
CO2 %	<u>33.0</u>	<u>31.4</u>	<u>29.5</u>
O2 %	<u>1.3</u>	<u>0.4</u>	<u>3.5</u>
Vacuum	<u>-40.2"</u>	<u>-39.4"</u>	<u>-40.0"</u>
SCFM	<u>154</u>	<u>151</u>	<u>119</u>
Temperature	<u>77</u>	<u>77</u>	<u>74</u>

Time of Shutdown: 8:53 AM

Time of Start-Up: 9:24 AM

Duration of Shutdown/Malfunction: 31 min

Reason for Shutdown/Malfunction: REPLACED CONTROLLER

- Air-Compressor System
- Blower
- High Gas Flow
- High Temperature
- LEL
- Low Gas Flow
- Low Temperature
- UV Scanner System
- Power Failure
- Scheduled Preventive Maintenance

TelStar here to replace controller

**PM MONITORING**

Name \_\_\_\_\_  
Arrival Time \_\_\_\_\_ Departure Time \_\_\_\_\_  
GEM# \_\_\_\_\_ Manometer \_\_\_\_\_ yes / no

LFG to Flares

CH4 %	CO2 %	O2 %

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3			

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			

Back Up Generator Running yes /  no

Control Room Bypass yes /  no

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed isolating all LFG in the piping system to avoid excess emissions, and notified the staff.

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.

Comments and/or Description of Malfunction and Affected Equipment:

Emission Exceedence: yes\* /  no

SSM Plan Procedures Followed:  yes\*  no\*

If SSM Plan Procedure not followed, explain procedure used:

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc. continued on the back side?

yes /  no

Signature 

Date 7/26/22

**SSM PLAN REPORT FORM /  
FLARE STATION DAILY CHECKLIST**  
City of Mountain View Flare Station

Date

July 27<sup>th</sup>, 2022

s m t w th f s

**AM MONITORING**

Name Jason R. Bean

Arrival Time 6:38 AM Departure Time 6:48 AM

GEM# EN001N #4 Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>44.5</u>	<u>31.1</u>	<u>1.8</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1	<u>1620</u>	<u>1.54"</u>	<u>90</u>
Flare #2			
Flare #3	<u>1621</u>	<u>0.99"</u>	<u>280</u>

Blower Oper.	RPM	Hours
Blower #1		
Blower #2		
Blower #3	<u>2100</u>	<u>80366.7</u>

Air Compressor Hours: 9564.2

Google SCFM: am: 16 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>46.4</u>	<u>44.6</u>	<u>42.4</u>
CO2 %	<u>32.7</u>	<u>31.4</u>	<u>34.4</u>
O2 %	<u>13</u>	<u>0.7</u>	<u>3.6</u>
Vacuum	<u>-41.0"</u>	<u>-40.2"</u>	<u>-40.9"</u>
SCFM	<u>155</u>	<u>152</u>	<u>122</u>
Temperature	<u>77</u>	<u>77</u>	<u>74</u>

**PM MONITORING**

Name \_\_\_\_\_

Arrival Time \_\_\_\_\_ Departure Time \_\_\_\_\_

GEM# \_\_\_\_\_ Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3			

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			

Back Up Generator Running yes / no

Control Room Bypass yes / no

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed isolating all LFG in the piping system to avoid excess emissions, and notified the staff.

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.

Comments and/or Description of Malfunction and Affected Equipment:

Time of Shutdown: 7:43 AM

Time of Start-Up: 10:57 AM

Duration of Shutdown/Malfunction: 3hr 14 min

Reason for Shutdown/Malfunction:

- Air-Compressor System
- Blower
- High Gas Flow
- High Temperature
- LEL
- Low Gas Flow
- Low Temperature
- UV Scanner System
- Power Failure
- Scheduled Preventive Maintenance

Clean Separator, Clean and replace Flame detector bulbs

Signature Jason R. Bean

Date 7/27/22

Emission Exceedence: yes\* / no

SSM Plan Procedures Followed: yes / no\*

If SSM Plan Procedure not followed, explain procedure used:

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc. continued on the back side?

yes / no

**SSM PLAN REPORT FORM /  
FLARE STATION DAILY CHECKLIST**  
City of Mountain View Flare Station

Date 8-2-22  
s m  w th f s

**AM MONITORING**

Name LEON ROSARIO  
Arrival Time 6:48 AM Departure Time 6:56 AM  
GEM# EN V #4 Manometer (yes) no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>45.2</u>	<u>33.2</u>	<u>2.0</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1	<u>1620</u>	<u>2.36"</u>	<u>109</u>
Flare #2	<u>/</u>	<u>/</u>	<u>/</u>
Flare #3	<u>1626</u>	<u>1.58"</u>	<u>350</u>

Blower Oper.	RPM	Hours
Blower #1	<u>2100</u>	<u>7943.5</u>
Blower #2	<u>/</u>	<u>/</u>
Blower #3	<u>/</u>	<u>/</u>

Air Compressor Hours: 9612.7

Google SCFM: am: 8 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>47.5</u>	<u>45.2</u>	<u>42.8</u>
CO2 %	<u>32.7</u>	<u>32.0</u>	<u>29.7</u>
O2 %	<u>1.7</u>	<u>0.8</u>	<u>3.4</u>
Vacuum	<u>-39.6"</u>	<u>-38.4"</u>	<u>-39.3"</u>
SCFM	<u>191</u>	<u>148</u>	<u>126</u>
Temperature	<u>77</u>	<u>77</u>	<u>74</u>

Time of Shutdown: 9:24 AM

Time of Start-Up: 9:29 AM

Duration of Shutdown/Malfunction: 5 min

Reason for Shutdown/Malfunction:

- Air-Compressor System
- Blower
- High Gas Flow
- High Temperature
- LEL
- Low Gas Flow
- Low Temperature
- UV Scanner System
- Power Failure
- Scheduled Preventive Maintenance

Clean Honeywell UV Bulbs.

**PM MONITORING**

Name \_\_\_\_\_  
Arrival Time \_\_\_\_\_ Departure Time \_\_\_\_\_  
GEM# \_\_\_\_\_ Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %

Flare Operation	Temp.	Vac.	SCFM
Flare #1	<u>/</u>	<u>/</u>	<u>/</u>
Flare #2	<u>/</u>	<u>/</u>	<u>/</u>
Flare #3	<u>/</u>	<u>/</u>	<u>/</u>

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			

Back Up Generator Running yes / no

Control Room Bypass yes / no

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed isolating all LFG in the piping system to avoid excess emissions, and notified the staff. yes / no

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.

Comments and/or Description of Malfunction and Affected Equipment:

Emission Exceedence: yes\* / no

SSM Plan Procedures Followed:

If SSM Plan Procedure not followed, explain procedure used:

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc. continued on the back side?

yes / no

Signature 

Date 8/2/22

**SSM PLAN REPORT FORM /  
FLARE STATION DAILY CHECKLIST**  
City of Mountain View Flare Station

Date 9-8-22  
 S m t w **th** f s

**AM MONITORING**

Name LEON ROSACCO

Arrival Time 7:18 AM Departure Time 7:29 AM  
 GEM# ENU #4 Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>45.1</u>	<u>33.1</u>	<u>1.8</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1	<u>1618</u>	<u>2.17"</u>	<u>103</u>
Flare #2			
Flare #3	<u>1617</u>	<u>1.45"</u>	<u>337</u>

Blower Oper.	RPM	Hours
Blower #1	<u>2100</u>	<u>18837.0</u>
Blower #2		
Blower #3		

Air Compressor Hours: 9920

Google SCFM: am: 47 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>48.2</u>	<u>44.0</u>	<u>41.6</u>
CO2 %	<u>33.6</u>	<u>33.0</u>	<u>30.3</u>
O2 %	<u>1.4</u>	<u>0.7</u>	<u>4.0</u>
Vacuum	<u>-39.3"</u>	<u>-38.4"</u>	<u>-39.0"</u>
SCFM	<u>185</u>	<u>157</u>	<u>125</u>
Temperature	<u>79</u>	<u>78</u>	<u>76</u>

Time of Shutdown: 1:48 pm

Time of Start-Up: 2:27 pm

Duration of Shutdown/Malfunction: 39 min

Reason for Shutdown/Malfunction:

- Air-Compressor System    Blower    High Gas Flow
- High Temperature    LEL    Low Gas Flow
- Low Temperature    UV Scanner System
- Power Failure    Scheduled Preventive Maintenance

D T D changing out belt  
on Air Compressor

**PM MONITORING**

Name \_\_\_\_\_

Arrival Time \_\_\_\_\_ Departure Time \_\_\_\_\_  
 GEM# \_\_\_\_\_ Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3			

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			

Back Up Generator Running yes / no

Control Room Bypass yes / no

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed isolating all LFG in the piping system to avoid excess emissions, and notified the staff.

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.

Comments and/or Description of Malfunction and Affected Equipment:

yes / no

Emission Exceedence:

yes\* / no

SSM Plan Procedures Followed:

yes no\*

If SSM Plan Procedure not followed, explain procedure used:

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc. continued on the back side?

yes / no

Signature 

Date 9/8/22

**SSM PLAN REPORT FORM /**  
**FLARE STATION DAILY CHECKLIST**  
 City of Mountain View Flare Station

Date

9-19-22

S M T W Th F S

**AM MONITORING**

Name LEON ROSARIO

Arrival Time 8:43 AM Departure Time \_\_\_\_\_  
 GEM# CNV #4 Manometer (yes) no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>43.0</u>	<u>31.1</u>	<u>2.5</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1	<u>1629</u>	<u>2.26"</u>	<u>105</u>
Flare #2	<u>/</u>	<u>/</u>	<u>/</u>
Flare #3	<u>1627</u>	<u>1.47"</u>	<u>342</u>

Blower Oper.	RPM	Hours
Blower #1	<u>2100</u>	<u>190969</u>
Blower #2	<u>/</u>	<u>/</u>
Blower #3	<u>/</u>	<u>/</u>

Air Compressor Hours: 1001.9

Google SCFM: am: 47 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>46.2</u>	<u>43.8</u>	<u>38.6</u>
CO2 %	<u>32.3</u>	<u>31.6</u>	<u>28.0</u>
O2 %	<u>7.0</u>	<u>1.0</u>	<u>4.9</u>
Vacuum	<u>-39.5"</u>	<u>-38.3"</u>	<u>-39.3"</u>
SCFM	<u>190</u>	<u>161</u>	<u>126</u>
Temperature	<u>77</u>	<u>77</u>	<u>74</u>

**PM MONITORING**

Name \_\_\_\_\_

Arrival Time \_\_\_\_\_ Departure Time \_\_\_\_\_  
 GEM# \_\_\_\_\_ Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3			

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			
Back Up Generator Running			yes / no

Control Room Bypass yes / no

The facility's program logic controller yes / no automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed isolating all LFG in the piping system to avoid excess emissions, and notified the staff.

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.

Comments and/or Description of Malfunction and Affected Equipment:

Time of Shutdown: 9 AM

Time of Start-Up: 9:30 AM

Duration of Shutdown/Malfunction: 30 min

Reason for Shutdown/Malfunction:

- Air-Compressor System
- Blower
- High Gas Flow
- High Temperature
- LEL
- Low Gas Flow
- Low Temperature
- UV Scanner System
- Power Failure
- Scheduled Preventive Maintenance

Blower change from #1 to #2

Emission Exceedence: yes\* / no


SSM Plan Procedures Followed: yes / no\*

If SSM Plan Procedure not followed, explain procedure used:

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc. continued on the back side?

yes / no



Date

9/19/22

**SSM PLAN REPORT FORM /  
FLARE STATION DAILY CHECKLIST**  
City of Mountain View Flare Station

Date

9/25/22

s m t w th f s

**AM MONITORING**

Name LEON ROSENG  
 Arrival Time 7:15pm Departure Time 8:30pm  
 GEM# FNV #9 Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>45.8</u>	<u>32.2</u>	<u>2.2</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1	<u>1618</u>	<u>3.25"</u>	<u>106</u>
Flare #2	<u>/</u>	<u>/</u>	<u>/</u>
Flare #3	<u>1627</u>	<u>2.22"</u>	<u>341</u>

Blower Oper.	RPM	Hours
Blower #1	<u>/</u>	<u>/</u>
Blower #2	<u>2100</u>	<u>63209.6</u>
Blower #3	<u>/</u>	<u>/</u>

Air Compressor Hours: 10048.1

Google SCFM: am: 0 pm: 54

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>48.2</u>	<u>42.8</u>	<u>40.2</u>
CO2 %	<u>33.2</u>	<u>30.8</u>	<u>27.9</u>
O2 %	<u>1.3</u>	<u>1.1</u>	<u>9.5</u>
Vacuum	<u>-39.2"</u>	<u>-38.6</u>	<u>-39.3</u>
SCFM	<u>203</u>	<u>165</u>	<u>135</u>
Temperature	<u>76</u>	<u>74</u>	<u>75</u>

**PM MONITORING**

Name \_\_\_\_\_  
 Arrival Time \_\_\_\_\_ Departure Time \_\_\_\_\_  
 GEM# \_\_\_\_\_ Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3			

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			

Back Up Generator Running yes / no

Control Room Bypass yes / no

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed isolating all LFG in the piping system to avoid excess emissions, and notified the staff.

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.

Comments and/or Description of Malfunction and Affected Equipment:

Time of Shutdown: 6:24 pm

Time of Start-Up: 8:03 pm

Duration of Shutdown/Malfunction: 1 hr 39 min

Reason for Shutdown/Malfunction:

- Air-Compressor System
- Blower
- High Gas Flow
- High Temperature
- LEL
- Low Gas Flow
- Low Temperature
- UV Scanner System
- Power Failure
- Scheduled Preventive Maintenance

flare #3 high temp

Emission Exceedence:

yes\* / no

SSM Plan Procedures Followed:

yes / no\*

If SSM Plan Procedure not followed, explain procedure used:

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc. continued on the back side?

yes / no

Signature

Date

**SSM PLAN REPORT FORM /  
FLARE STATION DAILY CHECKLIST**  
City of Mountain View Flare Station

Date

October 18<sup>th</sup>, 2022

S M **T** W Th F S

**AM MONITORING**

Name JASON R BEAN

Arrival Time 6:49 AM Departure Time 7:00 AM

GEM# ENVISION #1 Manometer yes  no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>42.7</u>	<u>31.2</u>	<u>21.6</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1	<u>1623</u>	<u>1.57"</u>	<u>89</u>
Flare #2			
Flare #3	<u>1629</u>	<u>0.92"</u>	<u>275</u>

Blower Oper.	RPM	Hours
Blower #1		
Blower #2	<u>2100</u>	<u>63748.2</u>
Blower #3		

Air Compressor Hours: 10254.4

Google SCFM: am: 52 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>46.1</u>	<u>43.2</u>	<u>37.3</u>
CO2 %	<u>33.0</u>	<u>32.0</u>	<u>27.1</u>
O2 %	<u>1.9</u>	<u>1.0</u>	<u>5.3</u>
Vacuum	<u>-41.3"</u>	<u>-40.3"</u>	<u>-41.1"</u>
SCFM	<u>187</u>	<u>158</u>	<u>134</u>
Temperature	<u>73</u>	<u>74</u>	<u>71</u>

Time of Shutdown: 11:53 PM

Time of Start-Up: 11:59 AM

Duration of Shutdown/Malfunction: 6 min

Reason for Shutdown/Malfunction:

- Air-Compressor System
- Blower
- High Gas Flow
- High Temperature
- LEL
- Low Gas Flow
- Low Temperature
- UV Scanner System
- Power Failure
- Scheduled Preventive Maintenance

Bloom Flow Meter Inspection

Signature

Date

**PM MONITORING**

Name \_\_\_\_\_

Arrival Time \_\_\_\_\_ Departure Time \_\_\_\_\_

GEM# \_\_\_\_\_ Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3			

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			

Back Up Generator Running yes /  no

Control Room Bypass yes /  no

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed isolating all LFG in the piping system to avoid excess emissions, and notified the staff.

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.

Comments and/or Description of Malfunction and Affected Equipment:

\_\_\_\_\_

Emission Exceedence: yes\* /  no

SSM Plan Procedures Followed:  yes / no\*

If SSM Plan Procedure not followed, explain procedure used:

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc. continued on the back side?

yes /  no

**SSM PLAN REPORT FORM /  
FLARE STATION DAILY CHECKLIST**  
City of Mountain View Flare Station

Date 10/29/22  
 s  m t w th f s

**AM MONITORING**

Name LEON ROSARZO  
 Arrival Time 7:20 AM Departure Time 7:39 AM  
 GEM# FNV #4 Manometer yes  no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>40.1</u>	<u>30.6</u>	<u>3.0</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1	<u>1622</u>	<u>1.58"</u>	<u>90</u>
Flare #2			
Flare #3	<u>1629</u>	<u>0.92"</u>	<u>276</u>

Blower Oper.	RPM	Hours
Blower #1		
Blower #2	<u>7100</u>	<u>13892.7</u>
Blower #3		

Air Compressor Hours: 10306.3

Google SCFM: am: 41 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>43.5</u>	<u>42.8</u>	<u>34.0</u>
CO2 %	<u>31.2</u>	<u>31.5</u>	<u>25.8</u>
O2 %	<u>7.5</u>	<u>1.0</u>	<u>6.1</u>
Vacuum	<u>-42.0"</u>	<u>-41.1"</u>	<u>-41.9"</u>
SCFM	<u>190</u>	<u>161</u>	<u>128</u>
Temperature	<u>71</u>	<u>72</u>	<u>69</u>

**PM MONITORING**

Name \_\_\_\_\_  
 Arrival Time \_\_\_\_\_ Departure Time \_\_\_\_\_  
 GEM# \_\_\_\_\_ Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3			

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			

Back Up Generator Running yes /  no

Control Room Bypass yes /  no

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed isolating all LFG in the piping system to avoid excess emissions, and notified the staff.

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.

Comments and/or Description of Malfunction and Affected Equipment:

Time of Shutdown: 7:42 AM

Time of Start-Up: 8:42 AM

Duration of Shutdown/Malfunction: 1 hr

Reason for Shutdown/Malfunction:

- Air-Compressor System
- Blower
- High Gas Flow
- High Temperature
- LEL
- Low Gas Flow
- Low Temperature
- UV Scanner System
- Power Failure
- Scheduled Preventive Maintenance

header choked off by liquid

Emission Exceedence:

yes\* /  no

SSM Plan Procedures Followed:


yes / no\*

If SSM Plan Procedure not followed, explain procedure used:

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc. continued on the back side?

yes /  no



10/29/22

**SSM PLAN REPORT FORM /  
FLARE STATION DAILY CHECKLIST**  
City of Mountain View Flare Station

Date 10/25/22  
s m  t w th f s

**AM MONITORING**

Name LEON ROSARIO

Arrival Time 7:39 am Departure Time 8:49 am

GEM# ENV #4 Manometer  yes / no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>42.1</u>	<u>31.8</u>	<u>7.8</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1	<u>1590</u>	<u>1.99"</u>	<u>86</u>
Flare #2			
Flare #3	<u>1601</u>	<u>1.21"</u>	<u>264</u>

Blower Oper.	RPM	Hours
Blower #1		
Blower #2	<u>2100</u>	<u>63916.1</u>
Blower #3		

Air Compressor Hours: 10315.6

Google SCFM: am: 34 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>47.5</u>	<u>43.1</u>	<u>36.9</u>
CO2 %	<u>33.7</u>	<u>32.2</u>	<u>26.8</u>
O2 %	<u>1.6</u>	<u>1.1</u>	<u>5.5</u>
Vacuum	<u>-41.4"</u>	<u>-40.5"</u>	<u>-41.3"</u>
SCFM	<u>148</u>	<u>160</u>	<u>136</u>
Temperature	<u>77</u>	<u>77</u>	<u>70</u>

Time of Shutdown:	<u>11:24 AM</u>	<u>11:45 AM</u>
Time of Start-Up:	<u>11:26 AM</u>	<u>11:53 AM</u>
Duration of Shutdown/Malfunction:	<u>2 min</u>	<u>8 min</u>

Reason for Shutdown/Malfunction: Low Gas flow

- Air-Compressor System
- Blower
- High Gas Flow
- High Temperature
- LEL
- Low Gas Flow
- Low Temperature
- UV Scanner System
- Power Failure
- Scheduled Preventive Maintenance

**PM MONITORING**

Name \_\_\_\_\_

Arrival Time \_\_\_\_\_ Departure Time \_\_\_\_\_

GEM# \_\_\_\_\_ Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %

Flare Operation	Tc/inp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3			

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			

Back Up Generator Running yes /  no

Control Room Bypass yes /  no

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed isolating all LFG in the piping system to avoid excess emissions, and notified the staff.

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.

Comments and/or Description of Malfunction and Affected Equipment:

Emission Exceedence: yes\* /  no

SSM Plan Procedures Followed:  yes / no\*

If SSM Plan Procedure not followed, explain procedure used:

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc. continued on the back side?

yes /  no



10/25/22

**SSM PLAN REPORT FORM /  
FLARE STATION DAILY CHECKLIST**  
City of Mountain View Flare Station

Date 10/26/22  
s m t w th f s

**AM MONITORING**

Name LEON ROSALDO  
Arrival Time 6:54 AM Departure Time 7:05 AM  
GEM# GUV #4 Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>43.0</u>	<u>31.3</u>	<u>2.7</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1	<u>1621</u>	<u>1.65"</u>	<u>91</u>
Flare #2	<u>—</u>	<u>—</u>	<u>—</u>
Flare #3	<u>1619</u>	<u>0.97"</u>	<u>784</u>

Blower Oper.	RPM	Hours
Blower #1	<u>—</u>	<u>—</u>
Blower #2	<u>2160</u>	<u>1393.9.3</u>
Blower #3	<u>—</u>	<u>—</u>

Air Compressor Hours: 10324.1

Google SCFM: am: 37 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>48.2</u>	<u>43.7</u>	<u>36.7</u>
CO2 %	<u>33.5</u>	<u>32.2</u>	<u>27.0</u>
O2 %	<u>1.5</u>	<u>1.0</u>	<u>5.6</u>
Vacuum	<u>-42.0"</u>	<u>-41.2"</u>	<u>-41.9"</u>
SCFM	<u>150</u>	<u>167</u>	<u>126</u>
Temperature	<u>71</u>	<u>71</u>	<u>69</u>

Time of Shutdown: 3:38 pm

Time of Start-Up: 3:40 pm

Duration of Shutdown/Malfunction: 2 min

Reason for Shutdown/Malfunction:

- Air-Compressor System
- Blower
- High Gas Flow
- High Temperature
- LEL
- Low Gas Flow
- Low Temperature
- UV Scanner System
- Power Failure
- Scheduled Preventive Maintenance

Google flow Spice

**PM MONITORING**

Name \_\_\_\_\_  
Arrival Time \_\_\_\_\_ Departure Time \_\_\_\_\_  
GEM# \_\_\_\_\_ Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3			

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			

Back Up Generator Running yes / no

Control Room Bypass yes / no

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed isolating all LFG in the piping system to avoid excess emissions, and notified the staff.

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.

yes / no

Comments and/or Description of Malfunction and Affected Equipment:

Time of Shutdown:	<u>3:38 pm</u>
Time of Start-Up:	<u>3:40 pm</u>
Duration of Shutdown/Malfunction:	<u>2 min</u>

Emission Exceedence: yes\* / no

SSM Plan Procedures Followed: yes / no\*

If SSM Plan Procedure not followed, explain procedure used:

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc. continued on the back side?

yes / no

Signature

Date 10/26/22

**SSM PLAN REPORT FORM /**  
**FLARE STATION DAILY CHECKLIST**  
 City of Mountain View Flare Station

Date 10/27/22  
 s m t w **th** f s

**AM MONITORING**

Name LEON VASQUEZ  
 Arrival Time 8:18 Am Departure Time 8:46 Am  
 GEM# GIV #4 Manometer (yes) no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>43.2</u>	<u>31.4</u>	<u>2.9</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1	<u>1612</u>	<u>1.59"</u>	<u>90</u>
Flare #2	<u>/</u>	<u>/</u>	<u>/</u>
Flare #3	<u>1615</u>	<u>1.62"</u>	<u>288</u>

Blower Oper.	RPM	Hours
Blower #1	<u>/</u>	<u>/</u>
Blower #2	<u>2100</u>	<u>63965.0</u>
Blower #3	<u>/</u>	<u>/</u>

Air Compressor Hours: 10333.6

Google SCFM: am: 27 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>48.3</u>	<u>44.1</u>	<u>34.7</u>
CO2 %	<u>33.3</u>	<u>32.6</u>	<u>25.4</u>
O2 %	<u>1.5</u>	<u>0.9</u>	<u>6.1</u>
Vacuum	<u>-42.0"</u>	<u>-41.1"</u>	<u>-41.7</u>
SCFM	<u>150</u>	<u>156</u>	<u>123</u>
Temperature	<u>70</u>	<u>72</u>	<u>68</u>

Time of Shutdown: 8:20 am

Time of Start-Up: 8:33 am

Duration of Shutdown/Malfunction: 13 min

Reason for Shutdown/Malfunction:

- Air-Compressor System
- Blower
- High Gas Flow
- High Temperature
- LEL
- Low Gas Flow
- Low Temperature
- UV Scanner System
- Power Failure
- Scheduled Preventive Maintenance

Take flare #1 out of  
Alarm

**PM MONITORING**

Name \_\_\_\_\_  
 Arrival Time \_\_\_\_\_ Departure Time \_\_\_\_\_  
 GEM# \_\_\_\_\_ Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3			

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			

Back Up Generator Running yes / no

Control Room Bypass yes / no

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed isolating all LFG in the piping system to avoid excess emissions, and notified the staff.

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.

Comments and/or Description of Malfunction and Affected Equipment:

yes / no

Emission Exceedence:

yes\* / no

SSM Plan Procedures Followed:


yes / no\*

If SSM Plan Procedure not followed, explain procedure used:

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc. continued on the back side?

yes / no

Signature 

Date 10/27/22

**SSM PLAN REPORT FORM /  
FLARE STATION DAILY CHECKLIST**  
City of Mountain View Flare Station

Date

October 30<sup>th</sup>, 2022

S m t w th f s

**AM MONITORING**

Name Jason R. Bean

Arrival Time 5:30 pm Departure Time 11:30 pm

GEM# EVN01N #4 Manometer  yes /  no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>43.3</u>	<u>32.1</u>	<u>3.1</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3	<u>1625</u>	<u>0.99"</u>	<u>264</u>

Blower Oper.	RPM	Hours
Blower #1		
Blower #2	<u>2100</u>	<u>30344.3</u>
Blower #3		

Air Compressor Hours: 10362.0

Google SCFM: am: 41 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>48.5</u>	<u>0.1</u>	<u>37.4</u>
CO2 %	<u>33.9</u>	<u>0.1</u>	<u>28.1</u>
O2 %	<u>1.6</u>	<u>20.1</u>	<u>5.5</u>
Vacuum	<u>-40.5"</u>	<u>-40.1"</u>	<u>-40.9"</u>
SCFM	<u>151</u>	<u>0</u>	<u>144</u>
Temperature	<u>70</u>	<u>70</u>	<u>63</u>

Time of Shutdown: 5:22 pm

Time of Start-Up: 7:25 pm

Duration of Shutdown/Malfunction: 2hr 3min

Reason for Shutdown/Malfunction:

- Air-Compressor System
- Blower
- High Gas Flow
- High Temperature
- LEL
- Low Gas Flow
- Low Temperature
- UV Scanner System
- Power Failure
- Scheduled Preventive Maintenance

2 Sumps out on Vista

**PM MONITORING**

Name \_\_\_\_\_

Arrival Time \_\_\_\_\_ Departure Time \_\_\_\_\_

GEM# \_\_\_\_\_ Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3			

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			

Back Up Generator Running yes /  no

Control Room Bypass yes /  no

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed isolating all LFG in the piping system to avoid excess emissions, and notified the staff.

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.

Comments and/or Description of Malfunction and Affected Equipment:

Emission Exceedence: yes\* /  no


SSM Plan Procedures Followed:  yes / no\*

If SSM Plan Procedure not followed, explain procedure used:

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc. continued on the back side?

yes /  no

Signature 

Date 10/30/22

**SSM PLAN REPORT FORM /  
FLARE STATION DAILY CHECKLIST**  
City of Mountain View Flare Station

Date October 31<sup>st</sup>, 2012  
s m t w th f s

**AM MONITORING**

Name Adrian Vega  
Arrival Time 8:30 AM Departure Time 9:39 AM  
GEM# ENCLISION # 4 Manometer yes no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>434</u>	<u>22.4</u>	<u>3.0</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2	<u>1600</u>	<u>0.84"</u>	<u>147</u>
Flare #3	<u>1629</u>	<u>1.06"</u>	<u>295</u>

Blower Oper.	RPM	Hours
Blower #1		
Blower #2		
Blower #3	<u>2100</u>	<u>30368.5</u>

Air Compressor Hours: 10364.1

Google SCFM: am: 30 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>48.5</u>	<u>44.7</u>	<u>38.2</u>
CO2 %	<u>34.9</u>	<u>33.6</u>	<u>28.2</u>
O2 %	<u>1.6</u>	<u>1.1</u>	<u>5.5</u>
Vacuum	<u>-41.5"</u>	<u>-40.7"</u>	<u>-41.3"</u>
SCFM	<u>150</u>	<u>235</u>	<u>120</u>
Temperature	<u>70</u>	<u>71</u>	<u>69</u>

Time of Shutdown: 8:31 AM

Time of Start-Up: 8:53 AM

Duration of Shutdown/Malfunction: 22 min

Reason for Shutdown/Malfunction:

- Air-Compressor System     Blower     High Gas Flow
- High Temperature     LEL     Low Gas Flow
- Low Temperature     UV Scanner System
- Power Failure     Scheduled Preventive Maintenance

Change from blower #2 to #3

**PM MONITORING**

Name \_\_\_\_\_  
Arrival Time \_\_\_\_\_ Departure Time \_\_\_\_\_  
GEM# \_\_\_\_\_ Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %

Flare Operation	Tc/inp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3			

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			

Back Up Generator Running yes / no

Control Room Bypass yes / no

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed isolating all LFG in the piping system to avoid excess emissions, and notified the staff.

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.

Comments and/or Description of Malfunction and Affected Equipment:

Emission Exceedence: yes\* / no

SSM Plan Procedures Followed: yes / no\*

If SSM Plan Procedure not followed, explain procedure used:

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc. continued on the back side? yes / no

Signature

Date

**SSM PLAN REPORT FORM /  
FLARE STATION DAILY CHECKLIST**  
City of Mountain View Flare Station

Date November 1<sup>ST</sup>, 2022  
 S M  W Th F S

**AM MONITORING**

Name Jason R Bean  
 Arrival Time 5:24pm Departure Time 5:35pm  
 GEM# ENVIRON #4 Manometer  yes / no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>43.6</u>	<u>31.9</u>	<u>2.9</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1	<u>1615</u>	<u>1.26"</u>	<u>80</u>
Flare #2			
Flare #3	<u>1610</u>	<u>0.99"</u>	<u>284</u>

Blower Oper.	RPM	Hours
Blower #1		
Blower #2		
Blower #3	<u>2100</u>	<u>30388.5</u>

Air Compressor Hours: 10369.6

Google SCFM: am: 33 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>48.5</u>	<u>45.3</u>	<u>37.6</u>
CO2 %	<u>34.5</u>	<u>33.8</u>	<u>27.7</u>
O2 %	<u>1.8</u>	<u>1.1</u>	<u>5.7</u>
Vacuum	<u>-41.4"</u>	<u>-40.5"</u>	<u>-41.3"</u>
SCFM	<u>151</u>	<u>201</u>	<u>145</u>
Temperature	<u>70</u>	<u>71</u>	<u>69</u>

Time of Shutdown: 11:58 AM

Time of Start-Up: 12:05 pm

Duration of Shutdown/Malfunction: 7 min

Reason for Shutdown/Malfunction:

- Air-Compressor System
- Blower
- High Gas Flow
- High Temperature
- LEL
- Low Gas Flow
- Low Temperature
- UV Scanner System
- Power Failure
- Scheduled Preventive Maintenance

Vista flow meter.

**PM MONITORING**

Name \_\_\_\_\_  
 Arrival Time \_\_\_\_\_ Departure Time \_\_\_\_\_  
 GEM# \_\_\_\_\_ Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %

Flare Operation	Tel/hp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3			

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			

Back Up Generator Running yes /

Control Room Bypass yes /

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed isolating all LFG in the piping system to avoid excess emissions, and notified the staff.

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.

Comments and/or Description of Malfunction and Affected Equipment:

Emission Exceedence: yes\* /

SSM Plan Procedures Followed:  yes / no\*

If SSM Plan Procedure not followed, explain procedure used:

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc. continued on the back side? yes /

Jason R Bean

11/1/22

Date

**SSM PLAN REPORT FORM /  
FLARE STATION DAILY CHECKLIST**  
City of Mountain View Flare Station

Date November 2<sup>nd</sup>, 2022  
 S m t w th f s

**AM MONITORING**

Name JASON R. BRAUN  
 Arrival Time 7:10 AM Departure Time 7:22 PM  
 GEM# ENVISION #4 Manometer  yes  no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>41.2</u>	<u>30.8</u>	<u>3.4</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1	<u>1632</u>	<u>1.60"</u>	<u>90</u>
Flare #2			
Flare #3	<u>1631</u>	<u>1.02"</u>	<u>289</u>

Blower Oper.	RPM	Hours
Blower #1		
Blower #2		
Blower #3	<u>2100</u>	<u>304142</u>

Air Compressor Hours: 10377.2

Google SCFM: am: 34 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>46.7</u>	<u>44.1</u>	<u>34.2</u>
CO2 %	<u>33.4</u>	<u>32.3</u>	<u>25.6</u>
O2 %	<u>2.3</u>	<u>1.2</u>	<u>6.4</u>
Vacuum	<u>-42.2"</u>	<u>-41.3"</u>	<u>-42.0"</u>
SCFM	<u>153</u>	<u>184</u>	<u>158</u>
Temperature	<u>69</u>	<u>70</u>	<u>68</u>

**PM MONITORING**

Name \_\_\_\_\_  
 Arrival Time \_\_\_\_\_ Departure Time \_\_\_\_\_  
 GEM# \_\_\_\_\_ Manometer \_\_\_\_\_ yes / no

LFG to Flares

CH4 %	CO2 %	O2 %

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3			

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			

Back Up Generator Running yes /  no

Control Room Bypass yes /  no

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed isolating all LFG in the piping system to avoid excess emissions, and notified the staff.

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.


Comments and/or Description of Malfunction and Affected Equipment:

Time of Shutdown:	<u>7:20 AM</u>
Time of Start-Up:	<u>8:51 AM</u>
Duration of Shutdown/Malfunction:	<u>1hr 31 min</u>

Reason for Shutdown/Malfunction:

- Air-Compressor System
- Blower
- High Gas Flow
- High Temperature
- LEL
- Low Gas Flow
- Low Temperature
- UV Scanner System
- Power Failure
- Scheduled Preventive Maintenance

Calibrate flow meters at  
inlets (Ristar)

Signature 

Date 11/2/22

Emission Exceedence: yes\* /  no

SSM Plan Procedures Followed:  yes / no\*

If SSM Plan Procedure not followed, explain procedure used:

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc. continued on the back side?

yes  no →

**SSM PLAN REPORT FORM /  
FLARE STATION DAILY CHECKLIST**  
City of Mountain View Flare Station

Date November 3<sup>rd</sup>, 2022

s m t w  f s

**AM MONITORING**

Name Adrian Vega

Arrival Time 7:00 AM Departure Time 7:15 AM

GEM# ENVISION #4 Manometer  yes / no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>41.1</u>	<u>30.7</u>	<u>3.5</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3	<u>1625</u>	<u>1.46"</u>	<u>3617</u>

Blower Oper.	RPM	Hours
Blower #1		
Blower #2		
Blower #3	<u>2100</u>	<u>304365</u>

Air Compressor Hours: 10385.1

Google SCFM: am: 33 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>47.1</u>	<u>42.9</u>	<u>32.7</u>
CO2 %	<u>33.8</u>	<u>32.3</u>	<u>24.8</u>
O2 %	<u>2.3</u>	<u>1.4</u>	<u>7.0</u>
Vacuum	<u>-42.7"</u>	<u>-41.1"</u>	<u>-41.9"</u>
SCFM	<u>155</u>	<u>113</u>	<u>164</u>
Temperature	<u>68</u>	<u>69</u>	<u>67</u>

**PM MONITORING**

Name \_\_\_\_\_

Arrival Time \_\_\_\_\_ Departure Time \_\_\_\_\_

GEM# \_\_\_\_\_ Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3			

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			

Back Up Generator Running yes /

Control Room Bypass yes /

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed isolating all LFG in the piping system to avoid excess emissions, and notified the staff.

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.

Comments and/or Description of Malfunction and Affected Equipment:

Time of Shutdown:	<u>7:24 AM</u>
Time of Start-Up:	<u>10:53 AM</u>
Duration of Shutdown/Malfunction:	<u>3hr 29min</u>

Emission Exceedence: yes\* /

SSM Plan Procedures Followed:  yes\* / no\*

If SSM Plan Procedure not followed, explain procedure used:

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc. continued on the back side? yes /

*Tel-star here to replace flow meter @ Vista*

Date 11/03/22

Signature *James R Ben*

**SSM PLAN REPORT FORM /  
FLARE STATION DAILY CHECKLIST**  
City of Mountain View Flare Station

Date November 16<sup>th</sup>, 2022  
s m t  th f s

**AM MONITORING**

Name Miguel Varela

Arrival Time 7:10 a.m. Departure Time 7:20 a.m.

GEM# ENVISION #4

Manometer

yes  no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>42.5</u>	<u>31.8</u>	<u>2.8</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1	/	/	/
Flare #2	/	/	/
Flare #3	<u>1619</u>	<u>1.50"</u>	<u>353</u>

Blower Oper.	RPM	Hours
Blower #1	/	/
Blower #2	/	/
Blower #3	<u>2100</u>	<u>30747.9</u>

Air Compressor Hours: 10503.7

Google SCFM: am: 33 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>46.5</u>	<u>42.1</u>	<u>36.3</u>
CO2 %	<u>34.5</u>	<u>32.5</u>	<u>26.3</u>
O2 %	<u>1.8</u>	<u>1.0</u>	<u>6.1</u>
Vacuum	<u>-42.6"</u>	<u>-41.7"</u>	<u>-42.3"</u>
SCFM	<u>175</u>	<u>232</u>	<u>128</u>
Temperature	<u>63</u>	<u>65</u>	<u>63</u>

**PM MONITORING**

Name \_\_\_\_\_

Arrival Time \_\_\_\_\_

Departure Time \_\_\_\_\_

GEM# \_\_\_\_\_

Manometer

yes / no

LFG to Flares

CH4 %	CO2 %	O2 %

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3			

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			

Back Up Generator Running  yes /  no

Control Room Bypass  yes /  no

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed isolating all LFG in the piping system to avoid excess emissions, and notified the staff.

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.

Comments and/or Description  
of Malfunction and Affected Equipment:

Time of Shutdown: 9:26 am

Time of Start-Up: 10:03 am

Duration of Shutdown/Malfunction: 37 min

Reason for Shutdown/Malfunction:

- Air-Compressor System
- Blower
- High Gas Flow
- High Temperature
- LEL
- Low Gas Flow
- Low Temperature
- UV Scanner System
- Power Failure
- Scheduled Preventive Maintenance

Clean Knockout

Emission Exceedence:  yes\* /  no\*


SSM Plan Procedures Followed:  yes /  no\*

If SSM Plan Procedure not followed, explain procedure used:

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other  
information, etc. continued on the back side?

yes /  no

Signature 

Date 11/16/22

**SSM PLAN REPORT FORM /  
FLARE STATION DAILY CHECKLIST**  
City of Mountain View Flare Station

Date 11-19-72  
s m t w th f  s

**AM MONITORING**

Name LEON ROSARIO  
Arrival Time 12:10 pm Departure Time 12:31 pm  
GEM# ENV # 4 Manometer yes  no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>92.8</u>	<u>31.7</u>	<u>7.7</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1	/	/	/
Flare #2	/	/	/
Flare #3	<u>1623</u>	<u>1.59"</u>	<u>360</u>

Blower Oper.	RPM	Hours
Blower #1	/	/
Blower #2	/	/
Blower #3	<u>2100</u>	<u>30823.3</u>

Air Compressor Hours: 10526.9

Google SCFM: am: 32 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>47.3</u>	<u>43.6</u>	<u>37.0</u>
CO2 %	<u>33.5</u>	<u>37.8</u>	<u>27.1</u>
O2 %	<u>1.5</u>	<u>0.9</u>	<u>5.9</u>
Vacuum	<u>-41.6"</u>	<u>-40.7"</u>	<u>-41.3"</u>
SCFM	<u>175</u>	<u>222</u>	<u>125</u>
Temperature	<u>63</u>	<u>66</u>	<u>67</u>

Time of Shutdown: 12:18 pm

Time of Start-Up: 12:30 pm

Duration of Shutdown/Malfunction: 12 min

Reason for Shutdown/Malfunction:

- Air-Compressor System
- Blower
- High Gas Flow
- High Temperature
- LEL
- Low Gas Flow
- Low Temperature
- UV Scanner System
- Power Failure
- Scheduled Preventive Maintenance

Reset flare #1

**PM MONITORING**

Name \_\_\_\_\_  
Arrival Time \_\_\_\_\_ Departure Time \_\_\_\_\_  
GEM# \_\_\_\_\_ Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3			

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			

Back Up Generator Running yes /  no

Control Room Bypass yes /  no

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed isolating all LFG in the piping system to avoid excess emissions, and notified the staff.

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.

Comments and/or Description of Malfunction and Affected Equipment:

Time of Shutdown:	<u>12:18 pm</u>
Time of Start-Up:	<u>12:30 pm</u>
Duration of Shutdown/Malfunction:	<u>12 min</u>


Emission Exceedence: yes\* /  no

SSM Plan Procedures Followed:  yes / no\*

If SSM Plan Procedure not followed, explain procedure used:

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc. continued on the back side? yes /  no



11/19/72

**SSM PLAN REPORT FORM /  
FLARE STATION DAILY CHECKLIST**  
City of Mountain View Flare Station

Date November 21<sup>st</sup>, 2022  
 S  M  T  W  TH  F  S

**AM MONITORING**

Name Adrian Vega  
 Arrival Time 6:40 AM Departure Time 7:00 AM  
 GEM# Envision #4 Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>48.8</u>	<u>31.3</u>	<u>3.0</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3	<u>1619</u>	<u>1.60"</u>	<u>3605</u>

Blower Oper.	RPM	Hours
Blower #1		
Blower #2		
Blower #3	<u>2100</u>	<u>30865.8</u>

Air Compressor Hours: 10539.6

Google SCFM: am: 34 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>48.3</u>	<u>48.4</u>	<u>33.8</u>
CO2 %	<u>34.7</u>	<u>32.9</u>	<u>24.6</u>
O2 %	<u>1.6</u>	<u>1.1</u>	<u>7.6</u>
Vacuum	<u>-42.4"</u>	<u>-41.5"</u>	<u>-42.3"</u>
SCFM	<u>175</u>	<u>236</u>	<u>124</u>
Temperature	<u>61</u>	<u>64</u>	<u>62</u>

**PM MONITORING**

Name \_\_\_\_\_  
 Arrival Time \_\_\_\_\_ Departure Time \_\_\_\_\_  
 GEM# \_\_\_\_\_ Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3			

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			

Back Up Generator Running yes / no

Control Room Bypass yes / no

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed isolating all LFG in the piping system to avoid excess emissions, and notified the staff.

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.

Comments and/or Description of Malfunction and Affected Equipment:

Time of Shutdown: <u>12:25 PM</u>
Time of Start-Up: <u>12:44 PM</u>
Duration of Shutdown/Malfunction: <u>21 min</u>

Reason for Shutdown/Malfunction:

- Air-Compressor System
- Blower
- High Gas Flow
- High Temperature
- LEL
- Low Gas Flow
- Low Temperature
- UV Scanner System
- Power Failure
- Scheduled Preventive Maintenance

Restart Flare #1

Emission Exceedence: yes\* / no

SSM Plan Procedures Followed: yes / no

If SSM Plan Procedure not followed, explain procedure used:

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc. continued on the back side? yes / no

Adrian Vega

11/21/22

**SSM PLAN REPORT FORM /  
FLARE STATION DAILY CHECKLIST**  
City of Mountain View Flare Station

Date November 28<sup>th</sup> 2022  
 s m t w th f s

**AM MONITORING**

Name JASON R. BEAN  
 Arrival Time 6:55AM Departure Time 7:00pm  
 GEM# ENVISION #4 Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>43.0</u>	<u>32.0</u>	<u>3.2</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1	<u>1661</u>	<u>2.14"</u>	<u>102</u>
Flare #2			
Flare #3	<u>1645</u>	<u>1.45"</u>	<u>338</u>

Blower Oper.	RPM	Hours
Blower #1		
Blower #2		
Blower #3	<u>2100</u>	<u>31035.5</u>

Air Compressor Hours: 10596.0

Google SCFM: am: 33 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>49.3</u>	<u>43.2</u>	<u>34.4</u>
CO2 %	<u>34.5</u>	<u>32.5</u>	<u>24.7</u>
O2 %	<u>1.3</u>	<u>0.9</u>	<u>7.4</u>
Vacuum	<u>-42.0"</u>	<u>-41.0"</u>	<u>-41.6"</u>
SCFM	<u>172</u>	<u>226</u>	<u>128</u>
Temperature	<u>60</u>	<u>63</u>	<u>62</u>

**PM MONITORING**

Name \_\_\_\_\_  
 Arrival Time \_\_\_\_\_ Departure Time \_\_\_\_\_  
 GEM# \_\_\_\_\_ Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3			

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			

Back Up Generator Running yes / no

Control Room Bypass yes / no

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed isolating all LFG in the piping system to avoid excess emissions, and notified the staff.

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.

Comments and/or Description of Malfunction and Affected Equipment:

Time of Shutdown:	<u>10:53pm</u>	<u>11:58pm</u>
Time of Start-Up:	<u>11:00 pm</u>	<u>12:05 pm</u>
Duration of Shutdown/Malfunction:	<u>7min</u>	<u>7min</u>

Emission Exceedence: yes\* / no


SSM Plan Procedures Followed: yes / no\*

If SSM Plan Procedure not followed, explain procedure used:

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc. continued on the back side?

yes / no

Signature 

Date 11/28/22

**SSM PLAN REPORT FORM /  
FLARE STATION DAILY CHECKLIST**  
City of Mountain View Flare Station

Date November 29<sup>th</sup>, 2022  
s m d w th f s

**AM MONITORING**

Name Miguel Varcia

Arrival Time 6:45 a.m. Departure Time 7:00 a.m.

GEM# ENVISION #4 Manometer  yes  no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>42.1</u>	<u>31.5</u>	<u>3.3</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1	<u>1626</u>	<u>1.54"</u>	<u>89</u>
Flare #2	/	/	/
Flare #3	<u>1627</u>	<u>0.99"</u>	<u>287</u>

Blower Oper.	RPM	Hours
Blower #1	/	/
Blower #2	/	/
Blower #3	<u>2100</u>	<u>31057.5</u>

Air Compressor Hours: 10603.8

Google SCFM: am: 34 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>48.2</u>	<u>47.2</u>	<u>33.8</u>
CO2 %	<u>34.1</u>	<u>32.5</u>	<u>24.3</u>
O2 %	<u>1.6</u>	<u>1.1</u>	<u>7.7</u>
Vacuum	<u>-42.7"</u>	<u>-41.8"</u>	<u>-42.6"</u>
SCFM	<u>176</u>	<u>234</u>	<u>133</u>
Temperature	<u>60</u>	<u>63</u>	<u>61</u>

Time of Shutdown: 12:30 pm

Time of Start-Up: 12:42 pm

Duration of Shutdown/Malfunction: 12 min

Reason for Shutdown/Malfunction:

- Air-Compressor System
- Blower
- High Gas Flow
- High Temperature
- LEL
- Low Gas Flow
- Low Temperature
- UV Scanner System
- Power Failure
- Scheduled Preventive Maintenance

Blower change #3 to  
#1

**PM MONITORING**

Name \_\_\_\_\_

Arrival Time \_\_\_\_\_ Departure Time \_\_\_\_\_

GEM# \_\_\_\_\_ Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3			

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			

Back Up Generator Running yes /  no

Control Room Bypass yes /  no

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed isolating all LFG in the piping system to avoid excess emissions, and notified the staff.  yes / no

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.

Comments and/or Description of Malfunction and Affected Equipment:

Emission Exceedence: yes\* /  no

SSM Plan Procedures Followed:  yes / no\*

If SSM Plan Procedure not followed, explain procedure used:

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc. continued on the back side?

yes /  no



11/29/22

Date

**SSM PLAN REPORT FORM /  
FLARE STATION DAILY CHECKLIST**  
City of Mountain View Flare Station

Date 12-16-22  
s m t w th f s

**AM MONITORING**

Name Leon Rosario  
Arrival Time 8:30 Am Departure Time 8:47 Am  
GEM# ENV #4 Manometer yes no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>44.5</u>	<u>32.7</u>	<u>23</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3	<u>1624</u>	<u>1.30"</u>	<u>331</u>

Blower Oper.	RPM	Hours
Blower #1	<u>2100</u>	<u>19501.1</u>
Blower #2		
Blower #3		

Air Compressor Hours: 10734.3

Google SCFM: am: 32 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>45.9</u>	<u>42.7</u>	<u>49.8</u>
CO2 %	<u>37.6</u>	<u>32.2</u>	<u>29.9</u>
O2 %	<u>2.6</u>	<u>1.1</u>	<u>3.4</u>
Vacuum	<u>-42.7"</u>	<u>-41.4"</u>	<u>-42.6"</u>
SCFM	<u>187</u>	<u>235</u>	<u>102</u>
Temperature	<u>57</u>	<u>59</u>	<u>56</u>

**PM MONITORING**

Name \_\_\_\_\_  
Arrival Time \_\_\_\_\_ Departure Time \_\_\_\_\_  
GEM# \_\_\_\_\_ Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3			

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			

Back Up Generator Running yes / no

Control Room Bypass yes / no

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed isolating all LFG in the piping system to avoid excess emissions, and notified the staff.

yes / no

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.

Comments and/or Description of Malfunction and Affected Equipment:

Time of Shutdown:	<u>8:52 Am</u>
Time of Start-Up:	<u>9:05 Am</u>
Duration of Shutdown/Malfunction:	<u>23 min.</u>

Emission Exceedence:

yes\* / no

SSM Plan Procedures Followed:

yes / no\*

If SSM Plan Procedure not followed, explain procedure used:

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc. continued on the back side?

yes / no



17/16/22  
Date

**SSM PLAN REPORT FORM /  
FLARE STATION DAILY CHECKLIST**  
City of Mountain View Flare Station

Date 12-20-22  
s m t w th f s

**AM MONITORING**

Name Leon Rosario  
Arrival Time 7:40 AM Departure Time 7:49 AM  
GEM# ENV # 4 Manometer (yes) no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>43.5</u>	<u>32.3</u>	<u>2.5</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1	<u>1681</u>	<u>207"</u>	<u>104</u>
Flare #2	<u>/</u>	<u>/</u>	<u>/</u>
Flare #3	<u>1664</u>	<u>1.90"</u>	<u>339</u>

Blower Oper.	RPM	Hours
Blower #1	<u>7100</u>	<u>19596.0</u>
Blower #2	<u>/</u>	<u>/</u>
Blower #3	<u>/</u>	<u>/</u>

Air Compressor Hours: 10765.1

Google SCFM: am: 32 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>44.1</u>	<u>41.6</u>	<u>42.8</u>
CO2 %	<u>32.9</u>	<u>37.9</u>	<u>29.8</u>
O2 %	<u>2.8</u>	<u>1.0</u>	<u>3.8</u>
Vacuum	<u>-42.5"</u>	<u>-41.6"</u>	<u>-42.4"</u>
SCFM	<u>184</u>	<u>239</u>	<u>80</u>
Temperature	<u>56</u>	<u>59</u>	<u>57</u>

**PM MONITORING**

Name \_\_\_\_\_  
Arrival Time \_\_\_\_\_ Departure Time \_\_\_\_\_  
GEM# \_\_\_\_\_ Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3			

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			

Back Up Generator Running yes / no

Control Room Bypass yes / no

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed isolating all LFG in the piping system to avoid excess emissions, and notified the staff.

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.

Comments and/or Description of Malfunction and Affected Equipment:

Time of Shutdown: 10:27 AM  
Time of Start-Up: 12:25 PM  
Duration of Shutdown/Malfunction: 1 hr 58 min

Reason for Shutdown/Malfunction:

- Air-Compressor System
- Blower
- High Gas Flow
- High Temperature
- LEL
- Low Gas Flow
- Low Temperature
- UV Scanner System
- Power Failure
- Scheduled Preventive Maintenance

Annual A/C maintenance  
by O&P compression

Signature 

Date 12/20/22

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc. continued on the back side?

yes / no

## **SECTION IV**

### **QUARTERLY LANDFILL GAS EMISSION MONITORING**

- LANDFILL SURFACE SWEEP
- COMPONENT CHECK


**CITY OF MOUNTAIN VIEW**  
**SHORELINE LANDFILL, FACILITY ID A2740**  
**QUARTERLY LANDFILL SURFACE SWEEP**  
**July 1 - December 31, 2022**

Date	Field Name*	Leaks Detected Above Regulatory Limit	Action/Comment
7/7/2022	Vista	No	
7/26/2022	Back Nine (four)	No	
7/27/2022	Back Nine (five)	Yes	Remove vegetative cover, raise well, and add new compact and slope for drainage
8/4/2022	6A Northeast	No	
8/10/2022	Front Nine	No	
9/27/2022	North Shore	No	
9/30/2022	Crittenden	No	
10/27/2022	Back Nine (four)	No	
10/27/2022	Back Nine (five)	No	
10/31/2022	Vista	No	
11/22/2022	6A Northeast	No	
11/22/2022	Front Nine	No	
12/19/2022	North Shore	No	
12/20/2022	Crittenden	No	

\* Monitoring records are attached

# VISTA - COMPLETE SYSTEM MAP


04/30/2018



<input checked="" type="checkbox"/> SURFACE SWEEP	<input type="checkbox"/> CAP INSPECTION	100' GRID	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/> LEAKS DETECTED OR FOUND
Inspection Date : <u>7/7/22</u> Start Time : <u>7:00AM</u> Finish Time: <u>9:45AM</u>			
Weather		<u>CLEAR</u>	
Instrument(s) Used		<u>TVA</u>	
Inspector(s)		<u>RAUL BANOA</u>	
Comments		<u>NO LEAKS DETECTED ABOVE REGULATORY LIMITS -</u>	
MPH WIND SPEED PPM GAS READING % CH4 GAS READING L=LOW AREA C=CRACK O=ODOR W=STANDING WATER			

# BACK NINE (FOUR) - COMPLETE SYSTEM MAP

04/30/2018



SURFACE SWEEP

CAP INSPECTION

100' GRID

YES  NO  LEAKS DETECTED OR FOUND

2.0 MPH WND SPEED

1.3 PPM GAS READING

% CH4 GAS READING

L=LOW AREA C=CRACK

O=ODOR W=STANDING WATER


Inspection Date :	7-26-22	Start Time :	8:40AM	Finish Time:	1:00 PM
Weather	Clear				
Instrument(s) Used	TVA 2020 / Gasdet				
Inspector(s)	Adrian Vega				
Comments	No leaks detected above regulatory limit				

Map Scale: 1" = 350'  
0 87.5 175 350 feet

- CONDENSATE PUMP STATION
- PROBES\_INSIDE
- PROBES\_OUTSIDE
- CONNECTION POINT
- END CAP
- HEADER
- HC TRANSITION
- HEADER\_10\_01\_SHP
- SUMP
- HORIZONTAL HEADER
- HEADERVALVE
- LFGLATERALVALVE
- LFGLATERALS
- TESTPORT
- VALVE
- PROPERTY\_BOUND
- VENTTRENCHBOXES
- VENTTRENCHBOXES
- PIEZOMETER
- VENTTRENCHSUMP

# BACK NINE (FIVE) - COMPLETE SYSTEM MAP

04/30/2018



SURFACE SWEEP

CAP INSPECTION

100' GRID

YES  NO  LEAKS DETECTED OR FOUND

2.0 MPH WIND SPEED

1.3 PPM GAS READING

% CH4 GAS READING

(L)=LOW AREA (C)=CRACK

(O)=ODOR (W)=STANDING WATER

Inspection Date : 7/27/12		Start Time : 8:00AM	Finish Time: 2:30PM
Weather		Clear	
Instrument(s) Used		TVA 8000 / Grator	
Inspector(s)		Adrian Vega.	
Comments		See Attached Paperwork	

CONDENSATE PUMP STATION

CONNECTION POINT

END CAP

HC TRANSITION

HEADERVALVE

LFGLATERALVALVE

LFGWELL

PIEZOMETER

PROBES\_INSIDE

PROBES\_OUTSIDE

PROBES\_REGULATORY



Map Scale: 1" = 300'

0 75 150 300 Feet

SUMP ----- AIR CONDEN\_LINES

TESTPORT ----- HEADER

VALVE ----- HEADER\_10\_01\_SHP

VENTTRENCHBOXES ----- HORIZONTAL HEADER

VENTTRENCHSUMP ----- LFGLATERS

PROPERTY\_BOUND

VENTTRENCHBOXES



**FINAL COVER REPAIR  
CITY OF MOUNTAIN VIEW**

<b>DATE:</b>	Identified	<u>8/8/22</u>	<b>SITE:</b>	Front Nine	Northshore
	Started	<u>8/11/22</u>		<input checked="" type="checkbox"/> Back Nine	Crittenden
	Completed	<u>8/16/22</u>		Vista	Cell 6A NE

**WEATHER:** Clear

<b>LOCATION:</b>	Grid #	<u>QQ4-QQ-18</u>	Other identifying information	_____
	Nearest Gas Well #	<u>LWB-06</u>	<u>See map.</u>	_____
	Approx. Distance from Well	<u>2'</u>	_____	_____

**TYPE OF REPAIR:**

CRACK	<input checked="" type="checkbox"/>	Clay	<input checked="" type="checkbox"/>	Vegetative
SUBSIDENCE	<input checked="" type="checkbox"/>	Clay	<input checked="" type="checkbox"/>	Vegetative
EROSION	<input type="checkbox"/>	Clay	<input type="checkbox"/>	Vegetative

**DESCRIPTION/ PROCEDURE FOR THE REPAIR:** Remove vegetative

crown, rip area, add new material compact and slope for drainage. (cracking)

Raise well, add dirt to fill in low spot. Reset box, compact and slope for drainage.

**COMMENTS:**

---



---



---



---

**MATERIALS:** Approx 200yds  
dirt

**EQUIPMENT:** Dump Truck, Water truck, Dozer, Motorgrader, Backhoe

**PERSONNEL:** Leon Rosario, Jason Beaman  
Adrian Vega, Raul Banda, Aless Valdez  
Ricardo, Steve Coats, Eric (wastewater)


**ATTACHMENT:** Map   
Photograph \_\_\_\_\_  
Other \_\_\_\_\_

AUG 17 2022

ENGR. & ENVIRONMENTAL  
COMPLIANCE DIVISION

# BACK NINE (FIVE) - COMPLETE SYSTEM MAP

04/30/2018



SURFACE SWEEP     CAP INSPECTION    100' GRID    YES  NO  LEAKS DETECTED OR FOUND

\_\_\_\_\_ MPH WIND SPEED

\_\_\_\_\_ PPM GAS READING

\_\_\_\_\_ % CH4 GAS READING

(L)=LOW AREA (C)=CRACK

(O)=ODOR (W)=STANDING WATER

Inspection Date :		Start Time :	Finish Time:
Weather			
Instrument(s) Used			
Inspector(s)			
Comments		<i>Cap Repair Location</i>	

**CONDENSATE PUMP STATION**  
**CONNECTION POINT**  
**END CAP**  
**HC TRANSITION**  
**HEADERVALVE**

**LFGLATERALVALVE**  
**LFGWELL**  
**PIEZOMETER**  
**PROBES\_INSIDE**  
**PROBES\_OUTSIDE**  
**PROBES\_REGULATORY**

**SUMP**  
**TESTPORT**  
**VALVE**  
**VENTTRENCHBOXES**  
**VENTTRENCHSUMP**

**AIR CONDEN\_LINES**  
**HEADER**  
**HEADER\_10\_01\_SHP**  
**HORIZONTAL HEADER**  
**LFGLATERALS**  
**PROPERTY\_BOUND**  
**VENTTRENCHBOXES**










# 6A NORTHEAST - COMPLETE SYSTEM MAP

04/30/2018




<input checked="" type="checkbox"/> SURFACE SWEEP	<input type="checkbox"/> CAP INSPECTION	100' GRID	YES <input type="checkbox"/>	NO <input checked="" type="checkbox"/> LEAKS DETECTED OR FOUND
_____ MPH WIND SPEED	_____ PPM GAS READING	_____ % CH4 GAS READING	_____ LOW AREA	_____ CRACK
_____ ODOR	_____ STANDING WATER	_____ COMMENTS	_____	_____
_____	_____	_____	_____	_____


Inspection Date : 8-4-22	Start Time : 9:05 AM	Finish Time: 10:50 AM
Weather	CLEAR	
Instrument(s) Used	TVA / KUBOTA	
Inspector(s)	RAUL BANDA	
Comments	NO LEAKS DETECTED ABOVE REGULATORY LIMITS	

# FRONT NINE - COMPLETE SYSTEM MAP

04/30/2018





- |                         |                 |                   |                 |                   |                 |
|-------------------------|-----------------|-------------------|-----------------|-------------------|-----------------|
| CONDENSATE PUMP STATION | HEADERVALVE     | PROBES_INSIDE     | VALVE           | AIR_CONDEN_LINES  | LGLATERTALS     |
| CONNECTION POINT        | LFGLATERALVALVE | PROBES_OUTSIDE    | VENTTRENCHBOXES | HEADER            | PROPERTY_BOUND  |
| END CAP                 | LFGWELL         | PROBES_REGULATORY | VENTTRENCHSUMP  | HEADER_10_01_SHP  | VENTTRENCHBOXES |
| HC TRANSITION           | SUMP            | TESTPORT          |                 | HORIZONTAL HEADER |                 |



<input checked="" type="checkbox"/> SURFACE SWEEP	<input type="checkbox"/> CAP INSPECTION	100' GRID	YES <input type="checkbox"/>	NO <input checked="" type="checkbox"/> LEAKS DETECTED OR FOUND																									
_____ MPH WIND SPEED	_____ PPM GAS READING	_____ % CH4 GAS READING																											
(L)=LOW AREA	(C)=CRACK	(O)=ODOR	(W)=STANDING WATER																										
<table border="1"> <thead> <tr> <th colspan="2">Inspection Date : 8-10-22</th> <th colspan="3">Start Time : 8:50 AM Finish Time: 10:40 AM</th> </tr> <tr> <th>Weather</th> <th colspan="4">CLEAR</th> </tr> </thead> <tbody> <tr> <td>Instrument(s) Used</td> <td colspan="4">TVA / KUBOTA</td> </tr> <tr> <td>Inspector(s)</td> <td colspan="4">RAUL BANOSA</td> </tr> <tr> <td>Comments</td> <td colspan="4">NO LEAKS DETECTED ABOVE REGULATORY LIMITS -</td> </tr> </tbody> </table>					Inspection Date : 8-10-22		Start Time : 8:50 AM Finish Time: 10:40 AM			Weather	CLEAR				Instrument(s) Used	TVA / KUBOTA				Inspector(s)	RAUL BANOSA				Comments	NO LEAKS DETECTED ABOVE REGULATORY LIMITS -			
Inspection Date : 8-10-22		Start Time : 8:50 AM Finish Time: 10:40 AM																											
Weather	CLEAR																												
Instrument(s) Used	TVA / KUBOTA																												
Inspector(s)	RAUL BANOSA																												
Comments	NO LEAKS DETECTED ABOVE REGULATORY LIMITS -																												

# NORTH SHORE - COMPLETE SYSTEM MAP

04/30/2018



SURFACE SWEEP

CAP INSPECTION

100' GRID

YES  NO  LEAKS DETECTED OR FOUND

ND MPH WIND SPEED

1.7 PPM GAS READING

— % CH4 GAS READING

= LOW AREA     = CRACK

= ODOOR     = STANDING WATER


Inspection Date :	<u>9/27/22</u>	Start Time : <u>10:00 AM</u>	Finish Time: <u>2:00 PM</u>
Weather	<u>Clear</u>		
Instrument(s) Used	<u>TVA 2020, Grates</u>		
Inspector(s)	<u>Adrian Vega</u>		<u>SEP 30 2022</u>
Comments	<u>No leaks detected above ENGR. &amp; ENVIRONMENTAL Regulatory limits</u>		

- CONDENSATE PUMP STATION
- CONNECTION POINT
- END CAP
- HC TRANSITION
- HEADERVALVE
- LGFLATERALVALVE
- LFGWELL
- PIEZOMETER

- PROBES\_INSIDE
  - PROBES\_OUTSIDE
  - PROBES\_REGULATORY
  - SUMP
  - TESTPORT
  - VALVE
  - VENTTRENCHBOXES
  - VENTTRENCHSUMP
- ... AIR\_CONDEN\_LINES
  - HEADER
  - HEADER\_10\_01\_SHP
  - HORIZONTAL\_HEADER
  - LGFLATERALS
  - PROPERTY\_BOUND
  - VENTTRENCHBOXES


# CRITTENDEN - COMPLETE SYSTEM MAP

04/30/2018




SURFACE SWEEP     CAP INSPECTION    100' GRID  
 NO MPH WIND SPEED  
 0.9 PPM GAS READING  
 % CH4 GAS READING  
 LOW AREA     CRACK  
 ODOOR     STANDING WATER

Inspection Date :	9/30/22 Start Time : 2:30 pm Finish Time: 5:30 pm		
Weather	Clear		
Instrument(s) Used	TVA		
Inspector(s)	Dionny Velasco		
Comments	No leaks detected above regulatory limit.		



# BACK NINE (FOUR) - COMPLETE SYSTEM MAP

04/30/2018



SURFACE SWEEP     CAP INSPECTION    100' GRID    YES  NO  LEAKS DETECTED OR FOUND

1.7 MPH WND SPEED

1.0 PPM GAS READING

% CH4 GAS READING

L=LOW AREA C=CRACK

O=ODOR V=STANDING WATER


Inspection Date :	10/27/22	Start Time :	3:00pm	Finish Time:	5:00pm
Weather	Clear				
Instrument(s) Used	TVA 2020 / Gasot				
Inspector(s)	Adrian Vega				
Comments	No leaks detected above regulatory limits.				

N  
Map Scale: 1" = 350'  
0 87.5 175 350 Feet


- CONDENSATE PUMP STATION
- ◆ CONNECTION POINT
- END CAP
- ▽ HC TRANSITION
- ▲ HEADERVALVE
- LGFLATERALVALVE
- LGFWELL
- PIEZOMETER
- PROBES\_INSIDE
- PROBES\_OUTSIDE
- PROBES\_REGULATORY
- SUMP
- ▲ TESTPORT
- VALVE
- VENTTRENCHBOXES
- VENTTRENCHSUMP
- - - AIR\_CONDEN\_LINES
- HEADER
- HEADER\_10\_01\_SHP
- HORIZONTAL\_HEADER
- LGFLATERALS
- PROPERTY\_BOUND
- VENTTRENCHBOXES

# BACK NINE (FIVE) - COMPLETE SYSTEM MAP

04/30/2018




<input checked="" type="checkbox"/> SURFACE SWEEP	<input type="checkbox"/> CAP INSPECTION	100' GRID	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/> LEAKS DETECTED OR FOUND
1.7 MPH WIND SPEED			
1.0 PPM GAS READING			
% CH4 GAS READING			
(L)=LOW AREA (C)=CRACK			
(O)=ODOR (W)=STANDING WATER			
Inspection Date : 10/27/22 Start Time : 7:00AM Finish Time: 3:00PM Weather: Clear Instrument(s) Used: TVA 2020 / Brator Inspector(s): Adrian Vega Comments: No leaks detected above regulatory limits			



# VISTA - COMPLETE SYSTEM MAP


04/30/2018



<input checked="" type="checkbox"/> SURFACE SWEEP	<input type="checkbox"/> CAP INSPECTION	100' GRID	YES <input type="checkbox"/>	NO <input checked="" type="checkbox"/> LEAKS DETECTED OR FOUND
2.0 MPH WIND SPEED	Inspection Date : 10/31/22 Start Time : 10:00 AM Finish Time: 3:00 PM			
0.9 PPM GAS READING	Weather Clear			
% CH4 GAS READING	Instrument(s) Used TIA 2020/Gator OCT 31 2022			
(L)=LOW AREA (C)=CRACK	Inspector(s) Adrian Vega			
(O)=ODOR (W)=STANDING WATER	Comments No leaks detected above regulatory limits			
ENGR. & ENVIRO COMPLIANCE DIV.				

# 6A NORTHEAST - COMPLETE SYSTEM MAP

04/30/2018



CONDENSATE PUMP STATION	HC TRANSITION	LFGWELL	PROBES_REGULATORY	VENTTRENCHBOXES	AIR_CONDEN_LINES	LFGLATERALS	Map Scale: 1" = 375'
◆ CONNECTION POINT	▼ HC TRANSITION	◆ PROBES_INSIDE	◆ VENTTRENCHSUMP	● VENTTRENCHSUMP	- - - AIR_CONDEN_LINES	— LFGLATERALS	
] END CAP	◆ HEADERVALVE	◆ PROBES_OUTSIDE	◆ TESTPORT	● HEADER	— PROPERTY_BOUND	— PROPERTY_BOUND	
	◆ LFGLATERALVALVE	◆ VALVE	◆ VENTPORT	— HEADER_10_01_SHP	— VENTTRENCHBOXES	— VENTTRENCHBOXES	
				— HORIZONTAL HEADER			

SURFACE SWEEP       CAP INSPECTION      100' GRID      YES  NO  LEAKS DETECTED OR FOUND

\_\_\_\_\_ MPH WIND SPEED

\_\_\_\_\_ PPM GAS READING

\_\_\_\_\_ % CH4 GAS READING


(L)=LOW AREA    (C)=CRACK

(O)=ODOR        (W)=STANDING WATER

Inspection Date : <i>11/30/22</i>	Start Time : <i>10:00 AM</i>	Finish Time: <i>1:00 PM</i>
Weather	<i>Clear</i>	
Instrument(s) Used	<i>TVA 2020 Operator</i>	
Inspector(s)	<i>Adrian Vega</i>	
Comments	<i>No leaks detected per ENGR. &amp; ENVIRONMENTAL COMPLIANCE DIVISION</i>	

# FRONT NINE - COMPLETE SYSTEM MAP

04/30/2018



- |                         |                 |                   |                   |                  |                 |
|-------------------------|-----------------|-------------------|-------------------|------------------|-----------------|
| CONDENSATE PUMP STATION | HEADERVALVE     | PROBES_INSIDE     | VALVE             | AIR_CONDEN_LINES | LGLATERS        |
| CONNECTION POINT        | LGGLATERALVALVE | PROBES_OUTSIDE    | VENTTRENCHBOXES   | HEADER           | PROPERTY_BOUND  |
| END CAP                 | LFGWELL         | PROBES_REGULATORY | VENTTRENCHSUMP    | HEADER_10_01_SHP | VENTTRENCHBOXES |
| HC TRANSITION           | SUMP            | TESTPORT          | HORIZONTAL HEADER |                  |                 |

Map Scale: 1" = 400'  
0 100 200 400 Feet


N  
600 CASTRO STREET MOUNTAIN VIEW CA 94039  
For information only. The City of Mountain View does not warrant  
the accuracy of the information contained herein. 04/30/2018

<input checked="" type="checkbox"/> SURFACE SWEEP	<input type="checkbox"/> CAP INSPECTION	100' GRID	YES <input type="checkbox"/>	NO <input checked="" type="checkbox"/> LEAKS DETECTED OR FOUND
Inspection Date : <u>11/22/22</u> Start Time : <u>8:00AM</u> Finish Time: <u>10:00AM</u>				
Weather <u>Clear</u>				
Instrument(s) Used <u>TVA 2020/Gator</u>				
Inspector(s) <u>Adrian Vega</u>				
Comments				
NOV 30 2022 ENGR. & ENVIRONMENTAL COMPLIANCE DIVISION				

MPH WIND SPEED  
 PPM GAS READING  
 % CH4 GAS READING  
 L=LOW AREA    C=CRACK  
 O=ODOR    W=STANDING WATER

# NORTH SHORE - COMPLETE SYSTEM MAP

04/30/2018




Map Scale: 1" = 300'  
0 75 150 300 Feet

<input checked="" type="checkbox"/> SURFACE SWEEP	<input type="checkbox"/> CAP INSPECTION	100' GRID	YES <input type="checkbox"/>	NO <input checked="" type="checkbox"/> LEAKS DETECTED OR FOUND
Inspection Date : 12/19/22 Start Time : 7:30 AM Finish Time: 9:30 AM				
Weather : clear				
Instrument(s) Used : TVA				
Inspector(s) : LEON ROLAZIO				
Comments : NO Leaks Detected over Regulatory limit				


LOW AREA     CRACK  
 ODOR     STANDING WATER

- CONDENSATE PUMP STATION
- ◆ CONNECTION POINT
- END CAP
- ▽ HC TRANSITION
- ▲ HEADERVALVE
- ▶ LFGLATERALVALVE
- LFGWELL
- PIEZOMETER
- PROBES\_INSIDE
- PROBES\_OUTSIDE
- PROBES\_REGULATORY
- SUMP
- ▲ TESTPORT
- ▶ VALVE
- VENTTRENCHBOXES
- VENTTRENCHSUMP
- AIR\_CONDEN\_LINES
- HEADER
- HEADER\_10\_01\_SHP
- HORIZONTAL HEADER
- LFGLATERALS
- PROPERTY\_BOUND
- VENTTRENCHBOXES



# CRITTENDEN - COMPLETE SYSTEM MAP

04/30/2018



SURFACE SWEEP

CAP INSPECTION

100' GRID

YES

NO  LEAKS DETECTED OR FOUND

**ND** MPH WIND SPEED

**2.1** PPM GAS READING

% CH4 GAS READING

=LOW AREA

=CRACK


=ODOR

=STANDING WATER

Inspection Date :	12/10/12	Start Time :	7:30 am	Finish Time:	9:30 am
Weather	Clear				
Instrument(s) Used	TVA				
Inspector(s)	LEON ROMERO				
Comments	No Leaks detected over Regulatory limit				



Map Scale: 1" = 200



**CITY OF MOUNTAIN VIEW**  
**SHORELINE LANDFILL, FACILITY ID A2740**  
**QUARTERLY COMPONENT CHECK**  
**July 1 - December 31, 2022**

**FLARE STATION COMPONENT CHECK**

Date	Location*	Leaks Detected - Above Regulatory limits
7/26/2022	Flare Station	No
10/26/2022	Flare Station	No

**MICROTURBINE COMPONENT CHECK**


Date	Location*	Leaks Detected - Above Regulatory limits
7/26/2022	Flare Statoion (S-16)	No
7/26/2022	Sewage Pump Station (S-17)	No
10/26/2022	Flare Statoion (S-16)	No
10/26/2022	Sewage Pump Station (S-17)	No

**LFG FIELD COMPONENT CHECK**

Date	Location*	Leaks Detected - Above Regulatory limits
7/1/2022	Vista	No
7/26/2022	Back Nine	Yes
8/4/2022	6 Acre Northeast	No
8/10/2022	Front Nine	No
9/27/2022	North Shore	No
9/30/2022	Crittenden	No
10/27/2022	Back Nine	No
10/27/2022	Vista	No
11/22/2022	6 Acre Northeast	No
11/22/2022	Front Nine	No
12/19/2022	North Shore	No
12/20/2022	Crittenden	No

**FLARE STATION COMPONENT LEAK CHECK FORM**  
**CITY OF MOUNTAIN VIEW**

DATE: 7/24/02

Signature 


**Leak Detected:**

NO       YES      If Yes, Concentration Above Background (ppm) \_\_\_\_\_  
 (If form completed in response to landfill gas collection and emissions control system leak, repair must be completed within 7 calendar days, and completed form must be returned to EEC for two year retention.)

DATE: Identified \_\_\_\_\_ Started \_\_\_\_\_  
 Completed \_\_\_\_\_

**COMPONENT:**

**OTHER IDENTIFYING INFORMATION**



- V
- V
- V
- CT1
- V
- V
- CT2
- V
- V
- CT3

[Navigation Bar: Back, Forward, Home, Help, Print Screen, Screens Menu]

**DESCRIPTION/ PROCEDURE FOR THE REPAIR:** \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

**COLLECTION SYSTEM SHUTDOWN:** \_\_\_\_\_

**LENGTH OF SHUTDOWN:** \_\_\_\_\_

**PERSONNEL:** \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

**ATTACHMENT:** Map \_\_\_\_\_  
 Photograph \_\_\_\_\_  
 Other \_\_\_\_\_

**COMMENTS:** \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

**SULFER PPM:** \_\_\_\_\_

**H<sub>2</sub>S PPM:** \_\_\_\_\_

JUL 29 2022

**ENGR. & ENVIRONMENTAL  
 COMPLIANCE DIVISION**

Flare Station Quarterly Form

1/20/2006

**FLARE STATION COMPONENT LEAK CHECK FORM**  
**CITY OF MOUNTAIN VIEW**

DATE: 10/26/02

Signature 


**Leak Detected:**

NO       YES      If Yes, Concentration Above Background (ppm) \_\_\_\_\_  
 (If form completed in response to landfill gas collection and emissions control system leak, repair must be completed within 7 calendar days, and completed form must be returned to EEC for two-year retention.)

DATE: Identified \_\_\_\_\_ Started \_\_\_\_\_  
 Completed \_\_\_\_\_

**COMPONENT:**

FLARE STATION



**OTHER IDENTIFYING INFORMATION**

OCT 30 2022

ENGR. & ENVIRONMENTAL  
COMPLIANCE DIVISION

- |                            |     |
|----------------------------|-----|
| <input type="checkbox"/> V |     |
| <input type="checkbox"/> V | CT1 |
| <input type="checkbox"/> V | CT2 |
| <input type="checkbox"/> V | CT3 |

File: 10000000 - Last Edited: 10/26/2002 - Page: 1 of 1 - Print: 100% | Undo/Redo | More Options | Comment | Delete | Value | Status | Metric | Alarm Sum | Alarm Rst | Print Screen | Screens Menu |

**DESCRIPTION/ PROCEDURE FOR THE REPAIR:** \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

**COLLECTION SYSTEM SHUTDOWN:** \_\_\_\_\_

**LENGTH OF SHUTDOWN:** \_\_\_\_\_

**PERSONNEL:** \_\_\_\_\_

**ATTACHMENT:**

Map \_\_\_\_\_

Photograph \_\_\_\_\_

Other \_\_\_\_\_


**COMMENTS:** \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

**SULFER PPM:** \_\_\_\_\_

**H<sub>2</sub>S PPM:** \_\_\_\_\_

CITY OF MOUNTAIN VIEW  
MICROTURBINE COMPONENT LEAK CHECK FORM AT FLARE STATION

DATE: 7/26/22

Signature: 


Leak Detected

NO  YES If yes, concentration above background (ppm) \_\_\_\_\_  
(If concentration at 1 cm more than 1000 ppm, repair must be completed within 7 days)

DATE: Identified \_\_\_\_\_ Started \_\_\_\_\_

Completed \_\_\_\_\_

COMPONENT



DESCRIPTION/ PROCEDURE FOR REPAIR \_\_\_\_\_

\_\_\_\_\_

PERSONNEL \_\_\_\_\_

\_\_\_\_\_

JUL 29 2022  
COMMENTS \_\_\_\_\_


ENGR. & ENVIRONMENTAL  
COMPLIANCE DIVISION

CITY OF MOUNTAIN VIEW  
MICROTURBINE COMPONENT LEAK CHECK FORM AT SEWAGE PUMP STATION

DATE:

7/26/22

Signature:



Leak Detected



NO  YES If yes, concentration above background (ppm) \_\_\_\_\_  
(If concentration at 1 cm more than 1000 ppm, repair must be completed within 7 days)

DATE: Identified

\_\_\_\_\_


Started

\_\_\_\_\_

Completed

\_\_\_\_\_

COMPONENT



DESCRIPTION/ PROCEDURE FOR REPAIR

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

PERSONNEL

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

COMMENTS

\_\_\_\_\_

\_\_\_\_\_

JUL 29 2022

ENGR. & ENVIRONMENTAL  
COMPLIANCE DIVISION

CITY OF MOUNTAIN VIEW  
MICROTURBINE COMPONENT LEAK CHECK FORM AT FLARE STATION

DATE: 10/26/22

Signature: 

Leak Detected


NO  YES If yes, concentration above background (ppm) \_\_\_\_\_  
(If concentration at 1 cm more than 1000 ppm, repair must be completed within 7 days)

DATE: Identified \_\_\_\_\_

Started \_\_\_\_\_

Completed \_\_\_\_\_

COMPONENT



DESCRIPTION/ PROCEDURE FOR REPAIR \_\_\_\_\_

PERSONNEL \_\_\_\_\_

COMMENTS \_\_\_\_\_

CITY OF MOUNTAIN VIEW  
MICROTURBINE COMPONENT LEAK CHECK FORM AT SEWAGE PUMP STATION

DATE:

10/26/22

Signature:



Leak Detected

NO

YES If yes, concentration above background (ppm) \_\_\_\_\_

(If concentration at 1 cm more than 1000 ppm, repair must be completed within 7 days)

DATE: Identified

\_\_\_\_\_


Started

\_\_\_\_\_

Completed

\_\_\_\_\_

COMPONENT



OCT 30 2022  
ENGR. & ENVIRONMENTAL  
COMPLIANCE DIVISION

DESCRIPTION/ PROCEDURE FOR REPAIR

\_\_\_\_\_

PERSONNEL

\_\_\_\_\_

COMMENTS

\_\_\_\_\_

**City of Mountain View  
Shoreline Landfill  
Component leak check and repair form  
Site Name: VISTA**

Inspection Date: 7-1-22 Start Time: 9:15 AM Finish Time: 12:00 PM

Inspector Name: R AUL SANDA

Instrument Used: TVA

Weather: CLEAR

Wind Speed: ND

Leak Detected: NO LEAKS DETECTED  
ABOVE REGULATOR Lm, 1

No.	Component	OVA Reading 1 CM above vault (PPM)	OVA Reading 2 IN above vault (PPM)	Repair/Remonitoring			Action Taken
				Repair Date	Re- monitorin g Date	OVA Reading one centimeter above vault With (PPM)	
1	ACDRAIN-1	ND	ND				
2	BGTP-01						
3	BGTP-02						
4	BGV-01H						
5	BGV-1AC						
6	VLE-01						
7	VLE-02						
8	VA-01A						
9	VA-01AC						
10	VA-01AL						
11	VA-01C						
12	VA-02AC						
13	VA-01						
14	VA-01V						
15	VA-02						
16	VA-02V						
17	VA-03						
18	VA-03V						
19	VA3A						
20	VA-03AV						
21	VA-04						
22	VA-04V						
23	VA-05						
24	VA-05V						
25	VA-06						
26	VA-06V						
27	VAHZ						
28	VAHZ-01						
29	VAHZ-02						
30	VAHZ-03						
31	VB-01						
32	VB-01V						
33	VB-02R						
34	VB-02RV						
35	VB-03						
36	VB-03V						
37	VB-03AC						
38	VB-03A	↓	↓				

JUL 29 2022

ENGR. & ENVIRONMENTAL  
COMPLIANCE DIVISION

No.	Component	OVA Reading 1 CM above vault (PPM)	OVA Reading 2 IN above vault (PPM)	Repair/Remonitoring			
				Repair Date	Re- monitorin g Date	OVA Reading one centimeter above vault With (PPM)	Action Taken
39	VB-03AV	NO	NO				
40	VB-04						
41	VB-04V						
42	VB-05A						
43	VB-05AV						
44	VB-05R						
45	VB-05RV						
46	VB-06						
47	VB-06V						
48	VB-07						
49	VB-07V						
50	VB-08						
51	VB-08V						
52	VB-09						
53	VB-09AC						
54	VB-09V						
55	VC-01						
56	VC-01V						
57	VC-02						
58	VC-02V						
59	VC-03						
60	VC-03V						
61	VC-04						
62	VC-04AC						
63	VC-04V						
64	VC-05						
65	VC-05V						
66	VC-06						
67	VC-06V						
68	VC-07						
69	VC-07V						
70	VC-08						
71	VC-08V						
72	VC-10						
73	VC-10V						
74	VE-01						
75	VE-01V						
76	VE-03						
77	VE-03AC						
78	VE-03V						
79	VE-04R						
80	VE-04RV						
81	VE-05						
82	VE-05V						
83	VE-06						
84	VE-06V						
85	VE-07						
86	VE-07V						
87	VE-08	↓	↓				

No.	Component	OVA Reading 1 CM above vault (PPM)	OVA Reading 2 IN above vault (PPM)	Repair/Remonitoring			
				Repair Date	Re- monitortin g Date	OVA Reading one centimeter above vault With (PPM)	Action Taken
88	VE-08V	ND	ND				
89	VE-09						
90	VE-09V						
91	VE-10						
92	VE-10V						
93	VE-11						
94	VE-11AC						
95	VE-11V						
96	VF-01						
97	VF-01V						
98	VF-02						
99	VF-02V						
100	VF-03						
101	VF-03AC						
102	VF-03V						
103	VF-04						
104	VF-04V						
105	VF-05R						
106	VF-05RV						
107	VF-06						
108	VF-06AC						
109	VF-06V						
110	VF-06V						
111	VF-07						
112	VF-07V						
113	VF07A						
114	VF-07AV						
115	VF-08R						
116	VF-08RV						
117	VF-09						
118	VF-09AC						
119	VF-09V						
120	VF-10						
121	VF-10V						
122	VF11						
123	VF-11V						
124	VG-01						
125	VG-01V						
126	VG-01A						
127	VG-01AV						
128	VG-02						
129	VG-02V						
130	VG-02R						
131	VG-02RV						
132	VG-03						
133	VG-03V						
134	VG-03A						
135	VG-03AV						
136	VG-04						

No.	Component	OVA Reading 1 CM above vault (PPM)	OVA Reading 2 IN above vault (PPM)	Repair/Remonitoring			
				Repair Date	Re- monitorin g Date	OVA Reading one centimeter above vault With (PPM)	Action Taken
137	VG-04V	ND	ND				
138	VG-04AC						
139	VG-04A						
140	VG-04AV						
141	VG-05						
142	VG-05AC						
143	VG-05V						
144	VG-06						
145	VG-06V						
146	VH-01						
147	VH-01V						
148	VH-02						
149	VH-02AC						
150	VH-02V						
151	VH-03						
152	VH-03V						
153	VH-04						
154	VH-04AC						
155	VH-04V						
156	VH-05						
157	VH-05AC						
158	VH-05V						
159	VH-06						
160	VH-06V						
161	VH-07						
162	VH-07V						
163	VH-08						
164	VH-08AC						
165	VH-08V						
166	VH-09						
167	VH-9V						
168	VH-10						
169	VH-10AC						
170	VH-10V						
171	VH-11						
172	VH-11V						
173	VH-12						
174	VH-12V						
175	VH-13						
176	VH-13V						
177	VJ-01						
178	VJ-01V						
179	VJ-02R						
180	VJ-02RV						
181	VJ-03R						
182	VJ-03RV						
183	VJ-04A						
184	VJ-04AV						
185	VJ-04R	↓	↓				

No.	Component	OVA Reading 1 CM above vault (PPM)	OVA Reading 2 IN above vault (PPM)	Repair/Remonitoring			
				Repair Date	Re- monitorin g Date	OVA Reading one centimeter above vault With (PPM)	Action Taken
186	VJ-04RV	ND	ND				
187	VJ-05R						
188	VJ-05RV						
189	VJ-06						
190	VJ-06V						
191	VJ-07R						
192	VJ-07RV						
193	VJ-08						
194	VJ-08V						
195	VJ-09R						
196	VJ-09RV						
197	VJ-10						
198	VJ-10V						
199	VJ-11R						
200	VJ-11RV						
201	VK-01						
202	VK-01V						
203	VK-02						
204	VK-02V						
205	VK-03						
206	VK-03V						
207	VK-04						
208	VK-04V						
209	VK-05						
210	VK-05V						
211	VSB-01						
212	VSB-02						
213	VSE-03						
214	VSF-01						
215	VSH-01						
216	VSJ-01						
217	VSJ-02						
218	VTPA-01						
219	VTPA-02						
220	VTPA-03						
221	VTPB-01						
222	VTPB-02						
223	VTPB-03						
224	VTPB-04						
225	VTPC-01						
226	VTPC-02						
227	VTPE-01						
228	VTPE-02						
229	VTPF-01						
230	VTPF-02						
231	VTPF-03						
232	VTPF-04						
233	VTPG-01	↓	↓				
234	VTPG-02	↓	↓				

No.	Component	OVA Reading 1 CM above vault (PPM)	OVA Reading 2 IN above vault (PPM)	Repair/Remonitoring			Action Taken
				Repair Date	Re- monitorin g Date	OVA Reading one centimeter above vault With (PPM)	
235	VTPG-03	ND	ND				
236	VTPG-04						
237	VTPH-01						
238	VTPH-02						
239	VTPH-03						
240	VTPH-04						
241	VTPJ-01						
242	VTPJ-02						
243	VTPJ-03						
244	VTPJ-05						
245	VTPK-01						
246	VTPK-02						
247	VVA-01H						
248	VVA-02H						
249	VVA-01AC						
250	VVA-02AC						
251	VVB-01H						
252	VVB-02AC						
253	VVB-02H						
254	VVB-01AC						
255	VVC-01H						
256	VVC-02H						
257	VVC-03H						
258	VVC-01AC						
259	VVC-01V						
260	VVC-02AC						
261	VVF-01H						
262	VVF-02H						
263	VVF-03H						
264	VVF-01AC						
265	VVF-02AC						
266	VVF-03AC						
267	VVG-01AC						
268	VVG-01H						
269	VVG-02AC						
270	VVG-02H						
271	VVG-03H						
272	VVG-04H						
273	VVG-03AC						
274	VVG-04AC						
275	VWH-01H						
276	VWH-02H						
277	VWH-03H						
278	VWH-01AC						
279	VWH-02AC						
280	VWH-03AC						
281	VWJ-01H						
282	VWJ-04H						
283	VWJ-05H						

S - Box Sealed

V- Vacuum Adjusted

4/12/2006

**City of Mountain View**  
**Shoreline Landfill**  
**Component leak check and repair form**  
**Site Name: BACK NINE**

Inspection Date: July 26<sup>th</sup>, 2019 Start Time: 8:40 AM Finish Time: 2:30 PM

Inspector Name: Adrian Vega Instrument Used: TVA 2020 /sniffer

Weather: Clear Leak Detected:

No.	Component	OVA Reading 1 CM above vault (PPM)	OVA Reading 2 IN above vault (PPM)	Repair Date	Re- monitoring Date	Repair/Remonitoring		Action Taken
							OVA Reading 1 CM above vault With (PPM)	
1	WA-01	ND	ND					
2	WA-01V							
3	WA-02							
4	WA-02V							
5	WA-04							
6	WA-04V							
7	WA-05							
8	WA-05V							
9	WA-06							
10	WA-06V							
11	WA-07							
12	WA-07V							
13	WA-08							
14	WA-08V							
15	WA-09							
16	WA-09V							
17	WA-10							
18	WA-10V							
19	WA-11							
20	WA-11V							
21	WA-12							
22	WA-12V							
23	WA-13							
24	WA-13V							
25	WA-14							
26	WA-14V							
27	WA-15							
28	WA-15V							
29	WA-16							
30	WA-16V							
31	WA-17							
32	WA-17V							
33	WA-18							
34	WA-18V							
35	WA-19							
36	WA-19V							
37	WA-20							
38	WA-20V							
39	WA-21	ND	ND					

		Repair/Remonitoring					
No.	Component	OVA Reading 1 CM above vault (PPM)	OVA Reading 2 IN above vault (PPM)	Repair Date	Re- monitoring Date	OVA Reading 1 CM above vault With (PPM)	Action Taken
40	WA-21V	ND	ND				
41	WA-22						
42	WA-22V						
43	WA-23						
44	WA-23V						
45	WA-24						
46	WA-24V						
47	WA-25						
48	WA-25V						
49	WA-26						
50	WA-26V						
51	WA-27						
52	WA-27V						
53	WA-28						
54	WA-28V						
55	WA-29						
56	WA-29V						
57	WB-01						
58	WB-01V						
59	WB-02						
60	WB-02V						
61	WB-03						
62	WB-03V						
63	WB-04						
64	WB-04V						
65	WB-05						
66	WB-05A						
67	WB-05AV	ND	ND				
68	W-06	1,800	1,000	8/12/22	8/15/22	ND	See Attached Paper work
69	WB-06V	ND	ND				
70	WB-06A						
71	WB-06AV						
72	WB-07						
73	WB-07V						
74	WB-07A						
75	WB-07AV						
76	WB-08	ND	ND				
77	WB-08V	3,000	3,050	8/12/22	8/15/22	ND	See Attached Paper work
78	WB-09	ND	ND				
79	WB-09V						
80	WB-10						
81	WB-10V						
82	WB-11						
83	WB-11V						
84	WB-12						
85	WB-12V						
86	WB-12A						
87	WB-12AV						
88	WB-13	ND	ND				

				Repair/Remonitoring			
No.	Component	OVA Reading 1 CM above vault (PPM)	OVA Reading 2 IN above vault (PPM)	Repair Date	Re- monitoring Date	OVA Reading 1 CM above vault With (PPM)	Action Taken
89	WB-13V	ND	ND				
90	WB-14						
91	WB-14V						
92	WB-15						
93	WB-15V						
94	WB-16						
95	WB-16V						
96	WB-17						
97	WB-17V						
98	WC-01						
99	WC-01V						
100	WC-02						
101	WC-02V						
102	WC-03						
103	WC-03V						
104	WC-04						
105	WC-04V						
106	WD-01						
107	WD-01V						
108	WD-02						
109	WD-02V						
110	WD-03						
111	WD-03V						
112	WD-04						
113	WD-04V						
114	WE-01						
115	WE-01V						
116	WE-01A						
117	WE-01AV						
118	WE-02						
119	WE-02V						
120	WE-03						
121	WE-03V						
122	WE-04						
123	WE-04V						
124	WE-05						
125	WE-05V						
126	WF-01						
127	WF-01V						
128	WF-02						
129	WF-02V						
130	WSA-01						
131	WSA-02						
132	WSA-03						
133	WSB-01						
134	WSB-02						
135	WSB-03						
136	WSC-01						
137	WSC-02	ND	ND				

No.	Component	Repair/Remonitoring					
		OVA Reading 1 CM above vault (PPM)	OVA Reading 2 IN above vault (PPM)	Repair Date	Re- monitoring Date	OVA Reading 1 CM above vault With (PPM)	Action Taken
138	WSD-01	ND	ND				
139	WSD-02						
140	WSE-01						
141	WSE-02						
142	WSF-01						
143	WTA-14						
144	WTP-10						
145	WTPA-01						
146	WTPA-20						
147	WTPA-25						
148	WTPA-30						
149	WTPA-40						
150	WTPA-05						
151	WTPB-01						
152	WTPB-10	ND	ND				
153	WTPB-20	3,500	3,000	8/12/22	8/15/22	ND	See Attached Paperwork
154	WTPB-29	ND	ND				
155	WTPB-34						
156	WTPB-37						
157	WTPB-40						
158	WTPB-45						
159	WTPC-05						
160	WTPD-09						
161	WTPE-10						
162	WTPE-01						
163	WTPF-05						
164	WTPF-07						
165	WVA-01ACH						
166	WVA-13H						
167	WVA-14ACH						
168	WVA-15ACH						
169	WVA-24ACH						
170	WVA-25ACH						
171	WVA-MAIN1						
172	WVA-MAIN2						
173	WVB-01ACH						
174	WVB-18ACH						
175	WVB-29ACH						
176	WVB-45ACH						
177	WV-01ACH						
178	WVC-14ACH						
179	WVC-01VAS						
180	WVD-01ACH						
179	WVE-01ACH						
180	WVE-16ACH	ND	ND				

2011-05-11a

S - Box Sealed

V- Vacuum Adjusted

**FINAL COVER REPAIR  
CITY OF MOUNTAIN VIEW**

<b>DATE:</b>	Identified	<u>8/8/22</u>	<b>SITE:</b>	<input type="checkbox"/> Front Nine	Northshore
Started	<u>8/11/22</u>	<input checked="" type="checkbox"/>	Back Nine	<input type="checkbox"/>	Crittenden
Completed	<u>8/16/22</u>	<input type="checkbox"/>	Vista	<input type="checkbox"/>	Cell 6A NE

**WEATHER:** Clear

<b>LOCATION:</b>	Grid #	<u>QQ41-QQ-18</u>	Other identifying information	<u>QQ-22-QQ-23</u>
Nearest Gas Well #	<u>LWB-06</u>	<u>See map.</u>	<u>LWB-08</u>	
Approx. Distance from Well	<u>2'</u>			

**TYPE OF REPAIR:**

CRACK	<input checked="" type="checkbox"/>	Clay	<input checked="" type="checkbox"/>	Vegetative
SUBSIDENCE	<input checked="" type="checkbox"/>	Clay	<input checked="" type="checkbox"/>	Vegetative
EROSION	<input type="checkbox"/>	Clay	<input type="checkbox"/>	Vegetative

**DESCRIPTION/ PROCEDURE FOR THE REPAIR:** Remove vegetative

crown, rip area, add new material compact and slope for drainage. (cracking)

Raise well, add dirt to fill in low spot. Reset box, compact and slope for drainage.

**COMMENTS:**

---



---



---



---

**MATERIALS:** Approx 200yds  
dirt

**EQUIPMENT:** Dump Truck, Water  
truck, Dozer, Motorgrader,  
Baichoe

**PERSONNEL:** Leon Rosario, Jason Bean  
Adrian Vega, Raul Banda, Aless Valdez  
Ricardo, Steve Coats, Eric (wastewater)


**ATTACHMENT:** Map   
Photograph \_\_\_\_\_  
Other \_\_\_\_\_

AUG 17 2022

ENGR. & ENVIRONMENTAL  
COMPLIANCE DIVISION

# BACK NINE (FIVE) - COMPLETE SYSTEM MAP

04/30/2018



<input type="checkbox"/> SURFACE SWEEP	<input type="checkbox"/> CAP INSPECTION	100' GRID	YES <input type="checkbox"/>	NO <input type="checkbox"/>	LEAKS DETECTED OR FOUND <input type="checkbox"/>
Inspection Date : Start Time : Finish Time:					
Weather					
Instrument(s) Used					
Inspector(s)					
Comments <i>Cap Repair Location</i>					









**City of Mountain View  
Shoreline Landfill**  
**Component leak check and repair form**  
**Site Name: 6 Acre North East**

Inspection Date: 8-4-22 Start Time: 7:15 AM Finish Time: 9:05 AM

Inspector Name: RAUL BANDA

Instrument Used: TVA / KUBOTA

Weather: CLEAR

Leak Detected: NO LEAKS DETECTED ABOVE REGULATORY LIMITS

S. No.	Component	OVA Reading 1 CM above vault (PPM)	OVA Reading 2 IN above vault (PPM)	Repair/Remonitoring			
				Repair Date	Re- monitoring Date	OVA Reading 1 CM above vault With (PPM)	Action Taken
1	NEA01	ND	ND				
2	NEA01L						
3	NEA02						
4	NEA02L						
5	NEA03						
6	NEA03L						
7	NEA04						
8	NEA04L						
9	NEA05						
10	NEA05L						
11	NEA06						
12	NEA06L						
13	NEA07						
14	NEA07L						
15	NEA08						
16	NEA08L						
17	NEA09						
18	NEA09L						
19	NEA10						
20	NEA10L						
21	NEA11						
22	NEA11L						
23	NEA12						
24	NEA12L						
25	NEA13						
26	NEA13L						
27	NEA14						
28	NEA14L						
29	NEA15						
30	NEA15L						
31	NEA16						
32	NEA16L						
33	NEB01						
34	NEB01L						
35	NEB02						
36	NEB02L	V	↓				
37	NEB03						

AUG 31 2022

ENGR. & ENVIRONMENTAL  
COMPLIANCE DIVISION

S. No.	Component	OVA Reading 1 CM above vault (PPM)	OVA Reading 2 IN above vault (PPM)	Repair/Remonitoring			
				Repair Date	Re- monitoring Date	OVA Reading 1 CM above vault With (PPM)	Action Taken
38	NEB03L	ND	ND				
39	NEB04						
40	NEB04L						
41	NEB05						
42	NEB05L						
43	NEB06						
44	NEB06L						
45	NEB07						
46	NEB07L						
47	NEB08						
48	NEB08L						
49	NEB09						
50	NEB09L						
51	NEB10						
52	NEB10L						
53	NEB11						
54	NEB11L						
55	NEB12						
56	NEB12L						
57	NEB13						
58	NEB13L						
59	NEB14						
60	NEB14L						
61	NEC01						
62	NEC01L						
63	NEC02						
64	NEC02L						
65	NEC03						
66	NEC03L						
67	NED01						
68	NED01L						
69	NED02						
70	NED02L						
71	NED03						
72	NED03L						
73	NEE01						
74	NEE01L						
75	NEE02						
76	NEE02L						
77	NEE03						
78	NEE03L						
79	NEE04						
80	NEE04L						
81	NEE05						
82	NEE05L						
83	NEE06						
84	NEE06L						
85	NESE02		↓				
86	NESE01		↓				

S. No.	Component	OVA Reading 1 CM above vault (PPM)	OVA Reading 2 IN above vault (PPM)	Repair/Remonitoring			
				Repair Date	Re- monitoring Date	OVA Reading 1 CM above vault With (PPM)	Action Taken
87	NESB05	ND	ND				
88	NESB04	1					
89	NESB03						
90	NESB02						
91	NESB01						
92	NESD01						
93	NESA05						
94	NESA04						
95	NESA03						
96	NESA02						
97	NESA01						
98	NESE04						
99	NESE03						
100	NECVA01						
101	NECVA02						
102	NECVA03						
103	NECVA04						
104	NECVB01						
105	NECVB02						
106	NECVB03						
107	NECVB04						
108	NECVB05						
109	NECVC01						
110	NECVD01						
111	NECVD02						
112	NECVE03						
113	NECVE02						
114	NECVE01						
115	6ANEMCV						
116	NEGVA01						
117	NEGVA02						
118	NEGVA03						
119	NEGVA04						
120	NEGVB01						
121	NEGVB02						
122	NEGVB03						
123	NEGVB04						
124	NEGVB05						
125	NEGVC01						
126	NEGVD01						
127	NEGVD02						
128	NEGVE03						
129	NEGVE02						
130	NEGVE01						
131	NETPA01W						
132	NETPA01E						
133	NETPA02N						
134	NETPA02S		↓				
135	NETPA03S	↓	↓				

S. No.	Component	OVA Reading 1 CM above vault (PPM)	OVA Reading 2 IN above vault (PPM)	Repair/Remonitoring			
				Repair Date	Re- monitoring Date	OVA Reading 1 CM above vault With (PPM)	Action Taken
136	NETPA03N	ND	ND				
137	NETPA04S						
138	NETPA04N						
139	NETPB01N						
140	NETPB01S						
141	NETPB02W						
142	NETPB02E						
143	NETPB03W						
144	NETPB03E						
145	NETPB04N						
146	NETPB04S						
147	NETPB05N						
148	NETPB05S						
149	NETPC01W						
150	NETPC01E						
151	NETPD01E						
152	NETPD01W						
153	NETPD02S						
154	NETPD02N						
155	NETPE03N						
156	NETPE03S						
157	NETPE02S						
158	NETPE02N						
159	NETPE01N						
160	NETPE01S						
161	6ANEMAV						
162	6ANEMCV						

2011-05-11a

S - Box Sealed

V- Vacuum Adjusted

**City of Mountain View  
Shoreline Landfill  
Component Leak Check and Repair Form  
Site Name: Front Nine**

Inspection Date: 8-10-22 Start Time: 7:00 AM Finish Time: 8:50 AM

Inspector Name: RAULDANOA Instrument Used: TVA / KUBOTA

Weather: CLEAR

Leak Detected: NO LEAKS DETECTED  
ABOVE REGULATORY LIM. 75

No.	Component	OVA Reading 1 CM above vault (PPM)	OVA Reading 2 IN above vault (PPM)	Repair/Remonitoring			
				Repair Date	Re- monitoring Date	OVA Reading 1 CM above vault With (PPM)	Action Taken
1	A-05	ND	ND				
2	A0-5V						
3	A-16						
4	A-16V						
5	AC-01						
6	AC-10						
7	AC-11						
8	AC-12						
9	AC-02						
10	AC-03						
11	AC-04						
12	AC-05						
13	AC-06						
14	AC-07						
15	AC-08						
16	AC-09						
17	B-12						
18	B-12V						
19	B-02						
20	B-02V						
21	B-20						
22	B-20V						
23	B-24						
24	B-24V						
25	B-28						
26	B-28V						
27	B-03						
28	B-03V						
29	B-04						
30	B-04V						<u>AUG 31 2022</u>
31	FHZ-01						
32	FHZ-02						
33	FHZ-03						
34	FHZ-04						
35	FHZ-05						
36	FS-01						
37	FS-10						

ENGR. & ENVIRONMENTAL  
COMPLIANCE DIVISION

No.	Component	OVA Reading 1 CM above vault (PPM)	OVA Reading IN above vault (PPM)	Repair/Remonitoring			
				Repair Date	Re- monitoring Date	OVA Reading 1 CM above vault With (PPM)	Action Taken
38	FS-11	ND	ND				
39	FS-12						
40	FS-13						
41	FS-14						
42	FS-02						
43	FS-03						
44	FS-04						
45	FS-05						
46	FS-06						
47	FS-07						
48	FS-08						
49	FS-09						
50	FTY-02						
51	FYV-2H						
52	HVA-02						
53	HVB-01						
54	HVD-01						
55	LE-01						
56	LE-01V						
57	LE-02						
58	LE-02V						
59	LE-03						
60	LE-03V						
61	LE-04						
62	LE-04V						
63	MPHZV						
64	SC-01AV						
65	SC-02AV						
66	SC03AV						
67	SCHDR-01						
68	TPA-01						
69	TPA-02						
70	TPA-03						
71	TPA-04						
72	TPA-05						
73	TPA-06						
74	TPA-07						
75	TPA-08						
76	TPB-01						
77	TPB-02						
78	TPB-03						
79	TPB-04						
80	TPB-05						
81	TPB-06						
82	TPB-06A						
83	TPB-07						
84	TPB-08						
85	TPD-01A						
86	TPY-01	V	V				

S - Box Sealed

### V- Vacuum Adjusted

**City of Mountain View  
Shoreline Landfill  
Component leak check and repair form  
Site Name: NORTHSHERE**

Inspection Date: 9/27/22

Start Time: 9:30AM

Finish Time: 2:00PM

Inspector Name: Adrian Vega

Instrument Used: TVA 2020/Gator

Weather: Clear.

Leak detected: No leaks detected above regulatory limits

No.	Component	OVA Reading 1 CM above vault (PPM)	OVA Reading 2 IN above vault (PPM)	Repair/Remonitoring			
				Repair Date	Re- monitoring Date	OVA Reading 1 CM above vault With (PPM)	Action Taken
1	WN-01	ND	ND				
2	WN-01V						
3	WN-02						
4	WN-02V						
5	WN-03R						
6	WN-03RV						
7	WN-04						
8	WN-04V						
9	WN-04A						
10	WN-04AV						
11	WN-05						
12	WN-05V						
13	WN-06						
14	WN-06V						
15	WN-07						
16	WN-07V						
17	WN-08						
18	WN-08V						
19	WN-09						
20	WN-09V						
21	WN-10						
22	WN-10V						
23	WN-11						
24	WN-11V						
25	WN-12						
26	WN-12V						
27	WN-13						<u>SEP 30 2022</u>
28	WN-13V						
29	WSN-01						
30	WSN-02						
31	WSN-03						
32	WSN-04						
33	WSN-05						
34	WTPN-13						
35	WTPN-15						
36	WTPN-49						
37	WTPN-50	ND	ND				

ENGR. & ENVIRONMENTAL  
COMPLIANCE DIVISION

No.	Component	OVA Reading 1 CM above vault (PPM)	OVA Reading 2 IN above vault (PPM)	Repair/Remonitoring			
				Repair Date	Re- monitoring Date	OVA Reading 1 CM above vault With (PPM)	Action Taken
38	WTPN-06	ND	ND				
39	WTPN-60						
40	WTPN-70						
41	WTPN-78						
42	WVN-50ACH						
43	WVN-01ACH						
44	WVN-064ACH	ND	ND				

S - Box Sealed

5 Box Sealed  
V- Vacuum Adjusted

**City of Mountain View  
Shoreline Landfill  
Component leak check and repair form  
Site Name: Crittenden**

Inspection Date: 9/30/22 Start Time: 2:30 pm Finish Time: 5:30 pm  
 Inspector Name: Danny S. Velasco Instrument Used: TVA  
 Weather: Clear Leak Detected: N/D

No.	Component	OVA Reading 1 CM above vault (PPM)	OVA Reading 2 IN above vault (PPM)	Repair/Remonitoring			
				Repair Date	Re-monitoring Date	OVA Reading 1 CM above vault With (PPM)	Action Taken
1	A/BHDRCON	<u>ND</u>	<u>ND</u>				
2	B/CHDRCON						
3	CDHDRCON						
4	CRA-01						
5	CRA-01V						
6	CRA-02R						
7	CRA-02RV						
8	CRA-03						
9	CRA-03V						
10	CRA-04						
11	CRA-04V						
12	CRA-05R						
13	CRA-05RV						
14	CRA-06						
15	CRA-06V						
16	CR07						
17	CRA-07V						
18	CRA-08						
19	CRA-08V						
20	CRA-09						
21	CRA-09V						
22	CRA-10						
23	CRA-10V						
24	CRA-11						
25	CRA-11V						
26	CRA-12						<u>SEP 30 2022</u>
27	CRA-12V						
28	CRA-13						
29	CRA-13V						
30	CRB-01						
31	CRB-01 Bottom						
32	CRB1VA Top						
33	CRB-02						
34	CRB2VA Bottom						
35	CRB2VA Top						
36	CRB-03						
37	CRB3VA Bottom						
38	CRB3VA Top						

**ENGR. & ENVIRONMENTAL  
COMPLIANCE DIVISION**

No.	Component	OVA Reading 1 CM above vault (PPM)	OVA Reading 2 IN above vault (PPM)	Repair/Remonitoring			
				Repair Date	Re-monitoring Date	OVA Reading 1 CM above vault With (PPM)	Action Taken
39	CRB-04	ND	ND				
40	CRB4VA Bottom						
41	CRB4VA Top						
42	CRB-05						
43	CRB5VA Bottom						
44	CRB5VA Top						
45	CRB-06						
46	CRB6VA Bottom						
47	CRB6VA Top						
48	CRB-07R						
49	CRB7RVA Top						
50	CRB7RVA Bottom						
51	CRB7VA Top						
52	CRB7VA Bottom						
53	CRB-08						
54	CRB8VA Top						
55	CRB8VA Bottom						
56	CRC-01						
57	CRC1VA						
58	CRC-02						
59	CRC2VA						
60	CRC-03						
61	CRC3VA						
62	CRC-04						
63	CRC4VA						
64	CRD-01						
65	CRD1VA						
66	CRD-02						
67	CRD2VA						
68	CRD-03						
69	CRD3VA						
70	CRD-04						
71	CRD-04VA						
72	CRD-05						
73	CRD5VA						
74	CRD-06						
75	CRD6VA						
76	CRD-07						
77	CRD7VA						
78	CRD-08						
79	CRD8VA						
80	CRD-09						
81	CRD9VA						
82	CRD10						
83	CRD10VA						
84	CRD11						
85	CRD11VA						
86	CRDAVA						
87	CRH5TP						

No.	Component	OVA Reading 1 CM above vault (PPM)	OVA Reading 2 IN above vault (PPM)	Repair/Remonitoring			
				Repair Date	Re-monitoring Date	OVA Reading 1 CM above vault With (PPM)	Action Taken
88	CRHV8TP	ND	ND				
89	CRHVA10TP						
90	CRHVA4TP						
91	CRHVB1TP						
92	CRHVB3TP						
93	CRHVB5TP						
94	CRHVD8TP						
95	CRS1						
96	CRS2						
97	CRS3						
98	CRS4						
99	CRS6A						
100	CRV5AC						
101	CRVA1ACTP						
102	CRVA2ACTP3						
103	CRVA6AC						
104	CRVA7AC						
105	CRVAC3TP6						
106	CRVAMAIN						
107	CRVB1AC						
108	CRVB2ACTP						
109	CRVB3ACTP4						
110	CRVB4AC						
111	CRVC1AC						
112	CRVC3AC						
113	CRVCAC2TP						
114	CRVD1AC						
115	CRVD2AC						
116	CRVD3AC						
117	CRVD5AC						
118	CRVH2TP						
119	CRVH4AC						
120	CRVHA9TP						
121	CRVHB6TP						
122	CRVHC1TP						
123	CRVHC3TP						
124	CRVHC4TP						
125	CRVHD1						
126	CRVHD3TP						
127	CRVHD5TP						
128	CRVHDNORTH						
129	CRVHMAIN						
130	CTPA11						
131	CTPA7						
132	CTPD1						
133	CTPD10						
134	CTPD11						
135	CTPD2						
136	CTPD4						

No.	Component	OVA Reading 1 CM above vault (PPM)	OVA Reading 2 IN above vault (PPM)	Repair/Remonitoring			
				Repair Date	Re-monitoring Date	OVA Reading 1 CM above vault With (PPM)	Action Taken
137	CTPD9	ND	ND				
138	CVT1						
139	CVT2						
140	CVT4						
141	CVT5						
142	CVT6						
143	CVT7						
144	CVT8						
145	CVTA1						
146	CVTB1/2						
147	CVTC1/2						
148	CVTD1/2						
149	CVTF-1/2						
150	CVTG1						
151	EFHDRCON						
152	FGHDRCON						
153	CS1						
154	CS10						
155	CS11						
156	CS12						
157	CS13						
158	CS14						
159	CS15						
160	CS17						
161	CS18						
162	CS2						
163	CS3						
164	CS4						
165	CS5						
166	CS6						
167	CS7						
168	CS8						
169	CS9						
		T=Top	B=Bottom				2011-05-11a

S - Box Sealed

V - Vacuum Adjusted

**City of Mountain View  
Shoreline Landfill  
Component leak check and repair form  
Site Name: BACK NINE**

Inspection Date: 10/27/22 Start Time: 7:00 AM Finish Time: 5:00 pm

Inspector Name: Adrian Vega Instrument Used: WA 2020/Gator

Weather: Clear Leak Detected: No leaks detected above regulatory limits

No.	Component	OVA Reading 1 CM above vault (PPM)	OVA Reading 2 IN above vault (PPM)	Repair/Remonitoring			Action Taken
				Repair Date	Re- monitoring Date	OVA Reading 1 CM above vault With (PPM)	
1	WA-01	ND	ND				
2	WA-01V						
3	WA-02						
4	WA-02V						
5	WA-04						
6	WA-04V						
7	WA-05						
8	WA-05V						
9	WA-06						
10	WA-06V						
11	WA-07						
12	WA-07V						
13	WA-08						
14	WA-08V						
15	WA-09						
16	WA-09V						
17	WA-10						
18	WA-10V						
19	WA-11						
20	WA-11V						
21	WA-12						
22	WA-12V						
23	WA-13						
24	WA-13V						
25	WA-14						
26	WA-14V						
27	WA-15						
28	WA-15V						
29	WA-16						
30	WA-16V						
31	WA-17						
32	WA-17V						
33	WA-18						
34	WA-18V						
35	WA-19						
36	WA-19V						
37	WA-20						
38	WA-20V						
39	WA-21	ND	ND				

		Repair/Remonitoring					
No.	Component	OVA Reading 1 CM above vault (PPM)	OVA Reading 2 IN above vault (PPM)	Repair Date	Re- monitoring Date	OVA Reading 1 CM above vault With (PPM)	Action Taken
40	WA-21V	ND	ND				
41	WA-22						
42	WA-22V						
43	WA-23						
44	WA-23V						
45	WA-24						
46	WA-24V						
47	WA-25						
48	WA-25V						
49	WA-26						
50	WA-26V						
51	WA-27						
52	WA-27V						
53	WA-28						
54	WA-28V						
55	WA-29						
56	WA-29V						
57	WB-01						
58	WB-01V						
59	WB-02						
60	WB-02V						
61	WB-03						
62	WB-03V						
63	WB-04						
64	WB-04V						
65	WB-05						
66	WB-05A						
67	WB-05AV						
68	W-06						
69	WB-06V						
70	WB-06A						
71	WB-06AV						
72	WB-07						
73	WB-07V						
74	WB-07A						
75	WB-07AV						
76	WB-08						
77	WB-08V						
78	WB-09						
79	WB-09V						
80	WB-10						
81	WB-10V						
82	WB-11						
83	WB-11V						
84	WB-12						
85	WB-12V						
86	WB-12A						
87	WB-12AV						
88	WB-13	ND	ND				

No.	Component	Repair/Remonitoring					Action Taken
		OVA Reading 1 CM above vault (PPM)	OVA Reading 2 IN above vault (PPM)	Repair Date	Re- monitoring Date	OVA Reading 1 CM above vault With (PPM)	
89	WB-13V	ND	ND				
90	WB-14						
91	WB-14V						
92	WB-15						
93	WB-15V						
94	WB-16						
95	WB-16V						
96	WB-17						
97	WB-17V						
98	WC-01						
99	WC-01V						
100	WC-02						
101	WC-02V						
102	WC-03						
103	WC-03V						
104	WC-04						
105	WC-04V						
106	WD-01						
107	WD-01V						
108	WD-02						
109	WD-02V						
110	WD-03						
111	WD-03V						
112	WD-04						
113	WD-04V						
114	WE-01						
115	WE-01V						
116	WE-01A						
117	WE-01AV						
118	WE-02						
119	WE-02V						
120	WE-03						
121	WE-03V						
122	WE-04						
123	WE-04V						
124	WE-05						
125	WE-05V						
126	WF-01						
127	WF-01V						
128	WF-02						
129	WF-02V						
130	WSA-01						
131	WSA-02						
132	WSA-03						
133	WSB-01						
134	WSB-02						
135	WSB-03						
136	WSC-01						
137	WSC-02	ND	ND				

No.	Component	Repair/Remonitoring					
		OVA Reading 1 CM above vault (PPM)	OVA Reading 2 IN above vault (PPM)	Repair Date	Re- monitoring Date	OVA Reading 1 CM above vault With (PPM)	Action Taken
138	WSD-01	ND	ND				
139	WSD-02	/	/				
140	WSE-01	/	/				
141	WSE-02	/	/				
142	WSF-01	/	/				
143	WTA-14	/	/				
144	WTP-10	/	/				
145	WTPA-01	/	/				
146	WTPA-20	/	/				
147	WTPA-25	/	/				
148	WTPA-30	/	/				
149	WTPA-40	/	/				
150	WTPA-05	/	/				
151	WTPB-01	/	/				
152	WTPB-10	/	/				
153	WTPB-20	/	/				
154	WTPB-29	/	/				
155	WTPB-34	/	/				
156	WTPB-37	/	/				
157	WTPB-40	/	/				
158	WTPB-45	/	/				
159	WTPC-05	/	/				
160	WTPD-09	/	/				
161	WTPE-10	/	/				
162	WTPE-01	/	/				
163	WTPF-05	/	/				
164	WTPF-07	/	/				
165	WVA-01ACH	/	/				
166	WVA-13H	/	/				
167	WVA-14ACH	/	/				
168	WVA-15ACH	/	/				
169	WVA-24ACH	/	/				
170	WVA-25ACH	/	/				
171	WVA-MAIN1	/	/				
172	WVA-MAIN2	/	/				
173	WVB-01ACH	/	/				
174	WVB-18ACH	/	/				
175	WVB-29ACH	/	/				
176	WVB-45ACH	/	/				
177	WW-01ACH	/	/				
178	WVC-14ACH	/	/				
179	WVC-01VAS	/	/			OCT 31 2022	
180	WVD-01ACH	/	/				
179	WVE-01ACH	/	/			ENGR. & ENVIRONMENTAL	
180	WVE-16ACH	ND	ND			COMPLIANCE DIVISION	

S - Box Sealed

V- Vacuum Adjusted

**City of Mountain View  
Shoreline Landfill  
Component leak check and repair form  
Site Name: VISTA**

Inspection Date: 10/27/22

Start Time: 10:00 AM

Finish Time: 3:00 PM

Inspector Name: Adrian Vega

Instrument Used: TVA 2020 / Water

Weather: Clear

Leak Detected: No Leaks detected above Regulatory limits

No.	Component	OVA Reading 1 CM above vault (PPM)	OVA Reading 2 IN above vault (PPM)	Repair/Remonitoring			Action Taken
				Repair Date	Re- monitoring Date	OVA Reading 1 CM above vault With (PPM)	
1	ACDRAIN-1	ND	ND				
2	BGTP-01						
3	BGTP-02						
4	BGV-01H						
5	BGV-1AC						
6	VLE-01						
7	VLE-02						
8	VA-01A						
9	VA-01AC						
10	VA-01AL						
11	VA-01C						
12	VA-02AC						
13	VA-01						
14	VA-01V						
15	VA-02						
16	VA-02V						
17	VA-03						
18	VA-03V						
19	VA3A						
20	VA-03AV						
21	VA-04						
22	VA-04V						
23	VA-05						
24	VA-05V						
25	VA-06						
26	VA-06V						
27	VAHZ						
28	VAHZ-01						
29	VAHZ-02						
30	VAHZ-03						
31	VB-01						
32	VB-01V						
33	VB-02R						
34	VB-02RV						
35	VB-03						
36	VB-03V						
37	VB-03AC	ND	ND				

No.	Component	OVA Reading 1 CM above vault (PPM)	OVA Reading 2 IN above vault (PPM)	Repair/Remonitoring			
				Repair Date	Re- monitoring Date	OVA Reading 1 CM above vault With (PPM)	Action Taken
38	VB-03A	ND	ND				
39	VB-03AV						
40	VB-04						
41	VB-04V						
42	VB-05A						
43	VB-05AV						
44	VB-05R						
45	VB-05RV						
46	VB-06						
47	VB-06V						
48	VB-07						
49	VB-07V						
50	VB-08						
51	VB-08V						
52	VB-09						
53	VB-09AC						
54	VB-09V						
55	VC-01						
56	VC-01V						
57	VC-02						
58	VC-02V						
59	VC-03						
60	VC-03V						
61	VC-04						
62	VC-04AC						
63	VC-04V						
64	VC-05						
65	VC-05V						
66	VC-06						
67	VC-06V						
68	VC-07						
69	VC-07V						
70	VC-08						
71	VC-08V						
72	VC-10						
73	VC-10V						
74	VE-01						
75	VE-01V						
76	VE-03						
77	VE-03AC						
78	VE-03V						
79	VE-04R						
80	VE-04RV						
81	VE-05						
82	VE-05V						
83	VE-06						
84	VE-06V						
85	VE-07	ND	ND				

No.	Component	OVA Reading 1 CM above vault (PPM)	OVA Reading 2 IN above vault (PPM)	Repair/Remonitoring			
				Repair Date	Re- monitoring Date	OVA Reading 1 CM above vault With (PPM)	Action Taken
86	VE-07V	ND	ND				
87	VE-08						
88	VE-08V						
89	VE-09						
90	VE-09V						
91	VE-10						
92	VE-10V						
93	VE-11						
94	VE-11AC						
95	VE-11V						
96	VF-01						
97	VF-01V						
98	VF-02						
99	VF-02V						
100	VF-03						
101	VF-03AC						
102	VF-03V						
103	VF-04						
104	VF-04V						
105	VF-05R						
106	VF-05RV						
107	VF-06						
108	VF-06AC						
109	VF-06V						
110	VF-06V						
111	VF-07						
112	VF-07V						
113	VF07A						
114	VF-07AV						
115	VF-08R						
116	VF-08RV						
117	VF-09						
118	VF-09AC						
119	VF-09V						
120	VF-10						
121	VF-10V						
122	VF11						
123	VF-11V						
124	VG-01						
125	VG-01V						
126	VG-01A						
127	VG-01AV						
128	VG-02						
129	VG-02V						
130	VG-02R						
131	VG-02RV						
132	VG-03						
133	VG-03V	ND	ND				

No.	Component	OVA Reading 1 CM above vault (PPM)	OVA Reading 2 IN above vault (PPM)	Repair/Remonitoring			
				Repair Date	Re- monitoring Date	OVA Reading 1 CM above vault With (PPM)	Action Taken
134	VG-03A	ND	ND				
135	VG-03AV						
136	VG-04						
137	VG-04V						
138	VG-04AC						
139	VG-04A						
140	VG-04AV						
141	VG-05						
142	VG 05AC						
143	VG-05V						
144	VG-06						
145	VG-06V						
146	VH-01						
147	VH-01V						
148	VH-02						
149	VH-02AC						
150	VH-02V						
151	VH-03						
152	VH-03V						
153	VH-04						
154	VH-04AC						
155	VH-04V						
156	VH-05						
157	VH-05AC						
158	VH-05V						
159	VH-06						
160	VH-06V						
161	VH-07						
162	VH-07V						
163	VH-08						
164	VH-08AC						
165	VH-08V						
166	VH-09						
167	VH-9V						
168	VH-10						
169	VH-10AC						
170	VH-10V						
171	VH-11						
172	VH-11V						
173	VH-12						
174	VH-12V						
175	VH-13						
176	VH-13V						
177	VJ-01						
178	VJ-01V						
179	VJ-02R						
180	VJ-02RV						
181	VJ-03R	ND	ND				

No.	Component	OVA Reading 1 CM above vault (PPM)	OVA Reading 2 IN above vault (PPM)	Repair/Remonitoring			
				Repair Date	Re- monitoring Date	OVA Reading 1 CM above vault With (PPM)	Action Taken
182	VJ-03RV	ND	ND				
183	VJ-04A						
184	VJ-04AV						
185	VJ-04R						
186	VJ-04RV						
187	VJ-05R						
188	VJ-05RV						
189	VJ-06						
190	VJ 06V						
191	VJ-07R						
192	VJ-07RV						
193	VJ-08						
194	VJ-08V						
195	VJ-09R						
196	VJ-09RV						
197	VJ-10						
198	VJ-10V						
199	VJ-11R						
200	VJ-11RV						
201	VK-01						
202	VK-01V						
203	VK-02						
204	VK-02V						
205	VK-03						
206	VK-03V						
207	VK-04						
208	VK-04V						
209	VK-05						
210	VK-05V						
211	VSB-01						
212	VSB-02						
213	VSE-03						
214	VSF-01						
215	VSH-01						
216	VSJ-01						
217	VSJ-02						
218	VTPA-01						
219	VTPA-02						
220	VTPA-03						
221	VTPB-01						
222	VTPB-02						
223	VTPB-03						
224	VTPB-04						
225	VTPC-01						
226	VTPC-02						
227	VTPE-01						
228	VTPE-02						
229	VTPF-01	ND	ND				

No.	Component	OVA Reading 1 CM above vault (PPM)	OVA Reading 2 IN above vault (PPM)	Repair/Remonitoring			
				Repair Date	Re- monitoring Date	OVA Reading 1 CM above vault With (PPM)	Action Taken
230	VTPF-02	ND	ND				
231	VTPF-03						
232	VTPF-04						
233	VTPG-01						
234	VTPG-02						
235	VTPG-03						
236	VTPG-04						
237	VTPH-01						
238	VTPH-02						
239	VTPH-03						
240	VTPH-04						
241	VTPJ-01						
242	VTPJ-02						
243	VTPJ-03						
244	VTPJ-05						
245	VTPK-01						
246	VTPK-02						
247	VVA-01H						
248	VVA-02H						
249	VVA-01AC						
250	VVA-02AC						
251	VVB-01H						
252	VVB-02AC						
253	VVB-02H						
254	VVB-01AC						
255	VVC-01H						
256	VVC-02H						
257	VVC-03H						
258	VVC-01AC						
259	VVC-01V						
260	VVC-02AC						
261	VVF-01H						
262	VVF-02H						
263	VVF-03H						
264	VVF-01AC						
265	VVF-02AC						
266	VVF-03AC						
267	VVG-01AC						
268	VVG-01H						
269	VVG-02AC						
270	VVG-02H						
271	VVG-03H						
272	VVG-04H						
273	VVG-03AC						
274	VVG-04AC						
275	VVH-01H						
276	VVH-02H						
277	VVH-03H	ND	ND				

No.	Component	OVA Reading 1 CM above vault (PPM)	OVA Reading 2 IN above vault (PPM)	Repair/Remonitoring			
				Repair Date	Re- monitoring Date	OVA Reading 1 CM above vault With (PPM)	Action Taken
278	VVH-01AC	ND	ND				
279	VVH-02AC						
280	VVH-03AC						
281	VVJ-01H						
282	VVJ-04H						
283	VVJ-05H						
284	VVJ-01AC						
285	VVJ-02AC						
286	VVJ-03H						
287	VVK-01AC						
288	VVK-01H						
289	VVK-02H						
290	VVTC1						
291	VVTC2						
292	VVTC3						
293	VVTC4						
294	VVTP1						
295	VVTP2						
296	VVTP3						
297	VVTP4						
298	VVTP5						
299	VVTS1						
300	VVTS2						
301	VVTS3						
302	VVTS4	ND	ND				

2011-05-11a

S - Box Sealed

V- Vacuum Adjusted

OCT 31 2022  
ENGR. & ENVIRONMENTAL  
COMPLIANCE DIVISION

**City of Mountain View**  
**Shoreline Landfill**  
**Component leak check and repair form**  
**Site Name: 6 Acre North East**

Inspection Date: 11/22/22 Start Time: 10:00 AM Finish Time: 1:00 PM  
 Inspector Name: Adrian Vega Instrument Used: TVA 2020/Gator  
 Weather: Clear Leak Detected: No leaks detected above Regulatory Limits

S. No.	Component	OVA Reading 1 CM above vault (PPM)	OVA Reading 2 IN above vault (PPM)	Repair/Remonitoring			
				Repair Date	Re-monitoring Date	OVA Reading 1 CM above vault With (PPM)	Action Taken
1	NEA01	ND	ND				
2	NEA01L						
3	NEA02						
4	NEA02L						
5	NEA03						
6	NEA03L						
7	NEA04						
8	NEA04L						
9	NEA05						
10	NEA05L						
11	NEA06						
12	NEA06L						
13	NEA07						
14	NEA07L						
15	NEA08						
16	NEA08L						
17	NEA09						
18	NEA09L						
19	NEA10						
20	NEA10L						
21	NEA11						
22	NEA11L						
23	NEA12						
24	NEA12L						
25	NEA13						
26	NEA13L						
27	NEA14						
28	NEA14L						
29	NEA15						
30	NEA15L						
31	NEA16						
32	NEA16L						
33	NEB01						
34	NEB01L						
35	NEB02						
36	NEB02L						
37	NEB03	ND	ND				

S. No.	Component	OVA Reading 1 CM above vault (PPM)	OVA Reading 2 IN above vault (PPM)	Repair/Remonitoring			
				Repair Date	Re- monitoring Date	OVA Reading 1 CM above vault With (PPM)	Action Taken
38	NEB03L	ND	ND				
39	NEB04						
40	NEB04L						
41	NEB05						
42	NEB05L						
43	NEB06						
44	NEB06L						
45	NEB07						
46	NEB07L						
47	NEB08						
48	NEB08L						
49	NEB09						
50	NEB09L						
51	NEB10						
52	NEB10L						
53	NEB11						
54	NEB11L						
55	NEB12						
56	NEB12L						
57	NEB13						
58	NEB13L						
59	NEB14						
60	NEB14L						
61	NEC01						
62	NEC01L						
63	NEC02						
64	NEC02L						
65	NEC03						
66	NEC03L						
67	NED01						
68	NED01L						
69	NED02						
70	NED02L						
71	NED03						
72	NED03L						
73	NEE01						
74	NEE01L						
75	NEE02						
76	NEE02L						
77	NEE03						
78	NEE03L						
79	NEE04						
80	NEE04L						
81	NEE05						
82	NEE05L						
83	NEE06						
84	NEE06L						
85	NESE02						
86	NESE01	ND	ND				

S. No.	Component	OVA Reading 1 CM above vault (PPM)	OVA Reading 2 IN above vault (PPM)	Repair/Remonitoring			
				Repair Date	Re- monitoring Date	OVA Reading 1 CM above vault With (PPM)	Action Taken
87	NESB05	ND	ND				
88	NESB04						
89	NESB03						
90	NESB02						
91	NESB01						
92	NESD01						
93	NESA05						
94	NESA04						
95	NESA03						
96	NESA02						
97	NESA01						
98	NESE04						
99	NESE03						
100	NECVA01						
101	NECVA02						
102	NECVA03						
103	NECVA04						
104	NECVB01						
105	NECVB02						
106	NECVB03						
107	NECVB04						
108	NECVB05						
109	NECVC01						
110	NECVD01						
111	NECVD02						
112	NECVE03						
113	NECVE02						
114	NECVE01						
115	6ANEMCV						
116	NEGVA01						
117	NEGVA02						
118	NEGVA03						
119	NEGVA04						
120	NEGVB01						
121	NEGVB02						
122	NEGVB03						
123	NEGVB04						
124	NEGVB05						
125	NEGVC01						
126	NEGVD01						
127	NEGVD02						
128	NEGVE03						
129	NEGVE02						
130	NEGVE01						
131	NETPA01W						
132	NETPA01E						
133	NETPA02N						
134	NETPA02S						
135	NETPA03S	ND	ND				

S. No.	Component	OVA Reading 1 CM above vault (PPM)	OVA Reading 2 IN above vault (PPM)	Repair/Remonitoring			
				Repair Date	Re- monitoring Date	OVA Reading 1 CM above vault With (PPM)	Action Taken
136	NETPA03N	ND	ND				
137	NETPA04S	/	/				
138	NETPA04N						
139	NETPB01N						
140	NETPB01S						
141	NETPB02W						
142	NETPB02E						
143	NETPB03W						
144	NETPB03E						
145	NETPB04N						
146	NETPB04S						
147	NETPB05N						
148	NETPB05S						
149	NETPC01W						
150	NETPC01E						
151	NETPD01E						
152	NETPD01W						
153	NETPD02S						
154	NETPD02N						
155	NETPE03N						
156	NETPE03S						
157	NETPE02S						
158	NETPE02N						
159	NETPE01N						
160	NETPE01S						
161	6ANEMAV						
162	6ANEMCV	ND	ND				
							2011-05-11a

S - Box Sealed

V- Vacuum Adjusted

NOV 30 2022  
ENGR. & ENVIRONMENTAL  
COMPLIANCE DIVISION

**City of Mountain View  
Shoreline Landfill  
Component Leak Check and Repair Form  
Site Name: Front Nine**

Inspection Date: 11/22/22

Start Time: 8:00 AM

Finish Time: 10:00 AM

Inspector Name: Adrian Vega

Instrument Used: TVA 3020/Bxator

Weather: Clear

Leak Detected: No leaks detected  
Above regulatory limits

No.	Component	OVA Reading 1 CM above vault (PPM)	OVA Reading IN above vault (PPM)	Repair/Remonitoring			Action Taken
				Repair Date	Re- monitoring Date	OVA Reading 1 CM above vault With (PPM)	
1	A-05	ND	ND				
2	A0-5V						
3	A-16						
4	A-16V						
5	AC-01						
6	AC-10						
7	AC-11						
8	AC-12						
9	AC-02						
10	AC-03						
11	AC-04						
12	AC-05						
13	AC-06						
14	AC-07						
15	AC-08						
16	AC-09						
17	B-12						
18	B-12V						
19	B-02						
20	B-02V						
21	B-20						
22	B-20V						
23	B-24						
24	B-24V						
25	B-28						
26	B-28V						
27	B-03						
28	B-03V						
29	B-04						
30	B-04V						
31	FHZ-01						
32	FHZ-02						
33	FHZ-03						
34	FHZ-04						
35	FHZ-05						
36	FS-01						
37	FS-10	ND	ND				

No.	Component	OVA Reading 1 CM above vault (PPM)	OVA Reading IN above vault (PPM)	Repair/Remonitoring			
				Repair Date	Re- monitoring Date	OVA Reading 1 CM above vault With (PPM)	Action Taken
38	FS-11	ND	ND				
39	FS-12						
40	FS-13						
41	FS-14						
42	FS-02						
43	FS-03						
44	FS-04						
45	FS-05						
46	FS-06						
47	FS-07						
48	FS-08						
49	FS-09						
50	FTY-02						
51	FYV-2H						
52	HVA-02						
53	HVB-01						
54	HVD-01						
55	LE-01						
56	LE-01V						
57	LE-02						
58	LE-02V						
59	LE-03						
60	LE-03V						
61	LE-04						
62	LE-04V						
63	MPHZV						
64	SC-01AV						
65	SC-02AV						
66	SC03AV						
67	SCHDR-01						
68	TPA-01						
69	TPA-02						
70	TPA-03						
71	TPA-04						
72	TPA-05						
73	TPA-06						
74	TPA-07						
75	TPA-08						
76	TPB-01						
77	TPB-02						
78	TPB-03						
79	TPB-04						
80	TPB-05						
81	TPB-06						
82	TPB-06A						
83	TPB0-7						
84	TPB-08						
85	TPD-01A						
86	TPY-01	ND	ND				

S - Box Sealed  
V- Vacuum Adjusted

NOV 30 2022  
ENGR. & ENVIRONMENTAL  
COMPLIANCE DIVISION

**City of Mountain View  
Shoreline Landfill  
Component leak check and repair form  
Site Name: NORTHSHORE**

Inspection Date: 12/19/22 Start Time: 7:30 AM Finish Time: 10 AM

Inspector Name: LEON ROSACIO Instrument Used: TVA

Weather: CLEAR Leak detected: No Leaks detected over Regulatory limit

No.	Component	OVA Reading 1 CM above vault (PPM)	OVA Reading 2 IN above vault (PPM)	Repair/Remonitoring			
				Repair Date	Re- monitoring Date	OVA Reading 1 CM above vault With (PPM)	Action Taken
1	WN-01	ND	ND				
2	WN-01V						
3	WN-02						
4	WN-02V						
5	WN-03R						
6	WN-03RV						
7	WN-04						
8	WN-04V						
9	WN-04A						
10	WN-04AV						
11	WN-05						
12	WN-05V						
13	WN-06						
14	WN-06V						
15	WN-07						
16	WN-07V						
17	WN-08						
18	WN-08V						
19	WN-09						
20	WN-09V						
21	WN-10						
22	WN-10V						
23	WN-11						
24	WN-11V						
25	WN-12						
26	WN-12V						
27	WN-13						
28	WN-13V						
29	WSN-01						
30	WSN-02						
31	WSN-03						
32	WSN-04						
33	WSN-05						
34	WTPN-13						
35	WTPN-15						
36	WTPN-49						
37	WTPN-50	✓	✓				

ENGR. & ENVIRONMENTAL  
COMPLIANCE DIVISION

DEC 30 2022

CITY OF MOUNTAIN VIEW

No.	Component	OVA Reading 1 CM above vault (PPM)	OVA Reading 2 IN above vault (PPM)	Repair/Remonitoring			
				Repair Date	Re- monitoring Date	OVA Reading 1 CM above vault With (PPM)	Action Taken
38	WTPN-06	ND	ND				
39	WTPN-60						
40	WTPN-70						
41	WTPN-78						
42	WVN-50ACH						
43	WVN-01ACII						
44	WVN-064ACH	↓	↓				

S - Box Sealed

S - Box Sealed  
V - Vacuum Adjusted

**City of Mountain View  
Shoreline Landfill  
Component leak check and repair form  
Site Name: Crittenden**

Inspection Date: 12/10/22 Start Time: 7:30 Am Finish Time: 10 Am

Inspector Name: LEON RODRIGO Instrument Used: TVA

Weather: Clear Leak Detected: NO LEAKS detected over Regulatory limit

No.	Component	OVA Reading 1 CM above vault (PPM)	OVA Reading 2 IN above vault (PPM)	Repair/Remonitoring			
				Repair Date	Re-monitoring Date	OVA Reading 1 CM above vault With (PPM)	Action Taken
1	A/BHDRCON	ND	ND				
2	B/CHDRCON						
3	CDHDRCON						
4	CRA-01						
5	CRA-01V						
6	CRA-02R						
7	CRA-02RV						
8	CRA-03						
9	CRA-03V						
10	CRA-04						
11	CRA-04V						
12	CRA-05R						
13	CRA-05RV						
14	CRA-06						
15	CRA-06V						
16	CR07						
17	CRA-07V						
18	CRA-08						
19	CRA-08V						
20	CRA-09						
21	CRA-09V						
22	CRA-10						
23	CRA-10V						
24	CRA-11						
25	CRA-11V						
26	CRA-12						
27	CRA-12V						
28	CRA-13						
29	CRA-13V						
30	CRB-01						
31	CRB-01 Bottom						
32	CRB1VA Top						
33	CRB-02						
34	CRB2VA Bottom						
35	CRB2VA Top						
36	CRB-03						
37	CRB3VA Bottom						
38	CRB3VA Top						

No.	Component	OVA Reading 1 CM above vault (PPM)	OVA Reading 2 IN above vault (PPM)	Repair/Remonitoring			
				Repair Date	Re-monitoring Date	OVA Reading 1 CM above vault With (PPM)	Action Taken
39	CRB-04	ND	ND				
40	CRB4VA Bottom						
41	CRB4VA Top						
42	CRB-05						
43	CRB5VA Bottom						
44	CRB5VA Top						
45	CRB-06						
46	CRB6VA Bottom						
47	CRB6VA Top						
48	CRB-07R						
49	CRB7RVA Top						
50	CRB7RVA Bottom						
51	CRB7VA Top						
52	CRB7VA Bottom						
53	CRB-08						
54	CRB8VA Top						
55	CRB8VA Bottom						
56	CRC-01						
57	CRC1VA						
58	CRC-02						
59	CRC2VA						
60	CRC-03						
61	CRC3VA						
62	CRC-04						
63	CRC4VA						
64	CRD-01						
65	CRD1VA						
66	CRD-02						
67	CRD2VA						
68	CRD-03						
69	CRD3VA						
70	CRD-04						
71	CRD-04VA						
72	CRD-05						
73	CRD5VA						
74	CRD-06						
75	CRD6VA						
76	CRD-07						
77	CRD7VA						
78	CRD-08						
79	CRD8VA						
80	CRD-09						
81	CRD9VA						
82	CRD10						
83	CRD10VA						
84	CRD11						
85	CRD11VA						
86	CRDAVA						
87	CRH5TP	↓	↓				

No.	Component	OVA Reading 1 CM above vault (PPM)	OVA Reading 2 IN above vault (PPM)	Repair/Remonitoring			
				Repair Date	Re-monitoring Date	OVA Reading 1 CM above vault With (PPM)	Action Taken
88	CRHV8TP	ND	ND				
89	CRHVA10TP						
90	CRHVA4TP						
91	CRHVB1TP						
92	CRHVB3TP						
93	CRHVB5TP						
94	CRHVD8TP						
95	CRS1						
96	CRS2						
97	CRS3						
98	CRS4						
99	CRS6A						
100	CRV5AC						
101	CRVA1ACTP						
102	CRVA2ACTP3						
103	CRVA6AC						
104	CRVA7AC						
105	CRVAC3TP6						
106	CRVAMAIN						
107	CRVB1AC						
108	CRVB2ACTP						
109	CRVB3ACTP4						
110	CRVB4AC						
111	CRVC1AC						
112	CRVC3AC						
113	CRVCAC2TP						
114	CRVD1AC						
115	CRVD2AC						
116	CRVD3AC						
117	CRVD5AC						
118	CRVH2TP						
119	CRVH4AC						
120	CRVHA9TP						
121	CRVHB6TP						
122	CRVHC1TP						
123	CRVHC3TP						
124	CRVHC4TP						
125	CRVHD1						
126	CRVHD3TP						
127	CRVHD5TP						
128	CRVHDNORTH						
129	CRVHMAIN						
130	CTPA11						
131	CTPA7						
132	CTPD1						
133	CTPD10						
134	CTPD11						
135	CTPD2						
136	CTPD4	✓	✓				

No.	Component	OVA Reading 1 CM above vault (PPM)	OVA Reading 2 IN above vault (PPM)	Repair/Remonitoring			
				Repair Date	Re-monitoring Date	OVA Reading 1 CM above vault With (PPM)	Action Taken
137	CTPD9	ND	ND				
138	CVT1						
139	CVT2						
140	CVT4						
141	CVT5						
142	CVT6						
143	CVT7						
144	CVT8						
145	CVTA1						
146	CVTB1/2						
147	CVTC1/2						
148	CVTD1/2						
149	CVTF-1/2						
150	CVTG1						
151	EFHDRCON						
152	FGHDRCON						
153	CS1						
154	CS10						
155	CS11						
156	CS12						
157	CS13						
158	CS14						
159	CS15						
160	CS17						
161	CS18						
162	CS2						
163	CS3						
164	CS4						
165	CS5						
166	CS6						
167	CS7						
168	CS8						
169	CS9						
		T=Top	B=Bottom				2011-05-11a

S - Box Sealed

V - Vacuum Adjusted

## **SECTION V**

### **MONTHLY LANDFILL GAS WELLHEAD MONITORING**

**CITY OF MOUNTAIN VIEW**  
**MONTHLY LANDFILL GAS WELL HEAD MONITORING**

July 2022

<b>VISTA</b>								
Permit Well ID	Date/Time	%CH4 by Vol.	%CO2 by Vol.	%O2 by Vol.	%Bal. by Vol.	Wellhead Temp. ° F	Initial Vacuum (inches of water column)	Adjusted Vacuum (inches of water column)
VA-1A*	7/14/2022 9:28	53.8	31.8	1.6	12.8	76	-3.79	
VA-1R*	7/14/2022 9:20	62.1	37.9	0	0.0	75	-0.24	
VA-2*	7/14/2022 9:35	61.3	31.0	1.1	6.6	70	-0.51	
VA-3A*	7/14/2022 9:46	37.7	23.9	4.9	33.5	77	-5.3	
VA-3R*	7/14/2022 9:40	44.7	26.6	0	28.7	75	-8.44	
VA-4*	7/14/2022 9:50	61.7	31.2	0.2	6.9	75	-2.11	
VA-5R	7/14/2022 10:10	39.5	25.9	4.2	49.2	70	-19.92	
VA-6	7/14/2022 10:14	68.3	19.3	2.3	10.1	72	-36.45	
VA-HZ*	7/14/2022 9:55	19.4	23.2	1.3	56.1	76	-0.1	
VB-1*	7/14/2022 10:25	57.2	31.8	0.2	10.8	77	-7.84	
VB-2R*	7/14/2022 10:32	36.5	17.5	6.6	39.4	78	-0.32	
VB-3	7/14/2022 10:38	56.7	34.2	0.1	9.0	79	-35.32	
VB-3A*	7/14/2022 10:43	34.5	20.7	6.9	37.9	78	-13.43	
VB-4*	7/14/2022 10:47	40.5	32.1	0	27.4	77	-15.37	
VB-5A*	7/14/2022 10:56	54.1	34.7	0.5	10.7	81	-0.93	
VB-5R*	7/14/2022 10:52	32.6	26.2	0	41.2	81	-3.88	
VB-6R*	7/14/2022 11:01	30.9	28.5	0.3	40.3	77	-2.73	
VB-7*	7/14/2022 11:05	55	37.2	0	7.8	79	-2.36	
VB-8*	7/14/2022 11:39	0	0.5	21.2	78.3	89	-33.96	
VB-9R	7/14/2022 11:09	43.7	33.3	0	23.0	86	-0.14	
VC-10	7/14/2022 12:19	44.4	33.0	0	22.6	84	-23.37	
VC-1R*	7/14/2022 11:17	14.2	16.8	8	61.0	86	-0.41	
VC-2R*	7/14/2022 11:44	12.4	21.2	0.1	66.3	90	-3.48	
VC-3*	7/14/2022 11:48	38.1	17.0	8.7	36.2	82	-16.94	
VC-4	7/14/2022 11:51	49.6	36.2	0	14.2	84	-0.1	
VC-5*	7/14/2022 11:57	0.2	0.3	21.7	77.8	87	-27.55	
VC-6*	7/14/2022 12:06	65.1	24.6	0.5	9.8	85	-22.17	
VC-7*	7/14/2022 12:10	61.4	36.2	0	2.4	82	-1.17	
VC-8*	7/14/2022 12:14	56.2	28.9	1.1	13.8	81	-26.86	
VE-10*	7/21/2022 8:14	0.2	0.9	20.7	78.2	62	-0.03	
VE-11	7/21/2022 8:19	50.6	32.3	0.7	16.4	63	-15.56	

\* - Alternative oxygen wellhead limit

\*\* - Alternate temperature wellehad limit

Permit Well ID	Date/Time	%CH4 by Vol.	%CO2 by Vol.	%O2 by Vol.	%Bal. by Vol.	Wellhead Temp. °F	Initial Vacuum (inches of water column)	Adjusted Vacuum (inches of water column)
VE-1R*	7/14/2022 12:45	32.9	23.8	2.3	41.0	87	-0.69	
VE-3	7/14/2022 12:31	47.7	36.2	0.1	16.0	85	-10.5	
VE-4R*	7/14/2022 12:48	0.2	0.4	21.7	77.7	87	-25.12	
VE-5*	7/14/2022 12:52	28	26.4	0	45.6	82	-1.75	
VE-6*-**	7/14/2022 12:56	19.5	25.3	0	55.2	90	-1.93	
VE-7*	7/21/2022 7:54	0	0.0	22.2	77.8	62	-0.01	
VE-8*	7/21/2022 8:02	19.4	23.3	0	57.3	61	-0.38	
VE-9*-**	7/21/2022 8:07	0.6	0.5	21.8	77.1	61	-34.87	
VF-1*	7/21/2022 8:31	5.7	10.5	9.6	74.2	61	-0.12	
VF-10	7/21/2022 9:50	61.3	37.6	0	1.1	72	-25.44	
VF-11**	7/21/2022 9:56	47.2	35.1	0	17.7	68	-30.14	
VF-2*	7/21/2022 8:37	19.7	13.0	9.3	58.0	62	-0.1	
VF-3**	7/21/2022 8:43	59.4	34.3	0	6.3	62	-3.53	
VF-4*	7/21/2022 8:49	10.4	6.3	16.8	66.5	64	-0.05	
VF-5R*	7/21/2022 8:54	38.8	25.9	0	35.3	62	-0.73	
VF-6	7/21/2022 9:07	55.3	39.7	0	5.0	64	-0.09	
VF-7*	7/21/2022 9:26	32.2	17.1	11.1	39.6	69	-3.7	
VF-7A	7/21/2022 9:21	62.8	36.5	0	0.7	67	-0.49	
VF-8R*	7/21/2022 9:32	56.2	33.2	1.6	9.0	67	-6.27	
VF-9	7/21/2022 9:41	56.9	40.5	0	2.6	72	-0.18	
VG-1	7/21/2022 10:10	39.2	29.0	3.9	27.9	70	-4.89	
VG-1A	7/21/2022 10:05	52.3	34.5	0	13.2	70	-2.25	
VG-2R	7/21/2022 10:17	59.3	31.6	0.4	8.7	73	-30.97	
VG-3**	7/21/2022 10:24	53.5	37.3	0.2	9.0	75	-1.7	
VG-3AR**	7/21/2022 10:27	53.8	38.0	0	8.2	75	-1.5	
VG-4**	7/21/2022 12:37	54.1	39.8	0.2	5.9	76	-0.84	
VG-4A	7/21/2022 12:31	49	31.8	0.2	19.0	76	-22.78	
VG-5	7/21/2022 12:41	48.5	38.2	0	13.3	77	-1.41	
VG-6	7/21/2022 12:48	56.5	41.6	0	1.9	80	-0.28	
VH-1	7/21/2022 13:08	54.7	31.1	0	14.2	79	-0.68	
VH-10**	7/21/2022 14:13	51.2	35.3	0	13.5	83	-0.18	
VH-11	7/21/2022 14:24	26.6	26.9	0.1	46.4	80	-0.48	
VH-12	7/21/2022 14:19	54.6	37.2	0.7	7.5	82	-0.47	
VH-13	7/21/2022 14:28	41.3	34.9	0	23.8	90	-0.01	
VH-2	7/21/2022 13:02	17.7	24.9	0	57.4	77	-0.05	
VH-3*	7/21/2022 13:16	15.1	14.1	9.7	61.1	80	-0.11	
VH-4**	7/21/2022 12:55	44.5	33.2	0.8	21.5	78	-0.83	
VH-5**	7/21/2022 13:22	42.9	34.3	0	22.8	77	-0.73	
VH-6	7/21/2022 13:34	50.4	33.2	0.3	16.1	77	-10.56	

\* - Alternative oxygen wellhead limit

\*\* - Alternate temperature wellehad limit

Permit Well ID	Date/Time	%CH4 by Vol.	%CO2 by Vol.	%O2 by Vol.	%Bal. by Vol.	Wellhead Temp. °F	Initial Vacuum (inches of water column)	Adjusted Vacuum (inches of water column)
VH-7R	7/21/2022 13:47	56.7	35.3	0.5	7.5	82	-1.7	
VH-8	7/21/2022 13:55	56	37.9	0	6.1	79	-0.04	
VH-9	7/22/2022 9:26	36.2	24.1	4.5	61.4	93	0.11	-0.1
VJ-10R*	7/22/2022 9:13	37.8	21.6	6.9	33.7	72	-4.09	
VJ-11R*	7/22/2022 9:06	29.1	17.0	10.7	43.2	75	-2.21	
VJ-1R	7/22/2022 7:49	43.4	30.7	0.1	25.8	67	-2.8	
VJ-2R*	7/22/2022 7:43	25.5	14.7	13	46.8	65	-7.53	
VJ-3R*-**	7/22/2022 7:35	42.7	21.1	8.1	28.1	66	-15.31	
VJ-4A*-**	7/22/2022 7:56	34	27.1	2.5	36.4	72	-2.83	
VJ-4R*-**	7/22/2022 8:01	47.5	33.6	0	18.9	64	-4.23	
VJ-5R*	7/22/2022 8:38	58.2	38.9	0	2.9	65	-31.42	
VJ-6R*	7/22/2022 8:44	60.6	37.6	0	1.8	70	-34.01	
VJ-7R*	7/22/2022 8:51	50.1	34.0	3	12.9	68	-14.08	
VJ-8*	7/22/2022 8:56	51	36.2	1.8	11.0	72	-4.51	
VJ-9R*	7/22/2022 9:01	48.4	28.2	2	21.4	70	-8.72	
VK-1R	7/22/2022 8:12	60.8	35.7	0	3.5	69	-12.68	
VK-2R	7/22/2022 8:17	61.3	32.9	0.2	5.6	70	-34.89	
VK-3R*	7/22/2022 8:33	59.3	29.5	2.7	8.5	74	-33.08	
VK-4*	7/22/2022 8:28	2.4	1.6	21	75.0	71	-35.34	
VK-5*	7/22/2022 8:22	54.4	34.6	2.1	8.9	69	-4.91	

## FRONT NINE

Permit Well ID	Date/Time	%CH4 by Vol.	%CO2 by Vol.	%O2 by Vol.	%Bal. by Vol.	Wellhead Temp. °F	Initial Vacuum (inches of water column)	Adjusted Vacuum (inches of water column)
A-16*	7/19/2022 8:28	0	1.0	21.4	77.6	61	-0.01	
A-5	7/13/2022 12:33	48.6	31.7	3.5	16.2	93	-0.17	
B-12	7/19/2022 7:55	46.4	32.0	3.6	18.0	61	-7.36	
B-2*	7/14/2022 7:45	5.5	2.9	20.7	70.9	64	-0.01	
B-28*	7/13/2022 12:56	0	1.2	20.7	78.1	94	-0.29	
B-3R*	7/14/2022 7:57	50.8	27.6	3.1	18.5	65	-0.48	
B-4R*	7/14/2022 8:02	36.1	21.5	4.3	62.5	68	-0.06	
FHZ-1*	7/19/2022 7:35	37.2	31.1	0.9	30.8	64	-0.01	
FHZ-2*	7/19/2022 7:40	54.8	39.7	0	5.5	61	-0.03	
FHZ-3*	7/19/2022 7:48	18.7	19.0	9.7	52.6	60	-0.04	
FHZ-4*	7/19/2022 8:11	19.8	23.5	0	56.7	62	-0.01	
FHZ-5*	7/19/2022 8:33	37.3	32.4	0	30.3	61	-0.01	
LE-1*	7/13/2022 13:20	10.1	11.0	8.1	70.8	91	-2.14	

\* - Alternative oxygen wellhead limit

\*\* - Alternate temperature wellehad limit

Permit Well ID	Date/Time	%CH4 by Vol.	%CO2 by Vol.	%O2 by Vol.	%Bal. by Vol.	Wellhead Temp. °F	Initial Vacuum (inches of water column)	Adjusted Vacuum (inches of water column)
LE-2*	7/14/2022 7:32	0.1	0.9	21.6	77.4	65	-0.01	
LE-3*	7/14/2022 7:38	26.9	15.5	12.2	45.4	63	-0.01	
LE-4*	7/14/2022 8:11	0.1	0.2	22.5	77.2	72	-12.05	
Y-1*	7/13/2022 13:01	0.4	1.1	19.8	78.7	95	-1.2	
Y-2*	7/13/2022 13:44	13.6	21.5	3.5	61.4	91	-0.1	
Y-3*	7/13/2022 13:52	0	0.1	21.8	78.1	84	-31.75	
Y-4*	7/13/2022 13:48	0.9	1.6	20.1	77.4	81	-0.01	
Y-5*	7/13/2022 13:31	0	2.7	17.8	79.5	90	-0.03	
Y-6*	7/13/2022 13:26	0	0.1	22	77.9	85	-4.99	

## MICHAELS

Permit Well ID	Date/Time	%CH4 by Vol.	%CO2 by Vol.	%O2 by Vol.	%Bal. by Vol.	Wellhead Temp. °F	Initial Vacuum (inches of water column)	Adjusted Vacuum (inches of water column)
B-20*	7/13/2022 9:46	0.3	1.0	20.8	77.9	72	-0.05	
B-24*	7/13/2022 9:50	8.9	4.5	19.2	67.4	71	-26.44	
MPHZ*	7/13/2022 9:40	13.7	21.8	1.5	63.0	74	-0.02	

## BACK NINE

Permit Well ID	Date/Time	%CH4 by Vol.	%CO2 by Vol.	%O2 by Vol.	%Bal. by Vol.	Wellhead Temp. °F	Initial Vacuum (inches of water column)	Adjusted Vacuum (inches of water column)
WA-10	7/21/2022 8:34	59.8	35.8	1	3.4	70	-2.13	
WA-11	7/21/2022 8:55	56.9	39.6	0	3.5	67	-1.97	
WA-12R	7/21/2022 8:58	58.3	41.7	0	0.0	70	-1.72	
WA-13*	7/21/2022 8:52	56.7	34.8	1.5	7.0	70	-21.89	
WA-14*	7/21/2022 9:04	2.3	3.1	20.3	74.3	69	-0.07	
WA-15R*	7/21/2022 9:15	3	1.8	21.1	74.1	67	-33.23	
WA-16*	7/21/2022 9:21	56.2	39.7	0.5	3.6	67	-0.89	
WA-17	7/21/2022 9:19	56	40.1	0.8	3.1	72	-1.61	
WA-18*	7/21/2022 9:27	56.1	28.0	3.6	12.3	68	-11.54	
WA-19*	7/21/2022 9:53	59.8	38.8	0	1.4	76	-0.01	
WA-1R*	7/21/2022 7:20	49.6	34.3	3.5	12.6	70	-6.94	
WA-2*	7/21/2022 7:34	66.3	33.7	0	0.0	64	-36.95	
WA-20*	7/21/2022 9:56	53.2	40.8	1.1	4.9	82	-8.85	
WA-21R*	7/21/2022 10:02	23	19.1	7.9	50.0	85	-0.08	

\* - Alternative oxygen wellhead limit

\*\* - Alternate temperature wellhead limit

Permit Well ID	Date/Time	%CH4 by Vol.	%CO2 by Vol.	%O2 by Vol.	%Bal. by Vol.	Wellhead Temp. °F	Initial Vacuum (inches of water column)	Adjusted Vacuum (inches of water column)
WA-22R*	7/21/2022 10:06	41	31.2	0.6	27.2	79	-1.53	
WA-23R*	7/21/2022 10:10	52.9	35.4	0	11.7	78	-3.53	
WA-24*	7/21/2022 10:25	48	32.3	4.1	15.6	79	-35.46	
WA-25*	7/21/2022 10:32	55.4	36.4	0.8	7.4	77	-0.02	
WA-26*	7/21/2022 10:39	51.4	37.9	1.2	9.5	81	-3.61	
WA-27*	7/21/2022 10:44	45.9	29.1	4.6	20.4	78	-19.8	
WA-28*	7/21/2022 10:48	54.3	40.9	0	4.8	85	-2.47	
WA-29*	7/21/2022 10:50	30.1	32.0	0	37.9	83	-3.16	
WA-4	7/21/2022 7:39	55.3	30.3	2.8	11.6	62	-10.43	
WA-5*	7/21/2022 8:07	0	0.0	22.9	77.1	62	-34.97	
WA-6*	7/21/2022 8:02	0	0.2	22.5	77.3	62	-2.41	
WA-7	7/21/2022 8:11	65.3	34.7	0	0.0	65	-4.03	
WA-8*	7/21/2022 8:29	3.2	18.7	0	78.1	70	-0.07	
WA-9*	7/21/2022 8:17	54.9	37.7	1.9	5.5	65	-8.22	
WB-1*	7/26/2022 14:00	58.5	37.3	0	4.2	85	-0.01	
WB-10R*	7/26/2022 10:21	45.5	27.2	4.4	22.9	80	-5.24	
WB-11*	7/26/2022 10:15	16.2	7.5	16.7	59.6	81	-8.36	
WB-12AR*	7/26/2022 9:52	42.1	35.5	0.1	22.3	79	-0.42	
WB-12R*	7/26/2022 10:02	35.7	31.0	0.7	32.6	76	-3.73	
WB-13R*	7/26/2022 9:43	28.8	30.7	0	40.5	75	-0.91	
WB-14R*	7/26/2022 9:41	42.2	34.1	0.4	23.3	76	-0.33	
WB-15R*	7/26/2022 9:27	52.1	36.4	1.5	10.0	78	-0.74	
WB-16R*	7/26/2022 9:25	21.1	24.2	0.7	54.0	78	-0.72	
WB-17R*	7/21/2022 10:14	32.7	26.6	2.4	38.3	77	-0.26	
WB-2*	7/26/2022 13:53	4.8	2.8	19.8	72.6	98	-7.38	
WB-3*	7/26/2022 13:27	54.2	30.7	2.8	12.3	89	-0.17	
WB-4*	7/26/2022 13:09	0.1	0.2	22.1	77.6	87	-33.87	
WB-5A*	7/26/2022 12:58	16.4	21.0	0	62.6	82	-0.46	
WB-5R*	7/26/2022 12:52	38.2	25.0	2.9	33.9	83	-3.73	
WB-6*	7/26/2022 12:41	25.8	24.3	5.1	44.8	78	-1.44	
WB-6A*	7/26/2022 12:47	38.3	30.2	1.8	29.7	83	-1.73	
WB-7*	7/26/2022 12:24	41.4	29.1	5.5	24.0	89	-4.91	
WB-7A*	7/26/2022 12:32	46.1	30.5	4.5	18.9	82	-0.32	
WB-8*	7/26/2022 10:39	18.4	12.4	14.6	54.6	76	-38.46	
WB-9*	7/26/2022 10:25	8.5	5.3	18.5	67.7	76	-6.2	
WC-1	7/27/2022 7:10	63.8	29.2	1.1	5.9	64	-4.42	
WC-2	7/27/2022 7:42	49.5	27.3	4.3	18.9	64	-15	
WC-3	7/27/2022 13:01	46.4	29.8	4.7	19.1	79	-3.51	
WC-4R	7/27/2022 13:11	62.4	30.9	0.3	6.4	83	-29.41	

\* - Alternative oxygen wellhead limit

\*\* - Alternate temperature wellehad limit

Permit Well ID	Date/Time	%CH4 by Vol.	%CO2 by Vol.	%O2 by Vol.	%Bal. by Vol.	Wellhead Temp. °F	Initial Vacuum (inches of water column)	Adjusted Vacuum (inches of water column)
WD-1	7/28/2022 8:28	64.9	35.1	0	0.0	66	-21.05	
WD-2	7/28/2022 8:17	63.2	23.3	2.2	11.3	65	-4.33	
WD-3*	7/28/2022 8:05	62.5	22.8	2.5	12.2	65	-37.94	
WD-4	7/28/2022 7:48	61	35.5	0	3.5	63	-0.46	
WE-1	7/28/2022 8:48	39.5	29.6	0	30.9	67	-27.28	
WE-1AR	7/28/2022 8:42	43.5	21.1	4.9	30.1	69	-35.1	
WE-2	7/28/2022 8:57	55.9	39.8	0	4.3	69	-1.36	
WE-3	7/28/2022 9:18	49.4	24.9	4.8	20.9	78	-5.49	
WE-4	7/28/2022 9:31	59.2	38.2	0	2.6	71	-18.92	
WE-5	7/28/2022 9:44	61.8	37.9	0	0.3	81	-5.93	
WF-1	7/28/2022 10:00	62.2	37.8	0	0.0	81	-0.43	
WF-2	7/27/2022 13:29	61	37.8	0	1.2	77	-0.58	
WN-10*	7/26/2022 7:52	57.5	42.5	0	0.0	65	-4.25	
WN-11*	7/21/2022 11:07	60	40.0	0	0.0	74	-3.92	
WN-12R*	7/21/2022 11:02	51.9	37.4	1.7	9.0	80	-1.52	
WN-13*	7/21/2022 10:56	18.4	14.3	14.3	53.0	86	-37.29	
WN-1R*	7/26/2022 8:51	54.5	34.9	0	10.6	70	-6.08	
WN-2R*	7/26/2022 8:45	59.4	39.0	0	1.6	71	-32.38	
WN-3R*	7/26/2022 8:41	0.7	0.6	22.1	76.6	68	-38	
WN-4*	7/26/2022 8:34	62.1	35.6	0	2.3	69	-35.67	
WN-4A*	7/26/2022 8:28	51	35.5	0	13.5	69	-37.91	
WN-5R*	7/26/2022 8:18	58.7	41.3	0	0.0	69	-11.44	
WN-6R*	7/26/2022 8:14	58.2	41.5	0	0.3	68	-1.56	
WN-7*	7/26/2022 8:08	56.5	42.3	0.1	1.1	69	-1.6	
WN-8R*	7/26/2022 8:05	38.9	33.7	0.5	26.9	66	-2.05	
WN-9R*	7/26/2022 7:54	58.7	41.3	0	0.0	66	-10.61	

## CRITTENDEN

Permit Well ID	Date/Time	%CH4 by Vol.	%CO2 by Vol.	%O2 by Vol.	%Bal. by Vol.	Wellhead Temp. °F	Initial Vacuum (inches of water column)	Adjusted Vacuum (inches of water column)
CRA-10*	7/25/2022 9:08	30.1	18	9.9	42	67	-1.91	
CRA-11	7/25/2022 9:36	54.1	35.9	0	10	69	-8.46	
CRA-12	7/25/2022 9:31	56.7	33.9	0	9.4	70	-8.54	
CRA-13*	7/25/2022 9:26	57.2	37.9	0.6	4.3	69	-6.61	
CRA-1R*	7/25/2022 8:05	53.9	37.8	0.1	8.2	64	-6.61	
CRA-2R*	7/25/2022 8:09	30.1	31.1	5.8	33	66	-3.33	
CRA-3*	7/25/2022 8:21	59.8	40.2	0	0	65	-6.45	

\* - Alternative oxygen wellhead limit

\*\* - Alternate temperature wellehad limit

Permit Well ID	Date/Time	%CH4 by Vol.	%CO2 by Vol.	%O2 by Vol.	%Bal. by Vol.	Wellhead Temp. °F	Initial Vacuum (inches of water column)	Adjusted Vacuum (inches of water column)
CRA-4*	7/25/2022 8:26	51.8	34.7	3.3	10.2	65	-4.01	
CRA-5R*	7/25/2022 8:34	53.7	34.9	0	11.4	64	-1.06	
CRA-6*	7/25/2022 8:38	54.6	33.8	1.7	9.9	65	-0.49	
CRA-7R*	7/25/2022 8:44	59.6	38.1	0	2.3	66	-0.79	
CRA-8*	7/25/2022 8:50	61.7	38.3	0	0	65	-1.93	
CRA-9*	7/25/2022 8:58	45.9	28.9	5.4	19.8	66	-2.55	
CRB-1R*	7/25/2022 9:48	53	33	2.7	11.3	73	-4.2	
CRB-2R*	7/25/2022 10:08	55.3	36.7	0	8	72	-2.55	
CRB-3*	7/25/2022 10:14	60.8	35.8	0	3.4	75	-3.62	
CRB-4R*	7/25/2022 10:17	31.2	21	4.9	42.9	74	-4.69	
CRB-5*	7/25/2022 10:22	28.5	11.5	11.4	48.6	68	-2.61	
CRB-6*	7/25/2022 10:32	67.3	28.7	0	4	76	-1.49	
CRB-7R*	7/25/2022 10:35	62.4	34	0	3.6	72	-7.02	
CRB-8*	7/25/2022 10:43	4.5	2.4	20.3	72.8	73	-6.4	
CRC-1	7/25/2022 10:39	53	25.8	2.3	18.9	73	-7.88	
CRC-2	7/25/2022 10:28	56.3	30	0	13.7	69	-4.91	
CRC-3	7/25/2022 10:11	58.8	33.3	0.4	7.5	78	-3.67	
CRC-4	7/25/2022 10:04	52.4	28.5	1.4	17.7	72	-3.46	
CRD-1*	7/25/2022 12:23	55.8	33.7	0.5	10	82	-8.55	
CRD-10*	7/25/2022 13:35	58.7	29	0	12.3	82	-6.39	
CRD-11*	7/25/2022 13:40	13.4	3.2	21.5	61.9	81	-4.14	
CRD-2	7/25/2022 12:28	62.2	34.6	0	3.2	75	-3.65	
CRD-3*	7/25/2022 12:34	59.9	39.3	0	0.8	78	-8.54	
CRD-4	7/25/2022 12:42	63.7	35	0	1.3	74	-6.68	
CRD-5*	7/25/2022 12:50	0.1	0.7	21	78.2	82	-2.25	
CRD-6	7/25/2022 12:55	47.6	25.4	4.1	22.9	82	-6.22	
CRD-7	7/25/2022 12:59	42.2	28.1	2.4	65	85	-8.94	
CRD-8R*	7/25/2022 13:15	54.9	29.5	2.4	13.2	86	-7.2	
CRD-9*	7/25/2022 13:27	38.7	23	5.9	32.4	86	-7.35	

## 6ANE

Permit Well ID	Date/Time	%CH4 by Vol.	%CO2 by Vol.	%O2 by Vol.	%Bal. by Vol.	Wellhead Temp. °F	Initial Vacuum (inches of water column)	Adjusted Vacuum (inches of water column)
NEA-1*	7/19/2022 9:49	49.5	33.5	1	16.0	73	-0.45	
NEA-10	7/19/2022 12:54	56.7	40.2	0	3.1	81	-4.61	
NEA-11*	7/19/2022 13:00	49.2	38.0	0	12.8	90	-3.65	
NEA-12	7/19/2022 13:03	46.3	33.3	3.8	16.6	91	-1.77	

\* - Alternative oxygen wellhead limit

\*\* - Alternate temperature wellehad limit

Permit Well ID	Date/Time	%CH4 by Vol.	%CO2 by Vol.	%O2 by Vol.	%Bal. by Vol.	Wellhead Temp. °F	Initial Vacuum (inches of water column)	Adjusted Vacuum (inches of water column)
NEA-13*	7/19/2022 13:08	53.1	35.2	1.6	10.1	91	-0.73	
NEA-14	7/19/2022 13:18	57	37.0	0.9	5.1	89	-35.55	
NEA-15*	7/19/2022 13:42	58.3	41.7	0	0.0	84	-35.26	
NEA-16A*	7/19/2022 13:54	58.4	41.6	0	0.0	86	-35.59	
NEA-2R*	7/19/2022 9:53	14.7	11.3	13.5	60.5	73	-28.79	
NEA-3*	7/19/2022 10:04	61.4	31.7	1.3	5.6	75	-3.43	
NEA-4*	7/19/2022 10:26	50.2	32.3	3.9	13.6	78	-2.93	
NEA-5R*	7/19/2022 10:34	27.9	22.4	7.2	42.5	80	-1.32	
NEA-6*	7/19/2022 12:29	14.9	21.0	1.6	62.5	79	-0.53	
NEA-7*	7/19/2022 12:34	58.8	41.2	0	0.0	79	-0.05	
NEA-8*-**	7/19/2022 12:40	47.6	37.2	1.3	13.9	86	-3.72	
NEA-9*	7/19/2022 12:47	58.2	41.8	0	0.0	84	-1.02	
NEB-1*	7/20/2022 7:47	0.1	0.3	22.6	77.0	64	-25.54	
NEB-10*	7/20/2022 9:21	33.4	33.7	0	32.9	68	-7.14	
NEB-11*	7/20/2022 9:29	49	38.7	0	12.3	66	-1.47	
NEB-12*	7/20/2022 9:33	57.7	41.6	0	0.7	70	-0.35	
NEB-13*	7/20/2022 9:38	0.1	0.2	22.4	77.3	69	-0.02	
NEB-14R*	7/20/2022 9:46	12.9	29.9	0	57.2	70	-0.09	
NEB-2*	7/20/2022 8:07	0	0.1	22.6	77.3	63	-37.08	
NEB-3*	7/20/2022 8:14	40.1	32.1	1.2	26.6	62	-0.07	
NEB-4*	7/20/2022 8:21	0.4	1.0	21.4	77.2	63	-0.19	
NEB-5*	7/20/2022 8:29	34	31.4	0	34.6	63	-0.18	
NEB-6*	7/20/2022 8:38	52	40.4	0	7.6	64	-1.81	
NEB-7*	7/20/2022 8:55	40.4	37.3	0	22.3	64	-0.43	
NEB-8*	7/20/2022 9:09	43.2	35.6	0	21.2	66	-0.54	
NEB-9	7/20/2022 9:14	31.7	33.2	0	35.1	64	-0.83	
NEC-1*	7/20/2022 10:04	39.1	32.4	1.8	26.7	75	-2.92	
NEC-2*	7/20/2022 10:12	47.5	36.6	0	15.9	80	-0.14	
NEC-3*	7/20/2022 10:21	17.2	14.9	13	54.9	80	-0.55	
NED-1R*	7/20/2022 10:34	0.1	9.0	15.1	75.8	82	-0.01	
NED-2	7/20/2022 10:39	49.1	38.6	0	12.3	79	-2.1	
NED-3	7/20/2022 10:47	36.7	27.0	0.8	35.5	75	-0.67	
NEE-1	7/20/2022 12:22	58.5	41.5	0	0.0	77	-13.44	
NEE-2R*	7/20/2022 12:32	55.3	38.9	0	5.8	72	-26.27	
NEE-3*	7/20/2022 12:45	25	23.4	4.2	47.4	75	-0.08	
NEE-4*	7/20/2022 12:54	63	37.0	0	0.0	74	-26.41	
NEE-5*	7/20/2022 13:04	37.7	30.8	0	31.5	74	-0.27	
NEE-6*	7/20/2022 13:13	43.4	35.4	0	21.2	76	-4.79	

\* - Alternative oxygen wellhead limit

\*\* - Alternate temperature wellehad limit

**CITY OF MOUNTAIN VIEW**  
**MONTHLY LANDFILL GAS WELL HEAD MONITORING**

August 2022

<b>VISTA</b>								
Permit Well ID	Date/Time	%CH4 by Vol.	%CO2 by Vol.	%O2 by Vol.	%Bal. by Vol.	Wellhead Temp. ° F	Initial Vacuum (inches of water column)	Adjusted Vacuum (inches of water column)
VA-1A*	8/10/2022 11:07	61.4	36.0	0	2.6	82	-1.81	
VA-1R*	8/10/2022 11:02	36.1	35.4	0	28.5	79	-2.29	
VA-2*	8/10/2022 11:12	56.5	29.9	2	11.6	79	-3.65	
VA-3A*	8/10/2022 11:30	37.2	23.9	4.7	34.2	81	-5.56	
VA-3R*	8/10/2022 11:20	38.7	26.8	0	34.5	82	-9.33	
VA-4*	8/10/2022 11:35	31.1	24.8	3.4	40.7	81	-11.89	
VA-5R	8/10/2022 11:43	60.7	23.9	2.3	13.1	82	-21.45	
VA-6	8/10/2022 11:48	68.1	19.8	1.7	10.4	77	-35.56	
VA-HZ*	8/10/2022 11:39	9.9	19.8	2.8	67.5	81	-0.13	
VB-1*	8/10/2022 11:59	46.9	27.2	4	21.9	79	-7.26	
VB-2R*	8/10/2022 12:04	38.6	19.7	4.7	37.0	82	-0.13	
VB-3	8/10/2022 12:14	55.1	33.5	0.1	11.3	86	-34.6	
VB-3A*	8/10/2022 12:21	37	22.8	6.4	33.8	86	-15.36	
VB-4*	8/10/2022 12:27	39.7	32.3	0	28.0	85	-15.36	
VB-5A*	8/10/2022 12:39	53.3	34.5	0.9	11.3	82	-0.92	
VB-5R*	8/10/2022 12:35	29.8	26.2	0	44.0	84	-4.99	
VB-6R*	8/10/2022 12:44	28.5	28.0	0.6	42.9	81	-2.54	
VB-7*	8/10/2022 12:48	53.7	37.8	0	8.5	88	-2.24	
VB-8*	8/10/2022 13:06	0.1	0.3	21.3	78.3	88	-34.95	
VB-9R	8/10/2022 12:54	40	33.4	0	26.6	86	-0.11	
VC-10	8/10/2022 13:42	43.7	32.2	0	24.1	87	-22.81	
VC-1R*	8/10/2022 13:01	11.2	12.3	11.9	64.6	89	-0.21	
VC-2R*	8/10/2022 13:13	11.7	21.8	0.1	66.4	98	-2.93	
VC-3*	8/10/2022 13:17	37.7	16.7	8.7	36.9	87	-14.75	
VC-4	8/10/2022 13:22	42.5	35.4	0	22.1	91	-0.21	
VC-5*	8/10/2022 13:26	0.3	0.6	21.5	77.6	93	-27.09	
VC-6*	8/10/2022 13:30	67.2	25.2	0	7.6	83	-18.81	
VC-7*	8/10/2022 13:36	57.9	37.9	0	4.2	89	-3.56	
VC-8*	8/10/2022 13:38	54.3	29.6	1	15.1	87	-32.89	
VE-10*	8/11/2022 8:31	0.1	0.7	20.5	78.7	70	-0.02	
VE-11	8/11/2022 8:36	52.1	34.1	0	13.8	74	-15.89	

\* - Alternative oxygen wellhead limit

\*\* - Alternate temperature wellehad limit

Permit Well ID	Date/Time	%CH4 by Vol.	%CO2 by Vol.	%O2 by Vol.	%Bal. by Vol.	Wellhead Temp. °F	Initial Vacuum (inches of water column)	Adjusted Vacuum (inches of water column)
VE-1R*	8/10/2022 13:51	32.3	24.3	2.2	41.2	85	-0.52	
VE-3	8/10/2022 13:55	46.3	36.3	0.2	17.2	87	-10.62	
VE-4R*	8/10/2022 14:01	0.5	0.7	21.5	77.3	88	-20.8	
VE-5*	8/10/2022 14:07	28	26.7	0	45.3	89	-1.95	
VE-6*-**	8/10/2022 14:12	19.1	25.6	0	55.3	88	-1.89	
VE-7*	8/11/2022 8:09	0	0.0	22.1	77.9	66	-0.02	
VE-8*	8/11/2022 8:15	20.2	23.8	0	56.0	70	-0.37	
VE-9*-**	8/11/2022 8:26	1.4	0.7	21.1	76.8	74	-35.47	
VF-1*	8/11/2022 8:55	5.5	10.6	9.3	74.6	76	-0.1	
VF-10	8/11/2022 10:13	60.8	38.1	0	1.1	73	-28.82	
VF-11**	8/11/2022 10:20	46.7	35.4	0	17.9	76	-30	
VF-2*	8/11/2022 8:58	19.6	13.4	9	58.0	73	-0.1	
VF-3**	8/11/2022 9:13	59.2	35.1	0	5.7	75	-4.41	
VF-4*	8/11/2022 9:20	10.5	6.1	16.5	66.9	78	-0.03	
VF-5R*	8/11/2022 9:25	37.1	26.7	0	36.2	76	-0.71	
VF-6	8/11/2022 9:39	49.5	40.1	0	10.4	75	-0.17	
VF-7*	8/11/2022 9:34	62.5	37.1	0	0.4	73	-0.51	
VF-7A	8/11/2022 9:47	62.2	37.4	0	0.4	79	-0.5	
VF-8R*	8/11/2022 10:00	56.9	34.4	0.8	7.9	75	-7.19	
VF-9	8/11/2022 10:05	56.3	41.3	0	2.4	77	-0.3	
VG-1	8/11/2022 10:36	37.8	29.1	3.9	29.2	78	-4.86	
VG-1A	8/11/2022 10:32	48.2	34.3	0	17.5	81	-2.93	
VG-2R	8/11/2022 10:40	56.7	30.9	0.8	11.6	78	-30.92	
VG-3**	8/11/2022 10:46	52.8	36.9	0	10.3	80	-1.8	
VG-3AR**	8/11/2022 10:49	53.1	37.6	0	9.3	80	-1.52	
VG-4**	8/11/2022 11:46	53.3	40.3	0	6.4	78	-1.02	
VG-4A	8/11/2022 11:01	51.7	33.3	0	15.0	79	-22.94	
VG-5	8/11/2022 11:52	46.3	38.8	0	14.9	78	-1.67	
VG-6	8/11/2022 12:01	53.9	41.2	0	4.9	97	-0.2	
VH-1	8/11/2022 12:17	48.7	31.4	0	19.9	75	-1.64	
VH-10**	8/11/2022 13:18	50.3	35.1	0	14.6	81	-0.29	
VH-11	8/11/2022 13:35	26.8	27.2	0	46.0	79	-0.48	
VH-12	8/11/2022 13:29	51.9	36.1	1.5	10.5	82	-0.53	
VH-13	8/11/2022 13:40	38.7	34.9	0	26.4	81	-0.02	
VH-2	8/11/2022 12:12	16.5	25.2	0	58.3	74	-0.1	
VH-3*	8/11/2022 12:27	12.3	12.2	10.8	64.7	84	-0.14	
VH-4**	8/11/2022 12:08	44.6	33.2	0.3	21.9	78	-0.84	
VH-5**	8/11/2022 12:33	39.7	34.0	0	26.3	77	-0.68	
VH-6	8/11/2022 12:49	49	33.6	0	17.4	79	-10.61	

\* - Alternative oxygen wellhead limit

\*\* - Alternate temperature wellehad limit

Permit Well ID	Date/Time	%CH4 by Vol.	%CO2 by Vol.	%O2 by Vol.	%Bal. by Vol.	Wellhead Temp. °F	Initial Vacuum (inches of water column)	Adjusted Vacuum (inches of water column)
VH-7R	8/11/2022 12:54	51.5	33.7	1.5	13.3	79	-4.22	
VH-8	8/11/2022 12:58	51.9	37.3	0	10.8	81	-0.67	
VH-9	8/19/2022 6:57	46.1	28.4	3.1	22.4	66	-1.85	
VJ-10R*	8/18/2022 9:08	37.9	21.5	7.4	33.2	66	-4.2	
VJ-11R*	8/18/2022 9:04	32.3	18.3	9.9	39.5	65	-2	
VJ-1R	8/11/2022 13:57	42.4	31.1	0	26.5	80	-2.31	
VJ-2R*	8/18/2022 8:12	42.3	23.9	6.5	27.3	65	-10.46	
VJ-3R*-**	8/18/2022 8:18	42.8	20.9	7.7	28.6	72	-17	
VJ-4A*-**	8/18/2022 8:24	31.7	25.0	3.5	39.8	74	-3.01	
VJ-4R*-**	8/18/2022 8:30	43.5	30.7	2.3	23.5	71	-4.22	
VJ-5R*	8/18/2022 8:41	57.9	38.1	0	4.0	64	-31.74	
VJ-6R*	8/18/2022 8:45	61.1	37.1	0	1.8	62	-34.75	
VJ-7R*	8/18/2022 8:51	47.8	31.1	3.7	17.4	63	-13.5	
VJ-8*	8/18/2022 8:56	34.6	25.8	7.1	32.5	64	-4.52	
VJ-9R*	8/18/2022 9:00	49.8	29.0	1.6	19.6	65	-8.09	
VK-1R	8/18/2022 9:17	56.3	33.9	0.3	9.5	66	-31.94	
VK-2R	8/18/2022 9:28	61.8	32.6	0.3	5.3	66	-32.58	
VK-3R*	8/18/2022 9:41	56.5	27.8	3.3	12.4	70	-33.43	
VK-4*	8/18/2022 9:37	2.5	1.5	21.1	74.9	70	-35.66	
VK-5*	8/18/2022 9:32	54.7	33.8	1.3	10.2	70	-3.96	

## FRONT NINE

Permit Well ID	Date/Time	%CH4 by Vol.	%CO2 by Vol.	%O2 by Vol.	%Bal. by Vol.	Wellhead Temp. °F	Initial Vacuum (inches of water column)	Adjusted Vacuum (inches of water column)
A-16*	8/3/2022 13:47	0	0.3	21.1	78.6	79	-30.71	
A-5	8/3/2022 9:11	48.3	32.1	3.8	15.8	75	-0.22	
B-12	8/3/2022 13:08	23	17.3	4.8	49.1	87	-30.13	
B-2*	8/3/2022 10:38	7	3.7	19.2	70.1	79	-0.01	
B-28*	8/3/2022 9:27	0	3.6	19.7	76.7	80	-0.02	
B-3R*	8/3/2022 10:44	21.1	12.1	12.2	54.6	90	-0.01	
B-4R*	8/3/2022 10:49	26.2	21.9	4.3	47.6	88	-0.07	
FHZ-1*	8/3/2022 12:39	52.1	36.5	0.2	11.2	84	-0.95	
FHZ-2*	8/3/2022 12:48	58.8	40.5	0	0.7	81	-0.03	
FHZ-3*	8/3/2022 12:53	52	36.6	1.9	9.5	73	-0.04	
FHZ-4*	8/3/2022 13:27	12.9	17.0	4.9	65.2	76	-0.04	
FHZ-5*	8/3/2022 13:58	44.8	33.7	0	21.5	87	-0.01	
LE-1*	8/3/2022 9:43	14.7	8.7	13.5	63.1	82	-1.85	

\* - Alternative oxygen wellhead limit

\*\* - Alternate temperature wellehad limit

Permit Well ID	Date/Time	%CH4 by Vol.	%CO2 by Vol.	%O2 by Vol.	%Bal. by Vol.	Wellhead Temp. °F	Initial Vacuum (inches of water column)	Adjusted Vacuum (inches of water column)
LE-2*	8/3/2022 10:23	0	0.7	20.3	79.0	81	-0.01	
LE-3*	8/3/2022 10:32	29.7	15.8	11.1	43.4	86	-0.01	
LE-4*	8/3/2022 12:26	0.5	0.1	21.2	78.2	84	-10.55	
Y-1*	8/3/2022 9:33	0.4	1.3	19.5	78.8	80	-1.26	
Y-2*	8/3/2022 10:06	3.5	5.1	16.1	75.3	84	-0.44	
Y-3*	8/3/2022 10:13	0	0.0	21	79.0	82	-31.37	
Y-4*	8/3/2022 10:19	0.9	1.4	19.3	78.4	84	-0.02	
Y-5*	8/3/2022 9:53	0	2.7	17.4	79.9	77	-0.04	
Y-6*	8/3/2022 9:49	0	0.0	21.5	78.5	82	-5.59	

## MICHAELS

Permit Well ID	Date/Time	%CH4 by Vol.	%CO2 by Vol.	%O2 by Vol.	%Bal. by Vol.	Wellhead Temp. °F	Initial Vacuum (inches of water column)	Adjusted Vacuum (inches of water column)
B-20*	8/1/2022 14:10	0.3	0.9	20.2	78.6	80	-0.04	
B-24*	8/1/2022 14:15	8.8	4.3	18.7	68.2	82	-14.17	
MPHZ*	8/1/2022 14:02	12.7	21.7	1.1	64.5	84	-0.01	

## BACK NINE

Permit Well ID	Date/Time	%CH4 by Vol.	%CO2 by Vol.	%O2 by Vol.	%Bal. by Vol.	Wellhead Temp. °F	Initial Vacuum (inches of water column)	Adjusted Vacuum (inches of water column)
WA-10	8/18/2022 9:14	58	33.9	1.3	6.8	68	-2.12	
WA-11	8/18/2022 9:34	59.8	40.1	0	0.1	71	-2.01	
WA-12R	8/18/2022 9:39	56.9	40.4	0.3	2.4	74	-4.85	
WA-13*	8/18/2022 9:26	57.5	34.9	1.2	6.4	69	-8.49	
WA-14*	8/18/2022 13:20	0.2	1.6	19.9	78.3	90	-0.08	
WA-15R*	8/18/2022 10:06	57.9	28.5	2.4	11.2	69	-3.86	
WA-16*	8/18/2022 11:43	56.6	39.0	0.6	3.8	79	-1.05	
WA-17	8/18/2022 11:49	56.2	38.9	0.8	4.1	81	-1	
WA-18*	8/18/2022 11:54	46.7	22.4	6.7	24.2	80	-10.24	
WA-19*	8/18/2022 12:03	0.9	1.5	19.9	77.7	84	-0.02	
WA-1R*	8/17/2022 14:33	45.3	31.1	4.8	18.8	82	-7.65	
WA-2*	8/17/2022 14:39	49.7	25.5	4.7	20.1	80	-34.59	
WA-20*	8/18/2022 12:07	44.1	28.4	5.6	21.9	85	-7.84	
WA-21R*	8/18/2022 12:16	0.3	0.1	21.5	78.1	86	-0.05	

\* - Alternative oxygen wellhead limit

\*\* - Alternate temperature wellhead limit

Permit Well ID	Date/Time	%CH4 by Vol.	%CO2 by Vol.	%O2 by Vol.	%Bal. by Vol.	Wellhead Temp. °F	Initial Vacuum (inches of water column)	Adjusted Vacuum (inches of water column)
WA-22R*	8/18/2022 12:23	44.6	31.2	0.3	23.9	86	-1.36	
WA-23R*	8/18/2022 12:26	56.3	36.2	0	7.5	88	-3.18	
WA-24*	8/18/2022 12:45	48.6	30.9	4.3	16.2	87	-33.97	
WA-25*	8/18/2022 12:50	59.5	37.0	0.6	2.9	89	-0.01	
WA-26*	8/18/2022 12:58	56.4	38.1	0.9	4.6	87	-3.4	
WA-27*	8/18/2022 13:04	52.7	32.0	2.4	12.9	87	-19.02	
WA-28*	8/18/2022 13:08	53.8	38.5	0.1	7.6	87	-2.1	
WA-29*	8/18/2022 13:11	27.8	29.3	0	42.9	85	-3.05	
WA-4	8/17/2022 14:45	50.9	27.9	2.7	18.5	82	-7.48	
WA-5*	8/18/2022 8:25	0	0.0	21.6	78.4	63	-35.26	
WA-6*	8/18/2022 8:20	7.1	5.8	17.4	69.7	66	-1.8	
WA-7	8/18/2022 8:58	62.8	32.9	0.7	3.6	67	-0.18	
WA-8*	8/18/2022 9:01	8	19.6	0	72.4	67	-0.02	
WA-9*	8/18/2022 9:09	49.5	33.3	3.1	14.1	65	-8.5	
WB-1*	8/17/2022 10:02	61.2	37.0	0	1.8	75	-0.07	
WB-10R*	8/17/2022 8:41	41.1	24.4	6	28.5	75	-5.12	
WB-11*	8/17/2022 8:33	19.1	8.6	15.7	56.6	69	-8.79	
WB-12AR*	8/17/2022 8:17	43.8	34.9	0.2	21.1	70	-0.64	
WB-12R*	8/17/2022 8:23	38	31.5	0.6	29.9	71	-3.83	
WB-13R*	8/17/2022 8:13	31.1	29.6	0.6	38.7	68	-1.02	
WB-14R*	8/17/2022 8:11	43.5	33.5	0.8	22.2	68	-0.49	
WB-15R*	8/17/2022 8:06	50.4	34.8	1.8	13.0	68	-1.21	
WB-16R*	8/17/2022 8:04	22	23.3	1.5	53.2	68	-1.06	
WB-17R*	8/18/2022 12:32	31.8	27.7	1.5	39.0	89	-0.16	
WB-2*	8/17/2022 9:52	26.9	22.7	6.8	43.6	74	-6.68	
WB-3*	8/17/2022 9:44	56.8	32.6	1	9.6	72	-0.2	
WB-4*	8/17/2022 9:39	4.5	1.2	20.4	73.9	74	-33.08	
WB-5A*	8/17/2022 9:29	13.3	22.1	0.2	64.4	73	-0.46	
WB-5R*	8/17/2022 9:24	46.7	28.3	0.3	24.7	73	-3.35	
WB-6*	8/17/2022 9:14	24.9	23.8	5.5	45.8	75	-1.4	
WB-6A*	8/17/2022 9:19	40.1	31.3	0.9	27.7	73	-1.87	
WB-7*	8/17/2022 9:02	44.3	32.0	4.1	19.6	76	-4.93	
WB-7A*	8/17/2022 9:08	42.9	28.3	5.9	22.9	73	-0.34	
WB-8*	8/17/2022 8:57	59.3	35.3	0.7	4.7	74	-24.89	
WB-9*	8/17/2022 8:46	35.5	23.5	6.9	34.1	76	-0.15	
WC-1	8/17/2022 10:08	53.4	27.5	4	15.1	74	-20.47	
WC-2	8/17/2022 10:19	43.8	27.5	3.5	25.2	77	-19.4	
WC-3	8/17/2022 10:23	48.7	30.9	4	16.4	80	-4.07	
WC-4R	8/17/2022 10:28	56.3	28.8	1.8	13.1	79	-30.53	

\* - Alternative oxygen wellhead limit

\*\* - Alternate temperature wellehad limit

Permit Well ID	Date/Time	%CH4 by Vol.	%CO2 by Vol.	%O2 by Vol.	%Bal. by Vol.	Wellhead Temp. °F	Initial Vacuum (inches of water column)	Adjusted Vacuum (inches of water column)
WD-1	8/17/2022 12:53	63.6	33.9	0	2.5	78	-18.08	
WD-2	8/17/2022 12:46	70.6	26.6	0	2.8	76	-4.81	
WD-3*	8/17/2022 12:32	65.2	32.7	0	2.1	77	-5.13	
WD-4	8/17/2022 12:24	60.3	34.9	0.5	4.3	76	-1.4	
WE-1	8/17/2022 13:08	38.3	29.1	0	32.6	81	-26.09	
WE-1AR	8/17/2022 13:01	42.5	20.5	4.8	32.2	80	-34.06	
WE-2	8/17/2022 13:15	55.7	38.9	0	5.4	81	-1.2	
WE-3	8/17/2022 13:19	68.8	22.9	1	7.3	80	-0.73	
WE-4	8/17/2022 13:57	59.7	38.4	0	1.9	82	-18.14	
WE-5	8/17/2022 14:09	60.8	37.0	0	2.2	79	-5.7	
WF-1	8/17/2022 14:20	62.5	37.3	0	0.2	82	-0.55	
WF-2	8/17/2022 12:18	61.2	36.8	0	2.0	81	-0.86	
WN-10*	8/19/2022 11:36	58.3	41.7	0	0.0	84	-3.85	
WN-11*	8/19/2022 11:30	60.6	39.4	0	0.0	83	-3.7	
WN-12R*	8/19/2022 11:23	56.6	39.3	0.6	3.5	83	-1.33	
WN-13*	8/19/2022 11:18	14.5	10.5	15.5	59.5	84	-36.74	
WN-1R*	8/19/2022 12:11	53.3	35.4	0.1	11.2	81	-6.81	
WN-2R*	8/19/2022 12:07	60.7	36.4	0	2.9	78	-31.47	
WN-3R*	8/19/2022 12:03	0.4	0.3	21.7	77.6	84	-33.11	
WN-4*	8/19/2022 11:58	56.4	31.2	1.7	10.7	79	-33.96	
WN-4A*	8/19/2022 11:55	49.3	33.9	0	16.8	82	-36.07	
WN-5R*	8/19/2022 11:51	58.8	39.7	0	1.5	83	-8.3	
WN-6R*	8/19/2022 11:48	58.1	39.7	0	2.2	82	-1.35	
WN-7*	8/19/2022 11:44	56.8	40.8	0.2	2.2	80	-1.41	
WN-8R*	8/19/2022 11:42	39.8	32.9	0.8	26.5	77	-1.86	
WN-9R*	8/19/2022 11:33	59.5	39.8	0	0.7	80	-10.34	

## CRITTENDEN

Permit Well ID	Date/Time	%CH4 by Vol.	%CO2 by Vol.	%O2 by Vol.	%Bal. by Vol.	Wellhead Temp. °F	Initial Vacuum (inches of water column)	Adjusted Vacuum (inches of water column)
CRA-10*	8/10/2022 12:55	35.3	23.3	4.2	37.2	81	-0.12	
CRA-11	8/10/2022 13:29	61.3	36.7	0	2	86	-0.35	
CRA-12	8/10/2022 13:17	61.1	32.7	0	6.2	84	-0.43	
CRA-13*	8/10/2022 13:08	58.6	37.1	0	4.3	83	-0.4	
CRA-1R*	8/10/2022 10:27	45.6	29.1	4.7	20.6	74	-0.41	
CRA-2R*	8/10/2022 10:34	17.2	16.9	9.6	56.3	73	-0.28	
CRA-3*	8/10/2022 10:41	45.2	36.4	0	18.4	80	-0.6	

\* - Alternative oxygen wellhead limit

\*\* - Alternate temperature wellehad limit

Permit Well ID	Date/Time	%CH4 by Vol.	%CO2 by Vol.	%O2 by Vol.	%Bal. by Vol.	Wellhead Temp. °F	Initial Vacuum (inches of water column)	Adjusted Vacuum (inches of water column)
CRA-4*	8/10/2022 10:47	42.8	27.8	6	23.4	80	-0.53	
CRA-5R*	8/10/2022 12:17	54.2	30.4	1.1	14.3	80	-0.06	
CRA-6*	8/10/2022 12:22	48.8	32.3	0.5	18.4	82	-0.07	
CRA-7R*	8/10/2022 12:28	36.3	29.9	0	33.8	81	-0.06	
CRA-8*	8/10/2022 12:34	57	34.3	0	8.7	83	-0.16	
CRA-9*	8/10/2022 12:39	32.4	19.8	9.1	38.7	85	-0.22	
CRB-1R*	8/10/2022 14:00	26.3	25.2	5.1	43.4	85	-0.24	
CRB-2R*	8/10/2022 14:14	51.2	34.6	0	14.2	87	-0.16	
CRB-3*	8/10/2022 14:25	60.2	32.5	0	7.3	83	-0.23	
CRB-4R*	8/10/2022 14:32	44.2	23.2	2.2	30.4	87	-0.27	
CRB-5*	8/10/2022 14:44	24.6	8.3	12	55.1	81	-0.09	
CRB-6*	8/10/2022 14:54	3.5	4.8	17.1	74.6	83	-0.11	
CRB-7R*	8/10/2022 15:00	62.8	32.7	0	4.5	83	-0.32	
CRB-8*	8/10/2022 15:19	18.5	13	13.1	55.4	81	-0.29	
CRC-1	8/10/2022 15:15	56	25.7	1.4	16.9	84	-0.25	
CRC-2	8/10/2022 14:49	60.1	29.2	0	10.7	82	-0.25	
CRC-3	8/10/2022 14:20	59.7	33.3	0	7	86	-0.2	
CRC-4	8/10/2022 14:06	51.8	26.4	2.2	19.6	83	-0.33	
CRD-1*	8/10/2022 15:34	57.9	34.2	0	7.9	84	-0.25	
CRD-10*	8/10/2022 16:53	56.8	26.5	0	16.7	80	-0.24	
CRD-11*	8/10/2022 17:01	0.1	0.2	21.8	77.9	81	-0.08	
CRD-2	8/10/2022 15:39	61.5	32	0	6.5	82	-0.08	
CRD-3*	8/10/2022 15:50	59.9	39	0	1.1	84	-0.22	
CRD-4	8/10/2022 16:04	64	33.9	0	2.1	80	-0.23	
CRD-5*	8/10/2022 16:16	59.7	28.4	0	11.9	87	-0.02	
CRD-6	8/10/2022 16:21	56.5	28.9	2.3	12.3	85	-0.19	
CRD-7	8/19/2022 10:59	22.1	10.6	4.9	69.8	76	-0.02	
CRD-8R*	8/10/2022 16:41	63	32.5	0	4.5	82	-0.24	
CRD-9*	8/10/2022 16:46	11.5	14.5	4.2	69.8	82	-0.06	

## 6ANE

Permit Well ID	Date/Time	%CH4 by Vol.	%CO2 by Vol.	%O2 by Vol.	%Bal. by Vol.	Wellhead Temp. °F	Initial Vacuum (inches of water column)	Adjusted Vacuum (inches of water column)
NEA-1*	8/3/2022 7:52	49.7	32.5	1.2	16.6	70	-0.43	
NEA-10	8/3/2022 9:26	56.2	39.8	0	4.0	72	-5.05	
NEA-11*	8/3/2022 9:33	49.3	37.7	0	13.0	76	-3.35	
NEA-12	8/3/2022 9:41	46.7	32.8	3.9	16.6	72	-1.58	

\* - Alternative oxygen wellhead limit

\*\* - Alternate temperature wellehad limit

Permit Well ID	Date/Time	%CH4 by Vol.	%CO2 by Vol.	%O2 by Vol.	%Bal. by Vol.	Wellhead Temp. °F	Initial Vacuum (inches of water column)	Adjusted Vacuum (inches of water column)
NEA-13*	8/3/2022 9:50	56.4	37.5	0.9	5.2	77	-0.6	
NEA-14	8/3/2022 9:57	53.2	34.6	3.6	8.6	73	-34.54	
NEA-15*	8/3/2022 10:04	57.6	40.8	0	1.6	74	-34.85	
NEA-16A*	8/3/2022 10:11	57.8	41.7	0	0.5	75	-34.7	
NEA-2R*	8/3/2022 8:00	10.9	8.4	15.3	65.4	70	-27.45	
NEA-3*	8/3/2022 8:07	61.3	31.1	1.3	6.3	71	-2.89	
NEA-4*	8/3/2022 8:15	51.5	33.0	3.1	12.4	70	-3.29	
NEA-5R*	8/3/2022 8:24	27.8	22.0	7.2	43.0	68	-1.32	
NEA-6*	8/3/2022 8:41	14.5	20.9	1.8	62.8	69	-0.57	
NEA-7*	8/3/2022 9:01	59	41.0	0	0.0	72	-0.1	
NEA-8*-**	8/3/2022 9:09	47.4	36.5	1.2	14.9	74	-4.73	
NEA-9*	8/3/2022 9:16	58.3	41.7	0	0.0	72	-0.97	
NEB-1*	8/3/2022 10:34	2.9	1.0	21	75.1	74	-33.44	
NEB-10*	8/3/2022 13:25	33.4	32.6	0	34.0	81	-6.16	
NEB-11*	8/3/2022 13:39	48.5	37.5	0	14.0	82	-1.01	
NEB-12*	8/3/2022 13:51	57.9	40.9	0	1.2	81	-0.13	
NEB-13*	8/3/2022 14:03	29.8	24.1	8.6	37.5	78	-0.01	
NEB-14R*	8/3/2022 14:17	34.5	35.2	0	30.3	77	-0.01	
NEB-2*	8/3/2022 10:44	0	0.0	21.9	78.1	75	-34.54	
NEB-3*	8/3/2022 12:30	48.9	34.9	0	16.2	71	-0.03	
NEB-4*	8/3/2022 12:43	1	1.9	19.1	78.0	78	-0.19	
NEB-5*	8/3/2022 12:50	31.6	28.0	0	40.4	77	-0.04	
NEB-6*	8/3/2022 12:57	51.7	38.6	0	9.7	70	-0.87	
NEB-7*	8/3/2022 13:07	44.3	37.5	0	18.2	81	-0.02	
NEB-8*	8/3/2022 13:14	45.3	35.4	0	19.3	79	-0.08	
NEB-9	8/3/2022 13:19	31.4	32.2	0	36.4	78	-0.38	
NEC-1*	8/4/2022 7:44	43.9	33.7	0.8	21.6	72	-0.69	
NEC-2*	8/4/2022 7:49	49	34.9	0	16.1	73	-0.31	
NEC-3*	8/4/2022 7:55	0.3	1.6	20.3	77.8	72	-0.03	
NED-1R*	8/4/2022 8:21	4.3	26.4	0.9	68.4	70	-0.05	
NED-2	8/4/2022 8:15	49.6	38.1	0	12.3	72	-2.15	
NED-3	8/4/2022 8:09	38.7	26.0	1	34.3	70	-0.61	
NEE-1	8/4/2022 8:30	59.4	40.5	0	0.1	75	-12.29	
NEE-2R*	8/4/2022 8:46	59	39.3	0	1.7	72	-24.71	
NEE-3*	8/4/2022 8:52	25.5	22.6	4.6	47.3	72	-0.08	
NEE-4*	8/4/2022 9:00	49.7	27.3	4.5	18.5	74	-25.14	
NEE-5*	8/4/2022 9:12	39.4	29.6	0	31.0	74	-0.25	
NEE-6*	8/4/2022 9:27	44.9	34.7	0	20.4	78	-4.64	

\* - Alternative oxygen wellhead limit

\*\* - Alternate temperature wellehad limit

**CITY OF MOUNTAIN VIEW**  
**MONTHLY LANDFILL GAS WELL HEAD MONITORING**

September 2022

<b>VISTA</b>								
Permit Well ID	Date/Time	%CH4 by Vol.	%CO2 by Vol.	%O2 by Vol.	%Bal. by Vol.	Wellhead Temp. ° F	Initial Vacuum (inches of water column)	Adjusted Vacuum (inches of water column)
VA-1A*	9/1/2022 8:18	56	32.8	2.3	8.9	67	-3.05	
VA-1R*	9/1/2022 8:13	28.8	30.4	0	40.8	64	-2.69	
VA-2*	9/1/2022 8:25	54.2	27.9	3	14.9	65	-3.38	
VA-3A*	9/1/2022 8:39	3	1.9	20.5	74.6	69	-5.27	
VA-3R*	9/1/2022 8:33	38.3	26.2	0.1	35.4	70	-9.65	
VA-4*	9/1/2022 8:44	28.3	22.9	4.2	44.6	69	-11.71	
VA-5R	9/1/2022 8:53	56.8	21.4	4.2	17.6	68	-19.04	
VA-6	9/1/2022 8:58	68.3	19.0	2.2	10.5	66	-36.17	
VA-HZ*	9/1/2022 8:49	20.6	22.9	1.6	54.9	67	-0.11	
VB-1*	9/1/2022 9:11	55.6	31.8	1.1	11.5	67	-8.01	
VB-2R*	9/1/2022 9:19	27.4	13.1	10.6	48.9	69	-0.2	
VB-3	9/1/2022 9:25	56.9	33.1	0.2	9.8	72	-35.06	
VB-3A*	9/1/2022 9:33	36.6	21.7	6.8	34.9	71	-14.67	
VB-4*	9/1/2022 9:48	40.7	31.1	0	28.2	72	-15.34	
VB-5A*	9/1/2022 9:57	55.1	34.0	0.4	10.5	77	-0.93	
VB-5R*	9/1/2022 9:53	30	25.5	0.1	44.4	76	-5.13	
VB-6R*	9/1/2022 10:01	30.4	27.6	1	41.0	77	-2.68	
VB-7*	9/1/2022 10:06	48.4	36.3	0	15.3	78	-2.26	
VB-8*	9/1/2022 10:31	57.8	37.9	0	4.3	80	-0.29	
VB-9R	9/1/2022 10:12	42	31.9	0	26.1	78	-0.14	
VC-10	9/1/2022 12:09	46.2	31.2	0	22.6	81	-22.93	
VC-1R*	9/1/2022 10:24	12	11.7	12.1	64.2	79	-0.22	
VC-2R*	9/1/2022 10:36	14.2	22.5	0.1	63.2	79	-2.91	
VC-3*	9/1/2022 10:41	32.8	14.1	10.6	42.5	80	-11.63	
VC-4	9/1/2022 10:45	39.6	33.6	0	26.8	79	-0.23	
VC-5*	9/1/2022 10:50	0.6	0.5	21.4	77.5	80	-22.14	
VC-6*	9/1/2022 10:54	69.4	23.9	0.3	6.4	78	-18.73	
VC-7*	9/1/2022 11:53	57.9	37.2	0	4.9	81	-3.84	
VC-8*	9/1/2022 11:58	59.2	29.0	0.9	10.9	81	-32.72	
VE-10*	9/1/2022 13:23	25.8	18.6	1.3	54.3	81	-0.01	
VE-11	9/1/2022 13:28	54	32.7	0.1	13.2	82	-14.93	

\* - Alternative oxygen wellhead limit

\*\* - Alternate temperature wellehad limit

Permit Well ID	Date/Time	%CH4 by Vol.	%CO2 by Vol.	%O2 by Vol.	%Bal. by Vol.	Wellhead Temp. °F	Initial Vacuum (inches of water column)	Adjusted Vacuum (inches of water column)
VE-1R*	9/1/2022 12:31	37.7	25.2	1.8	35.3	89	-0.56	
VE-3	9/1/2022 12:24	49.1	35.9	0.4	14.6	85	-10.58	
VE-4R*	9/1/2022 12:39	0.5	0.3	21.2	78.0	85	-16.38	
VE-5*	9/1/2022 12:44	31.5	26.7	0	41.8	85	-1.89	
VE-6*-**	9/1/2022 12:53	23.7	25.2	0	51.1	84	-1.87	
VE-7*	9/1/2022 13:01	49.7	27.1	4	19.2	84	-0.1	
VE-8*	9/1/2022 13:12	25.3	23.3	0	51.4	79	-0.27	
VE-9*-**	9/1/2022 13:18	3.1	1.3	21	74.6	81	-34.4	
VF-1*	9/1/2022 13:54	11.8	13.7	5.6	68.9	83	-0.05	
VF-10	9/8/2022 9:06	61.3	37.4	0	1.3	78	-28.15	
VF-11**	9/8/2022 9:12	48.9	36.0	0	15.1	76	-29.64	
VF-2*	9/1/2022 14:06	33.9	19.2	2.5	44.4	82	-0.62	
VF-3**	9/8/2022 7:39	59.9	35.3	0	4.8	74	-3.81	
VF-4*	9/8/2022 8:06	12.1	7.8	15.1	65.0	76	-0.02	
VF-5R*	9/8/2022 8:23	43.4	28.7	0	27.9	79	-0.55	
VF-6	9/8/2022 8:28	48.7	39.1	0	12.2	79	-0.16	
VF-7*	9/8/2022 8:42	25.8	12.7	13.4	48.1	78	-1.48	
VF-7A	9/8/2022 8:34	63	36.8	0	0.2	79	-0.34	
VF-8R*	9/8/2022 8:47	59.2	34.8	0.6	5.4	80	-6.79	
VF-9	9/8/2022 8:51	56.3	40.9	0	2.8	81	-0.22	
VG-1	9/8/2022 9:26	40.5	29.5	3.8	26.2	86	-4.81	
VG-1A	9/8/2022 9:21	49.3	34.0	0	16.7	86	-2.83	
VG-2R	9/8/2022 9:32	60.1	31.3	0.8	7.8	86	-30.67	
VG-3**	9/8/2022 9:43	54.4	37.3	0	8.3	87	-2.4	
VG-3AR**	9/8/2022 9:37	55.8	38.3	0	5.9	87	-2.93	
VG-4**	9/8/2022 9:55	55.7	41.2	0	3.1	87	-0.8	
VG-4A	9/8/2022 9:50	51.1	32.8	0.2	15.9	86	-21.92	
VG-5	9/8/2022 10:05	50	38.3	0	11.7	86	-1.25	
VG-6	9/8/2022 10:21	52.8	41.0	0	6.2	87	-0.13	
VH-1	9/8/2022 10:37	47.6	30.9	0	21.5	86	-1.68	
VH-10**	9/8/2022 12:09	52.3	35.2	0	12.5	96	-0.06	
VH-11	9/8/2022 12:19	31.2	28.3	0.1	40.4	100	-0.44	
VH-12	9/8/2022 12:15	53.9	34.8	1.6	9.7	99	-0.34	
VH-13	9/8/2022 12:26	47.1	36.2	0	16.7	103	-0.1	
VH-2	9/8/2022 10:29	19.1	25.6	0	55.3	87	-0.13	
VH-3*	9/8/2022 10:44	17.1	13.4	10.8	58.7	90	-0.13	
VH-4**	9/8/2022 10:25	46	32.4	1.3	20.3	89	-0.77	
VH-5**	9/8/2022 10:49	41.5	33.5	0	25.0	88	-0.49	
VH-6	9/8/2022 11:50	52	33.3	0.2	14.5	94	-9.77	

\* - Alternative oxygen wellhead limit

\*\* - Alternate temperature wellhead limit

Permit Well ID	Date/Time	%CH4 by Vol.	%CO2 by Vol.	%O2 by Vol.	%Bal. by Vol.	Wellhead Temp. °F	Initial Vacuum (inches of water column)	Adjusted Vacuum (inches of water column)
VH-7R	9/8/2022 11:54	51.4	33.7	1.5	13.4	100	-4.01	
VH-8	9/8/2022 11:59	53.6	36.2	0	10.2	96	-0.44	
VH-9	9/8/2022 12:04	45.4	29.6	0	25.0	96	-1.24	
VJ-10R*	9/8/2022 13:19	40	21.5	7.7	30.8	96	-3.62	
VJ-11R*	9/8/2022 13:16	54.1	28.7	2.2	15.0	96	-0.35	
VJ-1R	9/8/2022 12:33	46.7	30.6	0	22.7	96	-1.93	
VJ-2R*	9/8/2022 12:39	39.6	21.7	7.8	30.9	104	-10.76	
VJ-3R*-**	9/8/2022 12:43	49.4	23.2	6.1	21.3	97	-15.34	
VJ-4A*-**	9/8/2022 12:47	36.3	24.9	2.8	36.0	96	-2.74	
VJ-4R*-**	9/8/2022 12:52	44.2	30.2	1.5	24.1	98	-3.58	
VJ-5R*	9/8/2022 12:58	59.1	38.3	0	2.6	94	-30.33	
VJ-6R*	9/8/2022 13:01	61.3	36.3	0.2	2.2	93	-32.45	
VJ-7R*	9/8/2022 13:04	49.4	30.5	4.5	15.6	96	-11.38	
VJ-8*	9/8/2022 13:08	56.3	38.7	0.2	4.8	94	-4.53	
VJ-9R*	9/8/2022 13:12	56.7	30.6	1.3	11.4	96	-6.24	
VK-1R	9/8/2022 13:26	57.9	33.9	0	8.2	94	-29.58	
VK-2R	9/8/2022 13:29	65.1	33.3	0.1	1.5	93	-29.78	
VK-3R*	9/8/2022 13:37	53.2	25.4	4.4	17.0	95	-30.23	
VK-4*	9/8/2022 13:42	4.2	1.6	21.6	72.6	101	-31.68	
VK-5*	9/8/2022 13:33	58.8	35.8	1.1	4.3	96	-3.56	

## FRONT NINE

Permit Well ID	Date/Time	%CH4 by Vol.	%CO2 by Vol.	%O2 by Vol.	%Bal. by Vol.	Wellhead Temp. °F	Initial Vacuum (inches of water column)	Adjusted Vacuum (inches of water column)
A-16*	9/9/2022 10:38	1.5	1.0	21.5	76.0	85	-32.74	
A-5	9/9/2022 7:50	45.7	31.1	4.9	18.3	68	-0.27	
B-12	9/12/2022 10:04	41.3	35.5	1.2	5.0	73	-24.97	
B-2*	9/9/2022 9:13	8.5	4.8	19.4	67.3	74	-0.01	
B-28*	9/9/2022 8:03	0.4	5.1	20	74.5	72	-0.4	
B-3R*	9/9/2022 9:27	52.6	30.1	1.5	15.8	74	-0.07	
B-4R*	9/9/2022 9:32	24	22.0	4.7	49.3	76	-0.04	
FHZ-1*	9/9/2022 10:05	53.7	37.6	0	8.7	89	-0.14	
FHZ-2*	9/9/2022 10:10	58.1	39.9	0	2.0	92	-0.02	
FHZ-3*	9/9/2022 10:14	45.9	35.3	1.4	17.4	81	-0.04	
FHZ-4*	9/9/2022 10:31	18.2	19.6	3.1	59.1	86	-0.04	
FHZ-5*	9/9/2022 10:44	56.8	37.7	0	5.5	88	-0.01	
LE-1*	9/9/2022 8:16	28.1	21.8	2.8	47.3	76	-2.77	

\* - Alternative oxygen wellhead limit

\*\* - Alternate temperature wellehad limit

Permit Well ID	Date/Time	%CH4 by Vol.	%CO2 by Vol.	%O2 by Vol.	%Bal. by Vol.	Wellhead Temp. °F	Initial Vacuum (inches of water column)	Adjusted Vacuum (inches of water column)
LE-2*	9/9/2022 8:56	0	0.9	21.2	77.9	74	-0.01	
LE-3*	9/9/2022 9:04	40	21.3	8.2	30.5	75	-0.01	
LE-4*	9/9/2022 9:38	6.1	2.3	20.6	71.0	77	-7.64	
Y-1*	9/9/2022 8:09	0.3	1.3	20.8	77.6	74	-0.44	
Y-2*	9/9/2022 8:37	3.6	5.9	15.6	74.9	72	-0.34	
Y-3*	9/9/2022 8:47	0	0.0	22.2	77.8	73	-30.74	
Y-4*	9/9/2022 8:43	1.4	1.9	20.3	76.4	77	-0.02	
Y-5*	9/9/2022 8:25	0.1	2.6	18.5	78.8	71	-0.03	
Y-6*	9/9/2022 8:21	0.2	0.2	22.3	77.3	71	-4.89	

## MICHAELS

Permit Well ID	Date/Time	%CH4 by Vol.	%CO2 by Vol.	%O2 by Vol.	%Bal. by Vol.	Wellhead Temp. °F	Initial Vacuum (inches of water column)	Adjusted Vacuum (inches of water column)
B-20*	9/9/2022 11:44	2.6	2.8	19.6	75.0	80	-0.08	
B-24*	9/9/2022 11:46	9.9	5.8	18.3	66	79	-26.33	
MPHZ*	9/9/2022 11:42	16.8	22.9	0.2	60.1	79	-0.01	

## BACK NINE

Permit Well ID	Date/Time	%CH4 by Vol.	%CO2 by Vol.	%O2 by Vol.	%Bal. by Vol.	Wellhead Temp. °F	Initial Vacuum (inches of water column)	Adjusted Vacuum (inches of water column)
WA-10	9/19/2022 10:43	59.4	36.0	0.4	4.2	72	-2.09	
WA-11	9/19/2022 12:21	58.2	39.9	0	1.9	81	-1.44	
WA-12R	9/19/2022 12:28	55.6	41.1	0.1	3.2	86	-4.59	
WA-13*	9/19/2022 10:50	57.9	37.0	0.4	4.7	74	-8.68	
WA-14*	9/19/2022 12:43	0	1.6	20.1	78.3	82	-0.05	
WA-15R*	9/19/2022 12:57	45.5	23.9	6.2	24.4	82	-0.1	
WA-16*	9/19/2022 13:11	56.6	40.6	0	2.8	82	-1.67	
WA-17	9/19/2022 13:06	35.2	21.0	3.1	61.7	80	-14.64	
WA-18*	9/19/2022 13:19	49.5	24.2	4.9	21.4	81	-10.07	
WA-19*	9/19/2022 13:33	3.1	5.7	15.7	75.5	84	-0.42	
WA-1R*	9/19/2022 9:42	54.7	37.4	1.6	6.3	77	-5.42	
WA-2*	9/19/2022 9:48	66.4	32.2	0	1.4	74	-36.3	
WA-20*	9/19/2022 13:37	54.7	37.7	0.9	6.7	82	-5.78	
WA-21R*	9/19/2022 13:57	16.2	23.7	3.3	56.8	86	-1.31	

\* - Alternative oxygen wellhead limit

\*\* - Alternate temperature wellhead limit

Permit Well ID	Date/Time	%CH4 by Vol.	%CO2 by Vol.	%O2 by Vol.	%Bal. by Vol.	Wellhead Temp. °F	Initial Vacuum (inches of water column)	Adjusted Vacuum (inches of water column)
WA-22R*	9/19/2022 14:03	36.8	29.5	2.2	31.5	80	-1.18	
WA-23R*	9/19/2022 14:06	54.3	37.1	0	8.6	79	-2.94	
WA-24*	9/19/2022 14:21	46.9	32.1	3.4	17.6	81	-33.86	
WA-25*	9/19/2022 14:25	57.1	37.3	0.3	5.3	82	-2.28	
WA-26*	9/19/2022 14:31	53.5	38.4	0.9	7.2	79	-3.21	
WA-27*	9/19/2022 14:36	47.7	30.6	3.3	18.4	80	-18.94	
WA-28*	9/19/2022 14:39	52.8	40.6	0	6.6	78	-1.84	
WA-29*	9/19/2022 14:42	28.2	31.0	0	40.8	80	-2.67	
WA-4	9/19/2022 9:53	57.2	31.5	1.8	9.5	73	-6.42	
WA-5*	9/19/2022 10:18	25.3	14.3	13.6	46.8	73	-1.73	
WA-6*	9/19/2022 10:10	37.1	34.0	1.6	27.3	74	-0.98	
WA-7	9/19/2022 10:24	46.3	31.5	2.1	20.1	73	-1.79	
WA-8*	9/19/2022 10:31	0.1	15.0	1.9	83.0	79	-0.07	
WA-9*	9/19/2022 10:36	50.9	35.3	2.6	11.2	77	-8.46	
WB-1*	9/23/2022 11:50	62.3	37.7	0	0.0	86	-0.16	
WB-10R*	9/23/2022 10:30	39.6	23.2	7	30.2	77	-3.82	
WB-11*	9/23/2022 10:21	61.8	29.0	1.6	7.6	82	-6.25	
WB-12AR*	9/23/2022 9:55	43.9	36.6	0.1	19.4	73	-0.53	
WB-12R*	9/23/2022 10:03	38.2	32.5	0.6	28.7	75	-3.82	
WB-13R*	9/23/2022 9:49	32.1	32.0	0	35.9	72	-0.94	
WB-14R*	9/23/2022 9:46	47.2	36.3	0.5	16.0	69	-0.43	
WB-15R*	9/23/2022 9:39	55	40.5	0	4.5	70	-0.84	
WB-16R*	9/23/2022 9:34	26.2	26.9	0.8	46.1	71	-0.66	
WB-17R*	9/19/2022 14:13	34.4	29.8	0.4	35.4	83	-0.05	
WB-2*	9/23/2022 11:45	17.8	14.4	10.2	57.6	87	-6.56	
WB-3*	9/23/2022 11:36	56.6	34.0	0.5	8.9	84	-0.16	
WB-4*	9/23/2022 11:31	18.1	5.7	15.3	60.9	86	-30.94	
WB-5A*	9/23/2022 11:23	13.3	22.7	0.4	63.6	85	-0.47	
WB-5R*	9/23/2022 11:19	47.4	29.4	0.1	23.1	84	-2.94	
WB-6*	9/23/2022 11:10	57.4	41.7	0	0.9	83	-0.08	
WB-6A*	9/23/2022 11:13	45.2	33.0	0.3	21.5	86	-1.89	
WB-7*	9/23/2022 10:49	48.7	36.1	1.8	13.4	82	-4.5	
WB-7A*	9/23/2022 10:55	23.2	14.3	12.9	49.6	85	-0.02	
WB-8*	9/23/2022 10:45	61.4	38.4	0	0.2	82	-23.08	
WB-9*	9/23/2022 10:35	25.2	15.1	12	47.7	79	-0.11	
WC-1	9/23/2022 11:55	53.5	28.7	2.7	15.1	80	-18.81	
WC-2	9/23/2022 12:12	61.8	12.3	1.4	24.5	85	-0.33	
WC-3	9/23/2022 12:19	54.2	34.2	2	9.6	84	-3.03	
WC-4R	9/23/2022 12:23	57.5	29.6	1.6	11.3	84	-28.7	

\* - Alternative oxygen wellhead limit

\*\* - Alternate temperature wellehad limit

Permit Well ID	Date/Time	%CH4 by Vol.	%CO2 by Vol.	%O2 by Vol.	%Bal. by Vol.	Wellhead Temp. °F	Initial Vacuum (inches of water column)	Adjusted Vacuum (inches of water column)
WD-1	9/27/2022 9:07	64.7	33.8	0	1.5	65	-18.95	
WD-2	9/27/2022 9:00	60.9	24.4	0.4	14.3	62	-6.35	
WD-3*	9/27/2022 8:47	65.6	33.7	0	0.7	63	-4.99	
WD-4	9/23/2022 12:41	63.2	36.4	0	0.4	87	-0.63	
WE-1	9/27/2022 9:42	36.3	28.4	0	35.3	61	-27.78	
WE-1AR	9/27/2022 9:38	42	21.2	4.8	32.0	63	-35.97	
WE-2	9/27/2022 9:49	56.3	38.7	0	5.0	63	-1.33	
WE-3	9/27/2022 9:57	64.9	21.8	2.3	11.0	63	-3.4	
WE-4	9/27/2022 10:07	49.4	35.4	0	15.2	64	-19.36	
WE-5	9/27/2022 10:15	50	32.0	0	18.0	65	-6.24	
WF-1	9/27/2022 10:23	43.4	33.0	0	23.6	64	-2.26	
WF-2	9/23/2022 12:35	61.9	37.5	0	0.6	82	-0.59	
WN-10*	9/23/2022 8:11	57.4	42.6	0	0.0	69	-4.14	
WN-11*	9/23/2022 8:05	60.2	39.8	0	0.0	68	-3.77	
WN-12R*	9/23/2022 7:59	48.2	33.9	2.6	15.3	72	-0.79	
WN-13*	9/19/2022 14:48	2.2	1.9	20.4	75.5	82	-31.41	
WN-1R*	9/23/2022 9:24	50.1	37.0	0	12.9	75	-6.75	
WN-2R*	9/23/2022 9:16	3	3.3	19	74.7	70	-37.07	
WN-3R*	9/23/2022 9:10	0.2	0.2	21.4	78.2	70	-15.88	
WN-4*	9/23/2022 8:57	63	35.2	0	1.8	73	-36.23	
WN-4A*	9/23/2022 8:52	47.8	35.3	0	16.9	72	-37.8	
WN-5R*	9/23/2022 8:47	57.7	42.3	0	0.0	75	-5.22	
WN-6R*	9/23/2022 8:43	56.9	40.0	0.2	2.9	71	-1.55	
WN-7*	9/23/2022 8:29	57.3	42.6	0.1	0.0	74	-1.77	
WN-8R*	9/23/2022 8:25	37	32.3	1.3	29.4	70	-1.95	
WN-9R*	9/23/2022 8:16	58.3	41.7	0	0.0	67	-11.55	

## CRITTENDEN

Permit Well ID	Date/Time	%CH4 by Vol.	%CO2 by Vol.	%O2 by Vol.	%Bal. by Vol.	Wellhead Temp. °F	Initial Vacuum (inches of water column)	Adjusted Vacuum (inches of water column)
CRA-10*	9/19/2022 9:32	25.6	18.3	7.8	48.3	75	-0.09	
CRA-11	9/19/2022 10:03	57.5	34.2	1.3	7	77	-0.61	
CRA-12	9/19/2022 9:56	59.4	32	0	8.6	74	-0.6	
CRA-13*	9/19/2022 9:51	57.5	37	0	5.5	80	-0.58	
CRA-1R*	9/19/2022 8:25	55.9	37.2	2.6	4.3	68	-0.28	
CRA-2R*	9/19/2022 8:31	33.4	27.2	5.2	34.2	68	-0.29	
CRA-3*	9/19/2022 8:38	47.1	37	0	15.9	68	-0.91	

\* - Alternative oxygen wellhead limit

\*\* - Alternate temperature wellehad limit

Permit Well ID	Date/Time	%CH4 by Vol.	%CO2 by Vol.	%O2 by Vol.	%Bal. by Vol.	Wellhead Temp. °F	Initial Vacuum (inches of water column)	Adjusted Vacuum (inches of water column)
CRA-4*	9/19/2022 8:43	35.2	26.5	5.9	32.4	69	-0.48	
CRA-5R*	9/19/2022 8:52	28.3	27.4	1.5	42.8	69	-0.18	
CRA-6*	9/19/2022 8:57	11.5	21.3	2.5	64.7	70	-0.15	
CRA-7R*	9/19/2022 9:08	18.7	26.1	0	55.2	77	-0.27	
CRA-8*	9/19/2022 9:19	43.4	30.8	0	25.8	76	-0.17	
CRA-9*	9/19/2022 9:26	0.9	0.7	21	77.4	76	-0.06	
CRB-1R*	9/19/2022 10:12	19	21.8	6.3	52.9	72	-0.33	
CRB-2R*	9/19/2022 10:21	0.1	0	21.9	78	82	-0.13	
CRB-3*	9/19/2022 10:31	32	29.2	0	38.8	78	-0.08	
CRB-4R*	9/19/2022 10:45	43	28.7	0	28.3	84	-0.5	
CRB-5*	9/19/2022 12:18	15.2	5.7	14.2	64.9	83	-0.11	
CRB-6*	9/19/2022 12:24	0.2	1.4	19	79.4	82	-0.01	
CRB-7R*	9/19/2022 12:31	61	32.4	0	6.6	79	-0.31	
CRB-8*	9/19/2022 12:39	20.2	12.7	10.1	57	82	-0.32	
CRC-1	9/19/2022 12:35	52.3	25	2.7	20	85	-0.3	
CRC-2	9/19/2022 12:27	49.8	26.4	0	23.8	81	-0.28	
CRC-3	9/19/2022 10:27	24.3	18.5	4.6	78	74	-0.19	
CRC-4	9/19/2022 10:17	47.4	26.1	3.2	23.3	79	-0.63	
CRD-1*	9/19/2022 12:44	58.5	34.1	0	7.4	81	-0.3	
CRD-10*	9/19/2022 13:45	50	25.9	0	24.1	85	-0.27	
CRD-11*	9/19/2022 13:55	3	1	20.8	75.2	82	-0.01	
CRD-2	9/19/2022 12:51	63.4	31.8	0	4.8	89	-0.2	
CRD-3*	9/19/2022 13:00	61	39	0	0	79	-0.24	
CRD-4	9/19/2022 13:04	65.2	34.2	0	0.6	85	-0.25	
CRD-5*	9/19/2022 13:08	49	21.5	6.4	23.1	89	-0.09	
CRD-6	9/19/2022 13:16	53.6	26.5	3.8	16.1	81	-0.26	
CRD-7	9/19/2022 13:32	23.5	20.4	4.2	75.4	86	-0.07	
CRD-8R*	9/19/2022 13:35	55.7	30.9	0.3	13.1	89	-0.26	
CRD-9*	9/19/2022 13:40	29	18	6.7	46.3	89	-0.01	

## 6ANE

Permit Well ID	Date/Time	%CH4 by Vol.	%CO2 by Vol.	%O2 by Vol.	%Bal. by Vol.	Wellhead Temp. °F	Initial Vacuum (inches of water column)	Adjusted Vacuum (inches of water column)
NEA-1*	9/9/2022 7:44	51.8	32.8	1.1	14.3	70	-0.42	
NEA-10	9/9/2022 9:02	56.5	39.2	0	4.3	71	-5.47	
NEA-11*	9/9/2022 9:08	50.6	37.8	0	11.6	72	-3.62	
NEA-12	9/9/2022 9:16	46.8	32.5	4.1	16.6	73	-1.39	

\* - Alternative oxygen wellhead limit

\*\* - Alternate temperature wellehad limit

Permit Well ID	Date/Time	%CH4 by Vol.	%CO2 by Vol.	%O2 by Vol.	%Bal. by Vol.	Wellhead Temp. °F	Initial Vacuum (inches of water column)	Adjusted Vacuum (inches of water column)
NEA-13*	9/9/2022 9:24	55.5	36.5	1.2	6.8	76	-0.51	
NEA-14	9/9/2022 9:30	53.8	34.6	2.1	9.5	71	-34.63	
NEA-15*	9/9/2022 9:36	58.2	40.6	0	1.2	76	-34.43	
NEA-16A*	9/9/2022 9:43	57.9	41.0	0	1.1	77	-34.56	
NEA-2R*	9/9/2022 7:51	19.8	14.9	11.9	53.4	71	-26.68	
NEA-3*	9/9/2022 7:58	61.4	30.6	1.1	6.9	73	-1.99	
NEA-4*	9/9/2022 8:06	48.3	31.2	4.3	16.2	69	-2.92	
NEA-5R*	9/9/2022 8:11	62.6	35.4	0	2.0	68	-0.39	
NEA-6*	9/9/2022 8:20	18.4	22.2	1.3	58.1	68	-0.28	
NEA-7*	9/9/2022 8:27	59.2	40.8	0	0.0	71	-0.23	
NEA-8*-**	9/9/2022 8:35	48.8	36.5	0.8	13.9	68	-3.35	
NEA-9*	9/9/2022 8:44	58.4	41.6	0	0.0	72	-1.03	
NEB-1*	9/9/2022 10:00	0.2	0.5	22	77.3	81	-34.22	
NEB-10*	9/9/2022 10:57	45.6	36.6	0	17.8	83	-1.58	
NEB-11*	9/9/2022 11:10	53.7	39.0	0	7.3	84	-0.96	
NEB-12*	9/9/2022 11:18	55.8	40.1	0	4.1	85	-0.38	
NEB-13*	9/9/2022 11:26	54.5	41.3	0	4.2	87	-0.02	
NEB-14R*	9/9/2022 11:41	34.3	31.8	0	33.9	80	-0.1	
NEB-2*	9/9/2022 10:07	0	0.3	21.8	77.9	84	-34.22	
NEB-3*	9/9/2022 10:14	50.2	35.4	0.1	14.3	82	-0.27	
NEB-4*	9/9/2022 10:25	0.7	1.5	20.3	77.5	86	-0.12	
NEB-5*	9/9/2022 10:30	31.3	28.3	0	40.4	84	-0.14	
NEB-6*	9/9/2022 10:35	52.9	39.1	0	8.0	84	-1.2	
NEB-7*	9/9/2022 10:40	40.6	35.4	0	24.0	87	-0.22	
NEB-8*	9/9/2022 10:46	51.8	37.9	0	10.3	82	-0.23	
NEB-9	9/9/2022 10:51	36.1	33.4	0	30.5	83	-0.43	
NEC-1*	9/14/2022 15:36	51.6	37.7	0	10.7	78	-0.01	
NEC-2*	9/14/2022 15:44	53	36.4	0	10.6	75	-0.02	
NEC-3*	9/14/2022 15:53	46.6	35.5	0	17.9	78	-0.17	
NED-1R*	9/14/2022 17:04	9.9	23.2	1.7	65.2	77	-0.01	
NED-2	9/14/2022 16:58	50.3	38.0	0	11.7	78	-1.31	
NED-3	9/14/2022 16:53	40.9	27.2	0.5	31.4	79	-0.56	
NEE-1	9/14/2022 17:11	59.5	40.5	0	0.0	78	-13.47	
NEE-2R*	9/14/2022 17:18	58.4	39.9	0	1.7	77	-23.89	
NEE-3*	9/14/2022 17:22	28.3	24.8	4.1	42.8	75	-0.08	
NEE-4*	9/14/2022 17:28	47	26.8	4.9	21.3	77	-24.53	
NEE-5*	9/14/2022 17:32	43.8	31.3	0	24.9	78	-0.26	
NEE-6*	9/14/2022 17:36	44.8	34.8	0	20.4	78	-4.54	

\* - Alternative oxygen wellhead limit

\*\* - Alternate temperature wellehad limit

**CITY OF MOUNTAIN VIEW**  
**MONTHLY LANDFILL GAS WELL HEAD MONITORING**

October 2022

<b>VISTA</b>								
Permit Well ID	Date/Time	%CH4 by Vol.	%CO2 by Vol.	%O2 by Vol.	%Bal. by Vol.	Wellhead Temp. ° F	Initial Vacuum (inches of water column)	Adjusted Vacuum (inches of water column)
VA-1A*	10/6/2022 8:19	60.7	36.1	0	3.2	59	-4.31	
VA-1R*	10/6/2022 8:14	31.5	30.3	0	38.2	61	-0.69	
VA-2*	10/6/2022 8:24	51.6	27.7	3.7	17.0	59	-2.48	
VA-3A*	10/6/2022 8:35	61.9	28.7	0	9.4	59	-0.01	
VA-3R*	10/6/2022 8:29	36.9	27.2	0.1	35.8	59	-3.36	
VA-4*	10/6/2022 8:40	37.6	25.6	1.1	35.7	60	-3.32	
VA-5R	10/6/2022 8:48	60.5	23.8	3	12.7	59	-22.2	
VA-6	10/6/2022 8:54	61.7	18.3	4.1	15.9	60	-37.91	
VA-HZ*	10/6/2022 8:45	12.8	20.5	4	62.7	61	-0.16	
VB-1*	10/6/2022 9:06	58.6	36.2	0	5.2	61	-8.82	
VB-2R*	10/6/2022 9:13	50.8	27.6	0	21.6	61	-0.22	
VB-3	10/6/2022 9:18	56.3	34.4	0	9.3	61	-36.89	
VB-3A*	10/6/2022 9:23	44.3	24.1	5.6	26.0	62	-14.65	
VB-4*	10/6/2022 9:28	40.7	33.1	0	26.2	63	-16.25	
VB-5A*	10/6/2022 9:39	53.9	35.6	0.2	10.3	63	-1.05	
VB-5R*	10/6/2022 9:35	32.7	26.7	0	40.6	63	-2.19	
VB-6R*	10/6/2022 9:43	28.3	28.5	0.8	42.4	64	-1.63	
VB-7*	10/6/2022 9:49	46.7	37.5	0	15.8	62	-2.23	
VB-8*	10/6/2022 10:30	56.8	40.0	0	3.2	72	-0.29	
VB-9R	10/6/2022 9:53	36.8	33.0	0	30.2	64	-0.18	
VC-10	10/6/2022 12:05	42.7	33.4	0	23.9	76	-24.17	
VC-1R*	10/6/2022 10:01	10.3	11.5	13.2	65.0	65	-0.24	
VC-2R*	10/6/2022 10:35	12.6	23.1	0.1	64.2	68	-2.78	
VC-3*	10/6/2022 10:41	39.9	17.3	7.2	35.6	69	-13.89	
VC-4	10/6/2022 11:02	37.3	34.1	0	28.6	75	-0.24	
VC-5*	10/6/2022 10:47	0	0.2	22	77.8	72	-0.3	
VC-6*	10/6/2022 11:46	60.1	22.9	1.9	15.1	76	-22.15	
VC-7*	10/6/2022 11:52	56.2	37.4	0	6.4	75	-4.19	
VC-8*	10/6/2022 11:57	49	26.3	3.9	20.8	73	-31.16	
VE-10*	10/6/2022 12:58	0	1.1	20.2	78.7	75	-0.1	
VE-11	10/6/2022 13:08	50.9	35.1	0.2	13.8	79	-16.12	

\* - Alternative oxygen wellhead limit

\*\* - Alternate temperature wellehad limit

Permit Well ID	Date/Time	%CH4 by Vol.	%CO2 by Vol.	%O2 by Vol.	%Bal. by Vol.	Wellhead Temp. °F	Initial Vacuum (inches of water column)	Adjusted Vacuum (inches of water column)
VE-1R*	10/6/2022 12:24	37	26.2	2	34.8	76	-0.35	
VE-3	10/6/2022 12:18	47.2	38.3	0.2	14.3	76	-10.91	
VE-4R*	10/6/2022 12:29	0	0.2	21.7	78.1	76	-6.23	
VE-5*	10/6/2022 12:35	29.5	28.0	0	42.5	74	-0.93	
VE-6*-**	10/6/2022 12:38	21.1	26.9	0	52.0	77	-0.68	
VE-7*	10/6/2022 12:45	0.1	0.2	21.6	78.1	74	-0.1	
VE-8*	10/6/2022 12:50	18.9	23.3	0	57.8	74	-0.69	
VE-9*-**	10/6/2022 12:54	1.6	1.1	21.1	76.2	76	-36.58	
VF-1*	10/6/2022 13:24	8	13.1	7.6	71.3	75	-0.03	
VF-10	10/13/2022 8:28	61.6	37.4	0	1.0	59	-14.34	
VF-11**	10/13/2022 8:33	47.1	35.3	0	17.6	60	-31.07	
VF-2*	10/6/2022 13:29	28.1	18.6	4.8	48.5	76	-0.01	
VF-3**	10/6/2022 13:36	57.6	35.5	0	6.9	77	-3.31	
VF-4*	10/6/2022 13:41	12.1	15.2	5.3	67.4	76	-0.02	
VF-5R*	10/6/2022 13:53	40.1	29.5	0	30.4	74	-0.5	
VF-6	10/6/2022 13:57	44.7	38.7	0	16.6	75	-0.13	
VF-7*	10/13/2022 7:58	21.4	10.4	15.1	53.1	58	-1.18	
VF-7A	10/13/2022 7:48	63.3	36.6	0	0.1	58	-0.43	
VF-8R*	10/13/2022 8:09	58	34.3	1.1	6.6	58	-6.4	
VF-9	10/13/2022 8:13	56.4	41.2	0	2.4	59	-0.35	
VG-1	10/13/2022 8:48	39.2	30.0	3.6	27.2	63	-5.38	
VG-1A	10/13/2022 8:43	46.9	33.4	0	19.7	61	-3.41	
VG-2R	10/13/2022 8:57	47.3	25.2	4.7	22.8	60	-32.07	
VG-3**	10/13/2022 9:10	53.9	37.5	0	8.6	63	-3.02	
VG-3AR**	10/13/2022 9:05	54	37.7	0.3	8.0	64	-1.47	
VG-4**	10/13/2022 9:25	54.8	40.5	0	4.7	62	-1.12	
VG-4A	10/13/2022 9:17	47.4	32.9	0.2	19.5	62	-22.61	
VG-5	10/13/2022 9:31	47.2	38.2	0	14.6	63	-1.45	
VG-6	10/13/2022 9:44	48.7	39.4	0	11.9	61	-0.35	
VH-1	10/13/2022 10:03	44.2	31.3	0	24.5	63	-1.74	
VH-10**	10/13/2022 10:50	50.1	34.6	0	15.3	68	-0.35	
VH-11	10/13/2022 11:59	27.5	27.5	0.1	44.9	67	-0.47	
VH-12	10/13/2022 10:54	54.7	36.9	0.7	7.7	67	-0.53	
VH-13	10/13/2022 12:03	41.1	35.9	0	23.0	71	-0.03	
VH-2	10/13/2022 9:57	15.8	25.1	0	59.1	62	-0.1	
VH-3*	10/13/2022 10:09	15.4	13.6	11.3	59.7	62	-0.11	
VH-4**	10/13/2022 9:51	42.3	31.0	2.6	24.1	65	-0.9	
VH-5**	10/13/2022 10:16	38.4	33.7	0	27.9	63	-0.74	
VH-6	10/13/2022 10:26	50.1	33.3	0.4	16.2	64	-10.92	

\* - Alternative oxygen wellhead limit

\*\* - Alternate temperature wellehad limit

Permit Well ID	Date/Time	%CH4 by Vol.	%CO2 by Vol.	%O2 by Vol.	%Bal. by Vol.	Wellhead Temp. °F	Initial Vacuum (inches of water column)	Adjusted Vacuum (inches of water column)
VH-7R	10/13/2022 10:30	48.6	33.8	1.5	16.1	65	-4.39	
VH-8	10/13/2022 10:36	49.8	36.5	0	13.7	63	-0.13	
VH-9	10/13/2022 10:45	35	21.2	4.2	72.4	66	-1.11	
VJ-10R*	10/13/2022 13:11	38.6	21.7	7.2	32.5	71	-3.98	
VJ-11R*	10/13/2022 13:07	10.5	6.7	16.6	66.2	68	-2.79	
VJ-1R	10/13/2022 12:11	42.5	31.0	0	26.5	67	-2.39	
VJ-2R*	10/13/2022 12:17	39.4	23.9	6.6	30.1	76	-12.48	
VJ-3R*-**	10/13/2022 12:20	50.7	25.1	4.8	19.4	67	-16.2	
VJ-4A*-**	10/13/2022 12:26	24.7	20.3	6.5	48.5	67	-3.42	
VJ-4R*-**	10/13/2022 12:33	42.6	32.3	0	25.1	67	-3.83	
VJ-5R*	10/13/2022 12:41	56.7	38.8	0	4.5	67	-31.12	
VJ-6R*	10/13/2022 12:45	60.1	37.4	0	2.5	65	-35.09	
VJ-7R*	10/13/2022 12:48	45.2	30.1	4.3	20.4	67	-13.24	
VJ-8*	10/13/2022 12:52	43.9	32.9	2.5	20.7	65	-4.55	
VJ-9R*	10/13/2022 13:02	51.3	25.1	4.1	19.5	69	-1.01	
VK-1R	10/13/2022 13:16	53.7	34.8	0	11.5	67	-26.71	
VK-2R	10/13/2022 13:22	61.5	32.4	0.3	5.8	67	-31.38	
VK-3R*	10/13/2022 13:33	55	28.5	3.4	13.1	73	-33.17	
VK-4*	10/13/2022 13:37	4	2.5	19.7	73.8	73	-36.19	
VK-5*	10/13/2022 13:27	46.5	29.7	3.8	20.0	70	-9.8	

## FRONT NINE

Permit Well ID	Date/Time	%CH4 by Vol.	%CO2 by Vol.	%O2 by Vol.	%Bal. by Vol.	Wellhead Temp. °F	Initial Vacuum (inches of water column)	Adjusted Vacuum (inches of water column)
A-16*	10/6/2022 15:55	0	0.0	21.2	78.8	75	-32.06	
A-5	10/6/2022 7:49	44.7	30.2	4.9	20.2	60	-0.34	
B-12	10/6/2022 17:04	57.6	37.4	0	5.0	73	-24.97	
B-2*	10/6/2022 13:57	11.4	6.5	17.7	64.4	74	-0.03	
B-28*	10/6/2022 10:01	0	1.0	21.3	77.7	63	-0.01	
B-3R*	10/6/2022 14:01	58.6	30.5	0.9	10.0	79	-0.96	
B-4R*	10/6/2022 14:15	22.5	19.2	4.8	52.6	76	-0.06	
FHZ-1*	10/6/2022 15:18	43.6	32.0	1.8	22.6	79	-0.01	
FHZ-2*	10/6/2022 15:26	56.5	38.9	0	4.6	80	-0.06	
FHZ-3*	10/6/2022 15:31	50.1	34.0	1.9	14.0	76	-0.08	
FHZ-4*	10/6/2022 15:43	10.8	13.9	7	68.3	80	-0.04	
FHZ-5*	10/6/2022 16:01	48.5	34.7	0	16.8	75	-0.01	
LE-1*	10/6/2022 12:53	19.1	17.5	4.1	59.3	75	-1.5	

\* - Alternative oxygen wellhead limit

\*\* - Alternate temperature wellehad limit

Permit Well ID	Date/Time	%CH4 by Vol.	%CO2 by Vol.	%O2 by Vol.	%Bal. by Vol.	Wellhead Temp. °F	Initial Vacuum (inches of water column)	Adjusted Vacuum (inches of water column)
LE-2*	10/6/2022 13:41	0	0.3	20.5	79.2	79	-0.01	
LE-3*	10/6/2022 13:45	29.7	15.8	11.1	43.4	73	-0.11	
LE-4*	10/6/2022 14:57	1.3	0.8	20.6	77.3	78	-2.38	
Y-1*	10/6/2022 10:36	0.4	7.9	9.3	82.4	63	-0.34	
Y-2*	10/6/2022 13:23	2.9	4.4	16.1	76.6	74	-0.25	
Y-3*	10/6/2022 13:30	0	0.0	21.2	78.8	76	-32.09	
Y-4*	10/6/2022 16:52	0.9	0.9	20.2	78.0	74	-0.01	
Y-5*	10/6/2022 13:04	0	1.9	18.1	80.0	74	-0.03	
Y-6*	10/6/2022 12:43	0	0.0	21.9	78.1	72	-3.68	

## MICHAELS

Permit Well ID	Date/Time	%CH4 by Vol.	%CO2 by Vol.	%O2 by Vol.	%Bal. by Vol.	Wellhead Temp. °F	Initial Vacuum (inches of water column)	Adjusted Vacuum (inches of water column)
B-20*	10/4/2022 7:49	0.4	1.7	19.8	78.1	61	-0.01	
B-24*	10/4/2022 7:52	11.3	6.7	17.9	64.1	60	-24.08	
MPHZ*	10/4/2022 7:44	13.8	21.5	0.8	63.9	60	-0.01	

## BACK NINE

Permit Well ID	Date/Time	%CH4 by Vol.	%CO2 by Vol.	%O2 by Vol.	%Bal. by Vol.	Wellhead Temp. °F	Initial Vacuum (inches of water column)	Adjusted Vacuum (inches of water column)
WA-10	10/13/2022 9:52	57.5	33.8	1.1	7.6	61	-2.91	
WA-11	10/13/2022 10:28	59.5	39.6	0	0.9	63	-1.88	
WA-12R	10/13/2022 10:36	57.5	40.9	0	1.6	66	-1.64	
WA-13*	10/13/2022 10:20	59.2	36.7	0.4	3.7	68	-9.69	
WA-14*	10/13/2022 10:42	0.2	1.9	20.4	77.5	67	-0.07	
WA-15R*	10/13/2022 12:30	47.5	23.6	6.2	22.7	69	-0.13	
WA-16*	10/13/2022 12:43	57.5	39.7	0.2	2.6	69	-1.02	
WA-17	10/13/2022 12:38	56	38.8	0.7	4.5	72	-0.94	
WA-18*	10/13/2022 13:01	43.2	20.2	7.4	29.2	68	-12.08	
WA-19*	10/13/2022 13:13	14.3	17.2	5.3	63.2	66	-0.01	
WA-1R*	10/13/2022 7:56	40.4	27.9	7	24.7	60	-4.54	
WA-2*	10/13/2022 8:04	65.9	31.8	0	2.3	59	-37.76	
WA-20*	10/13/2022 13:21	46.4	32.8	4.1	16.7	69	-14.95	
WA-21R*	10/13/2022 13:30	16.9	22.1	3.6	57.4	73	-1.19	

\* - Alternative oxygen wellhead limit

\*\* - Alternate temperature wellhead limit

Permit Well ID	Date/Time	%CH4 by Vol.	%CO2 by Vol.	%O2 by Vol.	%Bal. by Vol.	Wellhead Temp. °F	Initial Vacuum (inches of water column)	Adjusted Vacuum (inches of water column)
WA-22R*	10/13/2022 13:41	35.4	27.7	3.2	33.7	71	-0.94	
WA-23R*	10/13/2022 13:45	56.6	37.2	0	6.2	72	-2.65	
WA-24*	10/13/2022 14:02	44.8	29.4	5.2	20.6	74	-35.44	
WA-25*	10/13/2022 14:06	56.7	35.7	0.9	6.7	71	-0.01	
WA-26*	10/13/2022 14:15	55.6	38.7	0.8	4.9	75	-3.31	
WA-27*	10/13/2022 14:23	51.6	32.7	2.9	12.8	73	-19.31	
WA-28*	10/13/2022 14:27	53.9	40.2	0	5.9	75	-1.96	
WA-29*	10/13/2022 14:30	28.3	29.9	0	41.8	72	-2.67	
WA-4	10/13/2022 8:23	36.9	21.1	4.8	33.2	60	-1.12	
WA-5*	10/13/2022 8:45	10.1	5.9	18.4	65.6	60	-14.29	
WA-6*	10/13/2022 8:36	56.9	40.9	0	2.2	60	-0.02	
WA-7	10/13/2022 9:04	37.5	26.5	4	32.0	60	-0.06	
WA-8*	10/13/2022 9:16	0.1	2.4	20	77.5	62	-0.02	
WA-9*	10/13/2022 9:23	0	0.0	22.7	77.3	64	-7.67	
WB-1*	10/27/2022 13:14	61.5	36.3	0	2.2	73	-0.22	
WB-10R*	10/27/2022 9:27	38.4	21.8	8.9	30.9	63	-6.78	
WB-11*	10/27/2022 9:21	57.9	25.8	3.6	12.7	60	-6.38	
WB-12AR*	10/27/2022 8:22	45.9	35.7	0.1	18.3	54	-0.6	
WB-12R*	10/27/2022 8:41	38.4	31.3	0.8	29.5	57	-3.99	
WB-13R*	10/27/2022 8:06	31.4	30.7	0.3	37.6	54	-1.16	
WB-14R*	10/27/2022 7:58	46.8	34.2	1.5	17.5	52	-0.43	
WB-15R*	10/24/2022 14:33	53.2	38.7	0.6	7.5	73	-0.45	
WB-16R*	10/24/2022 14:28	24.1	26.1	1	48.8	75	-0.35	
WB-17R*	10/13/2022 13:50	38.5	31.7	0	29.8	74	-0.18	
WB-2*	10/27/2022 12:58	7	5.0	18	70.0	74	-6.5	
WB-3*	10/27/2022 12:47	46.6	29.9	1.7	21.8	72	-0.27	
WB-4*	10/27/2022 12:32	0.2	0.1	22.1	77.6	74	-26.1	
WB-5A*	10/27/2022 10:46	13.5	21.4	1	64.1	70	-1.3	
WB-5R*	10/27/2022 10:40	45.6	28.1	0.2	26.1	69	-2.72	
WB-6*	10/27/2022 10:22	56.7	39.4	0.3	3.6	65	-0.07	
WB-6A*	10/27/2022 10:33	44.8	32.0	0.5	22.7	70	-2.29	
WB-7*	10/27/2022 10:06	41.9	30.1	4.2	23.8	64	-4.19	
WB-7A*	10/27/2022 10:16	19.8	11.9	14.7	53.6	65	-0.06	
WB-8*	10/27/2022 9:58	61.1	37.6	0	1.3	63	-21.73	
WB-9*	10/27/2022 9:41	38.8	21.7	7.5	32.0	60	-1.84	
WC-1	10/27/2022 13:21	63.1	32.7	0.1	4.1	75	-17.44	
WC-2	10/27/2022 13:35	55.4	29.9	2.1	12.6	74	-5.24	
WC-3	10/27/2022 13:45	53.2	33.4	2	11.4	78	-4.44	
WC-4R	10/27/2022 13:56	56.7	30.1	1.2	12.0	76	-29.25	

\* - Alternative oxygen wellhead limit

\*\* - Alternate temperature wellehad limit

Permit Well ID	Date/Time	%CH4 by Vol.	%CO2 by Vol.	%O2 by Vol.	%Bal. by Vol.	Wellhead Temp. °F	Initial Vacuum (inches of water column)	Adjusted Vacuum (inches of water column)
WD-1	10/27/2022 15:03	64.1	33.9	0	2.0	76	-18.9	
WD-2	10/27/2022 14:55	70.1	28.5	0	1.4	74	-5.62	
WD-3*	10/27/2022 14:39	63.4	34.0	0	2.6	74	-4.17	
WD-4	10/27/2022 14:32	62.2	35.3	0	2.5	77	-0.46	
WE-1	10/27/2022 15:18	33.6	27.0	0.1	39.3	74	-26.84	
WE-1AR	10/27/2022 15:11	37	21.0	4.6	37.4	74	-35.75	
WE-2	10/27/2022 15:24	54.4	37.6	0	8.0	74	-1.18	
WE-3	10/27/2022 15:33	64.8	20.7	2.2	12.3	73	-1.89	
WE-4	10/27/2022 15:44	59.1	37.7	0.2	3.0	73	-19.14	
WE-5	10/27/2022 15:51	60.8	37.2	0	2.0	73	-5.57	
WF-1	10/27/2022 16:02	32.4	22.1	4.8	69.0	74	-12.52	
WF-2	10/27/2022 14:24	60.5	36.2	0.2	3.1	77	-0.68	
WN-10*	10/19/2022 13:39	57.7	41.2	0	1.1	81	-4.08	
WN-11*	10/19/2022 13:35	56.1	35.9	0	8.0	81	-3.49	
WN-12R*	10/19/2022 13:19	59.2	40.8	0	0.0	80	-0.39	
WN-13*	10/19/2022 13:09	5.1	3.7	18.4	72.8	82	-35.59	
WN-1R*	10/19/2022 14:44	46.3	34.7	0.3	18.7	82	-4.78	
WN-2R*	10/19/2022 14:38	4.8	3.9	18.5	72.8	81	-37.4	
WN-3R*	10/19/2022 14:34	65	33.4	0	1.6	82	-0.06	
WN-4*	10/19/2022 14:20	59.7	32.8	0.6	6.9	80	-35.07	
WN-4A*	10/19/2022 14:08	45.6	33.7	0	20.7	83	-37.2	
WN-5R*	10/19/2022 14:04	56	40.3	0	3.7	82	-4.98	
WN-6R*	10/19/2022 13:59	52.5	36.7	1.3	9.5	82	-1.46	
WN-7*	10/19/2022 13:53	55.6	40.3	0	4.1	83	-2.57	
WN-8R*	10/19/2022 13:50	37	31.7	0.1	31.2	80	-1.94	
WN-9R*	10/19/2022 13:43	57.8	40.8	0	1.4	80	-10.4	

## CRITTENDEN

Permit Well ID	Date/Time	%CH4 by Vol.	%CO2 by Vol.	%O2 by Vol.	%Bal. by Vol.	Wellhead Temp. °F	Initial Vacuum (inches of water column)	Adjusted Vacuum (inches of water column)
CRA-10*	10/12/2022 10:36	18.5	14	10.7	56.8	64	-0.18	
CRA-11	10/12/2022 12:47	62	37	0	1	76	-0.39	
CRA-12	10/12/2022 12:39	60.6	32.7	0	6.7	75	-0.46	
CRA-13*	10/12/2022 12:35	53.1	34.2	1.5	11.2	70	-0.44	
CRA-1R*	10/12/2022 8:54	57.7	38	0.4	3.9	64	-0.32	
CRA-2R*	10/12/2022 9:10	0.9	0.5	21.9	76.7	62	-0.32	
CRA-3*	10/12/2022 9:21	42.6	34.9	0	22.5	62	-0.62	

\* - Alternative oxygen wellhead limit

\*\* - Alternate temperature wellehad limit

Permit Well ID	Date/Time	%CH4 by Vol.	%CO2 by Vol.	%O2 by Vol.	%Bal. by Vol.	Wellhead Temp. °F	Initial Vacuum (inches of water column)	Adjusted Vacuum (inches of water column)
CRA-4*	10/12/2022 9:28	31.9	25	6.2	36.9	62	-0.52	
CRA-5R*	10/12/2022 9:40	20.8	25	1.9	52.3	61	-0.2	
CRA-6*	10/12/2022 9:47	6.4	17.4	4.4	71.8	61	-0.17	
CRA-7R*	10/12/2022 9:56	15.4	23.9	0.5	60.2	63	-0.15	
CRA-8*	10/12/2022 10:10	40.1	29.7	0.1	30.1	63	-0.29	
CRA-9*	10/12/2022 10:20	0.5	0.4	22	77.1	62	-0.14	
CRB-1R*	10/12/2022 12:57	16.9	17.2	9	56.9	73	-0.14	
CRB-2R*	10/12/2022 13:31	30.8	30.6	0	38.6	76	-0.14	
CRB-3*	10/12/2022 13:41	26.4	28.8	0	44.8	73	-0.22	
CRB-4R*	10/12/2022 13:46	36.7	28.6	0	34.7	75	-0.23	
CRB-5*	10/12/2022 13:51	24.4	10.1	11.6	53.9	76	-0.05	
CRB-6*	10/12/2022 13:56	0.1	2.1	18.9	78.9	76	-0.13	
CRB-7R*	10/12/2022 14:03	42.1	23.5	5.6	28.8	73	-0.25	
CRB-8*	10/12/2022 14:12	11.1	6.9	13.8	68.2	75	-0.28	
CRC-1	10/12/2022 14:07	50.5	25.5	2.1	21.9	74	-0.28	
CRC-2	10/12/2022 13:59	50.7	27.3	0	22	75	-0.28	
CRC-3	10/12/2022 13:37	56.1	34.1	0	9.8	75	-0.13	
CRC-4	10/12/2022 13:19	54.4	29.3	0.9	15.4	76	-0.3	
CRD-1*	10/12/2022 14:16	56	34.2	0	9.8	74	-0.31	
CRD-10*	10/12/2022 14:57	45	26.6	0	28.4	76	-0.21	
CRD-11*	10/12/2022 15:02	2.3	1.2	20.7	75.8	77	-0.06	
CRD-2	10/12/2022 14:18	61.8	31.6	0	6.6	77	-0.12	
CRD-3*	10/12/2022 14:23	60.4	38.3	0	1.3	73	-0.25	
CRD-4	10/12/2022 14:26	64	34.5	0	1.5	73	-0.25	
CRD-5*	10/12/2022 14:30	51.7	24	5	19.3	34	-0.07	
CRD-6	10/12/2022 14:34	56.3	28.8	2.4	12.5	79	-0.21	
CRD-7	10/12/2022 14:41	20.2	15.2	4.9	77.1	77	-0.02	
CRD-8R*	10/12/2022 14:48	62.3	32.8	1	3.9	73	-0.24	
CRD-9*	10/12/2022 14:51	18.4	16.1	6	59.5	74	-0.02	

## 6ANE

Permit Well ID	Date/Time	%CH4 by Vol.	%CO2 by Vol.	%O2 by Vol.	%Bal. by Vol.	Wellhead Temp. °F	Initial Vacuum (inches of water column)	Adjusted Vacuum (inches of water column)
NEA-1*	10/20/2022 8:17	52.8	31.8	1.5	13.9	64	-0.29	
NEA-10	10/20/2022 9:07	55.6	37.7	0	6.7	63	-6.54	
NEA-11*	10/20/2022 9:12	48.1	35.9	0	16.0	63	-4.07	
NEA-12	10/20/2022 9:18	43.9	30.3	4.5	20.4	64	-2.83	

\* - Alternative oxygen wellhead limit

\*\* - Alternate temperature wellehad limit

Permit Well ID	Date/Time	%CH4 by Vol.	%CO2 by Vol.	%O2 by Vol.	%Bal. by Vol.	Wellhead Temp. °F	Initial Vacuum (inches of water column)	Adjusted Vacuum (inches of water column)
NEA-13*	10/20/2022 9:21	60.4	38.4	0	1.2	62	-0.98	
NEA-14	10/20/2022 9:26	55.1	35.0	1.9	8.0	61	-36.7	
NEA-15*	10/20/2022 9:29	59.4	40.2	0	0.4	63	-36.89	
NEA-16A*	10/20/2022 9:34	58.2	39.9	0.1	1.8	64	-36.89	
NEA-2R*	10/20/2022 8:23	12.3	8.8	16.1	62.8	62	-22.7	
NEA-3*	10/20/2022 8:29	57.2	28.8	2.5	11.5	61	-2.77	
NEA-4*	10/20/2022 8:33	47.4	30.1	4.8	17.7	62	-3.57	
NEA-5R*	10/20/2022 8:38	32.4	23.8	6.7	37.1	63	-0.74	
NEA-6*	10/20/2022 8:44	17.3	21.1	1.9	59.7	59	-0.3	
NEA-7*	10/20/2022 8:53	59.6	39.8	0	0.6	64	-0.34	
NEA-8*-**	10/20/2022 8:57	46.7	34.9	1.7	16.7	63	-3.12	
NEA-9*	10/20/2022 9:01	58.9	40.3	0	0.8	65	-2.01	
NEB-1*	10/20/2022 9:51	0.4	0.6	22	77.0	70	-27.09	
NEB-10*	10/20/2022 10:57	46.5	36.4	0	17.1	73	-1.54	
NEB-11*	10/20/2022 12:01	56.1	38.8	0	5.1	76	-0.91	
NEB-12*	10/20/2022 12:06	51.3	38.1	0	10.6	75	-0.5	
NEB-13*	10/20/2022 12:18	50	38.2	0	11.8	85	-0.1	
NEB-14R*	10/20/2022 12:25	34.6	30.8	0.6	34.0	78	-0.09	
NEB-2*	10/20/2022 9:59	0	0.3	21.9	77.8	67	-36.71	
NEB-3*	10/20/2022 10:06	59.1	38.6	0	2.3	73	-0.05	
NEB-4*	10/20/2022 10:13	0.9	1.6	20.5	77.0	71	-0.16	
NEB-5*	10/20/2022 10:17	28.8	27.7	0	43.5	69	-0.34	
NEB-6*	10/20/2022 10:22	53.6	38.2	0	8.2	70	-1.29	
NEB-7*	10/20/2022 10:36	40.5	35.0	0	24.5	71	-0.19	
NEB-8*	10/20/2022 10:47	51.9	37.2	0	10.9	74	-0.13	
NEB-9	10/20/2022 10:51	38.1	32.9	0	29.0	72	-0.37	
NEC-1*	10/20/2022 12:43	46.6	36.3	0	17.1	77	-0.06	
NEC-2*	10/20/2022 12:54	53.7	37.1	0	9.2	77	-0.06	
NEC-3*	10/20/2022 13:03	47.9	36.1	0	16.0	80	-0.18	
NED-1R*	10/20/2022 13:15	27.4	29.4	0	43.2	76	-0.11	
NED-2	10/25/2022 9:16	59.9	40.1	0	0.0	61	-0.05	
NED-3	10/20/2022 13:19	39.9	27.4	0.3	32.4	76	-0.71	
NEE-1	10/20/2022 13:26	58.3	39.4	0	2.3	76	-14.18	
NEE-2R*	10/20/2022 13:34	11.3	8.6	16.7	63.4	77	-19.68	
NEE-3*	10/20/2022 13:50	29.7	26.0	3.1	41.2	75	-0.05	
NEE-4*	10/20/2022 14:01	60.8	33.5	0.7	5.0	77	-25.66	
NEE-5*	10/20/2022 14:07	45.9	32.1	0	22.0	78	-0.13	
NEE-6*	10/20/2022 14:15	43.2	35.2	0	21.6	78	-4.49	

\* - Alternative oxygen wellhead limit

\*\* - Alternate temperature wellehad limit

**CITY OF MOUNTAIN VIEW**  
**MONTHLY LANDFILL GAS WELL HEAD MONITORING**

November 2022

<b>VISTA</b>								
Permit Well ID	Date/Time	%CH4 by Vol.	%CO2 by Vol.	%O2 by Vol.	%Bal. by Vol.	Wellhead Temp. ° F	Initial Vacuum (inches of water column)	Adjusted Vacuum (inches of water column)
VA-1A*	11/2/2022 8:06	63.1	36.5	0	0.4	48	-2.09	
VA-1R*	11/2/2022 8:01	52.7	34.3	0	13.0	46	-0.63	
VA-2*	11/2/2022 8:11	55.6	28.8	3	12.6	50	-2.78	
VA-3A*	11/2/2022 8:24	70.3	29.1	0	0.6	56	-0.34	
VA-3R*	11/2/2022 8:17	63.8	29.8	0.1	6.3	52	-1.4	
VA-4*	11/2/2022 8:28	56.4	29.3	1.7	12.6	53	-2.95	
VA-5R	11/2/2022 9:11	55.8	21.3	4.9	18.0	52	-12.4	
VA-6	11/2/2022 9:19	56.2	16.7	4.8	21.6	54	-39.06	
VA-HZ*	11/2/2022 8:34	17.9	22.9	2.7	56.5	52	-0.13	
VB-1*	11/2/2022 9:37	57.9	34.6	0.6	6.9	55	-8.99	
VB-2R*	11/2/2022 9:40	55.1	27.5	0	17.4	61	-0.23	
VB-3	11/2/2022 9:50	58	34.7	0	7.3	60	-38.05	
VB-3A*	11/2/2022 9:45	43.4	23.1	7	26.5	63	-12.79	
VB-4*	11/2/2022 9:55	40.8	32.6	0	26.6	61	-16.09	
VB-5A*	11/2/2022 10:06	52.8	33.7	0.2	13.3	70	-0.9	
VB-5R*	11/2/2022 10:00	42.4	28.2	0	29.4	66	-2.01	
VB-6R*	11/2/2022 10:10	31.4	28.8	0.7	39.1	69	-1.52	
VB-7*	11/2/2022 10:14	47.1	36.8	0	16.1	71	-2.25	
VB-8*	11/2/2022 10:28	57.2	39.3	0	3.5	69	-0.27	
VB-9R	11/2/2022 10:17	36.9	32.3	0	30.8	70	-0.19	
VC-10	11/2/2022 12:19	43.4	33.1	0	23.5	77	-24.57	
VC-1R*	11/2/2022 10:24	10.1	10.9	13.6	65.4	71	-0.28	
VC-2R*	11/2/2022 10:32	12.6	22.6	0.3	64.5	68	-2.46	
VC-3*	11/2/2022 10:39	46.1	18.3	6.8	28.8	72	-6.32	
VC-4	11/2/2022 10:43	37.8	32.5	0	29.7	73	-0.27	
VC-5*	11/2/2022 10:46	0.1	0.4	21.8	77.7	71	-18.06	
VC-6*	11/2/2022 10:50	51.4	19.2	4.9	24.5	73	-21.51	
VC-7*	11/2/2022 10:58	55.3	37.1	0.3	7.3	71	-4.39	
VC-8*	11/2/2022 11:01	57.2	29.6	1.5	11.7	68	-35.81	
VE-10*	11/2/2022 13:14	0.1	1.1	20.1	78.7	72	-0.24	
VE-11	11/2/2022 13:19	51	34.3	0.2	14.5	78	-16.76	

\* - Alternative oxygen wellhead limit

\*\* - Alternate temperature wellehad limit

Permit Well ID	Date/Time	%CH4 by Vol.	%CO2 by Vol.	%O2 by Vol.	%Bal. by Vol.	Wellhead Temp. °F	Initial Vacuum (inches of water column)	Adjusted Vacuum (inches of water column)
VE-1R*	11/2/2022 12:33	38.7	26.3	2.1	32.9	80	-0.77	
VE-3	11/2/2022 12:28	49.6	37.7	0	12.7	75	-10.34	
VE-4R*	11/2/2022 12:38	0	0.2	21.4	78.4	83	-5.39	
VE-5*	11/2/2022 12:43	34.5	28.8	0	36.7	76	-0.96	
VE-6*-**	11/2/2022 12:47	26.2	27.7	0	46.1	75	-0.66	
VE-7*	11/2/2022 12:55	0.1	0.2	21.6	78.1	75	-0.1	
VE-8*	11/2/2022 13:05	18.2	23.0	0.4	58.4	76	-0.73	
VE-9*-**	11/2/2022 13:09	52.2	29.0	1.3	17.5	72	-3.25	
VF-1*	11/2/2022 13:41	8.8	13.0	7.4	70.8	75	-0.04	
VF-10	11/10/2022 8:48	59.9	36.0	0.8	3.3	55	-30.18	
VF-11**	11/10/2022 8:54	47.1	35.9	0	17.0	52	-30.32	
VF-2*	11/2/2022 13:47	30.5	19.7	3.8	46.0	75	-0.01	
VF-3**	11/2/2022 13:52	58.9	35.6	0	5.5	78	-3.17	
VF-4*	11/2/2022 14:07	25.8	21.0	1.1	52.1	73	-0.1	
VF-5R*	11/2/2022 14:12	43.9	29.5	0	26.6	75	-0.42	
VF-6	11/11/2022 13:57	44.7	38.7	0	16.6	75	-0.13	
VF-7*	11/3/2022 8:41	19.6	9.5	16.3	54.6	54	-0.19	
VF-7A	11/3/2022 8:32	62.9	37.1	0	0.0	53	-0.26	
VF-8R*	11/3/2022 8:47	60.7	35.1	0.2	4.0	55	-0.26	
VF-9	11/3/2022 8:51	55.2	40.1	0	4.7	55	-0.26	
VG-1	11/10/2022 9:14	38	30.0	3.6	28.4	60	-5.28	
VG-1A	11/10/2022 9:06	44.9	33.2	0	21.9	58	-3.92	
VG-2R	11/10/2022 9:22	44.1	24.3	4.9	26.7	58	-35.19	
VG-3**	11/10/2022 9:32	52.8	37.5	0.1	9.6	57	-3.34	
VG-3AR**	11/10/2022 9:26	52.2	35.8	0.8	11.2	57	-2.47	
VG-4**	11/10/2022 9:42	52.6	38.5	1	7.9	58	-1.16	
VG-4A	11/10/2022 9:38	44.9	32.4	0.2	22.5	58	-24.21	
VG-5	11/10/2022 9:46	42.3	36.8	0	20.9	59	-1.68	
VG-6	11/10/2022 9:50	47.2	38.7	0	14.1	60	-0.27	
VH-1	11/10/2022 10:09	43.1	30.6	0.3	26.0	59	-1.77	
VH-10**	11/10/2022 10:41	50.3	34.9	0	14.8	63	-0.56	
VH-11	11/10/2022 10:49	26.7	28.2	0.2	44.9	63	-0.54	
VH-12	11/10/2022 10:45	58.2	38.8	0	3.0	60	-0.65	
VH-13	11/10/2022 10:54	34.1	33.1	0	32.8	61	-0.09	
VH-2	11/10/2022 10:03	15.3	24.8	0	59.9	57	-2.3	
VH-3*	11/10/2022 10:13	12.5	12.4	11.9	63.2	59	-0.12	
VH-4**	11/10/2022 9:55	48.5	36.5	0	15.0	58	-1.05	
VH-5**	11/10/2022 10:17	36.7	33.1	0	30.2	62	-0.8	
VH-6	11/10/2022 10:25	50.3	33.5	0.7	15.5	58	-11.57	

\* - Alternative oxygen wellhead limit

\*\* - Alternate temperature wellehad limit

Permit Well ID	Date/Time	%CH4 by Vol.	%CO2 by Vol.	%O2 by Vol.	%Bal. by Vol.	Wellhead Temp. °F	Initial Vacuum (inches of water column)	Adjusted Vacuum (inches of water column)
VH-7R	11/10/2022 10:30	49.2	34.0	1.2	15.6	63	-4.74	
VH-8	11/10/2022 10:33	47.8	35.6	0	16.6	65	-0.88	
VH-9	11/10/2022 10:37	42.7	31.7	0	25.6	62	-0.04	
VJ-10R*	11/10/2022 12:54	44.4	29.0	2.8	23.8	63	-5.9	
VJ-11R*	11/10/2022 12:51	13.4	8.0	16.2	62.4	60	-6.98	
VJ-1R	11/10/2022 11:34	40.6	30.0	0	29.4	64	-2.81	
VJ-2R*	11/10/2022 11:41	35.1	21.0	7.3	36.6	67	-11.14	
VJ-3R*-**	11/10/2022 11:44	54.4	26.2	3.8	15.6	65	-18.42	
VJ-4A*-**	11/10/2022 11:49	33.3	28.3	0	38.4	66	-5.06	
VJ-4R*-**	11/10/2022 11:53	42.9	32.0	0	25.1	66	-3.86	
VJ-5R*	11/10/2022 12:07	57.3	38.4	0	4.3	60	-32.68	
VJ-6R*	11/10/2022 12:11	61.2	37.7	0	1.1	59	-36.64	
VJ-7R*	11/10/2022 12:20	45.2	30.5	4.9	19.4	60	-11.64	
VJ-8*	11/10/2022 12:38	35.4	27.6	3.1	33.9	58	-4.39	
VJ-9R*	11/10/2022 12:48	46.6	29.3	1.2	22.9	59	-7.64	
VK-1R	11/10/2022 12:59	53.6	35.0	0	11.4	62	-24.51	
VK-2R	11/10/2022 13:02	63.6	32.3	0.1	4.0	66	-18.35	
VK-3R*	11/10/2022 13:17	42.8	23.2	7.2	26.8	64	-38.47	
VK-4*	11/10/2022 13:13	49.1	33.5	0	17.4	66	-28.91	
VK-5*	11/10/2022 13:06	54.6	35.0	1.1	9.3	63	-8.5	

## FRONT NINE

Permit Well ID	Date/Time	%CH4 by Vol.	%CO2 by Vol.	%O2 by Vol.	%Bal. by Vol.	Wellhead Temp. °F	Initial Vacuum (inches of water column)	Adjusted Vacuum (inches of water column)
A-16*	11/10/2022 7:52	0.4	0.6	21.7	77.3	48	-34.84	
A-5	11/10/2022 7:29	48.7	31.1	3.7	16.5	51	-0.36	
B-12	11/10/2022 8:10	0.1	0.1	22.3	77.5	50	-35.51	
B-2*	11/10/2022 9:04	5	2.6	20.7	71.7	57	-0.61	
B-28*	11/10/2022 9:48	0	0.6	20.5	78.9	60	-0.75	
B-3R*	11/10/2022 8:56	16.6	10.5	13.5	59.4	60	-0.03	
B-4R*	11/10/2022 8:51	38.1	22.5	4.5	69.3	54	-0.11	
FHZ-1*	11/10/2022 8:32	13.2	12.8	11.8	62.2	49	-0.04	
FHZ-2*	11/10/2022 8:25	49.5	36.1	0	14.4	50	-0.11	
FHZ-3*	11/10/2022 8:21	18.3	17.6	8.1	56.0	52	-0.09	
FHZ-4*	11/10/2022 7:57	1.8	11.3	7.1	79.8	49	-0.03	
FHZ-5*	11/10/2022 7:47	32.5	30.1	0	37.4	48	-0.01	
LE-1*	11/10/2022 9:33	10.4	18.1	1.1	70.4	60	-0.01	

\* - Alternative oxygen wellhead limit

\*\* - Alternate temperature wellehad limit

Permit Well ID	Date/Time	%CH4 by Vol.	%CO2 by Vol.	%O2 by Vol.	%Bal. by Vol.	Wellhead Temp. °F	Initial Vacuum (inches of water column)	Adjusted Vacuum (inches of water column)
LE-2*	11/10/2022 9:12	0.2	1.2	19.6	79.0	56	-0.01	
LE-3*	11/10/2022 9:08	8.3	3.1	20	68.6	54	-0.05	
LE-4*	11/10/2022 8:48	0	0.6	21.3	78.1	62	-0.01	
Y-1*	11/10/2022 9:45	0.1	1.0	20.3	78.6	62	-0.57	
Y-2*	11/10/2022 9:24	2.3	4.0	17	76.7	58	-0.48	
Y-3*	11/10/2022 9:20	0	0.1	22.3	77.6	59	-33.73	
Y-4*	11/10/2022 9:16	0.9	1.1	21	77.0	57	-0.61	
Y-5*	11/10/2022 9:30	0.1	1.6	18.8	79.5	57	-0.04	
Y-6*	11/10/2022 9:35	0.2	0.3	21.9	77.6	61	-0.94	

## MICHAELS

Permit Well ID	Date/Time	%CH4 by Vol.	%CO2 by Vol.	%O2 by Vol.	%Bal. by Vol.	Wellhead Temp. °F	Initial Vacuum (inches of water column)	Adjusted Vacuum (inches of water column)
B-20*	11/2/2022 7:48	0.2	0.7	21.4	77.7	45	-0.01	
B-24*	11/2/2022 7:56	11.6	7.0	18.3	63.1	47	-0.01	
MPHZ*	11/2/2022 7:43	18.7	22.6	0	58.7	47	-0.01	

## BACK NINE

Permit Well ID	Date/Time	%CH4 by Vol.	%CO2 by Vol.	%O2 by Vol.	%Bal. by Vol.	Wellhead Temp. °F	Initial Vacuum (inches of water column)	Adjusted Vacuum (inches of water column)
WA-10	11/14/2022 9:22	48.5	28.4	4.5	18.6	55	-1.39	
WA-11	11/14/2022 9:38	60.2	36.2	0.3	3.3	51	-0.4	
WA-12R	11/14/2022 9:45	59.2	40.3	0	0.5	50	-12.98	
WA-13*	11/14/2022 9:26	61.4	37.8	0	0.8	52	-11.14	
WA-14*	11/14/2022 9:57	0.1	2.0	19.1	78.8	53	-0.03	
WA-15R*	11/14/2022 10:04	41.6	21.0	8.3	29.1	60	-0.12	
WA-16*	11/14/2022 10:15	58.3	40.2	0	1.5	62	-2.45	
WA-17	11/14/2022 10:12	56.5	39.5	0.7	3.3	60	-0.66	
WA-18*	11/14/2022 10:28	31.5	15.2	11	42.3	54	-14.38	
WA-19*	11/14/2022 10:36	32.1	21.4	7.6	38.9	63	-0.01	
WA-1R*	11/14/2022 8:07	56.5	38.8	0.8	3.9	48	-1.45	
WA-2*	11/14/2022 8:13	63.6	30.3	0.9	5.2	47	-41.84	
WA-20*	11/14/2022 10:43	60.5	37.7	0.1	1.7	64	-1.16	
WA-21R*	11/14/2022 12:18	16	21.9	2.9	59.2	73	-0.52	

\* - Alternative oxygen wellhead limit

\*\* - Alternate temperature wellhead limit

Permit Well ID	Date/Time	%CH4 by Vol.	%CO2 by Vol.	%O2 by Vol.	%Bal. by Vol.	Wellhead Temp. °F	Initial Vacuum (inches of water column)	Adjusted Vacuum (inches of water column)
WA-22R*	11/14/2022 12:26	33.4	27.6	3.4	35.6	69	-1.2	
WA-23R*	11/14/2022 12:30	56.5	37.4	0	6.1	65	-3.08	
WA-24*	11/14/2022 12:43	57.6	35.6	1.2	5.6	60	-4.95	
WA-25*	11/14/2022 12:47	50.1	31.2	3.7	15.0	67	-0.07	
WA-26*	11/14/2022 12:57	56.4	38.6	0.8	4.2	64	-4.45	
WA-27*	11/14/2022 13:01	50.8	32.0	3.5	13.7	65	-19.03	
WA-28*	11/14/2022 13:06	52.6	39.6	0	7.8	60	-2.32	
WA-29*	11/14/2022 13:11	26.9	29.4	0	43.7	69	-2.74	
WA-4	11/14/2022 8:19	63.7	33.8	0	2.5	49	-0.36	
WA-5*	11/14/2022 8:38	40.8	23.8	7.6	27.8	51	-1.18	
WA-6*	11/14/2022 8:33	14.6	11.6	14.5	59.3	52	-11.2	
WA-7	11/14/2022 9:14	64.6	34.4	0	1.0	58	-0.1	
WA-8*	11/14/2022 9:09	0	0.1	22.3	77.6	50	-0.11	
WA-9*	11/14/2022 8:44	51.8	34.1	3	11.1	49	-6.39	
WB-1*	11/15/2022 10:07	61.9	36.2	0	1.9	66	-0.81	
WB-10R*	11/15/2022 8:39	44.2	24.6	6.9	24.3	62	-1.38	
WB-11*	11/15/2022 8:31	62.4	28.1	2.3	7.2	51	-7.16	
WB-12AR*	11/15/2022 7:46	43.8	34.8	0.1	21.3	47	-0.72	
WB-12R*	11/15/2022 7:54	37.9	31.7	0.8	29.6	51	-4.35	
WB-13R*	11/15/2022 7:39	28.8	30.3	0	40.9	46	-1.17	
WB-14R*	11/15/2022 7:36	46.6	34.1	0.8	18.5	46	-0.62	
WB-15R*	11/15/2022 7:29	54.6	38.8	0.7	5.9	46	-1.21	
WB-16R*	11/15/2022 7:27	21.8	25.9	1.3	51.0	46	-1.01	
WB-17R*	11/14/2022 12:35	20.4	26.5	0.2	52.9	62	-0.69	
WB-2*	11/15/2022 10:01	7.9	5.5	17.4	69.2	64	-6.8	
WB-3*	11/15/2022 9:49	48.9	29.8	1.5	19.8	65	-0.29	
WB-4*	11/15/2022 9:44	46.9	16.1	8.9	28.1	62	-1.72	
WB-5A*	11/15/2022 9:22	38.3	25.6	0	36.1	69	-0.73	
WB-5R*	11/15/2022 9:18	42.2	28.1	0.4	29.3	65	-3.24	
WB-6*	11/15/2022 9:09	56.7	39.2	0	4.1	63	-0.1	
WB-6A*	11/15/2022 9:12	44.2	32.0	0.4	23.4	63	-2.29	
WB-7*	11/15/2022 9:01	54	29.2	2.9	13.9	63	-3.46	
WB-7A*	11/15/2022 9:05	7.8	4.4	20.2	67.6	60	-0.04	
WB-8*	11/15/2022 8:56	60	37.3	0.2	2.5	59	-22.11	
WB-9*	11/15/2022 8:48	38.5	22.6	7.2	31.7	53	-4.96	
WC-1	11/15/2022 10:14	64.2	32.9	0.1	2.8	61	-17.65	
WC-2	11/15/2022 10:27	54.1	29.3	3.3	13.3	65	-6.37	
WC-3	11/15/2022 10:35	59.6	38.4	0.3	1.7	65	-6.52	
WC-4R	11/15/2022 10:39	52.1	28.7	1.8	17.4	66	-29.36	

\* - Alternative oxygen wellhead limit

\*\* - Alternate temperature wellehad limit

Permit Well ID	Date/Time	%CH4 by Vol.	%CO2 by Vol.	%O2 by Vol.	%Bal. by Vol.	Wellhead Temp. °F	Initial Vacuum (inches of water column)	Adjusted Vacuum (inches of water column)
WD-1	11/15/2022 12:52	65.4	34.4	0	0.2	68	-22.07	
WD-2	11/15/2022 12:44	68.4	29.1	0	2.5	66	-6.94	
WD-3*	11/15/2022 12:36	70.6	28.4	0	1.0	77	-11.48	
WD-4	11/15/2022 12:31	63.3	35.9	0	0.8	72	-1.49	
WE-1	11/15/2022 13:13	33.3	27.2	0	39.5	73	-27.01	
WE-1AR	11/15/2022 13:06	39.8	21.7	3.4	35.1	70	-33.02	
WE-2	11/15/2022 13:20	55.7	38.4	0	5.9	70	-1.2	
WE-3	11/15/2022 13:25	56.9	22.5	4	16.6	72	-3.93	
WE-4	11/15/2022 13:39	60.3	39.2	0	0.5	75	-20.67	
WE-5	11/15/2022 13:45	62.3	37.7	0	0.0	67	-6.58	
WF-1	11/15/2022 13:55	60	31.7	0.2	8.1	67	-6.81	
WF-2	11/15/2022 12:27	61.7	36.8	0	1.5	71	-0.68	
WN-10*	11/14/2022 13:39	58.2	40.6	0	1.2	68	-4.03	
WN-11*	11/14/2022 13:35	60.3	38.2	0	1.5	70	-3.61	
WN-12R*	11/14/2022 13:30	57.7	39.6	0.2	2.5	64	-0.45	
WN-13*	11/14/2022 13:20	1.3	1.8	19.8	77.1	60	-30.15	
WN-1R*	11/14/2022 14:45	46	32.5	1.9	19.6	70	-5.31	
WN-2R*	11/14/2022 14:40	62.5	35.2	0	2.3	65	-8.05	
WN-3R*	11/14/2022 14:33	53.2	30.8	2.1	13.9	62	-8.61	
WN-4*	11/14/2022 14:28	60.9	32.4	1	5.7	65	-38.26	
WN-4A*	11/14/2022 14:21	43.7	30.7	0	25.6	67	-34.8	
WN-5R*	11/14/2022 14:12	57.2	39.3	0	3.5	70	-7.45	
WN-6R*	11/14/2022 14:07	57.8	38.5	0.1	3.6	70	-1.75	
WN-7*	11/14/2022 14:01	54.4	38.9	0.9	5.8	70	-2.63	
WN-8R*	11/14/2022 13:57	37	30.3	1.1	31.6	66	-2.08	
WN-9R*	11/14/2022 13:48	58.1	39.1	0.1	2.7	69	-11.83	

## CRITTENDEN

Permit Well ID	Date/Time	%CH4 by Vol.	%CO2 by Vol.	%O2 by Vol.	%Bal. by Vol.	Wellhead Temp. °F	Initial Vacuum (inches of water column)	Adjusted Vacuum (inches of water column)
CRA-10*	11/7/2022 10:05	63.5	35.3	0	1.2	68	-0.03	
CRA-11	11/7/2022 10:25	60.2	38.4	0	1.4	69	-0.05	
CRA-12	11/7/2022 10:18	60.7	37.5	0	1.8	68	-0.08	
CRA-13*	11/7/2022 10:13	59.7	39.5	0	0.8	70	-0.09	
CRA-1R*	11/7/2022 8:55	59.4	37.7	0	2.9	67	-0.17	
CRA-2R*	11/7/2022 9:03	32.7	23.9	7.4	36	62	-0.01	
CRA-3*	11/7/2022 9:15	59.1	38.4	0	2.5	62	-0.14	

\* - Alternative oxygen wellhead limit

\*\* - Alternate temperature wellehad limit

Permit Well ID	Date/Time	%CH4 by Vol.	%CO2 by Vol.	%O2 by Vol.	%Bal. by Vol.	Wellhead Temp. °F	Initial Vacuum (inches of water column)	Adjusted Vacuum (inches of water column)
CRA-4*	11/7/2022 9:22	55.3	33.2	1.4	10.1	63	-0.09	
CRA-5R*	11/7/2022 9:30	38.6	30.3	0	31.1	66	-0.01	
CRA-6*	11/7/2022 9:36	52.3	31.6	0	16.1	61	-0.1	
CRA-7R*	11/7/2022 9:42	47.5	33.2	0	19.3	63	-0.01	
CRA-8*	11/7/2022 9:47	60.7	38.2	0	1.1	64	-0.05	
CRA-9*	11/7/2022 9:52	55.6	34.3	0.1	10	60	-0.03	
CRB-1R*	11/7/2022 10:37	53.7	32.8	2.3	11.2	66	-0.03	
CRB-2R*	11/7/2022 13:07	60.1	36	0	3.9	69	-2.39	
CRB-3*	11/7/2022 13:15	58.3	34.7	0	7	70	-1.32	
CRB-4R*	11/7/2022 13:18	58.4	35.6	0	6	67	-1.43	
CRB-5*	11/7/2022 13:22	20.6	11.8	8.6	59	68	-0.31	
CRB-6*	11/7/2022 13:33	44.6	19.9	0	35.5	66	-0.11	
CRB-7R*	11/7/2022 13:41	59.9	32.3	0	7.8	64	-2.43	
CRB-8*	11/7/2022 13:48	4.7	11.8	12.1	71.4	69	-2.45	
CRC-1	11/7/2022 13:44	53.5	27.6	1.9	17	70	-2.34	
CRC-2	11/7/2022 13:28	63.4	32.2	0	4.4	67	-1.51	
CRC-3	11/7/2022 13:11	64	34.8	0	1.2	72	-0.71	
CRC-4	11/7/2022 10:44	59.7	37.5	0	2.8	63	-0.02	
CRD-1*	11/7/2022 13:55	60.1	35.2	0.1	4.6	68	-2.65	
CRD-10*	11/7/2022 14:44	52	28.9	0	19.1	62	-2.17	
CRD-11*	11/7/2022 14:51	10.7	8.2	12.4	68.7	65	-0.77	
CRD-2	11/7/2022 13:59	61.7	33	0	5.3	69	-1.06	
CRD-3*	11/7/2022 14:03	60.3	38	0	1.7	67	-2.49	
CRD-4	11/7/2022 14:08	62.3	35.5	0	2.2	67	-2.27	
CRD-5*	11/7/2022 14:13	42.3	19.8	8.1	29.8	62	-1.06	
CRD-6	11/7/2022 14:18	56.1	28.7	2.8	12.4	62	-1.81	
CRD-7	11/7/2022 14:28	21.3	18.5	3.5	71	65	-0.28	
CRD-8R*	11/7/2022 14:32	61.9	33	0	5.1	63	-2.27	
CRD-9*	11/7/2022 14:38	35.9	24.3	6.2	33.6	60	-2.22	

## 6ANE

Permit Well ID	Date/Time	%CH4 by Vol.	%CO2 by Vol.	%O2 by Vol.	%Bal. by Vol.	Wellhead Temp. °F	Initial Vacuum (inches of water column)	Adjusted Vacuum (inches of water column)
NEA-1*	11/17/2022 7:57	50.3	32.9	1.2	15.6	47	-0.36	
NEA-10	11/17/2022 8:47	55.5	38.7	0	5.8	52	-6.12	
NEA-11*	11/17/2022 8:51	47	35.1	0	17.9	54	-4.22	
NEA-12	11/17/2022 8:56	43	30.7	4.2	20.7	51	-1.54	

\* - Alternative oxygen wellhead limit

\*\* - Alternate temperature wellehad limit

Permit Well ID	Date/Time	%CH4 by Vol.	%CO2 by Vol.	%O2 by Vol.	%Bal. by Vol.	Wellhead Temp. °F	Initial Vacuum (inches of water column)	Adjusted Vacuum (inches of water column)
NEA-13*	11/17/2022 9:15	60.5	39.5	0	0.0	52	-1	
NEA-14	11/17/2022 9:21	50.7	32.9	3	13.4	53	-38.74	
NEA-15*	11/17/2022 9:24	59.6	40.4	0	0.0	53	-39.2	
NEA-16A*	11/17/2022 9:29	58.7	40.5	0	0.8	52	-39.38	
NEA-2R*	11/17/2022 8:01	20.7	13.4	13.9	52.0	54	-22.69	
NEA-3*	11/17/2022 8:06	66.1	33.9	0	0.0	54	-2.85	
NEA-4*	11/17/2022 8:11	50.7	32.9	3.5	12.9	55	-4.12	
NEA-5R*	11/17/2022 8:20	35.5	24.5	6.6	33.4	53	-0.76	
NEA-6*	11/17/2022 8:27	17.3	21.4	1.9	59.4	53	-0.26	
NEA-7*	11/17/2022 8:31	60	40.0	0	0.0	50	-0.21	
NEA-8*-**	11/17/2022 8:36	47.1	35.2	1.4	16.3	51	-4.53	
NEA-9*	11/17/2022 8:43	59.1	40.9	0	0.0	53	-2.54	
NEB-1*	11/17/2022 9:47	2.4	2.1	20.8	74.7	56	-18.94	
NEB-10*	11/17/2022 10:38	46.7	37.3	0	16.0	58	-1.66	
NEB-11*	11/17/2022 10:45	56.4	39.3	0	4.3	63	-0.95	
NEB-12*	11/17/2022 10:49	46.8	36.8	0	16.4	60	-0.74	
NEB-13*	11/17/2022 10:57	43.8	35.2	0	21.0	62	-0.05	
NEB-14R*	11/17/2022 11:02	34.6	30.6	1	33.8	55	-0.23	
NEB-2*	11/17/2022 9:51	0.1	0.3	22.4	77.2	54	-38.83	
NEB-3*	11/17/2022 9:56	60.1	39.7	0	0.2	63	-0.27	
NEB-4*	11/17/2022 10:01	0.8	1.1	21.5	76.6	61	-0.2	
NEB-5*	11/17/2022 10:05	30.2	28.4	0	41.4	63	-0.01	
NEB-6*	11/17/2022 10:09	53.4	39.1	0	7.5	64	-1.41	
NEB-7*	11/17/2022 10:15	42.3	34.8	0	22.9	58	-0.68	
NEB-8*	11/17/2022 10:21	51.9	37.6	0	10.5	54	-0.3	
NEB-9	11/17/2022 10:26	42	34.9	0	23.1	55	-0.46	
NEC-1*	11/17/2022 11:54	46.7	36.4	0	16.9	61	-0.05	
NEC-2*	11/17/2022 11:59	54.4	37.6	0	8.0	67	-0.08	
NEC-3*	11/17/2022 12:03	43.6	34.8	0	21.6	69	-2.5	
NED-1R*	11/17/2022 12:12	39.2	34.3	0	26.5	65	-0.05	
NED-2	11/17/2022 12:18	59.8	40.2	0	0.0	66	-0.25	
NED-3	11/17/2022 12:26	40.1	29.4	0	30.5	67	-0.9	
NEE-1	11/17/2022 12:30	59.8	40.2	0	0.0	67	-15.2	
NEE-2R*	11/17/2022 12:37	26.5	20.2	11.2	42.1	68	-25.87	
NEE-3*	11/17/2022 12:41	26.7	24.9	3.3	45.1	64	-0.08	
NEE-4*	11/17/2022 12:48	61.1	34.5	0.5	3.9	68	-27.97	
NEE-5*	11/17/2022 13:02	41.9	31.9	0	26.2	70	-0.29	
NEE-6*	11/17/2022 13:06	42.5	34.8	0	22.7	66	-4.65	

\* - Alternative oxygen wellhead limit

\*\* - Alternate temperature wellehad limit

**CITY OF MOUNTAIN VIEW**  
**MONTHLY LANDFILL GAS WELL HEAD MONITORING**

December 2022

<b>VISTA</b>								
Permit Well ID	Date/Time	%CH4 by Vol.	%CO2 by Vol.	%O2 by Vol.	%Bal. by Vol.	Wellhead Temp. ° F	Initial Vacuum (inches of water column)	Adjusted Vacuum (inches of water column)
VA-1A*	12/1/2022 8:15	63.4	36.6	0	0.0	49	-2.22	
VA-1R*	12/1/2022 8:09	55.2	35.2	0	9.6	49	-0.42	
VA-2*	12/1/2022 8:20	64.3	32.4	0.4	2.9	49	-1.5	
VA-3A*	12/1/2022 8:29	69.5	30.5	0	0.0	50	-0.54	
VA-3R*	12/1/2022 8:25	66.1	31.5	0	2.4	49	-2.88	
VA-4*	12/1/2022 8:35	56.5	28.7	2.5	12.3	48	-3.95	
VA-5R	12/1/2022 8:51	36.9	14.0	4.1	38.2	48	-26.13	
VA-6	12/1/2022 9:07	63.2	18.2	3.9	14.7	38	-38.74	
VA-HZ*	12/1/2022 8:45	29.1	25.5	1.4	44.0	49	-0.22	
VB-1*	12/1/2022 9:45	57.6	34.8	1	6.6	48	-9.88	
VB-2R*	12/1/2022 9:55	62	27.1	0	10.9	50	-0.57	
VB-3	12/1/2022 10:05	58.1	35.9	0	6.0	50	-38.37	
VB-3A*	12/1/2022 10:22	43.1	22.8	6.6	27.5	50	-13.58	
VB-4*	12/1/2022 10:25	41.1	31.4	0	27.5	51	-16.48	
VB-5A*	12/1/2022 10:41	54.1	34.7	0.2	11.0	54	-1.34	
VB-5R*	12/1/2022 10:37	44.6	28.7	0	26.7	52	-2.3	
VB-6R*	12/1/2022 10:44	34.5	30.0	0.5	35.0	55	-1.61	
VB-7*	12/1/2022 10:48	49.1	36.9	0	14.0	55	-2.31	
VB-8*	12/1/2022 12:05	58.8	40.2	0	1.0	56	-0.07	
VB-9R	12/1/2022 10:54	36.2	32.1	0	31.7	55	-0.22	
VC-10	12/1/2022 13:04	44.2	33.8	0	22.0	63	-25.28	
VC-1R*	12/1/2022 11:03	9.3	10.1	14.8	65.8	59	-0.33	
VC-2R*	12/1/2022 12:22	12.5	21.3	0.6	65.6	58	-3.18	
VC-3*	12/1/2022 12:25	44.4	18.7	6.6	30.3	59	-11.52	
VC-4	12/1/2022 12:30	37.7	31.5	0	30.8	59	-0.23	
VC-5*	12/1/2022 12:39	49.4	24.8	0.3	25.5	59	-0.43	
VC-6*	12/1/2022 12:44	34.9	13.6	10.6	40.9	61	-23.75	
VC-7*	12/1/2022 12:52	55.3	37.1	0.1	7.5	61	-4.33	
VC-8*	12/1/2022 12:54	54.9	30.0	1.1	14.0	60	-34.28	
VE-10*	12/22/2022 8:42	0.6	1.7	19.5	78.2	49	-0.06	
VE-11	12/22/2022 8:47	51.2	34.6	0.1	14.1	50	-15.05	

\* - Alternative oxygen wellhead limit

\*\* - Alternate temperature wellehad limit

Permit Well ID	Date/Time	%CH4 by Vol.	%CO2 by Vol.	%O2 by Vol.	%Bal. by Vol.	Wellhead Temp. °F	Initial Vacuum (inches of water column)	Adjusted Vacuum (inches of water column)
VE-1R*	12/1/2022 13:18	37.3	26.9	2.3	33.5	64	-0.83	
VE-3	12/1/2022 13:15	50.8	38.3	0	10.9	61	-10.84	
VE-4R*	12/22/2022 8:15	36.6	31.7	0	31.7	49	-0.97	
VE-5*	12/22/2022 8:20	38.5	30.2	0	31.3	54	-0.88	
VE-6*-**	12/22/2022 8:23	28.5	28.6	0	42.9	55	-0.6	
VE-7*	12/22/2022 8:30	0.1	0.2	21.9	77.8	50	-0.03	
VE-8*	12/22/2022 8:34	14.9	21.1	1.2	62.8	51	-1.05	
VE-9*-**	12/22/2022 8:38	50.4	30.0	0.6	19.0	50	-0.41	
VF-1*	12/22/2022 9:11	5.7	9.4	10.6	74.3	49	-0.05	
VF-10	12/22/2022 9:54	49.4	30.0	4.2	16.4	51	-28.55	
VF-11**	12/22/2022 9:58	46.5	34.6	0	18.9	51	-30.46	
VF-2*	12/22/2022 9:15	26.5	17.0	6.4	50.1	49	-0.06	
VF-3**	12/22/2022 9:19	60	35.8	0	4.2	49	-4.88	
VF-4*	12/22/2022 9:24	14.7	9.8	13.8	61.7	49	-0.07	
VF-5R*	12/22/2022 9:30	45	29.4	0	25.6	50	-0.42	
VF-6	12/22/2022 9:33	42.8	35.6	0	21.6	49	-0.18	
VF-7*	12/22/2022 9:41	19.5	9.8	15.9	54.8	50	-1.46	
VF-7A	12/22/2022 9:38	63.1	36.9	0	0.0	49	-0.36	
VF-8R*	12/22/2022 9:44	58.7	33.0	1	7.3	80	-6.49	
VF-9	12/22/2022 9:47	56.6	40.6	0	2.8	51	-0.38	
VG-1	12/22/2022 10:17	39.3	29.8	3.8	27.1	56	-5.09	
VG-1A	12/22/2022 10:14	48.9	32.3	0	18.8	56	-3.51	
VG-2R	12/22/2022 10:21	48.6	26.2	3.4	21.8	57	-33.71	
VG-3**	12/22/2022 10:28	54.3	37.2	0	8.5	55	-2.88	
VG-3AR**	12/22/2022 10:24	56.6	38.2	0	5.2	57	-3.38	
VG-4**	12/22/2022 10:39	54.5	40.2	0.3	5.0	52	-0.8	
VG-4A	12/22/2022 10:32	45.4	32.8	0.2	21.6	51	-23.48	
VG-5	12/22/2022 10:42	48.1	37.5	0	14.4	53	-1.61	
VG-6	12/22/2022 10:47	47.2	38.5	0	14.3	52	-0.13	
VH-1	12/22/2022 11:43	44.4	30.6	0	25.0	58	-1.57	
VH-10**	12/22/2022 12:27	49.5	34.6	0	15.9	60	-0.61	
VH-11	12/22/2022 12:34	26.3	28.0	0.2	45.5	59	-0.44	
VH-12	12/22/2022 12:31	53.1	35.8	1.3	9.8	60	-0.56	
VH-13	12/22/2022 12:40	41	35.7	0	23.3	62	-0.22	
VH-2	12/22/2022 10:56	17.2	25.2	0	57.6	51	-0.2	
VH-3*	12/22/2022 11:52	15	12.5	11.7	60.8	63	-0.12	
VH-4**	12/22/2022 10:52	37.4	29.3	4.5	28.8	54	-0.78	
VH-5**	12/22/2022 11:56	36.5	32.3	0	31.2	61	-0.92	
VH-6	12/22/2022 12:02	45.4	30.1	2.5	22.0	56	-10.88	

\* - Alternative oxygen wellhead limit

\*\* - Alternate temperature wellehad limit

Permit Well ID	Date/Time	%CH4 by Vol.	%CO2 by Vol.	%O2 by Vol.	%Bal. by Vol.	Wellhead Temp. °F	Initial Vacuum (inches of water column)	Adjusted Vacuum (inches of water column)
VH-7R	12/22/2022 12:16	48	33.3	1.5	17.2	59	-4.85	
VH-8	12/22/2022 12:20	47.6	36.1	0	16.3	63	-0.78	
VH-9	12/22/2022 12:23	47	33.3	0	19.7	60	-0.11	
VJ-10R*	12/22/2022 13:53	39.3	22.7	6	32.0	55	-3.83	
VJ-11R*	12/22/2022 13:50	10.6	6.3	17	66.1	55	-9.52	
VJ-1R	12/22/2022 13:03	35	29.4	0	35.6	61	-3.37	
VJ-2R*	12/22/2022 12:51	24.9	15.7	11.2	48.2	65	-13.63	
VJ-3R*-**	12/22/2022 12:55	60.1	29.1	2.2	8.6	64	-22.84	
VJ-4A*-**	12/22/2022 13:08	29.8	27.4	0	42.8	63	-4.96	
VJ-4R*-**	12/22/2022 13:17	39.9	30.9	0.4	28.8	64	-3.73	
VJ-5R*	12/22/2022 13:23	57.7	39.0	0	3.3	62	-33	
VJ-6R*	12/22/2022 13:27	63.2	35.3	0	1.5	61	-0.95	
VJ-7R*	12/22/2022 13:33	44.7	30.0	5.1	20.2	55	-14.22	
VJ-8*	12/22/2022 13:38	60	39.0	0	1.0	54	-4.33	
VJ-9R*	12/22/2022 13:47	35.6	20.2	8.8	35.4	55	-5.51	
VK-1R	12/22/2022 14:00	55.6	35.1	0	9.3	55	-22.04	
VK-2R	12/22/2022 14:03	66	33.0	0	1.0	58	-6.18	
VK-3R*	12/22/2022 14:13	12.6	7.1	17.4	62.9	58	-14.85	
VK-4*	12/22/2022 14:10	0.8	0.7	21.7	76.8	60	-21.45	
VK-5*	12/22/2022 14:07	62.2	37.5	0	0.3	55	-2.11	

## FRONT NINE

Permit Well ID	Date/Time	%CH4 by Vol.	%CO2 by Vol.	%O2 by Vol.	%Bal. by Vol.	Wellhead Temp. °F	Initial Vacuum (inches of water column)	Adjusted Vacuum (inches of water column)
A-16*	12/20/2022 10:32	0.2	0.1	22.1	77.6	58	-32.7	
A-5	12/20/2022 7:21	54.1	35.1	2.1	8.7	49	-1.98	
B-12	12/20/2022 10:16	37.5	25.6	3.5	30.2	61	-14.82	
B-2*	12/20/2022 8:40	0	0.0	23.6	76.4	46	-0.2	
B-28*	12/20/2022 7:35	0.1	0.4	21.6	77.9	48	-1.47	
B-3R*	12/20/2022 8:54	34.7	18.1	5.3	41.9	44	-1.88	
B-4R*	12/20/2022 8:59	54.7	32.9	0	12.4	46	-0.02	
FHZ-1*	12/20/2022 9:59	12.7	8.6	18.4	60.3	50	-0.03	
FHZ-2*	12/20/2022 10:02	58.6	41.4	0	0.0	53	-0.1	
FHZ-3*	12/20/2022 10:08	19.1	27.5	2.8	50.6	55	-0.01	
FHZ-4*	12/20/2022 10:28	39.4	29.6	0	31.0	59	-0.45	
FHZ-5*	12/20/2022 10:38	52.2	35.5	0	12.3	62	-0.51	
LE-1*	12/20/2022 7:50	10.1	19.7	0.5	69.7	42	-0.02	

\* - Alternative oxygen wellhead limit

\*\* - Alternate temperature wellehad limit

Permit Well ID	Date/Time	%CH4 by Vol.	%CO2 by Vol.	%O2 by Vol.	%Bal. by Vol.	Wellhead Temp. °F	Initial Vacuum (inches of water column)	Adjusted Vacuum (inches of water column)
LE-2*	12/20/2022 8:29	0	0.9	19.6	79.5	44	-0.18	
LE-3*	12/20/2022 8:34	0	0.5	22.5	77.0	44	-0.03	
LE-4*	12/20/2022 9:04	0.4	2.0	19.5	78.1	48	-0.01	
Y-1*	12/20/2022 7:42	0.2	0.6	21.4	77.8	43	-1.7	
Y-2*	12/20/2022 8:16	2.2	17.5	3.7	76.6	45	-0.01	
Y-3*	12/20/2022 8:19	0	0.0	23.5	76.5	44	-0.03	
Y-4*	12/20/2022 8:22	1.5	2.0	19.8	76.7	44	-0.46	
Y-5*	12/20/2022 7:59	0.1	0.9	19.2	79.8	45	-0.08	
Y-6*	12/20/2022 7:54	0	0.0	23.2	76.8	42	-1.49	

## MICHAELS

Permit Well ID	Date/Time	%CH4 by Vol.	%CO2 by Vol.	%O2 by Vol.	%Bal. by Vol.	Wellhead Temp. °F	Initial Vacuum (inches of water column)	Adjusted Vacuum (inches of water column)
B-20*	12/19/2022 8:49	0	0.6	21.2	78.2	40	-26.73	
B-24*	12/19/2022 8:54	7.1	2.7	20.4	69.8	41	-36.90	
MPHZ*	12/19/2022 8:43	3.7	9.6	9.9	76.8	42	-0.19	

## BACK NINE

Permit Well ID	Date/Time	%CH4 by Vol.	%CO2 by Vol.	%O2 by Vol.	%Bal. by Vol.	Wellhead Temp. °F	Initial Vacuum (inches of water column)	Adjusted Vacuum (inches of water column)
WA-10	12/28/2022 10:14	54.1	31.9	2.5	11.5	54	-0.3	
WA-11	12/28/2022 10:22	59.8	39.8	0	0.4	57	-0.57	
WA-12R	12/28/2022 10:38	58	42.0	0	0.0	54	-0.19	
WA-13*	12/28/2022 12:16	61.4	38.6	0	0.0	58	-8.12	
WA-14*	12/28/2022 12:29	0	0.0	23	77.0	59	-0.13	
WA-15R*	12/28/2022 12:41	64.3	35.5	0.1	0.1	58	-0.19	
WA-16*	12/28/2022 12:45	61.5	38.4	0	0.1	56	-9.6	
WA-17	12/28/2022 12:48	0.1	0.2	22	77.7	62	-15.92	
WA-18*	12/28/2022 12:54	66	31.3	0.4	2.3	59	-1.87	
WA-19*	12/28/2022 13:07	0.2	0.0	21.7	78.1	58	-0.2	
WA-1R*	12/28/2022 8:13	55.2	39.2	1.1	4.5	42	-5.08	
WA-2*	12/28/2022 8:36	66.2	33.8	0	0.0	46	-40.56	
WA-20*	12/28/2022 13:13	60.9	38.3	0	0.8	64	-3.68	
WA-21R*	12/28/2022 13:25	28	26.6	1.3	44.1	64	-1.17	

\* - Alternative oxygen wellhead limit

\*\* - Alternate temperature wellhead limit

Permit Well ID	Date/Time	%CH4 by Vol.	%CO2 by Vol.	%O2 by Vol.	%Bal. by Vol.	Wellhead Temp. °F	Initial Vacuum (inches of water column)	Adjusted Vacuum (inches of water column)
WA-22R*	12/28/2022 13:38	35.3	28.7	3.2	32.8	57	-0.55	
WA-23R*	12/28/2022 13:41	55.7	39.6	0	4.7	58	-2.11	
WA-24*	12/28/2022 13:57	61.5	38.5	0	0.0	58	-1.08	
WA-25*	12/28/2022 14:04	59.7	40.3	0	0.0	59	-0.02	
WA-26*	12/28/2022 14:26	58.7	41.0	0	0.3	58	-0.06	
WA-27*	12/28/2022 14:35	61	38.7	0	0.3	59	-4.57	
WA-28*	12/28/2022 14:43	57.9	41.7	0	0.4	60	-0.42	
WA-29*	12/28/2022 14:45	53.9	40.6	0	5.5	60	-0.74	
WA-4	12/28/2022 8:55	63	32.3	0.8	3.9	45	-0.19	
WA-5*	12/28/2022 9:35	41.7	25.5	8.3	24.5	48	-31.64	
WA-6*	12/28/2022 9:15	58.5	41.5	0	0.0	43	-0.05	
WA-7	12/28/2022 9:46	63.8	36.0	0	0.2	51	-0.31	
WA-8*	12/28/2022 10:04	39.2	25.1	6.9	28.8	53	-0.1	
WA-9*	12/28/2022 10:10	57.8	39.7	0.5	2.0	55	-7.31	
WB-1*	12/13/2022 8:47	62.4	37.6	0	0.0	39	-0.78	
WB-10R*	12/13/2022 7:47	34.1	19.0	10.5	36.4	36	-2	
WB-11*	12/13/2022 7:42	39.2	21.4	9.5	29.9	35	-14.53	
WB-12AR*	12/13/2022 7:29	45.5	33.9	0.9	19.7	34	-0.77	
WB-12R*	12/13/2022 7:35	37.7	32.5	0.3	29.5	35	-4.66	
WB-13R*	12/13/2022 7:24	29.5	29.6	0	40.9	35	-1.42	
WB-14R*	12/13/2022 7:22	40.3	30.2	2.6	26.9	34	-0.77	
WB-15R*	12/13/2022 7:17	52.5	38.7	0.1	8.7	33	-1.47	
WB-16R*	12/13/2022 7:15	24.2	27.4	0	48.4	39	-1.28	
WB-17R*	12/28/2022 13:47	20.7	25.8	1	52.5	57	-0.35	
WB-2*	12/13/2022 8:42	0.3	3.2	17	79.5	46	-3.18	
WB-3*	12/13/2022 8:39	1.1	0.2	23.2	75.5	46	-5.39	
WB-4*	12/13/2022 8:33	53.5	19.2	6.6	20.7	46	-2.66	
WB-5A*	12/13/2022 8:21	52.4	28.4	0.1	19.1	38	-1.1	
WB-5R*	12/13/2022 8:17	39.4	28.5	0.7	31.4	43	-3.76	
WB-6*	12/13/2022 8:10	56	39.9	0.3	3.8	38	-0.11	
WB-6A*	12/13/2022 8:13	43.8	34.4	0	21.8	43	-2.39	
WB-7*	12/13/2022 8:02	16.4	9.3	17	57.3	39	-0.24	
WB-7A*	12/13/2022 8:05	3.4	1.3	22.6	72.7	37	-0.05	
WB-8*	12/13/2022 7:57	60.9	38.0	0.2	0.9	36	-21.96	
WB-9*	12/13/2022 7:51	52.8	30.3	2.8	14.1	38	-3.14	
WC-1	12/13/2022 8:54	64.9	33.6	0.3	1.2	37	-20.48	
WC-2	12/13/2022 9:04	39.5	21.6	3.1	29.3	35	-31.19	
WC-3	12/13/2022 9:08	25.4	16.4	4.6	44.6	33	-0.45	
WC-4R	12/13/2022 9:12	56.7	31.2	1.7	10.4	35	-28.25	

\* - Alternative oxygen wellhead limit

\*\* - Alternate temperature wellehad limit

Permit Well ID	Date/Time	%CH4 by Vol.	%CO2 by Vol.	%O2 by Vol.	%Bal. by Vol.	Wellhead Temp. °F	Initial Vacuum (inches of water column)	Adjusted Vacuum (inches of water column)
WD-1	12/13/2022 9:49	70.7	28.7	0	0.6	34	-30.4	
WD-2	12/13/2022 9:46	79.1	20.4	0	0.5	34	-3.45	
WD-3*	12/13/2022 9:39	83.3	15.3	0	1.4	41	-3.17	
WD-4	12/13/2022 9:36	67.2	32.3	0	0.5	39	-25.23	
WE-1	12/13/2022 9:57	43.9	29.3	0	26.8	32	-23.31	
WE-1AR	12/13/2022 9:53	65.5	24.9	0.6	9.0	32	-3.97	
WE-2	12/13/2022 10:02	59.4	40.0	0	0.6	35	-2.62	
WE-3	12/13/2022 10:06	34.5	16.1	4.7	38.2	36	-6.27	
WE-4	12/13/2022 10:13	59.9	39.5	0	0.6	35	-22.26	
WE-5	12/13/2022 10:18	57.6	36.9	0	5.5	39	-6.85	
WF-1	12/13/2022 10:21	62	38.0	0	0.0	39	-0.04	
WF-2	12/13/2022 10:25	60	36.6	0.2	3.2	40	-4.86	
WN-10*	12/29/2022 8:11	58.3	41.7	0	0.0	50	-4.01	
WN-11*	12/29/2022 8:06	59.9	40.1	0	0.0	50	-2.86	
WN-12R*	12/29/2022 8:01	58.9	41.1	0	0.0	50	-0.11	
WN-13*	12/29/2022 7:55	8.1	4.3	18.2	69.4	50	-13.73	
WN-1R*	12/29/2022 9:14	49.1	34.2	1.9	14.8	52	-6.75	
WN-2R*	12/29/2022 9:09	2.1	0.9	19.7	77.3	51	-35.93	
WN-3R*	12/29/2022 9:04	47.3	30.0	3.5	19.2	52	-8.63	
WN-4*	12/29/2022 8:59	63.5	35.9	0	0.6	51	-38.89	
WN-4A*	12/29/2022 8:53	50.5	32.7	0	16.8	52	-33.05	
WN-5R*	12/29/2022 8:48	59.2	40.8	0	0.0	51	-13.66	
WN-6R*	12/29/2022 8:42	59	39.2	0	1.8	51	-1.54	
WN-7*	12/29/2022 8:34	54.2	41.8	0	4.0	50	-0.25	
WN-8R*	12/29/2022 8:29	49.5	34.8	0	15.7	50	-3.46	
WN-9R*	12/29/2022 8:13	59	41.0	0	0.0	50	-13.18	

## CRITTENDEN

Permit Well ID	Date/Time	%CH4 by Vol.	%CO2 by Vol.	%O2 by Vol.	%Bal. by Vol.	Wellhead Temp. °F	Initial Vacuum (inches of water column)	Adjusted Vacuum (inches of water column)
CRA-10*	12/21/2022 8:37	41.1	29.6	1.6	27.7	44	-0.01	
CRA-11	12/21/2022 9:16	60.5	38.8	0	0.7	49	-0.13	
CRA-12	12/21/2022 8:52	61.8	37.3	0	0.9	47	-0.23	
CRA-13*	12/21/2022 8:47	57.8	39.1	0	3.1	44	-0.13	
CRA-1R*	12/20/2022 13:22	59.9	40.1	0	0	67	-0.02	
CRA-2R*	12/20/2022 13:29	43.1	39.1	0	17.8	61	-0.06	
CRA-3*	12/20/2022 13:50	57.9	42	0	0.1	61	-0.02	

\* - Alternative oxygen wellhead limit

\*\* - Alternate temperature wellehad limit

Permit Well ID	Date/Time	%CH4 by Vol.	%CO2 by Vol.	%O2 by Vol.	%Bal. by Vol.	Wellhead Temp. °F	Initial Vacuum (inches of water column)	Adjusted Vacuum (inches of water column)
CRA-4*	12/20/2022 14:02	34.9	23.8	8.8	32.5	69	-0.01	
CRA-5R*	12/20/2022 14:19	46.3	32.4	0.3	21	61	-0.07	
CRA-6*	12/21/2022 8:13	31.7	27.6	3.2	37.5	43	-1.38	
CRA-7R*	12/21/2022 8:19	27.4	27.4	0	45.2	42	-0.06	
CRA-8*	12/21/2022 8:26	56.4	34.2	0	9.4	40	-0.03	
CRA-9*	12/21/2022 8:30	0.3	0.3	23.5	75.9	40	-0.01	
CRB-1R*	12/21/2022 9:23	28.2	24.7	5.5	41.6	59	-0.11	
CRB-2R*	12/21/2022 11:54	50.2	34.9	0	14.9	61	-0.03	
CRB-3*	12/21/2022 12:01	53.2	32.1	0	14.7	70	-0.53	
CRB-4R*	12/21/2022 12:04	54.7	31.8	0	13.5	64	-0.01	
CRB-5*	12/21/2022 12:09	22.6	11.8	8.6	57	57	-0.06	
CRB-6*	12/21/2022 12:14	23.7	17.6	3.5	55.2	60	-0.01	
CRB-7R*	12/21/2022 12:24	62.4	34.9	0	2.7	57	-1.98	
CRB-8*	12/21/2022 12:34	12.5	14.5	7.5	65.5	59	-0.27	
CRC-1	12/21/2022 12:30	59.4	30.8	0	9.8	60	-0.14	
CRC-2	12/21/2022 12:21	64.6	32.9	0	2.5	59	-0.18	
CRC-3	12/21/2022 11:57	63.3	36.3	0	0.4	73	-0.01	
CRC-4	12/21/2022 11:49	49.3	32.5	0	18.2	72	-0.16	
CRD-1*	12/21/2022 12:42	57.8	36.6	0	5.6	65	-0.19	
CRD-10*	12/21/2022 13:27	56.2	29.9	0	13.9	62	-2.2	
CRD-11*	12/21/2022 13:31	26.1	17.2	9.8	46.9	59	-0.2	
CRD-2	12/21/2022 12:47	63.6	35.2	0	1.2	59	-1.8	
CRD-3*	12/21/2022 12:52	59.3	40.7	0	0	60	-0.21	
CRD-4	12/21/2022 12:55	61.8	38.2	0	0	61	-0.13	
CRD-5*	12/21/2022 13:02	67.1	32.9	0	0	61	-0.69	
CRD-6	12/21/2022 13:05	64.3	35	0	0.7	62	-6.54	
CRD-7	12/21/2022 13:11	43.1	30.9	0.8	25.2	60	-0.65	
CRD-8R*	12/21/2022 13:16	49.9	34.7	0	15.4	64	-0.6	
CRD-9*	12/21/2022 13:22	61	39	0	0	62	-0.74	

## 6ANE

Permit Well ID	Date/Time	%CH4 by Vol.	%CO2 by Vol.	%O2 by Vol.	%Bal. by Vol.	Wellhead Temp. °F	Initial Vacuum (inches of water column)	Adjusted Vacuum (inches of water column)
NEA-1*	12/15/2022 8:38	58.2	34.8	1.3	5.7	47	-0.32	
NEA-10	12/15/2022 9:45	54.6	39.9	0	5.5	50	-4.75	
NEA-11*	12/15/2022 9:50	48.4	38.2	0	13.4	50	-4.26	
NEA-12	12/15/2022 9:58	41.2	30.3	3.2	22.3	50	-1.63	

\* - Alternative oxygen wellhead limit

\*\* - Alternate temperature wellehad limit

Permit Well ID	Date/Time	%CH4 by Vol.	%CO2 by Vol.	%O2 by Vol.	%Bal. by Vol.	Wellhead Temp. °F	Initial Vacuum (inches of water column)	Adjusted Vacuum (inches of water column)
NEA-13*	12/15/2022 10:22	59.6	40.4	0	0.0	52	-1.11	
NEA-14	12/15/2022 10:37	53.2	34.9	2	9.9	50	-38.88	
NEA-15*	12/15/2022 10:44	58.8	41.2	0	0.0	55	-38.82	
NEA-16A*	12/15/2022 12:34	59.9	38.9	0.1	1.1	59	-38.68	
NEA-2R*	12/15/2022 8:45	1.9	1.2	20.7	76.2	46	-24.28	
NEA-3*	12/15/2022 8:51	65.1	34.3	0	0.6	45	-2.7	
NEA-4*	12/15/2022 9:01	47	31.4	4.9	16.7	49	-3.25	
NEA-5R*	12/15/2022 9:08	45.1	28.2	5.3	21.4	51	-0.68	
NEA-6*	12/15/2022 9:22	19.6	22.8	0.4	57.2	54	-0.21	
NEA-7*	12/15/2022 9:27	59.2	40.8	0	0.0	48	-0.19	
NEA-8*-**	12/15/2022 9:34	46.8	36.8	0.7	15.7	50	-3.44	
NEA-9*	12/15/2022 9:39	58.1	41.9	0	0.0	46	-1.77	
NEB-1*	12/15/2022 13:18	53.8	27.2	4.6	14.4	58	-15.13	
NEB-10*	12/15/2022 14:18	46.6	38.8	0	14.6	56	-1.38	
NEB-11*	12/15/2022 14:23	57	41.5	0	1.5	57	-7.89	
NEB-12*	12/15/2022 14:28	47.5	38.2	0	14.3	58	-0.49	
NEB-13*	12/15/2022 14:36	54.9	42.5	0	2.6	55	-0.05	
NEB-14R*	12/15/2022 14:40	42.8	36.3	0	20.9	56	-0.06	
NEB-2*	12/15/2022 13:26	2.3	1.4	18.8	77.5	63	-1.7	
NEB-3*	12/15/2022 13:33	59.6	40.4	0	0.0	65	-0.07	
NEB-4*	12/15/2022 13:41	48.5	29.8	3.7	18.0	60	-6.53	
NEB-5*	12/15/2022 13:47	28.8	27.9	0	43.3	60	-0.22	
NEB-6*	12/15/2022 13:52	52.9	40.6	0	6.5	59	-1.36	
NEB-7*	12/15/2022 13:58	43.4	37.2	0	19.4	57	-0.02	
NEB-8*	12/15/2022 14:08	53.2	39.8	0	7.0	62	-0.01	
NEB-9	12/15/2022 14:13	43.5	36.5	0	20.0	61	-0.37	
NEC-1*	12/15/2022 15:06	46.3	37.9	0.4	15.4	61	-8.64	
NEC-2*	12/15/2022 15:11	55.5	39.8	0	4.7	59	-0.09	
NEC-3*	12/15/2022 15:15	41.6	35.7	0	22.7	58	-0.13	
NED-1R*	12/15/2022 15:29	44.5	36.9	0	18.6	57	-0.01	
NED-2	12/15/2022 15:35	58.9	41.1	0	0.0	59	-0.11	
NED-3	12/15/2022 15:39	39.3	30.9	0	29.8	57	-1.97	
NEE-1	12/15/2022 15:43	58.4	41.6	0	0.0	55	-15.18	
NEE-2R*	12/15/2022 15:50	57.6	41.7	0	0.7	54	-26.83	
NEE-3*	12/15/2022 15:53	26.1	26.7	1.7	45.5	54	-0.18	
NEE-4*	12/15/2022 15:57	62.3	35.2	0	2.5	53	-25.86	
NEE-5*	12/15/2022 16:00	35.7	32.0	0	32.3	52	-0.37	
NEE-6*	12/15/2022 16:04	43	36.1	0	20.9	53	-4.8	

\* - Alternative oxygen wellhead limit

\*\* - Alternate temperature wellehad limit

## **SECTION VI**

**MONTHLY LANDFILL GAS WELLHEAD  
REPAIRS FOR EXCEEDENCES**

**OXYGEN AND METHANE CONCENTRATIONS  
AT THE MAIN HEADER**

**MONTHLY LANDFILL GAS WELLHEAD  
REPAIRS FOR EXCEEDENCES**

**CITY OF MOUNTAIN VIEW**  
**Monthly Landfill Gas Wellhead Repairs For Exceedances**  
**July 1 - December 31, 2022**

Date	Well I.D #	Exceedance Temperature (T) Oxygen (O <sub>2</sub> ) Vacuum (V)	Status Compliance within 5 days (yes/no)	Status Compliance within 15 days (yes/no)	Comments
There was no exceedance during this monitoring period					

**OXYGEN AND METHANE CONCETRATIONS  
AT THE MAIN HEADER**

**CITY OF MOUNTAIN VIEW**  
**SHORELINE LANDFILL, FACILITY ID A2740**  
**OXYGEN AND METHANE CONCENTRATIONS AT THE MAIN HEADER**  
**ON THE DAY OF WELLHEAD MONITORING**  
**July 1 - December 31, 2022**

Month	Name of Well Field Monitored	Monitoring Date	Main Header Reading *	
			O <sub>2</sub> %	CH <sub>4</sub> %
July	Back Nine	7/21/2022	< 5	> 35
		7/26/2022	< 5	> 35
		7/27/2022	< 5	> 35
		7/28/2022	< 5	> 35
	Cell 6ANE	7/19/2022	< 5	> 35
		7/20/2022	< 5	> 35
	Crittenden	7/25/2022	< 5	> 35
		7/13/2022	< 5	> 35
	Front Nine	7/14/2022	< 5	> 35
		7/19/2022	< 5	> 35
		7/13/2022	< 5	> 35
	Michaels	7/14/2022	< 5	> 35
		7/21/2022	< 5	> 35
		7/22/2022	< 5	> 35
August	Back Nine	8/17/2022	< 5	> 35
		8/18/2022	< 5	> 35
		8/19/2022	< 5	> 35
	Cell 6ANE	8/3/2022	< 5	> 35
		8/4/2022	< 5	> 35
	Crittenden	8/10/2022	< 5	> 35
		8/19/2022	< 5	> 35
	Front Nine	8/3/2022	< 5	> 35
		8/1/2022	< 5	> 35
		8/10/2022	< 5	> 35
	Michaels	8/11/2022	< 5	> 35
		8/18/2022	< 5	> 35
		8/19/2022	< 5	> 35
September	Back Nine	9/19/2022	< 5	> 35
		9/23/2022	< 5	> 35
		9/27/2022	< 5	> 35
	Cell 6ANE	9/9/2022	< 5	> 35
		9/14/2022	< 5	> 35
	Crittenden	9/19/2022	< 5	> 35
		9/9/2022	< 5	> 35
	Front Nine	9/12/2022	< 5	> 35
		9/9/2022	< 5	> 35
		9/8/2022	< 5	> 35
October	Back Nine	10/13/2022	< 5	> 35
		10/19/2022	< 5	> 35
		10/27/2022	< 5	> 35
	Cell 6ANE	10/20/2022	< 5	> 35
		10/12/2022	< 5	> 35
	Crittenden	10/6/2022	< 5	> 35
		10/4/2022	< 5	> 35
	Front Nine	10/6/2022	< 5	> 35
		10/13/2022	< 5	> 35
		10/13/2022	< 5	> 35
November	Back Nine	11/14/2022	< 5	> 35
		11/15/2022	< 5	> 35
	Cell 6ANE	11/17/2022	< 5	> 35
		11/7/2022	< 5	> 35
	Crittenden	11/10/2022	< 5	> 35
		11/2/2022	< 5	> 35

**CITY OF MOUNTAIN VIEW  
SHORELINE LANDFILL, FACILITY ID A2740  
OXYGEN AND METHANE CONCENTRATIONS AT THE MAIN HEADER  
ON THE DAY OF WELLHEAD MONITORING  
July 1 - December 31, 2022**

Month	Name of Well Field Monitored	Monitoring Date	Main Header Reading *	
			O <sub>2</sub> %	CH <sub>4</sub> %
Vista		11/2/2022	< 5	> 35
		11/3/2022	< 5	> 35
		11/10/2022	< 5	> 35
December	Back Nine	12/13/2022	< 5	> 35
		12/28/2022	< 5	> 35
		12/29/2022	< 5	> 35
	Cell 6ANE	12/15/2022	< 5	> 35
		12/20/2022	< 5	> 35
		12/21/2022	< 5	> 35
	Crittenden	12/20/2022	< 5	> 35
		12/19/2022	< 5	> 35
	Front Nine	12/1/2022	< 5	> 35
		12/22/2022	< 5	> 35
	Michaels	12/20/2022	< 5	> 35
		12/19/2022	< 5	> 35

\* Monitoring records are attached

**SSM PLAN REPORT FORM /  
FLARE STATION DAILY CHECKLIST**  
City of Mountain View Flare Station

Date 7-13-2022  
s m t w th f s

**AM MONITORING**

Name PAUL BANDA

Arrival Time 6:51 AM Departure Time 7:06 AM

GEM# ENVH2 Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>43.6</u>	<u>32.2</u>	<u>2.2</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1	<u>1634</u>	<u>3.66</u>	<u>132</u>
Flare #2	<u>1622</u>	<u>2.75</u>	<u>260</u>
Flare #3			

Blower Oper.	RPM	Hours
Blower #1	/	/
Blower #2	/	/
Blower #3	<u>2100</u>	<u>30031.4</u>

Air Compressor Hours: 9465.7

Google SCFM: am: 44 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>45.9</u>	<u>43.5</u>	<u>41.3</u>
CO2 %	<u>33.7</u>	<u>31.9</u>	<u>30.2</u>
O2 %	<u>1.7</u>	<u>0.7</u>	<u>4.5</u>
Vacuum	<u>-39.7</u>	<u>-39.0</u>	<u>-39.5</u>
SCFM	<u>153</u>	<u>146</u>	<u>124</u>
Temperature	<u>76</u>	<u>76</u>	<u>74</u>

Time of Shutdown:

Time of Start-Up:

Duration of Shutdown/Malfunction:

Reason for Shutdown/Malfunction:

- Air-Compressor System
- Blower
- High Gas Flow
- High Temperature
- LEL
- Low Gas Flow
- Low Temperature
- UV Scanner System
- Power Failure
- Scheduled Preventive Maintenance

**PM MONITORING**

Name \_\_\_\_\_

Arrival Time \_\_\_\_\_ Departure Time \_\_\_\_\_

GEM# \_\_\_\_\_ Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3			

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			

Back Up Generator Running yes / no

Control Room Bypass yes / no

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed isolating all LFG in the piping system to avoid excess emissions, and notified the staff.

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.

Comments and/or Description  
of Malfunction and Affected Equipment:

Time of Shutdown:

Time of Start-Up:

Duration of Shutdown/Malfunction:

Emission Exceedence: yes\* / no

SSM Plan Procedures Followed: yes / no\*

If SSM Plan Procedure not followed, explain procedure used:

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc. continued on the back side? yes / no

Signature

Date

**SSM PLAN REPORT FORM /  
FLARE STATION DAILY CHECKLIST**  
City of Mountain View Flare Station

Date 7-14-2022  
 s m t w **th** f s

**AM MONITORING**

Name RAUL DANOA

Arrival Time 6:28 AM Departure Time 6:39 AM

GEM# ENV HZ Manometer yes no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>44-6</u>	<u>32-4</u>	<u>1.9</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1	<u>1634</u>	<u>3.93</u>	<u>137</u>
Flare #2	<u>1622</u>	<u>2.98</u>	<u>274</u>
Flare #3	/	/	/

Blower Oper.	RPM	Hours
Blower #1	/	/
Blower #2	/	/
Blower #3	<u>2100</u>	<u>30055.0</u>

Air Compressor Hours: 9472.6

Google SCFM: am: 30 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>45.8</u>	<u>44.7</u>	<u>41.6</u>
CO2 %	<u>33.0</u>	<u>33.2</u>	<u>30.7</u>
O2 %	<u>1.6</u>	<u>0.6</u>	<u>3.7</u>
Vacuum	<u>-39.4</u>	<u>-39.0</u>	<u>-39.4</u>
SCFM	<u>154</u>	<u>147</u>	<u>120</u>
Temperature	<u>76</u>	<u>76</u>	<u>73</u>

Time of Shutdown:

Time of Start-Up:

Duration of Shutdown/Malfunction:

Reason for Shutdown/Malfunction:

- Air-Compressor System
- Blower
- High Gas Flow
- High Temperature
- LEL
- Low Gas Flow
- Low Temperature
- UV Scanner System
- Power Failure
- Scheduled Preventive Maintenance

**PM MONITORING**

Name \_\_\_\_\_

Arrival Time \_\_\_\_\_ Departure Time \_\_\_\_\_

GEM# \_\_\_\_\_ Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %
/	/	/

Flare Operation	Temp.	Vac.	SCFM
Flare #1	/	/	/
Flare #2	/	/	/
Flare #3	/	/	/

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum	/	/	/
SCFM	/	/	/

Back Up Generator Running yes / no

Control Room Bypass yes / no

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed isolating all LFG in the piping system to avoid excess emissions, and notified the staff.

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.

Comments and/or Description  
of Malfunction and Affected Equipment:

Time of Shutdown:

Time of Start-Up:

Duration of Shutdown/Malfunction:

Emission Exceedence: yes\* / no

SSM Plan Procedures Followed: yes / no\*

If SSM Plan Procedure not followed, explain procedure used:

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc. continued on the back side? yes / no

Signature

Date

**SSM PLAN REPORT FORM /  
FLARE STATION DAILY CHECKLIST**  
City of Mountain View Flare Station

Date July 19<sup>th</sup>, 2022  
 s m  w th f s

**AM MONITORING**

Name Jason R. Bean

Arrival Time 6:51am Departure Time 7:03am

GEM# Envisionity Manometer  yes / no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>43.9</u>	<u>31.0</u>	<u>22</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1	<u>1636</u>	<u>394"</u>	<u>137</u>
Flare #2	<u>1621</u>	<u>299"</u>	<u>275</u>
Flare #3			

Blower Oper.	RPM	Hours
Blower #1		
Blower #2		
Blower #3	<u>2100</u>	<u>30175.4</u>

Air Compressor Hours: 9507.5

Google SCFM: am: 30 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>45.7</u>	<u>45.0</u>	<u>40.4</u>
CO2 %	<u>33.5</u>	<u>31.7</u>	<u>28.7</u>
O2 %	<u>1.7</u>	<u>0.6</u>	<u>4.4</u>
Vacuum	<u>-39.6"</u>	<u>-38.9"</u>	<u>-39.6"</u>
SCFM	<u>154</u>	<u>148</u>	<u>122</u>
Temperature	<u>76</u>	<u>76</u>	<u>73</u>

Time of Shutdown:

Time of Start-Up:

Duration of Shutdown/Malfunction:

Reason for Shutdown/Malfunction:

- Air-Compressor System
- Blower
- High Gas Flow
- High Temperature
- LEL
- Low Gas Flow
- Low Temperature
- UV Scanner System
- Power Failure
- Scheduled Preventive Maintenance

**PM MONITORING**

Name \_\_\_\_\_

Arrival Time \_\_\_\_\_ Departure Time \_\_\_\_\_

GEM# \_\_\_\_\_ Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3			

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			

Back Up Generator Running yes / no

Control Room Bypass yes / no

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed isolating all LFG in the piping system to avoid excess emissions, and notified the staff.

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.

Comments and/or Description of Malfunction and Affected Equipment:

Time of Shutdown:

Time of Start-Up:

Duration of Shutdown/Malfunction:

Emission Exceedence: yes\* / no

SSM Plan Procedures Followed: yes / no\*

If SSM Plan Procedure not followed, explain procedure used:

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc. continued on the back side? yes / no

Signature

Date

**SSM PLAN REPORT FORM /  
FLARE STATION DAILY CHECKLIST**  
City of Mountain View Flare Station

Date 7-20-22  
s m t **w** th f s

**AM MONITORING**

Name LEON Rosales  
Arrival Time 7:45 am Departure Time 8:01 am  
GEM# 600 444 Manometer yes no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>43.7</u>	<u>31.0</u>	<u>2.2</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1	<u>1635</u>	<u>3.02"</u>	<u>139</u>
Flare #2	<u>1627</u>	<u>3.93"</u>	<u>273</u>
Flare #3			

Blower Oper.	RPM	Hours
Blower #1		
Blower #2		
Blower #3	<u>2100</u>	<u>30200.3</u>

Air Compressor Hours: 9514.8

Google SCFM: am: 29 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>46.2</u>	<u>44.4</u>	<u>39.5</u>
CO2 %	<u>32.7</u>	<u>31.2</u>	<u>27.5</u>
O2 %	<u>1.5</u>	<u>0.6</u>	<u>4.4</u>
Vacuum	<u>-39.7"</u>	<u>-38.9"</u>	<u>-39.7"</u>
SCFM	<u>155</u>	<u>150</u>	<u>132</u>
Temperature	<u>76</u>	<u>76</u>	<u>73</u>

Time of Shutdown:

Time of Start-Up:

Duration of Shutdown/Malfunction:

Reason for Shutdown/Malfunction:

- Air-Compressor System
- Blower
- High Gas Flow
- High Temperature
- LEL
- Low Gas Flow
- Low Temperature
- UV Scanner System
- Power Failure
- Scheduled Preventive Maintenance

**PM MONITORING**

Name \_\_\_\_\_  
Arrival Time \_\_\_\_\_ Departure Time \_\_\_\_\_  
GEM# \_\_\_\_\_ Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3			

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			

Back Up Generator Running yes / no

Control Room Bypass yes / no

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed isolating all LFG in the piping system to avoid excess emissions, and notified the staff.

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.

Comments and/or Description  
of Malfunction and Affected Equipment:

Time of Shutdown:

Time of Start-Up:

Duration of Shutdown/Malfunction:

Emission Exceedence: yes\* / no

SSM Plan Procedures Followed: yes / no\*

If SSM Plan Procedure not followed, explain procedure used:

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc. continued on the back side? yes / no

Signature

Date

**SSM PLAN REPORT FORM /  
FLARE STATION DAILY CHECKLIST**  
City of Mountain View Flare Station

Date July 21<sup>st</sup>, 2022  
 s m t w th f s

**AM MONITORING**

Name Jason R. Bean  
 Arrival Time 7:42pm Departure Time 7:53pm  
 GEM# ENVISION #4 Manometer (yes) no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>44.4</u>	<u>31.5</u>	<u>21</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1	<u>1617</u>	<u>3.91"</u>	<u>138</u>
Flare #2	<u>1613</u>	<u>2.98"</u>	<u>275</u>
Flare #3			

Blower Oper.	RPM	Hours
Blower #1		
Blower #2		
Blower #3	<u>2100</u>	<u>3024.2</u>

Air Compressor Hours: 9521.7

Google SCFM: am: 29 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>46.9</u>	<u>45.0</u>	<u>40.4</u>
CO2 %	<u>33.0</u>	<u>31.6</u>	<u>28.0</u>
O2 %	<u>1.2</u>	<u>0.5</u>	<u>4.4</u>
Vacuum	<u>-39.6"</u>	<u>-38.9"</u>	<u>-39.6 "</u>
SCFM	<u>153</u>	<u>151</u>	<u>129</u>
Temperature	<u>76</u>	<u>77</u>	<u>74</u>

Time of Shutdown:
Time of Start-Up:
Duration of Shutdown/Malfunction:

Reason for Shutdown/Malfunction:

- Air-Compressor System
- Blower
- High Gas Flow
- High Temperature
- LEL
- Low Gas Flow
- Low Temperature
- UV Scanner System
- Power Failure
- Scheduled Preventive Maintenance

**PM MONITORING**

Name \_\_\_\_\_  
 Arrival Time \_\_\_\_\_ Departure Time \_\_\_\_\_  
 GEM# \_\_\_\_\_ Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3			

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			

Back Up Generator Running yes / no

Control Room Bypass yes / no

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed isolating all LFG in the piping system to avoid excess emissions, and notified the staff.

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.

Comments and/or Description of Malfunction and Affected Equipment:

Emission Exceedence: yes\* / no

SSM Plan Procedures Followed: yes / no\*

If SSM Plan Procedure not followed, explain procedure used:

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc. continued on the back side? yes / no

Signature

Date

**SSM PLAN REPORT FORM /  
FLARE STATION DAILY CHECKLIST**  
City of Mountain View Flare Station

Date July 22<sup>nd</sup>, 2022  
s m t w th f s

**AM MONITORING**

Name Adrian Vega  
Arrival Time 6:49 AM Departure Time 7:13 AM  
GEM# ENVISION #4 Manometer (yes) no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>44.7</u>	<u>32.3</u>	<u>2.1</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1	<u>1621</u>	<u>3.32"</u>	<u>127</u>
Flare #2	<u>1626</u>	<u>2.53"</u>	<u>251</u>
Flare #3			

Blower Oper.	RPM	Hours
Blower #1		
Blower #2		
Blower #3	<u>2100</u>	<u>30247.4</u>

Air Compressor Hours: 9528.4

Google SCFM: am: 31 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>46.7</u>	<u>44.9</u>	<u>41.5</u>
CO2 %	<u>34.2</u>	<u>32.1</u>	<u>29.1</u>
O2 %	<u>1.5</u>	<u>0.8</u>	<u>4.5</u>
Vacuum	<u>-40.1"</u>	<u>-39.1"</u>	<u>-39.9"</u>
SCFM	<u>150</u>	<u>153</u>	<u>120</u>
Temperature	<u>74</u>	<u>76</u>	<u>73</u>

Time of Shutdown:
Time of Start-Up:
Duration of Shutdown/Malfunction:

Reason for Shutdown/Malfunction:
<input type="checkbox"/> Air-Compressor System
<input type="checkbox"/> High Temperature
<input type="checkbox"/> Low Temperature
<input type="checkbox"/> Power Failure
<input type="checkbox"/> Blower
<input type="checkbox"/> LEL
<input type="checkbox"/> UV Scanner System
<input type="checkbox"/> High Gas Flow
<input type="checkbox"/> Low Gas Flow
<input type="checkbox"/> Scheduled Preventive Maintenance

**PM MONITORING**

Name \_\_\_\_\_  
Arrival Time \_\_\_\_\_ Departure Time \_\_\_\_\_  
GEM# \_\_\_\_\_ Manometer \_\_\_\_\_ yes / no

LFG to Flares

CH4 %	CO2 %	O2 %

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3			

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			

Back Up Generator Running yes / no

Control Room Bypass yes / no

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed isolating all LFG in the piping system to avoid excess emissions, and notified the staff.

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.

Comments and/or Description of Malfunction and Affected Equipment:

Time of Shutdown:
Time of Start-Up:
Duration of Shutdown/Malfunction:

Emission Exceedence: yes\* / no

SSM Plan Procedures Followed: yes / no\*

If SSM Plan Procedure not followed, explain procedure used:

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc. continued on the back side? yes / no

Signature

Date

**SSM PLAN REPORT FORM /  
FLARE STATION DAILY CHECKLIST**  
City of Mountain View Flare Station

Date

July 25<sup>th</sup>, 2022

s m t w th f s

**AM MONITORING**

Name JASON R. BEAR

Arrival Time 6:56 AM Departure Time 7:10 AM

GEM# ENVISION H4 Manometer (yes) no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>45.0</u>	<u>32.3</u>	<u>1.7</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1	<u>1615</u>	<u>3.30"</u>	<u>127</u>
Flare #2	<u>1628</u>	<u>2.49"</u>	<u>246</u>
Flare #3			

Blower Oper.	RPM	Hours
Blower #1		
Blower #2		
Blower #3	<u>2100</u>	<u>3319.4</u>

Air Compressor Hours: 9549.2

Google SCFM: am: 26 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>46.7</u>	<u>45.0</u>	<u>42.3</u>
CO2 %	<u>32.2</u>	<u>31.6</u>	<u>29.4</u>
O2 %	<u>1.3</u>	<u>0.6</u>	<u>34</u>
Vacuum	<u>-40.0"</u>	<u>-39.1"</u>	<u>-39.9"</u>
SCFM	<u>150</u>	<u>151</u>	<u>118</u>
Temperature	<u>76</u>	<u>76</u>	<u>74</u>

Time of Shutdown:

Time of Start-Up:

Duration of Shutdown/Malfunction:

Reason for Shutdown/Malfunction:

- Air-Compressor System
- Blower
- High Gas Flow
- High Temperature
- LEL
- Low Gas Flow
- Low Temperature
- UV Scanner System
- Power Failure
- Scheduled Preventive Maintenance

**PM MONITORING**

Name \_\_\_\_\_

Arrival Time \_\_\_\_\_

Departure Time \_\_\_\_\_

GEM# \_\_\_\_\_

Manometer \_\_\_\_\_

yes / no

LFG to Flares

CH4 %	CO2 %	O2 %

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3			

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			

Back Up Generator Running yes / no

Control Room Bypass yes / no

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed isolating all LFG in the piping system to avoid excess emissions, and notified the staff.

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.

Comments and/or Description  
of Malfunction and Affected Equipment:

Time of Shutdown:
Time of Start-Up:
Duration of Shutdown/Malfunction:

Emission Exceedence: yes\* / no

SSM Plan Procedures Followed: yes / no\*

If SSM Plan Procedure not followed, explain procedure used:

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc. continued on the back side? yes / no

Signature \_\_\_\_\_

Date \_\_\_\_\_

**SSM PLAN REPORT FORM /  
FLARE STATION DAILY CHECKLIST**  
City of Mountain View Flare Station

Date July 26<sup>th</sup>, 2022  
S M T W Th F S

**AM MONITORING**

Name Jason R. Bean  
Arrival Time 7:20 AM Departure Time 7:30 AM  
GEM# ENVISION #4 Manometer  yes /  no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>44.6</u>	<u>32.2</u>	<u>1.8</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1	<u>1632</u>	<u>2.84"</u>	<u>116</u>
Flare #2	<u>1632</u>	<u>2.01"</u>	<u>228</u>
Flare #3			

Blower Oper.	RPM	Hours
Blower #1		
Blower #2		
Blower #3	<u>2100</u>	<u>30343.8</u>

Air Compressor Hours: 9556.2

Google SCFM: am: 27 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>46.9</u>	<u>44.7</u>	<u>42.0</u>
CO2 %	<u>33.0</u>	<u>31.4</u>	<u>29.5</u>
O2 %	<u>1.3</u>	<u>0.4</u>	<u>3.5</u>
Vacuum	<u>-40.2"</u>	<u>-39.4"</u>	<u>-40.0"</u>
SCFM	<u>154</u>	<u>151</u>	<u>119</u>
Temperature	<u>77</u>	<u>77</u>	<u>74</u>

Time of Shutdown: 8:53 AM

Time of Start-Up: 9:24 AM

Duration of Shutdown/Malfunction: 31 min

Reason for Shutdown/Malfunction: REPLACED CONTROLLER

- Air-Compressor System
- Blower
- High Gas Flow
- High Temperature
- LEL
- Low Gas Flow
- Low Temperature
- UV Scanner System
- Power Failure
- Scheduled Preventive Maintenance

TelStar here to replace controller

**PM MONITORING**

Name \_\_\_\_\_  
Arrival Time \_\_\_\_\_ Departure Time \_\_\_\_\_  
GEM# \_\_\_\_\_ Manometer \_\_\_\_\_ yes / no

LFG to Flares

CH4 %	CO2 %	O2 %

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3			

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			

Back Up Generator Running yes /  no

Control Room Bypass yes /  no

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed isolating all LFG in the piping system to avoid excess emissions, and notified the staff.

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.

Comments and/or Description of Malfunction and Affected Equipment:

Emission Exceedence: yes\* /  no

SSM Plan Procedures Followed:  yes\*  no\*

If SSM Plan Procedure not followed, explain procedure used:

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc. continued on the back side?

yes /  no

Signature 

Date 7/26/22

**SSM PLAN REPORT FORM /  
FLARE STATION DAILY CHECKLIST**  
City of Mountain View Flare Station

Date

July 27<sup>th</sup>, 2022

s m t w th f s

**AM MONITORING**

Name Jason R. Bean

Arrival Time 6:38 AM Departure Time 6:48 AM

GEM# EN001N #4 Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>44.5</u>	<u>31.1</u>	<u>1.8</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1	<u>1620</u>	<u>1.54"</u>	<u>90</u>
Flare #2			
Flare #3	<u>1621</u>	<u>0.99"</u>	<u>280</u>

Blower Oper.	RPM	Hours
Blower #1		
Blower #2		
Blower #3	<u>2100</u>	<u>80366.7</u>

Air Compressor Hours: 9564.2

Google SCFM: am: 16 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>46.4</u>	<u>44.6</u>	<u>42.4</u>
CO2 %	<u>32.7</u>	<u>31.4</u>	<u>34.4</u>
O2 %	<u>13</u>	<u>0.7</u>	<u>3.6</u>
Vacuum	<u>-41.0"</u>	<u>-40.2"</u>	<u>-40.9"</u>
SCFM	<u>155</u>	<u>152</u>	<u>122</u>
Temperature	<u>77</u>	<u>77</u>	<u>74</u>

**PM MONITORING**

Name \_\_\_\_\_

Arrival Time \_\_\_\_\_ Departure Time \_\_\_\_\_

GEM# \_\_\_\_\_ Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3			

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			

Back Up Generator Running yes / no

Control Room Bypass yes / no

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed isolating all LFG in the piping system to avoid excess emissions, and notified the staff.

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.

Comments and/or Description of Malfunction and Affected Equipment:

Time of Shutdown: 7:43 AM

Time of Start-Up: 10:57 AM

Duration of Shutdown/Malfunction: 3hr 14 min

Reason for Shutdown/Malfunction:

- Air-Compressor System
- Blower
- High Gas Flow
- High Temperature
- LEL
- Low Gas Flow
- Low Temperature
- UV Scanner System
- Power Failure
- Scheduled Preventive Maintenance

Clean Separator, Clean and replace Flame detector bulbs

Signature Jason R. Bean

Date 7/27/22

Emission Exceedence: yes\* / no

SSM Plan Procedures Followed: yes / no\*

If SSM Plan Procedure not followed, explain procedure used:

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc. continued on the back side?

yes / no

**SSM PLAN REPORT FORM /  
FLARE STATION DAILY CHECKLIST**  
City of Mountain View Flare Station

Date July 28th, 2022  
s m t w th f s

**AM MONITORING**

Name Adrian Vega

Arrival Time 7:40AM Departure Time 8:05AM

GEM# ENVISION #4 Manometer (yes) no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>45.1</u>	<u>32.9</u>	<u>1.9</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1	<u>1615</u>	<u>1.95"</u>	<u>102</u>
Flare #2			
Flare #3	<u>1627</u>	<u>1.28"</u>	<u>325</u>

Blower Oper.	RPM	Hours
Blower #1	<u>2100</u>	<u>17824.5</u>
Blower #2		
Blower #3		

Air Compressor Hours: 9573.1

Google SCFM: am: 0 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>47.3</u>	<u>45.0</u>	<u>43.0</u>
CO2 %	<u>34.8</u>	<u>32.7</u>	<u>30.7</u>
O2 %	<u>1.4</u>	<u>0.9</u>	<u>3.5</u>
Vacuum	<u>-40.1"</u>	<u>-39.2"</u>	<u>-39.9"</u>
SCFM	<u>154</u>	<u>150</u>	<u>126</u>
Temperature	<u>76</u>	<u>77</u>	<u>74</u>

Time of Shutdown:

Time of Start-Up:

Duration of Shutdown/Malfunction:

Reason for Shutdown/Malfunction:

- Air-Compressor System
- Blower
- High Gas Flow
- High Temperature
- LEL
- Low Gas Flow
- Low Temperature
- UV Scanner System
- Power Failure
- Scheduled Preventive Maintenance

**PM MONITORING**

Name \_\_\_\_\_

Arrival Time \_\_\_\_\_ Departure Time \_\_\_\_\_

GEM# \_\_\_\_\_ Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3			

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			

Back Up Generator Running yes / no

Control Room Bypass yes / no

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed, isolating all LFG in the piping system to avoid excess emissions, and notified the staff.

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.

Comments and/or Description of Malfunction and Affected Equipment:

Time of Shutdown:
Time of Start-Up:
Duration of Shutdown/Malfunction:

Emission Exceedence: yes\* / no

SSM Plan Procedures Followed: yes / no\*

If SSM Plan Procedure not followed, explain procedure used:

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc. continued on the back side? yes / no

Signature \_\_\_\_\_

Date \_\_\_\_\_

**SSM PLAN REPORT FORM /  
FLARE STATION DAILY CHECKLIST**  
City of Mountain View Flare Station

Date August 1<sup>st</sup>, 2022  
 s m t w th f s

**AM MONITORING**

Name JASON R. BEAN  
 Arrival Time 7:40AM Departure Time 7:53AM  
 GEM# ENVISION #4 Manometer (yes) no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>44.8</u>	<u>32.2</u>	<u>1.9</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1	<u>1617</u>	<u>2.07"</u>	<u>101</u>
Flare #2			
Flare #3	<u>1624</u>	<u>1.35"</u>	<u>328</u>

Blower Oper.	RPM	Hours
Blower #1	<u>2100</u>	<u>17920.4</u>
Blower #2		
Blower #3		

Air Compressor Hours: 9605.1

Google SCFM: am: 0 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>46.8</u>	<u>44.1</u>	<u>42.7</u>
CO2 %	<u>33.4</u>	<u>31.5</u>	<u>29.8</u>
O2 %	<u>1.4</u>	<u>1.1</u>	<u>3.7</u>
Vacuum	<u>-40.1"</u>	<u>-39.3"</u>	<u>-40.1"</u>
SCFM	<u>152</u>	<u>154</u>	<u>117</u>
Temperature	<u>77</u>	<u>77</u>	<u>74</u>

Time of Shutdown:

Time of Start-Up:

Duration of Shutdown/Malfunction:

Reason for Shutdown/Malfunction:

- Air-Compressor System
- Blower
- High Gas Flow
- High Temperature
- LEL
- Low Gas Flow
- Low Temperature
- UV Scanner System
- Power Failure
- Scheduled Preventive Maintenance

**PM MONITORING**

Name \_\_\_\_\_  
 Arrival Time \_\_\_\_\_ Departure Time \_\_\_\_\_  
 GEM# \_\_\_\_\_ Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3			

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			

Back Up Generator Running yes / no

Control Room Bypass yes / no

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed isolating all LFG in the piping system to avoid excess emissions, and notified the staff.

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.

Comments and/or Description of Malfunction and Affected Equipment:

Emission Exceedence: yes\* / no

SSM Plan Procedures Followed: yes / no\*

If SSM Plan Procedure not followed, explain procedure used:

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc. continued on the back side? yes / no

Signature

Date

**SSM PLAN REPORT FORM /  
FLARE STATION DAILY CHECKLIST**  
City of Mountain View Flare Station

Date 8-3-22  
s m t w th f s

**AM MONITORING**

Name LEON ROSARIO  
Arrival Time 8:10 am Departure Time 8:25 am  
GEM# ENV # 4 Manometer (yes) no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>45.7</u>	<u>31.6</u>	<u>1.9</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1	<u>1616</u>	<u>2.21"</u>	<u>102</u>
Flare #2	<u>/</u>	<u>/</u>	<u>/</u>
Flare #3	<u>1621</u>	<u>1.47"</u>	<u>340</u>

Blower Oper.	RPM	Hours
Blower #1	<u>700</u>	<u>17968.9</u>
Blower #2	<u>/</u>	<u>/</u>
Blower #3	<u>/</u>	<u>/</u>

Air Compressor Hours: 9621.2

Google SCFM: am: 38 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>47.4</u>	<u>46.1</u>	<u>42.5</u>
CO2 %	<u>32.6</u>	<u>32.0</u>	<u>29.3</u>
O2 %	<u>1.4</u>	<u>0.7</u>	<u>3.4</u>
Vacuum	<u>-39.2"</u>	<u>-38.2"</u>	<u>-38.9"</u>
SCFM	<u>192</u>	<u>162</u>	<u>123</u>
Temperature	<u>71</u>	<u>77</u>	<u>76</u>

Time of Shutdown:

Time of Start-Up:

Duration of Shutdown/Malfunction:

Reason for Shutdown/Malfunction:

- Air-Compressor System
- Blower
- High Gas Flow
- High Temperature
- LEL
- Low Gas Flow
- Low Temperature
- UV Scanner System
- Power Failure
- Scheduled Preventive Maintenance

**PM MONITORING**

Name \_\_\_\_\_

Arrival Time \_\_\_\_\_ Departure Time \_\_\_\_\_

GEM# \_\_\_\_\_ Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3			

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			

Back Up Generator Running yes / no

Control Room Bypass yes / no

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed isolating all LFG in the piping system to avoid excess emissions, and notified the staff.

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.

Comments and/or Description of Malfunction and Affected Equipment:

Time of Shutdown:

Time of Start-Up:

Duration of Shutdown/Malfunction:

Emission Exceedence: yes\* / no

SSM Plan Procedures Followed: yes / no\*

If SSM Plan Procedure not followed, explain procedure used:

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc. continued on the back side? yes / no

Signature

Date

**SSM PLAN REPORT FORM /  
FLARE STATION DAILY CHECKLIST**  
City of Mountain View Flare Station

Date 8-4-22  
s m t w th f s

**AM MONITORING**

Name LEON ROSARIO

Arrival Time 7:11 am Departure Time 7:25 am

GEM# ENV #4 Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>46.4</u>	<u>32.2</u>	<u>1.7</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1	<u>1624</u>	<u>2.18"</u>	<u>104</u>
Flare #2			
Flare #3	<u>1636</u>	<u>1.45"</u>	<u>338</u>

Blower Oper.	RPM	Hours
Blower #1	<u>2100</u>	<u>179910</u>
Blower #2		
Blower #3		

Air Compressor Hours: 9629.3

Google SCFM: am: 38 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>49.1</u>	<u>46.0</u>	<u>42.1</u>
CO2 %	<u>33.2</u>	<u>32.5</u>	<u>29.8</u>
O2 %	<u>1.5</u>	<u>0.6</u>	<u>3.5</u>
Vacuum	<u>-39.3"</u>	<u>-38.3"</u>	<u>-39.0"</u>
SCFM	<u>185</u>	<u>160</u>	<u>130</u>
Temperature	<u>71</u>	<u>77</u>	<u>74</u>

Time of Shutdown:

Time of Start-Up:

Duration of Shutdown/Malfunction:

Reason for Shutdown/Malfunction:

- Air-Compressor System
- Blower
- High Gas Flow
- High Temperature
- LEL
- Low Gas Flow
- Low Temperature
- UV Scanner System
- Power Failure
- Scheduled Preventive Maintenance

**PM MONITORING**

Name \_\_\_\_\_

Arrival Time \_\_\_\_\_ Departure Time \_\_\_\_\_

GEM# \_\_\_\_\_ Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3			

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			

Back Up Generator Running yes / no

Control Room Bypass yes / no

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed isolating all LFG in the piping system to avoid excess emissions, and notified the staff.

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.

Comments and/or Description of Malfunction and Affected Equipment:

Time of Shutdown:

Time of Start-Up:

Duration of Shutdown/Malfunction:

Emission Exceedence: yes\* / no

SSM Plan Procedures Followed: yes / no\*

If SSM Plan Procedure not followed, explain procedure used:

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc. continued on the back side? yes / no

Signature

Date

**SSM PLAN REPORT FORM /  
FLARE STATION DAILY CHECKLIST**  
City of Mountain View Flare Station

Date August 10<sup>th</sup>, 2022  
s m t w th f s

**AM MONITORING**

Name JASON R. Bean  
Arrival Time 6:38 AM Departure Time 6:51 AM  
GEM# ENVISANT #4 Manometer (yes) no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>45.0</u>	<u>31.0</u>	<u>21.0</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1	<u>1627</u>	<u>2118"</u>	<u>105</u>
Flare #2			
Flare #3	<u>1626</u>	<u>1,43"</u>	<u>344</u>

Blower Oper.	RPM	Hours
Blower #1	<u>2100</u>	<u>18135.3</u>
Blower #2		
Blower #3		

Air Compressor Hours: 9679.1

Google SCFM: am: 41 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>47.5</u>	<u>45.4</u>	<u>41.6</u>
CO2 %	<u>32.8</u>	<u>31.7</u>	<u>29.1</u>
O2 %	<u>1.8</u>	<u>0.6</u>	<u>3.8</u>
Vacuum	<u>-39.9"</u>	<u>-38.9"</u>	<u>-39.7"</u>
SCFM	<u>188</u>	<u>163</u>	<u>133</u>
Temperature	<u>77</u>	<u>77</u>	<u>74</u>

Time of Shutdown:

Time of Start-Up:

Duration of Shutdown/Malfunction:

Reason for Shutdown/Malfunction:

- Air-Compressor System     Blower     High Gas Flow
- High Temperature     LEL     Low Gas Flow
- Low Temperature     UV Scanner System
- Power Failure     Scheduled Preventive Maintenance

**PM MONITORING**

Name \_\_\_\_\_

Arrival Time \_\_\_\_\_ Departure Time \_\_\_\_\_

GEM# \_\_\_\_\_ Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3			

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			

Back Up Generator Running yes / no

Control Room Bypass yes / no

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed, isolating all LFG in the piping system to avoid excess emissions, and notified the staff.

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.

Comments and/or Description  
of Malfunction and Affected Equipment:

Time of Shutdown:

Time of Start-Up:

Duration of Shutdown/Malfunction:

Emission Exceedence: yes\* / no

SSM Plan Procedures Followed: yes / no\*

If SSM Plan Procedure not followed, explain procedure used:

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc. continued on the back side? yes / no

Signature

Date

**SSM PLAN REPORT FORM /  
FLARE STATION DAILY CHECKLIST**  
City of Mountain View Flare Station

Date 8-11-22  
s m t w th f s

**AM MONITORING**

Name LEON ROSALE 30  
Arrival Time 7:22 Am Departure Time 7:31 Am  
GEM# ENIV #4 Manometer yes no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>45.0</u>	<u>31.1</u>	<u>1.9</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1	<u>1635</u>	<u>2.24"</u>	<u>105</u>
Flare #2			
Flare #3	<u>1633</u>	<u>1.47"</u>	<u>392</u>

Blower Oper.	RPM	Hours
Blower #1	<u>2100</u>	<u>18160.1</u>
Blower #2		
Blower #3		

Air Compressor Hours: 9688.1

Google SCFM: am: 40 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>47.9</u>	<u>44.2</u>	<u>41.9</u>
CO2 %	<u>32.0</u>	<u>31.3</u>	<u>28.3</u>
O2 %	<u>1.6</u>	<u>0.6</u>	<u>3.6</u>
Vacuum	<u>-39.8"</u>	<u>-38.7"</u>	<u>-39.4"</u>
SCFM	<u>186</u>	<u>162</u>	<u>136</u>
Temperature	<u>78</u>	<u>77</u>	<u>74</u>

Time of Shutdown:

Time of Start-Up:

Duration of Shutdown/Malfunction:

Reason for Shutdown/Malfunction:

- Air-Compressor System
- Blower
- High Gas Flow
- High Temperature
- LEL
- Low Gas Flow
- Low Temperature
- UV Scanner System
- Power Failure
- Scheduled Preventive Maintenance

**PM MONITORING**

Name \_\_\_\_\_

Arrival Time \_\_\_\_\_ Departure Time \_\_\_\_\_

GEM# \_\_\_\_\_ Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3			

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			

Back Up Generator Running yes / no

Control Room Bypass yes / no

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed, isolating all LFG in the piping system to avoid excess emissions, and notified the staff.

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.

Comments and/or Description  
of Malfunction and Affected Equipment:

Time of Shutdown:

Time of Start-Up:

Duration of Shutdown/Malfunction:

Emission Exceedence: yes\* / no

SSM Plan Procedures Followed: yes / no\*

If SSM Plan Procedure not followed, explain procedure used:

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc. continued on the back side? yes / no

Signature

Date

**SSM PLAN REPORT FORM /  
FLARE STATION DAILY CHECKLIST**  
City of Mountain View Flare Station

Date

8-17-22

s m t **w** th f s

**AM MONITORING**

Name LEON ROSARIO

Arrival Time 6:56 am Departure Time 7:07 am

GEM# ENV #4 Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>44.5</u>	<u>32.1</u>	<u>2.0</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1	<u>1628</u>	<u>2.24"</u>	<u>104</u>
Flare #2			
Flare #3	<u>1617</u>	<u>1.45"</u>	<u>342</u>

Blower Oper.	RPM	Hours
Blower #1	<u>2100</u>	<u>18303.6</u>
Blower #2		
Blower #3		

Air Compressor Hours: 9739.2

Google SCFM: am: 43 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>47.8</u>	<u>44.4</u>	<u>41.1</u>
CO2 %	<u>32.2</u>	<u>31.0</u>	<u>29.3</u>
O2 %	<u>1.8</u>	<u>0.9</u>	<u>3.7</u>
Vacuum	<u>-39.3"</u>	<u>-38.4"</u>	<u>-39.2"</u>
SCFM	<u>184</u>	<u>160</u>	<u>130</u>
Temperature	<u>78</u>	<u>78</u>	<u>75</u>

Time of Shutdown:

Time of Start-Up:

Duration of Shutdown/Malfunction:

Reason for Shutdown/Malfunction:

- Air-Compressor System
- Blower
- High Gas Flow
- High Temperature
- LEL
- Low Gas Flow
- Low Temperature
- UV Scanner System
- Power Failure
- Scheduled Preventive Maintenance

**PM MONITORING**

Name \_\_\_\_\_

Arrival Time \_\_\_\_\_ Departure Time \_\_\_\_\_

GEM# \_\_\_\_\_ Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3			

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			

Back Up Generator Running yes / no

Control Room Bypass yes / no

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed, isolating all LFG in the piping system to avoid excess emissions, and notified the staff.

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.

Comments and/or Description of Malfunction and Affected Equipment:

Time of Shutdown:

Time of Start-Up:

Duration of Shutdown/Malfunction:

Emission Exceedence: yes\* / no

SSM Plan Procedures Followed: yes / no\*

If SSM Plan Procedure not followed, explain procedure used:

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc. continued on the back side? yes / no

Signature

Date

**SSM PLAN REPORT FORM /**  
**FLARE STATION DAILY CHECKLIST**  
 City of Mountain View Flare Station

Date August 18<sup>th</sup>, 2012  
 S M T W **Th** F S

**AM MONITORING**

Name JASON R Bean  
 Arrival Time 6:57 am Departure Time 7:02 pm  
 GEM# ENVISION#4 Manometer  yes / no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>34.4</u>	<u>31.7</u>	<u>2.1</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1	<u>1624</u>	<u>2.17"</u>	<u>104</u>
Flare #2			
Flare #3	<u>1630</u>	<u>1.39"</u>	<u>310</u>

Blower Oper.	RPM	Hours
Blower #1	<u>2100</u>	<u>18327.5</u>
Blower #2		
Blower #3		

Air Compressor Hours: 9747.6

Google SCFM: am: 42 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>46.8</u>	<u>44.0</u>	<u>40.7</u>
CO2 %	<u>32.0</u>	<u>31.0</u>	<u>28.8</u>
O2 %	<u>1.9</u>	<u>1.0</u>	<u>3.8</u>
Vacuum	<u>-39.8"</u>	<u>-38.7"</u>	<u>-39.6"</u>
SCFM	<u>186</u>	<u>164</u>	<u>128</u>
Temperature	<u>78</u>	<u>77</u>	<u>74</u>

**PM MONITORING**

Name \_\_\_\_\_  
 Arrival Time \_\_\_\_\_ Departure Time \_\_\_\_\_  
 GEM# \_\_\_\_\_ Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3			

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			

Back Up Generator Running yes / no

Control Room Bypass yes / no

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed isolating all LFG in the piping system to avoid excess emissions, and notified the staff.

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.

Comments and/or Description of Malfunction and Affected Equipment:

Time of Shutdown:

Time of Start-Up:

Duration of Shutdown/Malfunction:

Reason for Shutdown/Malfunction:

- Air-Compressor System
- Blower
- High Gas Flow
- High Temperature
- LEL
- Low Gas Flow
- Low Temperature
- UV Scanner System
- Power Failure
- Scheduled Preventive Maintenance

Emission Exceedence: yes\* / no

SSM Plan Procedures Followed: yes / no\*

If SSM Plan Procedure not followed, explain procedure used:

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc. continued on the back side? yes / no

Signature

Date

**SSM PLAN REPORT FORM /  
FLARE STATION DAILY CHECKLIST**  
City of Mountain View Flare Station

Date August 19<sup>th</sup>, 2022  
s t w th f s

**AM MONITORING**

Name JASON R. BEAN

Arrival Time 6:31 AM Departure Time 6:42 PM

GEM# ENVISION #4 Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>46.0</u>	<u>31.2</u>	<u>1.8</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1	<u>1618</u>	<u>2.17"</u>	<u>104</u>
Flare #2			
Flare #3	<u>1617</u>	<u>1.45"</u>	<u>310</u>

Blower Oper.	RPM	Hours
Blower #1	<u>2100</u>	<u>18351.2</u>
Blower #2		
Blower #3		

Air Compressor Hours: 9756.2

Google SCFM: am: 44 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>49.0</u>	<u>44.6</u>	<u>43.1</u>
CO2 %	<u>32.9</u>	<u>31.1</u>	<u>29.8</u>
O2 %	<u>1.3</u>	<u>0.9</u>	<u>3.4</u>
Vacuum	<u>-39.5"</u>	<u>-38.3"</u>	<u>-39.3"</u>
SCFM	<u>187</u>	<u>165</u>	<u>130</u>
Temperature	<u>78</u>	<u>78</u>	<u>75</u>

**PM MONITORING**

Name \_\_\_\_\_

Arrival Time \_\_\_\_\_ Departure Time \_\_\_\_\_

GEM# \_\_\_\_\_ Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3			

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			

Back Up Generator Running yes / no

Control Room Bypass yes / no

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed isolating all LFG in the piping system to avoid excess emissions, and notified the staff.

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.

Comments and/or Description  
of Malfunction and Affected Equipment:

Time of Shutdown:

Time of Start-Up:

Duration of Shutdown/Malfunction:

Reason for Shutdown/Malfunction:

- Air-Compressor System
- Blower
- High Gas Flow
- High Temperature
- LEL
- Low Gas Flow
- Low Temperature
- UV Scanner System
- Power Failure
- Scheduled Preventive Maintenance

Emission Exceedence: yes\* / no

SSM Plan Procedures Followed: yes / no\*

If SSM Plan Procedure not followed, explain procedure used:

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc. continued on the back side? yes / no

Signature

Date

**SSM PLAN REPORT FORM /  
FLARE STATION DAILY CHECKLIST**  
City of Mountain View Flare Station

Date September 1<sup>ST</sup>, 2022  
s m t w **th** f s

**AM MONITORING**

Name JASON R. BEAN  
Arrival Time 7:11am Departure Time 7:24pm  
GEM# ENVISION #4 Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>24.6</u>	<u>32.3</u>	<u>1.9</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1	<u>1629</u>	<u>2.20"</u>	<u>105</u>
Flare #2			
Flare #3	<u>1631</u>	<u>1.44"</u>	<u>341</u>

Blower Oper.	RPM	Hours
Blower #1	<u>2100</u>	<u>18663.9</u>
Blower #2		
Blower #3		

Air Compressor Hours: 9863.0

Google SCFM: am: 45 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>47.9</u>	<u>43.7</u>	<u>41.2</u>
CO2 %	<u>33.5</u>	<u>32.5</u>	<u>30.3</u>
O2 %	<u>1.4</u>	<u>0.8</u>	<u>4.0</u>
Vacuum	<u>-39.8"</u>	<u>-38.7"</u>	<u>-39.5"</u>
SCFM	<u>185</u>	<u>165</u>	<u>126</u>
Temperature	<u>77</u>	<u>78</u>	<u>74</u>

Time of Shutdown:

Time of Start-Up:

Duration of Shutdown/Malfunction:

Reason for Shutdown/Malfunction:

- Air-Compressor System
- Blower
- High Gas Flow
- High Temperature
- LEL
- Low Gas Flow
- Low Temperature
- UV Scanner System
- Power Failure
- Scheduled Preventive Maintenance

**PM MONITORING**

Name \_\_\_\_\_  
Arrival Time \_\_\_\_\_ Departure Time \_\_\_\_\_  
GEM# \_\_\_\_\_ Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %

Flare Operation	Trip	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3			

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			

Back Up Generator Running yes / no

Control Room Bypass yes / no

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed isolating all LFG in the piping system to avoid excess emissions, and notified the staff.

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.

Comments and/or Description  
of Malfunction and Affected Equipment:

Time of Shutdown:
Time of Start-Up:
Duration of Shutdown/Malfunction:

Emission Exceedence: yes\* / no

SSM Plan Procedures Followed: yes / no\*

If SSM Plan Procedure not followed, explain procedure used:

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc. continued on the back side? yes / no

Signature

Date

**SSM PLAN REPORT FORM /  
FLARE STATION DAILY CHECKLIST**  
City of Mountain View Flare Station

Date 9-8-22  
 S m t w **th** f s

**AM MONITORING**

Name LEON ROSACCO

Arrival Time 7:18 AM Departure Time 7:29 AM  
 GEM# ENU #4 Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>45.1</u>	<u>33.1</u>	<u>1.8</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1	<u>1618</u>	<u>2.17"</u>	<u>103</u>
Flare #2			
Flare #3	<u>1617</u>	<u>1.45"</u>	<u>337</u>

Blower Oper.	RPM	Hours
Blower #1	<u>2100</u>	<u>18837.0</u>
Blower #2		
Blower #3		

Air Compressor Hours: 9920

Google SCFM: am: 47 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>48.2</u>	<u>44.0</u>	<u>41.6</u>
CO2 %	<u>33.6</u>	<u>33.0</u>	<u>30.3</u>
O2 %	<u>1.4</u>	<u>0.7</u>	<u>4.0</u>
Vacuum	<u>-39.3"</u>	<u>-38.4"</u>	<u>-39.0"</u>
SCFM	<u>185</u>	<u>157</u>	<u>125</u>
Temperature	<u>79</u>	<u>78</u>	<u>76</u>

Time of Shutdown: 1:48 pm

Time of Start-Up: 2:27 pm

Duration of Shutdown/Malfunction: 39 min

Reason for Shutdown/Malfunction:

- Air-Compressor System    Blower    High Gas Flow
- High Temperature    LEL    Low Gas Flow
- Low Temperature    UV Scanner System
- Power Failure    Scheduled Preventive Maintenance

D T D changing out belt  
on Air Compressor

**PM MONITORING**

Name \_\_\_\_\_

Arrival Time \_\_\_\_\_ Departure Time \_\_\_\_\_  
 GEM# \_\_\_\_\_ Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3			

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			

Back Up Generator Running yes / no

Control Room Bypass yes / no

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed isolating all LFG in the piping system to avoid excess emissions, and notified the staff.

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.

Comments and/or Description of Malfunction and Affected Equipment:

yes / no

Emission Exceedence:

yes\* / no

SSM Plan Procedures Followed:

yes no\*

If SSM Plan Procedure not followed, explain procedure used:

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc. continued on the back side?

yes / no

Signature 

Date 9/8/22

**SSM PLAN REPORT FORM /  
FLARE STATION DAILY CHECKLIST**  
City of Mountain View Flare Station

Date 9-9-22  
s m t w th f s

**AM MONITORING**

Name PAUL BANDA

Arrival Time 6:59 AM Departure Time 7:13 AM  
GEM# ENV # 1 Manometer (yes) no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>46.3</u>	<u>33.0</u>	<u>1.9</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1	<u>1635</u>	<u>2.21</u>	<u>104</u>
Flare #2	<u>/</u>	<u>/</u>	<u>/</u>
Flare #3	<u>1636</u>	<u>1.42</u>	<u>336</u>

Blower Oper.	RPM	Hours
Blower #1	<u>2100</u>	<u>18855.2</u>
Blower #2	<u>/</u>	<u>/</u>
Blower #3	<u>/</u>	<u>/</u>

Air Compressor Hours: 9928.0

Google SCFM: am: 48 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>50.8</u>	<u>45.9</u>	<u>42.5</u>
CO2 %	<u>35.1</u>	<u>34.2</u>	<u>31.1</u>
O2 %	<u>0.9</u>	<u>0.7</u>	<u>4.4</u>
Vacuum	<u>-38.8</u>	<u>-38.1</u>	<u>-38.8</u>
SCFM	<u>186</u>	<u>158</u>	<u>129</u>
Temperature	<u>79</u>	<u>78</u>	<u>75</u>

Time of Shutdown:

Time of Start-Up:

Duration of Shutdown/Malfunction:

Reason for Shutdown/Malfunction:

- Air-Compressor System     Blower     High Gas Flow
- High Temperature     LEL     Low Gas Flow
- Low Temperature     UV Scanner System
- Power Failure     Scheduled Preventive Maintenance

**PM MONITORING**

Name \_\_\_\_\_

Arrival Time \_\_\_\_\_ Departure Time \_\_\_\_\_  
GEM# \_\_\_\_\_ Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3			

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			

Back Up Generator Running yes / no

Control Room Bypass yes / no

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed isolating all LFG in the piping system to avoid excess emissions, and notified the staff.

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.

Comments and/or Description  
of Malfunction and Affected Equipment:

Time of Shutdown:

Time of Start-Up:

Duration of Shutdown/Malfunction:

Emission Exceedence: yes\* / no

SSM Plan Procedures Followed: yes / no\*

If SSM Plan Procedure not followed, explain procedure used:

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc. continued on the back side? yes / no

Signature

Date

**SSM PLAN REPORT FORM /  
FLARE STATION DAILY CHECKLIST**  
City of Mountain View Flare Station

Date September 12<sup>th</sup>, 2022

S m t w th f s

**AM MONITORING**

Name Adrian Vega

Arrival Time 6:59 AM Departure Time 7:23 AM

GEM# Envision #4 Manometer yes no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>44.1</u>	<u>32.2</u>	<u>2.3</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1	<u>1617</u>	<u>2.24"</u>	<u>105</u>
Flare #2			
Flare #3	<u>1616</u>	<u>1.47"</u>	<u>341</u>

Blower Oper.	RPM	Hours
Blower #1	<u>2100</u>	<u>18927.4</u>
Blower #2		
Blower #3		

Air Compressor Hours: 9950.7

Google SCFM: am: 49 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>47.6</u>	<u>43.0</u>	<u>40.1</u>
CO2 %	<u>34.1</u>	<u>32.7</u>	<u>29.2</u>
O2 %	<u>1.6</u>	<u>1.1</u>	<u>4.6</u>
Vacuum	<u>-31.5"</u>	<u>-38.6"</u>	<u>-39.3"</u>
SCFM	<u>189</u>	<u>163</u>	<u>128</u>
Temperature	<u>79</u>	<u>79</u>	<u>76</u>

**PM MONITORING**

Name \_\_\_\_\_

Arrival Time \_\_\_\_\_ Departure Time \_\_\_\_\_

GEM# \_\_\_\_\_ Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3			

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			

Back Up Generator Running yes / no

Control Room Bypass yes / no

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed isolating all LFG in the piping system to avoid excess emissions, and notified the staff.

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.

Comments and/or Description of Malfunction and Affected Equipment:

Time of Shutdown:
Time of Start-Up:
Duration of Shutdown/Malfunction:

Emission Exceedence: yes\* / no

SSM Plan Procedures Followed: yes / no\*

If SSM Plan Procedure not followed, explain procedure used:

- Reason for Shutdown/Malfunction:
- Air-Compressor System     Blower     High Gas Flow
  - High Temperature     LEL     Low Gas Flow
  - Low Temperature     UV Scanner System
  - Power Failure     Scheduled Preventive Maintenance

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc. continued on the back side? yes / no

Signature \_\_\_\_\_

Date \_\_\_\_\_

**SSM PLAN REPORT FORM /**  
**FLARE STATION DAILY CHECKLIST**  
 City of Mountain View Flare Station

Date 9-14-22  
 S m t W th f s

**AM MONITORING**

Name LEON ROSARZO  
 Arrival Time 7:15 AM Departure Time 7:29 AM  
 GEM# CNV #4 Manometer (Yes) no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>43.6</u>	<u>31.8</u>	<u>2.5</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1	<u>1435</u>	<u>2.22"</u>	<u>105</u>
Flare #2	<u>/</u>	<u>/</u>	<u>/</u>
Flare #3	<u>1622</u>	<u>1.43"</u>	<u>338</u>

Blower Oper.	RPM	Hours
Blower #1	<u>2100</u>	<u>18975.4</u>
Blower #2	<u>/</u>	<u>/</u>
Blower #3	<u>/</u>	<u>/</u>

Air Compressor Hours: 9965.6

Google SCFM: am: 46 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>46.9</u>	<u>43.6</u>	<u>38.7</u>
CO2 %	<u>33.2</u>	<u>32.5</u>	<u>28.6</u>
O2 %	<u>1.9</u>	<u>1.1</u>	<u>4.8</u>
Vacuum	<u>-39.8</u>	<u>-38.7"</u>	<u>-39.6"</u>
SCFM	<u>186</u>	<u>165</u>	<u>126</u>
Temperature	<u>78</u>	<u>78</u>	<u>74</u>

Time of Shutdown:

Time of Start-Up:

Duration of Shutdown/Malfunction:

Reason for Shutdown/Malfunction:

- Air-Compressor System
- Blower
- High Gas Flow
- High Temperature
- LEL
- Low Gas Flow
- Low Temperature
- UV Scanner System
- Power Failure
- Scheduled Preventive Maintenance

**PM MONITORING**

Name \_\_\_\_\_  
 Arrival Time \_\_\_\_\_ Departure Time \_\_\_\_\_  
 GEM# \_\_\_\_\_ Manometer yes / no

LFG to Flares	CH4 %	CO2 %	O2 %

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3			

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			

Back Up Generator Running yes / no

Control Room Bypass yes / no

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed, isolating all LFG in the piping system to avoid excess emissions, and notified the staff.

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.

Comments and/or Description of Malfunction and Affected Equipment:

Time of Shutdown:	
Time of Start-Up:	
Duration of Shutdown/Malfunction:	
Reason for Shutdown/Malfunction:	
<input type="checkbox"/> Air-Compressor System <input type="checkbox"/> Blower <input type="checkbox"/> High Gas Flow <input type="checkbox"/> High Temperature <input type="checkbox"/> LEL <input type="checkbox"/> Low Gas Flow <input type="checkbox"/> Low Temperature <input type="checkbox"/> UV Scanner System <input type="checkbox"/> Power Failure <input type="checkbox"/> Scheduled Preventive Maintenance	
Emission Exceedence:	yes* / no
SSM Plan Procedures Followed:	yes / no*
If SSM Plan Procedure <u>not</u> followed, explain procedure used:	

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc. continued on the back side? yes / no

Signature

Date

**SSM PLAN REPORT FORM /**  
**FLARE STATION DAILY CHECKLIST**  
 City of Mountain View Flare Station

Date

9-19-22

S M T W Th F S

**AM MONITORING**

Name LEON ROSARIO

Arrival Time 8:43 AM Departure Time \_\_\_\_\_  
 GEM# CNV #4 Manometer (yes) no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>43.0</u>	<u>31.1</u>	<u>2.5</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1	<u>1629</u>	<u>2.26"</u>	<u>105</u>
Flare #2	<u>/</u>	<u>/</u>	<u>/</u>
Flare #3	<u>1627</u>	<u>1.47"</u>	<u>342</u>

Blower Oper.	RPM	Hours
Blower #1	<u>2100</u>	<u>190969</u>
Blower #2	<u>/</u>	<u>/</u>
Blower #3	<u>/</u>	<u>/</u>

Air Compressor Hours: 1001.9

Google SCFM: am: 47 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>46.2</u>	<u>43.8</u>	<u>38.6</u>
CO2 %	<u>32.3</u>	<u>31.6</u>	<u>28.0</u>
O2 %	<u>7.0</u>	<u>1.0</u>	<u>4.9</u>
Vacuum	<u>-39.5"</u>	<u>-38.3"</u>	<u>-39.3"</u>
SCFM	<u>190</u>	<u>161</u>	<u>126</u>
Temperature	<u>77</u>	<u>77</u>	<u>74</u>

**PM MONITORING**

Name \_\_\_\_\_

Arrival Time \_\_\_\_\_ Departure Time \_\_\_\_\_  
 GEM# \_\_\_\_\_ Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>/</u>	<u>/</u>	<u>/</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1	<u>/</u>	<u>/</u>	<u>/</u>
Flare #2	<u>/</u>	<u>/</u>	<u>/</u>
Flare #3	<u>/</u>	<u>/</u>	<u>/</u>

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum	<u>/</u>	<u>/</u>	<u>/</u>
SCFM	<u>/</u>	<u>/</u>	<u>/</u>
Back Up Generator Running	yes	/	<u>no</u>

Control Room Bypass yes / no

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed isolating all LFG in the piping system to avoid excess emissions, and notified the staff. yes / no

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions. yes / no

Comments and/or Description of Malfunction and Affected Equipment:

Time of Shutdown: 9 AM


Time of Start-Up: 9:30 AM

Duration of Shutdown/Malfunction: 30 min

Reason for Shutdown/Malfunction:

- Air-Compressor System  Blower  High Gas Flow
- High Temperature  LEL  Low Gas Flow
- Low Temperature  UV Scanner System
- Power Failure  Scheduled Preventive Maintenance

Blower change from #1 to #2

  
 Signature \_\_\_\_\_ Date 9/19/22

Emission Exceedence:

yes\* / no

SSM Plan Procedures Followed:

yes / no\*

If SSM Plan Procedure not followed, explain procedure used:

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc. continued on the back side?

yes / no

**SSM PLAN REPORT FORM /**  
**FLARE STATION DAILY CHECKLIST**  
 City of Mountain View Flare Station

Date September 23<sup>rd</sup>, 2022

S m t w th f s

**AM MONITORING**

Name Adrian Vega

Arrival Time 7:01 AM Departure Time 7:17 AM  
 GEM# EnVision #4 Manometer (yes) no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>44.3</u>	<u>30.8</u>	<u>2.3</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1	<u>16234</u>	<u>1.80"</u>	<u>95</u>
Flare #2			
Flare #3	<u>1621</u>	<u>1.12"</u>	<u>301</u>

Blower Oper.	RPM	Hours
Blower #1		
Blower #2	<u>2100</u>	<u>103449.1</u>
Blower #3		

Air Compressor Hours: 10029.2

Google SCFM: am: 38 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>48.0</u>	<u>43.1</u>	<u>39.9</u>
CO2 %	<u>38.6</u>	<u>31.5</u>	<u>28.1</u>
O2 %	<u>1.5</u>	<u>1.0</u>	<u>4.8</u>
Vacuum	<u>-40.6"</u>	<u>-39.6"</u>	<u>-40.5"</u>
SCFM	<u>191</u>	<u>166</u>	<u>132</u>
Temperature	<u>76</u>	<u>76</u>	<u>73</u>

Time of Shutdown:

Time of Start-Up:

Duration of Shutdown/Malfunction:

Reason for Shutdown/Malfunction:

- Air-Compressor System
- Blower
- High Gas Flow
- High Temperature
- LEL
- Low Gas Flow
- Low Temperature
- UV Scanner System
- Power Failure
- Scheduled Preventive Maintenance

**PM MONITORING**

Name \_\_\_\_\_

Arrival Time \_\_\_\_\_ Departure Time \_\_\_\_\_

GEM# \_\_\_\_\_ Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3			

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			

Back Up Generator Running yes / no

Control Room Bypass yes / no

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed isolating all LFG in the piping system to avoid excess emissions, and notified the staff, yes / no

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions, yes / no

Comments and/or Description of Malfunction and Affected Equipment:

Time of Shutdown:

Time of Start-Up:

Duration of Shutdown/Malfunction:

Emission Exceedence: yes\* / no

SSM Plan Procedures Followed: yes / no\*

If SSM Plan Procedure not followed, explain procedure used:

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc. continued on the back side? yes / no

Signature

Date

**SSM PLAN REPORT FORM /**  
**FLARE STATION DAILY CHECKLIST**  
 City of Mountain View Flare Station

Date September 27<sup>th</sup>, 2022  
 S m  W th F S

**AM MONITORING**

Name Adrian Vega

Arrival Time 7:43 AM Departure Time 8:00 AM

GEM# Envision #4 Manometer  yes / no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>43.5</u>	<u>30.5</u>	<u>2.4</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1	<u>1624</u>	<u>1.72"</u>	<u>92</u>
Flare #2			
Flare #3	<u>1629</u>	<u>1.03"</u>	<u>289</u>

Blower Oper.	RPM	Hours
Blower #1		
Blower #2	<u>2100</u>	<u>63245.1</u>
Blower #3		

Air Compressor Hours: 10062.8

Google SCFM: am: 48 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>44.8</u>	<u>42.6</u>	<u>38.5</u>
CO2 %	<u>32.6</u>	<u>31.4</u>	<u>37.3</u>
O2 %	<u>1.9</u>	<u>1.0</u>	<u>5.0</u>
Vacuum	<u>-40.9"</u>	<u>-39.8"</u>	<u>-40.7"</u>
SCFM	<u>192</u>	<u>186</u>	<u>133</u>
Temperature	<u>75</u>	<u>76</u>	<u>73</u>

Time of Shutdown:

Time of Start-Up:

Duration of Shutdown/Malfunction:

Reason for Shutdown/Malfunction:

- Air-Compressor System
- Blower
- High Gas Flow
- High Temperature
- LEL
- Low Gas Flow
- Low Temperature
- UV Scanner System
- Power Failure
- Scheduled Preventive Maintenance

**PM MONITORING**

Name \_\_\_\_\_

Arrival Time \_\_\_\_\_ Departure Time \_\_\_\_\_

GEM# \_\_\_\_\_ Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3			

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			

Back Up Generator Running yes / no

Control Room Bypass yes / no

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed, isolating all LFG in the piping system to avoid excess emissions, and notified the staff.

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.

Comments and/or Description of Malfunction and Affected Equipment:

Time of Shutdown:

Time of Start-Up:

Duration of Shutdown/Malfunction:

Emission Exceedence: yes\* / no

SSM Plan Procedures Followed: yes / no\*

If SSM Plan Procedure not followed, explain procedure used:

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc. continued on the back side? yes / no

Signature

Date

**SSM PLAN REPORT FORM /  
FLARE STATION DAILY CHECKLIST**  
City of Mountain View Flare Station

Date

October 4<sup>th</sup>, 2022

S m t w th f s

**AM MONITORING**

Name JASON R. BEAN  
Arrival Time 7:00PM Departure Time 7:13pm  
GEM# ENVISION H4 Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>43.3</u>	<u>31.5</u>	<u>2.5</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1	<u>1636</u>	<u>1.71"</u>	<u>94</u>
Flare #2			
Flare #3	<u>1616</u>	<u>1.06"</u>	<u>293</u>

Blower Oper.	RPM	Hours
Blower #1		
Blower #2	<u>2100</u>	<u>6316.4</u>
Blower #3		

Air Compressor Hours: 10129.1

Google SCFM: am: 49 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>47.1</u>	<u>42.6</u>	<u>38.8</u>
CO2 %	<u>33.0</u>	<u>31.9</u>	<u>28.4</u>
O2 %	<u>1.7</u>	<u>1.0</u>	<u>4.9</u>
Vacuum	<u>-40.8"</u>	<u>-39.9"</u>	<u>-40.7"</u>
SCFM	<u>192</u>	<u>164</u>	<u>130</u>
Temperature	<u>75</u>	<u>75</u>	<u>76</u>

Time of Shutdown:

Time of Start-Up:

Duration of Shutdown/Malfunction:

Reason for Shutdown/Malfunction:

- Air-Compressor System
- Blower
- High Gas Flow
- High Temperature
- LEL
- Low Gas Flow
- Low Temperature
- UV Scanner System
- Power Failure
- Scheduled Preventive Maintenance

**PM MONITORING**

Name \_\_\_\_\_  
Arrival Time \_\_\_\_\_ Departure Time \_\_\_\_\_  
GEM# \_\_\_\_\_ Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %

Flare Operation	Te/hp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3			

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			

Back Up Generator Running yes / no

Control Room Bypass yes / no

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed isolating all LFG in the piping system to avoid excess emissions, and notified the staff.

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.

Comments and/or Description of Malfunction and Affected Equipment:

Emission Exceedence: yes\* / no

SSM Plan Procedures Followed: yes / no\*

If SSM Plan Procedure not followed, explain procedure used:

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc. continued on the back side? yes / no

Signature

Date

**SSM PLAN REPORT FORM /  
FLARE STATION DAILY CHECKLIST**  
City of Mountain View Flare Station

Date 10-6-22  
S m t w th f s

**AM MONITORING**

Name LEON ROSALES

Arrival Time 7:30 AM Departure Time 7:41 AM

GEM# ENV #4 Manometer (yes) no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>43.2</u>	<u>31.3</u>	<u>2.6</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1	<u>1627</u>	<u>1.66"</u>	<u>91</u>
Flare #2			
Flare #3	<u>1634</u>	<u>1.00"</u>	<u>285</u>

Blower Oper.	RPM	Hours
Blower #1		
Blower #2	<u>2100</u>	<u>63460.6</u>
Blower #3		

Air Compressor Hours: 10147.7

Google SCFM: am: 47 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>46.5</u>	<u>43.5</u>	<u>38.3</u>
CO2 %	<u>33.0</u>	<u>32.1</u>	<u>28.4</u>
O2 %	<u>2.0</u>	<u>1.1</u>	<u>5.1</u>
Vacuum	<u>-41.0"</u>	<u>-40.1"</u>	<u>-40.9"</u>
SCFM	<u>193</u>	<u>157</u>	<u>132</u>
Temperature	<u>75</u>	<u>75</u>	<u>73</u>

Time of Shutdown:

Time of Start-Up:

Duration of Shutdown/Malfunction:

Reason for Shutdown/Malfunction:

- Air-Compressor System
- Blower
- High Gas Flow
- High Temperature
- LEL
- Low Gas Flow
- Low Temperature
- UV Scanner System
- Power Failure
- Scheduled Preventive Maintenance

**PM MONITORING**

Name \_\_\_\_\_

Arrival Time \_\_\_\_\_ Departure Time \_\_\_\_\_

GEM# \_\_\_\_\_ Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3			

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			

Back Up Generator Running yes / no

Control Room Bypass yes / no

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed isolating all LFG in the piping system to avoid excess emissions, and notified the staff.

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.

Comments and/or Description  
of Malfunction and Affected Equipment:

Time of Shutdown:
Time of Start-Up:
Duration of Shutdown/Malfunction:

Emission Exceedence: yes\* / no

SSM Plan Procedures Followed: yes / no\*

If SSM Plan Procedure not followed, explain procedure used:

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc. continued on the back side? yes / no

Signature

Date

**SSM PLAN REPORT FORM /  
FLARE STATION DAILY CHECKLIST**  
City of Mountain View Flare Station

Date 10-12-22  
 S m t w th f s

**AM MONITORING**

Name LEON ROSARIO

Arrival Time 7:58 am Departure Time 8:11 am

GEM# ENV #4 Manometer (yes) no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>41.7</u>	<u>31.2</u>	<u>2.9</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1	<u>1629</u>	<u>1.71"</u>	<u>92</u>
Flare #2			
Flare #3	<u>1622</u>	<u>1.02"</u>	<u>286</u>

Blower Oper.	RPM	Hours
Blower #1		
Blower #2	<u>2100</u>	<u>63605.4</u>
Blower #3		

Air Compressor Hours: 10202.4

Google SCFM: am: 49 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>45.0</u>	<u>43.3</u>	<u>35.6</u>
CO2 %	<u>32.2</u>	<u>32.0</u>	<u>26.4</u>
O2 %	<u>2.2</u>	<u>1.1</u>	<u>5.9</u>
Vacuum	<u>-41.1"</u>	<u>-40.2"</u>	<u>-41.0"</u>
SCFM	<u>194</u>	<u>157</u>	<u>140</u>
Temperature	<u>74</u>	<u>75</u>	<u>73</u>

Time of Shutdown:

Time of Start-Up:

Duration of Shutdown/Malfunction:

Reason for Shutdown/Malfunction:

- Air-Compressor System
- Blower
- High Gas Flow
- High Temperature
- LEL
- Low Gas Flow
- Low Temperature
- UV Scanner System
- Power Failure
- Scheduled Preventive Maintenance

**PM MONITORING**

Name \_\_\_\_\_

Arrival Time \_\_\_\_\_ Departure Time \_\_\_\_\_

GEM# \_\_\_\_\_ Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3			

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			

Back Up Generator Running yes / no

Control Room Bypass yes / no

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed isolating all LFG in the piping system to avoid excess emissions, and notified the staff.

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.

Comments and/or Description  
of Malfunction and Affected Equipment:

Time of Shutdown:
Time of Start-Up:
Duration of Shutdown/Malfunction:

Emission Exceedence: yes\* / no

SSM Plan Procedures Followed: yes / no\*

If SSM Plan Procedure not followed, explain procedure used:

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc. continued on the back side? yes / no

Signature \_\_\_\_\_

Date \_\_\_\_\_

**SSM PLAN REPORT FORM /  
FLARE STATION DAILY CHECKLIST**  
City of Mountain View Flare Station

Date October 13<sup>th</sup>, 2022  
S m t w th f s

**AM MONITORING**

Name Jason R. Bean

Arrival Time 7:04pm Departure Time 7:20am

GEM# Envision #4 Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>43.8</u>	<u>31.6</u>	<u>2.5</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1	<u>1633</u>	<u>1.72"</u>	<u>93</u>
Flare #2			
Flare #3	<u>1628</u>	<u>1.05"</u>	<u>291</u>

Blower Oper.	RPM	Hours
Blower #1		
Blower #2	<u>2100</u>	<u>636.288</u>
Blower #3		

Air Compressor Hours: 10210.0

Google SCFM: am: 49 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>46.7</u>	<u>44.0</u>	<u>38.8</u>
CO2 %	<u>32.7</u>	<u>32.2</u>	<u>27.7</u>
O2 %	<u>1.7</u>	<u>1.0</u>	<u>5.2</u>
Vacuum	<u>-41.0"</u>	<u>-40.0"</u>	<u>-40.7"</u>
SCFM	<u>194</u>	<u>157</u>	<u>140</u>
Temperature	<u>74</u>	<u>75</u>	<u>73</u>

Time of Shutdown:

Time of Start-Up:

Duration of Shutdown/Malfunction:

Reason for Shutdown/Malfunction:

- Air-Compressor System
- Blower
- High Gas Flow
- High Temperature
- LEL
- Low Gas Flow
- Low Temperature
- UV Scanner System
- Power Failure
- Scheduled Preventive Maintenance

**PM MONITORING**

Name \_\_\_\_\_

Arrival Time \_\_\_\_\_ Departure Time \_\_\_\_\_

GEM# \_\_\_\_\_ Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3			

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			

Back Up Generator Running yes / no

Control Room Bypass yes / no

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed isolating all LFG in the piping system to avoid excess emissions, and notified the staff.

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.

Comments and/or Description of Malfunction and Affected Equipment:

---



---



---

Emission Exceedence: yes\* / no

SSM Plan Procedures Followed: yes / no\*

If SSM Plan Procedure not followed, explain procedure used:

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc. continued on the back side? yes / no

Signature \_\_\_\_\_

Date \_\_\_\_\_

**SSM PLAN REPORT FORM /  
FLARE STATION DAILY CHECKLIST**  
City of Mountain View Flare Station

Date

October 9th, 2022

S m t w th f s

**AM MONITORING**

Name JOSON R. Bean  
Arrival Time 6:43PM Departure Time 6:58AM  
GEM# ENVISION #4 Manometer yes no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>43.3</u>	<u>31.2</u>	<u>2.5</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1	<u>1621</u>	<u>1.05"</u>	<u>96</u>
Flare #2			
Flare #3	<u>1634</u>	<u>1.14"</u>	<u>303</u>

Blower Oper.	RPM	Hours
Blower #1		
Blower #2	<u>2100</u>	<u>63712.1</u>
Blower #3		

Air Compressor Hours: 10263.9

Google SCFM: am: 42 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>46.3</u>	<u>43.9</u>	<u>38.4</u>
CO2 %	<u>32.5</u>	<u>32.0</u>	<u>28.0</u>
O2 %	<u>1.9</u>	<u>0.9</u>	<u>4.9</u>
Vacuum	<u>-41.3"</u>	<u>-40.3"</u>	<u>-41.0"</u>
SCFM	<u>187</u>	<u>156</u>	<u>126</u>
Temperature	<u>73</u>	<u>74</u>	<u>71</u>

Time of Shutdown:

Time of Start-Up:

Duration of Shutdown/Malfunction:

Reason for Shutdown/Malfunction:

- Air-Compressor System
- Blower
- High Gas Flow
- High Temperature
- LEL
- Low Gas Flow
- Low Temperature
- UV Scanner System
- Power Failure
- Scheduled Preventive Maintenance

**PM MONITORING**

Name \_\_\_\_\_  
Arrival Time \_\_\_\_\_ Departure Time \_\_\_\_\_  
GEM# \_\_\_\_\_ Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3			

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			

Back Up Generator Running yes / no

Control Room Bypass yes / no

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed isolating all LFG in the piping system to avoid excess emissions, and notified the staff.

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.

Comments and/or Description of Malfunction and Affected Equipment:

Emission Exceedence: yes\* / no

SSM Plan Procedures Followed: yes / no\*

If SSM Plan Procedure not followed, explain procedure used:

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc. continued on the back side? yes / no

Signature

Date

**SSM PLAN REPORT FORM /  
FLARE STATION DAILY CHECKLIST**  
City of Mountain View Flare Station

Date 10-20-22  
s m t w **th** f s

**AM MONITORING**

Name LEON Rosales

Arrival Time 7:41 AM Departure Time 7:52 AM

GEM# ENV #4

Manometer yes no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>43.8</u>	<u>32.5</u>	<u>2.4</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1	<u>1620</u>	<u>1.60"</u>	<u>90</u>
Flare #2			
Flare #3	<u>1624</u>	<u>0.96"</u>	<u>278</u>

Blower Oper.	RPM	Hours
Blower #1		
Blower #2	<u>2100</u>	<u>63797.1</u>
Blower #3		

Air Compressor Hours: 10271.9

Google SCFM: am: A2 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>47.3</u>	<u>44.5</u>	<u>38.7</u>
CO2 %	<u>32.6</u>	<u>32.0</u>	<u>28.0</u>
O2 %	<u>1.9</u>	<u>1.0</u>	<u>9.9</u>
Vacuum	<u>-41.2</u>	<u>-40.3</u>	<u>-41.0</u>
SCFM	<u>189</u>	<u>157</u>	<u>132</u>
Temperature	<u>73</u>	<u>73</u>	<u>71</u>

**PM MONITORING**

Name \_\_\_\_\_

Arrival Time \_\_\_\_\_ Departure Time \_\_\_\_\_

GEM# \_\_\_\_\_ Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3			

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			

Back Up Generator Running yes / no

Control Room Bypass yes / no

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed, isolating all LFG in the piping system to avoid excess emissions, and notified the staff.

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.

Comments and/or Description of Malfunction and Affected Equipment:

Time of Shutdown:

Time of Start-Up:

Duration of Shutdown/Malfunction:

Reason for Shutdown/Malfunction:

- Air-Compressor System
- Blower
- High Gas Flow
- High Temperature
- LEL
- Low Gas Flow
- Low Temperature
- UV Scanner System
- Power Failure
- Scheduled Preventive Maintenance

Emission Exceedence: yes\* / no

SSM Plan Procedures Followed: yes / no\*

If SSM Plan Procedure not followed, explain procedure used:

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc. continued on the back side? yes / no

Signature

Date

**SSM PLAN REPORT FORM /**  
**FLARE STATION DAILY CHECKLIST**  
 City of Mountain View Flare Station

Date 10/27/22  
 s m t w **th** f s

**AM MONITORING**

Name LEON VASQUEZ  
 Arrival Time 8:18 Am Departure Time 8:46 Am  
 GEM# GIV #4 Manometer (yes) no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>43.2</u>	<u>31.4</u>	<u>2.9</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1	<u>1612</u>	<u>1.59"</u>	<u>90</u>
Flare #2	<u>/</u>	<u>/</u>	<u>/</u>
Flare #3	<u>1615</u>	<u>1.62"</u>	<u>288</u>

Blower Oper.	RPM	Hours
Blower #1	<u>/</u>	<u>/</u>
Blower #2	<u>2100</u>	<u>63965.0</u>
Blower #3	<u>/</u>	<u>/</u>

Air Compressor Hours: 10333.6

Google SCFM: am: 27 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>48.3</u>	<u>44.1</u>	<u>34.7</u>
CO2 %	<u>33.3</u>	<u>32.6</u>	<u>25.4</u>
O2 %	<u>1.5</u>	<u>0.9</u>	<u>6.1</u>
Vacuum	<u>-42.0"</u>	<u>-41.1"</u>	<u>-41.7</u>
SCFM	<u>150</u>	<u>156</u>	<u>123</u>
Temperature	<u>70</u>	<u>72</u>	<u>68</u>

Time of Shutdown: 8:20 am

Time of Start-Up: 8:33 am

Duration of Shutdown/Malfunction: 13 min

Reason for Shutdown/Malfunction:

- Air-Compressor System
- Blower
- High Gas Flow
- High Temperature
- LEL
- Low Gas Flow
- Low Temperature
- UV Scanner System
- Power Failure
- Scheduled Preventive Maintenance

Take flare #1 out of  
Alarm

**PM MONITORING**

Name \_\_\_\_\_  
 Arrival Time \_\_\_\_\_ Departure Time \_\_\_\_\_  
 GEM# \_\_\_\_\_ Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3			

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			

Back Up Generator Running yes / no

Control Room Bypass yes / no

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed isolating all LFG in the piping system to avoid excess emissions, and notified the staff.

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.

Comments and/or Description of Malfunction and Affected Equipment:

yes / no

Emission Exceedence:

yes\* / no

SSM Plan Procedures Followed:


yes / no\*

If SSM Plan Procedure not followed, explain procedure used:

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc. continued on the back side?

yes / no

Signature 

Date 10/27/22

**SSM PLAN REPORT FORM /  
FLARE STATION DAILY CHECKLIST**  
City of Mountain View Flare Station

Date November 2<sup>nd</sup>, 2022  
 S m t w th f s

**AM MONITORING**

Name JASON R. BRAUN  
 Arrival Time 7:10 AM Departure Time 7:22 PM  
 GEM# ENVISION #4 Manometer  yes  no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>41.2</u>	<u>30.8</u>	<u>3.4</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1	<u>1632</u>	<u>1.60"</u>	<u>90</u>
Flare #2			
Flare #3	<u>1631</u>	<u>1.02"</u>	<u>289</u>

Blower Oper.	RPM	Hours
Blower #1		
Blower #2		
Blower #3	<u>2100</u>	<u>304142</u>

Air Compressor Hours: 10377.2

Google SCFM: am: 34 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>46.7</u>	<u>44.1</u>	<u>34.2</u>
CO2 %	<u>33.4</u>	<u>32.3</u>	<u>25.6</u>
O2 %	<u>2.3</u>	<u>1.2</u>	<u>6.4</u>
Vacuum	<u>-42.2"</u>	<u>-41.3"</u>	<u>-42.0"</u>
SCFM	<u>153</u>	<u>184</u>	<u>158</u>
Temperature	<u>69</u>	<u>70</u>	<u>68</u>

**PM MONITORING**

Name \_\_\_\_\_  
 Arrival Time \_\_\_\_\_ Departure Time \_\_\_\_\_  
 GEM# \_\_\_\_\_ Manometer \_\_\_\_\_ yes / no

LFG to Flares

CH4 %	CO2 %	O2 %

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3			

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			

Back Up Generator Running yes /  no

Control Room Bypass yes /  no

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed isolating all LFG in the piping system to avoid excess emissions, and notified the staff.

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.

Comments and/or Description of Malfunction and Affected Equipment:

Time of Shutdown:	<u>7:20 AM</u>
Time of Start-Up:	<u>8:51 AM</u>
Duration of Shutdown/Malfunction:	<u>1hr 31 min</u>

Emission Exceedence: yes\* /  no

SSM Plan Procedures Followed:  yes / no\*

If SSM Plan Procedure not followed, explain procedure used:

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc. continued on the back side?

yes  no

Jason R. Braun  
 Signature Date 11/2/22

**SSM PLAN REPORT FORM /  
FLARE STATION DAILY CHECKLIST**  
City of Mountain View Flare Station

Date November 3<sup>rd</sup>, 2022

s m t w  f s

**AM MONITORING**

Name Adrian Vega

Arrival Time 7:00 AM Departure Time 7:15 AM

GEM# ENVISION #4 Manometer  yes / no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>41.1</u>	<u>30.7</u>	<u>3.5</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3	<u>1625</u>	<u>1.46"</u>	<u>3617</u>

Blower Oper.	RPM	Hours
Blower #1		
Blower #2		
Blower #3	<u>2100</u>	<u>304365</u>

Air Compressor Hours: 10385.1

Google SCFM: am: 33 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>47.1</u>	<u>42.9</u>	<u>32.7</u>
CO2 %	<u>33.8</u>	<u>32.3</u>	<u>24.8</u>
O2 %	<u>2.3</u>	<u>1.4</u>	<u>7.0</u>
Vacuum	<u>-42.7"</u>	<u>-41.1"</u>	<u>-41.9"</u>
SCFM	<u>155</u>	<u>113</u>	<u>164</u>
Temperature	<u>68</u>	<u>69</u>	<u>67</u>

**PM MONITORING**

Name \_\_\_\_\_

Arrival Time \_\_\_\_\_ Departure Time \_\_\_\_\_

GEM# \_\_\_\_\_ Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3			

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			

Back Up Generator Running yes /

Control Room Bypass yes /

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed isolating all LFG in the piping system to avoid excess emissions, and notified the staff.

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.

Comments and/or Description of Malfunction and Affected Equipment:

Time of Shutdown:	<u>7:24 AM</u>
Time of Start-Up:	<u>10:53 AM</u>
Duration of Shutdown/Malfunction:	<u>3hr 29min</u>

Emission Exceedence: yes\* /

SSM Plan Procedures Followed:  yes\* / no\*

If SSM Plan Procedure not followed, explain procedure used:

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc. continued on the back side?

yes /

Signature 

Date 11/03/22

**SSM PLAN REPORT FORM /  
FLARE STATION DAILY CHECKLIST**  
City of Mountain View Flare Station

Date Monday 7<sup>th</sup>, 2022

s m t w th f s

**AM MONITORING**

Name Miguel Vazela

Arrival Time 6:38 Departure Time 6:49

GEM# ENVISION #4 Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>40.1</u>	<u>30.7</u>	<u>4.0</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1	<u>1632</u>	<u>1.95</u>	<u>99</u>
Flare #2	<u>/</u>	<u>/</u>	<u>/</u>
Flare #3	<u>1620</u>	<u>1.24</u>	<u>318</u>

Blower Oper.	RPM	Hours
Blower #1	<u>/</u>	<u>/</u>
Blower #2	<u>/</u>	<u>/</u>
Blower #3	<u>2100</u>	<u>3053.04</u>

Air Compressor Hours: 10420.7

Google SCFM: am: 35 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>47.3</u>	<u>43.3</u>	<u>30.3</u>
CO2 %	<u>34.0</u>	<u>32.7</u>	<u>22.7</u>
O2 %	<u>2.3</u>	<u>1.4</u>	<u>7.9</u>
Vacuum	<u>-41.7</u>	<u>-40.4</u>	<u>-41.4</u>
SCFM	<u>154</u>	<u>228</u>	<u>158</u>
Temperature	<u>67</u>	<u>69</u>	<u>67</u>

Time of Shutdown:

Time of Start-Up:

Duration of Shutdown/Malfunction:

Reason for Shutdown/Malfunction:

- Air-Compressor System
- Blower
- High Gas Flow
- High Temperature
- LEL
- Low Gas Flow
- Low Temperature
- UV Scanner System
- Power Failure
- Scheduled Preventive Maintenance

**PM MONITORING**

Name \_\_\_\_\_

Arrival Time \_\_\_\_\_ Departure Time \_\_\_\_\_

GEM# \_\_\_\_\_ Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3			

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			

Back Up Generator Running yes / no

Control Room Bypass yes / no

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed isolating all LFG in the piping system to avoid excess emissions, and notified the staff.

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.

Comments and/or Description  
of Malfunction and Affected Equipment:

Time of Shutdown:
Time of Start-Up:
Duration of Shutdown/Malfunction:

Emission Exceedence: yes\* / no

SSM Plan Procedures Followed: yes / no\*

If SSM Plan Procedure not followed, explain procedure used:

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc. continued on the back side? yes / no

Signature \_\_\_\_\_

Date \_\_\_\_\_

**SSM PLAN REPORT FORM /  
FLARE STATION DAILY CHECKLIST**  
City of Mountain View Flare Station

Date November 10<sup>th</sup>, 2022  
s m t w th f s

**AM MONITORING**

Name Jason R. Bean  
Arrival Time 6:40 AM Departure Time 6:51 AM  
GEM# ENVISION #4 Manometer (yes) no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>42.4</u>	<u>31.1</u>	<u>21.7</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1	<u>1625</u>	<u>1.55"</u>	<u>89</u>
Flare #2			
Flare #3	<u>1621</u>	<u>0.96"</u>	<u>284</u>

Blower Oper.	RPM	Hours
Blower #1		
Blower #2		
Blower #3	<u>2100</u>	<u>30602.4</u>

Air Compressor Hours: 10449.2

Google SCFM: am: 33 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>46.5</u>	<u>43.1</u>	<u>36.8</u>
CO2 %	<u>32.9</u>	<u>32.1</u>	<u>27.9</u>
O2 %	<u>2.1</u>	<u>1.4</u>	<u>4.8</u>
Vacuum	<u>-43.0"</u>	<u>-42.2"</u>	<u>-43.0"</u>
SCFM	<u>176</u>	<u>230</u>	<u>127</u>
Temperature	<u>65</u>	<u>68</u>	<u>65</u>

Time of Shutdown:

Time of Start-Up:

Duration of Shutdown/Malfunction:

Reason for Shutdown/Malfunction:

- Air-Compressor System
- Blower
- High Gas Flow
- High Temperature
- LEL
- Low Gas Flow
- Low Temperature
- UV Scanner System
- Power Failure
- Scheduled Preventive Maintenance

**PM MONITORING**

Name \_\_\_\_\_  
Arrival Time \_\_\_\_\_ Departure Time \_\_\_\_\_  
GEM# \_\_\_\_\_ Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3			

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			

Back Up Generator Running yes / no

Control Room Bypass yes / no

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed isolating all LFG in the piping system to avoid excess emissions, and notified the staff.

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.

Comments and/or Description  
of Malfunction and Affected Equipment:

Time of Shutdown:
Time of Start-Up:
Duration of Shutdown/Malfunction:

Emission Exceedence: yes\* / no

SSM Plan Procedures Followed: yes / no\*

If SSM Plan Procedure not followed, explain procedure used:

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other  
information, etc. continued on the back side? yes / no

Signature

Date

**SSM PLAN REPORT FORM /  
FLARE STATION DAILY CHECKLIST**  
City of Mountain View Flare Station

Date November 14<sup>th</sup>, 2022  
 s       t      w      th      f      s

**AM MONITORING**

Name Miguel Varela

Arrival Time 7:30 A.M. Departure Time 7:50 A.M.

GEM# ENVISION #4

Manometer

yes    no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>43.1</u>	<u>32.1</u>	<u>2.6</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1	<u>1632</u>	<u>1.56"</u>	<u>90</u>
Flare #2	<u>/</u>	<u>/</u>	<u>/</u>
Flare #3	<u>1627</u>	<u>0.94"</u>	<u>282</u>

Blower Oper.	RPM	Hours
Blower #1	<u>/</u>	<u>/</u>
Blower #2	<u>/</u>	<u>/</u>
Blower #3	<u>290</u>	<u>396.93</u>

Air Compressor Hours: 10486.9

Google SCFM: am: 33 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>47.9</u>	<u>42.8</u>	<u>36.9</u>
CO2 %	<u>34.3</u>	<u>32.6</u>	<u>27.3</u>
O2 %	<u>1.6</u>	<u>1.0</u>	<u>5.7</u>
Vacuum	<u>-42.8"</u>	<u>-41.8"</u>	<u>-42.6"</u>
SCFM	<u>175</u>	<u>238</u>	<u>130</u>
Temperature	<u>63</u>	<u>66</u>	<u>63</u>

**PM MONITORING**

Name \_\_\_\_\_

Arrival Time \_\_\_\_\_ Departure Time \_\_\_\_\_

GEM# \_\_\_\_\_ Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3			

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			

Back Up Generator Running yes / no

Control Room Bypass yes / no

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed isolating all LFG in the piping system to avoid excess emissions, and notified the staff.

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.

Comments and/or Description of Malfunction and Affected Equipment:

Time of Shutdown:

Time of Start-Up:

Duration of Shutdown/Malfunction:

Reason for Shutdown/Malfunction:

- Air-Compressor System
- Blower
- High Gas Flow
- High Temperature
- LEL
- Low Gas Flow
- Low Temperature
- UV Scanner System
- Power Failure
- Scheduled Preventive Maintenance

Emission Exceedence: yes\* / no

SSM Plan Procedures Followed: yes / no\*

If SSM Plan Procedure not followed, explain procedure used:

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc. continued on the back side? yes / no

Signature

Date

**SSM PLAN REPORT FORM /  
FLARE STATION DAILY CHECKLIST**  
City of Mountain View Flare Station

Date November 15<sup>th</sup>, 2022  
s m t w th f s

**AM MONITORING**

Name Miguel Vazquez

Arrival Time 6:55 A.M. Departure Time 7:05 A.M.

GEM# ENVISION#4 Manometer (yes) no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>42.9</u>	<u>31.8</u>	<u>2.6</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1	<u>1631</u>	<u>1.53"</u>	<u>89</u>
Flare #2	<u>/</u>	<u>/</u>	<u>/</u>
Flare #3	<u>1632</u>	<u>0.93"</u>	<u>278</u>

Blower Oper.	RPM	Hours
Blower #1	<u>/</u>	<u>/</u>
Blower #2	<u>/</u>	<u>/</u>
Blower #3	<u>2100</u>	<u>307228</u>

Air Compressor Hours: 10494.7

Google SCFM: am: 32 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>46.9</u>	<u>42.2</u>	<u>37.2</u>
CO2 %	<u>34.6</u>	<u>32.5</u>	<u>27.3</u>
O2 %	<u>1.9</u>	<u>1.0</u>	<u>5.9</u>
Vacuum	<u>-42.7"</u>	<u>-41.7"</u>	<u>-42.6"</u>
SCFM	<u>175</u>	<u>231</u>	<u>78</u>
Temperature	<u>63</u>	<u>66</u>	<u>64</u>

**PM MONITORING**

Name \_\_\_\_\_

Arrival Time \_\_\_\_\_

Departure Time \_\_\_\_\_

GEM# \_\_\_\_\_

Manometer \_\_\_\_\_

yes / no

LFG to Flares

CH4 %	CO2 %	O2 %

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3			

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			

Back Up Generator Running yes / no

Control Room Bypass yes / no

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed isolating all LFG in the piping system to avoid excess emissions, and notified the staff.

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.

Comments and/or Description  
of Malfunction and Affected Equipment:

Time of Shutdown:

Time of Start-Up:

Duration of Shutdown/Malfunction:

Reason for Shutdown/Malfunction:

- Air-Compressor System
- Blower
- High Gas Flow
- High Temperature
- LEL
- Low Gas Flow
- Low Temperature
- UV Scanner System
- Power Failure
- Scheduled Preventive Maintenance

Emission Exceedence: yes\* / no

SSM Plan Procedures Followed: yes / no\*

If SSM Plan Procedure not followed, explain procedure used:

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc. continued on the back side? yes / no

Signature \_\_\_\_\_

Date \_\_\_\_\_

**SSM PLAN REPORT FORM /  
FLARE STATION DAILY CHECKLIST**  
City of Mountain View Flare Station

Date November 17<sup>th</sup> 2022

s m t w th f s

**AM MONITORING**

Name Adrian Vega

Arrival Time 7:15 AM Departure Time 7:30 AM

GEM# Envision #4

Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>43.2</u>	<u>32.4</u>	<u>2.7</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3	<u>1636</u>	<u>1.17"</u>	<u>381</u>

Blower Oper.	RPM	Hours
Blower #1		
Blower #2		
Blower #3	<u>2100</u>	<u>30790.5</u>

Air Compressor Hours: 10510.9

Google SCFM: am: 10 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>48.4</u>	<u>42.5</u>	<u>36.9</u>
CO2 %	<u>33.7</u>	<u>32.6</u>	<u>26.6</u>
O2 %	<u>1.3</u>	<u>1.0</u>	<u>0.2</u>
Vacuum	<u>-42.8"</u>	<u>-41.8"</u>	<u>-42.7"</u>
SCFM	<u>196</u>	<u>235</u>	<u>122</u>
Temperature	<u>62</u>	<u>65</u>	<u>63</u>

**PM MONITORING**

Name \_\_\_\_\_

Arrival Time \_\_\_\_\_ Departure Time \_\_\_\_\_

GEM# \_\_\_\_\_ Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3			

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			

Back Up Generator Running yes / no

Control Room Bypass yes / no

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed, isolating all LFG in the piping system to avoid excess emissions, and notified the staff.

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.

Comments and/or Description of Malfunction and Affected Equipment:

Time of Shutdown:

Time of Start-Up:

Duration of Shutdown/Malfunction:

Reason for Shutdown/Malfunction:

- Air-Compressor System
- Blower
- High Gas Flow
- High Temperature
- LEL
- Low Gas Flow
- Low Temperature
- UV Scanner System
- Power Failure
- Scheduled Preventive Maintenance

Emission Exceedence: yes\* / no

SSM Plan Procedures Followed: yes / no\*

If SSM Plan Procedure not followed, explain procedure used:

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc. continued on the back side? yes / no

Signature \_\_\_\_\_

Date \_\_\_\_\_

**SSM PLAN REPORT FORM /**  
**FLARE STATION DAILY CHECKLIST**  
 City of Mountain View Flare Station

Date

December 1<sup>ST</sup>, 2022

S M T W **TH** F S

**AM MONITORING**

Name JASON R BEAN

Arrival Time 7:45 AM Departure Time 7:53 AM

GEM# EVOLVNT #4 Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>44.0</u>	<u>31.0</u>	<u>2.8</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1	<u>1620</u>	<u>1.44"</u>	<u>86</u>
Flare #2			
Flare #3	<u>1621</u>	<u>0.95"</u>	<u>281</u>

Blower Oper.	RPM	Hours
Blower #1	<u>2100</u>	<u>19140.4</u>
Blower #2		
Blower #3		

Air Compressor Hours: 10619.6

Google SCFM: am: 33 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>49.5</u>	<u>44.7</u>	<u>34.4</u>
CO2 %	<u>34.8</u>	<u>33.3</u>	<u>24.6</u>
O2 %	<u>1.6</u>	<u>0.8</u>	<u>6.9</u>
Vacuum	<u>-41.7"</u>	<u>-40.6"</u>	<u>-41.1"</u>
SCFM	<u>181</u>	<u>227</u>	<u>116</u>
Temperature	<u>60</u>	<u>63</u>	<u>62</u>

Time of Shutdown:

Time of Start-Up:

Duration of Shutdown/Malfunction:

Reason for Shutdown/Malfunction:

- Air-Compressor System
- Blower
- High Gas Flow
- High Temperature
- LEL
- Low Gas Flow
- Low Temperature
- UV Scanner System
- Power Failure
- Scheduled Preventive Maintenance

**PM MONITORING**

Name \_\_\_\_\_

Arrival Time \_\_\_\_\_

Departure Time \_\_\_\_\_

GEM# \_\_\_\_\_

Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3			

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			

Back Up Generator Running yes / no

Control Room Bypass yes / no

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed isolating all LFG in the piping system to avoid excess emissions, and notified the staff.

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.

Comments and/or Description of Malfunction and Affected Equipment:

Time of Shutdown:

Time of Start-Up:

Duration of Shutdown/Malfunction:

Emission Exceedence: yes\* / no

SSM Plan Procedures Followed: yes / no\*

If SSM Plan Procedure not followed, explain procedure used:

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc. continued on the back side? yes / no

Signature \_\_\_\_\_

Date \_\_\_\_\_

**SSM PLAN REPORT FORM /  
FLARE STATION DAILY CHECKLIST**  
City of Mountain View Flare Station

Date December 13<sup>th</sup>, 2022  
 S m t w th f s

**AM MONITORING**

Name JASON R. Bean  
 Arrival Time 6:51 AM Departure Time 7:01 AM  
 GEM# ENVION #4 Manometer (yes) no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>40.7</u>	<u>30.0</u>	<u>3.9</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3	<u>1615</u>	<u>146"</u>	<u>349</u>

Blower Oper.	RPM	Hours
Blower #1	<u>2100</u>	<u>19427.4</u>
Blower #2		
Blower #3		

Air Compressor Hours: 10710.8

Google SCFM: am: 54 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>43.8</u>	<u>42.5</u>	<u>32.8</u>
CO2 %	<u>31.5</u>	<u>32.4</u>	<u>23.5</u>
O2 %	<u>3.2</u>	<u>1.3</u>	<u>8.4</u>
Vacuum	<u>-42.4"</u>	<u>-41.6"</u>	<u>-42.2"</u>
SCFM	<u>186</u>	<u>235</u>	<u>130</u>
Temperature	<u>57</u>	<u>60</u>	<u>58</u>

Time of Shutdown:

Time of Start-Up:

Duration of Shutdown/Malfunction:

Reason for Shutdown/Malfunction:

- Air-Compressor System
- Blower
- High Gas Flow
- High Temperature
- LEL
- Low Gas Flow
- Low Temperature
- UV Scanner System
- Power Failure
- Scheduled Preventive Maintenance

**PM MONITORING**

Name \_\_\_\_\_  
 Arrival Time \_\_\_\_\_ Departure Time \_\_\_\_\_  
 GEM# \_\_\_\_\_ Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %

Flare Operation	Ts(np.)	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3			

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			

Back Up Generator Running yes / no

Control Room Bypass yes / no

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed isolating all LFG in the piping system to avoid excess emissions, and notified the staff.

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.

Comments and/or Description of Malfunction and Affected Equipment:

Emission Exceedence: yes\* / no

SSM Plan Procedures Followed: yes / no\*

If SSM Plan Procedure not followed, explain procedure used:

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc. continued on the back side? yes / no

Signature

Date

**SSM PLAN REPORT FORM /  
FLARE STATION DAILY CHECKLIST**  
City of Mountain View Flare Station

Date 12-15-22  
s m t w th f s

**AM MONITORING**

Name LEON KOSTER  
Arrival Time 8:17 AM Departure Time 8:32 AM  
GEM# ENV #4 Manometer (yes) no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>44.8</u>	<u>32.1</u>	<u>2.3</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1	/	/	/
Flare #2	/	/	/
Flare #3	<u>1624</u>	<u>1.29"</u>	<u>330</u>

Blower Oper.	RPM	Hours
Blower #1	<u>2100</u>	<u>19476.8</u>
Blower #2	/	/
Blower #3	/	/

Air Compressor Hours: 10726.7

Google SCFM: am: 31 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>46.6</u>	<u>43.1</u>	<u>44.3</u>
CO2 %	<u>32.9</u>	<u>32.3</u>	<u>30.5</u>
O2 %	<u>2.7</u>	<u>1.0</u>	<u>3.7</u>
Vacuum	<u>-42.6"</u>	<u>-41.6"</u>	<u>-41.4"</u>
SCFM	<u>187</u>	<u>731</u>	<u>96</u>
Temperature	<u>57</u>	<u>60</u>	<u>57</u>

Time of Shutdown:

Time of Start-Up:

Duration of Shutdown/Malfunction:

Reason for Shutdown/Malfunction:

- Air-Compressor System
- Blower
- High Gas Flow
- High Temperature
- LEL
- Low Gas Flow
- Low Temperature
- UV Scanner System
- Power Failure
- Scheduled Preventive Maintenance

**PM MONITORING**

Name \_\_\_\_\_  
Arrival Time \_\_\_\_\_ Departure Time \_\_\_\_\_  
GEM# \_\_\_\_\_ Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %

Flare Operation	Temp.	Vac.	SCFM
Flare #1	/	/	/
Flare #2	/	/	/
Flare #3			

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			

Back Up Generator Running yes / no

Control Room Bypass yes / no

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed, isolating all LFG in the piping system to avoid excess emissions, and notified the staff.

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.

Comments and/or Description  
of Malfunction and Affected Equipment:

Emission Exceedence: yes\* / no

SSM Plan Procedures Followed: yes / no\*

If SSM Plan Procedure not followed, explain procedure used:

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc. continued on the back side? yes / no

Signature

Date

**SSM PLAN REPORT FORM /  
FLARE STATION DAILY CHECKLIST**  
City of Mountain View Flare Station

Date December 19<sup>th</sup>, 2022  
 s m t w th f s

**AM MONITORING**

Name Adrian Vega

Arrival Time 7:05 AM Departure Time 7:20 AM

GEM# Envision #4 Manometer yes no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>42.4</u>	<u>32.9</u>	<u>2.4</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1	<u>1632</u>	<u>1.14"</u>	<u>78</u>
Flare #2			
Flare #3	<u>1626</u>	<u>0.77"</u>	<u>255</u>

Blower Oper.	RPM	Hours
Blower #1	<u>2100</u>	<u>19571.4</u>
Blower #2		
Blower #3		

Air Compressor Hours: 10757.2

Google SCFM: am: 33 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>43.0</u>	<u>42.0</u>	<u>42.9</u>
CO2 %	<u>32.1</u>	<u>32.7</u>	<u>30.9</u>
O2 %	<u>2.9</u>	<u>1.2</u>	<u>4.0</u>
Vacuum	<u>-43.4"</u>	<u>-42.5"</u>	<u>-43.3"</u>
SCFM	<u>187</u>	<u>244</u>	<u>87</u>
Temperature	<u>55</u>	<u>59</u>	<u>55</u>

**PM MONITORING**

Name \_\_\_\_\_

Arrival Time \_\_\_\_\_ Departure Time \_\_\_\_\_

GEM# \_\_\_\_\_ Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3			

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			

Back Up Generator Running yes / no

Control Room Bypass yes / no

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed isolating all LFG in the piping system to avoid excess emissions, and notified the staff.

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.

Comments and/or Description of Malfunction and Affected Equipment:

Time of Shutdown:

Time of Start-Up:

Duration of Shutdown/Malfunction:

Reason for Shutdown/Malfunction:

- Air-Compressor System
- Blower
- High Gas Flow
- High Temperature
- LEL
- Low Gas Flow
- Low Temperature
- UV Scanner System
- Power Failure
- Scheduled Preventive Maintenance

Emission Exceedence: yes\* / no

SSM Plan Procedures Followed: yes / no\*

If SSM Plan Procedure not followed, explain procedure used:

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc. continued on the back side? yes / no

Signature

Date

**SSM PLAN REPORT FORM /  
FLARE STATION DAILY CHECKLIST**  
City of Mountain View Flare Station

Date 12-20-22  
s m t w th f s

**AM MONITORING**

Name Leon Rosario  
Arrival Time 7:40 AM Departure Time 7:49 AM  
GEM# ENV # 4 Manometer (yes) no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>43.5</u>	<u>32.3</u>	<u>2.5</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1	<u>1681</u>	<u>207"</u>	<u>104</u>
Flare #2	<u>/</u>	<u>/</u>	<u>/</u>
Flare #3	<u>1664</u>	<u>1.90"</u>	<u>339</u>

Blower Oper.	RPM	Hours
Blower #1	<u>7100</u>	<u>19596.0</u>
Blower #2	<u>/</u>	<u>/</u>
Blower #3	<u>/</u>	<u>/</u>

Air Compressor Hours: 10765.1

Google SCFM: am: 32 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>44.1</u>	<u>41.6</u>	<u>42.8</u>
CO2 %	<u>32.9</u>	<u>37.9</u>	<u>29.8</u>
O2 %	<u>2.8</u>	<u>1.0</u>	<u>3.8</u>
Vacuum	<u>-42.5"</u>	<u>-41.6"</u>	<u>-42.4"</u>
SCFM	<u>184</u>	<u>239</u>	<u>80</u>
Temperature	<u>56</u>	<u>59</u>	<u>57</u>

**PM MONITORING**

Name \_\_\_\_\_  
Arrival Time \_\_\_\_\_ Departure Time \_\_\_\_\_  
GEM# \_\_\_\_\_ Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3			

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			

Back Up Generator Running yes / no

Control Room Bypass yes / no

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed isolating all LFG in the piping system to avoid excess emissions, and notified the staff.

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.

Comments and/or Description of Malfunction and Affected Equipment:

Time of Shutdown: 10:27 AM  
Time of Start-Up: 12:25 PM  
Duration of Shutdown/Malfunction: 1 hr 58 min

Reason for Shutdown/Malfunction:

- Air-Compressor System     Blower     High Gas Flow
- High Temperature     LEL     Low Gas Flow
- Low Temperature     UV Scanner System
- Power Failure     Scheduled Preventive Maintenance

Annual A/C maintenance  
by O&P compression

Signature 

Date 12/20/22

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc. continued on the back side?

yes / no

**SSM PLAN REPORT FORM /  
FLARE STATION DAILY CHECKLIST**  
City of Mountain View Flare Station

Date December 21<sup>st</sup>, 2022  
s m t  th f s

**AM MONITORING**

Name Adrian Vega  
Arrival Time 6:10 AM Departure Time 6:22 AM  
GEM# Envision #4 Manometer  yes / no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>44.7</u>	<u>39.0</u>	<u>21</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1	<u>1615</u>	<u>1.48"</u>	<u>88</u>
Flare #2			
Flare #3	<u>1616</u>	<u>1.00"</u>	<u>290</u>

Blower Oper.	RPM	Hours
Blower #1	<u>2100</u>	<u>19616.5</u>
Blower #2		
Blower #3		

Air Compressor Hours: 10773.5

Google SCFM: am: 31 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>47.9</u>	<u>42.2</u>	<u>43.4</u>
CO2 %	<u>34.0</u>	<u>32.4</u>	<u>30.4</u>
O2 %	<u>1.7</u>	<u>1.1</u>	<u>3.9</u>
Vacuum	<u>-43.0"</u>	<u>-49.1"</u>	<u>-42.9"</u>
SCFM	<u>180</u>	<u>242</u>	<u>90</u>
Temperature	<u>55</u>	<u>59</u>	<u>57</u>

Time of Shutdown:

Time of Start-Up:

Duration of Shutdown/Malfunction:

Reason for Shutdown/Malfunction:

- Air-Compressor System
- Blower
- High Gas Flow
- High Temperature
- LEL
- Low Gas Flow
- Low Temperature
- UV Scanner System
- Power Failure
- Scheduled Preventive Maintenance

**PM MONITORING**

Name \_\_\_\_\_  
Arrival Time \_\_\_\_\_ Departure Time \_\_\_\_\_  
GEM# \_\_\_\_\_ Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3			

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			

Back Up Generator Running yes / no

Control Room Bypass yes / no

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed isolating all LFG in the piping system to avoid excess emissions, and notified the staff.

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.

Comments and/or Description of Malfunction and Affected Equipment:

---



---



---

Emission Exceedence: yes\* / no

SSM Plan Procedures Followed: yes / no\*

If SSM Plan Procedure not followed, explain procedure used:

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc. continued on the back side? yes / no

Signature

Date

**SSM PLAN REPORT FORM /  
FLARE STATION DAILY CHECKLIST**  
City of Mountain View Flare Station

Date December 22<sup>nd</sup>, 2022  
 S m t w  f s

**AM MONITORING**

Name Adrian Vega

Arrival Time 7:10AM

Departure Time 7:26AM

GEM# Envision #4

Manometer yes no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>42.1</u>	<u>30.9</u>	<u>3.2</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1	<u>1629</u>	<u>1.57"</u>	<u>91</u>
Flare #2	<u>/</u>	<u>/</u>	<u>/</u>
Flare #3	<u>1618</u>	<u>1.05"</u>	<u>297</u>

Blower Oper.	RPM	Hours
Blower #1	<u>2100</u>	<u>19641.6</u>
Blower #2	<u>/</u>	<u>/</u>
Blower #3	<u>/</u>	<u>/</u>

Air Compressor Hours: 10781.6

Google SCFM: am: 33 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>47.4</u>	<u>42.9</u>	<u>32.0</u>
CO2 %	<u>33.8</u>	<u>33.0</u>	<u>23.2</u>
O2 %	<u>1.8</u>	<u>1.0</u>	<u>8.5</u>
Vacuum	<u>-42.3"</u>	<u>-41.3"</u>	<u>-42.1"</u>
SCFM	<u>199</u>	<u>236</u>	<u>121</u>
Temperature	<u>56</u>	<u>59</u>	<u>58</u>

Time of Shutdown:

Time of Start-Up:

Duration of Shutdown/Malfunction:

Reason for Shutdown/Malfunction:

- Air-Compressor System
- Blower
- High Gas Flow
- High Temperature
- LEL
- Low Gas Flow
- Low Temperature
- UV Scanner System
- Power Failure
- Scheduled Preventive Maintenance

**PM MONITORING**

Name \_\_\_\_\_

Arrival Time \_\_\_\_\_

Departure Time \_\_\_\_\_

GEM# \_\_\_\_\_

Manometer

yes / no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>/</u>	<u>/</u>	<u>/</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1	<u>/</u>	<u>/</u>	<u>/</u>
Flare #2	<u>/</u>	<u>/</u>	<u>/</u>
Flare #3	<u>/</u>	<u>/</u>	<u>/</u>

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum	<u>/</u>	<u>/</u>	<u>/</u>
SCFM	<u>/</u>	<u>/</u>	<u>/</u>

Back Up Generator Running yes / no

Control Room Bypass yes / no

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed isolating all LFG in the piping system to avoid excess emissions, and notified the staff.

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.

Comments and/or Description of Malfunction and Affected Equipment:

Time of Shutdown:

Time of Start-Up:

Duration of Shutdown/Malfunction:

Emission Exceedence: yes\* / no

SSM Plan Procedures Followed: yes / no\*

If SSM Plan Procedure not followed, explain procedure used:

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc. continued on the back side? yes / no

Signature

Date

**SSM PLAN REPORT FORM /  
FLARE STATION DAILY CHECKLIST**  
City of Mountain View Flare Station

Date December 28<sup>th</sup>, 2022  
s m t w **th** f s

**AM MONITORING**

Name JASON R. BEAN  
Arrival Time 8:02 AM Departure Time 8:13 AM  
GEM# ENVISION #4 Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>46.1</u>	<u>34.5</u>	<u>14</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3	<u>1624</u>	<u>1.23"</u>	<u>320</u>

Blower Oper.	RPM	Hours
Blower #1	<u>2100</u>	<u>19786.5</u>
Blower #2		
Blower #3		

Air Compressor Hours: 10823.0

Google SCFM: am: 30 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>48.4</u>	<u>43.5</u>	<u>47.1</u>
CO2 %	<u>35.1</u>	<u>33.7</u>	<u>32.4</u>
O2 %	<u>1.1</u>	<u>0.9</u>	<u>2.5</u>
Vacuum	<u>-424"</u>	<u>-41.4"</u>	<u>-42.3"</u>
SCFM	<u>179</u>	<u>237</u>	<u>71</u>
Temperature	<u>56</u>	<u>58</u>	<u>54</u>

Time of Shutdown:

Time of Start-Up:

Duration of Shutdown/Malfunction:

Reason for Shutdown/Malfunction:

- Air-Compressor System
- Blower
- High Gas Flow
- High Temperature
- LEL
- Low Gas Flow
- Low Temperature
- UV Scanner System
- Power Failure
- Scheduled Preventive Maintenance

**PM MONITORING**

Name \_\_\_\_\_  
Arrival Time \_\_\_\_\_ Departure Time \_\_\_\_\_  
GEM# \_\_\_\_\_ Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3			

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			

Back Up Generator Running yes / no

Control Room Bypass yes / no

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed isolating all LFG in the piping system to avoid excess emissions, and notified the staff.

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.

Comments and/or Description  
of Malfunction and Affected Equipment:

Emission Exceedence: yes\* / no

SSM Plan Procedures Followed: yes / no\*

If SSM Plan Procedure not followed, explain procedure used:

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc. continued on the back side? yes / no

Signature

Date

**SSM PLAN REPORT FORM /  
FLARE STATION DAILY CHECKLIST**  
City of Mountain View Flare Station

Date December 29<sup>th</sup>, 2012  
 S M T W **Th** F S

**AM MONITORING**

Name JASON R BEAN  
 Arrival Time 8:00 AM Departure Time 8:15 AM  
 GEM# ENVISUN #4 Manometer (yes) no

LFG to Flares

CH4 %	CO2 %	O2 %
<u>48.1</u>	<u>31.1</u>	<u>1.2</u>

Flare Operation	Temp.	Vac.	SCFM
Flare #1	/	/	/
Flare #2	/	/	/
Flare #3	<u>162.7</u>	<u>1.14"</u>	<u>294</u>

Blower Oper.	RPM	Hours
Blower #1	<u>2100</u>	<u>198106</u>
Blower #2	/	/
Blower #3	/	/

Air Compressor Hours: 10837.0

Google SCFM: am: 27 pm:

LFG at Inlets	6A NE	Vista	F9 / B9
CH4 %	<u>51.5</u>	<u>44.6</u>	<u>46.4</u>
CO2 %	<u>36.2</u>	<u>34.3</u>	<u>32.9</u>
O2 %	<u>0.8</u>	<u>0.9</u>	<u>2.9</u>
Vacuum	<u>-41.7"</u>	<u>-40.8"</u>	<u>-41.7"</u>
SCFM	<u>119</u>	<u>239</u>	<u>60</u>
Temperature	<u>57</u>	<u>59</u>	<u>57</u>

**PM MONITORING**

Name \_\_\_\_\_  
 Arrival Time \_\_\_\_\_ Departure Time \_\_\_\_\_  
 GEM# \_\_\_\_\_ Manometer yes / no

LFG to Flares

CH4 %	CO2 %	O2 %

Flare Operation	Temp.	Vac.	SCFM
Flare #1			
Flare #2			
Flare #3			

LFG at Inlets	6A NE	Vista	F9 / B9
Vacuum			
SCFM			

Back Up Generator Running yes / no

Control Room Bypass yes / no

The facility's program logic controller automatically reacted diligently and expeditiously to shut down the flare station, closed the shutdown valve as programmed isolating all LFG in the piping system to avoid excess emissions, and notified the staff.

The program logic controller or staff restarted the flare station and / or back-up generator in a diligent and expeditious manner to avoid excess emissions.

Comments and/or Description  
of Malfunction and Affected Equipment:

Time of Shutdown:

Time of Start-Up:

Duration of Shutdown/Malfunction:

Reason for Shutdown/Malfunction:

- Air-Compressor System
- Blower
- High Gas Flow
- High Temperature
- LEL
- Low Gas Flow
- Low Temperature
- UV Scanner System
- Power Failure
- Scheduled Preventive Maintenance

Emission Exceedence: yes\* / no

SSM Plan Procedures Followed: yes / no\*

If SSM Plan Procedure not followed, explain procedure used:

\* If Emission Exceedence or SSM Procedures are not followed it must be reported to EPA/BAAQMD within 24 hours per SSM plan. (Report to EEC immediately and complete departure report)

Are any comments, descriptions, other information, etc. continued on the back side? yes / no

Signature

Date

## SECTION VII

# CONTINUOUS TEMPERATURE AND FLOW MONITORING RECORDS

[Process Trends](#)[Comm Trends](#)

Trend Selection:

Flare Station

GO

Duration

1 Hour

6 Hour

12 Hour


1 Day

3 Days

Custom

Reset Chart

Normal



[Process Trends](#)[Comm Trends](#)


Trend Selection:

Flare Station

GO

Duration

- 1 Hour
- 6 Hour
- 12 Hour
- 1 Day
- 3 Days
- Custom**

[Reset Chart](#)**Nirmal**


[Process Trends](#)[Comm Trends](#)

Trend Selection:

Flare Station

GO


Trending Station: Flare Station



Duration

- 1 Hour
- 6 Hour
- 12 Hour
- 1 Day
- 3 Days
- Custom**

Hist.MOC\_Host.R46Flr6Temp.F\_CV  
Hist.MOC\_Host.R46Flr7Temp.F\_CV  
Hist.MOC\_Host.R46Flr8Temp.F\_CV  
Hist.MOC\_Host.R46Flr6aFlow.F\_CV  
Hist.MOC\_Host.R46Flr7aFlow.F\_CV  
Hist.MOC\_Host.R46Flr8aFlow.F\_CV



[Process Trends](#)[Comm Trends](#)


Trend Selection:

Flare Station


GO

Duration

- 1 Hour
- 6 Hour
- 12 Hour
- 1 Day
- 3 Days
- Custom**

[Reset Chart](#)**Nirmal**

File Message : MV FLARE STATION  
 File Name : 000036\_220825\_093400.DAD  
 Device Type : DX2000  
 Serial No. : S5X404709  
 Time Correction : None  
 Starting Condition : Auto  
 Dividing Condition : Auto  
 Meas Ch. : 30  
 Math Ch. : 0  
 Ext Ch. : 0  
 Data Count : 7200  
 Sampling Interval : 120.000 sec  
 Start Time : 2022/08/25 09:34:00.000  
 Stop Time : 2022/09/04 09:32:00.000  
 Trigger Time : 2022/09/04 09:32:00.000  
 Trigger No. : 7199  
 Damage Check : Not Damaged  
 Started by : [ Key In ]  
 Stopped by : [ Running ]  
 Printed Group : GROUP 1  
 Printed Range : 2022/08/31 03:58:00.000 - 2022/08/31 23:58:00.000  
 Comment :



[Process Trends](#)[Comm Trends](#)


Trend Selection:

Flare Station

GO

Duration

- 1 Hour
- 6 Hour
- 12 Hour
- 1 Day
- 3 Days
- Custom**

**Nirmal**

Flare 6 Temperature (deg F) (F.CV)  
Flare 7 Temperature (deg F) (F.CV)  
Flare 8 Temp (deg F) (F.CV)  
Flare 1 - A6 Flow  
Flare 2 - A7 Flow  
Flare 3 - A8 Flow

1632.22  
267.93  
1630.22  
104.00  
0.00  
339.15

scfm  
scfm  
scfm



[Process Trends](#)[Comm Trends](#)

Trend Selection:

Flare Station

GO

Duration

1 Hour

6 Hour

12 Hour


1 Day

3 Days

Custom

Reset Chart

Normal




[Process Trends](#)[Comm Trends](#)

Trend Selection:

Flare Station

GO



Duration

- 1 Hour
- 6 Hour
- 12 Hour
- 1 Day
- 3 Days
- Custom**

[Process Trends](#)[Comm Trends](#)


Trend Selection:

Flare Station

GO

Duration

- 1 Hour
- 6 Hour
- 12 Hour
- 1 Day
- 3 Days
- Custom**


[Reset Chart](#)**Nirmal**

[Process Trends](#)[Comm Trends](#)

Trend Selection:

Flare Station

GO



Duration

1 Hour
6 Hour
12 Hour
1 Day
3 Days
<b>Custom</b>
<a href="#">Reset Chart</a>

Normal

[Process Trends](#)[Comm Trends](#)


Trend Selection:

Flare Station

GO

Duration

- 1 Hour
- 6 Hour
- 12 Hour
- 1 Day
- 3 Days
- Custom**

**Nirmal**

[Process Trends](#)[Comm Trends](#)


Trend Selection:

Flare Station

GO

Duration

- 1 Hour
- 6 Hour
- 12 Hour
- 1 Day
- 3 Days
- Custom**

[Reset Chart](#)**Nirmal**

[Process Trends](#)[Comm Trends](#)

Trend Selection:


Flare Station

GO

Duration

- 1 Hour
- 6 Hour
- 12 Hour
- 1 Day
- 3 Days
- Custom

Normal



## **SECTION VIII**

### **LANDFILL GAS FLOW METER CALIBRATION**

**CITY OF MOUNTAIN VIEW  
LANDFILL GAS FLOW METER CALIBRATION  
July 1 - December 31, 2022**

**Annual Landfill Gas Flowmeter calibration was performed on February 16, 2022 and  
reported in the 2022 First Increment Semi-Annual Report.**