KINDER MORGAN
SFPP, L.P.

May 27, 2026

SFPP, L.P.

TV Tracking #: 1366 (Semi-Annual)

1. ☐ RECEIVED IN ENFORCEMENT: 05/27/2026

Director of Compliance and Enforcement
Bay Area Air District
375 Beale Street, Suite 600
San Francisco, CA 94105

Subject: **Title V Semi-Annual Monitoring Report for the period of November 1, 2025 through April 30, 2026 for SFPP, L.P. San Jose Terminal**
Plant ID #4020
Site Address: 2150 Kruse Drive, San Jose, CA 95131

Attn: Title V Reports

SFPP, L.P ("SFPP") submits the enclosed Semi-Annual Monitoring report in accordance with Section I.F. of the Final Major Facility Review Permit issued to Facility #A4020, SFPP San Jose Terminal. The Semi-Annual Monitoring Report covers the period from November 1, 2025 through April 30, 2026.

If you have any questions, please contact me at (713) 420-6076 or Seth_Tate@kindermorgan.com.

Sincerely,

Seth Tate
Sr. Air Permitting & Compliance Specialist
for SFPP, L.P.

cc: Nick Hawley, Todd Wagner, Dan Wittenberg, Nina Mcafee – SFPP, L.P.

Electronic Submittal

FedEx Tracking No.: 8723 0284 6245

Bay Area Air Quality Management District

375 Beale St, Suite 600, San Francisco, CA. 94105
Telephone: (415) 771-6000

Report of Required Monitoring
TITLE V Operating Permit

Facility Name: SFPP, L.P. San Jose Terminal

Address: 2150 Kruse Drive, San Jose, California 95131

Title V Permit Number: A4020

Reporting Period: November 1, 2025 through April 30, 2026

I hereby certify that I am a Responsible Official for the above named facility as defined in 40 Code of Federal Regulations, Part 70.2. I further certify that, based on information and belief formed after reasonable inquiry, the statements and information in this certification are true, accurate, and complete.

Daniel Wittenberg — Signature of Responsible Official

5/26/2026 — Date

Daniel Wittenberg

Name of Responsible Official (please print)

Director of Operations

Title of Responsible Official (please print)

Title V Semi-Annual Monitoring Verification Report for Period November 1, 2025 through April 30, 2026

Table VII - A
Applicable Limits and Compliance Monitoring Requirements
S1, S28, S29, S30, S31, S32 – LOADING RACKS, 1, 2, 3, 4, 5, 6

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status during Period: "Continuous"; "Intermittent"; or "Not in Compliance"	Additional Information
POC	BAAQMD 8-33-301.2	N		0.04 lb/1000 gallons	BAAQMD 8-33-309-4; 8-33-309.13; CARB Certification	C: P/9-15 months	Parametric; Source test; Recordkeeping; Notification	Continuous	
POC	BAAQMD 8-33-308	N		< 3,000 ppm as methane or 6% of the lel	BAAQMD 8-33-308.2; BAAQMD Condition #7492, part 5d, and part 9	C; P/weekly	Infrared HC Analyzer; Recordkeeping	Continuous	
POC	BAAQMD 8-33-309.2	N		18 in. of water column	BAAQMD 8-33-309.11, and BAAQMD Condition #7492, part 5b	P/during product loading	Pressure gauge; Recordkeeping	Continuous	
POC	SIP 8-33-301	Y		9.6 g/1000 liters (0.08 lb/1000 gallons)	CARB Certification	P/ 6 months; throughput limit revision	Source test, Recordkeeping	Continuous	
	SIP 8-33-308	Y		3,000 ppm as methane and 6.8 Kg (15 pounds) per day	BAAQMD Condition #7492, part 5d, and part 9	C	Infrared HC Analyzer	Continuous	
	SIP 8-33-309	Y		46 cm (18 in.) of water column	BAAQMD 8-33-309.11, and BAAQMD Condition #7492, part 5b	P/during product loading	Pressure gauge	Continuous	
	40 CFR 60.502(b)	Y		35 g/1000 liters	40 CFR 60.503(c)	P/6 months	Source test	Continuous	
POC	40 CFR 60.502(e)	Y		Vapor-tight gasoline tank trucks	40 CFR 60.505(b)	P/during product loading, and within 2 weeks	Vapor tightness documents	Continuous	

Title V Semi-Annual Monitoring Verification Report for Period November 1, 2025 through April 30, 2026

Table VII - A
Applicable Limits and Compliance Monitoring Requirements
S1, S28, S29, S30, S31, S32 – LOADING RACKS, 1, 2, 3, 4, 5, 6

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status during Period: "Continuous"; "Intermittent"; or "Not in Compliance"	Additional Information
	40 CFR 63.11088(a)	Y		80 mg/liters	40 CFR 63.11092(a)	P/6 months	Source test	Continuous	
	40 CFR 63.11088(a)	Y		Vapor-tight gasoline tank trucks	40 CFR 63.11092(f) (1)	P/annual	Certification test documents	Continuous	
	BAAQMD Condition #7492, part 7	Y		200 ppm as propane	BAAQMD Condition #7492, part 5c	P/C	Infrared HC Analyzer	Continuous	
Total material throughput limit	BAAQMD Condition #7492, part 2	Y		200,000 gallons/hr	BAAQMD Condition #7492, part 4	P/H	Record- keeping	Continuous	
Total material throughput limit	BAAQMD Condition #7492, part 3	Y		4,000,000 gallons/day 1,519,400,000 gallon/yr	BAAQMD Condition #7492, part 4	P/D	Record keeping	Continuous	
POC	BAAQMD Condition #7492, parts 13, and 14	Y		Operating temperature 600 degree Fahrenheit	BAAQMD Condition #7492, parts 15, and 17	C	Record Keeping	Continuous	
POC	BAAQMD Condition #7492, part 12	Y		Destruction efficiency 98.5%	BAAQMD Condition #7492, parts 13 and 17	C	Record Keeping	Continuous	
POC	BAAQMD Condition #7492, part 18	Y		Operating Mode	BAAQMD Regulation 2-6-409.7	P/Mode change	Record Keeping	Continuous	

Title V Semi-Annual Monitoring Verification Report for Period November 1, 2025 through April 30, 2026

Table VII - B
Applicable Limits and Compliance Monitoring Requirements
S2, S5, S19, S23, S26 - STORAGE TANKS - INTERNAL FLOATING ROOF

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status during Period: "Continuous"; "Intermittent"; or "Not in Compliance"	Additional Information
POC	BAAQMD 8-5-303.1	N		PVV set within 10% of max pressure or 25.8 mmHg (0.5 psia)	BAAQMD 8-5-403 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	BAAQMD 8-5-320.3.1	N		Gasket cover $\leq$ 0.32 cm (1/8 in) gap	BAAQMD 8-5-402.3 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	BAAQMD 8-5-320.3.2	N		Inaccessible opening no visible gap	BAAQMD 8-5-402.3 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	BAAQMD 8-5-320.4.2	N		Solid sampling or gauging wells in closed position with cover, seal or lid $\leq$ 0.32 cm (1/8 in)	BAAQMD 8-5-402.3 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	BAAQMD 8-5-320.4.3	N		Solid sampling or gauging wells: Gap between well and roof shall be added to gaps measured $\leq$ 1.3 cm (1/2 in)	BAAQMD 8-5-402.3 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	BAAQMD 8-5-320.5.2	N		Slotted sampling or gauging wells in closed position with cover, seal or lid $\leq$ 1.3 cm (1/2 in)	BAAQMD 8-5-402.2 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	BAAQMD 8-5-320.5.3	N		Slotted sampling or gauging wells: Gap between well and roof shall be added to gaps measured $\leq$ 1.3 cm (1/2 in)	BAAQMD 8-5-402.2 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	

Title V Semi-Annual Monitoring Verification Report for Period November 1, 2025 through April 30, 2026

Table VII - B
Applicable Limits and Compliance Monitoring Requirements
S2, S5, S19, S23, S26 - STORAGE TANKS - INTERNAL FLOATING ROOF

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status during Period: "Continuous"; "Intermittent"; or "Not in Compliance"	Additional Information
POC	BAAQMD 8-5-320.6	Y		Emergency roof drain with slotted membrane fabric cover $\geq$ 90% opening area	BAAQMD 8-5-402 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	BAAQMD 8-5-321.1	N		No holes, tears or other openings in the primary seal fabric	BAAQMD 8-5-402.2 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	BAAQMD 8-5-321.2	N		Primary seal metallic shoe or liquid mounted type	BAAQMD 8-5-402.1 8-5-404	P/10 yr P/10 yr	Inspection Certification	Continuous	
POC	BAAQMD 8-5-321.3	N		Primary seal metallic shoe extends minimum 61 cm (24 in) for external floating and 18 in for internal Floating Roof tank above liquid surface	BAAQMD 8-5-401, 8-5-404	P/10 yr P/10 yr	Inspection Certification	Continuous	
POC	BAAQMD 8-5-321.3.1	N		Gap between shoe and tank shell is no greater than 46 cm (18 in)	BAAQMD 8-5-401, 8-5-404	P/10 yr P/10 yr	Inspection Certification	Continuous	

Title V Semi-Annual Monitoring Verification Report for Period November 1, 2025 through April 30, 2026

Table VII - B
Applicable Limits and Compliance Monitoring Requirements
S2, S5, S19, S23, S26 - STORAGE TANKS - INTERNAL FLOATING ROOF

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status during Period: "Continuous"; "Intermittent"; or "Not in Compliance"	Additional Information
POC	BAAQMD 8-5-321.3.2	N		For welded tanks, gap between tank shell and the primary seal < 3.8 cm (1 1/2 in). No continuous gap > 0.32 cm ((1/8 in) shall exceed 10% of circumference. The cumulative length of all seal gaps exceeding 1.3 cm (1/2 in) < 10% of circumference and the cumulative length of all seal gaps exceeding 0.32 cm (1/8 in) < 40% of circumference	BAAQMD 8-5-401, 8-5- 404	P/10 yr P/10 yr	Inspection Certification	Continuous	
POC	BAAQMD 8-5-322.1	N		No holes, tears, or other openings	BAAQMD 8-5-402.2 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	BAAQMD 8-5-322.2	N		Secondary seal shall allow insertion up to 3.8 cm (1 ½ in) in width	BAAQMD 8-5-402, & 8-5-404	P/10 yr P/10 yr	Inspection Certification	Continuous	
POC	BAAQMD 8-5-322.3	N		Gap between tank shell and the secondary seal shall not exceed 1.3 cm (1/2 in)	BAAQMD 8-5-402, & 8-5-404	P/10 yr P/10 yr	Inspection Certification	Continuous	
POC	BAAQMD 8-5-328.1	N		Tank $\geq$ 75 m^3, Tank cleaning 90% control, POC concentration < 10,000 ppm	BAAQMD 8-5-502	P/A	Source Test	Continuous	
POC	SIP 8-5-303.1	Y		PVV set within 10% of max pressure or 25.8 mmHg (0.5 psia)	SIP 8-5-403 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	

Title V Semi-Annual Monitoring Verification Report for Period November 1, 2025 through April 30, 2026

Table VII - B
Applicable Limits and Compliance Monitoring Requirements
S2, S5, S19, S23, S26 - STORAGE TANKS - INTERNAL FLOATING ROOF

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status during Period: "Continuous"; "Intermittent"; or "Not in Compliance"	Additional Information
POC	SIP 8-320.3.1	Y		Gasket cover ≤ 0.32 cm (1/8 in) gap	SIP 8-5-402.3 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	SIP 8-320.3.2	Y		Inaccessible opening no visible gap	SIP 8-5-402.3 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	SIP 8-5-320.4.2	Y		Solid sampling or gauging wells in closed position with cover, seal or lid ≤ 0.32 cm (1/8 in)	SIP 8-5-402.3 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	SIP 8-5-320.4.3	Y		Solid sampling or gauging wells: Gap between well and roof shall be added to gaps measured ≤ 1.3 cm (1/2 in)	SIP 8-5-402.3 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	SIP 8-5-320.5.2	Y		Slotted sampling or gauging wells in closed position with cover, seal or lid ≤ 1.3 cm (1/2 in)	SIP 8-5-402.2 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	SIP 8-5-320.5.3	Y		Slotted sampling or gauging wells: Gap between well and roof shall be added to gaps measured ≤ 1.3 cm (1/2 in)	SIP 8-5-402.2 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	SIP 8-5-320.6	Y		Emergency roof drain with slotted membrane fabric cover ≥ 90% opening area	SIP 8-5-402 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	SIP 8-5-321.1	Y		No holes, tears or other openings in the primary seal fabric	SIP 8-5-402.2 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	

Title V Semi-Annual Monitoring Verification Report for Period November 1, 2025 through April 30, 2026

Table VII - B
Applicable Limits and Compliance Monitoring Requirements
S2, S5, S19, S23, S26 - STORAGE TANKS - INTERNAL FLOATING ROOF

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status during Period: "Continuous"; "Intermittent"; or "Not in Compliance"	Additional Information
POC	SIP 8-5-321.2	Y		Primary seal metallic shoe or liquid mounted type	SIP 8-5-402.1 8-5-404	P/10 yr P/10 yr	Inspection Certification	Continuous	
POC	SIP 8-5-321.3	Y		Primary seal metallic shoe extends minimum 61 cm (24 in) for external floating and 18 in for internal Floating Roof tank above liquid surface	SIP 8-5-401, 8-5-404	P/10 yr P/10 yr	Inspection Certification	Continuous	
POC	SIP 8-5-321.3.1	Y		Gap between shoe and tank shell is no greater than 46 cm (18 in)	SIP 8-5-401, 8-5-404	P/10 yr P/10 yr	Inspection Certification	Continuous	
POC	SIP 8-5-321.3.2	Y		For welded tanks, gap between tank shell and the primary seal < 3.8 cm (1 1/2 in). No continuous gap > 0.32 cm (1/8 in) shall exceed 10% of circumference. The cumulative length of all seal gaps exceeding 1.3 cm (1/2 in) < 10% of circumference and the cumulative length of all seal gaps exceeding 0.32 cm (1/8 in) < 40% of circumference	SIP 8-5-401, 8-5- 404	P/10 yr P/10 yr	Inspection Certification	Continuous	
POC	SIP 8-5-322.1	Y		No holes, tears, or other openings	SIP 8-5-402.2 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	SIP 8-5-322.2	Y		Secondary seal shall allow insertion up to 3.8 cm (1 ½ in) in width	SIP 8-5-402, & 8-5-404	P/10 yr P/10 yr	Inspection Certification	Continuous	

Title V Semi-Annual Monitoring Verification Report for Period November 1, 2025 through April 30, 2026

Table VII - B
Applicable Limits and Compliance Monitoring Requirements
S2, S5, S19, S23, S26 - STORAGE TANKS - INTERNAL FLOATING ROOF

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status during Period: "Continuous"; "Intermittent"; or "Not in Compliance"	Additional Information
POC	SIP 8-5-322.3	Y		Gap between tank shell and the secondary seal shall not exceed 1.3 cm (1/2 in)	SIP 8-5-402, & 8-5-404	P/10 yr P/10 yr	Inspection Certification	Continuous	
POC	SIP 8-5-328.1.1	Y		Tank $\geq$ 75 m^3, tank cleaning shall have liquid balancing with $\leq$ 0.5 psia	None	N	None	Continuous	
POC	SIP 8-5-328.1.2	Y		Tank $\geq$ 75 m^3, Tank cleaning 90% control, POC concentration < 10,000 ppm	SIP 8-5-502	P/A	Source Test	Continuous	
POC	40 CFR 63.11087(a)	Y			40 CFR 63.11092(e)(1)	P/E, 1 or 5 or 10 yrs	Visual Inspection, Recordkeeping	Continuous	Note: SFPP follows NESHAP WW as allowed in 40 CFR 60.110b(e)(5)
Total material through-put limit	BAAQMD Condition #26356, part 1	Y		923,275,248 gallon gasoline/yr 166,086,774 gallon Jet/yr 38,866,550 gallon ethanol/yr 416,752,896 gallon diesel/yr	BAAQMD Condition #26356, part 2	P/D	Record keeping	Continuous	

Title V Semi-Annual Monitoring Verification Report for Period November 1, 2025 through April 30, 2026

Table VII - C
Applicable Limits and Compliance Monitoring Requirements
S3, S7, S8, S9, S10, S14, S17, S18, S20, S22, S25, S27, S34, S35 - STORAGE TANKS-INTERNAL FLOATING ROOF

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status during Period: "Continuous"; "Intermittent"; or "Not in Compliance"	Additional Information
POC	BAAQMD 8-5-303.1	N		PVV set within 10% of max pressure or 25.8 mmHg (0.5 psia)	BAAQMD 8-5-403 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	BAAQMD 8-5-320.3.1	N		Gasket cover $\leq$ 0.32 cm (1/8 in) gap	BAAQMD 8-5-402.3 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	BAAQMD 8-320.3.2	N		Inaccessible opening no visible gap	BAAQMD 8-5-402.3 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	BAAQMD 8-5-320.4.2	N		Solid sampling or gauging wells in closed position with cover, seal or lid $\leq$ 0.32 cm (1/8 in)	BAAQMD 8-5-402.3 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	BAAQMD 8-5-320.4.3	N		Solid sampling or gauging wells: Gap between well and roof shall be added to gaps measured $\leq$ 1.3 cm (1/2 in)	BAAQMD 8-5-402.3 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	BAAQMD 8-5-320.5.2	N		Slotted sampling or gauging wells in closed position with cover, seal or lid $\leq$ 1.3 cm (1/2 in)	BAAQMD 8-5-402.2 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	BAAQMD 8-5-320.5.3	N		Slotted sampling or gauging wells: Gap between well and roof shall be added to gaps measured $\leq$ 1.3 cm (1/2 in)	BAAQMD 8-5-402.2 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	BAAQMD 8-5-320.6	N		Emergency roof drain with slotted membrane fabric cover $\geq$ 90% opening area	BAAQMD 8-5-402 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	BAAQMD 8-5-321.1	N		No holes, tears or other openings in the primary seal fabric	BAAQMD 8-5-402.2 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	

Title V Semi-Annual Monitoring Verification Report for Period November 1, 2025 through April 30, 2026

Table VII - C
Applicable Limits and Compliance Monitoring Requirements
S3, S7, S8, S9, S10, S14, S17, S18, S20, S22, S25, S27, S34, S35 - STORAGE TANKS-INTERNAL FLOATING ROOF

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status during Period: "Continuous"; "Intermittent"; or "Not in Compliance"	Additional Information
POC	BAAQMD 8-5-321.2	N		Primary seal metallic shoe or liquid mounted type	BAAQMD 8-5-402.1 8-5-404	P/10 yr P/10 yr	Inspection Certification	Continuous	
POC	BAAQMD 8-5-321.3	N		Primary seal metallic shoe extends minimum 61 cm (24 in) for external floating and 18 in for internal Floating Roof tank above liquid surface	BAAQMD 8-5-401, 8-5-404	P/10 yr P/10 yr	Inspection Certification	Continuous	
POC	BAAQMD 8-5-321.3.1	N		Gap between shoe and tank shell is no greater than 46 cm (18 in)	BAAQMD 8-5-401, 8-5-404	P/10 yr P/10 yr	Inspection Certification	Continuous	
POC	BAAQMD 8-5-321.3.2	N		For welded tanks, gap between tank shell and the primary seal < 3.8 cm (1 1/2 in). No continuous gap > 0.32 cm ((1/8 in) shall exceed 10% of circumference. The cumulative length of all seal gaps exceeding 1.3 cm (1/2 in) < 10% of circumference and the cumulative length of all seal gaps exceeding 0.32 cm (1/8 in) < 40% of circumference	BAAQMD 8-5-401, 8-5- 404	P/10 yr P/10 yr	Inspection Certification	Continuous	
POC	BAAQMD 8-5-322.1	N		No holes, tears, or other openings	BAAQM 8-5-402.2 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	BAAQMD 8-5-322.2	N		Secondary seal shall allow insertion up to 3.8 cm (1 ½ in) in width	BAAQMD 8-5-402, & 8-5-404	P/10 yr P/10 yr	Inspection Certification	Continuous	
POC	BAAQMD 8-5-322.3	N		Gap between tank shell and the secondary seal shall not exceed 1.3 cm (1/2 in)	BAAQMD 8-5-402, & 8-5-404	P/10 yr P/10 yr	Inspection Certification	Continuous	

Title V Semi-Annual Monitoring Verification Report for Period November 1, 2025 through April 30, 2026

Table VII - C
Applicable Limits and Compliance Monitoring Requirements
S3, S7, S8, S9, S10, S14, S17, S18, S20, S22, S25, S27, S34, S35 - STORAGE TANKS-INTERNAL FLOATING ROOF

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status during Period: "Continuous"; "Intermittent"; or "Not in Compliance"	Additional Information
POC	BAAQMD 8-5-328.1	N		Tank $\geq$ 75 m^3, Tank cleaning 90% control, POC concentration < 10,000 ppm	BAAQMD 8-5-502	P/A	Source Test	Continuous	
POC	SIP 8-5-303.1	Y		PVV set within 10% of max pressure or 25.8 mmHg (0.5 psia)	SIP 8-5-403 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	SIP 8-320.3.1	Y		Gasket cover $\leq$ 0.32 cm (1/8 in) gap	SIP 8-5-402.3 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	SIP 8-320.3.2	Y		Inaccessible opening no visible gap	SIP 8-5-402.3 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	SIP 8-5-320.4.2	Y		Solid sampling or gauging wells in closed position with cover, seal or lid $\leq$ 0.32 cm (1/8 in)	SIP 8-5-402.3 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	SIP 8-5-320.4.3	Y		Solid sampling or gauging wells: Gap between well and roof shall be added to gaps measured $\leq$ 1.3 cm (1/2 in)	SIP 8-5-402.3 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	SIP 8-5-320.5.2	Y		Slotted sampling or gauging wells in closed position with cover, seal or lid $\leq$ 1.3 cm (1/2 in)	SIP 8-5-402.2 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	SIP 8-5-320.5.3	Y		Slotted sampling or gauging wells: Gap between well and roof shall be added to gaps measured $\leq$ 1.3 cm (1/2 in)	SIP 8-5-402.2 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	SIP 8-5-320.6	Y		Emergency roof drain with slotted membrane fabric cover $\geq$ 90% opening area	SIP 8-5-402 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	SIP 8-5-321.1	Y		No holes, tears or other openings in the primary seal fabric	SIP 8-5-402.2 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	

Title V Semi-Annual Monitoring Verification Report for Period November 1, 2025 through April 30, 2026

Table VII - C
Applicable Limits and Compliance Monitoring Requirements
S3, S7, S8, S9, S10, S14, S17, S18, S20, S22, S25, S27, S34, S35 - STORAGE TANKS-INTERNAL FLOATING ROOF

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status during Period: "Continuous"; "Intermittent"; or "Not in Compliance"	Additional Information
POC	SIP 8-5-321.2	Y		Primary seal metallic shoe or liquid mounted type	SIP 8-5-402.1 8-5-404	P/10 yr P/10 yr	Inspection Certification	Continuous	
POC	SIP 8-5-321.3	Y		Primary seal metallic shoe extends minimum 61 cm (24 in) for external floating and 18 in for internal Floating Roof tank above liquid surface	SIP 8-5-401, 8-5-404	P/10 yr P/10 yr	Inspection Certification	Continuous	
POC	SIP 8-5-321.3.1	Y		Gap between shoe and tank shell is no greater than 46 cm (18 in)	SIP 8-5-401, 8-5-404	P/10 yr P/10 yr	Inspection Certification	Continuous	
POC	SIP 8-5-321.3.2	Y		For welded tanks, gap between tank shell and the primary seal < 3.8 cm (1 1/2 in). No continuous gap > 0.32 cm (1/8 in) shall exceed 10% of circumference. The cumulative length of all seal gaps exceeding 1.3 cm (1/2 in) < 10% of circumference and the cumulative length of all seal gaps exceeding 0.32 cm (1/8 in) < 40% of circumference	SIP 8-5-401, 8-5- 404	P/10 yr P/10 yr	Inspection Certification	Continuous	
POC	SIP 8-5-322.1	Y		No holes, tears, or other openings	SIP 8-5-402.2 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	SIP 8-5-322.2	Y		Secondary seal shall allow insertion up to 3.8 cm (1 ½ in) in width	SIP 8-5-402, & 8-5-404	P/10 yr P/10 yr	Inspection Certification	Continuous	
POC	SIP 8-5-322.3	Y		Gap between tank shell and the secondary seal shall not exceed 1.3 cm (1/2 in)	SIP 8-5-402, & 8-5-404	P/10 yr P/10 yr	Inspection Certification	Continuous	

Title V Semi-Annual Monitoring Verification Report for Period November 1, 2025 through April 30, 2026

Table VII - C
Applicable Limits and Compliance Monitoring Requirements
S3, S7, S8, S9, S10, S14, S17, S18, S20, S22, S25, S27, S34, S35 - STORAGE TANKS-INTERNAL FLOATING ROOF

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status during Period: "Continuous"; "Intermittent"; or "Not in Compliance"	Additional Information
POC	SIP 8-5-328.1.1	Y		Tank $\geq$ 75 m^3, tank cleaning shall have liquid balancing with $\leq$ 0.5 psia	None	N	None	Continuous	
POC	SIP 8-5-328.1.2	Y		Tank $\geq$ 75 m^3, Tank cleaning 90% control, POC concentration < 10,000 ppm	SIP 8-5-502	P/A	Source Test	Continuous	
POC	40 CFR 63.11087(a)	Y			40 CFR 63.11092(e)(1)	P/E, 1 or 5 or 10 years	Visual Inspection, Recordkeeping	Continuous	Note: SFPP follows NESHAP WW as allowed in 40 CFR 60.110b(e)(5)
Total material through put limit	BAAQMD Condition #26356, part 1	Y		923,275,248 gallon gasoline/yr 166,086,774 gallon Jet/yr 38,866,550 gallon ethanol/yr 416,752,896 gallon diesel/yr	BAAQMD Condition #26356, part 2	P/D	Record keeping	Continuous	

Title V Semi-Annual Monitoring Verification Report for Period November 1, 2025 through April 30, 2026

Table VII - D
Applicable Limits and Compliance Monitoring Requirements
S6, S13, S16, S21 - STORAGE TANKS-INTERNAL FLOATING ROOF

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status during Period: "Continuous"; "Intermittent"; or "Not in Compliance"	Additional Information
POC	BAAQMD 8-5-303.1	N		PVV set within 10% of max pressure or 25.8 mmHg (0.5 psia)	BAAQMD 8-5-403 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	BAAQMD 8-320.3.1	N		Gasket cover $\leq$ 0.32 cm (1/8 in) gap	BAAQMD 8-5-402.3 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	BAAQMD 8-320.3.2	N		Inaccessible opening no visible gap	BAAQMD 8-5-402.3 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	BAAQMD 8-5-320.4.2	N		Solid sampling or gauging wells in closed position with cover, seal or lid $\leq$ 0.32 cm (1/8 in)	BAAQMD 8-5-402.3 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	BAAQMD 8-5-320.4.3	N		Solid sampling or gauging wells: Gap between well and roof shall be added to gaps measured $\leq$ 1.3 cm (1/2 in)	BAAQMD 8-5-402.3 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	BAAQMD 8-5-320.5.2	N		Slotted sampling or gauging wells in closed position with cover, seal or lid $\leq$ 1.3 cm (1/2 in)	BAAQMD 8-5-402.2 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	BAAQMD 8-5-320.5.3	N		Slotted sampling or gauging wells: Gap between well and roof shall be added to gaps measured $\leq$ 1.3 cm (1/2 in)	BAAQMD 8-5-402.2 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	BAAQMD 8-5-320.6	N		Emergency roof drain with slotted membrane fabric cover $\geq$ 90% opening area	BAAQMD 8-5-402 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	

Title V Semi-Annual Monitoring Verification Report for Period November 1, 2025 through April 30, 2026

Table VII - D
Applicable Limits and Compliance Monitoring Requirements
S6, S13, S16, S21 - STORAGE TANKS-INTERNAL FLOATING ROOF

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status during Period: "Continuous"; "Intermittent"; or "Not in Compliance"	Additional Information
POC	BAAQMD 8-5-321.1	N		No holes, tears or other openings in the primary seal fabric	BAAQMD 8-5-402.2 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	BAAQMD 8-5-321.2	N		Primary seal metallic shoe or liquid mounted type	BAAQMD 8-5-402.1 8-5-404	P/10 yr P/10 yr	Inspection Certification	Continuous	
POC	BAAQMD 8-5-321.3	N		Primary seal metallic shoe extends minimum 61 cm (24 in) for external floating and 18 in for internal Floating Roof tank above liquid surface	BAAQMD 8-5-401, 8-5-404	P/10 yr P/10 yr	Inspection Certification	Continuous	
POC	BAAQMD 8-5-321.3.1	N		Gap between shoe and tank shell is no greater than 46 cm (18 in)	BAAQMD 8-5-401, 8-5-404	P/10 yr P/10 yr	Inspection Certification	Continuous	
POC	BAAQMD 8-5-321.3.2	N		For welded tanks, gap between tank shell and the primary seal < 3.8 cm (1 1/2 in). No continuous gap > 0.32 cm (1/8 in) shall exceed 10% of circumference. The cumulative length of all seal gaps exceeding 1.3 cm (1/2 in) < 10% of circumference and the cumulative length of all seal gaps exceeding 0.32 cm (1/8 in) < 40% of circumference	BAAQMD 8-5-401, 8-5- 404	P/10 yr P/10 yr	Inspection Certification	Continuous	
POC	BAAQMD 8-5-328.1	N		Tank $\geq$ 75 m^3, Tank cleaning 90% control, POC concentration < 10,000 ppm	BAAQMD 8-5-502	P/A	Source Test	Continuous	
POC	SIP 8-5-303.1	Y		PVV set within 10% of max pressure or 25.8 mmHg (0.5 psia)	SIP 8-5-403 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	

Title V Semi-Annual Monitoring Verification Report for Period November 1, 2025 through April 30, 2026

Table VII - D
Applicable Limits and Compliance Monitoring Requirements
S6, S13, S16, S21 - STORAGE TANKS-INTERNAL FLOATING ROOF

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status during Period: "Continuous"; "Intermittent"; or "Not in Compliance"	Additional Information
POC	SIP 8-320.3.1	Y		Gasket cover $\leq$ 0.32 cm (1/8 in) gap	SIP 8-5-402.3 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	SIP 8-320.3.2	Y		Inaccessible opening no visible gap	SIP 8-5-402.3 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	SIP 8-5-320.4.2	Y		Solid sampling or gauging wells in closed position with cover, seal or lid $\leq$ 0.32 cm (1/8 in)	SIP 8-5-402.3 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	SIP 8-5-320.4.3	Y		Solid sampling or gauging wells: Gap between well and roof shall be added to gaps measured $\leq$ 1.3 cm (1/2 in)	SIP 8-5-402.3 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	SIP 8-5-320.5.2	Y		Slotted sampling or gauging wells in closed position with cover, seal or lid $\leq$ 1.3 cm (1/2 in)	SIP 8-5-402.2 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	SIP 8-5-320.5.3	Y		Slotted sampling or gauging wells: Gap between well and roof shall be added to gaps measured $\leq$ 1.3 cm (1/2 in)	SIP 8-5-402.2 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	SIP 8-5-320.6	Y		Emergency roof drain with slotted membrane fabric cover $\geq$ 90% opening area	SIP 8-5-402 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	SIP 8-5-321.1	Y		No holes, tears or other openings in the primary seal fabric	SIP 8-5-402.2 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	SIP 8-5-321.2	Y		Primary seal metallic shoe or liquid mounted type	SIP 8-5-402.1 8-5-404	P/10 yr P/10 yr	Inspection Certification	Continuous	

Title V Semi-Annual Monitoring Verification Report for Period November 1, 2025 through April 30, 2026

Table VII - D
Applicable Limits and Compliance Monitoring Requirements
S6, S13, S16, S21 - STORAGE TANKS-INTERNAL FLOATING ROOF

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status during Period: "Continuous"; "Intermittent"; or "Not in Compliance"	Additional Information
POC	SIP 8-5-321.3	Y		Primary seal metallic shoe extends minimum 61 cm (24 in) for external floating and 18 in for internal Floating Roof tank above liquid surface	SIP 8-5-401, 8-5-404	P/10 yr P/10 yr	Inspection Certification	Continuous	
POC	SIP 8-5-321.3.1	Y		Gap between shoe and tank shell is no greater than 46 cm (18 in)	SIP 8-5-401, 8-5-404	P/10 yr P/10 yr	Inspection Certification	Continuous	
POC	SIP 8-5-321.3.2	Y		For welded tanks, gap between tank shell and the primary seal < 3.8 cm (1 1/2 in). No continuous gap > 0.32 cm ((1/8 in) shall exceed 10% of circumference. The cumulative length of all seal gaps exceeding 1.3 cm (1/2 in) < 10% of circumference and the cumulative length of all seal gaps exceeding 0.32 cm (1/8 in) < 40% of circumference	SIP 8-5-401, 8-5- 404	P/10 yr P/10 yr	Inspection Certification	Continuous	
POC	SIP 8-5-328.1.1	Y		Tank $\geq$ 75 m^3, tank cleaning shall have liquid balancing with $\leq$ 0.5 psia	None	N	None	Continuous	
POC	SIP 8-5-328.1.2	Y		Tank $\geq$ 75 m^3, Tank cleaning 90% control, POC concentration < 10,000 ppm	SIP 8-5-502	P/A	Source Test	Continuous	
POC	40 CFR 63.11087 (a)	Y			40 CFR 63.11092(e)(1)	P/E, 1 or 5 or 10 yrs	Visual Inspection, Recordkeeping	Continuous	Note: SFPP follows NESHAP WW as allowed in 40 CFR 60.110b(e)(5)

Title V Semi-Annual Monitoring Verification Report for Period November 1, 2025 through April 30, 2026

Table VII - D
Applicable Limits and Compliance Monitoring Requirements
S6, S13, S16, S21 - STORAGE TANKS-INTERNAL FLOATING ROOF

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status during Period: "Continuous"; "Intermittent"; or "Not in Compliance"	Additional Information
Total material through put limit	BAAQMD Condition #26356, part 1	Y		923,275,248 gallon gasoline/yr 166,086,774 gallon Jet/yr 38,866,550 gallon ethanol/yr 416,752,896 gallon diesel/yr	BAAQMD Condition #26356, part 2	P/M	Record keeping	Continuous	

Title V Semi-Annual Monitoring Verification Report for Period November 1, 2025 through April 30, 2026

Table VII – E
Applicable Limits and Compliance Monitoring Requirements
S12 - STORAGE TANK – INTERNAL FLOATING ROOF

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status during Period: "Continuous"; "Intermittent"; or "Not in Compliance"	Additional Information
POC	BAAQMD 8-5-303.1	N		PVV set within 10% of max pressure or 25.8 mmHg (0.5 psia)	BAAQMD 8-5-403 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	BAAQMD 8-320.3.2	N		Inaccessible opening no visible gap	BAAQMD 8-5-402.3 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	BAAQMD 8-5-320.4.2	N		Solid sampling or gauging wells in closed position with cover, seal or lid $\leq$ 0.32 cm (1/8 in)	BAAQMD 8-5-402.3 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	BAAQMD 8-5-320.4.3	N		Solid sampling or gauging wells: Gap between well and roof shall be added to gaps measured $\leq$ 1.3 cm (1/2 in)	BAAQMD 8-5-402.3 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	BAAQMD 8-5-320.5.2	N		Slotted sampling or gauging wells in closed position with cover, seal or lid $\leq$ 1.3 cm (1/2 in)	BAAQMD 8-5-402.2 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	BAAQMD 8-5-320.5.3	N		Slotted sampling or gauging wells: Gap between well and roof shall be added to gaps measured $\leq$ 1.3 cm (1/2 in)	BAAQMD 8-5-402.2 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	BAAQMD 8-5-320.6	N		Emergency roof drain with slotted membrane fabric cover $\geq$ 90% opening area	BAAQMD 8-5-402 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	BAAQMD 8-5-321.1	N		No holes, tears or other openings in the primary seal fabric	BAAQMD 8-5-402.2 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	

Title V Semi-Annual Monitoring Verification Report for Period November 1, 2025 through April 30, 2026

Table VII – E
Applicable Limits and Compliance Monitoring Requirements
S12 - STORAGE TANK – INTERNAL FLOATING ROOF

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status during Period: "Continuous"; "Intermittent"; or "Not in Compliance"	Additional Information
POC	BAAQMD 8-5-321.2	N		Primary seal metallic shoe or liquid mounted type	BAAQMD 8-5-402.1 8-5-404	P/10 yr P/10 yr	Inspection Certification	Continuous	
POC	BAAQMD 8-5-321.3	N		Primary seal metallic shoe extends minimum 61 cm (24 in) for external floating and 18 in for internal Floating Roof tank above liquid surface	BAAQMD 8-5-401, 8-5-404	P/10 yr P/10 yr	Inspection Certification	Continuous	
POC	BAAQMD 8-5-321.3.1	N		Gap between shoe and tank shell is no greater than 46 cm (18 in)	BAAQMD 8-5-401, 8-5-404	P/10 yr P/10 yr	Inspection Certification	Continuous	
POC	BAAQMD 8-5-321.3.2	N		For welded tanks, gap between tank shell and the primary seal < 3.8 cm (1 1/2 in). No continuous gap > 0.32 cm ((1/8 in) shall exceed 10% of circumference. The cumulative length of all seal gaps exceeding 1.3 cm (1/2 in) < 10% of circumference and the cumulative length of all seal gaps exceeding 0.32 cm (1/8 in) < 40% of circumference	BAAQMD 8-5-401, 8-5- 404	P/10 yr P/10 yr	Inspection Certification	Continuous	
POC	BAAQMD 8-5-328.1	N		Tank $\geq$ 75 m^3, Tank cleaning 90% control, POC concentration < 10,000 ppm	BAAQMD 8-5-502	P/A	Source Test	Continuous	
POC	SIP 8-5-303.1	Y		PVV set within 10% of max pressure or 25.8 mmHg (0.5 psia)	SIP 8-5-403 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	

Title V Semi-Annual Monitoring Verification Report for Period November 1, 2025 through April 30, 2026

Table VII – E
Applicable Limits and Compliance Monitoring Requirements
S12 - STORAGE TANK – INTERNAL FLOATING ROOF

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status during Period: "Continuous"; "Intermittent"; or "Not in Compliance"	Additional Information
POC	SIP 8-320.3.1	Y		Gasket cover ≤ 0.32 cm (1/8 in) gap	SIP 8-5-402.3 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	SIP 8-320.3.2	Y		Inaccessible opening no visible gap	SIP 8-5-402.3 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	SIP 8-5-320.4.2	Y		Solid sampling or gauging wells in closed position with cover, seal or lid ≤ 0.32 cm (1/8 in)	SIP 8-5-402.3 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	SIP 8-5-320.4.3	Y		Solid sampling or gauging wells: Gap between well and roof shall be added to gaps measured ≤ 1.3 cm (1/2 in)	SIP 8-5-402.3 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	SIP 8-5-320.5.2	Y		Slotted sampling or gauging wells in closed position with cover, seal or lid ≤ 1.3 cm (1/2 in)	SIP 8-5-402.2 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	SIP 8-5-320.5.3	Y		Slotted sampling or gauging wells: Gap between well and roof shall be added to gaps measured ≤ 1.3 cm (1/2 in)	SIP 8-5-402.2 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	SIP 8-5-320.6	Y		Emergency roof drain with slotted membrane fabric cover ≥ 90% opening area	SIP 8-5-402 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	SIP 8-5-321.1	Y		No holes, tears or other openings in the primary seal fabric	SIP 8-5-402.2 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	SIP 8-5-321.2	Y		Primary seal metallic shoe or liquid mounted type	SIP 8-5-402.1 8-5-404	P/10 yr P/10 yr	Inspection Certification	Continuous	

Title V Semi-Annual Monitoring Verification Report for Period November 1, 2025 through April 30, 2026

Table VII – E
Applicable Limits and Compliance Monitoring Requirements
S12 - STORAGE TANK – INTERNAL FLOATING ROOF

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status during Period: "Continuous"; "Intermittent"; or "Not in Compliance"	Additional Information
POC	SIP 8-5-321.3	Y		Primary seal metallic shoe extends minimum 61 cm (24 in) for external floating and 18 in for internal Floating Roof tank above liquid surface	SIP 8-5-401, 8-5-404	P/10 yr P/10 yr	Inspection Certification	Continuous	
POC	SIP 8-5-321.3.1	Y		Gap between shoe and tank shell is no greater than 46 cm (18 in)	SIP 8-5-401, 8-5-404	P/10 yr P/10 yr	Inspection Certification	Continuous	
POC	SIP 8-5-321.3.2	Y		For welded tanks, gap between tank shell and the primary seal < 3.8 cm (1 1/2 in). No continuous gap > 0.32 cm ((1/8 in) shall exceed 10% of circumference. The cumulative length of all seal gaps exceeding 1.3 cm (1/2 in) < 10% of circumference and the cumulative length of all seal gaps exceeding 0.32 cm (1/8 in) < 40% of circumference	SIP 8-5-401, 8-5- 404	P/10 yr P/10 yr	Inspection Certification	Continuous	
POC	SIP 8-5-328.1.1	Y		Tank $\geq$ 75 m^3, tank cleaning shall have liquid balancing with $\leq$ 0.5 psia	None	N	None	Continuous	
POC	SIP 8-5-328.1.2	Y		Tank $\geq$ 75 m^3, Tank cleaning 90% control, POC concentration < 10,000 ppm	SIP 8-5-502	P/A	Source Test	Continuous	
POC	40 CFR 63.11087 (a)	Y			40 CFR 63.11092(e)(1)	P/E, 1 or 5 or 10 yrs	Visual Inspection, Recordkeeping	Continuous	Note: SFPP follows NESHAP WW as allowed in 40 CFR 60.110b(e)(5)

Title V Semi-Annual Monitoring Verification Report for Period November 1, 2025 through April 30, 2026

Table VII – E
Applicable Limits and Compliance Monitoring Requirements
S12 - STORAGE TANK – INTERNAL FLOATING ROOF

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status during Period: "Continuous"; "Intermittent"; or "Not in Compliance"	Additional Information
Ethanol through-put limit	BAAQMD Condition #5406, part 1	Y		59.4 MM gallons/yr	BAAQMD Condition #5406, part 2	P/M	Recordkeeping	Continuous	

Title V Semi-Annual Monitoring Verification Report for Period November 1, 2025 through April 30, 2026

Table VII – F
Applicable Limits and Compliance Monitoring Requirements
S33, S40 - STORAGE TANKS-INTERNAL FLOATING ROOF

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status during Period: "Continuous"; "Intermittent"; or "Not in Compliance"	Additional Information
POC	BAAQMD 8-5-303.1	N		PVV set within 10% of max pressure or 25.8 mmHg (0.5 psia)	BAAQMD 8-5-403 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	BAAQMD 8-320.3.1	N		Gasket cover $\leq$ 0.32 cm (1/8 in) gap	BAAQMD 8-5-402.3 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	BAAQMD 8-320.3.2	N		Inaccessible opening no visible gap	BAAQMD 8-5-402.3 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	BAAQMD 8-5-320.4.2	N		Solid sampling or gauging wells in closed position with cover, seal or lid $\leq$ 0.32 cm (1/8 in)	BAAQMD 8-5-402.3 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	BAAQMD 8-5-320.4.3	N		Solid sampling or gauging wells: Gap between well and roof shall be added to gaps measured $\leq$ 1.3 cm (1/2 in)	BAAQMD 8-5-402.3 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	BAAQMD 8-5-320.5.2	N		Slotted sampling or gauging wells in closed position with cover, seal or lid $\leq$ 1.3 cm (1/2 in)	BAAQMD 8-5-402.2 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	BAAQMD 8-5-320.5.3	N		Slotted sampling or gauging wells: Gap between well and roof shall be added to gaps measured $\leq$ 1.3 cm (1/2 in)	BAAQMD 8-5-402.2 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	BAAQMD 8-5-320.6	N		Emergency roof drain with slotted membrane fabric cover $\geq$ 90% opening area	BAAQMD 8-5-402 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	

Title V Semi-Annual Monitoring Verification Report for Period November 1, 2025 through April 30, 2026

Table VII – F
Applicable Limits and Compliance Monitoring Requirements
S33, S40 - STORAGE TANKS-INTERNAL FLOATING ROOF

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status during Period: "Continuous"; "Intermittent"; or "Not in Compliance"	Additional Information
POC	BAAQMD 8-5-321.1	N		No holes, tears or other openings in the primary seal fabric	BAAQMD 8-5-402.2 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	BAAQMD 8-5-321.2	N		Primary seal metallic shoe or liquid mounted type	BAAQMD 8-5-402.1 8-5-404	P/10 yr P/10 yr	Inspection Certification	Continuous	
POC	BAAQMD 8-5-321.3	N		Primary seal metallic shoe extends minimum 61 cm (24 in) for external floating and 18 in for internal Floating Roof tank above liquid surface	BAAQMD 8-5-401, 8-5-404	P/10 yr P/10 yr	Inspection Certification	Continuous	
POC	BAAQMD 8-5-321.3.1	N		Gap between shoe and tank shell is no greater than 46 cm (18 in)	BAAQMD 8-5-401, 8-5-404	P/10 yr P/10 yr	Inspection Certification	Continuous	
POC	BAAQMD 8-5-321.3.2	N		For welded tanks, gap between tank shell and the primary seal < 3.8 cm (1 1/2 in). No continuous gap > 0.32 cm (1/8 in) shall exceed 10% of circumference. The cumulative length of all seal gaps exceeding 1.3 cm (1/2 in) < 10% of circumference and the cumulative length of all seal gaps exceeding 0.32 cm (1/8 in) < 40% of circumference	BAAQMD 8-5-401, 8-5- 404	P/10 yr P/10 yr	Inspection Certification	Continuous	
POC	BAAQMD 8-5-322.1	N		No holes, tears, or other openings	BAAQM 8-5-402.2 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	BAAQMD 8-5-322.2	N		Secondary seal shall allow insertion up to 3.8 cm (1 ½ in) in width	BAAQMD 8-5-402, & 8-5-404	P/10 yr P/10 yr	Inspection Certification	Continuous	

Title V Semi-Annual Monitoring Verification Report for Period November 1, 2025 through April 30, 2026

Table VII – F
Applicable Limits and Compliance Monitoring Requirements
S33, S40 - STORAGE TANKS-INTERNAL FLOATING ROOF

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status during Period: "Continuous"; "Intermittent"; or "Not in Compliance"	Additional Information
POC	BAAQMD 8-5-322.3	N		Gap between tank shell and the secondary seal shall not exceed 1.3 cm (1/2 in)	BAAQMD 8-5-402, & 8-5-404	P/10 yr P/10 yr	Inspection Certification	Continuous	
POC	BAAQMD 8-5-328.1.1	N		Tank $\geq$ 75 m^3, Tank cleaning 90% control, POC concentration < 10,000 ppm	BAAQMD 8-5-502	P/A	Source Test	Continuous	
POC	SIP 8-5-303.1	Y		PVV set within 10% of max pressure or 25.8 mmHg (0.5 psia)	SIP 8-5-403 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	SIP 8-320.3.1	Y		Gasket cover $\leq$ 0.32 cm (1/8 in) gap	SIP 8-5-402.3 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	SIP 8-320.3.2	Y		Inaccessible opening no visible gap	SIP 8-5-402.3 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	SIP 8-5-320.4.2	Y		Solid sampling or gauging wells in closed position with cover, seal or lid $\leq$ 0.32 cm (1/8 in)	SIP 8-5-402.3 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	SIP 8-5-320.4.3	Y		Solid sampling or gauging wells: Gap between well and roof shall be added to gaps measured $\leq$ 1.3 cm (1/2 in)	SIP 8-5-402.3 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	SIP 8-5-320.5.2	Y		Slotted sampling or gauging wells in closed position with cover, seal or lid $\leq$ 1.3 cm (1/2 in)	SIP 8-5-402.2 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	SIP 8-5-320.5.3	Y		Slotted sampling or gauging wells: Gap between well and roof shall be added to gaps measured $\leq$ 1.3 cm (1/2 in)	SIP 8-5-402.2 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	

Title V Semi-Annual Monitoring Verification Report for Period November 1, 2025 through April 30, 2026

Table VII – F
Applicable Limits and Compliance Monitoring Requirements
S33, S40 - STORAGE TANKS-INTERNAL FLOATING ROOF

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status during Period: "Continuous"; "Intermittent"; or "Not in Compliance"	Additional Information
POC	SIP 8-5-320.6	Y		Emergency roof drain with slotted membrane fabric cover ≥ 90% opening area	SIP 8-5-402 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	SIP 8-5-321.1	Y		No holes, tears or other openings in the primary seal fabric	SIP 8-5-402.2 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	SIP 8-5-321.2	Y		Primary seal metallic shoe or liquid mounted type	SIP 8-5-402.1 8-5-404	P/10 yr P/10 yr	Inspection Certification	Continuous	
POC	SIP 8-5-321.3	Y		Primary seal metallic shoe extends minimum 61 cm (24 in) for external floating and 18 in for internal Floating Roof tank above liquid surface	SIP 8-5-401, 8-5-404	P/10 yr P/10 yr	Inspection Certification	Continuous	
POC	SIP 8-5-321.3.1	Y		Gap between shoe and tank shell is no greater than 46 cm (18 in)	SIP 8-5-401, 8-5-404	P/10 yr P/10 yr	Inspection Certification	Continuous	
POC	SIP 8-5-321.3.2	Y		For welded tanks, gap between tank shell and the primary seal < 3.8 cm (1 1/2 in). No continuous gap > 0.32 cm ((1/8 in) shall exceed 10% of circumference. The cumulative length of all seal gaps exceeding 1.3 cm (1/2 in) < 10% of circumference and the cumulative length of all seal gaps exceeding 0.32 cm (1/8 in) < 40% of circumference	SIP 8-5-401, 8-5- 404	P/10 yr P/10 yr	Inspection Certification	Continuous	
POC	SIP 8-5-322.1	Y		No holes, tears, or other openings	SIP 8-5-402.2 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	

Title V Semi-Annual Monitoring Verification Report for Period November 1, 2025 through April 30, 2026

Table VII – F
Applicable Limits and Compliance Monitoring Requirements
S33, S40 - STORAGE TANKS-INTERNAL FLOATING ROOF

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status during Period: "Continuous"; "Intermittent"; or "Not in Compliance"	Additional Information
POC	SIP 8-5-322.2	Y		Secondary seal shall allow insertion up to 3.8 cm (1 ½ in) in width	SIP 8-5-402, & 8-5-404	P/10 yr P/10 yr	Inspection Certification	Continuous	
POC	SIP 8-5-322.3	Y		Gap between tank shell and the secondary seal shall not exceed 1.3 cm (1/2 in)	SIP 8-5-402, & 8-5-404	P/10 yr P/10 yr	Inspection Certification	Continuous	
POC	SIP 8-5-328.1.1	Y		Tank $\geq$ 75 m^3, tank cleaning shall have liquid balancing with $\leq$ 0.5 psia	None	N	None	Continuous	
POC	SIP 8-5-328.1.2	Y		Tank $\geq$ 75 m^3, Tank cleaning 90% control, POC concentration < 10,000 ppm	SIP 8-5-502	P/A	Source Test	Continuous	
POC	40 CFR 60.112b(a)(1)	Y			40 CFR 60.115b(a)(1)	P/E	Initial Report	Continuous	Note: SFPP follows NESHAP WW as allowed in 40 CFR 60.110b(e)(5)
POC	40 CFR 60.113b(a)(1)				40 CFR 60.115b(a)(2)	P/E	Visual Inspection Record keeping	Continuous	Note: SFPP follows NESHAP WW as allowed in 40 CFR 60.110b(e)(5)
POC	40 CFR 60.113b(a)(2)	Y			40 CFR 60.115b(a)(3)	P/12 month	Visual Inspection Record keeping	Continuous	Note: SFPP follows NESHAP WW as allowed in 40 CFR 60.110b(e)(5)
POC	40 CFR 63.11087(a)	Y	1/10/2011		40 CFR 63.11092(e)(1)	P/E, 1 or 5 or 10 yrs	Visual Inspection Record keeping	Continuous	Note: SFPP follows NESHAP WW as allowed in 40 CFR 60.110b(e)(5)
Total material throughput limit	BAAQMD Condition #26356, part 1	Y		923,275,248 gallon gasoline/yr 166,086,774 gallon Jet/yr 38,866,550 gallon ethanol/yr 416,752,896 gallon diesel/yr	BAAQMD Condition #26356, part 2	P/D	Record keeping	Continuous	
Liquid Stored		Y		>0.5 psia	40 CFR 601.116b(c)	P/D	Record Keeping	Continuous	Note: SFPP follows NESHAP WW as allowed in 40 CFR 60.110b(e)(5)

Title V Semi-Annual Monitoring Verification Report for Period November 1, 2025 through April 30, 2026

Table VII – F
Applicable Limits and Compliance Monitoring Requirements
S33, S40 - STORAGE TANKS-INTERNAL FLOATING ROOF

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status during Period: "Continuous"; "Intermittent"; or "Not in Compliance"	Additional Information
True Vapor Pressure		Y			40 CFR 60.116b(c)	P/D	Recordkeeping	Continuous	Note: SFPP follows NESHAP WW as allowed in 40 CFR 60.110b(e)(5)
Ture Vapor Pressure		Y		>0.74 psia	40 CFR 60.116b(d)	P/D	Notify	Continuous	Note: SFPP follows NESHAP WW as allowed in 40 CFR 60.110b(e)(5)

Title V Semi-Annual Monitoring Verification Report for Period November 1, 2025 through April 30, 2026

Table VII – G
Applicable Limits and Compliance Monitoring Requirements
S36 - STORAGE TANK-INTERNAL FLOATING ROOF

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status during Period: "Continuous"; "Intermittent"; or "Not in Compliance"	Additional Information
POC	BAAQMD 8-5-303.1	N		PVV set within 10% of max pressure or 25.8 mmHg (0.5 psia)	BAAQMD 8-5-403 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	BAAQMD 8-320.3.1	N		Gasket cover ≤ 0.32 cm (1/8 in) gap	BAAQMD 8-5-402.3 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	BAAQMD 8-320.3.2	N		Inaccessible opening no visible gap	BAAQMD 8-5-402.3 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	BAAQMD 8-5-320.4.2	N		Solid sampling or gauging wells in closed position with cover, seal or lid ≤ 0.32 cm (1/8 in)	BAAQMD 8-5-402.3 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	BAAQMD 8-5-320.4.3	N		Solid sampling or gauging wells: Gap between well and roof shall be added to gaps measured ≤ 1.3 cm (1/2 in)	BAAQMD 8-5-402.3 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	BAAQMD 8-5-320.5.2	N		Slotted sampling or gauging wells in closed position with cover, seal or lid ≤ 1.3 cm (1/2 in)	BAAQMD 8-5-402.2 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	BAAQMD 8-5-320.5.3	N		Slotted sampling or gauging wells: Gap between well and roof shall be added to gaps measured ≤ 1.3 cm (1/2 in)	BAAQMD 8-5-402.2 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	BAAQMD 8-5-320.6	N		Emergency roof drain with slotted membrane fabric cover ≥ 90% opening area	BAAQMD 8-5-402 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	BAAQMD 8-5-321.1	N		No holes, tears or other openings in the primary seal fabric	BAAQMD 8-5-402.2 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	

Title V Semi-Annual Monitoring Verification Report for Period November 1, 2025 through April 30, 2026

Table VII – G
Applicable Limits and Compliance Monitoring Requirements
S36 - STORAGE TANK-INTERNAL FLOATING ROOF

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status during Period: "Continuous"; "Intermittent"; or "Not in Compliance"	Additional Information
POC	BAAQMD 8-5-321.2	N		Primary seal metallic shoe or liquid mounted type	BAAQMD 8-5-402.1 8-5-404	P/10 yr P/10 yr	Inspection Certification	Continuous	
POC	BAAQMD 8-5-321.3	N		Primary seal metallic shoe extends minimum 61 cm (24 in) for external floating and 18 in for internal Floating Roof tank above liquid surface	BAAQMD 8-5-401, 8-5-404	P/10 yr P/10 yr	Inspection Certification	Continuous	
POC	BAAQMD 8-5-321.3.1	N		Gap between shoe and tank shell is no greater than 46 cm (18 in)	BAAQMD 8-5-401, 8-5-404	P/10 yr P/10 yr	Inspection Certification	Continuous	
POC	BAAQMD 8-5-321.3.2	N		For welded tanks, gap between tank shell and the primary seal < 3.8 cm (1 1/2 in). No continuous gap > 0.32 cm ((1/8 in) shall exceed 10% of circumference. The cumulative length of all seal gaps exceeding 1.3 cm (1/2 in) < 10% of circumference and the cumulative length of all seal gaps exceeding 0.32 cm (1/8 in) < 40% of circumference	BAAQMD 8-5-401, 8-5- 404	P/10 yr P/10 yr	Inspection Certification	Continuous	
POC	BAAQMD 8-5-322.1	N		No holes, tears, or other openings	BAAQM 8-5-402.2 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	BAAQMD 8-5-322.2	N		Secondary seal shall allow insertion up to 3.8 cm (1 ½ in) in width	BAAQMD 8-5-402, & 8-5-404	P/10 yr P/10 yr	Inspection Certification	Continuous	
POC	BAAQMD 8-5-322.3	N		Gap between tank shell and the secondary seal shall not exceed 1.3 cm (1/2 in)	BAAQMD 8-5-402, & 8-5-404	P/10 yr P/10 yr	Inspection Certification	Continuous	

Title V Semi-Annual Monitoring Verification Report for Period November 1, 2025 through April 30, 2026

Table VII – G
Applicable Limits and Compliance Monitoring Requirements
S36 - STORAGE TANK-INTERNAL FLOATING ROOF

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status during Period: "Continuous"; "Intermittent"; or "Not in Compliance"	Additional Information
POC	BAAQMD 8-5-328.1.1	N		Tank $\geq$ 75 m^3, Tank cleaning 90% control, POC concentration < 10,000 ppm	BAAQMD 8-5-502	P/A	Source Test	Continuous	
POC	SIP 8-5-303.1	Y		PVV set within 10% of max pressure or 25.8 mmHg (0.5 psia)	SIP 8-5-403 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	SIP 8-320.3.1	Y		Gasket cover $\leq$ 0.32 cm (1/8 in) gap	SIP 8-5-402.3 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	SIP 8-320.3.2	Y		Inaccessible opening no visible gap	SIP 8-5-402.3 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	SIP 8-5-320.4.2	Y		Solid sampling or gauging wells in closed position with cover, seal or lid $\leq$ 0.32 cm (1/8 in)	SIP 8-5-402.3 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	SIP 8-5-320.4.3	Y		Solid sampling or gauging wells: Gap between well and roof shall be added to gaps measured $\leq$ 1.3 cm (1/2 in)	SIP 8-5-402.3 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	SIP 8-5-320.5.2	Y		Slotted sampling or gauging wells in closed position with cover, seal or lid $\leq$ 1.3 cm (1/2 in)	SIP 8-5-402.2 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	SIP 8-5-320.5.3	Y		Slotted sampling or gauging wells: Gap between well and roof shall be added to gaps measured $\leq$ 1.3 cm (1/2 in)	SIP 8-5-402.2 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	SIP 8-5-320.6	Y		Emergency roof drain with slotted membrane fabric cover $\geq$ 90% opening area	SIP 8-5-402 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	SIP 8-5-321.1	Y		No holes, tears or other openings in the primary seal fabric	SIP 8-5-402.2 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	

Title V Semi-Annual Monitoring Verification Report for Period November 1, 2025 through April 30, 2026

Table VII – G
Applicable Limits and Compliance Monitoring Requirements
S36 - STORAGE TANK-INTERNAL FLOATING ROOF

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status during Period: "Continuous"; "Intermittent"; or "Not in Compliance"	Additional Information
POC	SIP 8-5-321.2	Y		Primary seal metallic shoe or liquid mounted type	SIP 8-5-402.1 8-5-404	P/10 yr P/10 yr	Inspection Certification	Continuous	
POC	SIP 8-5-321.3	Y		Primary seal metallic shoe extends minimum 61 cm (24 in) for external floating and 18 in for internal Floating Roof tank above liquid surface	SIP 8-5-401, 8-5-404	P/10 yr P/10 yr	Inspection Certification	Continuous	
POC	SIP 8-5-321.3.1	Y		Gap between shoe and tank shell is no greater than 46 cm (18 in)	SIP 8-5-401, 8-5-404	P/10 yr P/10 yr	Inspection Certification	Continuous	
POC	SIP 8-5-321.3.2	Y		For welded tanks, gap between tank shell and the primary seal < 3.8 cm (1 1/2 in). No continuous gap > 0.32 cm ((1/8 in) shall exceed 10% of circumference. The cumulative length of all seal gaps exceeding 1.3 cm (1/2 in) < 10% of circumference and the cumulative length of all seal gaps exceeding 0.32 cm (1/8 in) < 40% of circumference	SIP 8-5-401, 8-5- 404	P/10 yr P/10 yr	Inspection Certification	Continuous	
POC	SIP 8-5-322.1	Y		No holes, tears, or other openings	SIP 8-5-402.2 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	SIP 8-5-322.2	Y		Secondary seal shall allow insertion up to 3.8 cm (1 ½ in) in width	SIP 8-5-402, & 8-5-404	P/10 yr P/10 yr	Inspection Certification	Continuous	
POC	SIP 8-5-322.3	Y		Gap between tank shell and the secondary seal shall not exceed 1.3 cm (1/2 in)	SIP 8-5-402, & 8-5-404	P/10 yr P/10 yr	Inspection Certification	Continuous	

Title V Semi-Annual Monitoring Verification Report for Period November 1, 2025 through April 30, 2026

Table VII – G
Applicable Limits and Compliance Monitoring Requirements
S36 - STORAGE TANK-INTERNAL FLOATING ROOF

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status during Period: "Continuous"; "Intermittent"; or "Not in Compliance"	Additional Information
POC	SIP 8-5-328.1.1	Y		Tank $\geq$ 75 m^3, tank cleaning shall have liquid balancing with $\leq$ 0.5 psia	None	N	None	Continuous	
POC	SIP 8-5-328.1.2	Y		Tank $\geq$ 75 m^3, Tank cleaning 90% control, POC concentration < 10,000 ppm	SIP 8-5-502	P/A	Source Test	Continuous	
POC	40 CFR 63.11087(a)	Y			40 CFR 63.11092(e) (1)	P/E, 1 or 5 or 10 yrs	Visual Inspection Record keeping	Continuous	Note: SFPP follows NESHAP WW as allowed in 40 CFR 60.110b(e)(5)
Total material throughput limit	BAAQMD Condition #26356, part 1	Y		77,948,000 gallon gasoline/yr	BAAQMD Condition #26356, part 2	P/D	Record keeping	Continuous	
Liquid stored		Y			40 CFR 60.115(a)	P/D	Record keeping	Continuous	Note: SFPP follows NESHAP WW as allowed in 40 CFR 60.110b(e)(5)
True vapor pressure		Y			40 CFR 60.115(b)	P/D	Record keeping	Continuous	Note: SFPP follows NESHAP WW as allowed in 40 CFR 60.110b(e)(5)
True vapor pressure		Y		>1.0 psia	40 CFR 60.115(c)	P/D	Record keeping	Continuous	Note: SFPP follows NESHAP WW as allowed in 40 CFR 60.110b(e)(5)

Title V Semi-Annual Monitoring Verification Report for Period November 1, 2025 through April 30, 2026

Table VII - H
Applicable Limits and Compliance Monitoring Requirements
S39 – STORAGE TANK - UNDERGROUND

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status during Period: "Continuous"; "Intermittent"; or "Not in Compliance"	Additional Information
Throughput	BAAQMD Condition # 26356, Part 1	Y		S39<1,963,000 gallons/yr	BAAQMD Condition # 26356, Part 2	P/M	Recordkeeping	Continuous	

Title V Semi-Annual Monitoring Verification Report for Period November 1, 2025 through April 30, 2026

Table VII - I
Applicable Limits and Compliance Monitoring Requirements
S43 - OIL/WATER SEPARATOR

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status during Period: "Continuous"; "Intermittent"; or "Not in Compliance"	Additional Information
POC	BAAQMD 8-8-301.1	N		Roof seals, other openings Gap <0.125 inch	BAAQMD 8-8-301.1	P/Initially and 6 months	Visual inspection	Continuous	
POC	SIP 8-8-301.1	Y		Roof seals, other openings Gap <0.125 inch	SIP 8-8-301.1	P/Initially and 6 months	Visual inspection	Continuous	

Title V Semi-Annual Monitoring Verification Report for Period November 1, 2025 through April 30, 2026

Table VII – J
Applicable Limits and Compliance Monitoring Requirements
S44 - STORAGE TANK-INTERNAL FLOATING ROOF

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status during Period: "Continuous"; "Intermittent"; or "Not in Compliance"	Additional Information
POC	BAAQMD 8-5-303.1	N		PVV set within 10% of max pressure or 25.8 mmHg (0.5 psia)	BAAQMD 8-5-403 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	BAAQMD 8-320.3.1	N		Gasket cover $\leq$ 0.32 cm (1/8 in) gap	BAAQMD 8-5-402.3 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	BAAQMD 8-320.3.2	N		Inaccessible opening no visible gap	BAAQMD 8-5-402.3 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	BAAQMD 8-5-320.4.2	N		Solid sampling or gauging wells in closed position with cover, seal or lid $\leq$ 0.32 cm (1/8 in)	BAAQMD 8-5-402.3 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	BAAQMD 8-5-320.4.3	N		Solid sampling or gauging wells: Gap between well and roof shall be added to gaps measured $\leq$ 1.3 cm (1/2 in)	BAAQMD 8-5-402.3 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	BAAQMD 8-5-320.5.2	N		Slotted sampling or gauging wells in closed position with cover, seal or lid $\leq$ 1.3 cm (1/2 in)	BAAQMD 8-5-402.2 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	BAAQMD 8-5-320.5.3	N		Slotted sampling or gauging wells: Gap between well and roof shall be added to gaps measured $\leq$ 1.3 cm (1/2 in)	BAAQMD 8-5-402.2 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	BAAQMD 8-5-320.6	N		Emergency roof drain with slotted membrane fabric cover $\geq$ 90% opening area	BAAQMD 8-5-402 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	

Title V Semi-Annual Monitoring Verification Report for Period November 1, 2025 through April 30, 2026

Table VII – J
Applicable Limits and Compliance Monitoring Requirements
S44 - STORAGE TANK-INTERNAL FLOATING ROOF

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status during Period: "Continuous"; "Intermittent"; or "Not in Compliance"	Additional Information
POC	BAAQMD 8-5-321.1	N		No holes, tears or other openings in the primary seal fabric	BAAQMD 8-5-402.2 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	BAAQMD 8-5-321.2	N		Primary seal metallic shoe or liquid mounted type	BAAQMD 8-5-402.1 8-5-404	P/10 yr P/10 yr	Inspection Certification	Continuous	
POC	BAAQMD 8-5-321.3	N		Primary seal metallic shoe extends minimum 61 cm (24 in) for external floating and 18 in for internal Floating Roof tank above liquid surface	BAAQMD 8-5-401, 8-5-404	P/10 yr P/10 yr	Inspection Certification	Continuous	
POC	BAAQMD 8-5-321.3.1	N		Gap between shoe and tank shell is no greater than 46 cm (18 in)	BAAQMD 8-5-401, 8-5-404	P/10 yr P/10 yr	Inspection Certification	Continuous	
POC	BAAQMD 8-5-321.3.2	N		For welded tanks, gap between tank shell and the primary seal < 3.8 cm (1 1/2 in). No continuous gap > 0.32 cm ((1/8 in) shall exceed 10% of circumference. The cumulative length of all seal gaps exceeding 1.3 cm (1/2 in) < 10% of circumference and the cumulative length of all seal gaps exceeding 0.32 cm (1/8 in) < 40% of circumference	BAAQMD 8-5-401, 8-5- 404	P/10 yr P/10 yr	Inspection Certification	Continuous	
POC	BAAQMD 8-5-322.1	N		No holes, tears, or other openings	BAAQM 8-5-402.2 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	BAAQMD 8-5-322.2	N		Secondary seal shall allow insertion up to 3.8 cm (1 ½ in) in width	BAAQMD 8-5-402, & 8-5-404	P/10 yr P/10 yr	Inspection Certification	Continuous	

Title V Semi-Annual Monitoring Verification Report for Period November 1, 2025 through April 30, 2026

Table VII – J
Applicable Limits and Compliance Monitoring Requirements
S44 - STORAGE TANK-INTERNAL FLOATING ROOF

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status during Period: "Continuous"; "Intermittent"; or "Not in Compliance"	Additional Information
POC	BAAQMD 8-5-322.3	N		Gap between tank shell and the secondary seal shall not exceed 1.3 cm (1/2 in)	BAAQMD 8-5-402, & 8-5-404	P/10 yr P/10 yr	Inspection Certification	Continuous	
POC	BAAQMD 8-5-328.1	N		Tank $\geq$ 75 m^3, Tank cleaning 90% control, POC concentration < 10,000 ppm	BAAQMD 8-5-502	P/A	Source Test	Continuous	
POC	SIP 8-5-303.1	Y		PVV set within 10% of max pressure or 25.8 mmHg (0.5 psia)	SIP 8-5-403 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	SIP 8-320.3.1	Y		Gasket cover $\leq$ 0.32 cm (1/8 in) gap	SIP 8-5-402.3 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	SIP 8-320.3.2	Y		Inaccessible opening no visible gap	SIP 8-5-402.3 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	SIP 8-5-320.4.2	Y		Solid sampling or gauging wells in closed position with cover, seal or lid $\leq$ 0.32 cm (1/8 in)	SIP 8-5-402.3 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	SIP 8-5-320.4.3	Y		Solid sampling or gauging wells: Gap between well and roof shall be added to gaps measured $\leq$ 1.3 cm (1/2 in)	SIP 8-5-402.3 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	SIP 8-5-320.5.2	Y		Slotted sampling or gauging wells in closed position with cover, seal or lid $\leq$ 1.3 cm (1/2 in)	SIP 8-5-402.2 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	SIP 8-5-320.5.3	Y		Slotted sampling or gauging wells: Gap between well and roof shall be added to gaps measured $\leq$ 1.3 cm (1/2 in)	SIP 8-5-402.2 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	

Title V Semi-Annual Monitoring Verification Report for Period November 1, 2025 through April 30, 2026

Table VII – J
Applicable Limits and Compliance Monitoring Requirements
S44 - STORAGE TANK-INTERNAL FLOATING ROOF

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status during Period: "Continuous"; "Intermittent"; or "Not in Compliance"	Additional Information
POC	SIP 8-5-320.6	Y		Emergency roof drain with slotted membrane fabric cover ≥ 90% opening area	SIP 8-5-402 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	SIP 8-5-321.1	Y		No holes, tears or other openings in the primary seal fabric	SIP 8-5-402.2 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	SIP 8-5-321.2	Y		Primary seal metallic shoe or liquid mounted type	SIP 8-5-402.1 8-5-404	P/10 yr P/10 yr	Inspection Certification	Continuous	
POC	SIP 8-5-321.3	Y		Primary seal metallic shoe extends minimum 61 cm (24 in) for external floating and 18 in for internal Floating Roof tank above liquid surface	SIP 8-5-401, 8-5-404	P/10 yr P/10 yr	Inspection Certification	Continuous	
POC	SIP 8-5-321.3.1	Y		Gap between shoe and tank shell is no greater than 46 cm (18 in)	SIP 8-5-401, 8-5-404	P/10 yr P/10 yr	Inspection Certification	Continuous	
POC	SIP 8-5-321.3.2	Y		For welded tanks, gap between tank shell and the primary seal < 3.8 cm (1 1/2 in). No continuous gap > 0.32 cm ((1/8 in) shall exceed 10% of circumference. The cumulative length of all seal gaps exceeding 1.3 cm (1/2 in) < 10% of circumference and the cumulative length of all seal gaps exceeding 0.32 cm (1/8 in) < 40% of circumference	SIP 8-5-401, 8-5- 404	P/10 yr P/10 yr	Inspection Certification	Continuous	
POC	SIP 8-5-322.1	Y		No holes, tears, or other openings	SIP 8-5-402.2 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	

Title V Semi-Annual Monitoring Verification Report for Period November 1, 2025 through April 30, 2026

Table VII – J
Applicable Limits and Compliance Monitoring Requirements
S44 - STORAGE TANK-INTERNAL FLOATING ROOF

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status during Period: "Continuous"; "Intermittent"; or "Not in Compliance"	Additional Information
POC	SIP 8-5-322.2	Y		Secondary seal shall allow insertion up to 3.8 cm (1 ½ in) in width	SIP 8-5-402, & 8-5-404	P/10 yr P/10 yr	Inspection Certification	Continuous	
POC	SIP 8-5-322.3	Y		Gap between tank shell and the secondary seal shall not exceed 1.3 cm (1/2 in)	SIP 8-5-402, & 8-5-404	P/10 yr P/10 yr	Inspection Certification	Continuous	
POC	SIP 8-5-328.1.1	Y		Tank $\geq$ 75 m^3, tank cleaning shall have liquid balancing with $\leq$ 0.5 psia	None	N	None	Continuous	
POC	SIP 8-5-328.1.2	Y		Tank $\geq$ 75 m^3, Tank cleaning 90% control, POC concentration < 10,000 ppm	SIP 8-5-502	P/A	Source Test	Continuous	
POC	40 CFR 63.11087(a)	Y			40 CFR 63.11092(e)(1)	P/E, 1 or 5 or 10 yrs	Visual Inspection Record keeping	Continuous	Note: SFPP follows NESHAP WW as allowed in 40 CFR 60.110b(e)(5)
Throughput	BAAQMD Condition # 26356, Part 1	Y		923,275,248 gallon gasoline/yr	BAAQMD Condition # 26356, Part 2	P/M	Recordkeeping	Continuous	
Liquid stored		Y			40 CFR 60.115(a)	P/D	Record keeping	Continuous	Note: SFPP follows NESHAP WW as allowed in 40 CFR 60.110b(e)(5)
True vapor pressure		Y			40 CFR 60.115(b)	P/D	Record keeping	Continuous	Note: SFPP follows NESHAP WW as allowed in 40 CFR 60.110b(e)(5)
True vapor pressure		Y		>1.0 psia	40 CFR 60.115(c)	P/D	Record keeping	Continuous	Note: SFPP follows NESHAP WW as allowed in 40 CFR 60.110b(e)(5)
Gasoline throughput limit	BAAQMD Condition #16514, part 1	Y		214,520 gallons/yr	BAAQMD Condition #16514, part 2	P/M	Record keeping	Continuous	

Title V Semi-Annual Monitoring Verification Report for Period November 1, 2025 through April 30, 2026

Table VII - K
Applicable Limits and Compliance Monitoring Requirements
S45 - SUMP TANK – UNDERGROUND

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status during Period: "Continuous"; "Intermittent"; or "Not in Compliance"	Additional Information
Gasoline throughput limit	BAAQMD Condition #16514, part 1	Y		214,520 gallons/yr	BAAQMD Condition #16514, part 2	P/M	Recordkeeping	Continuous	
Jet Kerosene throughput limit	BAAQMD Condition #16514, part 1	Y		92,072 gallons/yr	BAAQMD Condition #16514, part 2	P/M	Recordkeeping	Continuous	

Title V Semi-Annual Monitoring Verification Report for Period November 1, 2025 through April 30, 2026

Table VII - L
Applicable Limits and Compliance Monitoring Requirements
S47 – UNLOADING RACK 7 (ETHANOL)

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status during Period: "Continuous"; "Intermittent"; or "Not in Compliance"	Additional Information
POC	BAAQMD 8-6-304	Y		21 gm/cubic meter (0.17 lb/1000 gallons)		N	N	Continuous	
POC	BAAQMD Condition # 23134, Part 3	Y		0.04 lb/1000 gallons	BAAQMD Condition # 23134, Part 5 and 6	P/A P/M	Source test Recordkeeping	Continuous	
Ethanol throughput limit	BAAQMD Condition #23134, part 1	Y		123.48 MM gallon/yr	BAAQMD Condition #23134, part 3	P/M	Recordkeeping	Continuous	

Title V Semi-Annual Monitoring Verification Report for Period November 1, 2025 through April 30, 2026

Table VII - M
Applicable Limits and Compliance Monitoring Requirements
S48 – OFFSPEC UNLOADING RACK 8

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status during Period: "Continuous"; "Intermittent"; or "Not in Compliance"	Additional Information
POC	BAAQMD 8-2-301	N		Not more than 15 lb/day & 300 ppm		N	N	Continuous	
	SIP BAAQMD 8-2-301	Y		Not more than 15 lb/day & 300 ppm		N	N	Continuous	
Unloading event limit	BAAQMD Condition #23491, part 1	Y		6600/yr	BAAQMD Condition #23491, part 3	P/M	Recordkeeping	Continuous	

Title V Semi-Annual Monitoring Verification Report for Period November 1, 2025 through April 30, 2026

Table VII - N
Applicable Limits and Compliance Monitoring Requirements
COMPONENTS

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status during Period: "Continuous"; "Intermittent"; or "Not in Compliance"	Additional Information
POC	BAAQMD 8-18-301	N		General equipment leak ≤ 100 ppm	BAAQMD 8-18-401.2	P/Q	Portable hydrocarbon detector, records	Continuous	
POC	BAAQMD 8-18-302	N		Valve leak ≤ 100 ppm	BAAQMD 8-18-401.2	P/Q	Portable hydrocarbon detector, records	Continuous	
POC	BAAQMD 8-18-303	N		Pump and compressor leak ≤ 500 ppm	BAAQMD 8-18-401.2	P/Q	Portable hydrocarbon detector, records	Continuous	
POC	BAAQMD 8-18-304	N		Connection leak ≤ 100 ppm	BAAQMD 8-18-401.2	P/Q	Portable hydrocarbon detector, records	Continuous	
POC	BAAQMD 8-18-305	N		Pressure relief valve leak ≤ 500 ppm	BAAQMD 8-18-401.2	P/Q	Portable hydrocarbon detector, records	Continuous	
POC	BAAQMD 8-18-306.1	N		Valve, pressure relief, pump or compressor must be repaired within 5 years or at the next scheduled turnaround	None	N		Continuous	
POC	BAAQMD 8-18-306.2	N		Awaiting repair Valves ≤ 0.5% Pressure Relief ≤ 1% Pump and Connector ≤ 1%	BAAQMD 8-18-401.5	P/24 hours	Inspection	Continuous	

Title V Semi-Annual Monitoring Verification Report for Period November 1, 2025 through April 30, 2026

Table VII - N
Applicable Limits and Compliance Monitoring Requirements
COMPONENTS

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status during Period: "Continuous"; "Intermittent"; or "Not in Compliance"	Additional Information
POC	BAAQMD 8-18-306.3.2	N		Mass emissions & non-repairable equipment allowed Valve ≤ 0.1 lb/day & ≤1.0% Pressure Relief ≤ 0.2 lb/day & ≤ 5% Pump and Connector ≤ 0.2 lb/day & ≤ 5%	BAAQMD 8-18-401.3	P/D	Inspection	Continuous	
POC	BAAQMD 8-18-306.3.3	N		Total valve, pressure relief, pump or compressor leaks ≥ 15 lb/day, they must be repaired within 7 days	None	N		Continuous	
POC	SIP 8-18-301	Y		General equipment leak ≤ 100 ppm	SIP 8-18-401.2	P/Q	Portable hydrocarbon detector, records	Continuous	
POC	SIP 8-18-302	Y		Valve leak ≤ 100 ppm	SIP 8-18-401.2	P/Q	Portable hydrocarbon detector, records	Continuous	
POC	SIP 8-18-303	Y		Pump and compressor leak ≤ 500 ppm	SIP 8-18-401.2	P/Q	Portable hydrocarbon detector, records	Continuous	
POC	SIP 8-18-304	Y		Connection leak ≤ 100 ppm	SIP 8-18-401.2	P/Q	Portable hydrocarbon detector, records	Continuous	
POC	SIP 8-18-305	Y		Pressure relief valve leak ≤ 500 ppm	SIP 8-18-401.2	P/Q	Portable hydrocarbon detector, records	Continuous	

Title V Semi-Annual Monitoring Verification Report for Period November 1, 2025 through April 30, 2026

Table VII - N
Applicable Limits and Compliance Monitoring Requirements
COMPONENTS

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status during Period: "Continuous"; "Intermittent"; or "Not in Compliance"	Additional Information
POC	SIP 8-18-306.1	Y		Valve, pressure relief, pump or compressor must be repaired within 5 years or at the next scheduled turnaround	None	N		Continuous	
POC	SIP 8-18-306.2	Y		Awaiting repair Valves ≤ 0.5% Pressure Relief ≤ 1% Pump and Connector ≤ 1%	SIP 8-18-401.5	P/24 hours	Inspection	Continuous	
POC	SIP 8-18-306.3.2	Y		Mass emissions & non-repairable equipment allowed Valve ≤ 0.1 lb/day & ≤1.0% Pressure Relief ≤ 0.2 lb/day & ≤ 5% Pump and Connector ≤ 0.2 lb/day & ≤ 5%	SIP 8-18-401.3	P/D	Inspection	Continuous	
POC	SIP 8-18-306.3.3	Y		Total valve, pressure relief, pump or compressor leaks ≥ 15 lb/day, they must be repaired within 7 days	None	N		Continuous	
POC	40 CFR 63.11089	Y		Liquid/vapor	40 CFR 63.11089	P/M	Inspection, Recordkeeping	Continuous	