

TV Tracking #: 98

1. ☐ RECEIVED IN
ENFORCEMENT: 11/20/2020

Semi-Annual Monitoring Report

(May 1, 2020 through October 31, 2020)

Bay Area Air Quality Management District

375 Beale Street, Suite 600, San Francisco, CA. 94105

Telephone: (415) 771-6000

Report of Required Monitoring TITLE V Operating Permit

Facility Name: SFPP, L.P. Brisbane Terminal

Address: 950 Tunnel Avenue, Brisbane, California 94005

Title V Permit Number: A4021

Reporting Period: May 1, 2020 through October 31, 2020

I hereby certify that I am a Responsible Official for the above named facility as defined in 40 Code of Federal Regulations, Part 70.2. I further certify that, based on information and belief formed after reasonable inquiry, the statements and information in this certification are true, accurate, and complete.



Signature of Responsible Official

11/19/2020

Date

D. Scott Manley

Name of Responsible Official (please print)

Director of Operations

Title of Responsible Official (please print)

Title V Semi-Annual Monitoring Verification Report for Period May 1, 2020 through October 31, 2020

Table VII - A
Applicable Limits and Compliance Monitoring Requirements
S21, S22, S23, S24, S25 – LOADING RACKS

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status during Period: "Continuous"; "Intermittent"; or "Not in Compliance"	Additional Information
POC	BAAQMD 8-33-301.1	N		9.6 g/1000 liters (0.08 lb/1000 gallons)	BAAQMD 8-33-309-4; CARB Certification	P/ 9-15 months	Source test, Recordkeeping	Continuous	
POC	BAAQMD 8-33-301.2	N	01/10/2011	0.04 lb/1000 gallons	BAAQMD 8-33-309-4; 8-33-309.13; CARB Certification	C: P/9-15 months	Parametric; Source test; Recordkeepin; Notification	Continuous	
	BAAQMD 8-33-308	N	01/10/2011	< 3,000 ppm as methane or 6% of the lower explosive limit	BAAQMD 8-33-308.2; BAAQMD Condition #4275, part 1e, and part 15	C: P/weekly	Infrared HC Analyzer; Recordkeeping	Continuous	
POC	BAAQMD 8-33-309.2	N	01/10/2011	18 in. of water column	BAAQMD 8-33-309.10, and BAAQMD Condition #4275, part 1b	P/during product loading	Pressure gauge; Recordkeeping	Continuous	
POC	SIP 8-33-301	Y		9.6 g/1000 liters (0.08 lb/1000 gallons)	CARB Certification	P/ 6 months; throughput limit revision	Source test, Recordkeeping	Continuous	

Title V Semi-Annual Monitoring Verification Report for Period May 1, 2020 through October 31, 2020

Table VII - A
Applicable Limits and Compliance Monitoring Requirements
S21, S22, S23, S24, S25 – LOADING RACKS

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status during Period: "Continuous"; "Intermittent"; or "Not in Compliance"	Additional Information
	SIP 8-33-308	Y		3,000 ppm as methane and 6.8 kg (15 pounds) per day	BAAQMD Condition #4275, part 1e, and part 2	C	Infrared HC Analyzer	Continuous	
	SIP 8-33-309	Y		46 cm (18 in.) of water column	BAAQMD 8-33-309, and BAAQMD Condition #4275, part 1b	P/during product loading	Pressure gauge	Continuous	
	40 CFR 60.502(b)	Y		35 g/1000 liters	40 CFR 60.503(c)	P/6 months	Source test	Continuous	
POC	40 CFR 60.502(e)	Y		Vapor-tight gasoline tank trucks	40 CFR 60.505(b)	P/during product loading, and within 2 weeks	Vapor tightness documents	Continuous	
POC	40 CFR 60.505(e)(ii)	Y		Vapor-tight gasoline tank trucks electronic recordkeeping	40 CFR 60.505(b)	P/during product loading, and within 2 weeks	Vapor tightness documents	Continuous	
	40 CFR 63.11088(a)	Y	1/10/2011	80 mg/liters	40 CFR 63.11092(a)	P/6 months	Source test	Continuous	
	40 CFR 63.11088(a)	Y	1/10/2011	Vapor-tight gasoline tank trucks	40 CFR 63.11092(f) (1)	P/annual	Certification test documents	Continuous	

Title V Semi-Annual Monitoring Verification Report for Period May 1, 2020 through October 31, 2020

Table VII - A
Applicable Limits and Compliance Monitoring Requirements
S21, S22, S23, S24, S25 – LOADING RACKS

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status during Period: "Continuous"; "Intermittent"; or "Not in Compliance"	Additional Information
	BAAQMD Condition #4275, part 5	Y		120 ppm as propane	BAAQMD Condition #4275, part 1c	P/C	Infrared HC Analyzer	Continuous	
Total material throughput limit	BAAQMD Condition #4275, part 6b	Y		250,000 gallons/hr 2,400,000 gallons/day 876,000,000 gallon/yr	BAAQMD Condition #4275, part 9	P/H	Record- keeping	Continuous	
POC	BAAQMD Condition #4275, part 11	Y		Operating temperature 500 degree Fahrenheit	BAAQMD Condition #4275, part 15	C	Record Keeping	Continuous	
POC	BAAQMD 8-18-305	Y		All equipment associated with delivery and loading operations shall be maintained to be leak free, vapor tight and in good working order.			Inspection	Continuous	

Title V Semi-Annual Monitoring Verification Report for Period May 1, 2020 through October 31, 2020

Table VII - B
Applicable Limits and Compliance Monitoring Requirements
S1, S2, S4, S5, S6, S7, S8, S9, S10, S11, S12, S13, S15, S16, S18, S20 - INTERNAL FLOATING ROOF TANKS

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status during Period: "Continuous"; "Intermittent"; or "Not in Compliance"	Additional Information
POC	BAAQMD 8-5-303.1	N		PVV set within 10% of max pressure or 25.8 mmHg (0.5 psia)	BAAQMD 8-5-403 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	BAAQMD 8-320.3.1	N		Gasket cover \leq 0.32 cm (1/8 in) gap	BAAQMD 8-5-402.3 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	BAAQMD 8-32 0.3.2	N		Inaccessible opening no visible gap	BAAQMD 8-5-402.3 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	BAAQMD 8-5-320.4.2	N		Solid sampling or gauging wells in closed position with cover, seal or lid \leq 0.32 cm (1/8 in)	BAAQMD 8-5-402.3 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	BAAQMD 8-5-320.4.3	N		Solid sampling or gauging wells: Gap between well and roof shall be added to gaps measured \leq 1.3 cm (1/2 in)	BAAQMD 8-5-402.3 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	BAAQMD 8-5-320.5.2	N		Slotted sampling or gauging wells in closed position with cover, seal or lid \leq 1.3 cm (1/2 in)	BAAQMD 8-5-402.2 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	

Title V Semi-Annual Monitoring Verification Report for Period May 1, 2020 through October 31, 2020

Table VII - B
Applicable Limits and Compliance Monitoring Requirements
S1, S2, S4, S5, S6, S7, S8, S9, S10, S11, S12, S13, S15, S16, S18, S20 - INTERNAL FLOATING ROOF TANKS

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status during Period: "Continuous"; "Intermittent"; or "Not in Compliance"	Additional Information
POC	BAAQMD 8-5-320.5.3	N		Slotted sampling or gauging wells: Gap between well and roof shall be added to gaps measured ≤ 1.3 cm (1/2 in)	BAAQMD 8-5-402.2 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	BAAQMD 8-5-320.6	Y		Emergency roof drain with slotted membrane fabric cover $\geq 90\%$ opening area	BAAQMD 8-5-402 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	BAAQMD 8-5-321.1	N		No holes, tears or other openings in the primary seal fabric	BAAQMD 8-5-402.2 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	BAAQMD 8-5-321.2	N		Primary seal metallic shoe or liquid mounted type	BAAQMD 8-5-402.1 & 8-5-404	P/10 yr P/10 yr	Inspection Certification	Continuous	
POC	BAAQMD 8-5-321.3	N		Primary seal metallic shoe extends minimum 61 cm (24 in) for external floating and 18 in for internal Floating Roof tank above liquid surface	BAAQMD 8-5-401, & 8-5-404	P/10 yr P/10 yr	Inspection Certification	Continuous	

Title V Semi-Annual Monitoring Verification Report for Period May 1, 2020 through October 31, 2020

Table VII - B
Applicable Limits and Compliance Monitoring Requirements
S1, S2, S4, S5, S6, S7, S8, S9, S10, S11, S12, S13, S15, S16, S18, S20 - INTERNAL FLOATING ROOF TANKS

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status during Period: "Continuous"; "Intermittent"; or "Not in Compliance"	Additional Information
POC	BAAQMD 8-5-321.3.1	N		Gap between shoe and tank shell is no greater than 46 cm (18 in)	BAAQMD 8-5-401, 8-5-404	P/10 yr P/10 yr	Inspection Certification	Continuous	
POC	BAAQMD 8-5-321.3.2	N		For welded tanks, gap between tank shell and the primary seal < 3.8 cm (1 1/2 in). No continuous gap > 0.32 cm ((1/8 in) shall exceed 10% of circumference. The cumulative length of all seal gaps exceeding 1.3 cm (1/2 in) < 10% of circumference and the cumulative length of all seal gaps exceeding 0.32 cm (1/8 in) < 40% of circumference	BAAQMD 8-5-401, 8-5- 404	P/10 yr P/10 yr	Inspection Certification	Continuous	
POC	BAAQMD 8-5-322.1	N		No holes, tears, or other openings	BAAQMD 8-5-402.2 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	BAAQMD 8-5-322.2	N		Secondary seal shall allow insertion up to 3.8 cm (1 1/2 in) in width	BAAQMD 8-5-402, & 8-5-404	P/10 yr P/10 yr	Inspection Certification	Continuous	

Title V Semi-Annual Monitoring Verification Report for Period May 1, 2020 through October 31, 2020

Table VII - B
Applicable Limits and Compliance Monitoring Requirements
S1, S2, S4, S5, S6, S7, S8, S9, S10, S11, S12, S13, S15, S16, S18, S20 - INTERNAL FLOATING ROOF TANKS

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status during Period: "Continuous"; "Intermittent"; or "Not in Compliance"	Additional Information
POC	BAAQMD 8-5-322.3	N		Gap between tank shell and the secondary seal shall not exceed 1.3 cm (1/2 in)	BAAQMD 8-5-402, & 8-5-404	P/10 yr P/10 yr	Inspection Certification	Continuous	
POC	BAAQMD 8-5-328.1.1	N		Tank $\geq 75 \text{ m}^3$, Tank cleaning 90% control, POC concentration < 10,000 ppm	BAAQMD 8-5-502	P/A	Source Test	Continuous	
POC	SIP 8-5-303.1	Y		PVV set within 10% of max pressure or 25.8 mmHg (0.5 psia)	SIP 8-5-403 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	SIP 8-320.3.1	Y		Gasket cover $\leq 0.32 \text{ cm}$ (1/8 in) gap	SIP 8-5-402.3 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	SIP 8-320.3.2	Y		Inaccessible opening no visible gap	SIP 8-5-402.3 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	SIP 8-5-320.4.2	Y		Solid sampling or gauging wells in closed position with cover, seal or lid $\leq 0.32 \text{ cm}$ (1/8 in)	SIP 8-5-402.3 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	

Title V Semi-Annual Monitoring Verification Report for Period May 1, 2020 through October 31, 2020

Table VII - B
Applicable Limits and Compliance Monitoring Requirements
S1, S2, S4, S5, S6, S7, S8, S9, S10, S11, S12, S13, S15, S16, S18, S20 - INTERNAL FLOATING ROOF TANKS

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status during Period: "Continuous"; "Intermittent"; or "Not in Compliance"	Additional Information
POC	SIP 8-5-320.4.3	Y		Solid sampling or gauging wells: Gap between well and roof shall be added to gaps measured ≤ 1.3 cm (1/2 in)	SIP 8-5-402.3 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	SIP 8-5-320.5.2	Y		Slotted sampling or gauging wells in closed position with cover, seal or lid ≤ 1.3 cm (1/2 in)	SIP 8-5-402.2 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	SIP 8-5-320.5.3	Y		Slotted sampling or gauging wells: Gap between well and roof shall be added to gaps measured ≤ 1.3 cm (1/2 in)	SIP 8-5-402.2 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	SIP 8-5-320.6	Y		Emergency roof drain with slotted membrane fabric cover $\geq 90\%$ opening area	SIP 8-5-402 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	SIP 8-5-321.1	Y		No holes, tears or other openings in the primary seal fabric	SIP 8-5-402.2 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	

Title V Semi-Annual Monitoring Verification Report for Period May 1, 2020 through October 31, 2020

Table VII - B
Applicable Limits and Compliance Monitoring Requirements
S1, S2, S4, S5, S6, S7, S8, S9, S10, S11, S12, S13, S15, S16, S18, S20 - INTERNAL FLOATING ROOF TANKS

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status during Period: "Continuous"; "Intermittent"; or "Not in Compliance"	Additional Information
POC	SIP 8-5-321.2	Y		Primary seal metallic shoe or liquid mounted type	SIP 8-5-402.1 8-5-404	P/10 yr P/10 yr	Inspection Certification	Continuous	
POC	SIP 8-5-321.3	Y		Primary seal metallic shoe extends minimum 61 cm (24 in) for external floating and 18 in for internal Floating Roof tank above liquid surface	SIP 8-5-401, 8-5-404	P/10 yr P/10 yr	Inspection Certification	Continuous	
POC	SIP 8-5-321.3.1	Y		Gap between shoe and tank shell is no greater than 46 cm (18 in)	SIP 8-5-401, 8-5-404	P/10 yr P/10 yr	Inspection Certification	Continuous	

Title V Semi-Annual Monitoring Verification Report for Period May 1, 2020 through October 31, 2020

Table VII - B
Applicable Limits and Compliance Monitoring Requirements
S1, S2, S4, S5, S6, S7, S8, S9, S10, S11, S12, S13, S15, S16, S18, S20 - INTERNAL FLOATING ROOF TANKS

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status during Period: "Continuous"; "Intermittent"; or "Not in Compliance"	Additional Information
POC	SIP 8-5-321.3.2	Y		For welded tanks, gap between tank shell and the primary seal < 3.8 cm (1 1/2 in). No continuous gap > 0.32 cm ((1/8 in) shall exceed 10% of circumference. The cumulative length of all seal gaps exceeding 1.3 cm (1/2 in) < 10% of circumference and the cumulative length of all seal gaps exceeding 0.32 cm (1/8 in) < 40% of circumference	SIP 8-5-401, 8-5- 404	P/10 yr P/10 yr	Inspection Certification	Continuous	
POC	SIP 8-5-322.1	Y		No holes, tears, or other openings	SIP 8-5-402.2 & 8-5-404	P/twice per year at 4 to 8 months interval	Inspection Certification	Continuous	
POC	SIP 8-5-322.2	Y		Secondary seal shall allow insertion up to 3.8 cm (1 1/2 in) in width	SIP 8-5-402, & 8-5-404	P/10 yr P/10 yr	Inspection Certification	Continuous	

Title V Semi-Annual Monitoring Verification Report for Period May 1, 2020 through October 31, 2020

Table VII - B
Applicable Limits and Compliance Monitoring Requirements
S1, S2, S4, S5, S6, S7, S8, S9, S10, S11, S12, S13, S15, S16, S18, S20 - INTERNAL FLOATING ROOF TANKS

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status during Period: "Continuous"; "Intermittent"; or "Not in Compliance"	Additional Information
POC	SIP 8-5-322.3	Y		Gap between tank shell and the secondary seal shall not exceed 1.3 cm (1/2 in)	SIP 8-5-402, & 8-5-404	P/10 yr P/10 yr	Inspection Certification	Continuous	
POC	SIP 8-5-328.1.1	Y		Tank ≥ 75 m ³ , tank cleaning shall have liquid balancing with ≤ 0.5 psia	None	N	None	Continuous	
POC	SIP 8-5-328.1.2	Y		Tank ≥ 75 m ³ , Tank cleaning 90% control, POC concentration < 10,000 ppm	SIP 8-5-502	P/A	Source Test	Continuous	
Certification	BAAQMD 8-5-404			Submit report within 60 days of inspection or source test	BAAQMD 8-5-404		Submittal	Continuous	
POC	BAAQMD Condition #17285, part 1	Y		52.56 MM gal/yr	BAAQMD Condition #17285, part 2	P/D	Record keeping	Continuous	
	BAAQMD Regulation 8, Rule 5 (amended on 10/18/06)	Y						Continuous	

Title V Semi-Annual Monitoring Verification Report for Period May 1, 2020 through October 31, 2020

Table VII - C
Applicable Limits and Compliance Monitoring Requirements
S29, S30, S31, S32 – UNDERGROUND TANKS/SUMPS

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status during Period: "Continuous"; "Intermittent"; or "Not in Compliance"	Additional Information
POC	40 CFR 63.11087 (a)	Y	1/10/2011		40 CFR 63.11092(e)(1)	P/E 1 or 5 or 10 yrs	Visual Inspection, Recordkeeping	Continuous	
	BAAQMD Condition #16325, part 1	Y		214,150 gallons gasoline/yr 92,350 gallons jet kerosene/yr	BAAQMD Condition #16325, part 2	P/D	Record keeping	Continuous	

Title V Semi-Annual Monitoring Verification Report for Period May 1, 2020 through October 31, 2020

Table VII - D
Applicable Limits and Compliance Monitoring Requirements
S28 – OIL/WATER SEPARATOR

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status during Period: "Continuous"; "Intermittent"; or "Not in Compliance"	Additional Information
POC	BAAQMD 8-8-301.1	N		Roof seals, other openings Gap <0.125 inch	BAAQMD 8-8-301.1	P/Initially and 6 months	Visual inspection	Continuous	
POC	SIP BAAQMD 8-8-301.1	Y		Roof seals, other openings Gap <0.125 inch	SIP BAAQMD 8-8-301.1	P/Initially and 6 months	Visual inspection	Continuous	
POC	BAAQMD Condition #11349, part 2	Y		10 ppm and 10% of inlet concentration	BAAQMD Condition #11349, part 5	P/Weekly	Portable hydrocarbon detector, recordkeeping	Continuous	
POC	BAAQMD Condition #11349, part 3	Y		Change-out with unspent carbon upon the detection of breakthrough or 6 ppm	BAAQMD Condition #11349, part 5 and part 6	P/Weekly	Portable hydrocarbon detector, recordkeeping	Continuous	

Title V Semi-Annual Monitoring Verification Report for Period May 1, 2020 through October 31, 2020

Table VII – E
Applicable Limits and Compliance Monitoring Requirements
S35 – ETHANOL UNLOADING RACK

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status during Period: "Continuous"; "Intermittent"; or "Not in Compliance"	Additional Information
POC	BAAQMD 8-6-304	Y		21 gm/cubic meter (0.17 lb/1000 gallons)		N	N	Continuous	
Ethanol through put limit	BAAQMD Condition #23531, part 1	Y		52.56 MM gallon/yr	BAAQMD Condition #23531, part 3	P/M	Recordkeeping	Continuous	

Title V Semi-Annual Monitoring Verification Report for Period May 1, 2020 through October 31, 2020

Table VII – F
Applicable Limits and Compliance Monitoring Requirements
S36 – OFF-SPECIFICATION FUEL UNLOADING RACK

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status during Period: "Continuous"; "Intermittent"; or "Not in Compliance"	Additional Information
POC	BAAQMD 8-2-301	N		Not more than 15 lb/day & 300 ppm		N	N	Continuous	
POC	SIP BAAQMD 8-2-301	Y		Not more than 15 lb/day & 300 ppm		N	N	Continuous	
Unloading event limit	BAAQMD Condition #23549, part 1	Y		10,950/yr	BAAQMD Condition #23549, part 3	P/M	Recordkeeping	Continuous	

Title V Semi-Annual Monitoring Verification Report for Period May 1, 2020 through October 31, 2020

Table VII – G
Applicable Limits and Compliance Monitoring Requirements
FUGITIVE COMPONENTS

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status during Period: "Continuous"; "Intermittent"; or "Not in Compliance"	Additional Information
POC	BAAQMD 8-18-301	N		General equipment leak \leq 100 ppm	BAAQMD 8-18-401.2 and 401.5	P/Q	Portable hydrocarbon detector, records	Continuous	
POC	BAAQMD 8-18-302	N		Valve leak \leq 100 ppm	BAAQMD 8-18-401.5 and 401.6	P/Q	Portable hydrocarbon detector, records	Continuous	
POC	BAAQMD 8-18-303	N		Pump and compressor leak \leq 500 ppm	BAAQMD 8-18-401.2 and 401.5	P/Q	Portable hydrocarbon detector, records	Continuous	
POC	BAAQMD 8-18-304	N		Connection leak \leq 100 ppm	BAAQMD 8-18-401.2 and 401.5	P/Q	Portable hydrocarbon detector, records	Continuous	
POC	BAAQMD 8-18-305	N		Pressure relief valve leak \leq 500 ppm	BAAQMD 8-18-401.2 and 401.5	P/Q	Portable hydrocarbon detector, records	Continuous	
POC	BAAQMD 8-18-306.1	N		Valve, pressure relief, pump or compressor must be repaired within 5 years or at the next scheduled turnaround	SIP 8-18-502.4	N		Continuous	

Title V Semi-Annual Monitoring Verification Report for Period May 1, 2020 through October 31, 2020

Table VII – G
Applicable Limits and Compliance Monitoring Requirements
FUGITIVE COMPONENTS

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status during Period: "Continuous"; "Intermittent"; or "Not in Compliance"	Additional Information
POC	BAAQMD 8-18-306.2	N		Awaiting repair Valves $\leq 0.5\%$ Pressure Relief $\leq 1\%$ Pump and Connector $\leq 1\%$	SIP 8-18-502.4	P/24 hours	Inspection	Continuous	
POC	BAAQMD 8-18-306.3.2	N		Mass emissions & non-repairable equipment allowed Valve ≤ 0.1 lb/day & $\leq 1.0\%$ Pressure Relief ≤ 0.2 lb/day & $\leq 5\%$ Pump and Connector ≤ 0.2 lb/day & $\leq 5\%$	SIP 8-18-502.4	P/D	Inspection	Continuous	
POC	BAAQMD 8-18-306.3.3	N		Total valve, pressure relief, pump or compressor leaks ≥ 15 lb/day, they must be repaired within 7 days	SIP 8-18-502.4	N		Continuous	
POC	SIP 8-18-301	Y		General equipment leak ≤ 100 ppm	SIP 8-18-401.2	P/Q	Portable hydrocarbon detector, records	Continuous	
POC	SIP 8-18-302	Y		Valve leak ≤ 100 ppm	SIP 8-18-401.2	P/Q	Portable hydrocarbon detector, records	Continuous	

Title V Semi-Annual Monitoring Verification Report for Period May 1, 2020 through October 31, 2020

Table VII – G
Applicable Limits and Compliance Monitoring Requirements
FUGITIVE COMPONENTS

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status during Period: "Continuous"; "Intermittent"; or "Not in Compliance"	Additional Information
POC	SIP 8-18-303	Y		Pump and compressor leak \leq 500 ppm	SIP 8-18-401.2	P/Q	Portable hydrocarbon detector, records	Continuous	
POC	SIP 8-18-304	Y		Connection leak \leq 100 ppm	SIP 8-18-401.2 & 403	P/Q	Portable hydrocarbon detector, records	Continuous	
POC	SIP 8-18-305	Y		Pressure relief valve leak \leq 500 ppm	BAAQMD 8-18-401.2 & 401.5	P/Q	Portable hydrocarbon detector, records	Continuous	
POC	SIP 8-18-306.1	Y		Valve, pressure relief, pump or compressor must be repaired within 5 years or at the next scheduled turnaround	SIP 8-25-503.4	N		Continuous	
POC	SIP 8-18-306.2	Y		Awaiting repair Valves \leq 0.5% Pressure Relief \leq 1% Pump and Connector \leq 1%	SIP 8-18-401.5	P/24 hours	Inspection	Continuous	

Title V Semi-Annual Monitoring Verification Report for Period May 1, 2020 through October 31, 2020

Table VII – G
Applicable Limits and Compliance Monitoring Requirements
FUGITIVE COMPONENTS

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status during Period: "Continuous"; "Intermittent"; or "Not in Compliance"	Additional Information
POC	SIP 8-18-306.3.2	Y		Mass emissions & non-repairable equipment allowed Valve ≤ 0.1 lb/day & $\leq 1.0\%$ Pressure Relief ≤ 0.2 lb/day & $\leq 5\%$ Pump and Connector ≤ 0.2 lb/day & $\leq 5\%$	SIP 8-18-401.3	P/D	Inspection	Continuous	
POC	SIP 8-18-306.3.3	Y		Total valve, pressure relief, pump or compressor leaks ≥ 15 lb/day, they must be repaired within 7 days	None	N		Continuous	
POC	SIP 8-25-302	Y		Pump leak ≤ 500 ppm	SIP 8-25-401.2 & 8-25-403	P/Q P/D	Portable hydrocarbon detector, records	Continuous	
POC	SIP 8-25-303	Y		Compressor leak ≤ 500 ppm	SIP 8-25-401.2 & 8-25-403	P/Q P/D	Portable hydrocarbon detector, records	Continuous	
POC	SIP 8-25-304.1	Y		Pump or compressor repaired within 5 years or next scheduled turnaround	SIP 8-25-304.1	P/Q	Portable hydrocarbon detector, records	Continuous	

Title V Semi-Annual Monitoring Verification Report for Period May 1, 2020 through October 31, 2020

Table VII – G
Applicable Limits and Compliance Monitoring Requirements
FUGITIVE COMPONENTS

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status during Period: "Continuous"; "Intermittent"; or "Not in Compliance"	Additional Information
POC	SIP 8-25-304.2	Y		Awaiting repaired valves < 1.0%	SIP 8-25-503.4	P/Q	Portable hydrocarbon detector, records	Continuous	
	SIP 8-25-305	Y		New or replaced pump and compressor leak \leq 500 ppm for 4 consecutive quarters	SIP 8-25-401.2 & 8-25-403	P/Q P/D	Portable hydrocarbon detector, records	Continuous	
	SIP 8-25-306	Y		Repeat pump , compressor leak must meet SIP BAAQMD 8-25-304 & 8-25-305	SIP 8-25-401.2 & 8-25-403	P/Q P/D	Portable hydrocarbon detector, records	Continuous	
					BAAQMD 8-18-503	P/Q P/Y	Reports	Continuous	
					BAAQMD 8-18-402.1	P/Q P/Y	Identification Code	Continuous	

Title V Semi-Annual Monitoring Verification Report for Period May 1, 2020 through October 31, 2020

Table VII - H
Applicable Limits and Compliance Monitoring Requirements
S33- EMERGENCY DIESEL GENERATOR

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status during Period: "Continuous"; "Intermittent"; or "Not in Compliance"	
Opacity	BAAQMD 6-1-303.1	N		Ringelmann 2.0 for no more than 3 minutes in any hour		N		Continuous	
FP	BAAQMD 6-1-310	N		0.15 gr/dscf		N		Continuous	
Opacity	SIP 6-303.1	Y		Ringelmann 2.0 for no more than 3 minutes in any hour		N		Continuous	
FP	SIP 6-1-310	Y		0.15 gr/dscf		N		Continuous	
SO ₂	BAAQMD 9-1-301	Y		Property Line Ground Level Limits: < 0.5 ppm for 3 minutes and < 0.25 ppm for 60 min. and <0.05 ppm for 24 hours	None	N	N/A	Continuous	
	BAAQMD 9-1-304	Y		0.5% wt sulfur in liquid fuel		P/E	Fuel certification recordkeeping	Continuous	
Hours of Operation	BAAQMD 9-8-330.1	N		Unlimited hours for emergencies	BAAQMD 9-8-530.2	P/monthly	Record Keeping	Continuous	
	BAAQMD 9-8-330.2	N		100 hours per year for reliability-related activities	BAAQMD 9-8-530	P/monthly	Record Keeping	Continuous	
	BAAQMD	N	1/1/2012	50 hours per year for	BAAQMD	P/monthly	Record Keeping	Continuous	

Title V Semi-Annual Monitoring Verification Report for Period May 1, 2020 through October 31, 2020

Table VII - H
Applicable Limits and Compliance Monitoring Requirements
S33- EMERGENCY DIESEL GENERATOR

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance Status during Period: "Continuous"; "Intermittent"; or "Not in Compliance"	
	9-8-330.3			reliability-related activities	9-8-530				
	CCR, Title 17, Section 93115.6(b)(3)(A)(1)(a)	N		20 hours/yr for maintenance and testing	CCR, Title 17, Section 93115.10(e)(1)	C	Totalizing Counter	Continuous	
	CCR, Title 17, Section 9311.6(b)(3)(A)(1)(a)	N		20 hours/yr for maintenance and testing	CCR, Title 17, Section 93115.10(g)	M	Record Keeping	Continuous	
	BAAQMD Condition #22820, part1	N		20 hours/yr for maintenance and testing	BAAQMD Condition #22820, part 3	C	Totalizing Counter	Continuous	
	BAAQMD Cond.# 22820, part1	Y		20 hours per year for reliability-related activities	BAAQMD Cond.# 22820, part 1	P/monthly	Record Keeping	Continuous	