

Gilroy Energy Center, LLC (for the Riverview Energy Center)

795 Minaker Road
Antioch, CA 94509

January 18, 2022

Director of Compliance and Enforcement
Bay Area Air Quality Management District
375 Beale Street, Suite 600
San Francisco, CA 94105
Attn: Title V

TV Tracking #: 363

1. RECEIVED IN
ENFORCEMENT: 01/20/2022

**Subject: Gilroy Energy Center, LLC for the Riverview Energy Center
Title V Semi-Annual Monitoring Report
Facility # B4512
Reporting Period: July 1, 2021 through December 31, 2021**

To Whom It May Concern:

Enclosed is the Title V CEMS Semi-Annual Monitoring Report for the Riverview Energy Center ("REC") for the reporting period from July 1, 2021 through December 31, 2021.

On September 11th, 2021, the facility experienced breakdown of its water injection system that resulted in exceedance of the Facility's NOx daily mass emission limit and of its 4-hour rolling NOx emission limit. A Reportable Compliance Activity (RCA) form was submitted to the District requesting breakdown relief (Report ID No. 08B71) regarding this event (Report ID No. 08B72) on September 13th, 2021. A detailed description of the event can be found in the attached Title V deviation letter.

By signing this report, I am certifying that based on information and belief formed after reasonable inquiry, the statements and information in the attached report are true, accurate, and complete.

If you have any questions or require additional information, please contact me at (707) 399-4395.

Sincerely,



Andrew Gundershaug
Plant Manager and Designated Representative/Responsible Official

Table VII – A
Applicable Limits and Compliance Monitoring Requirements
S-2 – COMBUSTION GAS TURBINE
July 1, 2021 through December 31, 2021

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance	
								Yes	No
NOx	BAAQMD 9-9-301.1.3	N		9 ppmv @ 15% O2, dry	BAAQMD 9-9-501 and BAAQMD condition #20010, part 23c	C	CEM	X	
NOx	SIP 9-9-301.3	Y		9 ppmv @ 15% O2, dry	SIP 9-9-501 and BAAQMD condition #20010, part 23c	C	CEM	X	
NOx	BAAQMD 9-9-301.1.3	N		9 ppmv @ 15% O2, dry	BAAQMD condition #20010, part 4a	P/Once every 8,000 operating hours or three years, whichever comes first	Source test	X	
NOx	SIP Regulation 9-9-301.3	Y		9 ppmv @ 15% O2, dry	SIP Regulation condition #20010, part 24a	P/Once every 8,000 operating hours or three years, whichever comes first	Source test	X	
NOx	NSPS, 40 CFR 60.332 (a)(1)	Y		75 ppmv @ 15% O2, dry	NSPS 40 CFR 60.334(b)	C	CEM		X
NOx	None	Y		None	40 CFR 75.10	C	CEM	X	
NOx	BAAQMD condition #20010, part 18(a)	Y		2.5 ppmv @ 15% O2, dry, 3-hr average except during turbine startup or shutdown	BAAQMD condition #20010, part 18(a), 23c	C	CEM	X	
NOx	BAAQMD condition #20010, part 18(a)	Y		2.5 ppmv @ 15% O2, dry, 3-hr average except during turbine startup or shutdown	BAAQMD condition #20010, part 24a	P/Once every 8,000 operating hours or three years, whichever comes first	Source test	X	
NOx	BAAQMD condition #20010, part 21	Y		121 lb/ day (as NO2)	BAAQMD condition #20010, part 23c	C	CEM		X
NOx	BAAQMD condition #20010, part 21	Y		14.7 tons per year (as NO2)	BAAQMD condition #20010, part 23c	C	CEM	X	

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance	
								Yes	No
CO	BAAQMD condition #20010, part 18(c)	Y		6 ppmv @ 15% O ₂ , dry, 3-hr average except during turbine startup or shutdown	BAAQMD condition #20010, parts 18(c) and 23c	C	CEM	X	
CO	BAAQMD condition #20010, part 18(c)	Y		6 ppmv @ 15% O ₂ , dry, 3-hr average except during turbine startup or shutdown	BAAQMD condition #20010, part 24c	P/ Once every 8,000 operating hours or three years, whichever comes first	Source test	X	
CO	BAAQMD condition #20010, part 21	Y		163 lb/ day	BAAQMD condition #20010, part 23c	C	CEM	X	
CO	BAAQMD condition #20010, part 21	Y		21.5 tons per year	BAAQMD condition #20010, part 23c	C	CEM	X	
CO ₂		Y		None	40 CFR 75.10	C	CEM (CO ₂) or CEM (O ₂) or fuel flow monitor	X	
SO ₂	BAAQMD 9-1-301	Y		GLC ₁ of 0.5 ppm for 3 min or 0.25 ppm for 60 min or 0.05 ppm for 24 hours		N		X	
SO ₂	SIP 9-1-301	Y		GLC ₁ of 0.5 ppm for 3 min or 0.25 ppm for 60 min or 0.05 ppm for 24 hours		N		X	
SO ₂	BAAQMD 9-1-302	Y		300 ppm (dry)	BAAQMD condition #20010, part 23e	P/Q	Fuel Gas Total sulfur content analysis	X	
SO ₂	SIP 9-1-302	Y		300 ppm (dry)	BAAQMD condition #20010, part 23e	P/Q	Fuel Gas Total sulfur content analysis	X	
SO ₂	NSPS 40 CFR 60.333(a)	Y		0.015% (vol.) @ 15% O ₂ (dry)	NSPS 40 CFR 60.334(h)(3), 40 CFR 75.11, 40 CFR 75, Appendix D, part 2.3, and BAAQMD Condition 20010, Part 23e	P/Q	Fuel Gas Total sulfur content analysis, Fuel measurements, calculations	X	
SO ₂	None	Y		None	40 CFR 75.11, 40 CFR 75, Appendix D, part 2.3		Fuel measurements, calculations	X	

Facility Name: Riverview Energy Center
 Permit for Facility #: B4512

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance	
								Yes	No
SO2	BAAQMD condition #20010, part 18(f)	Y		1.38 lb/hr	BAAQMD condition #20010, part 23e	P/Q	Fuel gas Total sulfur content analysis	X	
SO2	BAAQMD condition #20010, part 18(f)	Y		1.38 lb/hr	BAAQMD condition #20010, part 24f	P/Once every 8,000 operating hours or three years, whichever comes first	Source test	X	
SO2	BAAQMD condition #20010, part 21	Y		32 lb/ day	BAAQMD	P/Once every 8,000 operating hours or three years, whichever comes first	Source test	X	
					condition			X	
					#20010, part 24f			X	
SO2	BAAQMD condition #20010, part 21	Y		4.5 tons/year	BAAQMD	P/Once every 8,000 operating hours or three years, whichever comes first	Source test	X	
					condition			X	
					#20010, part 24f			X	
Opacity	BAAQMD 6-1-301	N		≥ Ringelmann No. 1 for no more than 3 minutes in any hour		N		X	
Opacity	SIP Regulation 6-301	Y		> Ringelmann No. 1 for no more than 3 minutes in any hour		N		X	
Opacity	BAAQMD condition #20010, part 18	Y		≥ Ringelmann No. 1 for no more than 3 minutes in any hour or equivalent 20% opacity		N		X	
FP	BAAQMD 6-1-310	N		0.15 grain/dscf		N		X	
FP	SIP Regulation 6-310	Y		0.15 grain/dscf		N		X	
PM10	BAAQMD condition #20010, part 18(e)	Y		3 lb/ hr	BAAQMD condition #20010, part 24e	P/Once every 8,000 operating hours or three years, whichever comes first	Source test	X	

Facility Name: Riverview Energy Center
Permit for Facility #: B4512

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance	
								Yes	No
PM10	BAAQMD condition #20010, part 21	Y		72 lb/day	BAAQMD condition #20010, parts 23d, 24e	P/Once every 8,000 operating hours or three years, whichever comes first	Source Test	X	
PM10	BAAQMD condition #20010, part 21	Y		9.8 tons/year	BAAQMD condition #20010, part 24e	P/Once every 8,000 operating hours or three years, whichever comes first	Source Test	X	
POC	BAAQMD condition #20010, part 18(d)	Y		2 ppmv @ 15% O ₂ , dry, 1-hr average except during turbine startup or shutdown	BAAQMD condition #20010, part 24d	P/Once every 8,000 operating hours or three years, whichever comes first	Source test	X	
POC	BAAQMD condition #20010, part 18(d)	Y		2 ppmv @ 15% O ₂ , dry, 1-hr average except during turbine startup or shutdown	BAAQMD condition #20010, part 24d	P/Once every 8,000 operating hours or three years, whichever comes first	Source test	X	
POC	BAAQMD condition #20010, part 21	Y		31 lb/calendar day	BAAQMD condition #20010, part 24d	P/Once every 8,000 operating hours or three years, whichever comes first	Source test	X	
POC	BAAQMD condition #20010, part 21	Y		4.1 ton/year	BAAQMD condition #20010, part 24d	P/Once every 8,000 operating hours or three years, whichever comes first	Source test	X	
NH3	BAAQMD condition #20010, Part 18(b)	N		10 ppmv @ 15% O ₂ , dry, averaged over 1 hr except during turbine startup or shutdown	BAAQMD condition #20010, parts 18.2 and 23b	C	District approved correct ammonia slip calculation and correction factor determined by source test	X	

Facility Name: Riverview Energy Center
 Permit for Facility #: B4512

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance	
								Yes	No
NH3	BAAQMD condition #20010, Part 18(b)	N		10 ppmv @ 15% O2, dry, averaged over 1 hr except during turbine startup or shutdown	BAAQMD condition #20010, part 24b	P/Once every 8,000 operating hours or three years, whichever comes first	Source test	X	
Heat input limit	BAAQMD condition #20010, part 22	Y		500 MM BTU/hr (HHV)	BAAQMD condition #20010, part 23d	C	Fuel meter, firing monitor	X	
Heat input limit	BAAQMD condition #20010, part 22	Y		500 MM BTU/hr (HHV)	BAAQMD condition #20010, part 23d	P/Q	Fuel composition analysis	X	
Heat input limit	BAAQMD condition #20010, part 22	Y		500 MM BTU/hr (HHV)	BAAQMD condition #20010, part 24g	P/Once every 8,000 operating hours or three years, whichever comes first	Source test	X	
Heat input limit	BAAQMD condition #20010, part 22	Y		12,000 MM BTU/day (HHV)	BAAQMD condition #20010, part 23d	C	fuel meter, firing monitor, calculations	X	
Heat input limit	BAAQMD condition #20010, part 22	Y		12,000 MM BTU/day (HHV)	BAAQMD condition #20010, part 23d	P/Q	Fuel composition analysis	X	
Heat input limit	BAAQMD condition #20010, part 22	Y		3,250,000 MM BTU/yr (HHV)	BAAQMD condition #20010, part 23d	C	fuel meter, firing monitor, calculations	X	
Heat input limit	BAAQMD condition #20010, part 22	Y		3,250,000 MM BTU/yr (HHV)	BAAQMD condition #20010, part 31g	P/Q	Fuel composition analysis	X	
MW				None	BAAQMD condition #20010, part 24h	P/Once every 8,000 operating hours or three years, whichever comes first	Source test	X	
Exhaust Gas temperature				None	BAAQMD condition #20010, part 24j	P/Once every 8,000 operating hours or three years, whichever comes first	Source test	X	

Facility Name: Riverview Energy Center
Permit for Facility #: B4512

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance	
								Yes	No
Stack gas flow rate				None	BAAQMD condition #20010, part 24i	P/Once every 8,000 operating hours or three years, whichever comes first	Source test	X	
NH3 injection rate				None	BAAQMD condition #20010, part 24k	P/Once every 8,000 operating hours or three years, whichever comes first	Source test	X	
Start-up Period	BAAQMD condition #20010, part 19			60 minutes per start-up	BAAQMD condition #20010, part 29(b)	P/E	Records	X	
Shutdown Period	BAAQMD condition #20010, part 20			30 minutes per shutdown	BAAQMD condition #20010, part 29(b)	P/E	Records	X	
Fuel Sulfur Content	40 CFR 60.333(b)	Y		0.8 percent by weight (8000 ppmw) sulfur	40 CFR 60.334(h)(1)	P	Fuel Sulfur Content Testing	X	

Table VII - B
Applicable Limits and Compliance Monitoring Requirements
S-2 – COOLING TOWER

Type of Limit	Citation of Limit	FE Y/N	Future Effective Date	Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type	Compliance	
								Yes	No
Opacity	BAAQMD Regulation 6-1-301	N		≥ Ringelmann 1 for no more than 3 min/hr		N		X	
Opacity	SIP Regulation 6-301	Y		> Ringelmann 1 for no more than 3 min/hr		N		X	
Particulate Weight	BAAQMD Regulation 6-1-310	N		0.15 grains per dscf		N		X	
Particulate Weight	SIP Regulation 6-310	Y		0.15 grains per dscf		N		X	
Particulate Weight	BAAQMD Regulation 6-1-311	Y		40 lb/hr	N	N		X	
Particulate Weight	SIP Regulation 6-311	Y		40 lb/hr	N	N		X	

Via FedEx

October 12, 2021

Director, Enforcement and Compliance Division
Bay Area Air Quality Management District, Suite 600
375 Beale Street
San Francisco, CA 94105-2066
Attn: Jeff Gove
jgove@baaqmd.gov

Director, Air Division (Attn: AIR-5)
U.S. Environmental Protection Agency
75 Hawthorne St.
San Francisco, CA 94105
R9.aeo@epa.gov

BAAQMD Compliance and Enforcement Division, MAILSTOP: RCA 30-DAY REPOT
375 Beale Street, Suite 600
San Francisco, CA 94105

**RE: Gilroy Energy Center, LLC for the Riverview Energy Center, Permit No. B4512
Breakdown 30 Day Follow-Up Report (RCA # 08B71)
Title V – 30 Day Deviation Follow-Up Report (RCA # 08B72)**

Dear Mr. Gove,

In accordance with the Major Facility Review Permit (Title V Permit) for Gilroy Energy Center, LLC for Riverview Energy Center (the “Facility”), this letter is intended to satisfy the 30-day follow-up reporting requirement as required by Section I.F. of the Title V Permit, which requires the reporting of all non-compliance instances of the Title V Permit in writing within 30 days of discovery of the incident and the written breakdown report as required by BAAQMD Rule 1-432. The required Title V 10-day initial notification was submitted to the District on September 22, 2021.

On September 11th, the Facility experienced breakdown of the water injection system which resulted in an exceedance of the Facility’s NO_x daily mass emission limit of 121 pounds, as stated in BAAQMD Condition #20010, part 21. The breakdown also caused an exceedance of the Facility’s 40 CFR 60.334(a)(1) and (b) 4-hour rolling NO_x emission limit of 75 ppm NO_x corrected to 15% O₂, as stated in Table VII-A of the Title V permit.

Based on the information presented herein, the Facility believes this event qualifies as an equipment breakdown as defined in BAAQMD Rule 1-208.

Event Description

At approximately 17:00, DAS time, the Facility, as well as six additional facilities operated from the same control room, were dispatched to meet the immediate demand of providing energy to the CAISO.

- At 17:20, the Control Room Operator (CRO) initiated startup of the unit.
- At 17:29, the CRO initiated automatic generation control (AGC) and allowed the unit to automatically increase its load.
- At 17:38, ammonia injection and the Facility's secondary abatement system, Selective Catalytic Reduction (SCR), began without issue. The NO_x inlet concentration was measured to be 166.3 ppm.
- By 17:59, the CRO determined that the unit would not come into compliance with its emission limits and initiated shutdown. The unit never exited startup.
- At 18:07, the unit's shutdown completed.
 - The unit operated for 47-minutes over two clock hours and emitted 126.5 pounds of NO_x, exceeding its daily mass emissions limit (Attachment A – Hourly Emissions Report).

Following the shutdown of the unit, the CRO dispatched an ICE technician to the Facility to troubleshoot the system. The ICE technician visually inspected the system and requested to watch the startup of the unit.

- At 20:31, the CRO initiated startup of the unit for a test run.
- At 20:44, ammonia flow initiated and the Facility's secondary abatement system, Selective Catalytic Reduction (SCR), began without issue. The NO_x inlet concentration was measured to be 20.3 ppm.
- At 20:53, the CRO and ICE technician determined that the NO_x concentration values were normal and within range. The ICE technician did not observe any abnormalities (Attachment B – ICE Technician Turnover) at the Facility so the CRO initiated shutdown of the unit.
- At 21:02, the unit's shutdown completed.
 - The unit operated for 31-minutes over 2 clock hours and emitted 8.1 pounds of NO_x. This run caused the Facility to exceed its 4-hour rolling NO_x emission limit of 75 ppm NO_x corrected to 15% O₂.

Corrective Actions

To prevent further mass emissions, the unit was shut down.

A technician was dispatched to the site immediately to visually inspect the NO_x water injection system. The technician observed a test run of the unit and could not determine the cause of the run's high NO_x emissions.

Compliance Status

The Facility was in full compliance with its air permit as of 00:00 on September 12th, 2021 and remains in full compliance.

Investigation and Cause Determination

Further investigation of the NO_x control system determined that the primary cause of the excess was a breakdown of the NO_x water drain valve. When the valve, an Atkomatic Solenoid Valve, is operating properly, it automatically opens at the end of a run to drain extra water from the system. Once the system is empty, it will close. The Atkomatic Solenoid Valve is known to unthread itself over time, fail open, and drain the system of water meant to abate NO_x emissions.

A deconstructed Atkomatic Solenoid Valve is shown in Attachment C – Atkomatic Solenoid Valve #6210. The plunger is located inside the valve casing. When the valve is assembled and installed, it is impossible to visually determine a breakdown has occurred.

Preventative Actions

Following the breakdown event on September 11th, the Atkomatic Solenoid valve was removed from service and a new one was installed (Attachment D – Maintenance Records).

The Facility acknowledges that this valve will fail without proper maintenance and has a preventative maintenance schedule. The valve was completely replaced in November 2020 and inspected in April 2021. No deficiencies were noted during the April 2021 inspection.

The Facility also reorganized its start-up checklist. In the past, CROs were instructed to initiate AGC before the unit came into compliance. The start-up checklist has been revised so that the unit will no longer be automatically ramped up to full load before the unit reaches compliance.

The Facility believes this event qualifies for Breakdown Relief pursuant to BAAQMD Regulation 1-208. As described above, this event:

- Is not the result of intent, neglect or disregard of BAAQMD regulations;
 - The facility has followed BAAQMD regulations and performs maintenance on the valve annually. The last maintenance activity was performed in April 2021.
- Is not the result of improper maintenance;
 - As demonstrated above, the facility has a robust maintenance program.
- Did not constitute a nuisance;
 - The facility took immediate action to correct the situation, shut down the equipment, and dispatched a maintenance technician to inspect the equipment.
- There has not be excessively recurrent breakdowns of this equipment.
 - There have been no recent instances of this equipment causing non-compliance at this Facility.

If you have any questions or require additional information, please contact Morgan Zellers, EHS Specialist, at 707-399-4395.

As a Responsible Official, I certify that based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate and complete.

Sincerely,



Andrew Gundershaug
Plant General Manager
Gilroy Energy Center, LLC for Riverview Energy Center

Cc:	McKenzie Bell	BAAQMD	via email attachment
	Jessica Grossman	Sr. Counsel, Calpine	via email attachment
	David Williams	EHS Manager, Calpine	via email attachment
	Chris Cullison	EHS Manager, Calpine	via email attachment

Attachments:

- Attachment A – Hourly Emissions Report
- Attachment B – ICE Technician Turnover
- Attachment C – Atkomatic Solenoid valve #6210
- Attachment D – Maintenance Record

Attachment A – Hourly Emissions Reports

Hours 17-18, 20-21

Solano Peakers
Solano Peakers
Riverview- Hourly Emissions Report
September 11, 2021 - Hour 17

1-Hr Emission Limits
NH3 ppm @15% O2 - 10

3-Hr Rolling Emission Limits
NOx ppm @15% O2 - 2.5 CO ppm @15% O2 - 6

Minute	O2%	NOx ppm	NOx ppm @15% O2	NOx lb/mmBtu	NOx lb/hr	CO ppm	CO ppm @15% O2	CO lb/mmBtu	CO lb/hr	NH3 ppm @15% O2	Inlet NOx ppm	Process Status
00	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
01	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
02	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
03	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
04	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
05	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
06	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
07	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
08	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
09	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
10	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
11	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
12	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
13	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
14	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
15	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
16	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
17	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
18	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
19	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
20	19.80	3.12	9.69	0.03561	4.11	47.52	147.56	0.33018	38.1	Down	8.5	Startup
21	17.83	20.97	40.30	0.14814	16.37	7.23	13.89	0.03109	3.4	Down	37.5	Startup
22	17.77	32.37	61.02	0.22430	29.97	3.54	6.67	0.01493	2.0	Down	41.2	Startup
23	17.36	46.63	77.72	0.28568	61.60	2.58	4.30	0.00962	2.1	Down	51.2	Startup
24	16.59	55.48	75.95	0.27918	73.58	2.08	2.85	0.00637	1.7	Down	64.9	Startup
25	16.31	76.63	98.50	0.36208	95.21	1.80	2.31	0.00518	1.4	Down	85.1	Startup
26	16.33	78.66	101.55	0.37330	97.77	1.59	2.05	0.00459	1.2	Down	86.5	Startup
27	16.33	78.12	100.86	0.37074	97.29	1.46	1.88	0.00422	1.1	Down	86.4	Startup
28	16.33	78.41	101.23	0.37212	97.62	1.39	1.79	0.00402	1.1	Down	86.6	Startup
29	16.33	78.92	101.89	0.37454	95.36	1.34	1.73	0.00387	1.0	Down	86.8	Startup
30	16.44	75.25	99.55	0.36593	91.03	1.29	1.71	0.00382	1.0	Down	82.0	Startup
31	16.46	74.36	98.81	0.36323	90.21	1.27	1.69	0.00378	0.9	Down	81.2	Startup

Minute	O2%	NOx ppm	NOx ppm @15% O2	NOx lb/mmBtu	NOx lb/hr	CO ppm	CO ppm @15% O2	CO lb/mmBtu	CO lb/hr	NH3 ppm @15% O2	Inlet NOx ppm	Process Status
32	16.47	74.05	98.62	0.36253	92.98	1.27	1.69	0.00378	1.0	Down	80.7	Startup
33	16.30	82.41	105.70	0.38855	116.06	1.26	1.62	0.00362	1.1	Down	89.6	Startup
34	15.91	109.39	129.34	0.47544	161.19	1.31	1.55	0.00347	1.2	Down	117.7	Startup
35	15.63	139.04	155.66	0.57220	215.82	1.38	1.54	0.00346	1.3	Down	148.8	Startup
36	15.39	167.38	179.23	0.65883	264.56	1.45	1.55	0.00347	1.4	Down	177.0	Startup
37	15.49	174.24	190.02	0.69851	283.26	1.50	1.64	0.00366	1.5	Down	184.4	Startup
38	16.01	151.48	182.77	0.67184	275.53	1.50	1.81	0.00405	1.7	0.00	166.3	Startup
39	16.17	138.46	172.71	0.63487	264.33	1.48	1.85	0.00413	1.7	0.00	151.7	Shutdown
40	16.16	134.60	167.54	0.61587	255.59	1.48	1.84	0.00412	1.7	0.43	146.4	Shutdown
41	16.20	133.02	166.98	0.61382	254.35	1.50	1.88	0.00421	1.7	0.52	144.7	Shutdown
42	16.19	133.23	166.89	0.61348	254.53	1.50	1.88	0.00420	1.7	0.61	144.8	Shutdown
43	16.19	133.70	167.48	0.61565	255.95	1.51	1.89	0.00423	1.8	0.64	145.3	Shutdown
44	16.18	134.37	167.96	0.61742	257.33	1.50	1.88	0.00420	1.8	2.48	146.1	Shutdown
45	16.17	130.15	162.34	0.59677	249.53	1.49	1.86	0.00416	1.7	4.94	147.1	Shutdown
46	16.17	124.43	155.21	0.57054	237.67	1.50	1.87	0.00419	1.7	1.30	148.2	Shutdown
47	16.18	122.97	153.71	0.56504	235.26	1.52	1.90	0.00425	1.8	0.87	147.4	Shutdown
48	16.19	123.15	154.26	0.56707	236.40	1.50	1.88	0.00420	1.8	0.54	147.7	Shutdown
49	16.19	122.90	153.95	0.56592	235.86	1.50	1.88	0.00420	1.8	0.41	147.8	Shutdown
50	16.19	122.66	153.65	0.56481	235.46	1.50	1.88	0.00420	1.8	0.21	147.9	Shutdown
51	16.19	122.54	153.50	0.56426	235.11	1.49	1.87	0.00418	1.7	0.00	148.0	Shutdown
52	16.19	122.33	153.24	0.56329	234.59	1.49	1.87	0.00418	1.7	0.00	148.2	Shutdown
53	16.19	122.14	153.00	0.56242	234.46	1.50	1.88	0.00420	1.8	0.00	148.1	Shutdown
54	16.18	122.11	152.64	0.56109	233.97	1.50	1.88	0.00420	1.8	0.00	148.2	Shutdown
55	16.18	121.82	152.28	0.55976	233.53	1.50	1.88	0.00420	1.8	0.00	148.1	Shutdown
56	16.18	122.25	152.81	0.56173	234.47	1.52	1.90	0.00425	1.8	0.00	148.2	Shutdown
57	16.18	122.20	152.75	0.56150	234.43	1.53	1.91	0.00428	1.8	0.00	148.6	Shutdown
58	16.19	122.40	153.32	0.56362	235.14	1.51	1.89	0.00423	1.8	0.00	148.6	Shutdown
59	16.18	122.91	153.64	0.56476	232.79	1.52	1.90	0.00425	1.8	0.00	148.8	Shutdown
Average Total 3-Hr RIng	16.4	106.3	139.4	0.51232	177.7 119.1	2.9	3.8	0.00851	3.0 2.0	4.97	121.6	Startup

Solano Peakers

Solano Peakers
Riverview- Hourly Emissions Report
September 11, 2021 - Hour 18

1-Hr Emission Limits	3-Hr Rolling Emission Limits
NH3 ppm @15% O2 - 10	NOx ppm @15% O2 - 2.5 CO ppm @15% O2 - 6

Minute	O2%	NOx ppm	NOx ppm @15% O2	NOx lb/mmBtu	NOx lb/hr	CO ppm	CO ppm @15% O2	CO lb/mmBtu	CO lb/hr	NH3 ppm @15% O2	Inlet NOx ppm	Process Status
00	16.31	114.65	147.37	0.54173	190.21	1.51	1.94	0.00434	1.5	0.81	142.0	Shutdown
01	16.81	88.03	126.99	0.46680	122.11	1.43	2.06	0.00462	1.2	0.09	118.4	Shutdown
02	17.62	37.63	67.69	0.24882	42.58	1.25	2.25	0.00503	0.9	0.00	70.0	Shutdown
03	18.36	13.80	32.06	0.11783	13.31	1.08	2.51	0.00561	0.6	Down	43.8	Shutdown
04	18.80	19.20	53.94	0.19829	21.84	1.05	2.95	0.00660	0.7	Down	33.5	Shutdown
05	18.75	30.27	83.07	0.30535	33.32	1.07	2.94	0.00657	0.7	Down	33.4	Shutdown
06	18.42	35.41	84.24	0.30967	33.92	1.09	2.59	0.00580	0.6	Down	37.9	Shutdown
07	17.90	42.27	83.13	0.30559	33.41	1.09	2.14	0.00480	0.5	Down	45.6	Shutdown
08	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Shutdown
09	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
10	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
11	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
12	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
13	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
14	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
15	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
16	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
17	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
18	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
19	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
20	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
21	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
22	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
23	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
24	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
25	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
26	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
27	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
28	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
29	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
30	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
31	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down

Minute	O2%	NOx ppm	NOx ppm @15% O2	NOx lb/mmBtu	NOx lb/hr	CO ppm	CO ppm @15% O2	CO lb/mmBtu	CO lb/hr	NH3 ppm @15% O2	Inlet NOx ppm	Process Status
32	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
33	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
34	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
35	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
36	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
37	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
38	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
39	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
40	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
41	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
42	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
43	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
44	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
45	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
46	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
47	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
48	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
49	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
50	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
51	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
52	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
53	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
54	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
55	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
56	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
57	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
58	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
59	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
Average Total 3-Hr Ring	17.9	47.7	93.8 0.0	0.34484	57.5 7.5	1.2	2.4 0.0	0.00528	0.9 0.1	7.03	65.6	Shutdown

Solano Peakers

Solano Peakers
Riverview- Hourly Emissions Report
 September 11, 2021 - Hour 20

1-Hr Emission Limits
 NH3 ppm @15% O2 - 10

3-Hr Rolling Emission Limits
 NOx ppm @15% O2 - 2.5 CO ppm @15% O2 - 6

Minute	O2%	NOx ppm	NOx ppm @15% O2	NOx lb/mmBtu	NOx lb/hr	CO ppm	CO ppm @15% O2	CO lb/mmBtu	CO lb/hr	NH3 ppm @15% O2	Inlet NOx ppm	Process Status
00	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
01	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
02	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
03	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
04	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
05	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
06	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
07	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
08	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
09	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
10	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
11	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
12	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
13	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
14	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
15	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
16	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
17	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
18	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
19	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
20	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
21	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
22	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
23	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
24	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
25	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
26	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
27	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
28	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
29	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
30	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
31	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Startup

Minute	O2%	NOx ppm	NOx ppm @15% O2	NOx lb/mmBtu	NOx lb/hr	CO ppm	CO ppm @15% O2	CO lb/mmBtu	CO lb/hr	NH3 ppm @15% O2	Inlet NOx ppm	Process Status
32	19.03	7.26	22.54	0.08287	9.23	20.43	63.44	0.14195	15.8	Down	19.7	Startup
33	17.84	25.41	48.99	0.18010	20.78	4.48	8.64	0.01933	2.2	Down	39.4	Startup
34	17.70	39.82	73.42	0.26988	45.06	2.82	5.20	0.01163	1.9	Down	42.7	Startup
35	16.97	55.02	82.60	0.30363	77.34	2.16	3.24	0.00726	1.8	Down	51.2	Startup
36	16.15	20.49	25.45	0.09356	25.66	2.24	2.78	0.00623	1.7	Down	20.1	Shutdown
37	16.06	20.43	24.90	0.09155	25.10	2.30	2.80	0.00627	1.7	Down	20.2	Shutdown
38	16.06	20.25	24.68	0.09074	24.81	2.26	2.75	0.00616	1.7	Down	20.1	Shutdown
39	16.07	20.10	24.55	0.09025	24.73	2.22	2.71	0.00607	1.7	Down	20.2	Shutdown
40	16.08	20.04	24.53	0.09017	24.61	2.16	2.64	0.00592	1.6	Down	20.2	Shutdown
41	16.09	19.90	24.41	0.08973	24.57	2.11	2.59	0.00579	1.6	Down	20.2	Shutdown
42	16.09	19.90	24.41	0.08973	24.54	2.08	2.55	0.00571	1.6	Down	20.3	Shutdown
43	16.09	19.90	24.41	0.08973	24.54	2.06	2.53	0.00565	1.5	Down	20.3	Shutdown
44	16.10	18.22	22.40	0.08232	22.57	2.03	2.50	0.00558	1.5	9.35	20.3	Shutdown
45	16.09	5.40	6.62	0.02435	6.69	2.01	2.47	0.00552	1.5	4.86	20.4	Shutdown
46	16.10	2.34	2.88	0.01057	2.89	2.01	2.47	0.00553	1.5	4.55	20.4	Shutdown
47	16.10	1.11	1.36	0.00502	1.37	1.99	2.45	0.00547	1.5	0.63	20.4	Shutdown
48	16.10	1.28	1.57	0.00578	1.58	1.94	2.38	0.00534	1.5	0.00	20.3	Shutdown
49	16.09	1.72	2.11	0.00776	2.12	1.91	2.34	0.00524	1.4	1.77	20.3	Shutdown
50	16.08	1.58	1.93	0.00711	1.94	1.90	2.33	0.00520	1.4	1.55	20.3	Shutdown
51	16.08	1.31	1.60	0.00589	1.61	1.91	2.34	0.00523	1.4	0.00	20.3	Shutdown
52	16.14	2.03	2.52	0.00925	2.54	1.91	2.37	0.00530	1.5	3.78	20.2	Shutdown
53	16.46	1.09	1.45	0.00532	1.45	1.91	2.54	0.00568	1.6	0.16	19.1	Shutdown
54	16.67	0.98	1.37	0.00502	1.38	1.95	2.72	0.00609	1.7	0.00	18.1	Shutdown
55	16.77	1.72	2.46	0.00903	2.48	1.96	2.80	0.00627	1.7	0.94	17.6	Shutdown
56	16.80	1.23	1.77	0.00651	1.65	1.97	2.83	0.00634	1.6	2.60	17.4	Shutdown
57	17.16	0.55	0.87	0.00319	0.55	2.00	3.16	0.00706	1.2	0.00	15.1	Shutdown
58	17.79	0.78	1.48	0.00544	0.61	1.91	3.62	0.00811	0.9	Down	18.4	Shutdown
59	18.01	10.13	20.68	0.07602	8.21	1.32	2.69	0.00603	0.7	Down	38.1	Shutdown
Average Total 3-Hr RIng	16.6	12.1	16.6	0.06103	14.8	2.8	3.8	0.00860	2.1	5.10	22.9	Startup
			0.0		7.0		0.0		1.0			

Solano Peakers
Solano Peakers
Riverview- Hourly Emissions Report
September 11, 2021 - Hour 21

1-Hr Emission Limits	3-Hr Rolling Emission Limits
NH3 ppm @15% O2 - 10	NOx ppm @15% O2 - 2.5 CO ppm @15% O2 - 6

Minute	O2%	NOx ppm	NOx ppm @15% O2	NOx lb/mmBtu	NOx lb/hr	CO ppm	CO ppm @15% O2	CO lb/mmBtu	CO lb/hr	NH3 ppm @15% O2	Inlet NOx ppm	Process Status
00	17.81	22.00	42.01	0.15441	16.80	1.20	2.29	0.00513	0.6	Down	41.0	Shutdown
01	17.81	27.79	53.06	0.19505	21.04	1.15	2.20	0.00491	0.5	Down	41.0	Shutdown
02	17.81	34.19	65.28	0.23997	26.04	1.11	2.12	0.00474	0.5	Down	41.1	Shutdown
03	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Shutdown
04	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Shutdown
05	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Shutdown
06	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Shutdown
07	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Shutdown
08	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Shutdown
09	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Shutdown
10	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Shutdown
11	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Shutdown
12	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Shutdown
13	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Shutdown
14	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Shutdown
15	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Shutdown
16	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Shutdown
17	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Shutdown
18	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Shutdown
19	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Shutdown
20	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Shutdown
21	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Shutdown
22	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Shutdown
23	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Shutdown
24	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Shutdown
25	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Shutdown
26	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Shutdown
27	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Shutdown
28	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Shutdown
29	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Shutdown
30	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Shutdown
31	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down

Minute	O2%	NOx ppm	NOx ppm @15% O2	NOx lb/mmBtu	NOx lb/hr	CO ppm	CO ppm @15% O2	CO lb/mmBtu	CO lb/hr	NH3 ppm @15% O2	Inlet NOx ppm	Process Status
32	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
33	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
34	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
35	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
36	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
37	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
38	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
39	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
40	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
41	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
42	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
43	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
44	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
45	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
46	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
47	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
48	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
49	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
50	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
51	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
52	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
53	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
54	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
55	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
56	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
57	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
58	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
59	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
Average Total 3-Hr Rlng	17.8	28.0	53.3 0.0	0.19589	21.2 1.1	1.2	2.3 0.0	0.00511	0.6 0.0	Down	41.0	Shutdown

Attachment B – ICE Technician Turnover

From: [Melvin Timtim](#)
To: [NorCal Peakers Projects](#)
Subject: 9/11/2021
Date: Saturday, September 11, 2021 11:19:27 PM

-At Riverview, visually checked turbine compartment/CEMS/MCC's/pumps most especially related to NOx water injection system for any abnormalities. Observed unit running normally as per test run.

Melvin Timtim

ICE Tech
Calpine Corp

Attachment C – Atkomatic Solenoid valve #6210

Attachment C – Aktomatic Solenoid Valve #6210




Figure 1: 6210 valve location within the NOx water injection system.



Figure 2: Fully assembled 6210 valve. The plunger that is known to unthread itself is located within the valve body circled in red.



Figure 3: Deconstructed Aktomatic Solenoid Valve. The plunger, circled in red, periodically unthreads from the plunger housing, circled in blue. During annual preventative maintenance, the mechanic applies sealant to the plunger's threads.

Attachment D – Maintenance Records

Preventative Maintenance Task

Valve inspection and replacement work orders generated 2018 – 2021.



PM	Description	Location	Asset	PMEQ1	Estimated Next Due Date	Plant Condition	Work Group	Status	Program Category	Task Category
105249	RP-1Y INSPECT/REBUILD SOV-6210 AND SOV-62002 VALVES	RP-01-01-CTG		RP	3/15/22	OUTAGE	WS-MECH	ACTIVE	MAINTENANCE	

Number of Records: 1

Saved Query:

Dynamic Query: (pm.pmoid = 250514)



Work Order Details

26240032: RP-3Y Replace Drain Valve SOV-6210 in CTG Package

Asset:

Location: RP-01-01-CTG CTG COMBUSTION TURBINE AND GENERATOR SYSTEMS

CI:

Sched Start:	4/26/18	Site:	WS	Job Plan:	26482
Sched Finish:		Priority:	3	Supervisor:	
Target Start:	4/26/18	Work Type:	PM	Lead:	TW13380
Target Finish:		Status:	CLOSE	Vendor:	
Actual Start:	4/26/18	Parent:		Owner:	
Actual Finish:	4/26/18	Failure Class:		Owner Group:	
Report Date:	2/3/18	Problem Code:		Service:	
Reported By:	GWHITBECK			Service Group:	
		GL Account:	50300-623000-9020605-2901-S10030-OM0000	Classification:	

Task IDs						
Task ID	Description	Status	Measurement Point	Value	Date	Observations
5	Refer to attachments for specific information on this workorder	CLOSE		0		
10	LOTO Gas Turbine Package, Demin Water supply and Fuel supply	CLOSE		0		
20	Remove and replace entire SOV-6210 valve assembly with a new valve	CLOSE		0		
30	Return systems to normal line up	CLOSE		0		
40	Test valve for proper operation during next available run	CLOSE		0		
50	Dispose of old valve assembly	CLOSE		0		

Actual Materials						
Task ID	Item	Description	Storeroom	Qty	Unit Cost	Line Cost
	688204	VALVE,SOLENOID, 3/4 IN PIPE, NC, SS BDY, 8-11/16 IN X 4-5/8 IN	WS-MAIN	1	2004.94	2004.94
Total Actual Materials:						2004.94



Work Order Details

28782348: RP-1Y INSPECT/REBUILD SOV-6210 AND SOV-62002 VALVES

Asset:

Location: RP-01-01-CTG CTG COMBUSTION TURBINE AND GENERATOR SYSTEMS

CI:

Sched Start:	11/9/20
Sched Finish:	11/10/20
Target Start:	11/9/20
Target Finish:	11/9/20
Actual Start:	11/9/20
Actual Finish:	11/9/20
Report Date:	8/26/20
Reported By:	JW13332

Site:	WS
Priority:	3
Work Type:	PM
Status:	CLOSE
Parent:	
Failure Class:	
Problem Code:	
GL Account:	50300-623000-9020605-2901-S10030-OM0000

Job Plan:	26482
Supervisor:	O&M MGR
Lead:	JG13462
Vendor:	
Owner:	
Owner Group:	
Service:	
Service Group:	
Classification:	

Task IDs						
Task ID	Description	Status	Measurement Point	Value	Date	Observations
5	Refer to attachments for specific information on this workorder	CLOSE		0		
10	LOTO Gas Turbine Package, Demin Water supply and Fuel supply	CLOSE		0		
20	Remove and replace entire SOV-6210 valve assembly with a new valve	CLOSE		0		
30	Return systems to normal line up	CLOSE		0		
40	Test valve for proper operation during next available run	CLOSE		0		
50	Dispose of old valve assembly	CLOSE		0		

Log						
Date	Class	Created By	Subject	Description	Long Description	
11/9/20	WORKORDER	JG13462		Complete		



Work Order Details

29219427: RP-1Y INSPECT/REBUILD SOV-6210 AND SOV-62002 VALVES

Asset:

Location: RP-01-01-CTG CTG COMBUSTION TURBINE AND GENERATOR SYSTEMS

CI:

Sched Start:	4/15/21	Site:	WS	Job Plan:	26482
Sched Finish:	4/15/21	Priority:	3	Supervisor:	O&M MGR
Target Start:	4/22/21	Work Type:	PM	Lead:	JG13462
Target Finish:	4/22/21	Status:	CLOSE	Vendor:	
Actual Start:	4/14/21	Parent:		Owner:	
Actual Finish:	4/14/21	Failure Class:		Owner Group:	
Report Date:	2/1/21	Problem Code:		Service:	
Reported By:	JW13332			Service Group:	
		GL Account:	50300-623000-9020605-2901-S10030-OM0000	Classification:	

Task IDs						
Task ID	Description	Status	Measurement Point	Value	Date	Observations
5	Refer to attachments for specific information on this workorder	CLOSE		0		
10	LOTO Gas Turbine Package, Demin Water supply and Fuel supply	CLOSE		0		
20	Remove and replace entire SOV-6210 valve assembly with a new valve	CLOSE		0		
30	Return systems to normal line up	CLOSE		0		
40	Test valve for proper operation during next available run	CLOSE		0		
50	Dispose of old valve assembly	CLOSE		0		

Log						
Date	Class	Created By	Subject	Description	Long Description	
4/14/21	WORKORDER	BUCHANANM		inspected no defects noted		



Work Order Details

29799840: Rp-Troubleshoot and repair nox excursion, 62002, 6210

Asset:

Location: RP-01-01-CTG CTG COMBUSTION TURBINE AND GENERATOR SYSTEMS

CI:

Sched Start:	9/13/21	Site:	WS	Job Plan:	
Sched Finish:		Priority:	4	Supervisor:	
Target Start:		Work Type:	CM	Lead:	JG13462
Target Finish:		Status:	COMP	Vendor:	
Actual Start:	9/15/21	Parent:		Owner:	
Actual Finish:	9/15/21	Failure Class:		Owner Group:	
Report Date:	9/13/21	Problem Code:		Service:	
Reported By:	BUCHANANM			Service Group:	
		GL Account:	50300-623000-9020605-2901-S10030-OM0000	Classification:	

Actual Materials						
Task ID	Item	Description	Storeroom	Qty	Unit Cost	Line Cost
	678441	COIL,ELECTRICAL, GT ATKOMATIC SOLENOID VALVE, 24 VDC	WS-MAIN	1	2101.68	2101.68
Total Actual Materials:						2101.68

Related Records				
Ticket	Description	Class	Status	Relationship
INV101237	Unit NOx #/day exceedance	PROBLEM	WEHS	RELATED

Log						
Date	Class	Created By	Subject	Description	Long Description	
9/15/21	WORKORDER	BUCHANANM		removed and replaced the 6210 valve		
9/13/21	Work Order # 29799840	BUCHANANM		E-mail generated from Work Order # 29799840	Priority 4 Location RP-01-01-CTG Asset # Description Rp-Troubleshoot and repair nox excursion, 62002, 6210	

[Click here to open Work Order](#)



Work Order Details

29799840: Rp-Troubleshoot and repair nox excursion, 62002, 6210

Log						
Date	Class	Created By	Subject	Description	Long Description	